

9. Evaluation

Type	Energy		Free travel <u>OA</u>	Further travel during which energy must be delivered <u>AB</u>	Actual travel			Minimum travel force			
	Actual value	Specified value			Actual value	Specified value		Actual value	Specified value		
						Min. <u>OB</u>	Max. <u>OC</u>				
Medium	0,83	1±0,5	4	16	30	20	40	35,6	20		


- I.: Measured duration of travel < maximum duration of travel (100ms)
- II. striker energy is Medium 1J ±0,5 J
- III. Verification of the withstand force proofed that the striker has the necessary force.

The striker full fills all Requirements of striker Type medium according to:  
IEC 60282-1 2002-01; VDE 0670 Teil 4 Abs. 12 02/98

370 / 65

2004-03-29

*L. Sandtke*  
Test engineer



*A. Tisch*  
Head of Laboratory

(  
C

(  
C

## 1. Object

Current-limiting high-voltage fuse-links

Class: Back-up

Striker: "medium"

Type: HH-SI 10/24kV 80A / 100A FC TB ÜLA 442/65 / 442/78

Ident-No.: 67240.0809 / 67240.1009

Rated voltage	10/24 kV	
Rated current	80 A	100 A
Rated maximum breaking current	63 kA	
Rated frequency	50 Hz	
Rated minimum breaking current	310 A	430 A

## 2. Reason for test

Type test according to IEC 60282-1 (VDE 0670 Teil 4): 1998-02

## 3. Tests performed

### 3.1 Temperature-rise tests and power-dissipation measurement

Rated current	80 A	100 A
Test laboratory	EFEN Prüflabor Eltville	
Test result: $\Delta\theta_{max}$ <sup>1)</sup>	67,4 K <sup>2)</sup>	91,8 K <sup>3)</sup>
Test result: $P_a$	at 50% $I_a$	38,4 W
	at 100% $I_R$	233,6 W
EFEN Lab-No.	01153	01154
Test passed	Yes	Yes

<sup>1)</sup> permissible temperature rise: 65 K

<sup>2)</sup> derating factor: 0,98

<sup>3)</sup> derating factor: 0,84

### 3.2 Breaking Test: Test Duty 1

Rated current	80 A	100 A
Test Laboratory / Document No	KEMA / 720-00	KEMA 731-98
Test circuit applied voltage: U	21,0 kV	21,2 kV
Test circuit prospective current I	63,2 kA	64,0 kA
EFEN Lab-No.	01072	99099
Test passed	Yes	Yes

3.3 Breaking Test: Test Duty 2

Rated current	80 A	100 A
Test Laboratory / Document No.	FGH / LV 00048 1E	FGH LV 00049 1E
Test circuit applied voltage U	21,06 kV	20,95 kV
Test circuit prospective current I	4,98 kA	5,99 kA
EFEN Lab-No.	00101	00102
Test passed	Yes	Yes

3.4 Breaking Test: Test Duty 3

Rated current	80 A	100 A
Test Laboratory / Document No.	FGH LV 00048	FGH LV 00049
Test circuit applied voltage: U	24,2 kV	24,5 kV
Test circuit prospective current I	307 A	426 A
EFEN Lab-No.	00101	00102
Test passed	Yes	Yes

3.5 Tests for time-current characteristics

Test Laboratory: EFEN Prüflabor Eltville

EFEN Lab-No: 01169

Test passed

3.6 Cut-off characteristics

EFEN Lab-No: 01171

3.7 Test of strikers

Test result: 0,83 J => Type medium

Test Laboratory: EFEN Prüflabor Eltville

EFEN Lab-No: 03088

Test passed


4. Test results


The products passed the type tests according to IEC 60 282-1 and VDE 0670 Teil 4 respectively at KEMA, FGH and EFEN test laboratories.


All requirements are fulfilled (see 3.).

370 / 65

2004-11-18

  
Test Engineer



  
Head of laboratory

Lab.-No. 01153

Sheet 1 of 2

1. Type HH-SI 10/24kV 80A FC TB ÜLA 442/65  
Order-No.: 67240.0809

2. Reason for test  
Temperature-rise tests and power-dissipation measurement

3. Tests performed / measurements

Measurement of temperatures, of voltage drop across fuse-link and power dissipation at different operating currents.

4. Applied standards

IEC 60282-1 1998-01 VDE 0670 Teil 4 Abs. 12 02/98

5. Test-laboratory, period of time

EFEN Prüflabor Eltville, 10/21/1998

6. Arrangement of the equipment

The high-voltage fuse-link is mounted vertically in a fuse-base, with the striker-pin at the top.

The size of bare copper conductors is 150 mm<sup>2</sup>.

Temperatures are measured at the fuse contacts (top and bottom), in the middle of the fuse with thermocouples and are recorded.

The test currents are recorded.

7. Inspection and test sequence

The fuse-link was loaded with test currents I = 40 A and I = 80 A

Test current I [A]	Comments
40	50% rated current
80	Rated current

Temperatures are measured at the fuse contacts and in the middle of the tube with thermocouples.

Calculation of power dissipation from recorded voltage drop and recorded test current.

Calculation of resistance depending on the currents.

## 8. Results

Type: HH-SI 10/24kV 80A FC TB ÜLA 442/65

 R<sub>cold</sub>: 19,4 mΩ

## 8.1 Temperature rise test

I [A]	θ <sub>amb.</sub> [°C]	Temperature		Temperature rise			Informative	
		θ <sub>top</sub> [°C]	θ <sub>bottom</sub>	θ <sub>perm.</sub> [°C]	Δθ <sub>top</sub> [K]	Δθ <sub>bottom</sub> [K]	Δθ <sub>perm.</sub> [K]	θ <sub>center</sub> [°C]
40	19,1	37,8	31,2	105	18,7	12,1	65	59,7
80	18,0	85,4	63,6	105	67,4	45,6	65	197,3

## 8.2 Power dissipation and resistance of the test object at defined currents.

I [A]	P <sub>d</sub> [W]	U <sub>fuse-link</sub> [V]	R [mΩ]
40	38,4	0,96	24,0
80	233,6	2,92	36,5

## 9. Evaluation

The limits for temperature (105 °C) and temperature-rise (65 K) for components and materials are followed according to the IEC standard up to 78 A. A derating factor of 0,975 has to be applied with reference to rated current.

 372 / 23  
 07/06/2001

  
 Test engineer

  
 Head of laboratory

Lab.-No. 01154

Sheet 1 of 2

1. Type HH-SI 10/24kV 100A FC TB ÜLA 442/78  
Order-No.: 67240.1009

## 2. Reason for test

Temperature-rise tests and power-dissipation measurement

## 3. Tests performed / measurements

Measurement of temperatures, of voltage drop across fuse-link and power dissipation at different operating currents.

## 4. Applied standards

IEC 60282-1 1998-01 VDE 0670 Teil 4 Abs. 12 02/98

## 5. Test-laboratory, period of time

EFEN Prüflabor Eltville, 12/01/1998

## 6. Arrangement of the equipment

The high-voltage fuse-link is mounted vertically in a fuse-base, with the striker-pin at the top.

The size of bare copper conductors is 150 mm<sup>2</sup>.

Temperatures are measured at the fuse contacts (top and bottom), in the middle of the fuse with thermocouples and are recorded.

The test currents are recorded.

## 7. Inspection and test sequence

The fuse-link was loaded with test currents I = 50 A and I = 100 A.

Test current I [A]	Comments
50	50% rated current
100	Rated current

Temperatures are measured at the fuse contacts and in the middle of the tube with thermocouples.

Calculation of power dissipation from recorded voltage drop and recorded test current.

Calculation of resistance depending on the currents.

## 8. Results

Type: HH-SI 10/24kV 100A FC TB ÜLA 442/78  
 $R_{cold}$ : 17,5 mΩ

### 8.1 Temperature rise test

I [A]	$\vartheta$ amb. [°C]	Temperature		Temperature rise			Informative	
		$\vartheta$ top [°C]	$\vartheta$ bottom [°C]	$\vartheta$ perm. [°C]	$\Delta\vartheta$ top [K]	$\Delta\vartheta$ bottom [K]	$\Delta\vartheta$ perm. [K]	$\vartheta$ center [°C]
50	22	46,2	38,2	105	24,2	16,2	65	76,2
100	23,8	115,6	90,3	105	91,8	66,5	65	251,2


### 8.2 Power dissipation and resistance of the test object at defined currents.

I [A]	P <sub>d</sub> [W]	U <sub>fuse-link</sub> [V]	R [mΩ]
50	59,0	1,18	23,6
100	397,0	3,97	39,7

## 9. Evaluation

The limits for temperature (105 °C) and temperature-rise (65 K) for components and materials are followed according to the IEC standard up to 84 A. A derating factor of 0,84 has to be applied with reference to rated current.

372 / 23  
07/06/2001



  
Test engineer

  
Head of laboratory

**REPORT OF PERFORMANCE**

**CLIENT** EFEN Elektrotechnische Fabrik GmbH,  
Eltville am Rhein, Germany  
**MANUFACTURER** EFEN Elektrotechnische Fabrik GmbH,  
Eltville am Rhein, Germany  
**APPARATUS** Current limiting fuses  
**DESIGNATION** HH-SI 10/24kV FC TB 442/56 1 - 2 - 4 - 6.3 - 10 - 16 - 20 - 25 - 31.5 - 40 - 50 - 63 A - 80 A  
**SERIAL No.** 67240.0010, 67240.0020, 67240.0040, 67240.0060, 67240.0100, 67240.0160, 67240.0200, 67240.0250, 67240.0320,  
67240.0400, 67240.0500, 67240.0630 and 67240.0800.

**RATINGS ASSIGNED BY THE MANUFACTURER**

Voltage	24	kV
Current	1 - 2 - 4 - 6.3 - 10 - 16 - 20 - 25 - 31.5 - 40 - 50 - 63 - 80	A (1)
Frequency	50	Hz
Breaking capacity at 24 kV	63	kA
Series	1	
Class	Back-up	

(1) The fuse-links 20 - 25 - 31.5 A and 40 - 50 - 63 A form a homogeneous series in accordance with Sub-clause 13.3.1 of IEC 60282-1.

The tests have been carried out strictly in accordance with IEC 60282-1, Sub-clause 13 (Test-duty 1).  
The apparatus has complied with the relevant requirements.

Date of tests 22nd November 2000 and 13th March 2001

The performance of the apparatus tested and the observations made during the tests have been recorded in the tables with test results and the oscilloscopes

**THIS REPORT CONSISTS OF:**

Pages	15
Circuit diagrams	1
Oscilloscopes	36
Drawings	19
Photographs	5
Information sheet	B70E

© Copyright: Publication or reproduction of the contents of this report in any other form than a complete copy to the letter, is not allowed without our written consent.

KEMA Nederland B.V.

A.L.J. Janssen  
Manager High-Power Laboratory

Arnhem, 27th February 2001

193

TABLE WITH TEST RESULTS

## REPORT 720-00 TYPE OF TESTS REQUESTED: Test duty 1

Condition before tests: Fuse-base new. Photograph 1502902.

Before each test new fuse-link.

Fuse-link mounted vertically in free air.

Distance fuse-link to floor 1.5 m.

Supply on top of the fuse-carrier.

TEST CIRCUIT SD2 PAGE 15

Date and test	Fuse-link Type	Resistance before test		Test circuit		Comments on arcing after voltage zero	Cut-off current at initiation of arcing peak kA	Pre-arc time ms	Arcing time ms	Total operating time ms	Recovery voltage (1) kV	Switching voltage peak kV	$\int_{12t}$ A $s \times 10^6$	$\int_{12t}$ A $s \times 10^6$	Melt Energy J	Condition after test Fuse-link Striker	Behaviour during test Remarks	
		Rated voltage kV	Rated current A	Applied voltage kV	Prospective current kA													
010313 5026				10.6	31.3													Checking of the prospective current TRV.
010313 5027				21.0														Checking of the applied voltage and TRV.
010313 5029	HH-SI10/24 FC TB 442/56 67240.0800 2049	24	19.3	21.0	63.2	40	10.0	10.0	0.63	6.50	7.53	20.8	46.5	18.2	44.7	237	hot Fuse cleared. 23 mm	
010313 5030	HH-SI10/24 FC TB 442/56 67240.0800 2050	24	19.0	21.0	63.2	85	12.4	12.8	0.41	4.80	5.21	20.8	62.8	18.6	64.9	309	hot Fuse cleared. 23 mm	
010313 5031	HH-SI10/24 FC TB 442/56 67240.0800 2052	24	19.0	21.0	63.2	83	12.5	12.7	0.38	4.50	4.88	20.8	66.8	15.0	58.8	260	hot Fuse cleared. 23 mm	

Remarks: Fuse-base showed no visible change.

(1) Maintained for 15 s.

KEMA

**REPORT OF PERFORMANCE**

**CLIENT** EFEN Elektrotechnische Fabrik GmbH,  
Elvile am Rhein, Germany  
**MANUFACTURER** EFEN Elektrotechnische Fabrik GmbH,  
Elvile am Rhein, Germany  
**APPARATUS** Current limiting fuses  
**DESIGNATION** HH-SI 10/24 FC TB 2 - 4 - 50 - 100 A  
**SERIAL No.** 67240.0020, 67240.0040 67240.0500, 67240.1000

**RATINGS ASSIGNED BY THE MANUFACTURER**

Voltage	24	kV
Current	2 - 4 - 50 - 100	A
Frequency	50	Hz
Breaking capacity at	24 kV	63 kA
Series	1	
Class	Back-up	

The tests have been carried out strictly in accordance with IEC 60282-1, Clause 13 (Test duty 1).  
The fuses have complied with the relevant requirements.

Date of tests 4th November 1998

The performance of the apparatus tested and the observations made during the tests have been recorded in the tables with test results and the oscillograms

**THIS REPORT CONSISTS OF:**

Pages	7
Circuit diagrams	1
Oscillograms	13
Drawings	30
Graphs	2
Report sheet	B70E

© Copyright: Publication or reproduction of the contents of this report in any other form than a complete copy to the letter, is not allowed without our written consent.

KEMA Nederland B.V.

A.L.J. Janssen

Arnhem, 16th February 1999



194



## TABLE WITH TEST RESULTS

**REPORT** 731-98 **TYPE OF TESTS REQUESTED:** Test Study 1 (1988 A)

**Condition before tests:** Fuse carrier in same condition.  
 Fuse—links mounted vertically in free air by means of clips.  
 Distance fuse—link to floor 1,20 m.

**Remarks:** Fuse—carrier contacts not damaged.

### (1) Maintained for 15 s.

KEMAK



## Test Report

No. LV 00048



Accredited testing laboratory to DIN EN 45001 for subject

DAT-P-020/92-01

High-voltage apparatus

DAT-P-020/92-12

switchgear and controlgear

DAT-P-020/92-21

High-voltage cables

and accessories

Voltage quality flicker

Duly signed copy

1E

Reference:

114-99/241, 246...248

114-00/034...047

Apparatus:

Current-limiting fuse-link

Types: a) HH-SI 10/24kV 50A FC TB 442/65,  
b) HH-SI 10/24kV 80A FC TB 442/78,

Ident-No.: 67240.0500

Ident-No.: 67240.0800

Rated voltage: 24 kV

Rated current: a) 50 A, b) 80 A

Class: Back-up

Manufacturer:

EFEN Elektrotechnische Fabrik GmbH,  
Postfach 12 54, D-65344 Eltville, Germany

Customer:

EFEN Elektrotechnische Fabrik GmbH,  
Postfach 12 54, D-65344 Eltville, Germany

Test Specification: IEC 282-1, fourth edition, 1994

Tests performed: Breaking tests:

Test duty 2 with type b):

Verification of the operation with prospective current  $I_2$  at which current limiting occurs when a high level of energy is stored in the inductance of the circuit.

Test duty 3 with type a) and b):

Verification of the operation at the rated minimum breaking current

a)  $I_3 = 171$  A,

b)  $I_3 = 307$  A.

Test Results:

During the breaking tests performed, the tested fuse-links fully complied with the standard conditions of behaviour with respect to breaking capacity.

Mannheim, May 9, 2000  
Hch



FORSCHUNGSGEMEINSCHAFT FÜR  
ELEKTRISCHE ANLAGEN UND STROMWIRTSCHAFT E.V.

A.V.

Test Engineer:

i.V. J. B.  
Helt Schaefer

Place and date of test: LVF Mannheim-Rheinau, 16/11/1999, 24/01/2000, 25/01/2000

Number of sheets: 24

C. B.

195

Forschungsgemeinschaft für Elektrische Anlagen und Stromwirtschaft e.V.

No. LV 00048

Sheet 14

FUSE-LINKS - BREAKING TESTS

Tested fuse-link Ur [kV] Ir [A] Type  
 24 80 HH-SI 10/24kV 80A FC TB 442/78  
 Ident.-No.: 67240.0800

Test-no.	114-99/		241	246	247	248
Specimen		No.	Adjustment test	991125	991126	991127
Resistance	mΩ	-		20.0	19.9	19.9
Test-duty (according to IEC 282-1)			2			
Power factor of the test circuit	cos φ			0.086		
Prospective breaking current (RMS)	kA	5.00	4.98	4.98	4.98	
Making angle after voltage zero	° el	8.5	8.6	9.0	10.6	
Pre-arcng / Melting time	t <sub>m</sub>	ms		3.71	3.74	3.71
Melting current	i <sub>m</sub>	kA		5.11	5.17	5.14
Pre-arcng Joule Integral	kA <sup>2</sup> s			24.2	25.0	24.5
Cut-off / Let through current	i <sub>d</sub>	kA		5.33	5.36	5.39
Arcing time	t <sub>LB</sub>	ms		6.86	6.81	6.94
Arcing Joule Integral	kA <sup>2</sup> s			65.6	63.7	70.8
Arcing time until breaking by the circuit breaker	ms		-	-	-	
Max. switching voltage	u <sub>S</sub>	kV		55.6	56.9	54.7
Power frequency recovery voltage	U <sub>w</sub>	kV	21.14	21.06	21.06	21.05
Maintaining voltage after breaking	s		> 60	> 60	> 60	

Test result:

Fuse operated correct	y/n		y	y	y
Switching voltage u <sub>S</sub> ≤ permissive value	y/n		y	y	y
Current limiting: (i <sub>d</sub> ≤ Let-through characteristic)	y/n		-	-	-
Requirement for I <sub>2</sub> : i <sub>m</sub> /I = 0.85...1.06	i <sub>m</sub> /I		1.03	1.04	1.03
Emission of flames or sand	y/n		n	n	n
Damages (external)	y/n		n	n	n
Operation of striker correct	y/n		y	y	y

Forschungsgemeinschaft für Elektrische Anlagen und Stromwirtschaft e.V.

No. LV 00048


Sheet 15

FUSE-LINKS - BREAKING TESTS

Tested fuse-link Ur [kV] Ir [A] Type  
 24. 80 67240.0800  
 HH-SI 10/24kV 80A FC TB 442/78

Test-no.	114-00/		34	35	36	
Specimen		No.	Adjustment test	991121	991120	
Resistance		mΩ	-	20.0	19.8	
Test-duty (according to IEC 282-1)				3		
Power factor of the test circuit		cos φ		0.51		
Prospective breaking current (RMS)		A		307		
Maintained current with low voltage source	at 306...304 A at 311...309 A	s		3.67	3.81	
Time of current-interruption while switching over from low voltage to high voltage circuit		ms		167	151	
Melting time	t <sub>m</sub>	s		3.67	3.81	
Pre-arcng Joule Integral		A <sup>2</sup> s		-	-	
Arcing time	t <sub>LB</sub>	ms		40	56	
Arcing Joule Integral		kA <sup>2</sup> s		3.67	4.40	
Arcing time until breaking by the circuit breaker		ms		-	-	
Max. switching voltage	u <sub>S</sub>	kV		34.8	34.8	
Power frequency recovery voltage	U <sub>W</sub>	kV	24.2	24.2	24.2	
Maintaining voltage after breaking		s		60	60	
<b>Test result:</b>						
Fuse operated correct		y/n		y	y	
Switching voltage u <sub>S</sub> ≤ permissive value		y/n		y	y	
Emission of flames or sand		y/n		n	n	
Damages (external)		y/n		n	n	
Operation of striker correct		y/n		y	y	







## Test Report

No. LV 00049

Accredited testing laboratory to DIN EN 45001 for subject



DAT-P-020/92-01

High-voltage apparatus  
switchgear and controlgear  
High-voltage cables  
and accessories  
Voltage quality flicker

DAT-P-020/92-12

DAT-P-020/92-21

Duly signed copy 1E

Reference: 114-98/410...413,  
114-00/493...497

Apparatus: Current-limiting fuse-link

Type: HH-SI 10/24kV 100A FC TB 442/78, Ident-No.: 67240.1000

Rated voltage: 24 kV

Rated current: 100 A

Class: Back-up

Manufacturer: EFEN Elektrotechnische Fabrik GmbH,  
Postfach 12 54, D-65344 Eltville, Germany

Customer: EFEN Elektrotechnische Fabrik GmbH,  
Postfach 12 54, D-65344 Eltville, Germany

Test Specification: IEC 282-1, fourth edition, 1994

Tests performed: Breaking tests:

**Test duty 2:**

Verification of the operation with prospective current  $I_2$  at which current limiting occurs when a high level of energy is stored in the inductance of the circuit.

**Test duty 3:**

Verification of the operation at the rated minimum breaking current  
 $I_3 = 426 \text{ A}$ .

Test Results: During the breaking tests performed, the tested fuse-links fully complied with the standard conditions of behaviour with respect to breaking capacity.

Mannheim, July 17, 2000  
Hch



FORSCHUNGSGEMEINSCHAFT FÜR  
ELEKTRISCHE ANLAGEN UND STROMWIRTSCHAFT E.V.

Test Engineer:

(Schaefer)

Place and date of test: LVF Mannheim-Rheinau, 8/9/1998, 7/6/2000

Number of sheets: 23

## FUSE-LINKS - BREAKING TESTS

Tested fuse-link Ur [kV] Ir [A] Type  
24 100 HH-SI 10/24kV 100A FC TB 442/78,  
Ident.-No. 67240.1000

Test-no.	114-98/		410	411	412	413
Specimen	No.	Adjustment test	98878	98879	98881	
Resistance	mΩ	-	16.8	16.9	17.0	
Test-duty (according to IEC 282-1)			2			
Power factor of the test circuit	cos φ		0.095			
Prospective breaking current (RMS)	KA		5.99			
Making angle after voltage zero	° el		9			
Pre-arcing / Melting time	t <sub>m</sub>	ms		3.5	3.6	3.6
Melting current	i <sub>m</sub>	kA		6.17	6.14	6.17
Pre-arcing Joule Integral		kA <sup>2</sup> s		35.5	35.0	35.6
Cut-off / Let through current	i <sub>d</sub>	kA		6.45	6.46	6.47
Arcing time	t <sub>LB</sub>	ms		6.4	6.6	6.6
Arcing Joule Integral		A <sup>2</sup> s		72.5	85.2	83.9
Arcing time until breaking by the circuit breaker		ms	-	-	-	-
Max. switching voltage	u <sub>S</sub>	kV		61.2	57.1	58.0
Power frequency recovery voltage	U <sub>w</sub>	kV	20.9	20.9	20.9	20.9
Maintaining voltage after breaking		s		60	60	60
<b>Test result:</b>						
Fuse operated correct	y/n		y	y	y	
Switching voltage u <sub>S</sub> ≤ permissive value	y/n		y	y	y	
Current limiting: (i <sub>d</sub> ≤ Let-through characteristic)	y/n		-	-	-	
Requirement for I <sub>2</sub> : i <sub>m</sub> /I = 0.85...1.06	i <sub>m</sub> /I		1.03	1.03	1.03	
Emission of flames or sand	y/n		n	n	n	
Damages (external)	y/n		n	n	n	
Operation of striker correct	y/n		y	y	y	




- 19 -

No. LV 00049

Sheet 14

## FUSE-LINKS - BREAKING TESTS



Tested fuse-link      Ur [kV]      Ir [A]      Type  
                         24                100            67240.1000  
     HH-SI 10/24KV 100A FC TB 442/78

Test-no.	114-00/		493	496	497	
Specimen		No.	Adjustment test	00707	00707a	
Resistance		mΩ	-	17.7	17.0	
Test-duty (according to IEC 282-1)				3		
Power factor of the test circuit	cos φ			0.51		
Prospective breaking current (RMS)		A		426		
Maintained current with low voltage source	at 432 A at 431 A	s		1.49	1.72	
Time of current-interruption while switching over from low voltage to high voltage circuit		ms		110	151	
Melting time	t <sub>m</sub>	s		1.49	1.72	
Pre-arc Joule Integral		kA <sup>2</sup> s		281	320	
Arcing time	t <sub>LB</sub>	ms		110	57.5	
Arcing Joule Integral		kA <sup>2</sup> s		12.2	8.35	
Arcing time until breaking by the circuit breaker		ms		-	-	
Max. switching voltage	u <sub>S</sub>	kV		35.4	35.8	
Power frequency recovery voltage	U <sub>w</sub>	kV	24.4	24.5	24.6	
Maintaining voltage after breaking		s		60	60	
<b>Test result:</b>						
Fuse operated correct	y/n		y	y		
Switching voltage u <sub>S</sub> ≤ permissive value	y/n		y	y		
Emission of flames or sand	y/n		n	n		
Damages (external)	y/n		Thin crack in tube	n		
Operation of striker correct	y/n		y	y		

Lab.-No. 01169

10/24 kV 1 A - 100 A acc. to IEC 60282-1 / VDE 0670 Teil 4

Order-No.: 67240.0019 - 67240.1009





06.06.2001 / 23

**EFEN GmbH**

Postfach 1254 · D-65332 Eltville · Tel. 00 49 (0) 61 29 46-0 · Fax 46222 · e-Mail: efen@efen.com · Internet: www.efen.com

Order-No.: 67240.0019 to 67240.1009



06.06.2001 / 23

1. Type HH – fuse link with striker 81902.0100(3) (duration 30mm)

2. Reason for test

Test of Strikers

3. Tests performed / measurements


- I. measurement of the duration of travel
- II. measurement of the force-travel characteristics and calculation of the striker energy actuated by the spring
- III. Verification of the withstand force according to applied standard (4)

4. Applied standards

IEC 60282-1 2002-01

VDE 0670 Teil 4 Abs. 12 02/98

4.1 standard in detail regarding strikers



039/80

OA – Free travel – No energy output specified.

AB – Further travel during which energy must be delivered.

OB – Minimum actual travel.

OC – Maximum actual travel.

CB – Maximum permitted return travel under withstand force (when applicable).

Type	Energy	Mechanical characteristics					
		Values of		Actual travel		Minimum withstand force	Maximum duration of travel (see note)
		Free travel (OA)*	Further travel during which energy must be delivered (AB)*	Min. (OB)*	Max. (OC)*		
J	mm	mm	mm	mm	mm	N	ms
Light	0,3 ± 0,25	2	8	10	30	Not applicable	100
Medium	1 ± 0,5	4	16	20	40	20	100
Heavy	2 ± 1	4	6	10	16	40	100

\* See figure 12.

NOTE – Duration of travel is defined for actual fuse-links as the time from commencement of arcing to the time when travel OB is reached. For dummy fuses it is the time from application of voltage until travel OB is reached.

## 5. Test-laboratory, period of time

EFEN laboratory Eltville, 4.12.2003

## 6. Arrangement of the equipment

I. The tested fuse link is fixed in a fuse-base. An NC (normally closed) switch will be opened if the striker has travelled 30mm. Current, Voltage and the NC switch are recorded by an digital oscilloscope.

II. & III. The force-travel characteristics will be measured by an approved force meter\*. For this measurement the striker will be prepared with an scale indicator for measuring the travelled way in mm.

\*Zwick Z2.5 / TN1S Material testing device

## 7. Inspection and test sequence

I. Intact striker circuit is tested with current < 10A and voltage < 15V.

II. Current, voltage and the NC switch are recorded.

III. Force of striker is measured at Positions: 0, 10, und 20mm.

The Position of the Striker is measured at the minimum withstand force of 20N.

## 8. Results


## I. measurement of the duration of travel

	duration of travel	Current	Voltage
Sample 1	5 ms	9,9 A	< 15 V
Sample 2	2 ms	11,7 A	< 15 V
Sample 3	4 ms	10 A	< 15 V
Sample 4	6 ms	9,9 A	< 15 V

II. measurement of the force-travel characteristics and calculation of the striker energy

Position	Length / mm	Sample 1		Sample 2		Sample 3		Average:
		Measrem. 1	Measrem. 2	Measrem. 1	Measrem. 2	Measrem. 1	Measrem. 2	
O	0	77	76,8	85,5	81,7	78	78	79,5
A	4	66,5	66,4	67,5	67,4	71,7	69,7	68,2
B	20	37,7	36,1	33,7	33,1	36,2	36,5	35,6
	Energy / J:	0,83	0,82	0,81	0,80	0,86	0,85	0,83

$$\text{Energy} = \frac{(F_A + F_B) \times \overline{AB}}{2000} \quad \text{Energy}[J]; F_A[N]; F_B[N]; \overline{AB}[mm];$$



III. Verification of the withstand force of 20N at Position  $\geq 20\text{mm}$

	Measurement	Force / N	Length / mm
Sample 1	1	20	27,4
Sample 1	2	20	27,7
Sample 2	1	20	27,3
Sample 2	2	20	26,9
Sample 3	1	20	28,4
Sample 3	2	20	28,4

9. Evaluation

Type	Energy		Free travel <u>OA</u>	Further travel during which energy must be delivered <u>AB</u>	Actual travel		Minimum travel force	
	Actual value	Specified value			Actual value	Specified value	Actual value	Specified value
	J	mm	mm		mm	mm	N	~20
Medium	0,83	1±0,5	4	16	30	20	40	35,6

- I.: Measured duration of travel < maximum duration of travel (100ms)
- II. striker energy is Medium 1J ±0,5 J
- III. Verification of the withstand force proofed that the striker has the necessary force.

The striker full fills all Requirements of striker Type medium according to:  
IEC 60282-1 2002-01; VDE 0670 Teil 4 Abs. 12 02/98

370 / 65

2004-03-29

*L. Sandner*  
Test engineer

*A. Hilt*  
Head of Laboratory



Приложение № 6



Deutsche  
Akkreditierungsstelle

Deutsche Akkreditierungsstelle GmbH

Превод от английски език

## Немски орган по акредитация

Поверен съгласно Раздел 8 подраздел 1 AkkStelleG във връзка с Раздел 1 подраздел 1 AkkStelleGBV

Подписала Многостраничните споразумения на EA, ILAC и IAF за Взаимно признаване

## АКРЕДИТАЦИЯ



Немски орган по акредитация (Deutsche Akkreditierungsstelle GmbH) удостоверява, че лабораторията за изпитване

FGH Engineering & Test GmbH  
Hallenweg 40, 68219 Mannheim

е компетентна съгласно условията на DIN EN ISO/IEC 17025:2005 за извършване на изпитания в следните области:

**Високоволтови устройства и системи и техни елементи**

**Захранващи кабели и комплекти за захранващи кабели**

*[Handwritten signature]*

Сертификатът за акредитация би трябвало да се прилага само във връзка с уведомлението за акредитация на 11.01.2012 с акредитационен номер D-PL-12110-01 и е валиден до 10.01.2017. Той се състои от настоящия лист, обратната страна на настоящия лист и следващо приложение с общо 22 страници.

Регистрационен номер на сертификата: D-PL-12110-01

Франкфурт на Майн, 11.01.2012

*[Handwritten signatures]*  
On behalf of Dipl.-Ing. (FH) Ralf Egner  
Head of Division 2

Този документ е превод. Окончателната версия е оригиналния Немски сертификат за акредитация.

Виж бележките на пърба

*[Handwritten signature]*

*[Handwritten signature]*

(  
C

(  
C

# Deutsche Akkreditierungsstelle GmbH

## Немски орган по акредитация

Офис Берлин  
Spittelmarkt 10  
10117 Berlin

Офис Франфуркт на Майн  
Gartenstraße 6  
60594 Frankfurt am Main

Офис Брауншвайг  
Bundesallee 100  
38116 Braunschweig

Публикуването на екстракти от сертификата за акредитация е предмет напредварително писмено одобрение от Немския орган по акредитация(( Deutsche Akkreditierungsstelle GmbH (DAkkS)).Изключение е непроменената форма of отделни разпространявания на настоящия лист от съответният орган за оценяване споменат на обратната страна на документа.

Да не се има предвид ,че акредитацията се отнася и за области извън обхвата на акредитация, удостоверено с DAkkS.

Акредитацията е издадена по реда на Закона за Органи по Акредитация (AkkStelleG) от 31 юли 2009 (Федерален закон ДВ I стр. 2625) и на Регламент (ЕС) № 765/2008 на Европейския парламент и на Съвета от 9 юли 2008 за определяне на изискванията за акредитация и надзор на пазара във връзка с предлагането на пазара на продукти (Официален вестник на Европейския съюз L 218 от 9 юли 2008 г., стр. 30).DAkkS е подписала Многостранични споразумения за взаимно признаване на Европейската организация за акредитация (EA), Международния акредитационен форум (IAF) и Международно Лабораторно сътрудничество за акредитация (ILAC.Подписалите тези споразумения взаимно признават акредитациите.

Актуалното състояние на членството може да бъде изтеглена от следните уебсайтове:

EA: [www.european-accreditation.org](http://www.european-accreditation.org)

ILAC: [www.ilac.org](http://www.ilac.org)

IAF: [www.iaf.nu](http://www.iaf.nu)

(

(



**DAkkS**

Deutsche  
Akkreditierungsstelle

## Deutsche Akkreditierungsstelle GmbH German Accreditation Body

Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1  
subsection 1 AkkStelleGBV

Signatory to the Multilateral Agreements of  
EA, ILAC and IAF for Mutual Recognition

## Accreditation



The Deutsche Akkreditierungsstelle GmbH (German Accreditation Body) attests that the  
testing laboratory

**FGH Engineering & Test GmbH**  
**Hallenweg 40, 68219 Mannheim**

Is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out tests in the  
following fields:

**High voltage devices and systems and their components**  
**Power cable and power cable sets**

The accreditation certificate shall only apply in connection with the notice of accreditation of 11.01.2012  
with the accreditation number D-PL-12110-01 and is valid until 10.01.2017. It comprises the cover sheet,  
the reverse side of the cover sheet and the following annex with a total of 22 pages.

Registration number of the certificate: D-PL-12110-01

On behalf of Dipl.-Ing. (FH) Ralf Egner  
Head of Division 2

Frankfurt am Main, 11.01.2012

This document is a translation. The definitive version is the original German accreditation certificate.

See notes overleaf.

(  
C

(  
C

# Deutsche Akkreditierungsstelle GmbH

Office Berlin  
Spittelmarkt 10  
10117 Berlin

Office Frankfurt am Main  
Gartenstraße 6  
60594 Frankfurt am Main

Office Braunschweig  
Bundesallee 100  
38116 Braunschweig

The publication of extracts of the accreditation certificate is subject to the prior written approval by Deutsche Akkreditierungsstelle GmbH (DAkkS). Exempted is the unchanged form of separate disseminations of the cover sheet by the conformity assessment body mentioned overleaf.

No impression shall be made that the accreditation also extends to fields beyond the scope of accreditation attested by DAkkS.

The accreditation was granted pursuant to the Act on the Accreditation Body (AkkStelleG) of 31 July 2009 (Federal Law Gazette I p. 2625) and the Regulation (EC) No 765/2008 of the European Parliament and of the Council of 9 July 2008 setting out the requirements for accreditation and market surveillance relating to the marketing of products (Official Journal of the European Union L 218 of 9 July 2008, p. 30). DAkkS is a signatory to the Multilateral Agreements for Mutual Recognition of the European co-operation for Accreditation (EA), International Accreditation Forum (IAF) and International Laboratory Accreditation Cooperation (ILAC). The signatories to these agreements recognise each other's accreditations.

The up-to-date state of membership can be retrieved from the following websites:

EA: [www.european-accreditation.org](http://www.european-accreditation.org)

ILAC: [www.ilac.org](http://www.ilac.org)

IAF: [www.laf.nu](http://www.laf.nu)

(  
C

(  
C

на KEMA Nederland B.V.  
High-Power Laboratory

Това приложение е валидно от 19-03-2015 до 01-04-2018 Заменя приложение с дата: 26-01-2015

**Место където се извършват дейности по акредитация**

Главен офис

Utrechtseweg 310, Building no. R11  
6812 AR  
Arnhem  
The Netherlands

No.	Материал или продукт	Вид дейност <sup>1</sup>	Вътрешен референтен номер
	Силови Трансформатори	Изпитания на късо съединение	IEC 60076-5 IEC 60076-11 EN 50464-1 IEEE Std C57.12.90 IEEE Std. C57.12.00
2	Токови Трансформатори	Изпитания на късо съединение Измерване на преходната моментна грешка	IEC 61869-2 IEEE Std C57.13 IEC 61869-1
3	Реактори	Изпитания на късо съединение	IEC 60076-6 IEEE Std C57.21
4	Високо честотни бобини за А.С. захранващи системи	Изпитания на късо съединение	IEC 60353
5	Метални А.С. КРУ1 - 52 kV съотв. > 1 kV и сглобяеми подстанции	Изпитания на късо съединение Проверка на включващи и изключващи мощности Механични работни изпитания Дъгов разряд поради вътрешна повреда	IEC 62271-200 IEC 62271-202 IEEE C37.74 IEEE Std C37.20.2 IEEE Std C37.20.7 ANSI C37.54 ANSI C37.55
6	Метални А.С. КРУ> 52 kV съотв.	Изпитания на късо съединение Проверка на включващи и изключващи мощности Механични работни изпитания Дъгов разряд поради вътрешна повреда	IEC 62271-203 IEEE Std C37.122

Това приложение беше одобрено от:  
Ir. J.C. van der Poel  
Главен Изпълнителен Директор

<sup>1</sup> Ако има препращане към поле (SXXX), това представлява приетата от собственика схема. Приетата версия е упомената във връзка с обхватата на схемата на собственика.  
Холандски Акредитационен съвет RvA

(  
C

(  
C

Приложение към ISO/IEC 17025:2005 Декларация  
за акредитация за регистрационен номер: L 020

на **KEMA Nederland B.V.**  
**High-Power Laboratory**

Това приложение е валидно от 19-03-2015 до 01-04-2018 Заменя приложение с дата: 26-01-2015

No.	Материал или продукт	Вид дейност <sup>1</sup>	Вътрешен референтен номер
7	Комутиационни апарати А.С. Ниско напрежение и контролни Предавателни сглобки	Изпитания на късо съединение	IEC 61439-1 IEC 61439-2 IEC 60439-2
8	Изолирани А.С. КРУ 1-52kV	Изпитания на късо съединение Проверка на включващи и изключващи мощности Механични работни тестове Дъгов разряд поради вътрешнаповреда	IEC 62271-201
9	Високоволтови А.С. прекъсвачи	Изпитания на късо съединение Изпитания на включване и изключване Тест на включване Механични изпитания и изпитанания на влияние върху околната среда	IEC 62271-100 IEC 62271-110 IEC 62271-101 IEEE Std C37.09 IEEE Std C37.09a IEEE Std C37.09 IEEE
10	Високоволтови генератори Прекъсвачи	Изпитания на късо съединение	IEEE Std C37.013 IEEE Std C37.013a
11	АС прекъсвачи за Железопътни приложения	Изпитания на включване и изключване	EN 50152-1 IEC 60077-4
12	Високоволтови А.С. Комутатори за номинални Напрежения над 1 kVUp Включително 52 kV	Изпитания на късо съединение Изпитания на включване и изключване Механични изпитвания за издържливост	IEC 62271-103
13	Променливотокови Комутатори за номинални Напрежения от 52 kV и нагоре	Изпитания на късо съединение Изпитания на включване и изключване Механични изпитвания за издържливост	IEC 62271-104 IEEE Std C37.247
14	Високоволтови А.С. Разединители и заземителни комутатори	Изпитания на късо съединение Тест на включване Работа при късо съединение Изпитания на оперативна и механична издържливост Операции при тежки условия на лед Операции при температурните граници Изпитания на контактната зона	IEC 62271-102 IEEE Std C37.34
15	Променивотокови контактори и пускатели	Включващи и изключващи мощности Координация с устройството със защита От късо съединение	IEC 62271-106
16	Автоматични Реклозери и прекъсвания при повреда	Тестове на прекъсвания Работни изпитвания за издържливост	IEC 62271-111 / IEEE Std C37.60

(  
C

(  
C