

## ТЕХНИЧЕСКО ПРЕДЛОЖЕНИЕ

за открита процедура за възлагане на обществена поръчка с наименование:  
„Доставка на прекъсвачи ниско напрежение” и реф. № PPD 15-033.

### Обособена позиция 1:

Доставка на автоматични прекъсвачи НН с лят корпус

ДО: „ЧЕЗ РАЗПРЕДЕЛЕНИЕ БЪЛГАРИЯ” АД, гр. София, бул. „Цариградско шосе“ № 159

ОТ: „ИНТЕРКОМПЛЕКС” ООД – гр. Пловдив

Адрес на управление: гр. Пловдив, бул. Пещерско шосе, №. 201

тел.: 032 / 241 414; факс: 032 / 241 415; e-mail: sales@intercomplex.bg

Единен идентификационен код: 115096057

Представяван от Ехиязар Узунян – управител

Упълномощен представител за тази процедура (ако е предвидено) .....  
с приложено пълномощно № ....., дата .....Тел.: ..... / .....; факс: .....; e-mail: .....



### УВАЖАЕМИ ГОСПОДА,

1. Запознат съм и приемам изискванията на Възложителя, като представям техническите спецификации от раздел IV на документацията с попълнени всички изисквани стойности за всички позиции от стоката по предмета на поръчката за обособена позиция 1.
2. Представям всички изисквани данни и документи, посочени в Приложение 2 от настоящото техническо предложение. Запознат съм с изискването, че представените документи трябва да бъдат на български език или с превод на български език, придружени с оригиналните документи, с изключение на каталозите и протоколите от типовите изпитвания, които могат да се представят и само на английски език.
3. Запознат съм, че представените от нас технически документи (протоколи от изпитания, каталози и др) са доказателство за декларираните от мен технически данни и параметри в техническите спецификации на стоката.
4. Потвърждавам, че представяните от нас стоки, описани в Техническото ни предложение ще отговарят на посочените от възложителя стандарти или на еквивалентни. В случай, че даден материал отговаря на стандарт, еквивалентен на посочения се задължаваме да го отразим в отделен документ и да представим доказателства за еквивалентността на двата стандарта.
5. Всички стойности, попълнени в колона „Гарантирано предложение” на приложените таблици от Технически спецификации от раздел IV от документацията за участие са точни и истински.
6. Предлагам гаранционен срок за предлаганите стоки – 24 (двадесет и четири) месеца / не по-малко от 24 месеца/, от датата на прием – предавателен протокол за получаване на стоката от Възложителя.
7. Запознат съм, че видовете стоки и ориентировъчни количества за доставка ще бъдат посочени от Възложителя при провеждане на процедура на договаряне без обявление.
8. Приемем, че в срок до ..... (не повече от 10 дни) от датата на подписване на договор с възложителя, ще еключе договор с посочения/те в офертата подизпълнител/и (попълва се, ако участникът е декларирал, че ще използва подизпълнител/и).
9. Запознат съм, че в процедурата на договаряне без обявление, изборът на изпълнител ще бъде направен по критерий „най-ниска цена“.
10. Запознат съм, че максималният срок за изпълнение на конкретен договор ще бъде определен от Възложителя в поканата за договаряне.

### Приложения:

1. Технически изисквания и спецификации за изпълнение на поръчката – раздел IV от документацията за участие – попълнени на съответните места;
2. Изисквани документи от Технически изисквания и спецификации.

07.08.2015 г.



Ехиязар Узунян - управител



**Приложение 1**  
**към техническо предложение**  
**по процедура PPD 15-033**

## ТЕХНИЧЕСКИ ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА

### ОБОСОБЕНА ПОЗИЦИЯ 1 – Доставка на автоматични прекъсвачи НН с лят корпус

Наименование на материала:	Триполюсни автоматични прекъсвачи НН с лят корпус, от 100 А до 400 А, с термомагнитна защита, категория А
Съкратено наименование на материала:	Трип. авт. прек. НН, с ТМ защита, 100-400 А, кат. А
Област: Н – Електрически уредби СрН/НН	Категория: 17 – Комутационни апарати НН за защита
Мерна единица: Брой	Аварийни запаси: Да

#### Характеристика на материала:

Триполюсните автоматични прекъсвачи НН с лят корпус представляват механични комутационни апарати от фиксиран тип с предно свързване на шинната система. Автоматичните прекъсвачи са способни да провеждат и да включват/изключват ръчно електрически токове във вериги при нормални условия и да включват, да провеждат за определено време и да изключват автоматично посредством електромеханична защита от термомагнитен тип токове във вериги при условията на претоварване и късо съединение.

Тялото (корпусът) на автоматичните прекъсвачи НН е изработено чрез формоване на устойчив на нагряване, на огън и на механични удари изолационен материал. Използваните в конструкцията изолационни материали съответстват на изискванията на т. 7.1. от БДС EN 60947-2:2006.

Управлението се осъществява ръчно посредством лост. Включването/изключването на контактите на трите полюса се осъществява едновременно с висока скорост, която не зависи от действията на оператора. Автоматичният прекъсвач изпълнява разединяваща функция, която е обозначена със съответния символ. На челния панел на прекъсвача е разположен тест-бутон за проверка на изключвателния механизъм. Лостът за управление при вертикално монтиране на автоматичните прекъсвачи се движи в направление „нагоре – надолу“, при което контактите се затварят при движение „нагоре“. Лостът има три ясно индицирани положения, съответстващи на позицията на контактната система: „Включено“, „Изключено“ и „Автоматично изключено от свръхтокове /Тест“. Конструкцията осигурява защита срещу проникване на твърди тела и вода до степен най-малко IP20 за клемните съединения и IP40 за челната повърхност на прекъсвача, съгласно БДС EN 60529+A1:2004.

Стойностите на прегряването на частите на триполюсните автоматични прекъсвачи НН с лят корпус при нормален работен режим при температура до 40°C не трябва да надвишават посочените в таблица 7 от БДС EN 60947-2:2006 стойности. Прекъсвачите са маркирани с информацията съгласно т. 5.2 от БДС EN 60947-2:2006 и CE маркировка за съответствие.

Прекъсвачите се доставят с предпазни клемови капаци, изолиращи фазови сепаратори и разширители и удължители на входа и на изхода, които са подходящи за свързване към шинна система, която е изработена с алуминиеви шини с правоъгълно сечение.

По искане на възложителя прекъсвачите трябва да бъдат доставени с адапторни планки, които са съобразени с присъединителните и габаритните размери на автоматичните прекъсвачи от сериите: А100, А1, А250, А2 и А2-400 съгласно табл. 1 и фиг. 1 по-долу, произведени от бившия ЕАЗ гр. Пловдив.

Триполюсните автоматични прекъсвачи са пакетирани в картонени кутии, на които е залепен етикет с наименование на материала „Автоматичен прекъсвач“, техническите данни, годината на производство, партидните номера и стандарта, в съответствие с който са произведени и изпитани - БДС EN 60947-2:2006.

#### Използване:

- Триполюсните автоматични прекъсвачи НН с лят корпус се монтират в разпределителни табла в трансформаторните постове и се използват за защита на електропроводните линии.

#### Съответствие на предлаганото изпълнение с нормативно-техническите документи:

Триполюсните автоматични прекъсвачи НН с лят корпус трябва да отговарят на посочените по-долу стандарт, или еквиваленти, включително на техните валидни изменения и допълнения:

- БДС EN 60947-1:2007 "Комутационни апарати за ниско напрежение. Част 1: Общи правила (IEC 60947-1:2007)"; и
- БДС EN 60947-2:2006 „Комутационни апарати за ниско напрежение. Част 2: Автоматични прекъсвачи (IEC 60947-2:2006)“ и техните валидни изменения и допълнения и
- БДС EN 60529+A1:2004 Степени на защита, осигурени от обвивката (IP код) (IEC 60529:1989+A1:1999)

да бъдат оценени положително по реда и при условията на Наредбата за съществените изисквания и оценяване на съответствието на електрически съоръжения, предназначени за използване в определени граници на напрежението (приета с ПМС № 182 от 6.07.2001 г., обн., ДВ, бр. 62 от 13.07.2001 г., в сила от 14.01.2003 г., изм. и доп., бр. 74 от 22.08.2003 г., бр. 24 от 21.03.2006 г., в сила от 21.03.2006 г., изм., бр. 40 от 16.05.2006 г., в сила от 5.05.2006 г., изм. и доп., бр. 37 от 8.05.2007 г., изм., бр. 50 от 17.06.2014 г.).

#### Изисквания към документацията и изпитванията:

№ по ред	Документ	Приложение № (или текст)
1.	Точно означение на типа, производителя и страната на производство (произход) и последно издание на каталога на производителя	Приложение ТС 1-1
2.	Техническо описание и чертежи с нанесени на тях размери	Приложение ТС 2-1
3.	ЕО декларация за съответствие	Приложение ТС 3
4.	Протоколи от типови изпитвания на английски или български език, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	Приложение ТС 4-1
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4 – заверено копие	Приложение ТС 5
6.	Техническо описание и чертежи с нанесени размери на монтажни планки, единичната цена на които не се включва в цената на прекъсвачите	Отговор на въпрос СВ-DOC-3861/31.07.2015
7.	Инструкции за транспортиране, складиране, монтиране, вкл. въртящия момент на затягане на клемовите съединения, обслужване и поддържане	Приложение ТС 7

Забележка: Всички оригинални документи трябва да бъдат на български език или с превод на български език. (Каталозите и протоколите от проверките и изпитванията могат да бъдат и само на английски.)

#### Технически данни


##### 1. Характеристики на работната среда

№ по ред	Характеристика	Стойност
1.1	Място на монтиране	На закрито
1.2	Максимална околна температура	+ 40° C
1.3	Минимална околна температура	Минус 5° C
1.4	Максимална средна околна температура за период от 24 ч.	+ 35° C
1.5	Относителна влажност (при 20°С)	До 90 %
1.6	Степен на замърсяване	3
1.7	Надморска височина	До 2000 m

##### 2. Параметри на електроразпределителната мрежа

№ по ред	Параметър	Стойност
2.1	Номинално напрежение	400 / 230 V
2.2	Максимално напрежение	440 / 253 V
2.3	Номинална честота	50 Hz
2.4	Брой проводници в разпределителната мрежа	4 проводна мрежа (L <sub>1</sub> , L <sub>2</sub> , L <sub>3</sub> , PEN)
2.5	Схема на разпределителната мрежа	TN-C


##### 3. Общи технически параметри и други данни




№ по ред	Технически параметър	Изискване	Гарантирано предложение
3.1	Брой на полюсите	3	3
3.2	Обявено работно напрежение ( $U_e$ )	min 690 V AC	690 V AC
3.3	Обявена честота	50 Hz	50 Hz
3.4	Обявено импулсно напрежение ( $U_{imp}$ )	min 6 kV	8 kV
3.5	Обявено изолационно напрежение ( $U_i$ )	min 690 V	800 V
3.6	Категория на приложение	A	A
3.7	Работна изключвателна възможност при късо съединение ( $I_{cs}$ )	min 50% от $I_{cu}$	100%
3.8	Защита от свръхтокове	-	-
3.8.1	Тип на защитата	Защитата от свръхтокове трябва да бъде от термомагнитен тип. (Допускат се изпълнения със защита от електронен тип.)	Защитата от свръхтокове е от термомагнитен тип - TMD / TMA
3.8.2	Защита от претоварване	а) Диапазон на настройване на тока на изключване $I_R = (\text{min } 0,8 + 1) \times I_n$	$(0.7-1)I_n$
		б) Условен ток на неизключване $I_{nd} = 1,05 \times I_R$ във времеви интервал от 120 минути	1,05 $I_R$
		в) Условен ток на изключване $I_a = 1,30 \times I_R$ във времеви интервал до 120 минути	1,3 $I_R$ / 120 минути
3.8.3	Защита от къси съединения	Токът на изключване $I_i$ трябва да бъде фиксиран на една от стойностите или регулируем в диапазона препоръчително от min $4 \times I_n$ до $10 \times I_n$	$(1-10) \times I_n$
3.9	Степен на защита от проникване на твърди тела и вода съгласно БДС EN 60529+A1:2004	-	-
3.9.1	Клемни съединения	IP 20	IP 20
3.9.2	Челна повърхност	IP 40	IP 40
3.10	Акcesoари	а) Два комплекта разширители и удължител за свързване към шинна система от алуминиева шина с правоъгълно сечение	Два комплекта разширители и удължител за свързване към шинна система от алуминиева шина с правоъгълно сечение

4. Триполюсни автоматични прекъсвачи НН с лят корпус, 100 A ÷ 400 A, с термомагнитна защита, категория А  
 4.1 Триполюсен автоматичен прекъсвач НН с лят корпус, 100 A, с термомагнитна защита, кат. А

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 17 5001		1SDA067397R1 XT1C 160 TMD 100-1000 3p F F	
Наименование на материала		Триполюсен автоматичен прекъсвач НН с лят корпус, 100 A, с термомагнитна защита, кат. А	
Съкратено наименование на материала		Трип. авт. прек. НН, с ТМ защита, 100 А, кат. А	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.1.1	Обявен ток ( $I_n$ )	100 A	100A
4.1.2	Обявена максимална изключвателна възможност при к.с. ( $I_{cu}$ )	min 12 kA / 500 V	18kA/500V




Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 17 5001		1SDA067397R1 XT1C 160 TMD 100-1000 3p F F	
Наименование на материала		Триполюсен автоматичен прекъсвач НН с лят корпус, 100 А, с термомагнитна защита, кат. А	
Съкратено наименование на материала		Трип. авт. прек. НН, с ТМ защита, 100 А, кат. А	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.1.3	Работна изключвателна възможност при късо съединение ( $I_{cs}$ )	Съгласно т. 3.7 и т. 4.1.2 Да се посочи	50% $I_{cu}$
4.1.4	Ток на изключване на защитата от къси съединения ( $I_l$ )	Съгласно т. 3.8.3 Да се посочи	10 $I_n$
4.1.5	Време за изключване при $I_{cu}$	max 0,010 s	5ms
4.1.6	Износоустойчивост	-	-
4.1.6a	Електрическа (брой к.ц.)	min 1500 бр.	8 000
4.1.6b	Механична (брой к.ц.)	min 8500 бр.	25 000
4.1.7	Максимални размери ВхШхД (Дълбочината „Д“ не включва лоста за управление)	165x110x125 mm	130/76/70
4.1.8	Тегло, kg	Да се посочи	0.9

#### 4.2 Триполюсен автоматичен прекъсвач НН с лят корпус, 160 А, с термомагнитна защита, кат. А

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 17 5002		1SDA067399R1 XT1C 160 TMD 160-1600 3p F F	
Наименование на материала		Триполюсен автоматичен прекъсвач НН с лят корпус, 160 А, с термомагнитна защита, кат. А	
Съкратено наименование на материала		Трип. авт. прек. НН, с ТМ защита, 160 А, кат. А	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.2.1	Обявен ток ( $I_n$ )	160 А	160А
4.2.2	Обявена максимална изключвателна възможност при к.с. ( $I_{cu}$ )	min 12 kA / 500 V	18kA/500V
4.2.3	Работна изключвателна възможност при късо съединение ( $I_{cs}$ )	Съгласно т. 3.7 и т. 4.2.2 Да се посочи	50% $I_{cu}$
4.1.4	Ток на изключване на защитата от къси съединения ( $I_l$ )	Съгласно т. 3.8.3 Да се посочи	10 $I_n$
4.2.5	Време за изключване при $I_{cu}$	max 0,010 s	5ms
4.2.6	Износоустойчивост	-	-
4.2.6a	Електрическа (брой к.ц.)	min 1000 бр.	8 000
4.2.6b	Механична (брой к.ц.)	min 7000 бр.	25 000
4.2.7	Максимални размери ВхШхД (Дълбочината „Д“ не включва лоста за управление)	185x140x100 mm	130/76/70
4.2.8	Тегло, kg	Да се посочи	0.9

#### 4.3 Триполюсен автоматичен прекъсвач НН с лят корпус, 250 А, с термомагнитна защита, кат. А

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 17 5003		1SDA068059R1 XT3N250 TMD250-2500 3p F F	
Наименование на материала		Триполюсен автоматичен прекъсвач НН с лят корпус, 250 А, с термомагнитна защита, кат. А	
Съкратено наименование на материала		Трип. авт. прек. НН, с ТМ защита, 250 А, кат. А	

№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.3.1	Обявен ток ( $I_n$ )	250 A	250A
4.3.2	Обявена максимална изключвателна възможност при к.с. ( $I_{cu}$ )	min 16 kA / 500 V	20kA/500V
4.3.3	Работна изключвателна възможност при късо съединение ( $I_{cs}$ )	Съгласно т. 3.7 и т. 4.3.2 Да се посочи	75% $\times I_{cu}$
4.3.4	Ток на изключване на защитата от къси съединения ( $I_i$ )	Съгласно т. 3.8.3 Да се посочи	10 $\times I_n$
4.3.5	Време за изключване при $I_{cu}$	max 0,010 s	7ms
4.3.6	Износоустойчивост	-	-
4.3.6a	Електрическа (брой к.ц.)	min 1000 бр.	8 000
4.3.6b	Механична (брой к.ц.)	min 7000 бр.	25 000
4.3.7	Максимални размери ВхШхД (Дълбочината „Д“ не включва лоста за управление)	225x140x130 mm	150/105/70
4.3.8	Тегло, kg	Да се посочи	1.5

#### 4.4 Триполюсен автоматичен прекъсвач НН с лят корпус, 400 А, с термомагнитна защита, кат. А

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 17 5005		<b>1SDA054437R1</b> <b>T5N400 TMA 400A 3P FF</b>	
Наименование на материала		Триполюсен автоматичен прекъсвач НН с лят корпус, 400 А, с термомагнитна защита, кат. А	
Съкратено наименование на материала		Трип. авт. прек. НН, с ТМ защита, 400 А, кат. А	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.5.1	Обявен ток ( $I_n$ )	400 А	400A
4.5.2	Обявена максимална изключвателна възможност при к.с. ( $I_{cu}$ )	min 20 kA / 500 V	25kA/500V
4.5.3	Работна изключвателна възможност при късо съединение ( $I_{cs}$ )	Съгласно т. 3.7 и т. 4.4.2 Да се посочи	100% $\times I_{cu}$
4.5.4	Ток на изключване на защитата от къси съединения ( $I_i$ )	Съгласно т. 3.8.3 Да се посочи	(5-10) $\times I_n$
4.5.5	Време за изключване при $I_{cu}$	max 0,010 s	6ms
4.5.6	Износоустойчивост	-	-
4.5.6a	Електрическа (брой к.ц.)	min 1000 бр.	7 000
4.5.6b	Механична (брой к.ц.)	min 4000 бр.	20 000
4.5.7	Максимални размери ВхШхД (Дълбочината „Д“ не включва лоста за управление)	300x195x160 mm	205/140/103.5
4.5.8	Тегло, kg	Да се посочи	3.25

Наименование на материала:

Триполюсни автоматични прекъсвачи НН с лят корпус, от 160 А до 1250 А, с електронна защита, категория А

Съкратено наименование на материала:

Трип. авт. прек. НН, с ел. защита, 160-1250 А, кат. А

Област: Н – Електрически уредби СрН/НН

Категория: 17 – Комутационни апарати НН за защита

Мерна единица: Брой

Аварийни запаси: Да ...

Характеристика на материала:

Триполюсните автоматични прекъсвачи НН с лят корпус представляват механични комутационни апарати от фиксиран тип с предно свързване на шинната система. Автоматичните прекъсвачи са способни да провеждат




и да включват/изключват ръчно електрически токове във вериги при нормални условия и да включват, да провеждат за определено време и да изключват автоматично посредством защита от електронен тип токове във вериги при условията на претоварване и късо съединение.

Тялото (корпусът) на автоматичните прекъсвачи НН е изработено чрез формоване на устойчив на нагряване, на огън и на механични удари изолационен материал. Използваните в конструкцията изолационни материали съответстват на изискванията на т. 7.1. от БДС EN 60947-2:2006.

Управлението се осъществява ръчно посредством лост. Включването/изключването на контактите на трите полюса се осъществява едновременно с висока скорост, която не зависи от действията на оператора. Автоматичният прекъсвач изпълнява разединяваща функция, която е обозначена с предвидения от стандарта символ. На челния панел на прекъсвача е разположен тест-бутон за проверка на изключвателния механизъм. Лостът за управление при вертикално монтиране на автоматичните прекъсвачи се движи в направление „нагоре – надолу“, при което контактите се затварят при движение „нагоре“. Лостът има три ясно индицирани положения, съответстващи на позицията на контактната система: „Включено“, „Изключено“ и „Автоматично изключено от свръхтокове /Тест“. Конструкцията осигурява защита срещу проникване на твърди тела и вода до степен най-малко IP20 за клемните съединения и IP40 за челната повърхност на прекъсвача, съгласно БДС EN 60529+A1:2004.

Стойностите на прегряването на частите на триполюсните автоматични прекъсвачи НН с лят корпус при нормален работен режим при температура до 40 °С не трябва да надвишават посочените в таблица 7 от БДС EN 60947-2:2006 стойности. Прекъсвачите са маркирани с информацията съгласно т. 5.2 от БДС EN 60947-2:2006 и СЕ маркировка за съответствие.

Прекъсвачите се доставят с предпазни клемови капаци, изолиращи фазови сепаратори и разширители и удължители на входа и на изхода, които са подходящи за свързване към шинна система, която е изработена с алуминиеви шини с правоъгълно сечение.

По искане на възложителя прекъсвачите трябва да бъдат доставени с адапторни планки, които са съобразени с присъединителните и габаритните размери на автоматичните прекъсвачи от сериите: А100, А1, А250, А2, А2-400, А3, А4 и А5 съгласно табл. 1 и фиг. 1 по-долу, произвеждани от бившия ЕАЗ гр. Пловдив.

Триполюсните автоматични прекъсвачи са пакетирани в картонени кутии, на които е залепен етикет с наименование на материала „Автоматичен прекъсвач“, техническите данни, годината на производство, партидните номера и стандарта, в съответствие с който са произведени и изпитани - БДС EN 60947-2:2006.

#### Използване:

- Триполюсните автоматични прекъсвачи НН с лят корпус се монтират в главните разпределителни табла в трансформаторните постове и се използват за защита на силови трансформатори СрН/0,4 kV с мощност до 800 kVA.

#### Съответствие на предлаганото изпълнение с нормативно-техническите документи:

Триполюсните автоматични прекъсвачи НН с лят корпус трябва да отговарят на посочените по-долу стандарти или еквиваленти, включително на техните валидни изменения и допълнения:

- БДС EN 60947-1:2007 „Комутационни апарати за ниско напрежение. Част 1: Общи правила (IEC 60947-1:2007)“; и
- БДС EN 60947-2:2006 „Комутационни апарати за ниско напрежение. Част 2: Автоматични прекъсвачи (IEC 60947-2:2006)“ и техните валидни изменения и допълнения
- БДС EN 60529+A1:2004 Степени на защита, осигурени от обвивката (IP код) (IEC 60529:1989+A1:1999) и

да бъдат оценени положително по реда и при условията на Наредбата за съществените изисквания и оценяване на съответствието на електрически съоръжения, предназначени за използване в определени граници на напрежението (Приета с ПМС № 182 от 6.07.2001 г., обн., ДВ, бр. 62 от 13.07.2001 г., в сила от 14.01.2003 г., изм. и доп., бр. 74 от 22.08.2003 г., бр. 24 от 21.03.2006 г., в сила от 21.03.2006 г., изм., бр. 40 от 16.05.2006 г., в сила от 5.05.2006 г., изм. и доп., бр. 37 от 8.05.2007 г., изм., бр. 50 от 17.06.2014 г.).

#### Изисквания към документацията и изпитванията:

№ по ред	Документ	Приложение № или текст
1.	Точно означение на типа, производителя и страната на производство (произход) и последно издание на каталога на производителя	Приложение ТС 1-2
2.	Техническо описание и чертежи с нанесени на тях размери	Приложение ТС 2-2
3.	ЕО декларация за съответствие	Приложение ТС 3

№ по ред	Документ	Приложение № или текст
4.	Протоколи от типови изпитвания на английски или български език, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	Приложение TC 4-2
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4 – заверено копие	Приложение TC 5
6.	Техническо описание и чертежи с нанесени размери на монтажни планки, единичната цена на които не се включва в цената на прекъсвачите	Отговор на въпрос СВ-DOC-3861/31.07.2015
7.	Инструкции за транспортиране, складиране, монтиране, вкл. въртящия момент на затягане на клемовите съединения, обслужване и поддържане	Приложение TC 7

Забележка: Всички оригинални документи трябва да бъдат на български език или с превод на български език. (Каталозите и протоколите от проверките и изпитванията могат да бъдат и само на английски.)

### Технически данни:

#### 1. Характеристики на работната среда


№ по ред	Характеристика	Стойност
1.1	Място на монтиране	На закрито
1.2	Максимална околна температура	+ 40 °C
1.3	Минимална околна температура	Минус 5 °C
1.4	Максимална средна околна температура за период от 24 ч.	+ 35 °C
1.5	Относителна влажност (при 20°C)	До 90 %
1.6	Степен на замърсяване	3
1.7	Надморска височина	До 2000 m



#### 2. Параметри на електроразпределителната мрежа

№ по ред	Параметър	Стойност
2.1	Номинално напрежение	400 / 230 V
2.2	Максимално напрежение	440 / 253 V
2.3	Номинална честота	50 Hz
2.4	Брой проводници в разпределителната мрежа	4 проводна мрежа (L <sub>1</sub> , L <sub>2</sub> , L <sub>3</sub> , PEN)
2.5	Схема на разпределителната мрежа	TN-C

#### 3. Общи технически параметри и други данни

№ по ред	Технически параметър	Изискване	Гарантирано предложение
3.1	Брой на полюсите	3	3
3.2	Обявено работно напрежение ( $U_e$ )	min 690 V AC	690 V AC
3.3	Обявена честота	50 Hz	50 Hz
3.4	Обявено импулсно напрежение ( $U_{imp}$ )	min 6 kV	8 kV
3.5	Обявено изолационно напрежение ( $U_i$ )	min 690 V	1000 V
3.6	Категория на приложение	A	A
3.7	Работна изключвателна възможност при късо съединение ( $I_{cs}$ )	min 50% от $I_{cu}$	100% от $I_{cu}$
3.8	Защита от свръхтокове	-	-


№ по ред	Технически параметър	Изискване	Гарантирано предложение
3.8.1	Тип и времетокова характеристика	<p>Защитата от свръхтокове трябва да бъде от електронен тип с времетокова характеристика от показания по-долу вид:</p> 	<p>Защитата от свръхтокове е от електронен тип (PR221DS) с времетокова характеристика от показания по-долу вид:</p> 
3.8.2	Защита от претоварване	а) Диапазон на настройване $I_R = (\min 0,5 \div 1) \times I_n$	$I_R = (0,4 \div 1) \times I_n$
		б) Условен ток на неизключване $I_{nd} = 1,05 \times I_R$ във времеви интервал от 120 минути	$I_{nd} = 1,05 \times I_R$ във времеви интервал от 120 минути
		в) Условен ток на изключване $I_d = 1,30 \times I_R$ във времеви интервал до 120 минути	$I_d = 1,30 \times I_R$ във времеви интервал до 120 минути
3.8.3	Защита от къси съединения	Токът на изключване $I_i$ трябва да бъде фиксиран на една от стойностите или регулируем в диапазона препоръчително от $\min 4 \times I_n$ до $10 \times I_n$	$(1-10) \times I_n$
3.9	Степен на защита от проникване на твърди тела и вода съгласно БДС EN 60529+A1:2004	-	-
3.9.1	Клемни съединения	IP 20	IP 20
3.9.2	Челна повърхност	IP 40	IP 40
3.10	Акcesoари	а) Два комплекта разширители и удължител за свързване към шинна система от алуминиева шина с правоъгълно сечение	а) Два комплекта разширители и удължител за свързване към шинна система от алуминиева шина с правоъгълно сечение
		б) Два комплекта предпазни клемови капаци и изолиращи фазови сепаратори.	б) Два комплекта предпазни клемови капаци и изолиращи фазови сепаратори.

4. Триполюсни автоматични прекъсвачи НН с лят корпус, от 160 А ÷ 1250 А, с електронна защита, категория А  
 4.1 Триполюсен автоматичен прекъсвач НН с лят корпус, 630 А, с електронна защита, кат. А

Номер на стандарта	Тип/референтен номер съгласно каталога на производителя
20 17 6002	1SDA054396R1 T5N630 PR221DS-LS/I 3p FF
Наименование на материала	Триполюсен автоматичен прекъсвач НН с лят корпус, 630 А, с електронна защита, кат. А
Съкратено наименование на материала	Трип. авт. прек. НН, с ел. защита, 630 А, кат. А





№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.3.1	Обявен ток ( $I_n$ )	630 A	630A
4.3.2	Обявена максимална изключвателна възможност при к.с. ( $I_{cu}$ )	min 20 kA / 500 V	25kA / 500V
4.3.3	Работна изключвателна възможност при късо съединение ( $I_{cs}$ )	Съгласно т. 3.7 и т. 4.3.2 Да се посочи	100% $\times I_{cu}$
4.3.4	Ток на изключване на защитата от къси съединения ( $I_i$ )	Съгласно т. 3.8.3 Да се посочи	(1-10) $\times I_n$
4.3.5	Време за изключване при $I_{cu}$	max 0,010 s	6ms
4.3.6	Износоустойчивост	-	-
4.3.6a	Електрическа (брой к.ц.)	min 1000 бр.	5 000
4.3.6b	Механична (брой к.ц.)	min 4000 бр.	20 000
4.3.7	Максимални размери ВхШхД (Дълбочината „Д“ не включва лоста за управление)	290x215x160 mm	205/140/103.5
4.3.8	Тегло, kg	Да се посочи	3.25

#### 4.2 Триполюсен автоматичен прекъсвач НН с лят корпус, 1000 А, с електронна защита, кат. А

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 17 6003		1SDA060561R1 T6H 1000 PR221DS-LS/I 3p FF	
Наименование на материала		Триполюсен автоматичен прекъсвач НН с лят корпус, 1000 А, с електронна защита, кат. А	
Съкратено наименование на материала		Трип. авт. прек. НН, с ел. защита, 1000 А, кат. А	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.4.1	Обявен ток ( $I_n$ )	1000 A	1000A
4.4.2	Обявена максимална изключвателна възможност при к.с. ( $I_{cu}$ )	min 45 kA / 500 V	50kA / 500V
4.4.3	Работна изключвателна възможност при късо съединение ( $I_{cs}$ )	Съгласно т. 3.7 и т. 4.4.2 Да се посочи	100% $\times I_{cu}$
4.4.4	Ток на изключване на защитата от къси съединения ( $I_i$ )	Съгласно т. 3.8.3 Да се посочи	(1-10) $\times I_n$
4.4.5	Време за изключване при $I_{cu}$	max 0,030 s	8ms
4.4.6	Износоустойчивост	-	-
4.4.6a	Електрическа (брой к.ц.)	min 500 бр.	4 000
4.4.6b	Механична (брой к.ц.)	min 2500 бр.	20 000
4.4.7	Максимални размери ВхШхД (Дълбочината „Д“ не включва лоста за управление)	375x210x160 mm	268/210/103.5mm
4.4.8	Тегло, kg	Да се посочи	9.5

#### 4.3 Триполюсен автоматичен прекъсвач НН с лят корпус, 1250 А, с електронна защита, кат. А

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 17 6004		1SDA062898R1 T7H 1250 PR231/P LS/I 3p FF	
Наименование на материала		Триполюсен автоматичен прекъсвач НН с лят корпус, 1250 А, с електронна защита, кат. А	
Съкратено наименование на материала		Трип. авт. прек. НН, с ел. защита, 1250 А, кат. А	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.5.1	Обявен ток ( $I_n$ )	1250 A	1250A
4.5.2	Обявена максимална изключвателна възможност при к.с. ( $I_{cu}$ )	min 45 kA / 500 V	50kA / 500V

4.5.3	Работна изключвателна възможност при късо съединение ( $I_{cs}$ )	Съгласно т. 3.7 и т. 4.5.2 Да се посочи	100% $I_{cu}$
4.5.4	Ток на изключване на защитата от къси съединения ( $I_i$ )	Съгласно т. 3.8.3 Да се посочи	(1-10) $I_n$
4.5.5	Време за изключване при $I_{cu}$	max 0,030 s	10ms
4.5.6	Износоустойчивост	-	-
4.5.6a	Електрическа (брой к.ц.)	min 500 бр.	4 000
4.5.6b	Механична (брой к.ц.)	min 2500 бр.	20 000
4.5.7	Максимални размери ВхШхД (Дълбочината „Д“ не включва лоста за управление)	375x210x160 mm	268/210/154mm
4.5.8	Тегло, kg	Да се посочи	9.5

07.08.2015 г.



Участник: ИНТЕРКОМПЛЕКС ООД

Гизар Узунян - управител

**Приложение ТС 1-1**  
**към Технически спецификации**  
**за обособена позиция 1**  
**от процедура PPD 15-033**

**Точно означение на типа, производителя и страната на производство  
 на триполюсни товари прекъсвач-разединители НН с лят корпус**

№	НАИМЕНОВАНИЕ	ТИП	ПРОИЗВОДИТЕЛ И СТРАНА НА ПРОИЗХОД
1	Триполюсен автоматичен прекъсвач НН с лят корпус, 100 А, с термомангнитна защита, кат.А;	<b>XT1C 160 TMD 100-1000 3p F F</b>	<b>ABB SACE, Италия</b>
2	Триполюсен автоматичен прекъсвач НН с лят корпус, 160 А, с термомангнитна защита, кат.А;	<b>XT1C 160 TMD 160-1600 3p F F</b>	
3	Триполюсен автоматичен прекъсвач НН с лят корпус, 250 А, с термомангнитна защита, кат.А;	<b>XT3N250 TMD 250-2500 3p F F</b>	
4	Триполюсен автоматичен прекъсвач НН с лят корпус, 400 А, с термомангнитна защита, кат.А;	<b>T5N400 TMA 400A 3P FF</b>	

07.08.2015 г.

Кандидат: ИНТЕРКОМПЛЕКС ООД



.....  
 Ехиязар Узунян - управител

Handwritten signatures and initials: "an", "K", "H", "L", "Luz" (bottom right)



Приложение ТС 1-2  
 към Технически спецификации  
 за обособена позиция 1  
 от процедура PPD 15-033

Точно означение на типа, производителя и страната на производство  
 на триполюсни товари прекъсвач-разединители НН с лят корпус

№	НАИМЕНОВАНИЕ	ТИП	ПРОИЗВОДИТЕЛ И СТРАНА НА ПРОИЗХОД
1	Триполюсен автоматичен прекъсвач НН с лят корпус, 630 А, с електронна защита, кат.А;	T5N630 PR221DS-LS/I 3p FF	ABB SACE, Италия
2	Триполюсен автоматичен прекъсвач НН с лят корпус, 1000 А, с електронна защита, кат.А;	T6H 1000 PR221DS-LS/I 3p FF	
3	Триполюсен автоматичен прекъсвач НН с лят корпус, 1200 А, с електронна защита, кат.А;	T7H 1250 PR231/P LS/I 3p FF	

07.08.2015 г.



Кандидат: ИНТЕРКОМПЛЕКС ООД

Ехиязар Узунян - управител

*Handwritten signatures and initials*

**Приложение ТС 2-1**  
**към Технически спецификации**  
**за обособена позиция 1**  
**от процедура PPD 15-033**

**Техническо описание и чертежи с нанесени на тях размери**  
**на триполюсни автоматични прекъсвачи НН с лят корпус,**  
**с термомагнитна защита, кат.А**

Триполюсните автоматични прекъсвачи НН с лят корпус представляват механични комутационни апарати от фиксиран тип с предно свързване на шинната система.

Автоматичните прекъсвачи са способни да провеждат и да включват/изключват ръчно електрически токове във вериги при нормални условия и да включват, да провеждат за определено време и да изключват автоматично посредством електромеханична защита от термомагнитен тип токове във вериги при условията на претоварване и късо съединение.

Тялото (корпусът) на автоматичните прекъсвачи НН е изработено чрез формоване на устойчив на нагряване, на огън и на механични удари изолационен материал. Използваните в конструкцията изолационни материали съответстват на изискванията на т. 7.1. от БДС EN 60947-2:2006.


Управлението се осъществява ръчно посредством лост. Включването/изключването на контактите на трите полюса се осъществява едновременно с висока скорост, която не зависи от действията на оператора. Автоматичният прекъсвач изпълнява разединяваща функция, която е обозначена със съответния символ. На челния панел на прекъсвача е разположен тест-бутон за проверка на изключвателния механизъм.

Лостът за управление при вертикално монтиране на автоматичните прекъсвачи се движи в направление „нагоре – надолу”, при което контактите се затварят при движение „нагоре”. Лостът има три ясно индицирани положения, съответстващи на позицията на контактната система: „Включено”, „Изключено” и „Автоматично изключено от свръхтокове /Тест”. Конструкцията осигурява защита срещу проникване на твърди тела и вода до степен най-малко IP20 за клемните съединения и IP40 за челната повърхност на прекъсвача, съгласно БДС EN 60529+A1:2004.

Стойностите на прегряването на частите на триполюсните автоматични прекъсвачи НН с лят корпус при нормален работен режим при температура до 40°C не трябва да надвишават посочените в таблица 7 от БДС EN 60947-2:2006 стойности. Прекъсвачите са маркирани с информацията съгласно т. 5.2 от БДС EN 60947-2:2006 и СЕ маркировка за съответствие.

Прекъсвачите се доставят с предпазни клемови капацы, изолиращи фазови сепаратори и разширители и удължители на входа и на изхода, които са подходящи за свързване към шинна система, която е изработена с алуминиеви шини с правоъгълно сечение.

- Триполюсните автоматични прекъсвачи НН с лят корпус се монтират в разпределителни табла в трансформаторните постове и се използват за защита на електропроводните линии.



Триполюсните автоматични прекъсвачи НН с лят корпус отговарят на посочените по-долу стандарти, включително на техните валидни изменения и допълнения:

- EN 60947-1:2007 "Комутационни апарати за ниско напрежение. Част 1: Общи правила (IEC 60947-1:2007)"; и
- EN 60947-2:2006 „Комутационни апарати за ниско напрежение. Част 2: Автоматични прекъсвачи (IEC 60947-2:2006)“ и техните валидни изменения и допълнения и
- EN 60529+A1:2004 Степени на защита, осигурени от обвивката (IP код) (IEC 60529:1989+A1:1999)


Подробни чертежи с нанесени размери има в приложения каталог – раздел 6, стр. 1/62+стр. 62/62.

07.08.2015 г.



Кандидат: ИНТЕРКОМПЛЕКС ООД

.....  
Ехиязар Узунян - управител



**Приложение ТС 2-2**  
**към Технически спецификации**  
**за обособена позиция 1**  
**от процедура PPD 15-033**

**Техническо описание и чертежи с нанесени на тях размери**  
**на триполюсни автоматични прекъсвачи НН с лят корпус, от 160 А до 1250 А, с електронна**  
**защита, категория А**

Триполюсните автоматични прекъсвачи НН с лят корпус представляват механични комутационни апарати от фиксиран тип с предно свързване на шинната система. Автоматичните прекъсвачи са способни да провеждат и да включват/изключват ръчно електрически токове във вериги при нормални условия и да включват, да провеждат за определено време и да изключват автоматично посредством защита от електронен тип токове във вериги при условията на претоварване и късо съединение.

Тялото (корпусът) на автоматичните прекъсвачи НН е изработено чрез формоване на устойчив на нагряване, на огън и на механични удари изолационен материал. Използваните в конструкцията изолационни материали съответстват на изискванията на т. 7.1. от БДС EN 60947-2:2006.


Управлението се осъществява ръчно посредством лост. Включването/изключването на контактите на трите полюса се осъществява едновременно с висока скорост, която не зависи от действията на оператора. Автоматичният прекъсвач изпълнява разединяваща функция, която е обозначена с предвидения от стандарта символ. На челния панел на прекъсвача е разположен тест-бутон за проверка на изключвателния механизъм. Лостът за управление при вертикално монтиране на автоматичните прекъсвачи се движи в направление „нагоре – надолу“, при което контактите се затварят при движение „нагоре“. Лостът има три ясно индицирани положения, съответстващи на позицията на контактната система: „Включено“, „Изключено“ и „Автоматично изключено от свръхтокове /Тест“.

Конструкцията осигурява защита срещу проникване на твърди тела и вода до степен най-малко IP20 за клемните съединения и IP40 за челната повърхност на прекъсвача, съгласно БДС EN 60529+A1:2004.

Стойностите на прегряването на частите на триполюсните автоматични прекъсвачи НН с лят корпус при нормален работен режим при температура до 40°C не трябва да надвишават посочените в таблица 7 от БДС EN 60947-2:2006 стойности. Прекъсвачите са маркирани с информацията съгласно т. 5.2 от БДС EN 60947-2:2006 и СЕ маркировка за съответствие.

Прекъсвачите се доставят с предпазни клемови капаци, изолиращи фазови сепаратори и разширители и удължители на входа и на изхода, които са подходящи за свързване към шинна система, която е изработена с алуминиеви шини с правоъгълно сечение.

Триполюсните автоматични прекъсвачи са пакетирани в картонени кутии, на които е залепен етикет с наименование на материала „Автоматичен прекъсвач“, техническите данни, годината на производство, партидните номера и стандарта, в съответствие с който са произведени и изпитани - БДС EN 60947-2:2006.




- Триполюсните автоматични прекъсвачи НН с лят корпус се монтират в главните разпределителни табла в трансформаторните постове и се използват за защита на силови трансформатори СрН/0,4 kV с мощност до 800 kVA.

Триполюсните автоматични прекъсвачи НН с лят корпус отговарят на посочените по-долу стандарти, включително на техните валидни изменения и допълнения:

- EN 60947-1:2007 “Комутационни апарати за ниско напрежение. Част 1: Общи правила (IEC 60947-1:2007)”; и
- EN 60947-2:2006 „Комутационни апарати за ниско напрежение. Част 2: Автоматични прекъсвачи (IEC 60947-2:2006)” и техните валидни изменения и допълнения и
- EN 60529+A1:2004 Степени на защита, осигурени от обвивката (IP код) (IEC 60529:1989+A1:1999)

Подробни чертежи с нанесени размери има в приложения каталог – раздел 6, стр. 1/62÷стр. 62/62.

07.08.2015 г.



Приложение ТС 3  
към Технически спецификации  
от процедура PPD 15-033

## ЕО ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният **Ехиязар Гарабед Узунян**, притежаващ лична карта № 643235253, издадена на 15.11.2011 от МВР, гр. Пловдив, с ЕГН 5105294446, адрес: гр. Пловдив, ул. Елин Пелин" 26, в качеството ми на управител на ИНТЕРКОМПЛЕКС ООД, със седалище и адрес на управление: гр. Пловдив, бул. Пещерско шосе № 201, вписано в Търговския регистър към Агенцията по вписванията с ЕИК 115096057, във връзка с участие в открита процедура за сключване на рамково споразумение за възлагане на обществени поръчки с предмет: **Доставка на прекъсвачи ниско напрежение; Реф. № PPD 15-033**

### ДЕКЛАРИРАМ:

Предлаганите от ИНТЕРКОМПЛЕКС ООД автоматични прекъсвачи НН с термомангнитна и електронна защита, както и товарите прекъсвач-разединители НН, производство на ABB SACE – Италия, от сериите Tmax и Tmax XT са в съответствие със следните европейски директиви:

Директива за ниско напрежение 2006/95/ЕС

Директива за електромагнитна съвместимост 2004/108/ЕС

Прекъсвачите са произведени и изпитани за съответствие със стандартите:

EN 60947-1; EN 60947-2; EN 60947-2; EN 60847EN 50081-1; EN 50081-2; EN 50082-1;

DIN EN 60947-2

Правя настоящата декларация на основание предоставените ми документи от производителя и АББ България ЕООД.

Известно ми е, че за за посочване на неверни данни нося наказателна отговорност по чл. 313 от Наказателния кодекс.

07.08.2015 г.



Декларатор: .....

Ехиязар Гарабед Узунян



## ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Ние АББ България ЕООД  
София 1592, бул. Хр. Колумб N:9

Декларираме че продуктите:

**Прекъсвачите с лят корпус и разединители на SACE Tmax и Tmax XT**

Тип: XT1C 160 TMD, XT3N 250 TMD, T5N 400 TMA, T5N 630 PR221DS-LS/I, T6H 1000 PR221DS-S/I, T7H 1250 PR231/P LS/I, XT1D 160 3p F F, XT3D 250 3p F, T5D 400 3p F F, T6D 630 3p F F

аксесоари и устройства към тях  
изпълняват следните ЕС – Директиви:

**Директива за ниско напрежение 2006/95,**


**Директива за електромагнитна съвместимост 2004/108/CE**


Проверени за съответствие с посочените по-долу стандарти:

**EN 60947-1, EN 60947-2, EN 50081-1, EN 50081-2, EN 50082-1, EN60947-3**

**DIN EN 60947-2** (стандарт, обхващащ А, В, С, N, S характеристики на изключване),

София,  
06.08.2015

  
Иво Глушков  
/Продуктов Мениджър/

  
Басил Такев  
/Старши Мениджър Продажби/

АББ България ЕООД  
Адрес на управление:  
бул. „Христофор Колумб“ № 9, ет. 3  
София 1592, България  
тел.: (+359 2)8075500, 8075600, 8075700  
факс: (+359 2)8075599 (8,7,6)  
уеб страница: [www.abb.bg](http://www.abb.bg)  
ел. поща: [office@bg.abb.com](mailto:office@bg.abb.com)

ЕИК: 831133152  
Ид. номер по ЗДДС: BG 831133152  
Банкови данни:  
ИНГ Банк, клон София  
IBAN: BG13INGB91451000027317 (BGN)  
IBAN: BG60INGB91451400027311 (EUR)  
BIC: INGBBGSF

Производство и офис:  
ул. „Варна“ № 1,  
Петрич 2850, България  
тел.: (+359 745) 69212/ 14  
факс: (+359 745) 69228/ 29/ 39  
Банкови данни:  
Уникредит Булбанк, клон Петрич  
IBAN: BG91UNCRR96601058227914 (BGN)  
IBAN: BG22UNCRR9660125822792 (EUR)  
BIC: UNCRBGSF



## Type Approval Certificate

This is to certify that the undernoted products have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

<b>PRODUCER</b>	ABB Sace S.p.A Via Biaioni 35 24123 Bergamo Italy
<b>PLACE OF PRODUCTION</b>	Via Enrico Fermi 14 03100 Frosinone Italy
<b>DESCRIPTION</b>	Moulded case circuit breakers
<b>TYPE</b>	Tmax XT1, XT3, equipped with thermal-magnetic release TMD/TMA Tmax XT2, XT4, equipped with thermal-magnetic release or Ekip microprocessor based electronic releases: software version 1.20 (Ekip LSI and LSIG), 2.07 (Ekip LS/I, Ekip I, Ekip M-LIU).
<b>APPLICATION</b>	Marine, Offshore and Industrial applications for use in environmental categories ENV1, ENV2 and ENV3 as detailed in LR Type Approval Test Specification No. 1: 2002.
<b>SPECIFIED STANDARD</b>	IEC 60947-1: 2011 IEC 60947-2: 2006
<b>ADDITIONAL TESTS</b>	Low Temperature, -25°C ±2.5°C for 16 hours

<b>Certificate No.</b>	12/00065
<b>Issue Date</b>	10 October 2012
<b>Expiry Date</b>	9 October 2017
<b>Sheet</b>	1 of 3

Lloyd's Register EMEA  
71 Fenchurch Street, London EC3M 4BS

P. Scialoja  
London Design Support Office  
Lloyd's Register EMEA



*[Handwritten signature]*

*[Handwritten signature]* 20




## RATINGS

Tmax Type	Rated Current In at 45°C (A)	Voltage 50-60Hz (V)	Power factor	Peak Making Icm (kA)	Short Circuit	
					Ultimate S/C Breaking Capacity Icu (kA)	Service S/C Breaking Capacity Ics (kA)
XT1B	160	240	0,19	52,5	25	25
XT1C	160	240	0,19	84	40	40
XT1N	160	240	0,19	143	65	50
XT1S	160	240	0,19	187	85	64
XT1H	160	240	0,19	220	100	75
XT2N	160	240	0,14	143	65	65
XT2S	160	240	0,14	187	85	85
XT2H	160	240	0,14	220	100	100
XT2L	160	240	0,14	330	150	150
XT2V	160	240	0,14	440	200	200
XT2N	160	440	0,19	75,6	36	36
XT2S	160	440	0,19	105	50	50
XT2H	160	440	0,19	143	65	65
XT2L	160	440	0,19	220	100	100
XT2V	160	440	0,19	330	150	150
XT2N	160	690	0,29	17	10	10
XT2S	160	690	0,29	24	12	12
XT2H	160	690	0,29	30	15	15
XT2L	160	690	0,29	36	18	18
XT2V	160	690	0,29	40	20	15
XT3N	250	440	0,21	52,5	25	19

Certificate No. 12/00065  
 Issue Date 10 October 2012  
 Expiry Date 9 October 2017  
 Sheet 2 of 3

Lloyd's Register EMEA  
 71 Fenchurch Street, London EC3M 4BS

P. Scallan  
 London Design Support Office  
 Lloyd's Register EMEA



This is a copy of an electronic document. In the event of any discrepancy between this copy and the electronic document, which is retained and published by Lloyd's Register, the electronic document shall always prevail.

ОПУТНААА

Tmax Type	Rated Current In at 45°C (A)	Voltage 50-60Hz (V)	Power factor	Peak Making Icm (kA)	Short Circuit	
					Ultimate S/C Breaking Capacity Icu (kA)	Service S/C Breaking Capacity Ics (kA)
XT3S	250	440	0,23	84	40	20
XT3N	250	690	0,7	7,85	5	4
XT4N	250	240	0,14	143	65	65
XT4S	250	240	0,14	187	85	85
XT4H	250	240	0,14	220	100	100
XT4L	250	240	0,14	330	150	150
XT4V	250	240	0,14	440	200	200
XT4N	250	440	0,19	75,6	36	36
XT4S	250	440	0,19	105	50	50
XT4H	250	440	0,19	143	65	65
XT4L	250	440	0,19	220	100	100
XT4V	250	440	0,19	330	150	150
XT4N	250	690	0,21	17	10	10
XT4S	250	690	0,21	24	12	12
XT4H	250	690	0,21	30	15	15
XT4L	250	690	0,21	40	20	20
XT4V	250	690	0,21	52,5	25	20

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. 12/00065 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Certificate No. 12/00065  
 Issue Date 10 October 2012  
 Expiry Date 9 October 2017  
 Sheet 3 of 3

P. Scialla  
 London Design Support Office  
 Lloyd's Register EMEA



Lloyd's Register EMEA  
 71 Fenchurch Street, London EC3M 4BS

This is a copy of an electronic document. In the event of any discrepancy between the printed and electronic versions, the electronic version shall always prevail.

ОПТИМААА

01 22



ASSOCIAZIONE PER LA CERTIFICAZIONE  
DELLE APPARECCHIATURE ELETTRICHE

V.le della Brigata Partigiana 6/21 - 16129 - GENOVA (Italy)  
tel. +10/565197 fax. +10/5848807 e-mail: acaecon@lin.it



## Certificate of Conformity

LOVAG-Certificate No. IT 00.032

### Apparatus

Moulded case Three Pole Air-break Independent-operation Circuit-breakers  
Frame size 250 A - 800 V (U<sub>n</sub>) - 50/60 Hz - with short-circuit and overload releases;

I<sub>n</sub> = 250 A

### Designation

T3N

### Manufacturer or responsible vendor

ABB SACE S.p.A. - Via Baloni, 35 - 24123 Bergamo (Italy)

Tested for: ABB SACE S.p.A. - Via Baloni, 35 - 24123 Bergamo (Italy)

Tested by: ACAE Laboratory IA.01

The apparatus, constructed in accordance with the description mentioned in the Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60947-2 (1995), Corrigendum (1997) and Amendment 1 (1997).

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated below.

Utilization category A

Test sequence: III


U<sub>n</sub> = 415 V I<sub>n</sub> = 36 kA

This document includes Report No.: 00.305/T01

Issue Date: 2000.09.18

Responsible Certification Body

Authorized Signature  
Date: 2000.12.19



ДАТНУЛ  
ОРУТУНАА

LOVAG  
Low Voltage Agreement Group

Page 1 / 34

## Test Report No. 00.305 / T 01

Test laboratory: ACAE IA.01

Client: ABB SACE S.p.A.

Manufacturer: ABB SACE S.p.A.

Test object: Low voltage moulded case c.b. series TMAX

Type designation: T3N

Date(s) of test(s): from 2000.08.01 to 2000.09.15

Test specification: IEC 60947-2 (1995), Corrigendum (1997) and Amendment 1 (1997)

Test sequence(s): III

Test results: Icu at 415 V found in compliance with rated characteristics

The Record of Proving Test consists of:

34 pages LOVAG test report forms 5 oscillograms included

no other pages drawing nr. RH0013.309 issued 00.02.14 enclosed

1 diagram included 1 photograph included

Date of issue: 2000.09.18

Signatures: *Roberto Spadolini*  
(Authorized representative)

Responsible Test Laboratory

*Alleguano*

Note:  
The test result relates only to the forms tested.  
The test report shall not be reproduced except in full  
without the written approval of the test laboratory.

F 947-2/1 ind 2

*[Handwritten signature]*

ВАРНО С  
ОРИГИНАЛ

*[Handwritten signature]* 2A

LOVAG

Description and characterization of the test object

Characteristics  
Type of circuit-breaker:  
Number of poles 3  
Kind of current a.c.  
Number of phases 3  
Rated frequency 50 - 60 Hz  
Utilization category A  
Reference temperature 40 °C  
Suitability for isolation Yes

Rated and limiting values; (according to test volume)

Main circuit:  
Rated impulse withstand voltage  $U_{imp}$  8 kV  
Rated insulation voltage  $U_i$  800 V  
Conventional thermal current  $I_n / I_{thp}$  250 A / -  
Rated current  $I_n$  250 A

Rated current in the neutral pole

Short-circuit characteristics:

$U_p/V$	$I_{em}/kA$	$I_{sc}/kA$	$I_{sw}/kA$	$I_{st}/kA$	$I_{tr}/kA$
220/230	105	50	37,5	-	-
380/415	75,6	36	27	-	-
440	52,5	25	18,8	-	-
500	40	20	15	-	-
690	7,7	5	3,8	-	-

Authorized representative  
*[Signature]*



LOVAG

Control circuits:

Electrical control circuits:

Kind of current -  
Rated frequency -  
Rated control circuit voltage  $U_c$  -  
Rated control supply voltage  $U_s$  -  
Rated impulse withstand voltage  $U_{imp}$  -  
Rated insulation voltage  $U_i$  -

Air-supply control circuits:

Rated supply pressure -  
Limits of pressure -  
Required volume for each closing operation -  
Required volume for each opening operation -

Auxiliary circuits:

Rated operational voltage  $U_o$  -  
Rated impulse withstand voltage  $U_{imp}$  -  
Rated insulation voltage  $U_i$  -

Rated frequency

Rated operational current  $I_e$

Number of circuits

Number and kind of contact elements

Authorized representative  
*[Signature]*

**LOVAG**

Test report No.: 00.305 / T 01  
Page 4 / 34

**Releases:**

- Shunt release:
  - Rated control circuit voltage  $U_c$
  - Kind of current
  - Rated frequency if a.c.
- Undervoltage or no-voltage release
  - Rated control circuit voltage  $U_c$
  - Kind of current
  - Rated frequency if a.c.
- Over-current release:
  - Short-circuit release
    - Instantaneous release
    - definite time-delay release
  - Rated current  $I_n$
  - Kind of current
  - Rated frequency if a.c.
  - Current setting (or range of settings)
  - Time setting (or range of settings)
- Overload release (IEC 60947-1; 2.4.30):
  - Instantaneous release
  - definite time-delay release
  - inverse time-delay release
  - dependent on ambient air temperature
  - independent of ambient air temperature
- Reference temperature
  - Rated current  $I_n$
  - Kind of current
  - Rated frequency if a.c.
  - Current setting (or range of settings)
  - Time setting (or range of settings)

Yes

32 A to 250 A  
a.c.  
50 - 60 Hz  
from 500 A up to 2500 A

40 °C  
32 A to 250 A  
a.c.  
50 - 60 Hz  
22 A to 32 A and  
175 A to 250 A



F 947-2/4 ind 1

Date 00.08.18

Authorized representative

*M*

ВЯРНО С  
ОРИГИНАЛ



*25*

**LOVAG**

Test report No.: 00.305 / T 01  
Page 5 / 34

**Time / current characteristics settings R32**

Type designation : T3N



Test laboratory: ACAE (A.01)

Authorized representative



Date 00.09.18

F 947-2/5 ind 1

*M*

Time / current characteristics: settings R250

Type designation: T3N



*Handwritten signature*



ВЯРНО С  
ОРИГИНАЛ  
*Handwritten signature* 26

Integral fused circuit-breakers:  
(Co-ordination with short-circuit protective devices)

- Kind of protective devices
- Type of fuse
- Maximum operational voltage
- Rated current  $I_n$
- Maximum prospective short-circuit peak current

Switching overvoltages:  
(Characteristics not defined)

Individual enclosure:

- Type
- Kind of material
- Degree of protection
- Inside dimensions (in millimetres)  
height
- width
- depth

When no enclosure:

- Safety perimeter defined:  
height 220 mm
- width 155 mm
- depth 70 mm
- Kind of screen (woven wire mesh, perforated metal, expanded metal) metal sheet
- Size of holes ( $\leq 30 \text{ mm}^2$ ) yes
- Distance during test -

Openings around the manual operating means:




Openings in the area of the manual operating means through which the arc chamber can be reached by a music wire of 0.25 mm diameter. No

*Handwritten signature*

Test report No.: 00.305 / T 01  
Page 8 / 34  
Type: T3N

LOVAG  
Type test according to: IEC 60947-2

INSTALLATION INSIDE METAL ENCLOSURE FOR SHORT-CIRCUIT TESTS



- A: VISTA FRONTALE CON COPERTINO
- B: VISTA FRONTALE SENZA COPERTINO
- C: VISTA LATERALE SINISTRA
- D: VISTA LATERALE DESTRA
- E: AREA FRONTALE 10T, 0,6
- F: AREA REAR/10T, AREA-0,6

GRABARE SENZA FERRITORE ECCETTO PARTE I  
E DISEGNARE SENZA FERRITORE ECCETTO VALLI 1

F 947-2/73 ind 0

Date 00.09.18

Authorized representative



ВЯРНО С  
ОРИГИНАЛ

28

LOVAG

Type test according to: IEC 60947-2

Test report No. 00.305 / T 01  
Page 9 / 34  
Type: T3N

SAMPLE UNDER TEST

Sample	Serial number	In (A)	Test sequence	Test result at page	Delivery term of the sample to the laboratory
1	0219	32	III	11	31.07.00
2	0215	250	III	18	31.07.00

REFERENCE DRAWINGS

Nr. Drawings	Denomination	issue status
RA 0450.801-834	Standard circuit breaker assembly	99.05.19
RA 0450	Material list	99.05.19
RA 0457.801	Case assembly	99.05.19
RA 0457	Material list	99.05.19
RA 0458	Cover	99.05.19
RA 0531	Trip shaft assembly	99.05.19
RA 0487.801-802	Moving contact assembly	99.05.19
RA 0487	Material list	99.05.19
RA 0497	Moving contact plate	99.05.19
RA 0470.801	Operating mechanism assembly	99.05.19
RA 0470	Material list	99.05.19
RA 0493	Operating mechanism spring	99.05.19
RA 0505.801	Arching chamber assembly	99.05.19
RA 0505	Material list	99.05.19
RA 0512.801	Fixed contact assembly	99.05.19
RA 0512	Material list	99.05.19
RA 0510	Fixed contact plate	99.05.19
RA 0519.801-810	Relay assembly	99.05.19
RA 0519	Material list	99.05.19
RA 0720.801	Clamp assembly	99.05.19
RA 0720	Material list	99.05.19

Test laboratory: ACAE IA.01

Authorized representative

Date 00.09.18

F 947-2/73 ind 0

<b>LOVAG</b>		Test report No.: 00.305 / T 01 Page 10 / 34
Type test according to: IEC 60947-2		Type: T3N
<b>TEST SEQUENCE III</b>		
Rated ultimate short-circuit breaking capacity		
Test sequence III comprises the following tests:		
<b>Sub-clause</b>	<b>Test</b>	<b>Pageform</b>
8.3.5.1	Verification of overload releases	F 947-2/41
8.3.5.2	Rated ultimate short-circuit breaking capacity Additional sequence of short-circuit operations on four-pole circuit-breakers (if applicable)	F 947-2/42, + F 947-2/36 F 947-2/43 - F 947-2/44
8.3.5.3	Verification of dielectric withstand	F 947-2/27
8.3.5.4	Verification of leakage current (if applicable) Verification of overload releases	F 947-2/20 F 947-2/41



ВЯРНО С  
ОРИГИНАЛА

<b>LOVAG</b>		Test report No.: 00.305 / T 01 Page 11 / 34
Type test according to: IEC 60947-2		Type: T3N
Test sequence III		
<b>Standard and clause</b>	<b>Kind of tests and requirements</b>	<b>Test values Results</b>
60947-1 Table IX, X and XI	<b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b>	
Cabling characteristics		6 mm <sup>2</sup>
Cable		- X - mm
Bar	6 mm <sup>2</sup>	1
Number	- X - mm	2000 mm
Length	1	10 Nm
Tightening torque	2000 mm	
Reference temperature	40 °C ± 2 °C	40 °C
Ambient temperature	k	-
Correction factor	h	22 A
(k = 1, for release independent of ambient temperature)		
Current setting value		
<b>Test current</b>		
either k x 2.0 x I <sub>n</sub>		44 A
Test sequence II (I <sub>cs</sub> = I <sub>cm</sub> )	before 8.3.4.1	
Test sequence III,	before 8.3.5.2	
Test sequence IV,	before 8.3.6.2	
Test sequence V,	after 8.3.6.5	
Test sequence VI,	before 8.3.7.5	
Combined test sequence	before 8.3.8.2	
or k x 2.5 x I <sub>n</sub>		- A
Test sequence II (I <sub>cs</sub> = I <sub>cm</sub> )	after 8.3.4.4	
Test sequence III,	after 8.3.5.3	
Test sequence V,	after 8.3.7.7	
Combined test sequence	after 8.3.8.6	
Individual pole short-circuit test sequence		
Test sequence for circuit-breakers for IT-systems		
<b>Tripping time</b>		
(for twice the value of current setting on single pole)		282 s
Ph <sub>1</sub>	± 310 s	285 s
Ph <sub>2</sub>	± 310 s	266 s
Ph <sub>3</sub>	± 310 s	
Test laboratory: ACAE IA.01	Authorized representative	F 947-2/41 Ind 2
	Date: 00.09.18	

*[Handwritten signature]*

*[Handwritten signature]*



LOVAG		Test report No.: 00.305 / T 01 Page 12 / 34	Test report No.: 00.305 / T 01 Page 13 / 34
Type test according to: IEC 60947-2 Test sequence III		Type: T3N	Type: T3N
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.5.2	<b>RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY</b>  Utilization category A  Rated operational voltage $U_n$ 415 V Recovery voltage $1.05 \times U_n$ Rated ultimate short-circuit breaking capacity $I_{cu}$ 436 V Rated short-circuit making capacity $I_{cm}$ 38,7 kA 76,3 kA  Power factor 0,25 Frequency 50 Hz  Control supply voltage $0.85 \times U_n - V$ Maximum value of the closing time  Sequence of operation O - t - CO Circuit diagram O - t - CO Calibration of the test circuit  Safety area Pageform 6 Installation of the material tested Pageform 73 Energization direction Top/Bottom  Smallest individual enclosure (if applicable) Type Kind of material Inside dimensions Height Width Depth  Cabling characteristics Cable 6 mm <sup>2</sup> Bar - x - mm Number 1 Length supply side 500 mm load side 250 mm Tightening torque 10 Nm	436 V 38,7 kA 76,3 kA  0,25 50 Hz  - V - ms  O - t - CO Page 26 / 34 Page 13 / 34  Page 7 / 34 Page 8 / 34 Top  - mm - mm - mm  6 mm <sup>2</sup> - x - mm 1 500 mm 250 mm 10 Nm	
8.3.2.1			

LOVAG		Test report No.: 00.305 / T 01 Page 13 / 34	Test report No.: 00.305 / T 01 Page 13 / 34
Type test according to: IEC 60947-2		Type: T3N	Type: T3N
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 8.3.4.1.5	<b>CALIBRATION OF THE TEST CIRCUIT (*)</b>  Oscillogram  Applied voltage 438 V  Frequency 50 Hz  RMS current value At 20 ms $i_1$ $i_2$ $i_3$ 36,5 kA 36,9 kA 36,7 kA  Average RMS Value 36,7 kA  Peak current maximum value 76,3 kA  Power factor 0,23  (*) Description of the method for determination of short-circuit power factor is given at page 25 / 34		Page 28 / 34  438 V  50 Hz  36,5 kA 36,9 kA 36,7 kA  36,7 kA  76,3 kA  0,23

Test laboratory: SCAE IA.01  
Date 00.09.18  
Authorized representative  
F 947-2/72 Ind 0



ВРНО С  
ОРИГОНАЛ 29

<b>LOVAG</b>		Test report No.: 00.305 / T 01 Page 15 / 34
Type test according to: IEC 60947-2 Test sequence III		Type: T3N
Standard and clause	Kind of tests and requirements	Test values Results
8.3.3.5 8.3.4.2 8.3.5.3 8.3.6.5 8.3.7.3 8.3.7.7 8.3.8.4 C.3 B.10.3.1 H.3	<b>VERIFICATION OF DIELECTRIC WITHSTAND</b>  Test voltage 2 x U <sub>n</sub> , min. 1000 V Test sequence I Test sequence II Test sequence III Test sequence IV Test sequence V, stage 1 Test sequence V, stage 2 Combined test sequence Individual pole short-circuit test sequence Test sequence B.11 Test sequence for circuit-breakers for IT-systems  Application of the test voltage - Main circuit of the circuit-breaker - Isolating contacts of the withdrawable unit (if applicable)  Test duration 1 min 1 min	1000 V 1000 V 1 min 1 min
8.3.3.2.2 a)		

F 947-2/27 no 2

Authorized representative  
Date 00.09.18

Test laboratory: ACAE IA.01

<b>LOVAG</b>		Test report No.: 00.305 / T 01 Page 14 / 34
Type test according to: IEC 60947-2 Test sequence III		Type: T3N
Standard and clause	Kind of tests and requirements	Test values Results
7.2.1.1.3	<b>OPERATION „O“</b> Oscillogram Peak current value Maximum total duration Recovery voltage (phase to phase or phase to neutral) Average Ratio between U <sub>m</sub> and U <sub>n</sub> Joule integral Melting of the fusible element Holes in the PE-sheet (if applicable) Cracks observed if Yes Time interval between operations  <b>OPERATION „CO“</b> Oscillogram Applied voltage Peak current value Maximum total duration Recovery voltage (phase to phase or phase to neutral) Average Ratio between U <sub>m</sub> and U <sub>n</sub> Joule integral Closing operation time Melting of the fusible element Cracks observed if Yes	Page 29 / 34 9,81 kA 17,5 kA 12,8 kA 6,5 ms 438 V 438 V 439 V 438 V 1,05 167x10 <sup>3</sup> A <sup>2</sup> 848x10 <sup>3</sup> A <sup>2</sup> 419x10 <sup>3</sup> A <sup>2</sup> No No No Page - / - 6 min  Page 30 / 34 439 V 13,1 kA 17,4 kA 12,2 kA 7,5 ms 440 V 438 V 437 V 438 V 1,05 330x10 <sup>3</sup> A <sup>2</sup> 944x10 <sup>3</sup> A <sup>2</sup> 360x10 <sup>3</sup> A <sup>2</sup> - ms No No Page - / -

F 947-2/26 Ind 2

Authorized representative  
Date 00.09.18

Test laboratory: ACAE IA.01



ВЯРНО С  
ОРИГИНАЛА

LOVAG		Test report No.: 00.305 / T 01 Page 16 / 34 Type: T3N	
Type test according to: IEC 60947-2 Test sequence III		Type: T3N	
Standard and clause	Kind of tests and requirements	Test values Results	
8.3.3.2	<b>VERIFICATION OF LEAKAGE CURRENT</b> For circuit-breakers suitable for isolation having an operational voltage $U_o$ greater than 50 V. - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable) Test voltage: $1.1 \times U_o$ , 415 V Application of the test voltage: 455 V		
60947-1 7.2.7	Leakage current		
8.3.3.2	Test sequence I (in new condition)	≤ 0.5 mA	
8.3.3.5	Test sequence I (after overload performance)	≤ 2 mA	
8.3.4.3	Test sequence II	≤ 2 mA	
8.3.5.3	Test sequence III	≤ 6 mA	
8.3.6.5	Test sequence IV	≤ 2 mA	
8.3.7.3	Test sequence V, stage 1	≤ 2 mA	
8.3.7.7	Test sequence V, stage 2	≤ 6 mA	
8.3.8.5	Combined test sequence	≤ 2 mA	
C.3	Individual pole short-circuit test sequence $I_{sc}$	≤ 6 mA	
H.3	Individual pole short-circuit test sequence $I_{tr}$	≤ 6 mA	



ВЪРНО С  
ОРИГИНАЛ

Authorized representative

Date 00.09.18

F 947-2/20 Ind 2

LOVAG		Test report No.: 00.305 / T 01 Page 17 / 34 Type: T3N	
Type test according to: IEC 60947-2 Test sequence III		Type: T3N	
Standard and clause	Kind of tests and requirements	Test values Results	
60947-1 Table IX, X and XI	<b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b> Cabling characteristics Cable: 10 mm <sup>2</sup> Bar: - x - mm Number: 1 Length: 2000 mm Tightening torque: 10 Nm Reference temperature: 40 °C ± 2 °C Ambient temperature: k Correction factor: $k$ (k = 1 for releases independent of ambient temperature) Current setting value: $I_n$ Test current: - A either $k \times 2.0 \times I_n$ before 8.3.4.1 Test sequence II ( $I_{sc} = I_{sc}$ ) before 8.3.5.2 Test sequence III, before 8.3.6.2 Test sequence IV, after 8.3.6.5 Test sequence V, before 8.3.7.5 Combined test sequence before 8.3.8.2 or $k \times 2.5 \times I_n$ 55 A Test sequence II ( $I_{sc} = I_{sc}$ ) after 8.3.4.4 Test sequence III, after 8.3.5.3 Test sequence V, after 8.3.7.7 Combined test sequence after 8.3.8.6 Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems Tripping time (for twice the value of current setting on single pole) Ph <sub>1</sub> ≤ 310 s Ph <sub>2</sub> ≤ 310 s Ph <sub>3</sub> ≤ 310 s	10 mm <sup>2</sup> - x - mm 1 2000 mm 10 Nm 40 °C k $I_n$ - A 55 A 206 s 112 s 188 s	
8.3.5.1	Test sequence II ( $I_{sc} = I_{sc}$ ) before 8.3.4.1		
8.3.5.1	Test sequence III, before 8.3.5.2		
8.3.6.6	Test sequence IV, after 8.3.6.5		
8.3.7.4	Test sequence V, before 8.3.7.5		
8.3.8.1	Combined test sequence before 8.3.8.2		
8.3.5.4	Test sequence II ( $I_{sc} = I_{sc}$ ) after 8.3.4.4		
8.3.5.4	Test sequence III, after 8.3.5.3		
8.3.7.8	Test sequence V, after 8.3.7.7		
8.3.8.7	Combined test sequence after 8.3.8.6		
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		

Test laboratory: A CAE IA 01

Authorized representative

Date 00.09.18

F 947-2/41 Ind 2

Handwritten signature

LOVAG		Test report No.: 00.305 / T 01 Page 18 / 34	Test report No.: 00.305 / T 01 Page 19 / 34
Type test according to: IEC 60947-2 Test sequence III		Type: T3N	Type: T3N
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 Table IX, X and XI	<b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b>		
Cabling characteristics		120 mm <sup>2</sup>	
Cable	120 mm <sup>2</sup>	- X - mm	
Bar	- X - mm	1	
Number	1	2000 mm	
Length	2000 mm	10 Nm	
Tightening torque			
Reference temperature	40 °C ± 2 °C	40 °C	
Ambient temperature		-	
Correction factor	k	250 A	
(k = 1 for release independent of ambient temperature)			
Current setting value	I <sub>n</sub>		
Test current		500 A	
either k x 2.0 x I <sub>n</sub>			
Test sequence II (I <sub>th</sub> = I <sub>sn</sub> )	before 8.3.4.1		
Test sequence III,	before 8.3.5.2		
Test sequence IV,	before 8.3.6.2		
Test sequence V,	after 8.3.6.5		
Test sequence VI,	before 8.3.7.5		
Test sequence VII,	before 8.3.8.2		
Combined test sequence	before 8.3.8.2		
or k x 2.5 x I <sub>n</sub>			
Test sequence II (I <sub>th</sub> = I <sub>sn</sub> )	after 8.3.4.4		
Test sequence III,	after 8.3.5.3		
Test sequence V,	after 8.3.7.7		
Combined test sequence	after 8.3.8.6		
Individual pole short-circuit test sequence			
Test sequence for circuit-breakers for IT-systems			
Tripping time			
(for twice the value of current setting on single pole)			
Ph <sub>1</sub>	≤ 310 s	106 s	
Ph <sub>2</sub>	≤ 310 s	107 s	
Ph <sub>3</sub>	≤ 310 s	113 s	

Handwritten signature



ВЯРНО С  
ОРИГІНАЛА

Handwritten signature

LOVAG		Test report No.: 00.305 / T 01 Page 19 / 34	Test report No.: 00.305 / T 01 Page 19 / 34
Type test according to: IEC 60947-2 Test sequence III		Type: T3N	Type: T3N
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.5.2	<b>RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY</b>		
Utilization category	A		
Rated operational voltage U <sub>e</sub>	415 V	436 V	
Recovery voltage	1.05 x U <sub>e</sub>	36,7 kA	
Rated ultimate short-circuit breaking capacity	I <sub>cu</sub>	76,3 kA	
Rated short-circuit making capacity	I <sub>sm</sub>		
Power factor	0,25	0,23	
Frequency	50 Hz	50 Hz	
Control supply voltage	0,85 x U <sub>e</sub> - V	- V	
Maximum value of the closing time		- ms	
Sequence of operation	O - t - CO	O - t - CO	
Circuit diagram		Page 26 / 34	
Calibration of the test circuit		Page 20 / 34	
Safety area	Pageform 6	Page 7 / 34	
Installation of the material tested	Pageform 73	Page 8 / 34	
Energization direction	Top/Bottom	Bottom	
Smallest individual enclosure (if applicable)			
Type			
Kind of material			
Inside dimensions			
Height		- mm	
Width		- mm	
Depth		- mm	
Cabling characteristics			
Cable	120 mm <sup>2</sup>	120 mm <sup>2</sup>	
Bar	- X - mm	- X - mm	
Number	1	1	
Length	500 mm	500 mm	
Tightening torque	supply side load side	250 mm	
		10 Nm	

F 947-2/42 ind 2

Date 00.09.18

Authorized representative

Handwritten signature

Test laboratory: ACAE JA.01

LOVAG		Test report No.: 00.305 / T 01 Page 20 / 34 Type: T3N	Test values Results
Type test according to: IEC 60947-2		Kind of tests and requirements	
Standard and clause	Kind of tests and requirements		Test values Results
60947-1 8.3.4.1.5	<b>CALIBRATION OF THE TEST CIRCUIT</b>		Page 28 / 34
	Oscillogram		438 V
	Applied voltage		50 Hz
	Frequency		36,5 kA 36,9 kA 36,7 kA
	RMS, current value At 20 ms	$i_k$ $i_b$ $i_b$	
	Average RMS, Value		36,7 kA
	Peak current maximum value		78,3 kA
	Power factor		0,23
	(*) Description of the method for determination of short-circuit power factor is given at page 25 / 34		
		Authorized representative	Date 00.09.18
		F 947-272.ind 0	



ВЯРНО С  
ОРИГІНАЛ

LOVAG		Test report No.: 00.305 / T 01 Page 21 / 34 Type: T3N	Test values Results
Type test according to: IEC 60947-2 Test sequence III		Kind of tests and requirements	
Standard and clause	Kind of tests and requirements		Test values Results
	<b>OPERATION „O“</b>		Page 31 / 34
	Oscillogram	$i_k$ $i_b$ $i_b$	13,1 kA 23,9 kA 19,1 kA 7,40 ms 437 V 438 V 440 V 438 V
	Peak current value	$U_{(1-2)}$ $U_{(2-3)}$ $U_{(3-1)}$ or $U_{(1-N)}$ or $U_{(2-N)}$ or $U_{(3-N)}$	1,05 $313 \times 10^3 \text{ A}_2 \cdot \text{s}$ $1830 \times 10^3 \text{ A}_2 \cdot \text{s}$ $990 \times 10^3 \text{ A}_2 \cdot \text{s}$ No No No Page - / -
	Maximum total duration	$U_m$	3 min
	Recovery voltage (phase to phase or phase to neutral)	$U_m/U_b$ $P_{H1}$ $P_{H2}$ $P_{H3}$ Yes/No Yes/No Yes/No	
	Average		
	Ratio between $U_m$ and $U_b$		
	Joule integral		
	Melting of the fusible element		
	Holes in the PE-sheet (if applicable)		
	Cracks observed if Yes		
	Time interval between operations		3 min
	<b>OPERATION „CO“</b>		Page 32 / 34
	Oscillogram	$i_k$ $i_b$ $i_b$	438 V 20,1 kA 22,5 kA 16,5 kA 8,80 ms 436 V 438 V 439 V 438 V
	Applied voltage	$U_{(1-2)}$ $U_{(2-3)}$ $U_{(3-1)}$ or $U_{(1-N)}$ or $U_{(2-N)}$ or $U_{(3-N)}$	1,05 $916 \times 10^3 \text{ A}_2 \cdot \text{s}$ $1940 \times 10^3 \text{ A}_2 \cdot \text{s}$ $748 \times 10^3 \text{ A}_2 \cdot \text{s}$ - ms No No Page - / -
	Peak current value	$U_m$	
	Maximum total duration	$U_m/U_b$ $P_{H1}$ $P_{H2}$ $P_{H3}$ Yes/No Yes/No	
	Recovery voltage (phase to phase or phase to neutral)		
	Average		
	Ratio between $U_m$ and $U_b$		
	Joule integral		
	Closing operation time		
	Melting of the fusible element		
	Cracks observed if Yes		
7.2.1.1.3			
		Authorized representative	Date 00.09.18
		F 947-206.ind 2	

*[Handwritten signature]*

LOVAG		Test report No.: 00.305 / T 01 Page 22 / 34	Type: T3N
Type test according to: IEC 60947-2 Test sequence III		Test sequence III	
Standard and clause	Kind of tests and requirements	Test values Results	
	<b>VERIFICATION OF DIELECTRIC WITHSTAND</b>		
	Test voltage	1000 V	1000 V
8.3.3.5	2 x U <sub>m</sub> min. 1000 V		
8.3.4.2	Test sequence I		
8.3.5.3	Test sequence II		
8.3.6.5	Test sequence III		
8.3.7.3	Test sequence IV		
8.3.7.7	Test sequence V, stage 1		
8.3.8.4	Test sequence V, stage 2		
C.3	Combined test sequence		
B.10.3.1	Individual pole short-circuit test sequence		
H.3	Test sequence B.11		
	Test sequence for circuit-breakers for IT-systems		
8.3.3.2.2 a)	Application of the test voltage		
	- Main circuit of the circuit-breaker		
	- Isolating contacts of the withdrawable unit (if applicable)		
	Test duration	1 min	1 min




ВАРНО С  
ОРИГИНАЛ

LOVAG		Test report No.: 00.305 / T 01 Page 23 / 34	Type: T3N
Type test according to: IEC 60947-2 Test sequence III		Test sequence III	
Standard and clause	Kind of tests and requirements	Test values Results	
	<b>VERIFICATION OF LEAKAGE CURRENT</b>		
	For circuit-breakers suitable for isolation having an operational voltage U <sub>o</sub> greater than 50 V.		
8.3.3.2	- Main circuit of the circuit-breaker		
	- Isolating contacts of a withdrawable unit (if applicable)		
	Test voltage	1.1 x U <sub>o</sub> 415 V	456 V
60947-1 7.2.7	Application of the test voltage		
8.3.3.2	Leakage current		
8.3.3.5	Test sequence I (in new condition)	≤ 0.5 mA	- mA
8.3.4.3	Test sequence I (after overload performance)	≤ 2 mA	- mA
8.3.5.3	Test sequence II	≤ 2 mA	- mA
8.3.6.5	Test sequence III	≤ 6 mA	< 6 mA
8.3.7.3	Test sequence IV	≤ 2 mA	- mA
8.3.7.7	Test sequence V, stage 1	≤ 2 mA	- mA
8.3.8.5	Test sequence V, stage 2	≤ 6 mA	- mA
C.3	Combined test sequence	≤ 2 mA	- mA
H.3	Individual pole short-circuit test sequence I <sub>sc</sub>	≤ 6 mA	- mA
	Individual pole short-circuit test sequence I <sub>r</sub>	≤ 6 mA	- mA

Test laboratory: AC&E I.A.01  
Authorized representative  
Date 00.09.18  
F 947-2/22 ind 2



CIRCUIT DIAGRAM B



- 1 - Three-phase generator
- 2 - Back up circuit breaker
- 3 - Air reactor
- 4 - Three-phase transformer
- 5 - Short-circuit making switch
- 6 - Device for the detection of fault current
- 7 - Non inductive shunt for current measurement
- 8 - Resistor
- 9 - Shunt for voltage measurement
- 10 - Apparatus under test

*[Handwritten signature]*





ВЕРНО С  
 ОПРИНААА

SYMBOLS USED FOR THE IDENTIFICATION OF THE MEASUREMENTS RECORDED BY THE OSCILLOGRAM

- 1 First phase current
- 2 Second phase current
- 3 Third phase current
- 4 First phase voltage measured across the pole of the circuit breaker
- 5 Second phase voltage measured across the pole of the circuit breaker
- 6 Third phase voltage measured across the pole of the circuit breaker
- 7 First phase voltage measured phase to phase across the closing device
- 8 Second phase voltage measured phase to phase across the closing device
- 9 Third phase voltage measured phase to phase across the closing device
- 11 Shunt closing release voltage

*[Handwritten signature]*





0




ВЪРНО С  
ОРИГИНАЛ

*[Handwritten signature]*

82

LOVAG  
 Test report No.: 00.305 / T 01  
 Page 30 / 34  
 Type: T3N  
 Type test according to: IEC 60947-2




F 947-2/73 ind 0  
 Date 00.09.18  
 Authorized representative  
 [Signature]



ВЯРНО С  
 ОПИЦИНАА

[Handwritten signature]


LOVAG  
 Test report No.: 00.305 / T 01  
 Page 31 / 34  
 Type: T3N  
 Type test according to: IEC 60947-2



F 947-2/73 ind 0  
 Date 00.09.18  
 Authorized representative  
 [Signature]

[Handwritten mark]

[Handwritten mark]




*[Signature]*  
 Authorized representative

Date 00.05.18

F 947-2/73 ind 0

*[Handwritten signature]*



Test laboratory: ACME IA.01

*[Signature]*  
 Authorized representative

Date 00.09.19

F 947-2/73 ind 0

**ВЕРНО С  
 ОРИГІНАЛ**

*[Handwritten signature]*





ASSOCIAZIONE PER LA CERTIFICAZIONE  
DELLE APPARECCHIATURE ELETTRICHE

Via delle Brigate Partigiane 6/21 - 16129 - GENOVA (Italy)  
tel. +10/565197 fax. +10/5848607 e-mail: accaacc@dm.it



# Certificate of Conformity

LOVAG-Certificato No. IT 00.031

This Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

**Apparatus**  
Moulded case Three Pole Air-break Independent-operation Circuit-breakers  
Frame size 160 A - 800 V ( $U_n$ ) - 50/60 Hz - with short-circuit and overload releases:

$I_n = 160$  A

**Designation**

T1B

**Manufacturer or responsible vendor**

ABB SACE S.p.A. - Via Baloni, 35 - 24123 Bergamo (Italy)

**Tested for:** ABB SACE S.p.A. - Via Baloni, 35 - 24123 Bergamo (Italy)

**Tested by:** ACAE Laboratory IA.01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60947-2 (1995), Corrigendum (1997) and Amendment 1 (1997).

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated below.


Utilization category A

Test sequence: II ( $I_n = I_{cu}$ )

$U_n = 415$  V  $I_n = I_{cu} = 16$  kA

This document includes Report No.: 00.291/T01  
Issue Date: 2000.09.18

Responsible Certification Body



Authorized Signature:  
Date: 2000.12.19

LOVAG  
Low Voltage Agreement Group

## Test Report No. 00.291 / T 01

**Test laboratory:** ACAE IA.01  
**Client:** ABB SACE S.p.A.  
**Manufacturer:** ABB SACE S.p.A.  
**Test object:** Low voltage moulded case c.b. series T1MAX  
**Type designation:** T1B  
**Date(s) of test(s):** from 2000.08.01 to 2000.09.15  
**Test specification:** IEC 60947-2 (1995), Corrigendum (1997) and Amendment 1 (1997)

**Test sequence(s):** II ( $I_n = I_{cu}$ )

**Test results:** Icu / Ics at 415 V found in compliance with rated characteristics

**The Record of Proving Test consists of:**

45 pages LOVAG test report forms 7 oscillograms included

no other pages drawing nr. RH0011.309 issued 00.01.25 enclosed

2 diagram included 1 photograph included

**Date of issue:** 2000.09.18

Responsible Test Laboratory

**Signatures:** *[Signature]*  
(Authorized representative)

*[Signature]*

**Note:**  
The test result relates only to the items tested.  
The test report shall not be reproduced except in full without the written approval of the test laboratory.

ОРУЖИНАА

**LOVAG**

**Description and characterization of the test object**

**Characteristics**

**Type of circuit-breaker:**

Number of poles 3  
Kind of current a.c.  
Number of phases 3  
Rated frequency 50 - 60 Hz  
Utilization category A  
Reference temperature 40 °C  
Suitability for isolation Yes

**Rated and limiting values: (according to test volume)**

Main circuit  
Rated impulse withstand voltage  $U_{imp}$  8 kV  
Rated insulation voltage  $U_i$  800 V  
Conventional thermal current  $I_{th} / I_{thc}$  160 A / -  
Rated current  $I_n$  160 A

**Rated current in the neutral pole**

-

**Short-circuit characteristics:**

$U_{jV}$	$I_{cw}/kA$	$I_{cp}/kA$	$I_{cs}/kA$	$I_{pr}/kA$
220/230	52,5	25	25	-
380/415	32	16	16	-
440	17	10	10	-
500	13,5	8	8	-
690	5,9	4	4	-



ВЯРНО С  
ОРИГИНАЛ

**LOVAG**

**Control circuits:**

**Electrical control circuits:**

Kind of current -  
Rated frequency -  
Rated control circuit voltage  $U_c$  -  
Rated control supply voltage  $U_k$  -  
Rated impulse withstand voltage  $U_{imp}$  -  
Rated insulation voltage  $U_i$  -

**Air-supply control circuits:**

Rated supply pressure -  
Limits of pressure -  
Required volume for each closing operation -  
Required volume for each opening operation -

**Auxiliary circuits:**

Rated operational voltage  $U_o$  -  
Rated impulse withstand voltage  $U_{imp}$  -  
Rated insulation voltage  $U_i$  -  
Rated frequency -  
Rated operational current  $I_e$  -  
Number of circuits -  
Number and kind of contact elements -

*MP*

LOVAG

Releases:

- Shunt release:
- Rated control circuit voltage  $U_c$
- Kind of current
- Rated frequency if a.c.
- Undervoltage or no-voltage release
- Rated control circuit voltage  $U_{c0}$
- Kind of current
- Rated frequency if a.c.
- Over-current release:
- Short-circuit release
  - instantaneous release
  - definite time-delay release
- Rated current  $I_n$
- Kind of current
- Rated frequency if a.c.
- Current setting (or range of settings)
- Time setting (or range of settings)
- Overload release (IEC 60947-1; 2.4.30):
  - instantaneous release
  - definite time-delay release
  - inverse time-delay release dependent on ambient air temperature independent of ambient air temperature
- Reference temperature
- Rated current  $I_n$
- Kind of current
- Rated frequency if a.c.
- Current setting (or range of settings)
- Time setting (or range of settings)

Yes

16 A to 160 A

a.c.

50 - 60 Hz

from 500 A up to 1600 A

R16 to R160

yes

40 °C

16 to 160 A

a.c.

50 - 60 Hz

11 A to 16 A and

112 A to 160 A





*Mp*

LOVAG

Time / current characteristics settings R16

Type designation: T1B





*Mp*

ВЕРНО С  
ОРИГИНАЛ

LOVAG

Time / current characteristics settings R160

Type designation : T1B



ВЯРНО С  
ОРИГИНАЛА

LOVAG

Integral fused circuit-breakers:  
(Co-ordination with short-circuit protective devices)

- Kind of protective devices
- Type of fuse
- Maximum operational voltage
- Rated current  $I_n$
- Maximum prospective short-circuit peak current

Switching overvoltages:  
(Characteristics not defined)

Individual enclosure:

- Type
- Kind of material
- Degree of protection
- Inside dimensions (in millimetres)  
height  
width  
depth

When no enclosure:

- Safety perimeter defined:  
height 175 mm  
width 116 mm  
depth 70 mm

Kind of screen  
(woven wire mesh, perforated metal, expanded metal)

metal sheet

Size of holes ( $\leq 30 \text{ mm}^2$ )

yes

Distance during test

-

Openings around the manual operating means:

Openings in the area of the manual operating means through which the arc chamber can be reached by a music wire of 0.26 mm diameter.

no

*MP*

*Handwritten signatures*





<b>LOVAG</b>		Test report No.: 00.291 / T 01 Page 10 / 45
Type test according to: IEC 60847-2		Type: T1B
<b>TEST SEQUENCE II (<math>I_{cs} = I_{cu}</math>)</b>		
Rated ultimate short-circuit breaking capacity For circuit-breakers with $I_{cs} = I_{cu}$		
Test sequence II ( $I_{cs} = I_{cu}$ ) comprises the following tests:		
Sub-clause	Test	Pageform
8.3.5.1	Verification of overload releases	F 947-2/41
8.3.4.1	Rated service short-circuit breaking capacity	F 947-2/35 + F 947-2/37
8.3.4.2	Verification of operational capability	F 947-2/38
8.3.4.3	Verification of dielectric withstand	F 947-2/27
8.3.4.4	Verification of leakage current (if applicable)	F 947-2/20
8.3.4.5	Verification of temperature-rise	F 947-2/30
8.3.5.4	Verification of overload releases	F 947-2/41
8.3.5.4	Verification of overload release	F 947-2/41



Test Laboratory: ACME IA.01  
 Authorized representative: *[Signature]*  
 Date: 00.09.19

Test Laboratory: ACME IA.01  
 Authorized representative: *[Signature]*  
 Date: 00.09.19

<b>LOVAG</b>		Test report No.: 00.291 / T 01 Page 11 / 45
Type test according to: IEC 60847-2		Type: T1B
Test sequence II ( $I_{cs} = I_{cu}$ )		
Standard and clause	Kind of tests and requirements	Test values Results
60847-1 Table IX, X and XI	<b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b>	
Cabling characteristics		
Cable	2,5 mm <sup>2</sup>	2,5 mm <sup>2</sup>
Bar	- x - mm	- x - mm
Number	1	1
Length	2000 mm	2000 mm
Tightening torque		7 Nm
Reference temperature	40 °C ± 2 °C	40 °C
Ambient temperature		-
Correction factor	k	11 A
(k = 1 for releases independent of ambient temperature)		
Current setting value	$I_n$	
Test current		22 A
either $k \times 2.0 \times I_n$		
Test sequence II ( $I_{cs} = I_{cu}$ )	before 8.3.4.1	
Test sequence III,	before 8.3.5.2	
Test sequence IV,	before 8.3.6.2	
Test sequence V,	after 8.3.6.5	
Test sequence VI,	before 8.3.7.5	
Combined test sequence	before 8.3.8.2	
or $k \times 2.5 \times I_n$		- A
Test sequence II ( $I_{cs} = I_{cu}$ )	after 8.3.4.4	
Test sequence III,	after 8.3.5.3	
Test sequence V,	after 8.3.7.7	
Combined test sequence	after 8.3.8.6	
Individual pole short-circuit test sequence		
Test sequence for circuit-breakers for IT-systems		
Tripping time	(for twice the value of current setting on single pole)	
$Ph_1$	$\geq 150$ s	121 s
$Ph_2$	$\leq 150$ s	118 s
$Ph_3$	$\geq 150$ s	125 s

ВЯРНО С  
ОРИГІНАЛ

LOVAG		Test report No.: 00.291 / T 01 Page 12 / 45	Test report No.: 00.291 / T 01 Page 13 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{cs} = I_{cu}$ )		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.4.1 8.3.8.3	<b>TEST OF RATED SERVICE SHORT-CIRCUIT BREAKING CAPACITY</b>		438 V 16,7 kA
Table 4	Utilization category Rated operational voltage $U_n$ Recovery voltage Rated service short-circuit breaking capacity $I_{cs}$ Rated ultimate short-circuit making capacity $I_{cu}$ Ratio between $I_{cs}$ and $I_{cu}$	A 415 V $1.05 \times U_n$ 16 kA 16 kA $I_{cs}/I_{cu} = 100\%$	
Table XI	Power factor Frequency	0,30 50 Hz	0,28 50 Hz
8.3.2.1 7.2.1.1.3	Control supply voltage Maximum value of the closing time	$0,85 \times U_n - V$	- V - ms
	Sequence of operation Circuit diagram Calibration of the test circuit	O - t - CO - t - CO	O - t - CO - t - CO Page 34 / 45 Page 13 / 45
	Safety area Installation of the material tested Energization direction	Pageform 6 Pageform 73 Top/Bottom	Page 7 / 45 Page 8 / 45 Top
60947-1 Table IX, X and XI	Cabling characteristics Cable Bar Number Length Tightening torque	2,5 mm <sup>2</sup> - X - mm 1 supply side load side 250 mm 250 mm 7 Nm	2,5 mm <sup>2</sup> - X - mm 1 500 mm 250 mm 7 Nm

LOVAG		Test report No.: 00.291 / T 01 Page 13 / 45	Test report No.: 00.291 / T 01 Page 13 / 45
Type test according to: IEC 60947-2		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 8.3.4.1.5	<b>CALIBRATION OF THE TEST CIRCUIT (*)</b>		Page 37 / 45
	Oscillogram		438 V
	Applied voltage		50 Hz
	Frequency		17,0 kA 18,7 kA 16,6 kA
	RMS current value At 20 ms		16,7 kA
	Average RMS value		34,3 kA
	Peak current maximum value		0,28
	Power factor		
	(*) Description of the method for determination of short-circuit power factor is given at page 33 / 45		

Test laboratory: ACAE IA 01  
F 947-2/72.ind 0  
Date 00.09.18

Authorized representative  
Date 00.09.18

*Handwritten signature*

*Handwritten signature*



ВЯРНО С  
ОРИГИНАЛА

*Handwritten signature*

47

LOVAG		Test report No.: 00.291 / T 01 Page 14 / 45	Test values Results
Type test according to: IEC 60947-2 Test sequence II ( $I_{in} = I_{ed}$ )		Type: T1B	
Standard and clause	Kind of tests and requirements		Test values Results
	<p><b>OPERATION „CO“</b></p> <p>Oscillogram</p> <p>Peak current value</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average</p> <p>Ratio between <math>U_m</math> and <math>U_e</math></p> <p>Joule integral</p> <p>Melting of the fusible element</p> <p>Holes in the PE-sheet (if applicable)</p> <p>Cracks observed if Yes</p>	<p><math>i_1</math> <input type="checkbox"/></p> <p><math>i_2</math> <input type="checkbox"/></p> <p><math>i_3</math> <input type="checkbox"/></p> <p><math>U_{(1-2)}</math> <input checked="" type="checkbox"/> or <math>U_{(1-N)}</math> <input type="checkbox"/></p> <p><math>U_{(2-3)}</math> <input checked="" type="checkbox"/> or <math>U_{(2-N)}</math> <input type="checkbox"/></p> <p><math>U_{(3-1)}</math> <input checked="" type="checkbox"/> or <math>U_{(3-N)}</math> <input type="checkbox"/></p> <p><math>U_m</math> <input type="checkbox"/></p> <p><math>U_m/U_e</math> <input type="checkbox"/></p> <p><math>Ph_1</math> <input type="checkbox"/></p> <p><math>Ph_2</math> <input type="checkbox"/></p> <p><math>Ph_3</math> <input type="checkbox"/></p> <p>Yes/No <input type="checkbox"/></p> <p>Yes/No <input type="checkbox"/></p> <p>Yes/No <input type="checkbox"/></p>	<p>Page 38 / 45</p> <p>5,11 kA</p> <p>9,47 kA</p> <p>5,44 kA</p> <p>6,30 ms</p> <p>440 V</p> <p>439 V</p> <p>438 V</p> <p>439 V</p> <p>1,05</p> <p><math>49,4 \times 10^3 \text{ A}^2 \cdot \text{s}</math></p> <p><math>206 \times 10^3 \text{ A}^2 \cdot \text{s}</math></p> <p><math>74,7 \times 10^3 \text{ A}^2 \cdot \text{s}</math></p> <p>No</p> <p>No</p> <p>No</p> <p>Page - / -</p>
	<p>Time interval between operations</p> <p><b>OPERATION „CO“</b></p> <p>Oscillogram</p> <p>Applied voltage</p> <p>Peak current value</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average</p> <p>Ratio between <math>U_m</math> and <math>U_e</math></p> <p>Joule integral</p> <p>Closing operation time</p> <p>Melting of the fusible element</p> <p>Cracks observed if Yes</p>	<p><math>i_1</math> <input type="checkbox"/></p> <p><math>i_2</math> <input type="checkbox"/></p> <p><math>i_3</math> <input type="checkbox"/></p> <p><math>U_{(1-2)}</math> <input checked="" type="checkbox"/> or <math>U_{(1-N)}</math> <input type="checkbox"/></p> <p><math>U_{(2-3)}</math> <input checked="" type="checkbox"/> or <math>U_{(2-N)}</math> <input type="checkbox"/></p> <p><math>U_{(3-1)}</math> <input checked="" type="checkbox"/> or <math>U_{(3-N)}</math> <input type="checkbox"/></p> <p><math>U_m</math> <input type="checkbox"/></p> <p><math>U_m/U_e</math> <input type="checkbox"/></p> <p><math>Ph_1</math> <input type="checkbox"/></p> <p><math>Ph_2</math> <input type="checkbox"/></p> <p><math>Ph_3</math> <input type="checkbox"/></p> <p>Yes/No <input type="checkbox"/></p> <p>Yes/No <input type="checkbox"/></p> <p>Yes/No <input type="checkbox"/></p>	<p>6 min</p> <p>Page 39 / 45</p> <p>438 V</p> <p>8,64 kA</p> <p>2,83 kA</p> <p>8,41 kA</p> <p>7,30 ms</p> <p>438 V</p> <p>438 V</p> <p>439 V</p> <p>438 V</p> <p>1,05</p> <p><math>194 \times 10^3 \text{ A}^2 \cdot \text{s}</math></p> <p><math>24,4 \times 10^3 \text{ A}^2 \cdot \text{s}</math></p> <p><math>169 \times 10^3 \text{ A}^2 \cdot \text{s}</math></p> <p>- ms</p> <p>No</p> <p>No</p> <p>Page - / -</p>
7.2.1.1.3			

LOVAG		Test report No.: 00.291 / T 01 Page 15 / 45	Test values Results
Type test according to: IEC 60947-2 Test sequence II ( $I_{in} = I_{ed}$ )		Type: T1B	
Standard and clause	Kind of tests and requirements		Test values Results
	<p>Time interval between operations</p> <p><b>OPERATION „CO“</b></p> <p>Oscillogram</p> <p>Applied voltage</p> <p>Peak current value</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average</p> <p>Ratio between <math>U_m</math> and <math>U_e</math></p> <p>Joule integral</p> <p>Closing operation time</p> <p>Melting of the fusible element</p> <p>Cracks observed if Yes</p>	<p><math>i_1</math> <input type="checkbox"/></p> <p><math>i_2</math> <input type="checkbox"/></p> <p><math>i_3</math> <input type="checkbox"/></p> <p><math>U_{(1-2)}</math> <input checked="" type="checkbox"/> or <math>U_{(1-N)}</math> <input type="checkbox"/></p> <p><math>U_{(2-3)}</math> <input checked="" type="checkbox"/> or <math>U_{(2-N)}</math> <input type="checkbox"/></p> <p><math>U_{(3-1)}</math> <input checked="" type="checkbox"/> or <math>U_{(3-N)}</math> <input type="checkbox"/></p> <p><math>U_m</math> <input type="checkbox"/></p> <p><math>U_m/U_e</math> <input type="checkbox"/></p> <p><math>Ph_1</math> <input type="checkbox"/></p> <p><math>Ph_2</math> <input type="checkbox"/></p> <p><math>Ph_3</math> <input type="checkbox"/></p> <p>Yes/No <input type="checkbox"/></p> <p>Yes/No <input type="checkbox"/></p>	<p>6 min</p> <p>Page 40 / 45</p> <p>439 V</p> <p>4,86 kA</p> <p>9,58 kA</p> <p>6,25 kA</p> <p>5,80 ms</p> <p>438 V</p> <p>437 V</p> <p>438 V</p> <p>438 V</p> <p>1,05</p> <p><math>44,7 \times 10^3 \text{ A}^2 \cdot \text{s}</math></p> <p><math>222 \times 10^3 \text{ A}^2 \cdot \text{s}</math></p> <p><math>92,7 \times 10^3 \text{ A}^2 \cdot \text{s}</math></p> <p>- ms</p> <p>No</p> <p>No</p> <p>Page - / -</p>
7.2.1.1.3			

Test laboratory: ACAE IA.01

F 947-2/37 Ind 2

F 947-2/36 Ind 2

F 947-2/36 Ind 2

Date 00.09.18

Date 00.09.18

Date 00.09.18

Authorized representative

Authorized representative

Authorized representative



ВЕРНО С  
ОРИГИНАЛА



LOVAG		Test report No.: 00.291 / T 01 Page 18 / 45	Test report No.: 00.291 / T 01 Page 19 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{th} = I_{td}$ )		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.2	<b>VERIFICATION OF LEAKAGE CURRENT</b> For circuit-breakers suitable for isolation having an operational voltage $U_o$ greater than 50 V. - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	456 V	
60947-1 7.2.7	Test voltage Application of the test voltage	1.1 x $U_o$ , 415 V	
8.3.3.2	Leakage current		
8.3.3.5	Test sequence I (in new condition)	$\leq 0.5$ mA	- mA
8.3.4.3	Test sequence I (after overload performance)	$\leq 2$ mA	- mA
8.3.5.3	Test sequence II	$\leq 2$ mA	< 2 mA
8.3.5.3	Test sequence III	$\leq 6$ mA	- mA
8.3.5.5	Test sequence IV	$\leq 2$ mA	- mA
8.3.7.3	Test sequence V, stage 1	$\leq 2$ mA	- mA
8.3.7.7	Test sequence V, stage 2	$\leq 6$ mA	- mA
8.3.8.5	Combined test sequence	$\leq 2$ mA	- mA
C.3	Individual pole short-circuit test sequence $I_{sc}$	$\leq 6$ mA	- mA
H.3	Individual pole short-circuit test sequence $I_r$	$\leq 6$ mA	- mA

LOVAG		Test report No.: 00.291 / T 01 Page 19 / 45	Test report No.: 00.291 / T 01 Page 19 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{th} = I_{td}$ )		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.4.4 8.3.6.3 8.3.7.2 8.3.8.6 8.3.2.5 60947-1 8.3.3.3.1	<b>VERIFICATION OF TEMPERATURE-RISE ONLY FOR TERMINALS</b>  Temperature-rise test  Ambient temperature	10...40°C	- °C
60947-1 8.3.3.3.4	Main circuits		
	Conventional thermal current $I_{th}$	.A	- A
	Conventional thermal current for enclosure $I_{thc}$	.A	- A
	Conventional thermal current for neutral pole	- A	- A
	Cabling characteristics		
	Phase poles		
	Cable	- mm <sup>2</sup>	- mm <sup>2</sup>
	Bar	- x - mm	- x - mm
	Number	-	-
	Length	- mm	- mm
	Tightening torque		
	Neutral pole (if applicable)		
	Cable	- mm <sup>2</sup>	- mm <sup>2</sup>
	Bar	- x - mm	- x - mm
	Number	-	-
	Length	- mm	- mm
	Tightening torque		
	Arrangement:	3 phase <input type="checkbox"/> or poles in series <input type="checkbox"/>	- K
	Temperature-rise limits		
	Terminals	S - K	- K
Note : Test not carried out (see table X IEC 947-2 Amendment 2)			
Test laboratory: ACAE IA.01		Authorized representative	F 947-2/20 Ind 2
		Date 00.09.18	Date 00.09.18

ВЯРНО С  
ОРИГИНАЛА



Authorized representative

F 947-2/20 Ind 2


F 947-2/20 Ind 2

Authorized representative

Date 00.09.18

LOVAG		Test report No.: 00.291 / T 01 Page 20 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{ca} = I_{cb}$ )		Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 Table IX, X and XI	<p><b>VERIFICATION OF OVERLOAD RELEASES</b></p> <p>Cabling characteristics Cable 2,5 mm<sup>2</sup> Bar - x - mm 1 Number 2000 mm Length 2000 mm Tightening torque Arrangement 3 phase <input type="checkbox"/> or poles in series <input checked="" type="checkbox"/> 7 Nm</p> <p>Reference temperature 40 °C ± 2 °C Ambient temperature k Correction factor I<sub>n</sub> (k = 1 for releases independent of ambient temperature) Current setting value</p> <p><b>Test current</b> k x 1.45 x current setting value Test sequence I after 8.3.3.6 Test sequence II after 8.3.4.4 Combined test sequence after 8.3.8.8</p> <p>Tripping time ≤ 60 min</p>	<p>2,5 mm<sup>2</sup> - x - mm 1 2000 mm 7 Nm</p> <p>40 °C - 11 A</p> <p>16 A</p> <p>6 min</p>

LOVAG		Test report No.: 00.291 / T 01 Page 21 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{ca} = I_{cb}$ )		Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 Table IX, X and XI	<p><b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b></p> <p>Cabling characteristics Cable 2,5 mm<sup>2</sup> Bar - x - mm 1 Number 2000 mm Length 2000 mm Tightening torque 7 Nm</p> <p>Reference temperature 40 °C ± 2 °C Ambient temperature k Correction factor I<sub>n</sub> (k = 1 for releases independent of ambient temperature) Current setting value</p> <p><b>Test current</b> either k x 2.0 x I<sub>n</sub> Test sequence II (<math>I_{ca} = I_{cb}</math>) before 8.3.4.1 Test sequence III, before 8.3.5.2 Test sequence IV, before 8.3.6.2 Test sequence V, after 8.3.6.5 Test sequence VI, before 8.3.7.5 Combined test sequence before 8.3.8.2</p> <p>or k x 2.5 x I<sub>n</sub> Test sequence I (<math>I_{ca} = I_{cb}</math>) after 8.3.4.4 Test sequence III, after 8.3.5.3 Test sequence V, after 8.3.7.7 Combined test sequence after 8.3.8.6 Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems</p> <p>Tripping time (for twice the value of current setting on single pole) Ph<sub>1</sub> ≤ 190 s Ph<sub>2</sub> ≤ 190 s Ph<sub>3</sub> ≤ 190 s</p>	<p>2,5 mm<sup>2</sup> - x - mm 1 2000 mm 7 Nm</p> <p>40 °C - 11 A</p> <p>- A</p> <p>27,5 A</p> <p>27,5 A</p> <p>≤ 190 s ≤ 190 s ≤ 190 s</p>



ВЯРНО С  
ОРИГИНАЛА

Test laboratory: ACAE IA.01  
Authorized representative  
Date 00.09.18

Test laboratory: ACAE IA.01  
Authorized representative  
Date 00.09.18

F 947-2/00 Ind 2

F 947-2/41 Ind 2

*[Handwritten signature]*

ВЯРНО С  
ОРИГИНАЛ

*[Handwritten signature]*

LOVAG		Test report No.: 00.291 / T 01 Page 22 / 45 Type: T1B	
Type test according to: IEC 60947-2 Test sequence II ( $I_{cs} = I_{cu}$ )		Type: T1B	
Standard and clause	Kind of tests and requirements	Test values Results	
60947-1 Table IX, X and XI	<p><b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b></p> <p>Cabling characteristics Cable 70 mm<sup>2</sup> Bar - X - mm 1 Number 1 Length 2000 mm Tightening torque 7 Nm</p> <p>Reference temperature 40 °C ± 2 °C Ambient temperature k Correction factor k (k = 1 for releases independent of ambient temperature) Current setting value I<sub>n</sub></p> <p>Test current 320 A</p> <p>either k x 2.0 x I<sub>n</sub> Test sequence II (<math>I_{cs} = I_{cu}</math>) before 8.3.4.1 Test sequence III, before 8.3.5.2 Test sequence IV, before 8.3.6.2 Test sequence IV after 8.3.5.5 Test sequence V, before 8.3.7.5 Combined test sequence before 8.3.8.2</p> <p>or k x 2.5 x I<sub>n</sub> Test sequence II (<math>I_{cs} = I_{cu}</math>) after 8.3.4.4 Test sequence III, after 8.3.5.3 Test sequence V, after 8.3.7.7 Combined test sequence after 8.3.8.6 Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems</p> <p>Tripping time (for twice the value of current setting on single pole) Ph<sub>1</sub> ≤ 190 s Ph<sub>2</sub> ≤ 190 s Ph<sub>3</sub> ≤ 190 s</p>	<p>70 mm<sup>2</sup> - X - mm 1 2000 mm 7 Nm</p> <p>40 °C</p> <p>160 A</p> <p>320 A</p> <p>- A</p> <p>68 s 63 s 70 s</p>	



*[Handwritten signature]*  
Authorized representative

Date 00.09.18

F 947-2/41 ind 2

LOVAG		Test report No.: 00.291 / T 01 Page 23 / 45 Type: T1B	
Type test according to: IEC 60947-2 Test sequence II ( $I_{cs} = I_{cu}$ )		Type: T1B	
Standard and clause	Kind of tests and requirements	Test values Results	
8.3.4.1 8.3.8.3	<p><b>TEST OF RATED SERVICE SHORT-CIRCUIT BREAKING CAPACITY</b></p> <p>Utilization category A</p> <p>Rated operational voltage U<sub>o</sub> 415 V Recovery voltage 1.05 x U<sub>o</sub> Rated service short-circuit breaking capacity I<sub>cs</sub> 16 kA Rated ultimate short-circuit making capacity I<sub>cu</sub> 16 kA Ratio between I<sub>cs</sub> and I<sub>cu</sub> I<sub>cs</sub>/I<sub>cu</sub> = 100 %</p>	<p>Power factor 0.30 Frequency 50 Hz</p> <p>Control supply voltage 0.85 x U<sub>o</sub> - V Maximum value of the closing time - V</p> <p>Sequence of operation O - t - CO - t - CO Circuit diagram Page 34 / 45 Calibration of the test circuit Page 24 / 45</p> <p>Safety area Page 7 / 45 Installation of the material tested Page 8 / 45 Energization direction Bottom</p> <p>Cabling characteristics Cable 70 mm<sup>2</sup> Bar - X - mm 1 Number 1 Length 500 mm Tightening torque supply side 250 mm load side 7 Nm</p>	<p>436 V 16.7 kA</p> <p>0.28 50 Hz</p> <p>- V - ms</p> <p>O - t - CO - t - CO Page 34 / 45 Page 24 / 45</p> <p>Page 7 / 45 Page 8 / 45 Bottom</p> <p>70 mm<sup>2</sup> - X - mm 1 500 mm 250 mm 7 Nm</p>

Test laboratory: ACAE IA.01

*[Handwritten signature]*  
Authorized representative

Date 00.09.18

F 947-2/05 ind 2



LOVAG		Test report No.: 00.291 / T 01 Page 24 / 45	Test report No.: 00.291 / T 01 Page 25 / 45
Type test according to: IEC 60947-2		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 8.3.4.1.5	<b>CALIBRATION OF THE TEST CIRCUIT</b>		Page 41 / 45
	Oscillogram		6,69 kA 13,3 kA 9,19 kA 6,5 ms 436 V 438 V 438 V 437 V 437 V
	Applied voltage		1,05 85,9x10 <sup>3</sup> A <sup>2</sup> s 457x10 <sup>3</sup> A <sup>2</sup> s 207x10 <sup>3</sup> A <sup>2</sup> s
	Frequency	50 Hz	No No No
	RMS, current value At 20 ms	i <sub>1</sub> i <sub>2</sub> i <sub>3</sub>	Page - / - 3 min
	Average RMS, value		3 min
	Peak current, maximum value		
	Power factor		
	(*) Description of the method for determination of short-circuit power factor is given at page 33 / 45		
			Page 42 / 45 438 V 9,34 kA 6,64 kA 13,1 kA 6,5 ms 438 V 437 V 438 V 438 V 1,05 226x10 <sup>3</sup> A <sup>2</sup> s 90,7x10 <sup>3</sup> A <sup>2</sup> s 485x10 <sup>3</sup> A <sup>2</sup> s - ms No No No

LOVAG		Test report No.: 00.291 / T 01 Page 25 / 45	Test report No.: 00.291 / T 01 Page 25 / 45
Type test according to: IEC 60947-2		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
	<b>OPERATION „O“</b>		
	Oscillogram		
	Peak current value		
	Maximum total duration		
	Recovery voltage (phase to phase or phase to neutral)		
	Average		
	Ratio between U <sub>m</sub> and U <sub>0</sub>		
	Joule integral		
	Melting of the fusible element		
	Holes in the PE-sheet (if applicable)		
	Cracks observed		
	Time interval between operations		
	<b>OPERATION „CO“</b>		
	Oscillogram		
	Applied voltage		
	Peak current value		
	Maximum total duration		
	Recovery voltage (phase to phase or phase to neutral)		
	Average		
	Ratio between U <sub>m</sub> and U <sub>0</sub>		
	Joule integral		
	Closing operation time		
	Melting of the fusible element		
	Cracks observed		
7.2.1.1.3			



ВЯРНО С  
ОРИГИНАЛ

53

*MP*

*MP*

*MP*

<b>LOVAG</b>		Test report No.: 00.291 / T 01 Page 26 / 45	Test report No.: 00.291 / T 01 Page 27 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{sc} = I_{cw}$ )		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
7.2.1.1.3	<p>Time interval between operations</p> <p>OPERATION "CO"</p> <p>Oscillogram</p> <p>Applied voltage</p> <p>Peak current value</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average</p> <p>Ratio between <math>U_m</math> and <math>U_0</math></p> <p>Joule integral</p> <p>Closing operation time</p> <p>Melting of the fusible element</p> <p>Cracks observed if Yes</p>	<p>3 min</p> <p>3 min</p> <p><math>i_1</math></p> <p><math>i_2</math></p> <p><math>i_3</math></p> <p><math>U_{(1-2)}</math> or <math>U_{(1-N)}</math></p> <p><math>U_{(2-3)}</math> or <math>U_{(2-N)}</math></p> <p><math>U_{(3-1)}</math> or <math>U_{(3-N)}</math></p> <p><math>U_m</math></p> <p><math>U_m/U_0</math></p> <p><math>Ph_1</math></p> <p><math>Ph_2</math></p> <p><math>Ph_3</math></p> <p>Yes/No</p> <p>Yes/No</p>	<p>3 min</p> <p>Page 43 / 45</p> <p>438 V</p> <p>3,60 kA</p> <p>12,3 kA</p> <p>11,0 kA</p> <p>7,4 ms</p> <p>439 V</p> <p>440 V</p> <p>437 V</p> <p>439 V</p> <p>1,06</p> <p><math>35,6 \times 10^3 \text{ A}^2 \text{ s}</math></p> <p><math>371 \times 10^3 \text{ A}^2 \text{ s}</math></p> <p><math>308 \times 10^3 \text{ A}^2 \text{ s}</math></p> <p>- ms</p> <p>No</p> <p>No</p> <p>No</p> <p>Page - / -</p>

<b>LOVAG</b>		Test report No.: 00.291 / T 01 Page 27 / 45	Test report No.: 00.291 / T 01 Page 27 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{sc} = I_{cw}$ )		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.4.2; 8.3.8.4	<p>VERIFICATION OF OPERATIONAL CAPABILITY</p> <p>Short-circuit release</p> <p>Overload release</p> <p>Circuit diagram</p> <p>Rated operational voltage <math>U_n</math></p> <p>(Same rated operational voltage as used for the test of the rated service short-circuit breaking capacity)</p> <p>Rated current <math>I_n</math></p>	<p>min. setting</p> <p>max. setting</p> <p>V</p> <p>1600 A</p> <p>160 A</p> <p>415 V</p> <p>160 A</p>	<p>1600 A</p> <p>160 A</p> <p>415 V</p> <p>160 A</p>
Table XI	<p>Power factor</p> <p>Time constant</p> <p>Frequency</p>	<p>0,8 ms</p> <p>50 Hz</p>	<p>0,8 ms</p> <p>50 Hz</p>
Table VIII	<p>Operating cycles per hour</p> <p>On-time</p> <p>Number of operating cycles</p> <p>(5% of the number of operations given in column 4 of table 6)</p>	<p>120 /h</p> <p>50</p>	<p>120 /h</p> <p>180 ms</p> <p>50</p>

Test laboratory: ACAE IA.01

Authorized representative: *[Signature]*

Date: 00.09.18

F 947-2/38 Ind 2



ВЕРНО С  
ОРИГІНАЛА

*[Handwritten signature]* 57

LOVAG		Test report No.: 00.291 / T 01 Page 28 / 45	Test report No.: 00.291 / T 01 Page 29 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{th} = I_{th}$ )		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.5 8.3.4.2 8.3.5.3 8.3.6.5 8.3.7.3 8.3.7.7 8.3.8.4 C.3 B.10.3.1 H.3	<b>VERIFICATION OF DIELECTRIC WITHSTAND</b>  Test voltage $2 \times U_e$ , min. 1000 V Test sequence I Test sequence II Test sequence III Test sequence IV Test sequence V, stage 1 Test sequence V, stage 2 Combined test sequence Individual pole short-circuit test sequence Test sequence B.II Test sequence for circuit-breakers for IT-systems  Application of the test voltage - Main circuit of the circuit-breaker - Isolating contacts of the withdrawable unit (if applicable)  Test duration	1000 V	1000 V
8.3.3.2 60947-1 7.2.7	<b>VERIFICATION OF LEAKAGE CURRENT</b>  For circuit-breakers suitable for isolation having an operational voltage $U_e$ greater than 50 V.  - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)  Test voltage $1.1 \times U_e$ , 415 V  Application of the test voltage  Leakage current Test sequence I (in new condition) $\leq 0.5$ mA Test sequence I (after overload performance) $\leq 2$ mA Test sequence II $\leq 2$ mA Test sequence III $\leq 6$ mA Test sequence IV $\leq 2$ mA Test sequence V, stage 1 $\leq 2$ mA Test sequence V, stage 2 $\leq 6$ mA Combined test sequence $\leq 2$ mA Individual pole short-circuit test sequence $I_{th}$ $\leq 6$ mA Individual pole short-circuit test sequence $I_{tr}$ $\leq 6$ mA	456 V	456 V



ВЯРНО С  
ОРИГИНАЛ

Authorized representative

Date 00.09.18

F 947-227 Ind 2

Test laboratory: ACAE IA.01

Authorized representative

Date 00.09.18

F 947-220 Ind 2

*[Handwritten signatures]*

LOVAG		Test report No.: 00.291 / T 01 Page 30 / 45	Test report No.: 00.291 / T 01 Page 31 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{th} = I_{th}$ )		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.4.4 8.3.6.3 8.3.7.2 8.3.8.6 8.3.2.5 60947-1 8.3.3.3.1	<b>VERIFICATION OF TEMPERATURE-RISE ONLY FOR TERMINALS</b>  Temperature-rise test  Ambient temperature  Main circuits  Conventional thermal current $I_{th}$ Conventional thermal current for enclosure $I_{th}$ Conventional thermal current for neutral pole  Cabling characteristics Phase poles Cable Bar Number Length Tightening torque Neutral pole (if applicable) Cable Bar Number Length Tightening torque Arrangement:  Temperature-rise limits Terminals	40 °C  10...40°C  - A - A - A  70 mm <sup>2</sup> - x - mm 1 2000 mm 7 Nm  - mm <sup>2</sup> - x - mm - mm - Nm  3 phase <input type="checkbox"/> or poles in series <input checked="" type="checkbox"/>  ≤ 80 K	70 mm <sup>2</sup> - x - mm 1 2000 mm 7 Nm  - mm <sup>2</sup> - x - mm - mm - Nm  72 K



ВЕРНО С  
ОРИГИНАЛА


ly 56

*Handwritten signatures and initials.*

LOVAG		Test report No.: 00.291 / T 01 Page 31 / 45	Test report No.: 00.291 / T 01 Page 31 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{th} = I_{th}$ )		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 Table IX, X and XI	<b>VERIFICATION OF OVERLOAD RELEASES</b>  Cabling characteristics Cable Bar Number Length Tightening torque Arrangement  Reference temperature Ambient temperature Correction factor ( $k = 1$ for releases independent of ambient temperature) Current setting value  Test current  k x 1.45 x current setting value Test sequence I Test sequence II Combined test sequence  Tripping time	70 mm <sup>2</sup> - x - mm 1 2000 mm 3 phase <input type="checkbox"/> or poles in series <input checked="" type="checkbox"/>  40 °C ± 2 °C  k I <sub>n</sub>  ≤ 120 min	70 mm <sup>2</sup> - x - mm 1 2000 mm 7 Nm  40 °C - 160 A  232 A  1 min

Test laboratory: ACAE IA.01  
Authorized representative: *[Signature]*  
Date 00.09.18  
F 947-2/09 ind 2

LOVAG		Test report No.: 00.289 / T 01 Page 32 / 45	Test report No.: 00.289 / T 01 Page 33 / 45
Type test according to: IEC 60947-2 Test sequence II ( $I_{os} = I_{th}$ )		Type: T1B	Type: T1B
Standard and clause	Kind of tests and requirements	Test values	Results
60947-1 Table IX, X and XI	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	70 mm <sup>2</sup> - X - mm 1 2000 mm 7 Nm  40 °C ± 2 °C k I <sub>h</sub>  - A	70 mm <sup>2</sup> - X - mm 1 2000 mm 7 Nm  40 °C - 160 A - A
8.3.5.1 8.3.5.1 8.3.6.1 8.3.6.6 8.3.7.4 8.3.8.1	Cabling characteristics Cable Bar Number Length Tightening torque  Reference temperature Ambient temperature Correction factor (k = 1 for releases independent of ambient temperature) Current setting value  Test current  either k x 2.0 x I <sub>h</sub> Test sequence II ( $I_{os} = I_{th}$ ) before 8.3.4.1 Test sequence III, before 8.3.5.2 Test sequence IV, before 8.3.6.2 Test sequence IV after 8.3.6.5 Test sequence V, before 8.3.7.5 Combined test sequence before 8.3.8.2  or k x 2.5 x I <sub>h</sub> Test sequence II ( $I_{os} = I_{th}$ ) after 8.3.4.4 Test sequence III, after 8.3.5.3 Test sequence V, after 8.3.7.7 Combined test sequence after 8.3.8.6 Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems  Tripping time (for twice the value of current setting on single pole) Ph <sub>1</sub> Ph <sub>2</sub> Ph <sub>3</sub>	70 mm <sup>2</sup> - X - mm 1 2000 mm 7 Nm  40 °C ± 2 °C k I <sub>h</sub>  - A  400 A  400 A  ≤ 190 S ≤ 190 S ≤ 190 S	

LOVAG		Test report N° : 00.281 / T 01 Page 33 / 45																																																																																																																																		
Type test according to : IEC 60947-2		Type: T1B																																																																																																																																		
<p><b>Method for determination of short-circuit power factor</b></p> <p>The method is based on a three-phase current calibration with the maximum asymmetry on one phase. This condition is obtained by the operation of the closing device when no-load voltage wave is passing through zero value. In order to guarantee the required precision the tolerance on the closing time is ± 0.2 ms of the passing time through the zero value of this voltage. Power factor is checked on only one phase, in accordance with 8.3.2.2.4 of Test Instruction LOVAG LTI IEC 947-2 rev.3. The measurement of the power factor is performed by a digital recorder associated with a computer. The amplitude A (first positive peak) and B (first negative peak) are measured and from the formula <math>k = [B/A]</math> is deduced the power factor value showed in the annexed table.</p>																																																																																																																																				
																																																																																																																																				
<table border="1"> <thead> <tr> <th>Power factor</th> <th>k</th> <th>Power factor</th> <th>k</th> <th>Power factor</th> <th>k</th> <th>Power factor</th> <th>k</th> <th>Power factor</th> <th>k</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>0</td> <td>0,12</td> <td>0,313</td> <td>0,24</td> <td>0,529</td> <td>0,36</td> <td>0,682</td> <td>0,48</td> <td>0,794</td> </tr> <tr> <td>0,01</td> <td>0,031</td> <td>0,13</td> <td>0,354</td> <td>0,25</td> <td>0,544</td> <td>0,37</td> <td>0,693</td> <td>0,49</td> <td>0,801</td> </tr> <tr> <td>0,02</td> <td>0,061</td> <td>0,14</td> <td>0,365</td> <td>0,26</td> <td>0,558</td> <td>0,38</td> <td>0,707</td> <td>0,5</td> <td>0,809</td> </tr> <tr> <td>0,03</td> <td>0,09</td> <td>0,15</td> <td>0,375</td> <td>0,27</td> <td>0,572</td> <td>0,39</td> <td>0,713</td> <td>0,51</td> <td>0,817</td> </tr> <tr> <td>0,04</td> <td>0,118</td> <td>0,16</td> <td>0,384</td> <td>0,28</td> <td>0,586</td> <td>0,4</td> <td>0,723</td> <td>0,52</td> <td>0,824</td> </tr> <tr> <td>0,05</td> <td>0,145</td> <td>0,17</td> <td>0,413</td> <td>0,29</td> <td>0,599</td> <td>0,41</td> <td>0,733</td> <td>0,53</td> <td>0,831</td> </tr> <tr> <td>0,06</td> <td>0,172</td> <td>0,18</td> <td>0,431</td> <td>0,3</td> <td>0,612</td> <td>0,42</td> <td>0,742</td> <td>0,54</td> <td>0,838</td> </tr> <tr> <td>0,07</td> <td>0,197</td> <td>0,19</td> <td>0,448</td> <td>0,31</td> <td>0,624</td> <td>0,43</td> <td>0,751</td> <td>0,55</td> <td>0,845</td> </tr> <tr> <td>0,08</td> <td>0,222</td> <td>0,2</td> <td>0,465</td> <td>0,32</td> <td>0,636</td> <td>0,44</td> <td>0,76</td> <td></td> <td></td> </tr> <tr> <td>0,09</td> <td>0,246</td> <td>0,21</td> <td>0,482</td> <td>0,33</td> <td>0,648</td> <td>0,45</td> <td>0,769</td> <td></td> <td></td> </tr> <tr> <td>0,1</td> <td>0,269</td> <td>0,22</td> <td>0,498</td> <td>0,34</td> <td>0,66</td> <td>0,46</td> <td>0,777</td> <td></td> <td></td> </tr> <tr> <td>0,11</td> <td>0,292</td> <td>0,23</td> <td>0,514</td> <td>0,35</td> <td>0,674</td> <td>0,47</td> <td>0,785</td> <td></td> <td></td> </tr> </tbody> </table>			Power factor	k	Power factor	k	Power factor	k	Power factor	k	Power factor	k	0	0	0,12	0,313	0,24	0,529	0,36	0,682	0,48	0,794	0,01	0,031	0,13	0,354	0,25	0,544	0,37	0,693	0,49	0,801	0,02	0,061	0,14	0,365	0,26	0,558	0,38	0,707	0,5	0,809	0,03	0,09	0,15	0,375	0,27	0,572	0,39	0,713	0,51	0,817	0,04	0,118	0,16	0,384	0,28	0,586	0,4	0,723	0,52	0,824	0,05	0,145	0,17	0,413	0,29	0,599	0,41	0,733	0,53	0,831	0,06	0,172	0,18	0,431	0,3	0,612	0,42	0,742	0,54	0,838	0,07	0,197	0,19	0,448	0,31	0,624	0,43	0,751	0,55	0,845	0,08	0,222	0,2	0,465	0,32	0,636	0,44	0,76			0,09	0,246	0,21	0,482	0,33	0,648	0,45	0,769			0,1	0,269	0,22	0,498	0,34	0,66	0,46	0,777			0,11	0,292	0,23	0,514	0,35	0,674	0,47	0,785		
Power factor	k	Power factor	k	Power factor	k	Power factor	k	Power factor	k																																																																																																																											
0	0	0,12	0,313	0,24	0,529	0,36	0,682	0,48	0,794																																																																																																																											
0,01	0,031	0,13	0,354	0,25	0,544	0,37	0,693	0,49	0,801																																																																																																																											
0,02	0,061	0,14	0,365	0,26	0,558	0,38	0,707	0,5	0,809																																																																																																																											
0,03	0,09	0,15	0,375	0,27	0,572	0,39	0,713	0,51	0,817																																																																																																																											
0,04	0,118	0,16	0,384	0,28	0,586	0,4	0,723	0,52	0,824																																																																																																																											
0,05	0,145	0,17	0,413	0,29	0,599	0,41	0,733	0,53	0,831																																																																																																																											
0,06	0,172	0,18	0,431	0,3	0,612	0,42	0,742	0,54	0,838																																																																																																																											
0,07	0,197	0,19	0,448	0,31	0,624	0,43	0,751	0,55	0,845																																																																																																																											
0,08	0,222	0,2	0,465	0,32	0,636	0,44	0,76																																																																																																																													
0,09	0,246	0,21	0,482	0,33	0,648	0,45	0,769																																																																																																																													
0,1	0,269	0,22	0,498	0,34	0,66	0,46	0,777																																																																																																																													
0,11	0,292	0,23	0,514	0,35	0,674	0,47	0,785																																																																																																																													
<p>Test laboratory : ACAE I.A.01</p> <p>Authorized representative</p> <p>Date 00.09.18</p> <p>F 947-2/73 Ind 0</p>																																																																																																																																				




ВЯРНО С  
ОРИГИНАЛ

Handwritten signature

Handwritten signature

Handwritten signature and number 54

CIRCUIT DIAGRAM B



- 1 - Three-phase generator
- 2 - Back up circuit breaker
- 3 - Air reactors
- 4 - Three-phase transformer
- 5 - Short-circuit making switch
- 6 - Devices for the direction of fault current
- 7 - Non inductive shunt for current measurement
- 8 - Reactors
- 9 - Divider for voltage measurement
- 10 - Apparatus under test




ВЯРНО С  
 ОПРИГНАЛА

*[Handwritten signature]* 58

Testing circuit scheme


Adopted for performing the verification temperature rise and overload releases



Test report N° : 00.291 / T 01  
 Page 36 / 45  
 Type: T1B

**SYMBOLS USED FOR THE IDENTIFICATION OF THE MEASUREMENTS RECORDED BY THE OSCILLOGRAM**

- 1 First phase current
- 2 Second phase current
- 3 Third phase current
- 4 First phase voltage measured across the pole of the circuit breaker
- 5 Second phase voltage measured across the pole of the circuit breaker
- 6 Third phase voltage measured across the pole of the circuit breaker
- 7 First phase voltage measured phase to phase across the closing device
- 8 Second phase voltage measured phase to phase across the closing device
- 9 Third phase voltage measured phase to phase across the closing device
- 11 Shunt closing release voltage




*[Handwritten signature]*

*[Handwritten signature]*


ВАРНО С  
 ОПРИНАЛ

LOVAG  
 Test report No.: 00.291 / T 01  
 Page 39 / 45  
 Type: T1B  
 Type test according to: IEC 60947-2



Test laboratory: ACAE IA.01  
 F 947-273.ind 0  
 Authorized representative  
 Date 00.09.18

LOVAG  
 Test report No.: 00.291 / T 01  
 Page 38 / 45  
 Type: T1B  
 Type test according to: IEC 60947-2





Test laboratory: ACAE IA.01  
 F 947-273.ind 0  
 Authorized representative  
 Date 00.09.18

*Handwritten signature*

*Handwritten signature*

ВЯРНО С  
 ОПРИНАМА






ВЕРНО С  
ОРИГИНАЛА

*[Signature]*




Test report No.: 00.291 / T 01  
 Page 43 / 45  
 Type: T1B



Test laboratory: AGAE IA.01  
 Authorized representative: *[Signature]*  
 Date 00.05.18  
 F 947-2/73 Ind 0

Test report No.: 00.291 / T 01  
 Page 42 / 45  
 Type: T1B



Test laboratory: AGAE IA.01  
 Authorized representative: *[Signature]*  
 Date 00.05.18  
 F 947-2/73 Ind 0

*[Handwritten signature]*


*[Handwritten signature]*

*[Handwritten signature]*

ВЯНО С  
 ОРИГИНАЛА 01 02



<b>LOVAG</b>	Test report No.: 00.291 / T 01
	Page 44 / 45
Type test according to: IEC 60947-2	
Type: T1B	



ВЯРНО С  
ОРИГИНАЛА

63

<b>LOVAG</b>	Test report No.: 00.291 / T 01
	Page 45 / 45
Type test according to: IEC 60947-2	
Type: T1B	

COMPLETE LIST OF DRAWINGS AND DRAWINGS  
CHECKED FOR THE COMPLIANCE OF THE PRODUCT

Nr. Drawings	Denomination	Issue status
RA 0050.801-857	Standard circuit breaker assembly	99.05.19
RA 0050	Material list	99.05.19
RA 0054.801	Case assembly	99.05.19
RA 0054	Material list	99.05.19
RA 0055	Cover	99.05.19
RA 0056.801-802	Trip shaft assembly	99.05.19
RA 0056	Material list	99.05.19
RA 0082.801	Operating mechanism assembly	99.05.19
RA 0082	Material list	99.05.19
RA 0106	Arching chamber assembly	99.05.19
RA 0106	Material list	99.05.19
RA 0112.801	Fixed contact assembly	99.05.19
RA 0112	Material list	99.05.19
RA 0115	Fixed contact plate	99.05.19
RA 0116.801	Clamp assembly	99.05.19
RA 0116	Material list	99.05.19
RA 0132	Spring	99.05.19
RA 0134.801-810	Moving contact + relais assembly	99.05.19
RA 0134	Material list	99.05.19
RA 0136	Moving contact plate	99.05.19

Test laboratory: ACAE (A.01)

F 947-2/73 Ind 0


Authorized representative

Date 00.09.18

*MP*

*Handwritten signature*

Fig.	Material / Materiale	N. Series / Serie	Finishing / Finitura
Fig. 1	General tolerance for machining / Tolleranza generale per lavorazioni meccaniche: Tread quality tolerance Tolleranza filletti qualità Coord. punching N.C. mesh QUALITÀ PER DIMENSIONI / QUALITÀ PER QUOTE: UNI - 130 2168 Linear angles / Angoli angolari Flatness tolerances / Planarità tollerabilità	US II	Finishing / Finitura
Fig. 2	Fig. 1	Fig. 1	Fig. 1
Fig. 3	Fig. 1	Fig. 1	Fig. 1
Fig. 4	Fig. 1	Fig. 1	Fig. 1
Fig. 5	Fig. 1	Fig. 1	Fig. 1
Fig. 6	Fig. 1	Fig. 1	Fig. 1
Fig. 7	Fig. 1	Fig. 1	Fig. 1
Fig. 8	Fig. 1	Fig. 1	Fig. 1
Fig. 9	Fig. 1	Fig. 1	Fig. 1
Fig. 10	Fig. 1	Fig. 1	Fig. 1
Fig. 11	Fig. 1	Fig. 1	Fig. 1
Fig. 12	Fig. 1	Fig. 1	Fig. 1
Fig. 13	Fig. 1	Fig. 1	Fig. 1
Fig. 14	Fig. 1	Fig. 1	Fig. 1
Fig. 15	Fig. 1	Fig. 1	Fig. 1
Fig. 16	Fig. 1	Fig. 1	Fig. 1
Fig. 17	Fig. 1	Fig. 1	Fig. 1
Fig. 18	Fig. 1	Fig. 1	Fig. 1
Fig. 19	Fig. 1	Fig. 1	Fig. 1
Fig. 20	Fig. 1	Fig. 1	Fig. 1
Fig. 21	Fig. 1	Fig. 1	Fig. 1
Fig. 22	Fig. 1	Fig. 1	Fig. 1
Fig. 23	Fig. 1	Fig. 1	Fig. 1
Fig. 24	Fig. 1	Fig. 1	Fig. 1
Fig. 25	Fig. 1	Fig. 1	Fig. 1
Fig. 26	Fig. 1	Fig. 1	Fig. 1
Fig. 27	Fig. 1	Fig. 1	Fig. 1
Fig. 28	Fig. 1	Fig. 1	Fig. 1
Fig. 29	Fig. 1	Fig. 1	Fig. 1
Fig. 30	Fig. 1	Fig. 1	Fig. 1
Fig. 31	Fig. 1	Fig. 1	Fig. 1
Fig. 32	Fig. 1	Fig. 1	Fig. 1
Fig. 33	Fig. 1	Fig. 1	Fig. 1
Fig. 34	Fig. 1	Fig. 1	Fig. 1
Fig. 35	Fig. 1	Fig. 1	Fig. 1
Fig. 36	Fig. 1	Fig. 1	Fig. 1
Fig. 37	Fig. 1	Fig. 1	Fig. 1
Fig. 38	Fig. 1	Fig. 1	Fig. 1
Fig. 39	Fig. 1	Fig. 1	Fig. 1
Fig. 40	Fig. 1	Fig. 1	Fig. 1
Fig. 41	Fig. 1	Fig. 1	Fig. 1
Fig. 42	Fig. 1	Fig. 1	Fig. 1
Fig. 43	Fig. 1	Fig. 1	Fig. 1
Fig. 44	Fig. 1	Fig. 1	Fig. 1
Fig. 45	Fig. 1	Fig. 1	Fig. 1
Fig. 46	Fig. 1	Fig. 1	Fig. 1
Fig. 47	Fig. 1	Fig. 1	Fig. 1
Fig. 48	Fig. 1	Fig. 1	Fig. 1
Fig. 49	Fig. 1	Fig. 1	Fig. 1
Fig. 50	Fig. 1	Fig. 1	Fig. 1
Fig. 51	Fig. 1	Fig. 1	Fig. 1
Fig. 52	Fig. 1	Fig. 1	Fig. 1
Fig. 53	Fig. 1	Fig. 1	Fig. 1
Fig. 54	Fig. 1	Fig. 1	Fig. 1
Fig. 55	Fig. 1	Fig. 1	Fig. 1
Fig. 56	Fig. 1	Fig. 1	Fig. 1
Fig. 57	Fig. 1	Fig. 1	Fig. 1
Fig. 58	Fig. 1	Fig. 1	Fig. 1
Fig. 59	Fig. 1	Fig. 1	Fig. 1
Fig. 60	Fig. 1	Fig. 1	Fig. 1
Fig. 61	Fig. 1	Fig. 1	Fig. 1
Fig. 62	Fig. 1	Fig. 1	Fig. 1
Fig. 63	Fig. 1	Fig. 1	Fig. 1
Fig. 64	Fig. 1	Fig. 1	Fig. 1
Fig. 65	Fig. 1	Fig. 1	Fig. 1
Fig. 66	Fig. 1	Fig. 1	Fig. 1
Fig. 67	Fig. 1	Fig. 1	Fig. 1
Fig. 68	Fig. 1	Fig. 1	Fig. 1
Fig. 69	Fig. 1	Fig. 1	Fig. 1
Fig. 70	Fig. 1	Fig. 1	Fig. 1
Fig. 71	Fig. 1	Fig. 1	Fig. 1
Fig. 72	Fig. 1	Fig. 1	Fig. 1
Fig. 73	Fig. 1	Fig. 1	Fig. 1
Fig. 74	Fig. 1	Fig. 1	Fig. 1
Fig. 75	Fig. 1	Fig. 1	Fig. 1
Fig. 76	Fig. 1	Fig. 1	Fig. 1
Fig. 77	Fig. 1	Fig. 1	Fig. 1
Fig. 78	Fig. 1	Fig. 1	Fig. 1
Fig. 79	Fig. 1	Fig. 1	Fig. 1
Fig. 80	Fig. 1	Fig. 1	Fig. 1
Fig. 81	Fig. 1	Fig. 1	Fig. 1
Fig. 82	Fig. 1	Fig. 1	Fig. 1
Fig. 83	Fig. 1	Fig. 1	Fig. 1
Fig. 84	Fig. 1	Fig. 1	Fig. 1
Fig. 85	Fig. 1	Fig. 1	Fig. 1
Fig. 86	Fig. 1	Fig. 1	Fig. 1
Fig. 87	Fig. 1	Fig. 1	Fig. 1
Fig. 88	Fig. 1	Fig. 1	Fig. 1
Fig. 89	Fig. 1	Fig. 1	Fig. 1
Fig. 90	Fig. 1	Fig. 1	Fig. 1
Fig. 91	Fig. 1	Fig. 1	Fig. 1
Fig. 92	Fig. 1	Fig. 1	Fig. 1
Fig. 93	Fig. 1	Fig. 1	Fig. 1
Fig. 94	Fig. 1	Fig. 1	Fig. 1
Fig. 95	Fig. 1	Fig. 1	Fig. 1
Fig. 96	Fig. 1	Fig. 1	Fig. 1
Fig. 97	Fig. 1	Fig. 1	Fig. 1
Fig. 98	Fig. 1	Fig. 1	Fig. 1
Fig. 99	Fig. 1	Fig. 1	Fig. 1
Fig. 100	Fig. 1	Fig. 1	Fig. 1



ВІРНО С  
ОРИГІНАЛ

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*



ASSOCIAZIONE PER LA CERTIFICAZIONE  
DELLE APPARECCHIATURE ELETTRICHE



Via Tito Livio, 5 - 24123 - BERGAMO (Italy)

tel. +390354175244 fax. +390354534662 e-mail: acaecert@tin.it

# Certificate of Conformity

LOVAG-Certificate No. IT 04.016

## Apparatus

Moulded case Three Pole Air-break Independent operation Circuit-breakers  
Frame size 630 A · 1000 V (U) · 50/60 Hz · with microprocessor based  
overcurrent releases:

$I_n = 320 \text{ A to } 630 \text{ A}$

## Designation

T5N 630

## Manufacturer or responsible vendor

ABB SACE S.p.A. - Via Baioni, 35 - 24123 Bergamo (Italy)

## Tested for: ABB SACE S.p.A.

## Tested by: ACAE Laboratory IA.01

The apparatus, constructed in accordance with the description mentioned in  
the Test Report listed on this Certificate has been subjected to the series of  
proving tests in accordance with IEC 60947-2 (1995), Corrigendum (1997)  
and IEC 60947-2:1995/A1/1997 EN 60947-2:1996 and  
EN 60947-2:1996/A1:1997

The results are shown in the Test Report in accordance to LOVAG. The values  
obtained and the general performance are considered to comply with the  
above Standard(s) and to justify the characteristic assigned by the manufacturer  
as stated below.

Utilization category A

Test sequence: II ( $I_{cs} = I_{cu}$ )

$U_n = 440 \text{ V}$       $I_n = I_{cu} = 30 \text{ kA}$

This document includes Report No.: 03.089

Issue Date: 2004.02.24

Responsible Certification Body: ACAE



PRD N°070B Rev.00  
Signatory of EA and IAF Mutual Recognition Agreements

Mauro Marchi

Authorized Signature

Date: 2004.03.18



ВЕРНО С  
ОРИГИНАЛ 65

This Certificate applies only to  
the apparatus tested. The  
responsibility for conformity of  
any apparatus having the same  
designation with that tested  
rests with the manufacturer or  
responsible vendor.

This certificate has been pre-  
pared according to LOVAG  
(Low Voltage Agreement Group)  
Objectives and Operating Prin-  
ciples of mutual recognition.  
The responsible certification  
body as member of LOVAG  
issues a Certificate of Confor-  
mity with the above mentioned  
Standard(s) following the  
exclusive use of LOVAG Test  
Instructions wherever  
applicable.

Only integral reproduction of  
this Certificate or reproductions  
of this page accompanied by  
any page(s) on which are  
stated the tests performed and  
the assigned rated charac-  
teristics of the apparatus  
tested, are permitted without  
written permission from the  
LOVAG Signatory responsible  
for this Certificate.

## LOVAG CERTIFICATES

- LOVAG** is the Low Voltage Agreement Group which is an Agreement Group registered by EOTC the European Organisation for Conformity Assessment, Registration No. 0009. LOVAG's main purpose as an Agreement Group shall be for the mutual recognition of the test reports and/or certificates of conformity by its signatories.
- Membership** LOVAG presently has five signatories to the Agreement, ACAE (Italy), ALPHA (Germany), ASEFA (France), CEBEC (Belgium) and Intertek SEMKO AB (Sweden) and employs around 40 European Testing Laboratories.
- Certificates** LOVAG Certificates are issued by the signatory bodies to the Agreement using test reports and certificates in a common and recognisable format in the market. They are recognised and accepted in the European Economic Area and elsewhere in the world.
- Test Instructions** LOVAG uses common LOVAG Test Instructions for each of the International and European Standards covered by the Agreement and signatories to the Agreement abide by these when testing for LOVAG Certification.
- Qualifications** All signatory bodies to the Agreement are accredited and/or assessed to EN 45011 (ISO/IEC Guide 65) and their laboratories are accredited and/or assessed to EN ISO/IEC 17025.

For further information contact your local certification body from the list below or contact the Secretariat of LOVAG at: ALPHA e.V., Stresemannallee 19, D-60596 Frankfurt am Main, Phone: +49 69 9620 6343, Fax : +49 69 96206344, e-mail: secretariat@lovag.net

### LIST OF LOVAG SIGNATORIES:

<p><b>ACAE</b> Via Tito Livio 5 I-24123 Bergamo ITALY Fax: +39 035 453 4662 e-mail: acaecert@tin.it</p> 	<p><b>CEBEC</b> Avenue Van Kaiken 9A Bte 1 B-1070-Brussels BELGIUM Fax: +32 2 556 00 36 e-mail: info@cebec.be</p> 
<p><b>ALPHA e. V.</b> Stresemannallee 19 D-60596 Frankfurt am Main GERMANY Fax: +49 69 9620 6344 e-mail: office@alpha-cert.de</p> 	<p><b>Intertek SEMKO AB</b> Box 1103, Torshamnsgatan 43 SE-164 22 Kista SWEDEN Fax: +46 8 750 6030 e-mail: lovag@semko.se</p> 
<p><b>ASEFA</b> 33 av du general leclerc F-92260 Fontenay-aux-roses France Fax: +33 1 40 95 88 18 e-mail: asefa@lciio.fr</p> 	



**Test Report No. 03.089**

Test laboratory: ACAE IA.01  
 1 - 24123 Bergamo  
 Client: ABB SACE S.p.A.  
 Manufacturer: ABB SACE S.p.A.  
 Test object: Low voltage moulded case c.b. series TMAX  
 Type designation: T5N 630  
 Date(s) of test(s): from 2003.12.05 to 2004.01.09  
 Test specification: IEC 60947-2:1995, Corrigendum (1997) and IEC 60947-2:1995/A1:1997  
 EN 60947-2:1996 and EN 60947-2:1996/A1:1997  
 Test sequence(s): II (ics = Icu)

Test results: Ics / Icu at 440 V found in compliance with rated characteristics

The Record of Proving Test consists of:

- 44 pages LOVAG test report forms
- oscillograms
- other pages
- diagrams
- drawings nr. 1SDH000437 R0.102 enclosed
- photographs

Date of issue: 2004.02.24

Responsible Test Laboratory  
S. Mangano

Signatures: R. Oprandi *R. Oprandi*  
 (Authorized representative)

Note:  
 This test result relates only to the items tested.  
 The test report shall not be reproduced except in full  
 without the written approval of the test laboratory.



ВЯРНО С  
ОРИГИНАЛА  
67

Description and characterization of the test object

Characteristics

Type of circuit-breaker:

Number of poles: 3  
 Kind of current: a.c.  
 Number of phases: 3  
 Rated frequency: 50-60 HZ  
 Utilization category: A  
 Reference temperature: 40 °C  
 Suitability for isolation: Yes

Rated and limiting values: (according to test volume)

Main circuit:

Rated impulse withstand voltage  $U_{imp}$ : 8 kV  
 Rated insulation voltage  $U_i$ : 1000 V  
 Conventional thermal current  $I_{th} / I_{thB}$ : 630 A / -  
 Rated current  $I_n$ : 630 A  
 Rated current in the neutral pole: - A

Short-circuit characteristics:


$U_{LN}$	$I_{sm}/kA$	$I_{cw}/kA$	$I_{sc}/kA$	$I_{cu}/kA$	$I_{pr}/kA$
415	75,6	36	36	-	-
440	63	30	30	-	-
690	40	20	20	-	-
-	-	-	-	-	-
-	-	-	-	-	-

LOVAG

Releases:

- Shunt release:
  - Rated control circuit voltage  $U_c$
  - Kind of current
  - Rated frequency if a.c.
- Undervoltage or no-voltage release
  - Rated control circuit voltage  $U_c$
  - Kind of current
  - Rated frequency if a.c.
- Over-current release:
  - Short-circuit release
    - Instantaneous release
    - definite time-delay release
  - Rated current  $I_n$
  - Kind of current
  - Rated frequency if a.c.
  - Current setting (or range of settings)
- Time setting (or range of settings)
- Overload release (IEC 60947-1; 2.4.30):
  - Instantaneous release
  - definite time-delay release
  - inverse time-delay release
    - dependent on ambient air temperature
    - independent of ambient air temperature
  - Reference temperature
  - Rated current  $I_n$
  - Kind of current
  - Rated frequency if a.c.
  - Current setting (or range of settings)
  - Time setting (or range of settings)

Test laboratory: ACAE I.A.01



TRF IEC/EN 60947-2  
Ed. 2.1 form 3

Date 04.02.24

Authorized representative


*Rsp*

ВЕРНО С  
ОРИГИНАЛ *ly* 68

LOVAG

Time / current characteristics

Type designation of ABB SACE PR221DS overcurrent release



Test laboratory: ACAE I.A.01

TRF IEC/EN 60947-2  
Ed. 2.1 form 5

Date 04.02.24

Authorized representative


*Rsp*

*Handwritten signature*



Time / current characteristics

Type designation of ABB SACE PR221DS overcurrent release



Test laboratory: ACAE LA 01

*Raf*


Authorized representative

Date 04.02.24

TRF IEC/EN 60947-2  
Ed. 2.1 form 5

Time / current characteristics

Type designation of ABB SACE PR221DS overcurrent release



Test laboratory: ACAE LA 01

*Raf*

Authorized representative

Date 04.02.24

TRF IEC/EN 60947-2  
Ed. 2.1 form 5

ВЯРНО С  
ОРИГИНАЛ

**LOVAG**

Integral fused circuit-breakers:  
(Co-ordination with short-circuit protective devices)

Kind of protective devices

- Type of fuse
- Maximum operational voltage
- Rated current  $I_n$
- Maximum prospective short-circuit peak current

Individual enclosure:

- Type
- Kind of material
- Degree of protection
- Inside dimensions:
  - height
  - width
  - depth

When no enclosure:

Safety perimeter defined:  
height  
width  
depth

Kind of screen  
(woven wire mesh, perforated metal, expanded metal)

Size of holes ( $\leq 30 \text{ mm}^2$ )  
Distance during test

Openings around the manual operating means:  
Openings in the area of the manual operating means through which the arc chamber can be reached by a music wire of 0.25 mm diameter.

see page 8 / 44

see page 8 / 44

see page 8 / 44

see page 8 / 44

see page 8 / 44



see page 8 / 44

none

Type test according to: IEC 60947-2


Type: T5N 630

**INSTALLATION INSIDE METAL SCREEN FOR SHORT-CIRCUIT TESTS**



- ⊙ Con U<sub>n</sub>-690V isolating barriers for use with separators at face
- ⊙ When U<sub>n</sub>-690V Rear Isolating barrier and phase separators should be added

INTER	INSIDE	A	B	C	D	E	F	N	DIS
T4	U <sub>n</sub> -400V	30	25	264	159	194	50		
	U <sub>n</sub> -400V	60	45	314	159	194	50		RC0040/000
T4	U <sub>n</sub> -400V	30	25	264	159	194	200		
	U <sub>n</sub> -400V	60	45	314	159	194	200		
T5 400A	U <sub>n</sub> -400V	30	25	264	194	240	200		RC0040/001
	U <sub>n</sub> -400V	60	45	314	194	240	200		
T5 630A	U <sub>n</sub> -400V	90	85	384	194	240	200		RC0040/500
	U <sub>n</sub> -400V	120	105	434	194	240	200		



NOTE FOR ATURA  
PERFORATION GAUGE  
HOLLOW-TOTAL SURFACE BRIT-0, 46  
SP. METAL  
HOLLOW-TOTAL SURFACE BRIT-0, 46



Test laboratory: ACAE IA-01

Authorized representative

Date 04.02.24

TRF IEC/EN 60947-2  
Ed. 2.1 form 70

Authorized representative

Date 04.02.24

<b>LOVAG</b>	Test report No.: 03.089 Page 9 / 44
Type test according to: IEC 60947-2 Test sequence II	Type: TSN 630
<b>TEST SEQUENCE II (<math>I_{cs} = I_{cu}</math>)</b>	
Rated service short-circuit breaking capacity for circuit-breakers with $I_{cs} = I_{cu}$	
Test sequence II ( $I_{cs} = I_{cu}$ ) comprises the following tests:	
<b>Sub-clause Test</b>	<b>Page form</b>
8.3.5.1 Verification of overload releases	46
8.3.4.1 Rated service short-circuit breaking capacity	40 - 42
8.3.4.2 Verification of operational capability	43
8.3.4.3 Verification of dielectric withstand	32
8.3.4.4 Verification of leakage current (if applicable)	25
8.3.4.5 Verification of temperature-rise	44
8.3.5.4 Verification of overload releases	35
	46

<b>LOVAG</b>	Test report No.: 03.089 Page 10 / 44	
Type test according to: IEC 60947-2 Test sequence II ( $I_{cs} = I_{cu}$ )	Type: TSN 630	
<b>Standard and clause</b>	<b>Kind of tests and requirements</b>	<b>Test values Results</b>
60947-1 Table 9, 10 and 11	<b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b>  Cabling characteristics Cable 185 mm <sup>2</sup> Bar - X - mm Number 1 Length 2000 mm Tightening torque 25 Nm  Reference temperature 40 °C ± 2 °C Ambient temperature Correction factor (k = 1 for releases independent of ambient temperature) k Current setting value $I_n$  <b>Test current</b> either k x 2.0 x $I_n$ 256 A Test sequence II ( $I_{cs} = I_{cu}$ ) before 8.3.4.1 Test sequence III before 8.3.5.2 Test sequence IV before 8.3.6.2 Test sequence V after 8.3.6.5 Combined test sequence before 8.3.7.5 Verification of discrimination before 8.3.8.2 Verification of back-up protection before 8.3.5.2  or k x 2.5 x $I_n$ - A Test sequence II ( $I_{cs} = I_{cu}$ ) after 8.3.4.5 Test sequence III after 8.3.5.3 Test sequence V after 8.3.7.7 Combined test sequence after 8.3.8.6 Verification of discrimination after 8.3.5.3 Verification of back-up protection after 8.3.5.3 Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems  Tripping time (for twice the value of current setting on single pole) Ph <sub>1</sub> ≤ 30 s Ph <sub>2</sub> ≤ 30 s Ph <sub>3</sub> ≤ 30 s	185 mm <sup>2</sup> - X - mm 2000 mm 25 Nm  22 °C - 128 A  256 A  - A  28 s 28 s 29 s
Test laboratory: ACAE IA.01	Authorized representative	TRF IEC/EN 60947-2 Ed. 2.1 form 46
	Date 04.02.24	

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

ВАРНО С  
ОРИГИНАЛ



*[Handwritten signature]*

Authorized representative

Date 04.02.24

TRF IEC/EN 60947-2  
Ed. 2.1 form 99

LOVAG		Test report No.: 03.089 Page 11 / 44	Test report No.: 03.089 Page 12 / 44
Type test according to: IEC 60947-2 Test sequence II (Ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.4.1 8.3.8.3	<b>TEST OF RATED SERVICE SHORT-CIRCUIT BREAKING CAPACITY</b>		
Table 4	Utilization category Rated operational voltage $U_n$ Recovery voltage Rated service short-circuit breaking capacity $I_{cs}$ Rated ultimate short-circuit breaking capacity $I_{cu}$ Ratio between $I_{cs}$ and $I_{cu}$	A 440 V $1.05 \times U_n$ 30 kA 30 kA $I_{cs}/I_{cu} = 100\%$	462 V 20 kA
Table 11	Power factor Frequency	0,25 50 Hz	0,25 50 Hz
8.3.2.1 7.2.1.1.3	Control supply voltage Maximum value of the closing time	$0,85 \times U_n - V$	- V - ms
60947-1 Table 9, 10 and 11	Sequence of operation Circuit diagram Calibration of the test circuit Safety area Installation of the material tested Energization direction Cabling characteristics Cable Bar Number Length Tightening torque	O - t - CO - t - CO Pageform 169 Pageform 6 Pageform 6 Top/Bottom 185 mm <sup>2</sup> - x - mm 1 supply side load side 250 mm 250 mm 25 Nm	O - t - CO - t - CO Page 33 / 44 Page 12 / 44 Page 7 / 44 Page 8 / 44 Top 185 mm <sup>2</sup> - x - mm 1 500 mm 250 mm 25 Nm



ВЯРНО С  
ОРИГІНАЛАМ

Handwritten signature

Handwritten signature

LOVAG		Test report No.: 03.089 Page 12 / 44	Test report No.: 03.089 Page 12 / 44
Type test according to: IEC 60947-2		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 8.3.4.1.5	<b>CALIBRATION OF THE TEST CIRCUIT (*)</b>		
	Oscillogram		Page 36 / 44
	Applied voltage		7462 V
	Frequency	50 Hz	50 Hz
	RMS current value at 20 ms	$I_k$ $I_z$ $I_s$	30,9 kA 31,8 kA 31,9 kA
	Average RMS. value		31,5 kA
	Peak current maximum value		66,0 kA
	Power factor		0,25
	(*) Description of the method for determination of short-circuit power factor is given at page 32 / 44		

Authorized representative  
Date 04.02.24

Test laboratory: ACAE IA.01

TRF IEC/EN 60947-2  
Ed. 2.1 form 169

LOVAG		Test report No.: 03.089 Page 13 / 44	Test report No.: 03.089 Page 14 / 44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
	<p><b>OPERATION „O“</b></p> <p>Oscillogram</p> <p>Peak current value</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average value</p> <p>Ratio between <math>U_m</math> and <math>U_e</math></p> <p>Joule Integral</p> <p>Melting of the fusible element</p> <p>Holes in the PE-sheet (if applicable)</p> <p>Cracks observed if Yes</p> <p>Time interval between operations</p> <p><b>OPERATION „CO“</b></p> <p>Oscillogram</p> <p>Applied voltage</p> <p>Peak current value</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average value</p> <p>Ratio between <math>U_m</math> and <math>U_e</math></p> <p>Joule Integral</p> <p>Closing operation time</p> <p>Melting of the fusible element</p> <p>Cracks observed if Yes</p>	<p>Page 40 / 44</p> <p>17,0 kA</p> <p>18,8 kA</p> <p>25,4 kA</p> <p>6,9 ms</p> <p>462 V</p> <p>463 V</p> <p>463 V</p> <p>1,05</p> <p><math>641 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>737 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>1810 \times 10^3 \text{ A}^2\text{s}</math></p> <p>No</p> <p>No</p> <p>No</p> <p>No</p> <p>Page - / -</p> <p>3 min</p> <p>Page 41 / 44</p> <p>463 V</p> <p>11,5 kA</p> <p>27,0 kA</p> <p>20,6 kA</p> <p>8,0 ms</p> <p>463 V</p> <p>464 V</p> <p>462 V</p> <p>463 V</p> <p>1,05</p> <p><math>476 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>1710 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>1310 \times 10^3 \text{ A}^2\text{s}</math></p> <p>- ms</p> <p>No</p> <p>No</p> <p>Page - / -</p>	<p>Page 42 / 44</p> <p>462 V</p> <p>25,5 kA</p> <p>17,3 kA</p> <p>14,7 kA</p> <p>9,3 ms</p> <p>464 V</p> <p>462 V</p> <p>463 V</p> <p>1,05</p> <p><math>1720 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>996 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>642 \times 10^3 \text{ A}^2\text{s}</math></p> <p>- ms</p> <p>No</p> <p>No</p> <p>Page - / -</p>

LOVAG		Test report No.: 03.089 Page 14 / 44	Test report No.: 03.089 Page 14 / 44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
7.2.1.1.3	<p>Time interval between operations</p> <p><b>OPERATION „CO“</b></p> <p>Oscillogram</p> <p>Applied voltage</p> <p>Peak current value</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average value</p> <p>Ratio between <math>U_m</math> and <math>U_e</math></p> <p>Joule Integral</p> <p>Closing operation time</p> <p>Melting of the fusible element</p> <p>Cracks observed if Yes</p>	<p>3 min</p> <p><math>i_1</math></p> <p><math>i_2</math></p> <p><math>i_3</math></p> <p><math>U_{(1-2)}</math> or <math>U_{(1-N)}</math></p> <p><math>U_{(2-3)}</math> or <math>U_{(2-N)}</math></p> <p><math>U_{(3-1)}</math> or <math>U_{(3-N)}</math></p> <p><math>U_m</math></p> <p><math>U_m/U_e</math></p> <p>Ph<sub>1</sub></p> <p>Ph<sub>2</sub></p> <p>Ph<sub>3</sub></p> <p>Yes/No</p> <p>Yes/No</p> <p>Yes/No</p> <p>Yes/No</p> <p>3 min</p> <p><math>U_{(1-2)}</math> or <math>U_{(1-N)}</math></p> <p><math>U_{(2-3)}</math> or <math>U_{(2-N)}</math></p> <p><math>U_{(3-1)}</math> or <math>U_{(3-N)}</math></p> <p><math>U_m</math></p> <p><math>U_m/U_e</math></p> <p>Ph<sub>1</sub></p> <p>Ph<sub>2</sub></p> <p>Ph<sub>3</sub></p> <p>Yes/No</p> <p>Yes/No</p>	<p>3 min</p> <p>Page 42 / 44</p> <p>462 V</p> <p>25,5 kA</p> <p>17,3 kA</p> <p>14,7 kA</p> <p>9,3 ms</p> <p>464 V</p> <p>462 V</p> <p>463 V</p> <p>1,05</p> <p><math>1720 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>996 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>642 \times 10^3 \text{ A}^2\text{s}</math></p> <p>- ms</p> <p>No</p> <p>No</p> <p>Page - / -</p>




Test laboratory: ACAE IA.01  
Authorized representative: *Rof*  
Date 04.02.24

TRF IEC/EN 60947-2  
Ed. 2.1 form 42

*[Handwritten signatures]*

**ВАРФОС**  
*[Handwritten initials]*

LOVAG		Test report No.: 03.069 Page 157/44	Test report No.: 03.069 Page 16/44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.4.2	VERIFICATION OF OPERATIONAL CAPABILITY		
8.3.8.4	Short-circuit release min. setting Overload release max. setting Circuit diagram Rated operational voltage $U_n$ (Same rated operational voltage as used for the test of the rated service short-circuit breaking capacity) Rated current $I_n$	- A - A Page - - V - A	- A - A Page - - V - A
Table 11	Power factor Time constant Frequency	- - ms - Hz	- - ms - Hz
Table 6	Operating cycles per hour On-time Number of operating cycles (5 % of the number of operations given in column 4 of table 8)	- /h - -	- /h - ms -
		Note: Test not carried out (see clause 8.3.4.2 Amendment 2)	
		TRF IEC/EN 60947-2 Ed. 2.1 (amr. 43)	TRF IEC/EN 60947-2 Ed. 2.1 (amr. 32)
		Date 04.02.24	Date 04.02.24
		Authorized representative	Authorized representative



ВАРНО С  
ОРИГИНАЛ

01 74

*Handwritten signature*

LOVAG		Test report No.: 03.069 Page 16/44	Test report No.: 03.069 Page 16/44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND		
8.3.3.5 8.3.4.3 8.3.5.3 8.3.6.5 8.3.7.3 8.3.7.7 8.3.8.5 B.10.3.1 A.5 A.6.3 C.3 H.3	Test voltage $2 \times U_n$ , min. 1000 V Test sequence I Test sequence II Test sequence III Test sequence IV Test sequence V, stage 1 Test sequence V, stage 2 Combined test sequence Test sequence B.II Verification of discrimination Verification of back-up protection Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems	1000 V	1000 V
8.3.3.2.2 a)	Application of the test voltage - Main circuit of the circuit-breaker - Isolating contacts of the withdrawable unit (if applicable)		
	Test duration	1 min	1 min
		TRF IEC/EN 60947-2 Ed. 2.1 (amr. 32)	TRF IEC/EN 60947-2 Ed. 2.1 (amr. 32)
		Date 04.02.24	Date 04.02.24
		Authorized representative	Authorized representative

*Handwritten signature*

LOVAG		Test report No.: 03.089 Page 17 / 44
Type test according to: IEC 60847-2 Test sequence II (ics = Icu)		Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results
8.3.3.2	<b>VERIFICATION OF LEAKAGE CURRENT</b> For circuit-breakers suitable for isolation having an operational voltage $U_0$ greater than 50 V. - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	484 V
60947-1 7.2.7	Test voltage Application of the test voltage  Leakage current Test sequence I (in new condition) Test sequence I (after overload performance) Test sequence II Test sequence III Test sequence IV Test sequence V, stage 1 Test sequence V, stage 2 Combined test sequence Individual pole short-circuit test sequence $I_{sc}$ Individual pole short-circuit test sequence $I_r$	1.1 x $U_0$ 440 V  ≤ 0.5 mA ≤ 2 mA ≤ 2 mA ≤ 6 mA ≤ 2 mA ≤ 2 mA ≤ 2 mA ≤ 6 mA ≤ 6 mA ≤ 6 mA ≤ 6 mA

Test laboratory: ACAE IA.01

*Rsp*

Authorized representative

Date 04.02.24

TRF IEC/EN 60847-2  
Ed. 2.1 form 25

Test laboratory: ACAE IA.01

*Rsp*

Authorized representative

Date 04.02.24

TRF IEC/EN 60847-2  
Ed. 2.1 form 44

LOVAG		Test report No.: 03.089 Page 18 / 44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results
8.3.4.4 8.3.6.3 8.3.7.2 8.3.8.6 8.3.2.5	<b>VERIFICATION OF TEMPERATURE-RISE ONLY FOR TERMINALS</b>  Temperature-rise test	-
60947-1 8.3.3.3.1	Ambient temperature	10...40 °C - °C
60947-1 8.3.3.3.4	<b>Main circuits</b> Conventional thermal current $I_{th}$ Conventional thermal current for enclosure $I_{thw}$ Conventional thermal current for the neutral pole	- A - A - A
60947-1 Table 9, 10 and 11	<b>Cabling characteristics</b> Phase poles Cable Bar Number Length Tightening torque Neutral pole (if applicable) Cable Bar Number Length Tightening torque Arrangement:	- mm <sup>2</sup> - x - mm - - mm - Nm - mm <sup>2</sup> - x - mm - - mm - Nm 3 phase <input type="checkbox"/> or poles in series <input type="checkbox"/>
Table 7	Temperature-rise limits Terminals	≤ K - K

Note:  
Test not carried out (see table X)

ВЯРНО С  
ОРИГИНАЛА



*Ans 85*

LOVAG		Test report No.: 03.089 Page 19 / 44	Test report No.: 03.089 Page 20 / 44
Type test according to: IEC 60947-2 Test sequence II (Ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 Table 9, 10 and 11	<b>VERIFICATION OF OVERLOAD RELEASES</b>  Cabling characteristics Cable 185 mm <sup>2</sup> Bar - x - mm 1 Number 2000 mm Length 25 Nm Tightening torque Arrangement: 3 phase <input type="checkbox"/> or poles in series <input checked="" type="checkbox"/>  Reference temperature 40 °C ± 2 °C Ambient temperature Correction factor k (k = 1 for releases independent of ambient temperature) Current setting value 128 A  Test current k x 1.45 x current setting value 185.6 A Test sequence I after 8.3.3.6 Test sequence II after 8.3.4.4 Combined test sequence after 8.3.8.6  Tripping time ≤ 60 min  1 min	185 mm <sup>2</sup> - x - mm 1 2000 mm 25 Nm  40 °C - 128 A  185.6 A  1 min	185 mm <sup>2</sup> - x - mm 1 2000 mm 25 Nm  40 °C - 128 A  185.6 A  1 min

LOVAG		Test report No.: 03.089 Page 20 / 44	Test report No.: 03.089 Page 20 / 44
Type test according to: IEC 60947-2 Test sequence II (Ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 Table 9, 10 and 11	<b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b>  Cabling characteristics Cable 185 mm <sup>2</sup> Bar - x - mm 1 Number 2000 mm Length 25 Nm Tightening torque  Reference temperature 40 °C ± 2 °C Ambient temperature Correction factor (k = 1 for releases independent of ambient temperature) k Current setting value I <sub>n</sub>  Test current either k x 2.0 x I <sub>n</sub> - A Test sequence II (I <sub>cs</sub> = I <sub>cu</sub> ) before 8.3.4.1 Test sequence III before 8.3.5.2 Test sequence IV after 8.3.6.2 Test sequence V before 8.3.7.5 Combined test sequence before 8.3.8.2 Verification of discrimination before 8.3.5.2 Verification of back-up protection before 8.3.5.2  or k x 2.5 x I <sub>n</sub> 320 A Test sequence II (I <sub>cs</sub> = I <sub>cu</sub> ) after 8.3.4.5 Test sequence III after 8.3.5.3 Test sequence V after 8.3.7.7 Combined test sequence after 8.3.8.6 Verification of discrimination after 8.3.5.3 Verification of back-up protection after 8.3.5.3 Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems  Tripping time (for twice the value of current setting on single pole) Ph <sub>1</sub> ≤ 30 s Ph <sub>2</sub> ≤ 30 s Ph <sub>3</sub> ≤ 30 s	185 mm <sup>2</sup> - x - mm 1 2000 mm 25 Nm  40 °C ± 2 °C - I <sub>n</sub>  - A  320 A  after 8.3.4.5 after 8.3.5.3 after 8.3.7.7 after 8.3.8.6 after 8.3.5.3 after 8.3.5.3  ≤ 30 s ≤ 30 s ≤ 30 s	185 mm <sup>2</sup> - x - mm 1 2000 mm 25 Nm  22 °C - 128 A  - A  320 A  19 s 18 s 18 s



Authorized representative

Date 04.02.24

TRF IEC/EN 60947-2  
Ed. 2.1 form 35

Test laboratory: ACAE IA.01

Authorized representative

Date 04.02.24

TRF IEC/EN 60947-2  
Ed. 2.1 form 45

*Handwritten signature*

ВЪРНО С  
ОРИГИНАЛА

*Handwritten initials*



LOVAG		Test report No.: 03.089 Page 21 / 44	Test report No.: 03.089 Page 22 / 44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 Table 9, 10 and 11	<p><b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b></p> <p>Cabling characteristics Cable 185 mm<sup>2</sup> Bar - x - mm 2 Number 2 Length 2000 mm Tightening torque 25 Nm</p> <p>Reference temperature 40 °C ± 2 °C Ambient temperature Correction factor (k = 1 for releases independent of ambient temperature) k Current setting value I<sub>n</sub></p> <p>Test current 1260 A</p> <p>either k x 2.0 x I<sub>n</sub> Test sequence II (I<sub>th</sub> = I<sub>th</sub>) before 8.3.4.1 Test sequence III before 8.3.5.2 Test sequence IV before 8.3.6.2 Test sequence V after 8.3.6.5 Combined test sequence before 8.3.7.5 Verification of discrimination before 8.3.8.2 Verification of back-up protection before 8.3.5.2</p> <p>or k x 2.5 x I<sub>n</sub> Test sequence II (I<sub>th</sub> = I<sub>th</sub>) after 8.3.4.5 Test sequence III after 8.3.5.3 Test sequence V after 8.3.7.7 Combined test sequence after 8.3.8.6 Verification of discrimination after 8.3.5.3 Verification of back-up protection after 8.3.5.3 Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems</p> <p>Tripping time (for twice the value of current setting on single pole) Ph<sub>1</sub> ≤ 118 s Ph<sub>2</sub> ≤ 118 s Ph<sub>3</sub> ≤ 118 s</p>	<p>185 mm<sup>2</sup> - x - mm 2 2000 mm 25 Nm</p> <p>22 °C - 630 A</p> <p>1260 A</p> <p>- A</p> <p>108 s 106 s 107 s</p>	

LOVAG		Test report No.: 03.089 Page 22 / 44	Test report No.: 03.089 Page 22 / 44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.4.1 8.3.8.3	<p><b>TEST OF RATED SERVICE SHORT-CIRCUIT BREAKING CAPACITY</b></p> <p>Utilization category A</p> <p>Rated operational voltage U<sub>n</sub> 440 V Recovery voltage 1.05 x U<sub>n</sub> Rated service short-circuit breaking capacity I<sub>cs</sub> 30 kA Rated ultimate short-circuit breaking capacity I<sub>cu</sub> 30 kA Ratio between I<sub>cs</sub> and I<sub>cu</sub> I<sub>cs</sub>/I<sub>cu</sub> = 100 %</p>	<p>462 V 30 kA</p>	<p>462 V 30 kA</p>
Table 4	<p>Power factor 0.25 Frequency 50 Hz</p>	<p>0.25 50 Hz</p>	<p>0.25 50 Hz</p>
Table 11	<p>Control supply voltage 0.85 x U<sub>n</sub> - V Maximum value of the closing time</p>	<p>- V - ms</p>	<p>- V - ms</p>
8.3.2.1 7.2.1.1.3	<p>Sequence of operation Circuit diagram Calibration of the test circuit</p>	<p>O - t - CO - t - CO Pageform 169</p>	<p>O - t - CO - t - CO Page 33 / 44 Page 23 / 44</p>
60947-1 Table 9, 10 and 11	<p>Safety area Installation of the material tested Energization direction</p> <p>Cabling characteristics Cable 185 mm<sup>2</sup> Bar - x - mm 2 Number 2 Length 500 mm supply side 250 mm load side</p> <p>Tightening torque</p>	<p>Pageform 6 Pageform 6 Top/Bottom Bottom</p>	<p>Page 7 / 44 Page 8 / 44 Bottom</p>

Test laboratory: ACAE IA.01  
Authorized representative

Date 04.02.24

TRF IEC/EN 60947-2  
Ed. 2.1 form 46



ВЯРНО С  
ОРИГИНАЛА

es 77



LOVAG		Test report No.: 03.069 Page 25 / 44	Test report No.: 03.069 Page 26 / 44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
7.2.1.1.3	<p>Time interval between operations</p> <p>OPERATION „CO“</p> <p>Oscillogram</p> <p>Applied voltage</p> <p>Peak current value</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average value</p> <p>Ratio between <math>U_m</math> and <math>U_e</math></p> <p>Joule integral</p> <p>Closing operation time</p> <p>Melting of the fusible element</p> <p>Cracks observed if Yes</p>	<p>3 min</p> <p>3 min</p> <p><math>I_1</math> <math>I_2</math> <math>I_3</math></p> <p><math>U_{(1-2)}</math> or <math>U_{(1-3)}</math> or <math>U_{(2-3)}</math> or <math>U_{(1-3)}</math></p> <p><math>U_m</math> <math>U_e</math></p> <p><math>Ph_1</math> <math>Ph_2</math> <math>Ph_3</math></p> <p>Yes/No Yes/No</p>	<p>3 min</p> <p>Page 39 / 44</p> <p>462 V</p> <p>22,8 kA</p> <p>22,1 kA</p> <p>12,2 kA</p> <p>7,7 ms</p> <p>463 V</p> <p>464 V</p> <p>462 V</p> <p>463 V</p> <p>1,05</p> <p><math>1200 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>1390 \times 10^3 \text{ A}^2\text{s}</math></p> <p><math>335 \times 10^3 \text{ A}^2\text{s}</math></p> <p>-ms</p> <p>No</p> <p>No</p> <p>No</p> <p>Page - / -</p>
Test laboratory: ACAE IA.01		Authorized representative	Authorized representative
Date 04.02.24		Date 04.02.24	Date 04.02.24

*[Handwritten signatures]*

LOVAG		Test report No.: 03.069 Page 26 / 44	Test report No.: 03.069 Page 26 / 44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.4.2	<p>VERIFICATION OF OPERATIONAL CAPABILITY</p> <p>Short-circuit release</p> <p>Overload release</p> <p>Circuit diagram</p> <p>Rated operational voltage <math>U_n</math></p> <p>(Same rated operational voltage as used for the test of the rated service short-circuit breaking capacity)</p> <p>Rated current <math>I_n</math></p>	<p>min. setting</p> <p>max. setting</p> <p>440 V</p> <p>630 A</p> <p>630 A</p> <p>440 V</p> <p>630 A</p>	<p>630 A</p> <p>630 A</p> <p>Page 34 / 44</p> <p>440 V</p> <p>648 A</p>
Table 11	<p>Power factor</p> <p>Time constant</p> <p>Frequency</p>	<p>0,80</p> <p>-ms</p> <p>50 Hz</p>	<p>0,77</p> <p>-ms</p> <p>50 Hz</p>
Table 8	<p>Operating cycles per hour</p> <p>On-time</p> <p>Number of operating cycles</p> <p>(% of the number of operations given in column 4 of table 8)</p>	<p>60 /h</p> <p>50</p>	<p>60 /h</p> <p>145 ms</p> <p>50</p>
Test laboratory: ACAE IA.01		Authorized representative	Authorized representative
Date 04.02.24		Date 04.02.24	Date 04.02.24



ВЯРНО С  
ОРИГИНАЛ

*[Handwritten initials]* 79

LOVAG		Test report No.: 03.089 Page 27 / 44	Test report No.: 03.089 Page 28 / 44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
	<b>VERIFICATION OF DIELECTRIC WITHSTAND</b>		
	Test voltage	1000 V	1000 V
8.3.3.5	2 x U <sub>n</sub> , min. 1000 V		
8.3.4.3	Test sequence I		
8.3.5.3	Test sequence II		
8.3.6.5	Test sequence III		
8.3.7.3	Test sequence IV		
8.3.7.7	Test sequence V, stage 1		
8.3.8.5	Test sequence V, stage 2		
B.10.3.1	Combined test sequence		
A.5	Verification of discrimination		
A.6.3	Verification of back-up protection		
C.3	Individual pole short-circuit test sequence		
H.3	Test sequence for circuit-breakers for IT-systems		
8.3.3.2.2 a)	Application of the test voltage		
	- Main circuit of the circuit-breaker		
	- Isolating contacts of the withdrawable unit (if applicable)		
	Test duration	1 min	1 min



Ref

Authorized representative

TRF IEC/EN 60947-2  
Ed. 2.1 form 32

Date 04.02.24

LOVAG		Test report No.: 03.089 Page 28 / 44	Test report No.: 03.089 Page 28 / 44
Type test according to: IEC 60947-2 Test sequence II (ics = Icu)		Type: TSN 630	Type: TSN 630
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
	<b>VERIFICATION OF LEAKAGE CURRENT</b>		
	For circuit-breakers suitable for isolation having an operational voltage U <sub>n</sub> greater than 50 V.		
8.3.3.2	- Main circuit of the circuit-breaker		
	- Isolating contacts of a withdrawable unit (if applicable)		
	Test voltage	1.1 x U <sub>n</sub> 440 V	484 V
60947-1 7.2.7	Application of the test voltage		
	<b>Leakage current</b>		
8.3.3.2	Test sequence I (in new condition)	≤ 0.5 mA	- mA
8.3.3.5	Test sequence I (after overload performance)	≤ 2 mA	- mA
8.3.4.3	Test sequence II	≤ 2 mA	< 2 mA
8.3.5.3	Test sequence III	≤ 6 mA	- mA
8.3.6.5	Test sequence IV	≤ 2 mA	- mA
8.3.7.3	Test sequence V, stage 1	≤ 2 mA	- mA
8.3.7.7	Test sequence V, stage 2	≤ 6 mA	- mA
8.3.8.5	Combined test sequence	≤ 2 mA	- mA
C.3	Individual pole short-circuit test sequence I <sub>su</sub>	≤ 6 mA	- mA
H.3	Individual pole short-circuit test sequence I <sub>tr</sub>	≤ 6 mA	- mA

Test laboratory: ACAE IA.01

Ref

Authorized representative

TRF IEC/EN 60947-2  
Ed. 2.1 form 25

Date 04.02.24

*[Handwritten signatures]*

ВЕРНО С  
ОРИГИНАЛА

ly 80




LOVAG		Test report No.: 03.089 Page 31 / 44	Test report No.: 03.089 Page 32 / 44
Type test according to: IEC 60947-2 Test sequence II (Ics = Icu)		Type: T5N 630	Type: T5N 630
Standard and clause	Kind of tests and requirements	Test values	Results
60947-1 Table 9, 10 and 11	<p><b>VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</b></p> <p>Cabling characteristics Cable 185 mm<sup>2</sup> Bar - x - mm 2 Length 2000 mm Tightening torque 25 Nm</p> <p>Reference temperature 40 °C ± 2 °C Ambient temperature - Correction factor (k = 1 for released independent of ambient temperature) k 630 A Current setting value I<sub>n</sub> -A</p> <p>Test current -A</p> <p>either k x 2,0 x I<sub>n</sub> Test sequence II (I<sub>cs</sub> = I<sub>cu</sub>) before 8.3.4.1 Test sequence III before 8.3.5.2 Test sequence IV before 8.3.6.2 Test sequence V after 8.3.6.5 Test sequence VI before 8.3.7.5 Combined test sequence before 8.3.8.2 Verification of discrimination before 8.3.5.2 Verification of back-up protection before 8.3.5.2</p> <p>or k x 2,5 x I<sub>n</sub> Test sequence II (I<sub>cs</sub> = I<sub>cu</sub>) after 8.3.4.5 Test sequence III after 8.3.5.3 Test sequence V after 8.3.7.7 Combined test sequence after 8.3.8.6 Verification of discrimination after 8.3.5.3 Verification of back-up protection after 8.3.5.3 Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems</p> <p>Tripping time (for twice the value of current setting on single pole) Ph1 ≤ 118 s Ph2 ≤ 118 s Ph3 ≤ 118 s</p>	<p>185 mm<sup>2</sup> - x - mm 2 2000 mm 25 Nm</p> <p>26 °C - 630 A -A</p> <p>1575 A</p> <p>64 s 67 s 67 s</p>	
8.3.5.1 8.3.5.1 8.3.6.1 8.3.6.6 8.3.7.4 8.3.8.1 A.5 A.6.3  8.3.5.4 8.3.5.4 8.3.7.8 8.3.8.7 A.5 A.6.3 C.4 H.4			

TRF IECEN 60947-2  
Ed. 2.1 form 46

Date 04.02.24

Authorized representative




ВІРНО С  
ОРИГІНАЛ

82

LOVAG		Test report No.: 03.089 Page 32 / 44	Test report No.: 03.089 Page 32 / 44																																																																																																																																		
Type test according to: IEC 60947-2		Type: T5N 630	Type: T5N 630																																																																																																																																		
<p><b>Method for determination of short-circuit power factor</b></p> <p>The method is based on a three-phase current calibration with the maximum asymmetry on one phase. This condition is obtained by the operation of the closing device when no-load voltage wave is passing through zero value. In order to guarantee the required precision the tolerance on the closing time is ± 0.2 ms of the passing time through the zero value of this voltage.</p> <p>Power factor is checked on only one phase, in accordance with 8.3.2.2.4 of Test Instruction LOVAG LTI IEC 947-2 rev.3.</p> <p>The measurement of the power factor is performed by a digital recorder associated with a computer. The amplitude A (first positive peak) and B (first negative peak) are measured and from the formula <math>k = [B/A]</math> is deduced the power factor value showed in the annexed table.</p>																																																																																																																																					
<table border="1"> <thead> <tr> <th>Power factor</th> <th>k</th> <th>Power factor</th> <th>k</th> <th>Power factor</th> <th>k</th> <th>Power factor</th> <th>k</th> <th>Power factor</th> <th>k</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>0</td> <td>0,12</td> <td>0,313</td> <td>0,24</td> <td>0,528</td> <td>0,36</td> <td>0,682</td> <td>0,48</td> <td>0,784</td> </tr> <tr> <td>0,01</td> <td>0,031</td> <td>0,13</td> <td>0,334</td> <td>0,25</td> <td>0,544</td> <td>0,37</td> <td>0,693</td> <td>0,49</td> <td>0,801</td> </tr> <tr> <td>0,02</td> <td>0,061</td> <td>0,14</td> <td>0,355</td> <td>0,26</td> <td>0,559</td> <td>0,38</td> <td>0,707</td> <td>0,5</td> <td>0,809</td> </tr> <tr> <td>0,03</td> <td>0,09</td> <td>0,15</td> <td>0,375</td> <td>0,27</td> <td>0,572</td> <td>0,39</td> <td>0,713</td> <td>0,51</td> <td>0,817</td> </tr> <tr> <td>0,04</td> <td>0,118</td> <td>0,16</td> <td>0,394</td> <td>0,28</td> <td>0,588</td> <td>0,4</td> <td>0,723</td> <td>0,52</td> <td>0,824</td> </tr> <tr> <td>0,05</td> <td>0,145</td> <td>0,17</td> <td>0,413</td> <td>0,29</td> <td>0,599</td> <td>0,41</td> <td>0,733</td> <td>0,53</td> <td>0,831</td> </tr> <tr> <td>0,06</td> <td>0,172</td> <td>0,18</td> <td>0,431</td> <td>0,3</td> <td>0,612</td> <td>0,42</td> <td>0,742</td> <td>0,54</td> <td>0,838</td> </tr> <tr> <td>0,07</td> <td>0,197</td> <td>0,19</td> <td>0,448</td> <td>0,31</td> <td>0,624</td> <td>0,43</td> <td>0,751</td> <td>0,55</td> <td>0,845</td> </tr> <tr> <td>0,08</td> <td>0,222</td> <td>0,2</td> <td>0,465</td> <td>0,32</td> <td>0,636</td> <td>0,44</td> <td>0,76</td> <td></td> <td></td> </tr> <tr> <td>0,09</td> <td>0,246</td> <td>0,21</td> <td>0,482</td> <td>0,33</td> <td>0,648</td> <td>0,45</td> <td>0,769</td> <td></td> <td></td> </tr> <tr> <td>0,1</td> <td>0,269</td> <td>0,22</td> <td>0,498</td> <td>0,34</td> <td>0,66</td> <td>0,46</td> <td>0,777</td> <td></td> <td></td> </tr> <tr> <td>0,11</td> <td>0,292</td> <td>0,23</td> <td>0,514</td> <td>0,35</td> <td>0,674</td> <td>0,47</td> <td>0,785</td> <td></td> <td></td> </tr> </tbody> </table>				Power factor	k	Power factor	k	Power factor	k	Power factor	k	Power factor	k	0	0	0,12	0,313	0,24	0,528	0,36	0,682	0,48	0,784	0,01	0,031	0,13	0,334	0,25	0,544	0,37	0,693	0,49	0,801	0,02	0,061	0,14	0,355	0,26	0,559	0,38	0,707	0,5	0,809	0,03	0,09	0,15	0,375	0,27	0,572	0,39	0,713	0,51	0,817	0,04	0,118	0,16	0,394	0,28	0,588	0,4	0,723	0,52	0,824	0,05	0,145	0,17	0,413	0,29	0,599	0,41	0,733	0,53	0,831	0,06	0,172	0,18	0,431	0,3	0,612	0,42	0,742	0,54	0,838	0,07	0,197	0,19	0,448	0,31	0,624	0,43	0,751	0,55	0,845	0,08	0,222	0,2	0,465	0,32	0,636	0,44	0,76			0,09	0,246	0,21	0,482	0,33	0,648	0,45	0,769			0,1	0,269	0,22	0,498	0,34	0,66	0,46	0,777			0,11	0,292	0,23	0,514	0,35	0,674	0,47	0,785		
Power factor	k	Power factor	k	Power factor	k	Power factor	k	Power factor	k																																																																																																																												
0	0	0,12	0,313	0,24	0,528	0,36	0,682	0,48	0,784																																																																																																																												
0,01	0,031	0,13	0,334	0,25	0,544	0,37	0,693	0,49	0,801																																																																																																																												
0,02	0,061	0,14	0,355	0,26	0,559	0,38	0,707	0,5	0,809																																																																																																																												
0,03	0,09	0,15	0,375	0,27	0,572	0,39	0,713	0,51	0,817																																																																																																																												
0,04	0,118	0,16	0,394	0,28	0,588	0,4	0,723	0,52	0,824																																																																																																																												
0,05	0,145	0,17	0,413	0,29	0,599	0,41	0,733	0,53	0,831																																																																																																																												
0,06	0,172	0,18	0,431	0,3	0,612	0,42	0,742	0,54	0,838																																																																																																																												
0,07	0,197	0,19	0,448	0,31	0,624	0,43	0,751	0,55	0,845																																																																																																																												
0,08	0,222	0,2	0,465	0,32	0,636	0,44	0,76																																																																																																																														
0,09	0,246	0,21	0,482	0,33	0,648	0,45	0,769																																																																																																																														
0,1	0,269	0,22	0,498	0,34	0,66	0,46	0,777																																																																																																																														
0,11	0,292	0,23	0,514	0,35	0,674	0,47	0,785																																																																																																																														
<p>Test laboratory: ACAE IA.01</p> <p>Authorized representative</p> <p>Date 04.02.24</p>																																																																																																																																					


CIRCUIT DIAGRAM TYPE A



- 1 - Three-phase generator
- 2 - Back-up circuit breaker
- 3 - Air reactors
- 4 - Three-phase transformer
- 5 - Short-circuit making switch
- 6 - Device for the detection of fault current
- 7 - Non inductive shunts for current measurement
- 8 - Resistors
- 9 - Dividers for voltage measurement
- 10 - Apparatus under test




CIRCUIT DIAGRAM TYPE S





- 1 - Three-phase transformer
- 2 - Short-circuit making switch
- 3 - Device for the detection of fault currents
- 4 - Apparatus under test
- 5 - Load (reactors and resistances)
- 6 - Non inductive shunts for current measurement
- 8 - Voltmeter for voltage measurement



*Handwritten signature*


ВЕРНО С  
ОРИГИНАЛА

<p><b>LOVAG</b></p>	<p>Test report No.: 03.089 Page 35 / 44</p>
<p>Type test according to: IEC 60947-2</p>	<p>Type: T5N 630</p>
<p align="center"><b>SYMBOLS USED FOR THE IDENTIFICATION OF THE MEASUREMENTS RECORDED BY THE OSCILLOGRAM</b></p> <ol style="list-style-type: none"> <li>1 First phase current</li> <li>2 Second phase current</li> <li>3 Third phase current</li> <li>4 First phase voltage measured across the pole of the circuit breaker</li> <li>5 Second phase voltage measured across the pole of the circuit breaker</li> <li>6 Third phase voltage measured across the pole of the circuit breaker</li> <li>7 First phase voltage measured phase to phase across the closing device</li> <li>8 Second phase voltage measured phase to phase across the closing device</li> <li>9 Third phase voltage measured phase to phase across the closing device</li> <li>11 Shunt closing release voltage</li> </ol>	
<p>Test laboratory: ACAE IA.01</p> <p align="right">         Authorized representative     </p> <p align="right">       TRF IECEN 60947-2        Ed. 2.1 form 170        Date 04.02.24     </p>	






**ВЕРНО С  
ОРИГИНАЛ**









**ВЯРНО С  
 ОПИГНААА**









ВЯРНО С  
 ОПРИНИМАА

87 86








COMPLETE LIST OF DRAWINGS AND DRAWINGS  
 CHECKED FOR THE COMPLIANCE OF THE PRODUCT

TYPE OF DOCUMENT	N° DRAWING	Index of modification	Date
Assembly drawing*	ISDH000437R0.106	N0115	03-01-22
Instruction leaflet *	ISDH000437R0.001	L0815	03-07-21
Nameplate divg *	Allegato L	-	03-03-20
Welded case or metal (frame dwgs (all components))	RA1645	L0707	03-01-24
	RA1646	L0707	03-01-24
	RA1722	L0823	03-09-02
	RA1813	L0832	03-09-22
Material list	RA1722.801	L0707	03-01-24
	RA1813.801	L0707	03-01-24
Operating handle dwg	RA1675	L0808	03-06-30
Main and arcing fixed contacts assembly dwgs	RA1823	L0823	03-09-02
	RA1681	L0808	03-06-30
Material list	RA1624.802	L0808	03-06-30
	RA1651.802	L0808	03-06-30
Main and arcing moving contacts assembly dwgs	RA1612	L0823	03-09-02
	RA1613	L0707	03-01-24
Material list	RA1612.802	L0808	03-06-30
	RA1613.801	L0707	03-01-24
Main and arcing fixed contacts dwgs	RA1628	L0808	03-06-30
Main and arcing moving contacts dwgs	RA1615	L0707	03-01-24
Operating mechanism assembly dwgs	RA1659	L0707	03-01-24
Material list	RA1659.803	L0808	03-06-30
Operating mechanism springs dwg	RA1716	L0707	03-01-24
Main contact springs dwg	RA1651	L0707	03-01-24
Arc chute assembly dwg	RA1636	L0707	03-01-24
Material list	RA1636.802	L0707	03-01-24
Overcurrent release assembly dwg	RA1810	L0707	03-01-24
Material list	RA1810.830	L0707	03-01-24
	RA1810.853	L0707	03-01-24
Tripping device assembly dwg	RA2333	L0687	02-12-11
Material list	RA2333.801	L0687	02-12-11
Electronic release components dwgs	REC374	L0381	01-04-19
	REC522	L0456	01-10-01
Material list	REC074-1	L0656	02-10-25
	REC080812	L0456	01-10-01
	REC058009	L0456	01-10-01
Main terminals dwg	158488	27875	94-10-07
Tripping characteristic *	ISDH000436R0.511	-	03-01-22
Screen for SC Tests	FG0840/050	-	02-10-18

ВЕРНО С  
 ОПРИТНАЛА



Drawn Dra. 2002-07-11 COLLEONI R.	Supp. dep. Off. Resp.	Title TITOLO	Scale SCALE
Appr. Appr.	Take over dep. Off. Sott. Resp.	File No NUMERO FILE	Drawn Dra.
Appr. Appr.	Appr. Appr.	Spec. No NUMERO SPEC.	Drawn Dra.
Appr. Appr.	Appr. Appr.	Spec. No NUMERO SPEC.	Drawn Dra.

*Am*

*Handwritten signature*



ВЯРНО С  
ОРИГИНАЛ *ly 89*



ASSOCIATION ALFA ETIPELUTICIONE  
SOCIETA' ALFA-ACAE/ISTITUTO SILE ELETTRICITA'

Via Tito Livio, 5 - 24123 - BERGAMO (Italy)

tel. +39 035 2175244 fax. +39 035 4534628 e-mail: acae@acae.it



# Certificate of Conformity

LOVAG-Certificate No. IT 06.034

### Apparatus

Three poles circuit breaker 630 V (U<sub>n</sub>) - 1000 V (U<sub>i</sub>) - 1000 A (I<sub>u</sub>) - 50/60 Hz at 70 kA at 230V - 36 kA at 415 V - 30 kA at 440 V - 25 kA at 500 V - 15 kA at 690 V - I<sub>sc</sub> 20 kA at 690 V with short-circuit and overcurrent releases; I<sub>n</sub> = 1000 A

### Designation

T6N 1000

### Manufacturer or responsible vendor

ABB SACE S.p.A. - Via Bajori, 35 - 24123 Bergamo (Italy)

### Tested for: ABB SACE S.p.A.

### Tested by: ACAE Laboratory I.A. 01

The apparatus, constructed in accordance with the description mentioned in the Test Report, listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60947-2 (2003) EN 60947-2 (2003):

### Test sequence:

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s), and to satisfy the characteristics assigned by the manufacturer as stated below.

### Utilization category B

Suitable for isolation

$U_n = 690$  V a.c. 50/60 Hz  $U_i = 1000$  V  $U_{sc} = 8kV$

This document includes Report No. 05.087

Issue Date: 2006.07.13

Responsible Certification Body: ACAE



**SINCERT**  
SOCIETA' ITALIANA CERTIFICAZIONE  
SISTEMI ELETTRICI

Mauro Marchi

Authorized Signature

Date: 2006.07.20

Supervisors of IEC and IEC related Recognition Agreements

## LOVAG CERTIFICATES

### LOVAG

is the Low Voltage Agreement Group which is a Mutual Agreement Group of Certification Bodies founded in 1987 which has achieved a high level of competence in testing and certification of low voltage equipment. LOVAG's main purpose as an Agreement Group shall be for the mutual recognition of the test reports and/or certificates of conformity by its signatories.

### Membership

LOVAG presently has six signatories to the Agreement: ACAE (Italy), ALPHA (Germany), Applus CTC (Spain), ASEFA (France), Intertek Semko AB (Sweden) and SGS Belgium NV - Division SGS CEBEC (Belgium) and employs around 40 European Testing Laboratories.

### Certificates

LOVAG Certificates are issued by the signatory bodies to the Agreement using test reports and certificates in a common and recognisable format in the market. They are recognised and accepted in the European Economic Area and elsewhere in the world.

### Test Instructions

LOVAG uses common LOVAG Test Instructions for each of the International and European Standards covered by the Agreement and signatories to the Agreement abide by these when testing for LOVAG Certification.

### Qualifications

All signatory bodies to the Agreement are accredited and/or assessed to EN 45011 (ISO/IEC Guide 65) and their laboratories are accredited and/or assessed to EN ISO/IEC 17025.

For further information contact your local certification body from the list below or contact the Secretariat of LOVAG at: ALPHA e.V., Stresemannallee 15, D-60596 Frankfurt am Main, Phone: +49 69 9620 6343, Fax + 49 69 9620 6344, e-mail: secretariat@lovag.net

### LIST OF LOVAG SIGNATORIES:

<p><b>ACAE</b> Via Tito Livio 5 I-24123 Bergamo ITALY Fax +39 035 453 4642 e-mail: acae@acae.it</p>	<p><b>ASEPA</b> 33 av du general Indecq F-92260 Fontenay-aux-roses FRANCE Fax + 33 1 47 33 35 10 e-mail: asepa@asepa.fr</p>	<p><b>SGS Belgium NV</b> Division SGS CEBEC Avenue Van Kalken 9/A Bld 1 B-1070 Brussels BELGIUM Fax + 32 2 555 00 36 e-mail: alio@pirmag.be</p>	<p><b>Intertek Semko AB</b> Box 1100 Torshamnsgatan 43 SE-784 22 Kalle SWEDEN Fax + 46 8 72 8026 e-mail: lovag@intertek.se</p>
<p><b>ALPHA e.V.</b> Stresemannallee 15 D-60596 Frankfurt am Main GERMANY Fax +49 69 9620 6044 e-mail: alpha@alpha-cert.de</p>	<p><b>Applus+ CTC</b> Campus UAB E-08193 Bellaterra (Barcelona) SPAIN Fax + 34 93 497 2070 e-mail: amaginat@applus.com</p>		

ОПУТНААА 2/90

Test Report No. 05.087

Test laboratory: ACAE IA.01  
 Client: I - 24123 Bergamo  
 Manufacturer: ABB SACE S.p.A.  
 Test object: Low voltage molded case circuit breaker TMAX  
 Type designation: T6N 1000  
 Date(s) of test(s): from 2006.01.30 to 2006.02.15  
 Test specification: IEC 60947-2:2003  
 EN 60947-2:2003

Test sequence(s): 1

Test results: Sequence 1 at 650V found in compliance with rated characteristics

The Record of Proving Test consists of:

- 35 pages LOVAG test report forms - oscillograms
- other pages - drawing 1SDH00047SR0.125 enclosed
- diagrams - photographs

Date of issue: 2006.07.13

Signatures: R. Oprandi  
 (Name, function and signature of authorized representative)

Responsible Test Laboratory  
 M. Bortoli  
 ACAE Inspector  
 M. Marchi

Note:  
 The test result relates only to the items tested.  
 This test report shall not be reproduced except in full  
 without the written approval of the test laboratory.



Description and characterization of the test object

Characteristics

Type of circuit-breaker: T6N 1000  
 Number of poles: 3  
 Kind of current: a.c.  
 Number of phases: 3  
 Rated frequency: 50-60 Hz  
 Utilization category: B  
 Reference temperature: 40 °C  
 Suitability for isolation: Yes

Rated and limiting values: (according to test volume)

Main circuit:  
 Rated impulse withstand voltage  $U_{imp}$ : 8 kV  
 Rated insulation voltage  $U_i$ : 1000 V  
 Conventional thermal current  $I_n / I_{th}$ : 1000 / - A  
 Rated current  $I_n$ : 1000 A  
 Rated current in the neutral pole: - A

Short-circuit characteristics:

$U_N$	$I_{cm}/kA$	$I_{cs}/kA$	$I_{cw}/kA$	$I_{sc}/kA$	$I_{tr}/kA$
230 ac	154	70	70	10	-
415 ac	75.6	36	36	10	-
440 ac	63	30	30	10	-
500 ac	52.5	25	25	10	-
650 ac	40	20	15	10	-

*[Handwritten signatures and initials]*

ВЕРНО С  
ОРИГИНАЛ

*[Handwritten signature]*

**LOVAG**

**Control circuits:**

**Electrical control circuits:**

Kind of current -

Rated frequency - Hz

Rated control circuit voltage  $U_c$  - V

Rated control supply voltage  $U_s$  - V

Rated impulse withstand voltage  $U_{imp}$  - kV

Rated insulation voltage  $U_i$  - V

**Air-supply control circuits:**

Rated supply pressure - kPa

Limits of pressure - kPa

Required volume for each closing operation - m<sup>3</sup>

Required volume for each opening operation - m<sup>3</sup>

**Auxiliary circuits:**

Rated operational voltage  $U_o$  - V

Rated impulse withstand voltage  $U_{imp}$  - kV

Rated insulation voltage  $U_i$  - V

Rated frequency - Hz

Rated operational current  $I_o$  - A

Number of circuits -

Number and kind of contact elements -

*R. Ghomah*

Authorized representative



ВАРНО С  
ОРИГИНАЛ

*ay 92*

*[Handwritten signatures]*

**LOVAG**

**Releases:**

**Shunt release:**

- Rated control circuit voltage  $U_c$  - V

- Kind of current a.c.

- Rated frequency if a.c. 50-60 Hz

**Undervoltage or no-voltage release**

- Rated control circuit voltage  $U_o$  - V

- Kind of current -

- Rated frequency if a.c. - Hz

**Over-current release:**

- Short-circuit release

- Instantaneous release Yes

- definite time-delay release -

- Rated current  $I_n$  1000 A

- Kind of current a.c.

- Rated frequency if a.c. 50-60 Hz

- Current setting (or range of settings) 1500 to 10000 A

- Time setting (or range of settings) - s

**Overload release (IEC 60947-1; 2.4.30):**

- Instantaneous release -

- definite time-delay release -

- inverse time-delay release Yes

dependent on ambient air temperature

independent of ambient air temperature

- Reference temperature Yes

- Rated current  $I_n$  40 °C

- Kind of current 1000 A

- Rated frequency if a.c. a.c.

- Current setting (or range of settings) 50-60 Hz

- Time setting (or range of settings) 400 to 1000 A

from 3s to 18s at 6xI<sub>n</sub> (1)

(1) Symbol explanation at page 6 / 35

*R. Ghomah*

Authorized representative





<p><b>LOVAG</b></p> <p>Test report No.: 05.087 Page 7 / 35</p>	<p><b>Integral fused circuit-breakers:</b> (Co-ordination with short-circuit protective devices)</p> <p>Kind of protective devices</p> <ul style="list-style-type: none"> <li>- V</li> <li>- A</li> <li>- KA</li> </ul> <p>Kind of fuse</p> <ul style="list-style-type: none"> <li>- Maximum operational voltage</li> <li>- Rated current <math>I_n</math></li> <li>- Maximum prospective short-circuit peak current</li> </ul> <p><b>Individual enclosure:</b></p> <ul style="list-style-type: none"> <li>- Type</li> <li>- Kind of material</li> <li>- Degree of protection</li> <li>- Inside dimensions</li> <li>height - mm</li> <li>width - mm</li> <li>depth - mm</li> </ul> <p><b>When no enclosure:</b></p> <p>Safety perimeter defined:</p> <p>height - mm width - mm depth - mm</p> <p>Kind of screen (woven wire mesh, perforated metal, expanded metal)</p> <p>Size of holes (<math>\leq 30 \text{ mm}^2</math>)</p> <p>Distance during test</p> <p><b>Openings around the manual operating means:</b></p> <p>Openings in the area of the manual operating means through which the arc chamber can be reached by a music wire of 0.25 mm diameter.</p>	<p>Test laboratory: ACAE IA.01</p> <p>Authorized representative: <i>R. Gherard</i></p> <p>Date: 08.07.13</p> <p>TRF IEC/EN 60947-2 Ed. 3.0 form 5</p>
--	--	---

*[Handwritten signature]*

*[Handwritten signature]*

**ВЯРНО С  
ОРИГИНАЛА**



*[Handwritten signature]* 94

<p><b>LOVAG</b></p> <p>Test report No.: 05.087 Page 8 / 35</p>	<p><b>INSTALLATION INSIDE METAL SCREEN</b></p> <p>ABB SACE L.V. 501837/021</p> <p>Test laboratory: ACAE IA.01</p> <p>Authorized representative: <i>R. Gherard</i></p> <p>Date: 08.07.13</p> <p>TRF IEC/EN 60947-2 Ed. 3.0 form 177</p>
--	--

<b>LOVAG</b>		Test report No.: 05.087 Page 9 / 35		
<b>THE SAMPLES UNDER TEST</b>				
N°	Identification Number	Rated current (A)	Sequence	Page
1	AG 01095074	1000	I at 690 V	10 - 31 / 35
Test laboratory: AC&E IA.01		Authorized representative <i>R. Ghemul</i>		Date 05.07.13
		TRF IEC/EN 60947-2 Ed. 3.0 form 177		

<b>LOVAG</b>		Test report No.: 05.087 Page 10 / 35
Type test according to: IEC 60947-2 Test sequence I		
<b>TEST SEQUENCE I</b>		
General performance characteristics		
Test sequence I comprises the following tests:		
Sub-clause Test	Page-Form	Test Report Page No.
8.3.3.1 Tripping limits and characteristics	14 - 24	11 - 16
8.3.3.2 Dielectric properties	25	17
Verification of impulse withstand voltage	26	18
Power-frequency withstand verification	26	18
Verification of creepage distances	27	19
Verification of leakage current (if applicable)	28 - 32	20 - 24
8.3.3.3 Mechanical operation and operational performance capability	33	25
8.3.3.4 Overload performance (if applicable)	34	26
8.3.3.5 Verification of dielectric withstand	27	27
Verification of leakage current (if applicable)	35 - 36	28
8.3.3.6 Verification of temperature-rise	37	29
8.3.3.7 Verification of overload releases	38	30
8.3.3.8 Verification of undervoltage and shunt releases (if applicable)	39	31
8.3.3.9 Verification of main contact position (if applicable)		
Test laboratory: AC&E IA.01		Date 08.07.13
Authorized representative <i>R. Ghemul</i>		TRF IEC/EN 60947-2 Ed. 3.0 form 13

*AG*

*[Signature]*

*[Signature]*


ВЯРНО С  
ОРИГИНАЛА

*[Signature]* 95



LOVAG		Test report No.: 05.087 Page 11 / 35	Test report No.: 05.087 Page 12 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: TSN 1000	Type: TSN 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1 60947-1 Table 9, 10 and 11	<b>TEST OF TRIPPING LIMITS AND CHARACTERISTICS</b>  Cabling characteristics Cable Bar Number Length Tightening torque  Opening under short-circuit conditions  Ambient air temperature  Minimum / Maximum current setting  Single or combination of phase pole(s) Test current(s) Duration of current flow No tripping Test current(s) Duration of current flow Tripping  Combination of phase poles Test current(s) Duration of current flow No tripping Test current(s) Duration of current flow Tripping  Combination of phase poles Test current(s) Duration of current flow No tripping Test current(s) Duration of current flow Tripping	150 mm <sup>2</sup> - X - mm 4 2000 mm 43 Nm  10...40 °C 1500 / 9500 A 1/2 0.8 x 1500 / 9500 A ≥ 200 ms 1.2 x 1500 / 9500 A ≤ 200 ms 2/3 0.8 x 1500 / 9500 A ≥ 200 ms 1.2 x 1500 / 9500 A ≤ 200 ms 3/1 0.8 x 1500 / 9500 A ≥ 200 ms 1.2 x 1500 / 9500 A ≤ 200 ms	150 mm <sup>2</sup> - X - mm 4 2000 mm 43 Nm  20 °C 1200 / 7600 A 220 / 220 ms 1800 / 11400 A 33 / 30 ms 1200 / 7600 A 220 / 220 ms 1800 / 11400 A 34 / 32 ms 1200 / 7600 A 220 / 220 ms 1800 / 11400 A 32 / 28 ms
8.3.3.1.2	Additional test of opening under short-circuit conditions on each phase pole individually  Minimum / Maximum current setting 1500 / 9500 A  Single pole tripping values given by manufacturer: phase poles 1500 / 9500 A neutral pole (if different to phase pole) - / - A  Phase pole 1 Test current(s) 1.2 x 1500 / 9500 A Duration of current flow ≤ 200 ms Tripping  Phase pole 2 Test current(s) 1.2 x 1500 / 9500 A Duration of current flow ≤ 200 ms Tripping  Phase pole 3 Test current(s) 1.2 x 1500 / 9500 A Duration of current flow ≤ 200 ms Tripping  Neutral pole (if applicable) Test current(s) 1.2 x - / - A Duration of current flow ≤ - ms Tripping	1800 / 11400 A 33 / 31 ms  1800 / 11400 A 35 / 33 ms  1800 / 11400 A 34 / 32 ms  - / - A - / - ms	TRF IEC/EN 60947-2 Ed. 3.0 form 14 Date 08.07.13

LOVAG		Test report No.: 05.087 Page 12 / 35	Test report No.: 05.087 Page 12 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: TSN 1000	Type: TSN 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1.2	Additional test of opening under short-circuit conditions on each phase pole individually  Minimum / Maximum current setting 1500 / 9500 A  Single pole tripping values given by manufacturer: phase poles 1500 / 9500 A neutral pole (if different to phase pole) - / - A  Phase pole 1 Test current(s) 1.2 x 1500 / 9500 A Duration of current flow ≤ 200 ms Tripping  Phase pole 2 Test current(s) 1.2 x 1500 / 9500 A Duration of current flow ≤ 200 ms Tripping  Phase pole 3 Test current(s) 1.2 x 1500 / 9500 A Duration of current flow ≤ 200 ms Tripping  Neutral pole (if applicable) Test current(s) 1.2 x - / - A Duration of current flow ≤ - ms Tripping	1800 / 11400 A 33 / 31 ms  1800 / 11400 A 35 / 33 ms  1800 / 11400 A 34 / 32 ms  - / - A - / - ms	TRF IEC/EN 60947-2 Ed. 3.0 form 16 Date 08.07.13



ВЯРНО С  
ОРИГИНАЛА

en 96

LOVAG		Test report No.: 05.087 Page 13 / 35	Test report No.: 05.087 Page 14 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: TSN 1000	Type: TSN 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1.3	Opening under overload conditions Ambient air temperature: 10...40 °C	- °C	- °C
8.3.3.1.3 a)	Instantaneous or definite time-delay releases Minimum / Maximum current setting Single or combination of phase pole(s) Test current(s) Duration of current flow No tripping Test current(s) Duration of current flow Tripping Single or combination of phase pole(s) Test current(s) Duration of current flow No tripping Test current(s) Duration of current flow Tripping Single or combination of phase pole(s) Test current(s) Duration of current flow No tripping Test current(s) Duration of current flow Tripping	- / - A ... / ... 0.9 x - / - A ≥ - S 1.1 x - / - A S - S ... / ... 0.9 x - / - A ≥ - S 1.1 x - / - A S - S ... / ... 0.9 x - / - A ≥ - S 1.1 x - / - A S - S	- / - A - / - S - / - A - / - S - / - A - / - S - / - A - / - S - / - A - / - S - / - A - / - S - / - A - / - S - / - A - / - S

LOVAG		Test report No.: 05.087 Page 14 / 35	Test report No.: 05.087 Page 14 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: TSN 1000	Type: TSN 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1.3 b)	Inverse time-delay releases dependent on ambient air temperature Minimum / Maximum current setting Conventional time Reference temperature (according to the manufacturer's data) Ambient air temperature Tripping values in accordance with the manufacturer's temperature/current data: at minimum current setting at maximum current setting Conventional non-tripping current No tripping Conventional tripping current Operating time	- / - A - h - °C - A to - A - A to - A 1.05 x - / - A > - min 1.3 x - / - A ≤ - min	- / - A - / - min - / - A - / - min

Test laboratory: ACAE IA.01

TRF IECEN 60947-2  
Ed. 3.0 form 18

*R. G. Gromov*

Authorized representative

Date 06.07.13

Test laboratory: ACAE IA.01

TRF IECEN 60947-2  
Ed. 3.0 form 17

*R. G. Gromov*

Authorized representative

Date 06.07.13



ВЕРНО С  
ОРИГИНАЛА

86 98

LOVAG		Test report No.: 05.087 Page 15/35	Test report No.: 05.087 Page 15/35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1.3 b)	inverse time-delay releases independent on ambient air temperature Minimum / Maximum current setting Conventional time Measurement 1: Ambient air temperature Reference temperature according to the manufacturer's data or standard ( $T_{ref}$ ) Conventional non-tripping current No tripping Conventional tripping current Operating time Measurement 2: Ambient air temperature Reference temperature according to the manufacturer's data or standard ( $T_{ref}$ )	400 / 1000 A 2 h $T_{ref} \pm 2^\circ\text{C}$ 40 °C 1.05 x 400 / 1000 A > 2 h 1.3 x 400 / 1000 A ≤ 2 h $(T_{ref} - 10) \pm 2^\circ\text{C}$ or $(T_{ref} + 10) \pm 2^\circ\text{C}$ 40 °C	40 °C 420 / 1050 A 2 / 2 h 520 / 1300 A 1.1 / 6.5 min 30 °C
7.2.1.2.4 b)	Correction factor $k_1$ $k_1 = 0.3 \% / \text{K} \times   \text{amb. air temp.} - \text{ref. temp.}  $	-	-
7.2.1.2.4 b)	Conventional non-tripping current No tripping Conventional tripping current Operating time	(1.05 - $k_1$ ) x 400 / 1000 A > 2 h (1.3 + $k_1$ ) x 400 / 1000 A ≤ 2 h	420 / 1050 A 2 / 2 h 520 / 1300 A 1.1 / 6.5 min



ВЯРНО С  
ОРИГИНАЛА

98

LOVAG		Test report No.: 05.087 Page 15/35	Test report No.: 05.087 Page 15/35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1.3 b)	Additional test: Timocurrent characteristics Ambient air temperature Reference temperature Minimum / Maximum current setting Test current given by manufacturer or, when no value is given, with 2.0 x current setting Operating time Maximum setting Minimum setting	40 °C 40 °C 400 / 1000 A 93 s to 113 s 15.5 s to 19 s	by arrangement 40 °C 1000 / 2500 A - / - A 104 s 18 s
LT1 8.3.3.1.3 b)			

Test laboratory: ACAE IA.01  
*R. Stambolov*  
Authorized representative

TRF IEC/EN 60947-2  
Ed. 3.0 form 20

Date 08.07.13

*Handwritten signature*

LOVAG		Test report No.: 05.087 Page 17/35	Test report No.: 05.087 Page 18/35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.2	<b>TEST OF DIELECTRIC PROPERTIES</b>		
60947-1 8.3.3.4.1 2)	Verification of impulse withstand voltage Tests 1,2 / 50 μs		
8.3.3.4.1 2) a)	Circuits incorporating solid-state devices disconnected <input checked="" type="checkbox"/> No / <input type="checkbox"/> Yes, if Yes.		Page -
Table H.1, 12	Test voltage Main circuits Control- and auxiliary circuits	9.6 kV -kV	9.6 kV -kV
8.3.3.4.1 2) c) i) ii) iii) iv)	Application of the test voltage Main-poles to ground Control and auxiliary circuits (if rating is lower than main circuit) Additional test across open contacts for equipment suitable for isolation	5 impulses per polarity	50 Hz 2200 V - V
Table 14	Test voltage Main circuits	12.1 kV	12.1 kV
	Application of the test voltage Across open main contacts	5 impulses per polarity	
8.3.3.2 iii)	Additional test across open contacts for equipment not suitable for isolation		
Table 12A	Power-frequency test voltage Test voltage Main circuits	42 - 65 Hz - V	42 - 65 Hz 2200 V - V
	Application of the test voltage Across open main contacts	5 s	5 s

LOVAG		Test report No.: 05.087 Page 18/35	Test report No.: 05.087 Page 18/35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 8.3.3.4.1 3) c)	Power-frequency withstand verification of solid insulation		
8.3.3.4.1 3) c) b) i) ii) iii) b) ii)	Circuits incorporating solid-state devices disconnected <input checked="" type="checkbox"/> No / <input type="checkbox"/> Yes, if Yes. Power-frequency test Test frequency Main circuits Test voltage Control- and auxiliary circuits Application of the test voltage Main-poles to ground Between main-poles Control and auxiliary circuits (if rating is lower than main circuit) Alternative test with direct voltage	42 - 65 Hz 2200 V 2200 V 5 s	50 Hz 2200 V - V - V
Table 12A	Test voltage Main circuits Control- and auxiliary circuits		
8.3.3.4.1 2) c) i) ii) iii)	Application of the test voltage Main-poles to ground Between main-poles Control and auxiliary circuits (if rating is lower than main circuit)	5 s	5 s
Table 12A	Test voltage Main circuits Control- and auxiliary circuits		
8.3.3.4.1 2) c) i) ii) iii)	Application of the test voltage Main-poles to ground Between main-poles Control and auxiliary circuits (if rating is lower than main circuit)	5 s	5 s
60947-1 8.3.3.4.1. 7)	Verification of creepage distances		
Appendix G	Working voltage or rated insulation voltage Pollution degree Material group Minimum creepage distance	1000 V 3 1 10 mm	37 mm

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

ВАРНОЕ  
ОРИГИНАЛ



*[Handwritten signature]* 99

Test laboratory: ACAE IA.01

TRF IEC/EN 60947-2  
Ed. 3.0 form 25

TRF IEC/EN 60947-2  
Ed. 3.0 form 26

*R. Spasov*  
Authorized representative

Date 06.07.13

Date 06.07.13





LOVAG		Test report No.: 05.087 Page 21 / 35	Test report No.: 05.087 Page 22 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
7.2.1.1.5	E) Impossibility to close the circuit-breaker when the isolating contacts are not fully closed	-	-
	F) Impossibility to close the circuit-breaker when the withdrawable distance is less than the specified isolating distance	-	-
	G) The specified isolating distances cannot be inadvertently reduced	-	-
7.2.1.1.5	<b>Stored energy operating circuit-breaker</b>		
	- Verification of operating conditions of the device indicating the storing mechanism is fully charged	-	-
7.2.1.1.5	- Verification of the direction of operation when the energy storing mechanism is manually operated	-	-
	<b>Mechanical operation</b>		
8.3.3.3.2 b)	- With the closing device energized (electrically, mechanically or manually), the opening order shall cause total tripping	yes	yes
	- With the tripping device actuated (electrically, mechanically or manually), a closing order remains ineffective	yes	yes
8.3.3.3.2 b)	- The circuit-breaker closed, a further closing order by a power-operated device, does not cause any anomaly	yes	yes
	- Opening time (if indicated)	- ms	- ms
8.3.3.3.2 b)	- Closing time (if indicated)	- ms	- ms
Test laboratory: ACAE IA.01		Test laboratory: ACAE IA.01	
Authorized representative		Authorized representative	
Date 05.07.13		Date 05.07.13	



ВЯРНО С  
ОРИГИНАЛ

LOVAG		Test report No.: 05.087 Page 22 / 35	Test report No.: 05.087 Page 22 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
7.2.1.1.3	<b>Dependent power closing circuit-breaker</b>		
	Verification of operating in no-load condition opening time (if indicated) closing time (if indicated)	U = 1.1 x U <sub>n</sub> - ms - ms	- V - ms - ms
	Verification of operating in no-load condition opening time (if indicated) closing time (if indicated)	U = 0.85 x U <sub>n</sub> - ms - ms	- V - ms - ms
7.2.1.1.5	Verification of closing time when the current established by the circuit-breaker is equal to its rated making capacity I <sub>em</sub>	U = 0.85 x U <sub>n</sub>	see test sequence if or III Page -
	<b>Stored energy closing circuit-breaker</b>		
	Verification of operating of the stored energy closing mechanism opening time closing time	U = 0.85 x U <sub>n</sub> - ms - ms	- V - ms - ms
7.2.1.1.5	Verification of operating of the stored energy closing mechanism opening time closing time	U = 1.1 x U <sub>n</sub> - ms - ms	- V - ms - ms
	Impossibility for the closing mechanism to operate when it is charged to slightly below the full charge		-
Test laboratory: ACAE IA.01		Test laboratory: ACAE IA.01	
Authorized representative		Authorized representative	
Date 05.07.13		Date 05.07.13	

cu

LOVAG		Test report No.: 05.087 Page 23 / 35	Test report No.: 05.087 Page 24 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.3.2 c)	<b>Undervoltage release</b> Minimum / Maximum rated control supply voltage $U_c$	- / - V	- / - V
8.3.3.3.2 c) i)	Drop-out voltage - Lower limit - Upper limit (at operational temperature of the circuit-breaker) $U \geq 0.85 \times U_{c, \max}$ $U \leq 0.7 \times U_{c, \min}$ $U \leq 0.7 \times U_{c, \max}$	- V	- V
ii)	Limits of operation - Impossibility of closing by the operation of the actuator - Verification of closing by the operation of the actuator	- V	- V
iii)	Performance under overvoltage conditions Verification of operating after the application of an overvoltage - Impossibility of closing by the operation of the actuator - Verification of closing by the operation of the actuator	- V	- V
8.3.3.3.2 d)	<b>Shunt release</b> Minimum rated control supply voltage $U_{c, \min}$ Verification of operating at an ambient temperature of $+55 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$ - Tripping	- V	- V

Test laboratory: ACAE IA.01  
Date 08.07.13

TRF IEC/EN 60947-2  
Ed. 3.0 form 31



*[Handwritten signature]*

**ВЯРНО С  
ПУТНААА**

*[Handwritten signature]* 102

LOVAG		Test report No.: 05.087 Page 24 / 35	Test report No.: 05.087 Page 24 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.3.3	<b>Operational performance capability without current</b> Number of closing operations with undervoltage release not energized (if applicable)	10	-
Table 8 Column 3 Column 2	Number of operating cycles Operating cycles per hour	2500 960 /h	2500 960 /h
8.3.3.3.4	<b>Operational performance capability with current</b> Short-circuit release Overload release Circuit diagram Maximum rated operational voltage $U_{e, \max}$ Rated current $I_n$	min. setting max. setting 690 V 1000 A	1500 A 1000 A Page 33 / 35 690 V 1000 A
Table 11	Power factor Time constant Frequency	0.8 - ms 50 Hz	0.77 - ms 50 Hz
Table 8 Column 2 Column 4	Operating cycles per hour On-time Number of operating cycles	20 /h 500	20 /h 140 ms 500
8.3.3.3.5	<b>Additional test of operational performance capability without current for withdrawable circuit-breakers</b> Number of operating cycles Visual inspection of isolating contacts, withdrawal mechanism and interlocks	100	-

Test laboratory: ACAE IA.01  
Date 08.07.13

TRF IEC/EN 60947-2  
Ed. 3.0 form 32

*[Handwritten signature]*

*[Handwritten signature]*  
Authorized representative

LOVAG		Test report No.: 05.087 Page 25 / 35	Test report No.: 05.087 Page 26 / 35											
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000											
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results											
8.3.3.4	<b>OVERLOAD PERFORMANCE</b> Rated current $I_n$ Overload release (maximum) Current setting Short-circuit release (maximum) Control supply voltage Maximum rated operational voltage $U_{n,max}$ Recovery voltage reduced voltage on automatic opening according to note 2) Number of operating cycles per hour Circuit diagram Safety area Alternating current: Test current Power factor Frequency Direct current: Test current Time constant	- A - A - A 0.85 x $U_n$ - V - V 1.05 x $U_{n,max}$ - V - V - / h Pagotom 6 6 x $I_n$ - A - 45 - 62 Hz 2.5 x $I_n$ - A - ms	- V - V - V - / h Page - Page - - A - - Hz - A - ms											
Table 8 Column 2 60947-1 8.3.3.5.2 8.3.2.1														
Table 12														
Table 11														
Table 12														
Table 11														
	<table border="1"> <thead> <tr> <th>Test method</th> <th>Number of operations manual</th> <th>Automatic</th> </tr> </thead> <tbody> <tr> <td><input type="checkbox"/> Standard</td> <td>9</td> <td>3</td> </tr> <tr> <td><input type="checkbox"/> Reduced voltage on automatic opening according to note 2)</td> <td>12</td> <td>3</td> </tr> <tr> <td><input type="checkbox"/> Opening caused by short-circuit releases</td> <td>-</td> <td>12</td> </tr> </tbody> </table>	Test method	Number of operations manual	Automatic	<input type="checkbox"/> Standard	9	3	<input type="checkbox"/> Reduced voltage on automatic opening according to note 2)	12	3	<input type="checkbox"/> Opening caused by short-circuit releases	-	12	
Test method	Number of operations manual	Automatic												
<input type="checkbox"/> Standard	9	3												
<input type="checkbox"/> Reduced voltage on automatic opening according to note 2)	12	3												
<input type="checkbox"/> Opening caused by short-circuit releases	-	12												
	On-time on manual operation Melting of the fusible element	min./max. Yes/No	- / - ms ....											

LOVAG		Test report No.: 05.087 Page 26 / 35	Test report No.: 05.087 Page 26 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.5 8.3.4.3 8.3.5.3 8.3.6.5 8.3.7.3 8.3.7.7 B.10.3.1 A.5 A.6.3 C.3 H.3 60947-1 8.3.3.4.1 9)	<b>VERIFICATION OF DIELECTRIC WITHSTAND</b>  Test sequence I Test sequence II Test sequence III Test sequence IV Test sequence V, stage 1 Test sequence V, stage 2 Combined test sequence Test sequence B.11 Verification of discrimination Verification of back-up protection Individual pole short-circuit test sequence Test sequence for circuit-breakers for IT-systems  <b>Power-frequency withstand verification</b> Circuits incorporating solid-state devices disconnected <input checked="" type="checkbox"/> No / <input type="checkbox"/> Yes, if Yes  Test frequency 42 - 65 Hz Test voltage 2 x $U_n$ , min. 1000 V 1380 V  Application of the test voltage - Main circuit of the circuit-breaker - Isolating contacts of the withdrawable unit (if applicable) - Insert of withdrawable unit - Withdrawable unit (base) - Combination of base and insert		
8.3.3.2.2 a)		5 s	

Test laboratory: ACAE IA.01  
R. Ghomel  
Authorized representative  
TRF IEC/EN 60947-2  
Ed. 3.0 form 34  
Date 06.07.13

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

ВЯРНО С  
ОРИГИНАЛА

*Handwritten signature* 103





LOVAG		Test report No.: 05.087 Page 28 / 35	Test report No.: 05.087 Page 30 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	
<b>VERIFICATION OF OVERLOAD RELEASES</b>			
8.3.3.7 8.3.4.5 8.3.8.7	Test sequence I after 8.3.3.6 Test sequence II after 8.3.4.4 Combined test sequence after 8.3.8.6		
<b>Tripping test</b>			
Time interval to previous test of temperature-rise (if applicable)			
60947-1 Table 9, 10 and 11	Cabling characteristics Cable 150 mm <sup>2</sup> Bar - x - mm 4 Number 4 Length 2000 mm Tightening torque <input checked="" type="checkbox"/> 3 phase or <input type="checkbox"/> poles in series Arrangement: Reference temperature 40° C ± 2° C Ambient temperature Correction factor k (k = 1 for releases independent of ambient temperature) Current setting value 1000 A		~ min 150 mm <sup>2</sup> - x - mm 4 2000 mm 43 Nm 40 °C - 1000 A
Table 6	Test current Phase poles k x 1.45 x current setting value or tripping current according to the manufacturer's temperature/current data (for releases dependent on ambient temperature) Tripping time ≤ 120 min Neutral pole (if applicable) k x 1.45 x current setting value or tripping current according to the manufacturer's temperature/current data (for releases dependent on ambient temperature) Tripping time ≤ - min		1450 A - A 5 min - A - A - min
TRF IEC/EN 60947-2 Ec. 3.0 Item 37		TRF IEC/EN 60947-2 Ec. 3.0 Item 38	
Date 06.07.13		Date 06.07.13	
Authorized representative <i>R. Stenich</i>		Authorized representative <i>R. Stenich</i>	

LOVAG		Test report No.: 05.087 Page 30 / 35	Test report No.: 05.087 Page 30 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000	Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results	
<b>VERIFICATION OF UNDER-VOLTAGE AND SHUNT RELEASES</b>			
8.3.3.8	Under-voltage releases Ambient temperature Minimum / Maximum rated control supply voltage $U_c$ Drop-out-voltage $0.35 \times U_{c,max} \leq U_{trip} \leq 0.70 \times U_{c,max}$		- °C - V
8.3.3.3.2 d)	<b>Shunt releases</b> Ambient temperature Minimum rated control supply voltage $U_c$ Verification of operating - Tripping $U = 0.70 \times U_{c,max}$		- °C - V
TRF IEC/EN 60947-2 Ec. 3.0 Item 37		TRF IEC/EN 60947-2 Ec. 3.0 Item 38	
Date 06.07.13		Date 06.07.13	
Authorized representative <i>R. Stenich</i>		Authorized representative <i>R. Stenich</i>	

*CE*

*[Signature]*

**ВЯРНО С  
ОРИГИНАЛА**



*[Signature]* 105

LOVAG		Test report No.: 05.087 Page 31 / 35
Type test according to: IEC 60947-2 Test sequence I		Type: T6N 1000
Standard and clause	Kind of tests and requirements	Test values Results
8.3.3.9	<b>VERIFICATION OF THE MAIN CONTACT POSITION</b> For circuit-breakers suitable for isolation having an operational voltage $U_n$ greater than 50 V. Dependent and independent manual operation	
60947-1 8.2.5.2.1	Type of actuator	-
60947-1 Figure 16	Determination of the normal actuator opening force (F)	160 N
8.2.5.2	Fixing of the moving contact in pole	yes
Table 17	Test force with contact kept close (3 x F, not less than the minimum nor more than the maximum given in table 17 corresponding to the type of actuator)	400 N
	Test duration	10 s
8.2.5.3	<b>Condition of equipment during and after test</b>	
	The actuator cannot be locked in the OFF-Position while test force is applied.	Yes/No
	After the test, when the test force is no longer applied, the actuator being left free, the open position is not indicated.	Yes/No
	There is no damage to the equipment such as to impair its normal operation.	Yes/No


*Handwritten signature*

LOVAG		Test report No.: 05.087 Page 32 / 35
Type test according to: IEC 60947-2		Type: T6N 1000
and the instruments have an measurement uncertainty like follow :		
Quantity		$\leq \pm 2.5\%$ by transient recorders
Voltage		$< \pm 1.5\%$ by multimeters or similar
Current		$\leq \pm 2.5\%$ for dielectric test
Time		$\leq \pm 2.5\%$
Force		$< \pm 1\%$
Torque		$< \pm 1\%$
Resistance		$< \pm 5\%$
Temperature		$< \pm 3\%$
Linear dimensions		$\pm 2^\circ\text{C}$ up to $100^\circ\text{C}$
Relative humidity		$\pm 2\%$ above $100^\circ\text{C}$
		$\pm 0.05$ mm
		$\pm 5\%$ in the range $20\% + 95\%$ RH

*Handwritten signature*

*Handwritten signature*

**ВЕРНО С  
ОРИГИНАЛА**



Test laboratory: ACAE IA.01

TRF IEC/EN 60947-2  
Ed. 3.0 form 3B

*Handwritten signature*

Authorized representative

Date 06.07.13

Test laboratory: ACAE IA.01


TRF IEC/EN 60947-2  
Ed. 3.0 form 177

*Handwritten signature*


Authorized representative

Date 06.07.13

*Handwritten signature* 106



CIRCUIT DIAGRAM TYPE S



- 1 - Three-phase transformer
- 2 - Short-circuit making switch
- 3 - Dividers for the detection of fault currents
- 4 - Apparatus under test
- 5 - Load (reactors and resistances)
- 6 - Non inductive shunts for current measurement
- 8 - Voltmeter for voltage measurement



*CU*

*[Handwritten signature]*

*[Handwritten signature]*

ВЯРНО С  
ОРИГИНАЛА

*[Handwritten signature]* 107







Via Tito Livio, 5 - 24123 - BERGAMO (Italy)  
tel. +39 035 4774242 fax. +39 035 4524664 e-mail: acasec@acae.it



# Certificate of Conformity

LOVAG-Certificato No. IT 08.009

### Apparatus

Four poles circuit breaker 690 V (U<sub>n</sub>) - 1000 V (U<sub>i</sub>) - 8 kV (U<sub>g</sub>) - 1250 A (I<sub>cs</sub>) - 50/60 Hz - I<sub>cs</sub> = 1000 A at 230V - 1000 A at 500V - I<sub>cs</sub> = 1250 A at 690V - I<sub>cs</sub> = 1000 A with short-circuit and overload releases. PR831/P L1

### Designation

TTV 1250

Manufacturer or responsible vendor  
ABB S.p.A. - ABB SACE Division  
Via Beldi 35 - 24123 Bergamo (Italy)

Tested for: ABB S.p.A. - ABB SACE Division

Tested by: ACAE Laboratory IA 01

This apparatus, constructed in accordance with the description mentioned in the "Test" Report listed on this Certificate, has been subjected to the series of dynamic tests in accordance with IEC 60947-2 (2006), EN 60947-2 (2006).  
Test sequence: 1) at 690 V

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standards; and to justify the characteristic assigned by the manufacturer as stated below

### Suitable for isolation


900 V (U<sub>n</sub>) - 1000 V (U<sub>i</sub>) - 8 kV (U<sub>g</sub>) - 1250 A (I<sub>cs</sub>) - 50/60 Hz

Approved release performances according to the d.m. Standard

This document includes Report No. 07.053

Issue Date: 2008.04.14

Responsible Certification Body: ACAE



Mauro Marini

Authorized Signatory

Date: 2008.04.17

ВЕРНО С  
ОРИГИНАЛА

109

## LOVAG CERTIFICATES

### LOVAG

is the Low Voltage Agreement Group which is a Mutual Arrangement Group of Certification Bodies founded in 1991 which has achieved a high level of worldwide recognition in testing and certification of low voltage equipment.  
LOVAG's main purpose is an Agreement Group which by the mutual recognition of testing and test reports and/or certifications of conformity by its signatories.

### Membership

LOVAG presently has seven signatories to the Agreement:  
ACAE (Italy), ALPHA Certification, Applied T.C. (Spain), ASEA, (Finland), Intertek Semko AB, Sweden, SGS Belgium NV - Division SGS CEBEC, Belgium, and VEIKI-VKI, Hungary and employs around 40 European testing laboratories.

### Certificates

LOVAG Certificates are issued by the signatory bodies to the Agreement using test reports and certificates in a common and recognizable format in the market. They are recognized and accepted in the European Economic Area and elsewhere in the world.

### Test instructions








LOVAG uses common LOVAG Test Instructions to which of the International and European Standards covered by the Agreement, and Signatories to the Agreement refer by their own testing for LOVAG Certification.

### Qualifications

All signatory bodies to the Agreement are accredited under ISO 9001 to EN 45001, ISO/IEC Guide 68, and their laboratories are approved and/or assessed to EN ISO/IEC 17025.

For further information contact your local certification body from the list below or contact the Secretariat of LOVAG at "ALPHA e.V." - Stresemannallee 19 - D-60596 Frankfurt am Main Phone: + 49 69 9623 6343 Fax: + 49 69 9623 8344, e-mail: secretariat@lovag.net

### LIST OF LOVAG SIGNATORIES:

 <b>ACAE</b> Via Tito Livio 5 I-24123 Bergamo ITALY Fax: + 39 035 452 4664 e-mail: accert@acae.it	 <b>SGS Belgium NV</b> - Division <b>SGS CEBEC</b> Avenue Van Kalken 9A Bld 1 B-1070 Brussels BELGIUM Fax: + 32 2 359 30 36 e-mail: sbs@cebec.com
 <b>ALPHA e.V.</b> Stresemannallee 19 D-60596 Frankfurt am Main GERMANY Fax: + 49 69 9623 8344 e-mail: office@alpha-ev.de	 <b>Intertek Semko AB</b> Box 4502 Torshamnsgatan 43 SE-104 23 Kista SWEDEN Phone: + 46 8 756 0091 e-mail: info@intertek.se
 <b>eplus</b> Via Tito Livio 5 I-24123 Bergamo ITALY Fax: + 39 035 452 4664 e-mail: info@eplus.com	 <b>VEIKI-VKI, electric</b> Large Laboratoriu Ltd Vaseljovo c. 24 H-7138 Budapest HUNGARY Fax: + 36 1 41 11 1163 e-mail: wsl@veiki.vki.hu
 <b>ASEFA</b> 30 av du general Lelièvre F-22280 Fohentay-sur-Seine FRANCE Fax: + 33 1 45 95 98 13 e-mail: info@asefa.fr	

17-RV17 November 2006

Test Report No. 07.053

Test laboratory: ACAE IA.01  
 Client: I - 24123 Bergamo  
 Manufacturer: ABB S.p.A.  
 Test object: Low voltage molded case circuit breaker Tmax  
 Type designation: TTV 1250  
 Date(s) of test(s): from 2007.12.28 to 2008.01.31  
 Test specification: IEC 60947-2:2006  
 EN 60947-2:2006  
 Test sequence(s): I

Test results: Sequence I at 690V found in compliance with rated characteristics

The Record of Proving Test consists of:

- 39 pages LOVAG test report forms - oscillograms
- other pages - drawing
- diagrams - photographs

Date of issue: 2008.04.14

Signatures: R. Oprandi  
 (Name, function and signature  
 of authorized representative)

Responsible Test Laboratory  
 M. Boroli

ACAЕ Inspector  
 M. Marchi

Note:  
 The test result relates only to the items tested.  
 The test report shall not be reproduced except in full  
 without the written approval of the test laboratory.

LOVAG

Description and characterization of the test object

Characteristics

Type of circuit-breaker: TTV 1250  
 Number of poles: 4  
 Kind of current: a.c.  
 Number of phases: 3  
 Rated frequency: 50-60 Hz  
 Utilization category: B  
 Reference temperature: 40 °C  
 Suitability for isolation: Yes  
 Pollution degree: 3  
 Material group: 1

Rated and limiting values: (according to test volume)

Main circuit:  
 Rated impulse withstand voltage  $U_{imp}$ : 8 kV  
 Rated insulation voltage  $U_i$ : 1000 V  
 Conventional thermal current  $I_n / I_{th}$ : 1250 / - A  
 Rated current  $I_n$ : 1250 A  
 Rated current in the neutral pole: 1250 A

Short-circuit characteristics:

$U_p/V$	$I_{sc}/kA$	$I_{sc}/kA$	$I_{sc}/kA$	$I_{sc}/kA$	$I_{sc}/kA$
230 ac	440	200	200	15	-
415 ac	330	150	150	15	-
440 ac	286	130	130	15	-
500 ac	220	100	100	15	-
690 ac	132	60	45	15	-

Test laboratory: ACAE IA.01

*R. Oprandi*  
 Authorized representative

*Am*

*[Handwritten signature]*

*[Handwritten signature]*

ВЯРНО С  
 ОПИТИНАА

*1110*



**LOVAG**

**Releases:**

- Shunt release:
- Rated control circuit voltage  $U_c$
- Kind of current
- Rated frequency if a.c.
- Undervoltage or no-voltage release
- Rated control circuit voltage  $U_c$
- Kind of current
- Rated frequency if a.c.
- Over-current release:

Kind of release  
 electromagnetic  
 electronic

- Short-circuit release
- Instantaneous release
- definite time-delay release
- Rated current  $I_n$
- Rated instantaneous short-circuit current setting  $I_{sc}$
- Kind of current
- Rated frequency if a.c.
- Current setting (or range of settings)
- Time setting (or range of settings)
- Overload release (IEC 60947-1; 2.4.30):
- Instantaneous release
- definite time-delay release
- Inverse time-delay release
- dependent on ambient air temperature
- independent of ambient air temperature
- Reference temperature
- Rated current  $I_n$
- Kind of current
- Rated frequency if a.c.
- Current setting (or range of settings)
- Time setting (or range of settings)
- Time setting at 2 times  $I_n$  (on single pole)

**LOVAG**

**Control circuits:**

- Electrical control circuits:
- Kind of current
- Rated frequency
- Rated control circuit voltage  $U_c$
- Rated control supply voltage  $U_s$
- Rated impulse withstand voltage  $U_{imp}$
- Rated insulation voltage  $U_i$

**All-supply control circuits:**

- Rated supply pressure
- Limits of pressure
- Required volume for each closing operation
- Required volume for each opening operation

**Auxiliary circuits:**

- Rated operational voltage  $U_o$
- Rated impulse withstand voltage  $U_{imp}$
- Rated insulation voltage  $U_i$
- Rated frequency
- Rated operational current  $I_o$
- Number of circuits
- Number and kind of contact elements

ВЯРНО С  
ОРИГИНАЛ



*Handwritten signature and number 1111*

LOVAG

PR231/P - Protection functions and parameterisations

Protection functions	Trip threshold	Trip curves(I)	Excludability	Relation $t = f(I)$
L Against overload with long inverse time delay trip and trip characteristic according to an inverse time curve ( $tI^2 = K$ ) according to IEC 60364-4-52, standard	$I_{sc} = 0.40 \dots 1 \times I_n$ $I_{sep} = 0.04 \times I_n$ Trip between 1.1...1.3 $I_n$	$3t \times I^2 = 11$ $tI^2 = 3 - 23s$ Tolerance: $\pm 10\%$	-	$t = K/I^2$
J Against short circuit with instantaneous trip (selectable as an alternative to protection function S)	$I_{sc} = 1.1, 1.5, 2, 2.5, 3, 3.5, 4, 5, 5.5, 6, 7, 7.5, 8, 8.5, 9, 10 \times I_n$ Tolerance: $\pm 10\%$	instantaneous	-	$t = K$


1) These tolerances hold in the following conditions:  
 - self-powered trip unit at full power  
 - two or three-phase power supply  
 In conditions other than those considered, the following tolerances hold:

Trip threshold  
 S  $\pm 10\%$   
 I  $\pm 15\%$

Trip time  
 S  $\pm 20\%$   
 I  $\pm 60ms$

LOVAG

Time / current characteristics



Note: Symbol explanation at page 6 / 39

*Handwritten signature*

*Handwritten signature*

ВЯРНО С  
ОРИГИНАЛА




*Handwritten signature*

*Handwritten signature*

LOVAG

INSTALLATION INSIDE METAL SCREEN



Date 08.04.14

Authorized representative

Test laboratory: ACAE IA.01

*R. Ghisani*

LOVAG

Integral fused circuit-breakers:

(Co-ordination with short-circuit protective devices)

- Kind of protective devices
- Type of fuse
- Maximum operational voltage
- Rated current  $I_n$
- Maximum prospective short-circuit peak current

Individual enclosure:

- Type
- Kind of material
- Degree of protection
- Inside dimensions
- height
- width
- depth

When no enclosure:

Safety perimeter defined:

- height
- width
- depth

Kind of screen

(woven wire mesh, perforated metal, expanded metal)

Size of holes ( $\leq 30 \text{ mm}^2$ )

Distance during test

Openings around the manual operating means:

Openings in the area of the manual operating means through which the arc chamber can be reached by a music wire of 0.26 mm diameter.

none

*[Handwritten signature]*

ВЯРНО С  
ОРИГИНАЛА



*[Handwritten signature]*

*[Handwritten signature]*

Date 08.04.14

Authorized representative

Test laboratory: ACAE IA.01

*R. Ghisani*



LOVAG		Test report No.: 07.053 Page 11 / 39
Type test according to: IEC 60947-2 Test sequence: I		Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results
8.3.3.1 60947-1 Table 9, 10 and 11	<b>TEST OF TRIPPING LIMITS AND CHARACTERISTICS</b> Cabling characteristics Cable - mm <sup>2</sup> Bar - x - mm Number - Length - mm Tightening torque  Opening under short-circuit conditions  Ambient air temperature 10...40 °C  Minimum current setting / Minimum time delay 1250 A / - s Maximum current setting / Maximum time delay 12500 A / - s	- mm <sup>2</sup> 80 x 10 mm 1 500 mm 40 Nm     23 °C
8.3.3.1.2	Single or combination of phase pole(s) Test current(s) 0,8 x 1250 / 12500 A Duration of current flow ≥ 200 ms No tripping Test current(s) 1,2 x 1250 / 12500 A Duration of current flow ≤ 200 ms Tripping  Combination of phase poles Test current(s) 0,8 x 1250 / 12500 A Duration of current flow ≥ 200 ms No tripping Test current(s) 1,2 x 1250 / 12500 A Duration of current flow ≤ 200 ms Tripping  Combination of phase poles Test current(s) 0,8 x 1250 / 12500 A Duration of current flow ≥ 200 ms No tripping Test current(s) 1,2 x 1250 / 12500 A Duration of current flow ≤ 200 ms Tripping	1/2 1000 / 10000 A > 200 / > 200 ms 1500 / 15000 A 41 / 39 ms  2/3 1000 / 10000 A > 200 / > 200 ms 1500 / 15000 A 44 / 41 ms  3/1 1000 / 10000 A > 200 / > 200 ms 1500 / 15000 A 40 / 43 ms
Test laboratory: ACAE IA.01		TRF IEC/EN 60947-2 Ed. 4.0 form 16
Authorized representative		Date 08.04.14



ВЯРНО С  
ОРИГИНАЛА

071115

LOVAG		Test report No.: 07.053 Page 12 / 39
Type test according to: IEC 60947-2 Test sequence: I		Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results
8.3.3.1.2	Tests on combinations of the neutral pole with the phase poles in the case of circuit-breakers having a neutral pole provided with an short-circuit release  Cabling characteristics Cable - mm <sup>2</sup> Bar - x - mm Number - Length - mm Tightening torque  Opening under short-circuit conditions  Ambient air temperature 10...40 °C  Minimum current setting / Minimum time delay 1250 A / - s Maximum current setting / Maximum time delay 12500 A / - s	- mm <sup>2</sup> 80 x 10 mm 1 500 mm 40 Nm     23 °C
8.3.3.1.2	Single or combination of poles Test current(s) 0,8 x 1250 / 12500 A Duration of current flow ≥ 200 / 200 ms No tripping Test current(s) 1,2 x 1250 / 12500 A Duration of current flow ≤ 200 / 200 ms Tripping	N/L1 1000 / 10000 A 220 / 220 ms 1500 / 15000 A 47 / 46 ms
Test laboratory: ACAE IA.01		TRF IEC/EN 60947-2 Ed. 4.0 form 17
Authorized representative		Date 08.04.14

*Handwritten signature*

LOVAG		Test report No.: 07.053 Page 13 / 39 Type: TTV 1250	Test values Results
Type test according to: IEC 60947-2 Test sequence I		Kind of tests and requirements	Test values Results
8.3.3.1.2	Additional test of opening under short-circuit conditions on each phase pole individually	Minimum current setting / Minimum time delay 1250 A / - s Maximum current setting / Maximum time delay 12500 A / - s Single pole tripping values given by manufacturer: Corrections factor K (for multiplied of current tripping value on two poles) Correction factor for phase poles K1 = - neutral pole (if different to phase pole) K2 = - Phase pole 1 Test current(s) 1.2 x 1250 / 12500 A Duration of current flow ≤ 200 ms Tripping Phase pole 2 Test current(s) 1.2 x 1250 / 12500 A Duration of current flow ≤ 200 ms Tripping Phase pole 3 Test current(s) 1.2 x 1250 / 12500 A Duration of current flow ≤ 200 ms Tripping Neutral pole (if applicable) Test current(s) 1.2 x 1250 / 12500 A Duration of current flow ≤ 200 ms Tripping	1500 / 15000 A 44 / 40 ms 1500 / 15000 A 42 / 42 ms 1500 / 15000 A 48 / 45 ms 1500 / 15000 A 49 / 47 ms
Test laboratory: ACAE IA.01		<i>R. Ghomchi</i> Authorized representative	TRF IEC/EN 60947-2 Ed. 4.0 form 16 Date 03.04.14

ВЯРНО С  
ОРИГИНАЛА



27116

LOVAG		Test report No.: 07.053 Page 14 / 39 Type: TTV 1250	Test values Results
Type test according to: IEC 60947-2 Test sequence I		Kind of tests and requirements	Test values Results
8.3.3.1.3 b)	Inverse time-delay releases dependent on ambient air temperature	Minimum current setting / Minimum time delay ... A / ... s Maximum current setting / Maximum time delay ... A / ... s Conventional time ... h Reference temperature (according to the manufacturer's data) ... °C Ambient temperature test room (for electronic releases) ... °C Ambient air temperature ... °C Correction factor at the minimum current setting K1 = ... Correction factor at the maximum current setting (K1 and K2 given by manufacturer) K2 = ...	- °C - °C
Table 6		Test at the minimum current setting Conventional non-tripping current No tripping Conventional tripping current Operating time	k1 x 1.05 x ... A > ... min - A - min
6.1.1.part1		Test at the maximum current setting Conventional non-tripping current No tripping Conventional tripping current Operating time	k2 x 1.05 x ... A > ... min - A - min
Test laboratory: ACAE IA.01		<i>R. Ghomchi</i> Authorized representative	TRF IEC/EN 60947-2 Ed. 4.0 form 20 Date 03.04.14

OK



LOVAG		Test report No.: 07.053 Page 15 / 39	Test report No.: 07.053 Page 16 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: T7V 1250	Type: T7V 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1.3 b)	<b>Inverse time-delay releases independent on ambient air temperature</b> Minimum current setting / Minimum time delay 500 A / 3 s Maximum current setting / Maximum time delay 1250 A / 12 s Conventional time 2 h Measurement 1: Ambient air temperature $T_{ref} \pm 2^\circ C$ Reference temperature according to the manufacturer's data or standard ( $T_{ref}$ ) 40 °C Conventional non-tripping current 1.05 x 500 / 1250 A No tripping > 2 h Conventional tripping current 1.3 x 500 / 1250 A Operating time $\leq 2$ h Measurement 2: Ambient air temperature $(T_{ref} - 10) \pm 2^\circ C$ or $(T_{ref} + 10) \pm 2^\circ C$ Reference temperature according to the manufacturer's data or standard ( $T_{ref}$ ) 40 °C Correction factor $k_1$ $k_1 = 0.3 \% / K \times   \text{amb. air temp.} - \text{ref. temp.}  $ Conventional non-tripping current (1.05 - $k_1$ ) x 500 / 1250 A No tripping > 2 h Conventional tripping current (1.3 + $k_1$ ) x 500 / 1250 A Operating time $\leq 2$ h	40 °C 525 / 1312.5 A > 2 h / > 2 h 650 / 1625 A 1 / 4 min 30 °C 525 / 1312.5 A > 2 h / > 2 h 650 / 1312.5 A 1 / 4 min	by arrangement 40 °C
7.2.1.2.4 b)			
7.2.1.2.4 b)			

LOVAG		Test report No.: 07.053 Page 16 / 39	Test report No.: 07.053 Page 16 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: T7V 1250	Type: T7V 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1.3 b)	<b>Additional test: Time/current characteristics</b> Ambient air temperature 40 °C Reference temperature $k_1 = 1$ Correction factor at the minimum current setting $k_2 = 1$ Correction factor at the maximum current setting ( $k_1$ and $k_2$ given by manufacturer) Minimum current setting / Minimum time delay 500 A / 3 s Maximum current setting / Maximum time delay 1250 A / 12 s With manufacturer agreement Test at 2.5 times of current setting Test at the minimum current setting $k_1 \times 2.5 \times 500A$ Operating time from 15.5 s to 19 s Test at the maximum current setting $k_2 \times 2.5 \times 1250 A$ Operating time from 62 s to 76 s	500 A / 3 s 1250 A / 12 s 1250 A 18 s 3125 A 71 s	by arrangement 40 °C
8.3.3.1.3 b)			

CM

ВЯРНО С  
ОРИГИНАЛА



*R. G. G.*  
Authorized representative

TRF IEC/EN 60947-2  
Ed. 4.0 form 21

Date 08.04.14

Test laboratory: ACAE IA.01

*R. G. G.*  
Authorized representative

Date 08.04.14

TRF IEC/EN 60947-2  
Ed. 4.0 form 22


07/11/17

LOVAG		Test report No.: 07.053 Page 17 / 39	Test report No.: 07.053 Page 18 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1	<b>TEST OF TRIPPING LIMITS AND CHARACTERISTICS</b> For circuit-breakers having a neutral pole provided with an overload release		
60947-1 Table 9, 10 and 11	Cabling characteristics (if not equal to phase poles) Cable - mm <sup>2</sup> Bar - X - mm Number - Length - mm Tightening torque	- mm <sup>2</sup> 80 x 10 mm 1 500 mm 40 Nm	- mm <sup>2</sup> 80 x 10 mm 1 500 mm 40 Nm
8.3.3.1.3	Opening under overload conditions Ambient air temperature: 10...40 °C		40 °C
8.3.3.1.3 a)	Instantaneous or definite time-delay releases Minimum current setting / Minimum time delay - A / - s Maximum current setting / Maximum time delay - A / - s Test current(s) 0.9 x I <sub>n</sub> - A Duration of current flow ≥ I <sub>n</sub> - s No tripping Test current(s) 1.2 x I <sub>n</sub> x I <sub>n</sub> - A Duration of current flow S - I <sub>n</sub> - s Tripping	- A / - s - A / - s 0.9 x I <sub>n</sub> - A ≥ I <sub>n</sub> - s 1.2 x I <sub>n</sub> x I <sub>n</sub> - A S - I <sub>n</sub> - s	- A - I <sub>n</sub> s - I <sub>n</sub> A - I <sub>n</sub> s
Test laboratory: ACAE IA 01		Test laboratory: ACAE IA 01	
Authorized representative		Authorized representative	
Date 08.04.14		Date 08.04.14	
TRF IEC/EN 60947-2 Ed. 4.0 term 2A		TRF IEC/EN 60947-2 Ed. 4.0 term 2B	

LOVAG		Test report No.: 07.053 Page 18 / 39	Test report No.: 07.053 Page 18 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.1.3 b)	Inverse time-delay releases of the neutral pole		
Table 6	Minimum current setting / Minimum time delay 500 A / 3 s Maximum current setting / Maximum time delay 1250 A / 12 s Conventional time 2 h		
6.1.1 part 1	Releases dependent on ambient air temperature Reference temperature (according to the manufacturer's data) - °C Ambient temperature test room (for electronic releases) - °C Ambient air temperature - °C Correction factor at the minimum current setting k1 = - Correction factor at the maximum current setting (k1 and k2 given by manufacturer) k2 = - Test at the minimum current setting Conventional non-tripping current k1 x 1.05 x I <sub>n</sub> - A No tripping > - min Conventional tripping current k1 x 1.2 x 1.3 x I <sub>n</sub> - A Operating time ≤ - min Test at the maximum current setting Conventional non-tripping current k2 x 1.05 x I <sub>n</sub> - A No tripping > - min Conventional tripping current k2 x 1.2 x 1.3 x I <sub>n</sub> - A Operating time ≤ - min	- °C - °C - °C k1 = - k2 = - k1 x 1.05 x I <sub>n</sub> - A > - min k1 x 1.2 x 1.3 x I <sub>n</sub> - A ≤ - min k2 x 1.05 x I <sub>n</sub> - A > - min k2 x 1.2 x 1.3 x I <sub>n</sub> - A ≤ - min	- °C - °C - °C - / - A - / - h - / - h - / - min - / - A - / - h - / - A - / - min
7.2.1.2.4 b)	Releases Independent of ambient air temperature Measurement 1: Ambient air temperature T <sub>ref</sub> ± 2 °C Reference temperature according to the manufacturer's data or standard (T <sub>ref</sub> ) 40 °C Conventional non-tripping current 1.05 x 500 / 1250 A No tripping > 2 h Conventional tripping current 1.2 x 1.3 x 500 / 1250 A Operating time ≤ 2 h	T <sub>ref</sub> ± 2 °C 40 °C 1.05 x 500 / 1250 A > 2 h 1.2 x 1.3 x 500 / 1250 A ≤ 2 h	40 °C 525 / 1312.5 A > 2 / > 2 h 780 / 1950 A 1 / 3 min
Test laboratory: ACAE IA 01		Test laboratory: ACAE IA 01	
Authorized representative		Authorized representative	
Date 08.04.14		Date 08.04.14	
TRF IEC/EN 60947-2 Ed. 4.0 term 2A		TRF IEC/EN 60947-2 Ed. 4.0 term 2B	

*Handwritten signature*

ВЯРНО С  
ОРИГИНАЛА



21118

LOVAG		Test report No.: 07.053 Page 19 / 39	Test values Results
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	
Standard and clause	Kind of tests and requirements		Test values Results
	Measurement 2: Ambient air temperature $(T_{ref} - 10) \pm 2 \text{ } ^\circ\text{C}$ or $(T_{ref} + 10) \pm 2 \text{ } ^\circ\text{C}$ Reference temperature (according to the manufacturer's data) 40 °C Correction factor $k_1$ : $k_1 = 0.3 \% / \text{K} \times   \text{amb. air temp.} - \text{ref. temp.}  $ $k_1 = 0.3 \% / \text{K} \times   \text{amb. air temp.} - \text{ref. temp.}  $ Conventional non-tripping current $(1.05 - k_1) \times 500 / 1250 \text{ A}$ > 2 h No tripping Conventional tripping current $(1.2 \times 1.3 + k_1) \times 500 / 1250 \text{ A}$ Operating time $\leq 2 \text{ h}$	30 °C	
7.2.1.2, 4 b)			
7.2.1.2, 4 b)			
8.3.3.1, 3 b)	Additional test: Time/current characteristic of the neutral pole overload release Ambient air temperature 40 °C Reference temperature Correction factor at the minimum current setting $k1 = 1$ Correction factor at the maximum current setting $k2 = 1$ ( $k1$ and $k2$ given by manufacturer) Minimum current setting / Minimum time delay 500 A / 3 s Maximum current setting / Maximum time delay 1250 A / 12 s With manufacturer agreement Test at 2.5 times of current setting Test at the minimum current setting Operating time $k1 \times 2.5 \times 500 \text{ A}$ from 15.5 s to 19 s Test at the maximum current setting Operating time $k2 \times 2.5 \times 1250 \text{ A}$ from 62 s to 76 s	500 A / 3 s 1250 A / 12 s 1250 A 1250 A 17.5 s 3125 A 71 s	

ВЯРНО С  
ОРИГИНАЛА

с-1119



LOVAG		Test report No.: 07.053 Page 20 / 39	Test values Results
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	
Standard and clause	Kind of tests and requirements		Test values Results
8.3.3.2 60947-1 8.3.3.4.1 2) 8.3.3.4.1 2) a)	<b>TEST OF DIELECTRIC PROPERTIES</b> Verification of impulse withstand voltage Tests 1.2 / 50 $\mu\text{s}$ Circuits incorporating solid-state devices disconnected <input checked="" type="checkbox"/> No / <input type="checkbox"/> Yes, if Yes		Page - 9.6 kV - kV - kV
Table H.1, 12	Test voltage Main circuits Control circuits Auxiliary circuits Application of the test voltage Main-poles to ground Between main-poles Control and auxiliary circuits (if rating is lower than main circuit)	9.6 kV - kV - kV 5 impulses per polarity	
8.3.3.4.1 2) c) i) ii) iii) iv)	<b>Additional test across open contacts for equipment suitable for isolation</b>		
Table 14	Test voltage Main circuits Application of the test voltage Across open main contacts	12.1 kV 5 impulses per polarity	12.1 kV
iv)	<b>Test across open contacts for equipment NOT suitable for isolation</b>		
Table 12 8.3.3.2 iii)	Test voltage Main circuits Application of the test voltage Across open main contacts	- kV 5 impulses per polarity	- kV

CU

Authorized representative  
R. Ghanadi

Test laboratory: ACAE IA.01

Date 08.04.14

TRF IEC/EN 60947-2  
Ed. 4.0 form 27

LOVAG		Test report No.: 07.053 Page 21 / 39	Test report No.: 07.053 Page 22 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: T7V 1250	Type: T7V 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
60947-1 8.3.3.4.1.3)	Power-frequency withstand verification of solid insulation		
8.3.3.4.1.3) c)	Circuits incorporating solid-state devices disconnected <input checked="" type="checkbox"/> No / <input type="checkbox"/> Yes; if Yes	Page -	
b) i)	Power-frequency test:		
Table 12A	Test frequency Main circuits 42 - 65 Hz Test voltage Control- and auxiliary circuits 2200 V - V	50 Hz 2200 V - V	
8.3.3.4.1.2) c) i) ii) iii)	Application of the test voltage Main-poles to ground Between main-poles Control and auxiliary circuits (if rating is lower than main circuit)	5 s	
b) ii)	Alternative test with direct voltage		
Table 12A	Test voltage Main circuits - V Control- and auxiliary circuits - V	- V - V	
8.3.3.4.1.2) c) i) ii) iii)	Application of the test voltage Main-poles to ground Between main-poles Control and auxiliary circuits (if rating is lower than main circuit)	5 s	
60947-1 8.3.3.4.1.7)	Verification of creepage distances		
Appendix G	Working voltage or rated insulation voltage Pollution degree Material group Minimum creepage distance	1000 V 3 1 12.5 mm	96.6 mm

LOVAG		Test report No.: 07.053 Page 22 / 39	Test report No.: 07.053 Page 22 / 39
Type test according to: IEC 60947-2 Test sequence ...		Type: T7V 1250	Type: T7V 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
<b>VERIFICATION OF LEAKAGE CURRENT</b>			
8.3.3.2 8.3.3.5 8.3.4.3 8.3.5.3 8.3.6.5 8.3.7.3 8.3.7.7 8.3.8.5 C.3 H.3 L.7.2.2.3 L.7.2.3.3 O.6.1.2	iv) Test sequence I (in new condition) Test sequence I (after overload performance) Test sequence II Test sequence III Test sequence IV Test sequence V, stage 1 Test sequence V, stage 2 Combined test sequence Individual pole short-circuit test sequence $I_{sc}$ Individual pole short-circuit test sequence $I_{tr}$ Circuit-breaker CBIs Class X Circuit-breaker CBIs Class Y Circuit-breaker CBIs (sequence II / III)	$\leq 0.5$ mA $\leq 2$ mA $\leq 2$ mA $\leq 6$ mA $\leq 2$ mA $\leq 2$ mA $\leq 6$ mA $\leq 2$ mA $\leq 6$ mA $\leq 6$ mA $\leq 6$ mA $\leq 6$ mA $\leq 6$ mA $\leq 2 / 6$ mA	0.11 mA - mA - mA - mA - mA - mA - mA - mA - mA - mA - mA - mA - mA - mA
8.3.3.2	iv) Leakage current		
	For circuit-breakers suitable for isolation having an operational voltage $U_o$ greater than 50 V.		
	Test frequency Test voltage	45 - 65 Hz $1.1 \times U_o$ , 759 V	50 Hz 760 V
	Application of the test voltage - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)		

CM

*[Handwritten signature]*

ВЯРНО С  
ОРИГИНАЛ

ly 120



Test laboratory: ACAE IA.01

TRF IEC/EN 60947-2  
Ed. 4.0 form 28

*[Handwritten signature]*  
Authorized representative

Date 08.04.14

Date 08.04.14

LOVAG		Test report No.: 07.053 Page 23 / 39	Test report No.: 07.053 Page 24 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.3	<b>TEST OF MECHANICAL OPERATION AND OF OPERATIONAL PERFORMANCE CAPABILITY</b>		
8.3.3.3.2	Construction and mechanical operation		
8.3.3.3.2 a)	Construction		
7.1.1	Withdrawable circuit-breakers		
	A) Verification of isolating distances in the disconnected position		
	1. Main circuit and auxiliary circuit indicated as suitable for connection	- kV	
	Rated impulse withstand voltage $U_{imp}$	-	
	Pollution degree	- mm	
	Minimum clearance (inhomogeneous field)		
	Isolating distance of main circuit		
	Isolating distance of auxiliary circuits	- mm	
	2. Auxiliary circuit not connected to the main circuit		
	Rated impulse withstand voltage $U_{imp}$	- kV	
	Pollution degree	-	
	Minimum clearance (inhomogeneous field)	- mm	
	Isolating distance of auxiliary circuits		
	B) Verification of the indication of isolating contact position	open	
		closed	
	C) Impossibility to re-close with the withdrawable mechanism when the circuit-breaker is closed		
	D) Impossibility to separate with the withdrawable mechanism when the circuit-breaker is closed		

LOVAG		Test report No.: 07.053 Page 24 / 39	Test report No.: 07.053 Page 24 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
7.2.1.1.5	<b>Stored energy operating circuit-breaker</b>		
	- Verification of operating conditions of the device indicating the storing mechanism is fully charged		
	- Verification of the direction of operation when the energy storing mechanism is manually operated		
8.3.3.3.2 b)	<b>Mechanical operation</b>		
	- With the closing device energized (electrically, mechanically or manually), the opening order shall cause total tripping		P
	- With the tripping device actuated (electrically, mechanically or manually), a closing order remains ineffective		P
	- The circuit-breaker closed, a further closing order by a power-operated device, does not cause any anomaly		
	- Opening time (if indicated)	- ms	- ms
	- Closing time (if indicated)	- ms	- ms

*Ch*

*04*

*R*

**ВЯРНО С  
ОРИГИНАЛА**

*01121*



Test laboratory: ACAE IA.01

TRF IEC/EN 60947-2  
Ed. 4.0 form 30

*R. Gherghel*  
Authorized representative

Date 08.04.14

*R. Gherghel*  
Authorized representative

Date 08.04.14

TRF IEC/EN 60947-2  
Ed. 4.0 form 31



LOVAG		Test report No.: 07.053 Page 27 / 39	Test report No.: 07.053 Page 28 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.3	<b>Operational performance capability without current</b> Kind of release: Shunt <input type="checkbox"/> <input type="checkbox"/> Undervoltage <input type="checkbox"/> Number of closing operations with undervoltage release not energized (if applicable) 10 Opening by release 5% Number of operating cycles 2500 Operating cycles per hour 20/h Opening by release 5%	-	-
Table 8 Column 3 Column 2	<b>Operational performance capability with current</b> Short-circuit release min. setting 1250 A Overload release max. setting 1250 A Circuit diagram Page 33 / 39 Maximum rated operational voltage $U_{e \text{ max.}}$ 690 V Rated current $I_n$ 1250 A Power factor 0.8 Time constant - ms Frequency 50 Hz	2500 960/h	- V - V - V
Table 11	Operating cycles per hour 20/h On-time 20/h Number of operating cycles 500 <b>Additional test of operational performance capability without current for withdrawable circuit-breakers</b> Number of operating cycles 100 Visual inspection of isolating contacts, withdrawal mechanism and interlocks	0.77 - ms 50 Hz	- / h - A - ms
Table 8 Column 2 Column 4	Operating cycles per hour 20/h On-time 20/h Number of operating cycles 500	20/h 150 ms 500	- A - ms
8.3.3.5	<b>Additional test of operational performance capability without current for withdrawable circuit-breakers</b> Number of operating cycles 100 Visual inspection of isolating contacts, withdrawal mechanism and interlocks	100	- / ms

ВРНО С  
ОПУТНААА  
123



Test laboratory: ACAE IA 01  
 Authorized representative  
 Date 08.04.14

TRF IEC/EN 60947-2  
 Ed. 4.0 form 04

LOVAG		Test report No.: 07.053 Page 28 / 39	Test report No.: 07.053 Page 28 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.4	<b>OVERLOAD PERFORMANCE</b> Rated current $I_n$ - A Current setting Overload release (maximum) - A Short-circuit release (maximum) - A Control supply voltage $0.85 \times U_n$ - V Maximum rated operational voltage $U_{e \text{ max.}}$ - V Recovery voltage $1.05 \times U_{e \text{ max.}}$ reduced voltage on automatic opening according to note 2) - V Number of operating cycles per hour - / h	-	- V - V - V
Table 12	Circuit diagram form 0 Safety area Alternating current: Test current $6 \times I_n$ - A Power factor - Frequency 45 - 62 Hz Direct current: Test current $2.5 \times I_n$ - A Time constant - ms	- / h	- / h Page - Page - - A - Hz - A - ms
Table 8 Column 2 60947-1 8.3.3.5.2 8.3.2.1	<b>Test method</b> <input type="checkbox"/> Standard <input type="checkbox"/> Reduced voltage on automatic opening according to note 2) <input type="checkbox"/> Opening caused by short-circuit releases	<b>Number of operations</b> manual 9 automatic 3 12 - 12	-
Table 12	On-time on manual operation min./max. Melting of the fusible element Yes/No	min./max. Yes/No	- / - ms
Table 11			-

Test laboratory: ACAE IA 01  
 Authorized representative  
 Date 08.04.14

TRF IEC/EN 60947-2  
 Ed. 4.0 form 05





LOVAG		Test report No.: 07.053 Page 31 / 39	Test report No.: 07.053 Page 32 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.6	VERIFICATION OF TEMPERATURE-RISE		21.6 °C
8.3.2.5	Temperature-rise test		
60947-1 8.3.3.3.1	Ambient temperature	10...40 °C	
60947-1 8.3.3.3.4	Main circuits		
60947-1 8.3.3.3.4	Conventional thermal current $I_n$	1250 A	1250 A
60947-1 8.3.3.3.4	Conventional thermal current for enclosure $I_{nE}$	- A	- A
60947-1 8.3.3.3.4	Conventional thermal current of the neutral pole	- A	- A
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Phase poles		
	Cable	- mm <sup>2</sup>	- mm <sup>2</sup>
	Bar	100 x 5 mm	50 x 10 mm
	Number	2	2
	Length	3000 mm	3000 mm
	Tightening torque		40 Nm
	Neutral pole (if applicable)		
	Cable	- mm <sup>2</sup>	- mm <sup>2</sup>
	Bar	- x - mm	- x - mm
	Number	-	-
	Length	- mm	- mm
	Tightening torque	-	- Nm
	Arrangement:	<input checked="" type="checkbox"/> 3 phase or <input type="checkbox"/> poles in series	
Table 7	Temperature-rise limits		
	- Terminals	≤ 90 K	61.6 K
	- Manual operating means:		
	metallic	≤ - K	- K
	non metallic	≤ 35 K	7 K
	- Parts intended to be touched:		
	metallic	≤ - K	- K
	non-metallic	≤ 50 K	8.5 K
	- Parts, which need not to be touched:		
	metallic	≤ - K	- K
	non-metallic	≤ 60 K	36 K
Test laboratory: ACAE IA.01		Test laboratory: ACAE IA.01	
Authorized representative		Authorized representative	
Date 08.04.14		Date 08.04.14	
TRF IEC/EN 60947-2 Ed. 4.0 form 37		TRF IEC/EN 60947-2 Ed. 4.0 form 39	

LOVAG		Test report No.: 07.053 Page 32 / 39	Test report No.: 07.053 Page 32 / 39
Type test according to: IEC 60947-2 Test sequence I		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
8.3.3.7 8.3.4.5 8.3.5.7	VERIFICATION OF OVERLOAD RELEASES		
60947-1 Table 9, 10 and 11	Test sequence I Test sequence II Test sequence VI	after 8.3.3.6 after 8.3.4.4 after 8.3.5.6	
	Tripping test		
	Time interval to previous test of temperature-rise (if applicable)		- min
	Cabling characteristics		
	Cable	- mm <sup>2</sup>	- mm <sup>2</sup>
	Bar	- x - mm	- x - mm
	Number	-	-
	Length	- mm	- mm
	Tightening torque		- Nm
	Arrangement:	<input checked="" type="checkbox"/> 3 phase or <input type="checkbox"/> poles in series	
	Reference temperature	20-40°C ± 2 °C	21.6 °C
	Ambient temperature		
	Correction factor k		
	(k = 1 for releases independent of ambient temperature)		
	Current setting value	1250 A	1250 A
	Test current		
	Phase poles		
	k x 1.45 x current setting value	1812.5 A	1812.5 A
	or tripping current according to the manufacturer's temperature/current data		
	(for releases dependent on ambient temperature)	- A	- A
Table 6	Tripping time	≤ 120 min	3 min
	Neutral pole (if applicable)		
	k x 1.45 x current setting value	- A	- A
	or tripping current according to the manufacturer's temperature/current data		
	(for releases dependent on ambient temperature)	- A	- A
	Tripping time	≤ - min	- min
Test laboratory: ACAE IA.01		Test laboratory: ACAE IA.01	
Authorized representative		Authorized representative	
Date 08.04.14		Date 08.04.14	
TRF IEC/EN 60947-2 Ed. 4.0 form 37		TRF IEC/EN 60947-2 Ed. 4.0 form 39	

ВЯРНО С  
ОРИГИНАЛ



Test laboratory: ACAE IA.01

Authorized representative

Date 08.04.14

TRF IEC/EN 60947-2  
Ed. 4.0 form 37

Test laboratory: ACAE IA.01

Authorized representative

Date 08.04.14

TRF IEC/EN 60947-2  
Ed. 4.0 form 39

LOVAG		Test report No.: 07.053 Page 33 / 39	Type: TVV 1250
Type test according to: IEC 60947-2 Test sequence I		Kind of tests and requirements	
Standard and clause	Kind of tests and requirements	Test values Results	
8.3.3.8	<b>VERIFICATION OF UNDERS-VOLTAGE AND SHUNT RELEASES</b>		
8.3.3.3.2 c)	<b>Under-voltage releases</b> Ambient temperature Minimum / Maximum rated control supply voltage $U_c$ Drop-out-voltage $0.95 \times U_{c, \text{min}} \leq U_{\text{drop}} \leq 0.70 \times U_{c, \text{min}}$	- °C - V	
8.3.3.3.2 d)	<b>Shunt releases</b> Ambient temperature Minimum rated control supply voltage $U_c$ Verification of operating -Tripping $U = 0.70 \times U_{c, \text{min}}$	- °C - V	

*[Handwritten signature]*

*[Handwritten signature]*



ВЕРНО С  
ОРИГИНАЛА *[Signature]* 126

LOVAG		Test report No.: 07.053 Page 34 / 39	Type: TVV 1250
Type test according to: IEC 60947-2 Test sequence I		Kind of tests and requirements	
Standard and clause	Kind of tests and requirements	Test values Results	
8.3.3.9	<b>VERIFICATION OF THE MAIN CONTACT POSITION</b> For circuit-breakers suitable for isolation having an operational voltage $U_c$ greater than 50 V. <b>Dependent and independent manual operation</b> Type of actuator Determination of the normal actuator opening force (F) Fixing of the moving contact in pole		
60947-1 8.2.5.2.1			
60947-1 Figure 16			
8.2.5.2		80 N	right
Table 17	Test force with contact kept close (3 x F, not less than the minimum nor more than the maximum given in table 17 corresponding to the type of actuator)		240 N
	Test duration	10 s	10 s
8.2.5.3	<b>Condition of equipment during and after test</b> The actuator cannot be locked in the OFF-Position while test force is applied. After the test, when the test force is no longer applied, the actuator being left free, the open position is not indicated. There is no damage to the equipment such as to impair its normal operation.	Yes/No Yes/No Yes/No	yes yes

*[Handwritten signature]*

*[Handwritten signature]*  
Authorized representative

Date 08.04.14

Test laboratory: ACAE IA.01  
TRF IEC/EN 60947-2  
Ed. 4.0 form 41

<b>LOVAG</b>	Test report No.: 07.053 Page 35 / 39
Type test according to: IEC 60947-2	Type: TTV 1250
The instruments have an measurement uncertainty like follow :	
Quantity	
Voltage	$\leq \pm 2.5\%$ by transient recorders $< \pm 1.5\%$ by multimeters or similar $\leq \pm 2.5\%$ for dielectric test
Current	$\leq \pm 2.5\%$
Time	$< \pm 1\%$
Force	$< \pm 1\%$
Torque	$< \pm 5\%$
Resistance	$< \pm 3\%$
Temperature	$\pm 2^\circ\text{C}$ up to $100^\circ\text{C}$ $\pm 2\%$ above $100^\circ\text{C}$
Linear dipensions	$\pm 0,05$ mm
Relative humidity	$\leq \pm 5\%$ in the range $20\% - 95\%$ RH
Test laboratory: ACAE IA.01 <i>R. Ghomchi</i> Authorized representative Date 08.04.14	

<b>LOVAG</b>	Test report No.: 07.053 Page 36 / 39
Type test according to: IEC 60947-2	Type: TTV 1250
CIRCUIT DIAGRAM TYPE S 	
1 - Three-phase transformer 2 - Short-circuit making switch 3 - Device for the detection of fault currents 4 - Dividers for the arcing voltage measurement 5 - Apparatus under test 6 - Load (reactors and resistances) 7 - Non inductive shunts for current measurement 8 - Voltmeter for voltage measurement	
Test laboratory: ACAE IA.01 <i>R. Ghomchi</i> Authorized representative Date 08.04.14 TRF IEC/EN 60947-2 Ed. 4.0 form 248	

ВЯРНО С  
ОРИГИНАЛА



128




Test report No.: 07.053  
Page 39 / 39

Type: TTV 1250

LOVAG

Type test according to: IEC 60947-2



TRF IEC/EN 60947-2  
Ed. 4.0 form 248  
Date: 08.04.14  
Authorized representative  
R. Gherardi

Ch



ВАРНО С  
ОРИГИНАЛ

129



Via Tito Livio, 5 - 24123 - BERGAMO (Italy)  
Tel. +39 035 41 75 244 Fax. +39 035 45 54 866 e-mail: [secret@acae.it](mailto:secret@acae.it)



# Certificate of Conformity

LOVAG-Certificate No. IT 08.018

## Apparatus

Four poles circuit breaker 690 V (U<sub>n</sub>) - 1000 V (U<sub>m</sub>) - 2 kV (U<sub>imp</sub>) - 250 A (I<sub>n</sub>) - 50/60 Hz - 1 - 200 kA at 230V - 1 - 45 kA at 690V - 1 - 50 kA at 690V - 1 - 15 kA at 690V with microprocessor based overcurrent releases. PR33-1P

## Designation

TTV 1250

## Manufacturer or responsible vendor

ABB S.p.A. - ABB SACE Division  
Via Saroni, 35 - 24123 Bergamo (Italy)

## Tested for: ABB S.p.A. - ABB SACE Division

The apparatus, constructed in accordance with the description mentioned in the Test Report issued on this Certificate has been subjected to the series of proving tests in accordance with IEC 60847-2 (2006) EN 60947-2 (2006).  
Test sequence: Annex H  
at 690 V - 15 kA (1.2xImax current setting of short time delay release (12.5 kA)

The results as shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standards; and to justify the characteristic assigned by the manufacturer as stated below:  
Utilization category B  
Suitable for operation

U<sub>n</sub> 950 V 50/60 Hz I<sub>n</sub> 1250 A I<sub>cs</sub> 15 kA

This document includes Report No. 08.005  
Issue Date: 2008.04.16

Responsible Certification Body: ACAE

**SINCERT**  
SISTEMA ITALIANO  
CERTIFICAZIONE  
ELETTRICA



Valter March

Authorized Signature

Date: 2008.04.17

OPUTIHAAA

ly 150

## LOVAG CERTIFICATES

**LOVAG** is the Low Voltage Agreement Body which is a Mutual Agreement Group of Certification Bodies founded in 1993 which has achieved a high level of competence in testing and certification of low voltage equipment.  
LOVAG's main purpose as an Agreement Group shall be to be the mutual recognition of the test records and/or certificates of conformity by its signatories.

### Membership

LOVAG presently has seven signatories to the Agreement:  
ACAE (Italy), ALPHA (Germany), ABSYS CTC (Spain), ASEFA (France), Intertek Semko AB (Sweden), SGS Belgium NV, Divisor SGS CEEC (Belgium) and VEIKI-VNL (Hungary) and members include 40 European Testing Laboratories.

### Certificates

LOVAG Certificates are issued by the signatory bodies to the Agreement using their records and certificates of conformity and recognizable format in the market. They are recognised and accepted in the European Economic Area and elsewhere in the world.

### Test Instructions








LOVAG issues common LOVAG Test Instructions for each of the international and European Standards covered by the Agreement and signatories to the Agreement which by those when testing for LOVAG Certification.

### Qualifications

All signatory bodies to the Agreement are accredited and/or addressed to EN-45011:1993/IEC Guide 65 and their laboratories are accredited to and/or addressed to EN ISO/IEC 17024.

For further information contact your local certification body from the list below or contact the Secretariat of LOVAG at: ALPHA e.V., Stresemannallee 19, D-60596 Frankfurt am Main, Phone: +49 69 9620 6343, Fax: +49 69 9620 6344, e-mail: [secret@lovag.net](mailto:secret@lovag.net)

### LIST OF LOVAG SIGNATORIES:

 <b>ACAE</b> Via Tito Livio 3 I-24123 Bergamo ITALY Tel: +39 035 453 4862 Fax: +39 035 453 4862 e-mail: <a href="mailto:secret@acae.it">secret@acae.it</a>	 <b>SGS Belgium NV</b> - Divisor SGS CEEC Avenue Van Kalker 6A Bbx 1 B-1075 Brussels BELGIUM Tel: +32 2 536 00 36 e-mail: <a href="mailto:divisor@sgs.be">divisor@sgs.be</a>
 <b>ALPHA e.V.</b> Stresemannallee 19 D-60596 Frankfurt am Main GERMANY Tel: +49 69 9620 6344 e-mail: <a href="mailto:info@alpha-cert.net">info@alpha-cert.net</a>	 <b>Intertek Semko AB</b> Box 1192 Terminatorvägen 42 S-15154 22 Kista SWEDEN Tel: +46 8 751 9640 e-mail: <a href="mailto:cert@intertek.se">cert@intertek.se</a>
 <b>Appius+CTC</b> Compu-DAB E-08180 Bellmunt Barcelona, SPAIN Tel: +34 93 30 72 04 e-mail: <a href="mailto:info@acae.com">info@acae.com</a>	 <b>VEIKI-VNL Electric</b> Lajta Laboratorius Ltd Vaskopalya 2-4 H-1155 Budapest HUNGARY Tel: +36 1 41 91 2700 e-mail: <a href="mailto:info@veiki-vnl.hu">info@veiki-vnl.hu</a>
 <b>ASEFA</b> 33 av du general Leclerc F-92350 Fontenay-aux-roses FRANCE Tel: +33 1 40 45 80 10 e-mail: <a href="mailto:seifa@seifa.fr">seifa@seifa.fr</a>	

Test Report No. 08.005

Test laboratory: ACAE IA.01  
 Client: I - 24123 Bergamo  
 Manufacturer: ABB S.p.A.  
 Test object: Low voltage molded case circuit-breaker series Tmax  
 Type designation: TTV 1250  
 Date(s) of test(s): from 2008.02.01 to 2008.02.04  
 Test specification: IEC 60947-2:2006  
 EN 60947-2:2006  
 Test sequence(s): Annex H

Test results: Annex H at 690V found in compliance with rated characteristics

The Record of Proving Test consists of:

- 31 pages LOVAG test report forms - oscillograms
- other pages - drawings
- diagrams - photographs

Date of issue: 2008.04.16

Signatures: R. Oprandi  
 (Name, function and signature of authorized representative)

Responsible Test Laboratory  
 M. Bortoli

ACAЕ Inspector  
 M. Marchi

Note:  
 The test result relates only to the items tested.  
 The test report shall not be reproduced except in full  
 without the written approval of the test laboratory.



LOVAG

Description and characterization of the test object

Characteristics

Type of circuit-breaker:

Number of poles: 4  
 Kind of current: a.c.  
 Number of phases: 3  
 Rated frequency: 50+60 Hz  
 Utilization category: B  
 Reference temperature: 40 °C  
 Suitability for isolation: yes  
 Pollution degree: 3  
 Material group: I

Rated and limiting values: (according to test volume)

Main circuit:

Rated impulse withstand voltage  $U_{imp}$ : 8 kV  
 Rated insulation voltage  $U_i$ : 1000 V  
 Conventional thermal current  $I_n / I_{ns}$ : 1250 / - A  
 Rated current  $I_n$ : 1250 A  
 Rated current in the neutral pole: 1250 A

Short-circuit characteristics:

$U_p/V$	$I_{mp}/kA$	$I_{wp}/kA$	$I_{wp}/kA$	$I_{wp}/kA$	$I_{wp}/kA$	$I_{wp}/kA$
230	440	200	200	15	-	-
415	330	150	150	15	-	-
440	286	130	130	15	-	-
500	220	100	100	15	-	-
690	132	60	45	15	-	15

*R. Oprandi*

Authorized representative

ВАРНО С  
 ОПИТИВАНА

**LOVAG**

- Control circuits:**
- Electrical control circuits:**
- Kind of current -
  - Rated frequency - Hz
  - Rated control circuit voltage  $U_c$  - V
  - Rated control supply voltage  $U_s$  - V
  - Rated impulse withstand voltage  $U_{imp}$  - kV
  - Rated insulation voltage  $U_i$  - V
- Air-supply control circuits:**
- Rated supply pressure - kPa
  - Limits of pressure - kPa
  - Required volume for each closing operation - m<sup>3</sup>
  - Required volume for each opening operation - m<sup>3</sup>
- Auxiliary circuits:**
- Rated operational voltage  $U_o$  - V
  - Rated impulse withstand voltage  $U_{imp}$  - kV
  - Rated insulation voltage  $U_i$  - V
  - Rated frequency - Hz
  - Rated operational current  $I_o$  - A
  - Number of circuits -
  - Number and kind of contact elements -



ВАРНО С  
ОРИГИНАЛ

*Handwritten signature*

152

**LOVAG**



- Releases:**
- Shunt release:**
- Rated control circuit voltage  $U_c$  - V
  - Kind of current -
  - Rated frequency if a.c. - Hz
- Undervoltage or no-voltage release**
- Rated control circuit voltage  $U_c$  - V
  - Kind of current -
  - Rated frequency if a.c. - Hz
- Over-current release:**
- Kind of release  electromagnetic  electronic
- Short-circuit release**
- Instantaneous release Yes
  - definite time-delay release -
  - Rated current  $I_n$  400-1250 A
  - Rated instantaneous short-circuit current setting  $I_s$  - A
  - Kind of current a.c.
  - Rated frequency if a.c. 50+60 Hz
  - Current setting (or range of settings) 600A-6000A - 1875A-18750A
  - Time setting (or range of settings) - s
- Overload release (IEC 60947-1, 2.4.30):**
- Instantaneous release -
  - definite time-delay release -
  - inverse time-delay release Yes
  - dependent on ambient air temperature -
  - independent of ambient air temperature Yes
  - Reference temperature 40 °C
  - Rated current  $I_n$  400-1250 A
  - Kind of current a.c.
  - Rated frequency if a.c. 50+60 Hz
  - Current setting (or range of settings) 160A-400A - 500A-1250A
  - Time setting (or range of settings) 3-144 s
  - Time setting at 2 times  $I_n$  (on single pole) ≤ 144 s

*Handwritten signature*



Time / current characteristics

Type designation: ABB SACE PR 33/P - L S I overcurrent release



LOVAG

Time / current characteristics

Type designation: ABB SACE PR 33/P - L S I overcurrent release

PR33/P - Protection functions and parameterisations

Protection functions	Trip threshold	Trip curves(1)	Excludability	Relation $t = f(I)$
L Against overload with delay time- 0.025 x I <sub>n</sub> Trip between 1.05 ... 1.2 x I <sub>n</sub> characteristic according to an inverse time curve (I <sup>2</sup> t=k) according to the IEC 60847-2 Standard	I <sub>1</sub> = 0.40 ... 1.1 x I <sub>n</sub> step = 0.025 x I <sub>n</sub> Trip between 1.05 ... 1.2 x I <sub>n</sub>	at 3 x I <sub>n</sub> t <sub>1</sub> = 3 - 12 - 24 - 36 - 48 - 72 - 108 - 144 s Tolerance: ±10% up to 6 x I <sub>n</sub> ±20% above 6 x I <sub>n</sub>	~	t = k / I <sup>2</sup>
S Against short-circuit with short inverse time-delay trip and trip characteristic with inverse time (I <sup>2</sup> t=k) or with definite time	I <sub>2</sub> = 0.6 - 0.8 - 1.2 - 1.8 - 2.4 - 3 - 3.6 - 4.2 - 5 - 5.8 - 6.6 - 7.4 - 8.2 - 9 - 10 x I <sub>n</sub> Tolerance: ±7% up to 4 x I <sub>n</sub> ±10% above 4 x I <sub>n</sub>	at 10 x I <sub>n</sub> t <sub>2</sub> = 0.1 ... 0.8 s Step = 0.15 Tolerance: min (=10%, ±40ms)	0	t = k / I <sup>2</sup>
I Against short-circuit with adjustable instantaneous trip	I <sub>3</sub> = 1.5 - 2 - 3 - 4 - 5 - 6 - 7 - 8 - 9 - 10 - 11 - 12 - 13 - 14 - 15 x I <sub>n</sub> (I <sub>2</sub> ) Tolerance: ±10%	t <sub>3</sub> = 0.6 - 0.8 - 1.2 - 1.8 - 2.4 - 3 - 3.6 - 4.2 - 5 - 5.8 - 6.6 - 7.4 - 8.2 - 9 - 10 x I <sub>n</sub> Tolerance: ±7% up to 4 x I <sub>n</sub> ±10% above 4 x I <sub>n</sub> I <sub>3</sub> = 1.5 - 2 - 3 - 4 - 5 - 6 - 7 - 8 - 9 - 10 - 11 - 12 - 13 - 14 - 15 x I <sub>n</sub> (I <sub>2</sub> ) Tolerance: ±10%	0	t = k

1) These tolerances hold in the following conditions:  
- self-powered trip unit at full power and/or auxiliary supply power supply  
In conditions other than those considered, the following tolerances hold:

Trip threshold  
S ± 10%  
I ± 15%

2) For I<sub>3</sub> = 1250 A / 1600 A => I<sub>3max</sub> = 12 x I<sub>n</sub>

ВЕРНО С  
ОРИГИНАЛ

*ly*

133





LOVAG		Test report No.: 08.005 Page 11 / 31	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	
H.2	<b>INDIVIDUAL POLE SHORT-CIRCUIT (It)</b> Maximum rated operational voltage for application on IT-systems $U_{0, max}$ . Recovery voltage Maximum current setting of (a) instantaneous release or, in the absence of such a release, (b) short-time delay release or, if applicable (c) definite time delay release Test current: 1.2 times max. value of (a) <input type="checkbox"/> (b) <input checked="" type="checkbox"/> or (c) <input type="checkbox"/> A Setting of adjustable overcurrent releases overload releases short-circuit releases Power factor Frequency Control supply voltage Maximum value of the closing time Sequence of operation Circuit diagram Calibration of the test circuit Safety area Installation of the material tested Energization direction Smallest individual enclosure (if applicable) Type Kind of material Inside dimensions (H x W x D) Cabling characteristics Cable Bar Number Length Tightening torque	690 V 1.05 x $U_0$ - A 12500 A 155000 A maximum maximum 0.3 50 Hz 0.85 x $U_0$ - V - ms O - t - CO Page 20 / 31 Page 12 / 31 Page 7 / 31 Page 7 / 31 Top - mm <sup>2</sup> 50 x 10mm 2 500 mm 250 mm 40 Nm	
Table 10			
Table 11			
8.3.2.1			
7.2.1.1.3			
8.3.2.1			
60947-1 Tables 9-10 and 11			
Test laboratory: ACAE IA.01		TRF IEC/EN 60947-2 Ed. 4.0 form 151	
R. Ghemah Authorized representative		Date 2008.04.16	

LOVAG		Test report No.: 08.005 Page 12 / 31	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	
60947-1 8.3.4.1.5	<b>CALIBRATION OF THE TEST CIRCUIT</b> Oscillogram Applied voltage Frequency <input checked="" type="checkbox"/> Short-circuit making/breaking current r.m.s. current value Average r.m.s. value at Peak current value Power factor <input type="checkbox"/> Short-time withstand current r.m.s. current value Average r.m.s. value at Peak current value Power factor Current-flow time Joule Integral Average value	Page 22 / 31 726 V 50 Hz 15.9 kA -kA -kA 19.6 kA 20 ms 31.2 kA 0.29 -kA -kA -kA -kA -ms -kA -ms -A <sup>2</sup> s -A <sup>2</sup> s -A <sup>2</sup> s -A <sup>2</sup> s	
Test laboratory: ACAE IA.01		TRF IEC/EN 60947-2 Ed. 4.0 form 247	
R. Ghemah Authorized representative		Date 2008.04.16	

ВЕРНО С  
ОРИГИНАЛА



136

LOVAG		Test report No.: 08.005 Page 13 / 31	Test report No.: 08.005 Page 14 / 31
Type test according to: IEC 60947-2 Test sequence H		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
	Test carried out on circuit-breaker pole	Ph1	Ph2
	OPERATION „O“ Oscillogram Applied voltage 726 V Peak current value 30.7 kA Total duration 21,3 ms Recovery voltage (phase to phase) 726 V Ratio between $U_1$ and $U_2$ 1,05 Joule integral $6.61 \times 10^6$ A <sup>2</sup> s Melting of the fusible element No Holes in the PE-sheet (if applicable) - Cracks observed Yes/No No if Yes Yes/No Page -	$U_1$ (-/-) $U_1/U_2$	Page 25 / 31 726 V 30.5 kA 31,1 ms 726 V 1,05 $8.35 \times 10^6$ A <sup>2</sup> s No - No Page -
	Time interval between operations $\geq 3$ min	$\geq 3$ min	$\geq 3$ min
	OPERATION „CO“ Oscillogram Applied voltage 726 V Peak current value 30 kA Total duration 30,8 ms Recovery voltage (phase to phase) 726 V Ratio between $U_1$ and $U_2$ 1,05 Joule integral $8.1 \times 10^6$ A <sup>2</sup> s Closing operation time -ms Melting of the fusible element No Cracks observed Yes/No No if Yes Yes/No Page -	$U_1$ (-/-) $U_1/U_2$	Page 26 / 31 726 V 22,5 kA 28,3 ms 726 V 1,05 $5.63 \times 10^6$ A <sup>2</sup> s -ms No No Page -
7.2.1.1.3			

Test laboratory: ACAE IA.01

TRF IEC/EN 60947-2  
Ed. 4.0 form 120

*R. Ghorashi*  
Authorized representative

Date 2008.04.16



ВЕРНО С  
ОРИГИНАЛА

*ey* 137

LOVAG		Test report No.: 08.005 Page 14 / 31	Test report No.: 08.005 Page 14 / 31
Type test according to: IEC 60947-2 Test sequence H		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
	Test carried out on circuit-breaker pole	Ph1	Ph2
	OPERATION „O“ Oscillogram Applied voltage 726 V Peak current value 30.7 kA Total duration 21,3 ms Recovery voltage (phase to phase) 726 V Ratio between $U_1$ and $U_2$ 1,05 Joule integral $6.61 \times 10^6$ A <sup>2</sup> s Melting of the fusible element No Holes in the PE-sheet (if applicable) - Cracks observed Yes/No No if Yes Yes/No Page -	$U_1$ (-/-) $U_1/U_2$	Page 25 / 31 726 V 30.5 kA 31,1 ms 726 V 1,05 $8.35 \times 10^6$ A <sup>2</sup> s No - No Page -
	Time interval between operations $\geq 3$ min	$\geq 3$ min	$\geq 3$ min
	OPERATION „CO“ Oscillogram Applied voltage 726 V Peak current value 30 kA Total duration 30,8 ms Recovery voltage (phase to phase) 726 V Ratio between $U_1$ and $U_2$ 1,05 Joule integral $8.1 \times 10^6$ A <sup>2</sup> s Closing operation time -ms Melting of the fusible element No Cracks observed Yes/No No if Yes Yes/No Page -	$U_1$ (-/-) $U_1/U_2$	Page 26 / 31 726 V 22,5 kA 28,3 ms 726 V 1,05 $5.63 \times 10^6$ A <sup>2</sup> s -ms No No Page -
7.2.1.1.3			

Test laboratory: ACAE IA.01

TRF IEC/EN 60947-2  
Ed. 4.0 form 120

*R. Ghorashi*  
Authorized representative

Date 2008.04.16

*ey*

LOVAG		Test report No.: 08.005 Page 15 / 31	Test report No.: 08.005 Page 16 / 31
Type test according to: IEC 60947-2 Test sequence H		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
	Test carried out on circuit-breaker pole	Ph3	
	<b>OPERATION „O“</b>	Page 27 / 31	
	Oscillogram	726 V	
	Applied voltage	30,5 kA	
	Peak current value	31,1 ms	
	Total duration	726 V	
	Recovery voltage (phase to phase)	1,05	
	Ratio between $U_1$ and $U_2$	$U_1 (-/-)$	
	Joule Integral	$U_1/U_2$	
	Melting of the fusible element	Yes/No	No
	Holes in the PE-sheet (if applicable)	Yes/No	-
	Cracks observed	Yes/No	No
	If Yes	Page -	
	Time interval between operators	≥3 min	3 min
	<b>OPERATION „CO“</b>		
	Oscillogram	Page 28 / 31	
	Applied voltage	726 V	
	Peak current value	24 kA	
	Total duration	28,3 ms	
	Recovery voltage (phase to phase)	726 V	
	Ratio between $U_1$ and $U_2$	1,05	
	Joule Integral	$U_1 (-/-)$	
	Closing operation time	$U_1/U_2$	
	Melting of the fusible element	Yes/No	-ms
	Cracks observed	Yes/No	No
	If Yes	Page -	No
7.2.1.1.3			



ВЕРНО С  
ОРИГИНАЛА

138

LOVAG		Test report No.: 08.005 Page 16 / 31	Test report No.: 08.005 Page 16 / 31
Type test according to: IEC 60947-2 Test sequence H		Type: TTV 1250	Type: TTV 1250
Standard and clause	Kind of tests and requirements	Test values Results	Test values Results
	<b>VERIFICATION OF DIELECTRIC WITHSTAND</b>		
8.3.3.5	Test sequence I		
8.3.4.3	Test sequence II		
8.3.5.3	Test sequence III		
8.3.5.5	Test sequence IV		
8.3.7.3	Test sequence V, stage 1		
8.3.7.7	Test sequence V, stage 2		
8.3.8.5	Test sequence VI, combined test sequence		
B.10.3.1	Test sequence B.11		
A.5	Verification of discrimination		
A.6.3	Verification of back-up protection		
C.3	Individual pole short-circuit test sequence		
H.3	Test sequence for circuit-breakers for IT-systems		
L.7.2.2.3	Circuit-breaker CBIs Class X		
L.7.2.3.3	Circuit-breaker CBIs Class Y		
O.6.1.2	Circuit-breaker ICBS (sequence II / III)		
60947-1	<b>Power-frequency withstand verification</b>		
8.3.3.4.1.3)	Circuits incorporating solid-state devices disconnected	<input checked="" type="checkbox"/> No / <input type="checkbox"/> Yes, if Yes	Page -
	Test frequency	42 - 65 Hz	50 Hz
	Test voltage	2 x $U_n$ , min. 1000 V 1380 V	1380 V
8.3.3.2.2 a)	Application of the test voltage		5 s
	- Main circuit of the circuit-breaker		
	- Isolating contacts of the withdrawable unit (if applicable)		
	- Insert of withdrawable unit		
	- Withdrawable unit (base)		
	- Combination of base and insert		


С

R. Spandh  
Authorized representative

Test laboratory: ACAE IA.01  
TRF IEC/EN 60947-2  
Ed. 4.0 form 30  
Date 2008.04.10



<b>LOVAG</b>	Test report No.: 08.005 Page 19 / 31
Type test according to: IEC 60947-2	Type: TTV 1250
The instruments have an measurement uncertainty like follow :	
Quantity	
Voltage	≤ ±2.5% by transient recorders < ±1.5% by multimeters or similar ≤ ±2.5% for dielectric test
Current	≤ ±2.5%
Time	< ±1%
Force	< ±1%
Torque	< ±5%
Resistance	< ±3%
Temperature	±2°C up to 100°C ±2% above 100°C
Linear dimensions	±0,05 mm
Relative humidity	±2.5% in the range 20% + 95% RH
<p>Test laboratory: ACAE IA.01</p> <p><i>R. Ghazali</i> Authorized representative</p> <p>TRF IECEN 60947-2 Ed. 4.0 form 248 Date 2008.04.19</p>	



ВЯРНО С  
ОРИГИНАЛА



<p><b>LOVAG</b></p>	<p>Test report No.: 06.005 Page 21 / 31</p>
<p>Type: TTV 1250</p>	
<p>Type test according to: IEC 60947-2</p>	
<p>Test laboratory: ACAE IA.01</p>	
<p>Authorized representative: <i>R. Grand</i></p>	
<p>Date 2008.04.16</p>	

**SYMBOLS USED FOR THE IDENTIFICATION OF THE MEASUREMENTS RECORDED BY THE OSCILLOGRAM**

- 1\_U1 L1 phase current
- 2\_U2 L2 phase current
- 3\_U3 L3 phase current
- 4\_Ur4 L1 phase arc voltage and recovery voltage
- 5\_Ur5 L2 phase arc voltage and recovery voltage
- 6\_Ur6 L3 phase arc voltage and recovery voltage
- 7\_Ur1 L1 - L2 phases applied voltage
- 8\_Ur2 L2 - L3 phases applied voltage
- 9\_Ur3 L3 - L1 phases applied voltage
- 10\_BC Closing coil

Test laboratory: ACAE IA.01


TRF IEC/EN 60947-2  
Ed. 4.0 form 246

Date 2008.04.16

Authorized representative



**ВЯРНО С  
ОРИГИНАЛ**




*cy*

*cy*

*cy*


*cy*



**ВЯРНО С  
ОРИГИНАЛА**



*[Handwritten signature]*




*[Handwritten signature]*


*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*





**ВЯРНО С  
ОРИГИНАЛА**



*CU*

*CU* 143



Cu

ВЯРНО С  
ОРИГИНАЛА



ME

G

G




Test report No.: 08.005  
Page 31 / 31

Type: TTV 1250

LOVAG

Type test according to: IEC 60947-2



TRF IEC/EN 60947-2  
Ed. 4.0 form 248

Date 2008.04.10

*R. Spasov*

Authorized representative

Test laboratory: ACAE IA.01



ВЯРНО С  
ОРИГИНАЛА

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

Ci riserviamo tutti i diritti connessi con il presente documento e con l'oggetto o la materia ivi rappresentati con divieto di riproduzione, utilizzarlo o renderlo accessibile a terzi in assenza di previa autorizzazione.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.

# SUMMARY TABLE OF BASE CERTIFICATION

## TMAX

### T1 - T2 - T3 - T4 - T5

*Handwritten signature*

Lovag Acae	_____	2
Special test	_____	3
Coordination	_____	5
Special test at 1000 V	_____	5
Special test at 400 Hz	_____	5

Prep. LB-DTS G. Consolandi Dis.		Resp-Dep. LB-DTS A. Bottarelli Uff. Resp.		
App. LB-DTS M. Carminati App.		Take over dep. Uff. usizz.		
Rev.	emission	I	L	M
Mod.	01-02-16	03-09-11	04-10-29	05-04-12

Titolo  
Titolo  
**SUMMARY TABLE OF BASE CERTIFICATION**  
Tmax

**ABB SACE S.p.a.**

Doc. No.  
N° Doc  
**RL0038**



**ՎՅՐՈՇ  
ՕՐՈՒՄՆԱԿԱՆ**

*Handwritten signatures and initials*

Ci riserviamo tutti i diritti connessi con il presente documento e con l'oggetto o la materia ivi rappresentati con divieto di riprodurlo, utilizzarlo o renderlo accessibile a terzi in assenza di previa autorizzazione.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.

## Tmax

CB TYPE	SEQ. I	SEQUENCE II (Ics)				SEQUENCE III (Icu)				SEQUENCE IV (Icw)
		415 V	440 V	500 V	690 V	415 V	440 V	500 V	690 V	
T1B 1P 160	02.041					02.043 (240V)				NA
T1B-160	00.046	00.031	02.047		02.048	00.031	02.047		02.048	NA
T1C-160		03.104	00.053		00.054	00.030	00.055		00.056	NA
T1E-100	04.056	04.057				04.058				
T1N-160		04.010	00.057		00.058	02.044	00.059		00.060	NA
T2N-160	01.039	01.020	01.038		01.052	01.020	01.038		01.052	NA
T2S-160		01.022	01.040		01.053	01.022	01.040		01.053	NA
T2H-160		01.023	01.041		01.054	01.023	01.041		01.054	NA
T2L-160	03.001	01.024	01.042			01.021	01.043			NA
T3N-250	00.052	01.104	00.034		00.042	00.032	00.035		00.043	NA
T3S-250		01.105	00.036		00.044	00.033	00.037			NA
T4N-250										NA
T4S-250		03.045	03.087		03.046	03.045	03.087		03.046	NA
T4H-250		03.042	03.094		03.091	03.042	03.094		03.091	NA
T4L-250		04.030	03.096		03.090	04.030	03.096		03.090	NA
T4V-250	04.009	03.084	03.081		03.116	03.084	03.081		03.116	NA
T4N-320	03.143									NA
T4S-320	03.144	03.047	03.088		03.048	03.047	03.088		03.048	NA
T4H-320	03.145	03.044	03.095		03.092	03.044	03.095		03.092	NA
T4L-320	03.147	04.031	03.097		03.093	04.031	03.097		03.093	NA
T4V-320	03.146	03.085	03.086		03.117	03.085	03.086		03.117	NA
T5N-400			04.011		04.017		04.011		04.017	
T5S-400	04.015	04.036	04.014		04.012	04.036	04.014		04.012	
T5H-400	04.024	04.037	03.118		03.135	04.037	03.118		03.135	
T5L-400	04.025		03.119		03.150		03.119		03.150	
T5V-400	04.026	04.029	03.123		03.151	04.029	03.123		03.151	04.027
T5N-630			04.016		04.018		04.016		04.018	NA
T5S-630	04.019		03.120		04.013		03.120		04.013	NA
T5H-630			03.121		03.136		03.121		03.137	NA
T5L-630			03.122		03.138		03.122			
T5V-630	04.124	04.122	03.124		03.134		03.124			

ABB SACE S.p.a.

Summary table of base certification  
Tmax

RL0038

Page 2 of 5

ВЕРНО  
ОРИГИНАЛ

148



Cl riserviamo tutti i diritti connessi con il presente documento e con l'oggetto o la materia ivi rappresentati con divieto di riprodurlo, utilizzarlo o renderlo accessibile a terzi in assenza di previa autorizzazione.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.

## Special test


CB type	Trip	Type test	Rated	Standard	Certificate number
T2	PR221-DS	ESD, EMC....		IEC 61000-4... IEC 60947-2 Annex F	ABB SACE TMS 20994
YU T1-T2-T3		EFT		CEI EN 61000-4-4/4-5	ABB SACE TMS 21081
Solenoid Operator T1-T2		ESD, EMC....		IEC 61000-4-....	ABB SACE TMS 21085
T4	PR221-DS	ESD, EMC....		IEC 61000-4... IEC 60947-2 Annex F	TR-21160
T4 with MOE-E / AUX-E		ESD, EMC....		IEC 61000-4... IEC 60947-2	TR-21221
PR020/k		ESD, EMC....		IEC 61000-4... EN 50081/2	TR-21263
T1-T2-T3		Environmental tests		Ship registers	LBPR 5157
T4 - T5	PR221-222	Environmental tests		Ship registers	LBRT 5351
T2L160+side-mounted remote control mechanism		Mechanical vibrations		ABB SACE IT0102	Mariperman 9797
T1N160+front-mounted remote control mechanism		Mechanical vibrations		ABB SACE IT0102	Mariperman 9798
T1N160+side-mounted remote control mechanism		Mechanical vibrations		ABB SACE IT0102	Mariperman 9799
T2L160+PR221 DS		Mechanical vibrations		ABB SACE IT0102	Mariperman 9800
T3S250+direct rotary handle		Mechanical vibrations		ABB SACE IT0102	Mariperman 9801
T3S250+front-mounted remote control mechanism		Mechanical vibrations		ABB SACE IT0102	Mariperman 9802
T2L160+front-mounted remote control mechanism		Mechanical vibrations		ABB SACE IT0102	Mariperman 9803
T3S 250		Mechanical vibrations		ABB SACE IT0102	Mariperman 9806
T4S 250	PR221-DS	Mechanical vibrations		ABB SACE IT0228	M.M. 57-03
T4H 320	PR221-DS	Mechanical vibrations		ABB SACE IT0228	M.M. 58-03
T5V 630	PR222DS/PD	Mechanical vibrations		ABB SACE IT0228	M.M. 59-03
T5L 400	PR221DS	Mechanical vibrations		ABB SACE IT0228	M.M. 60-03
T1C 160		Sequence II	415V 20 KA	IEC 60947-2	LBRP 5210
T1C 160		Mechanical properties of terminals		IEC 60947-1	LBRP 5352
T1 - T2 - T3	TM	Icu a 500 V		CNS 2931	LBRP 5260
T3C	TM	Sequence III	415V 25 KA	IEC 60947-2	LOVAG IT 02.045
T4 - T5	EL	Icu a 415 V		CNS 2931	LBRP 5423
T5V 400		Annex H	415-690 V It 5,76 KA	IEC 60947-2	LOVAG IT 04.017
T4V 250		Climatic Test		IEC 60947-2	LOVAG A 04.017
T5V 630		Climatic Test		IEC 60947-2	LOVAG A 04.018
T5V 630		Annex H	690 V - It 7,56 KA	IEC 60947-2	LOVAG IT 04.121
Relè	PR 222 MP	Sgancio della SA per	100 A		LBR52030

ABB SACE S.p.a.

Summary table of base certification  
Tmax

RL0038

Page 3 of 5



*[Handwritten signatures and notes]*  
 OPIPIHAAA  
 149

Ci riserviamo tutti i diritti connessi con il presente documento e con l'oggetto o la materia ivi rappresentati con divieto di riprodurlo, utilizzarlo o renderlo accessibile a terzi in assenza di previa autorizzazione.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.

		intervento di L o R			
T2H 160		Shock Test	22 g 11 ms	IEC 60068-2-27	LBRP 6314-00
T4 250	PR 222 MP	EMC	690 V	EN 60947-2:2003	80SD00653/1
T4 250	PR 222 MP	EMC	690 V	RINA Rules:2002	80SD00653/2
T4 250	PR 221 DS	EMC	690 V	EN 60947-2:2003	80SE00624
T4 250	PR 222 DS/PD	EMC	690 V	RINA Rules:2002	80SE00625
T4 160	PR223 EF/DS	EMC	415 V	IEC 60947-1/2	TR 21364
T4 160	PR223 EF/DS	EMC	415 V	IEC 60533 - DNV 2.4	TR 21369
T5 250	PR223 EF/DS	EMC	690 V	IEC 60947-2	TR 80SE00622/1
T5 250	PR223 EF/DS	EMC	690 V	RINA Rules: 2002	TR 80SE00622/2
T4 250		Shock	22 g 11 ms	IEC 60068-2-27	LBRP 6315-00
T5 400		Shock	22 g 11 ms	IEC 60068-2-27	LBRP 6316-00

## Coordination

CB type	Trip	Type test	Rated	Standard	Certificate number
T2S160	MA 20	Type '2' co-ordination with A30 & TA25DU19	415V 50KA	IEC 60947-4-1	LOVAG 01.106
T2S160	MA 32	Type '2' co-ordination with A30 & TA42DU25	415V 50KA	IEC 60947-4-1	LOVAG 01.107
T2H160	MA 52	Type '2' co-ordination with A50 & TA75DU42	440V 50KA	IEC 60947-4-1	LOVAG 01.112
T2H160	MA 80	Type '2' co-ordination with A63 & TA75DU63	440V 50KA	IEC 60947-4-1	LOVAG 01.113
T2L160	MA 20	Type '2' co-ordination with A30 & TA25DU19	500V 50KA	IEC 60947-4-1	LOVAG 02.026
T2L160	MA 52	Type '2' co-ordination with A50 & TA75DU32	500V 50KA	IEC 60947-4-1	LOVAG 02.027
T2L160	MA 80	Type '2' co-ordination with A75 & TA75DU63	500V 50KA	IEC 60947-4-1	LOVAG 02.028
T3S250	MA 160	Type '2' co-ordination with A110 & TA110DU110	400V 50KA	IEC 60947-4-1	LOVAG 02.042
T3C	TM	Sequence III	415V 25KA	IEC 60947-2	LOVAG 02.045
T2S160	MA 52	Type '2' co-ordination with A50 & TA75DU42	415V 50KA	IEC 60947-4-1	LOVAG 01.108
T2S160	MA 80	Type '2' co-ordination with A63 & TA75DU80	415V 50KA	IEC 60947-4-1	LOVAG 01.109
T2H160	MA 32	Type '2' co-ordination with A30 & TA42DU25	440V 50KA	IEC 60947-4-1	LOVAG 01.111
T2L160	MA 52	Type '2' co-ordination with A50 & TA75DU42	415V 80KA	IEC 60947-4-1	LOVAG 03.021
T2L160	MA 80	Type '2' co-ordination with A63 & TA75DU80	415V 80KA	IEC 60947-4-1	LOVAG 03.022
T2L160	MA 100	Type '2' co-ordination with A95 & TA110DU110	415V 80KA	IEC 60947-4-1	LOVAG 03.023

Ci riserviamo tutti i diritti connessi con il presente documento e con l'oggetto o la materia ivi rappresentati con divieto di riprodurlo, utilizzarlo o renderlo accessibile a terzi in assenza di previa autorizzazione.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.

### Special test at 1000 V

CB type	Trip	Type test	Rated	Standard	Certificate number

### Special test at 400 Hz

CB type	Trip	Type test	Rated	Standard	Certificate number

*Cu*

*L* *ly*



DATA  
OPERA

*Handwritten signatures and initials*

Триваючість ТС 5



L'ENTE ITALIANO DI ACCREDITAMENTO

Member degli Accordi di Mutual Recognition EA, IAF e IAC  
Signatory of EA, IAF and IAC Mutual Recognition Agreements



License Number 024

# CERTIFICATO DI ACCREDITAMENTO

## Accreditation Certificate

Registrazione n° **070B** Rev. **08**  
Registration n°

Si dichiara che **ACAE**  
We declare that

Via Tito Livio, 5 24123 - BERGAMO (BG) - Italia

è conforme al requisiti della norma **UNI CEI EN 45011 Ed. 1999**

meets the requirements of the standard **EN 45011 Ed. 1998**

quale Organismo di **Certificazione di prodotti/servizi**  
(così come dettagliato negli Allegati al presente Certificato)

as Body for the **Certification of products/services**  
(as stated in the Enclosures to this Certificate)

Il presente Certificato non è da ritenersi valido se non accompagnato dai relativi Allegati e può essere sospeso o revocato in qualsiasi momento nel caso di inadempimento accertata da parte di ACCREDITIA. La vigenza dell'accREDITAMENTO può essere verificata sul sito WEB ([www.accredia.it](http://www.accredia.it)) o richiesta direttamente al Dipartimento di competenza.

*This Certificate is not valid without the relative Enclosures and can be suspended or withdrawn at any time in the event of non fulfillment as ascertained by ACCREDITIA. Confirmation of the validity of accreditation can be verify on website ([www.accredia.it](http://www.accredia.it)) or by contacting the relevant Department.*

MD-17-DC Rev. 00

Data di 1ª emissione  
1st issue date  
2003 -05 -21


Data di modifica  
Modification date  
2011 -11 -08

Data di scadenza  
Expiring date  
2015 -05 -20

Il Direttore di Dipartimento  
The Department Director

Il Presidente  
The President

Il Direttore Generale  
The General Director



ACCREDITIA

Sede operativa: Via Saccardo, 9 | 20134 Milano - Italy | Tel. +39 02 2100961 | Fax +39 02 21009637  
Sede legale: Piazza Mincio, 2 | 00198 Roma - Italy | Tel. +39 06 8440991 | Fax +39 06 8841199  
info@accredia.it | [www.accredia.it](http://www.accredia.it) | Partita IVA - Codice Fiscale 10566361001

ВІРНО С  
ОРИГІНАЛ

**ACCREDIA**

L'ENTE ITALIANO DI ACCREDITAMENTO

Membro degli Accordi di Muto Riconoscimento EA, IAF e ILAC  
Signatory of EA, IAF and ILAC Mutual Recognition Agreements



License Number 024

1/5

**Allegato 1 al Certificato di accreditamento n° 070B Rev. 08**  
**Enclosure 1 to the accreditation Certificate n° 070B Rev. 08**

rilasciato a / issued to: **ACAE**

**Certificazione di prodotti nei seguenti settori:**

- Apparecchiature e componenti elettrici di bassa e alta tensione  
(Vedere l'Allegato al Certificato).

**Certification of products within the following sectors:**

- Low and medium voltage electrical products  
(see Enclosure to the Certificate).

*Ca*

L'accreditamento per i settori elencati nel presente Allegato è valido fino a tutto il 2015 -05 -20  
The accreditation for the sectors listed in this Enclosure is valid until 2015 -05 -20

  
Il Direttore di Dipartimento  
The Department Director

  
Il Presidente  
The President

*CA*



Milano, 2011 -11 -08

ACCREDIA

Sede operativa: Via Saccardo, 9 | 20134 Milano - Italy | Tel. +39 02 2100961 | Fax +39 02 21009637  
Sede legale: Piazza Mincio, 2 | 00198 Roma - Italy | Tel. +39 06 8440991 | Fax +39 06 8841199  
info@accredia.it | www.accredia.it | Partita IVA - Codice Fiscale 10566361001

**ДІПЛОМ  
ОПІВНУВАА**

*Handwritten signatures and initials*

**Allegato 2 al Certificato di accreditamento n° 070B Rev. 08**  
**Enclosure 2 to the accreditation Certificate n° 070B Rev. 08**

rilasciato a / issued to: **ACAE**

Aggiornato in data: 2011 -11 -08

**LOW AND HIGH VOLTAGE PRODUCTS - LIST OF IEC - EN - CEI STANDARDS**  
**ELENCO NORME IEC - EN - CEI PER PRODOTTI DI BASSA E ALTA TENSIONE**

**TC 11 Overhead lines**

**CT 11 Impianti elettrici ad alta tensione e di distribuzione pubblica di bassa tensione.**

- 61284 Requirements and tests for fittings
- 61219 Earthing or earthing and short-circuiting equipment using lances as a short-circuiting device
- 61230 Portable equipment for earthing or earthing and short-circuiting
- 61235 Insulating hollow tubes for electrical purposes
- TC 14 Power transformers
- CT 14 Trasformatori
- 60076-1 Power transformers - Part 1: General
- 50464-1 Three phase oil immersed distribution transformers 50 Hz up to 38 kV from 50 kVA to 2500 kVA


**TC 17 Switchgear and controlgear**

**CT 17 Grossa apparecchiatura**

- 60947-1 Low voltage switchgear and controlgear - Part 1: General rules
- 60947-2 Low voltage switchgear and controlgear - Part 2: Circuit breakers
- 60947-3 Low voltage switchgear and controlgear - Part 3: Switch disconnectors, switch disconnectors and Fuse-combination units
- 60947-4-1 Low voltage switchgear and controlgear - Part 4: Contactors and motor-starters-Section 1- Electrotechnical contactors and motor-starters
- 60947-4-2 Low voltage switchgear and controlgear - Part 4: Contactors and motor-starters-Section 2- AC semiconductor motor controllers and starters
- 60947-4-3 Low voltage switchgear and controlgear - Part 4-3: AC semiconductor starters for non-motor loads
- 60947-5-1 Low voltage switchgear and controlgear - Part 5: Control circuit devices and switching elements - Section 1- Electromechanical control circuit devices
- 60947-5-2 Low voltage switchgear and controlgear - Part 5-2: Control circuit devices and switching elements - Proximity switches
- 60947-5-3 Low voltage switchgear and controlgear - Part 5-3: Control circuit devices and switching elements - Requirements for proximity devices with defined behaviour under fault conditions
- 60947-5-5 Low voltage switchgear and controlgear - Part 5-5: Control circuit devices and switching devices -Electrical emergency stop device with mechanical latching function
- 60947-6-1 Low voltage switchgear and controlgear - Part 6-1: Multiple function equipment-Section 1: Automatic transfer switching equipment
- 60947-6-2 Low voltage switchgear and controlgear - Part 6-2: Multiple function equipment-Section 2: Control and protective switching device(CPS)
- 60947-7-1 Low voltage switchgear and controlgear - Part 7-1: Ancillary equipment-Section 1:Terminal blocks or copper conductors
- 60947-7-2 Low voltage switchgear and controlgear - Part 7-2: Ancillary equipment-Section 2:Protective conductor terminal blocks for copper conductors
- 60947-7-3 Low voltage switchgear and controlgear - Part 7-3: Ancillary equipment-Section 7-3:Safety Requirements for fuse terminal blocks
- 60439-1 Low-voltage switchgear and controlgear assemblies-Part 1:Type- tested and partially type- tested assemblies
- 60439-2 Low-voltage switchgear and controlgear assemblies-Part 2:Particular requirements for busbar trunking systems (busway)
- 60439-3 Low-voltage switchgear and controlgear assemblies-Part 3:Particular requirements for low-voltage switchgear and controlgear assemblies intended to be installed in places where unskilled persons have access for their use-Distribution boards.
- 60439-4 Low-voltage switchgear and controlgear assemblies.Part 4:Particular requirements for assemblies for construction sites (ACS)

L'accreditamento per i settori elencati nel presente Allegato è valido fino a tutto il 2015 -05 -20  
 The accreditation for the sectors listed in this Enclosure is valid until 2015 -05 -20

  
 Il Direttore di Dipartimento  
 The Department Director

  
 Il Presidente  
 The President

  
 Il Direttore Generale  
 The General Director.







L'ENTE ITALIANO DI ACCREDITAMENTO

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC  
Signatory of EA, IAF and ILAC Mutual Recognition Agreements



License Number 024

# Allegato 2 al Certificato di accreditamento n° 070B Rev. 08 Enclosure 2 to the accreditation Certificate n° 070B Rev. 08

- 60439-5 Low-voltage switchgear and controlgear assemblies. Part 5: Particular requirements for assemblies intended to be installed outdoors in public places-Cabledistribution cabinets(CDCs)for power Distribution in networks.
- 62208 Empty enclosures for low-voltage switchgear and controlgear-General requirements
- 61095 Elettromeccanical contactors for household and similar purposes
- 62271-100 High-voltage alternating current circuit-breakers
- 62271-102 High-voltage alternating current disconnectors and hearing switches
- 60271-103 High-voltage switches for rated voltage above 1 kV and less than 52 kV
- 62271-104 High-voltage switches for rated voltage of 52 kV and above
- 62271-105 High-voltage alternating current switch-fuse combinations
- 62271-106 High-voltage alternating current contactors and contactor based motor-starters
- 62271-200 Metal enclosed switchgear and controlgear for rated voltages up to and including 36 kV
- 62271-202 High-voltage/low voltage prefabricated substations
- 62271-203 Gas-insulated metal enclosed switchgear for rated voltages above 52 Kv

### TC 23 Electrical accessories

#### CT 23 Apparecchiatura a bassa tensione

- 60898 Electrical accessories-Circuit-breakers for overcurrent protection for household and similar installations Part 1:Circuit-breakers for a.c. operation
- 60309-1 Plug,socket-outlets and couplers for industrial purposes - Part 1: General requirements
- 60309-2 Plug,socket-outlets and couplers for industrial purposes - Part 2: Dimensional interchangeability requirements for top pin in contact-tube accessories.
- 60309-3 Plug,socket-outlets and couplers for industrial purposes - Part 3: Particular requirements for plug, socket-outlets,connectors and appliance inlets for use in explosive gas atmospheres
- 61008-1 Residual current operated circuit-breakers without integral overcurrent protection for household and similar use (RCCB's) - Part 1: General rules
- 61008-2-1 Residual current operated circuit-brakers without Integral overcurrent protection for household similar use (RCCB's) - Part 2-1: Applicability of the general rules to RCCB's functionally independent of line voltage
- 61008-2-2 Residual current operated circuit-breakers without integral overcurrent protection for household and similar use (RCCB's) - Part 2-2:Applicability of the general rules to RCCB's functionall dependent of line voltage
- 61009-1 Residual current operated circuit-breakers with integral overcurrent protection for household and similar use (RCBO's) - Part 1: General rules
- 61009-2-1 Residual current operated circuit-breakers with integral overcurrent protection for household and similar use (RCBO's) - Part 2-1: Applicability of general rules to RCBO's functionally independent of line voltage
- 61009-2-2 Residual current operated circuit-brakers with integral overcurrent protection for household and similar use (RCBO's) - Part 2-2: Applicability of general rules to RCBO's functionally dependent of line voltage
- 62019 Electrical accessories circuit-breakers and similar equipment for household use - Auxiliary contact units
- 50085-1 Cable trunking systems and cable ducting systems for electrical installation: General requirements
- 50086-1 Conduit systems for cable management - Part 1:General requirements
- 50086-2-1 Conduit systems for cable management - Part 2-1: Particular requirements for rigid conduits systems
- 50086-2-2 Conduit systems for cable management - Part 2-2: Particular requirements for pliable conduits systems
- 50086-2-3 Conduit systems for cable management - Part 2-3: Particular requirements for flexible conduitv systems
- 50086-2-4 Conduit systems for cable management - Part 2-4: Particular requirements for conduit systems buried underground
- 60669-1 Switches for household and similar fixed-electrical installations - Part 1: General requirements
- 60669-2-1 Switches for household and similar fixed-electrical installations - Part 2: Electronic switches
- 60755 General requirements for residual current operated protective devices

### TC 32 Fuses


#### CT 32 Fusibili

- 60282-1 High-voltage fuses-Part 1: Current- limiting fuses
- 60282-2 High-voltage fuses-Part 2: Expulsion fuses
- 60269-1 Low-voltage fuses - Part 1: General requirements
- 60269-2 Low-voltage fuses - Part 2: Supplementary requirements for fuses for use by authorized persons

L'accreditamento per i settori elencati nel presente Allegato è valido fino a tutto il 2015 -05 -20  
The accreditation for the sectors listed in this Enclosure is valid until 2015 -05 -20

Il Direttore di Dipartimento  
The Department Director

Il Presidente  
The President



**Allegato 2 al Certificato di accreditamento n° 070B Rev. 08**  
**Enclosure 2 to the accreditation Certificate n° 070B Rev. 08**

- 60269-3 Low-voltage fuses - Part 3: Supplementary requirements for fuses for use by unskilled persons
- 60269-4 Low-voltage fuses - Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices
- 60644 Specification for high-voltage fuse-links for motor circuit applications

**TC 33 Power capacitor**

**CT 33 Condensatori**

- 60358 Coupling capacitors and capacitor dividers

**TC 36 Insulator**

**CT 36 Isolatori**

- 50180 Bushings above 1kV up to 36kV and from 250A up to 3150A for liquid filled transformer
- 50181 Bushings above 1kV up to 36kV and from 250A to 1250A for equipment other than liquid filled transformers
- 50243 Outdoor bushings for 24kV and 36kV, 5kA and 8kA for liquid filled transformers
- 50386 Bushings up to 1 kV and from 250A up to 5000A for liquid filled transformers
- 50387 Busbar bushings up to 1kV and from 1,25kA to 5kA for liquid filled transformers
- 60137 Insulated bushings for alternating voltages above 1kV
- 60168 Tests on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltage greater than 1000 V
- 273 Characteristics of indoor and outdoor post insulators for systems with nominal voltages greater than 1000 V

**TC 37 Surge arresters**

**CT 37 Scaricatori**

- 60099-4 Metal oxide surge arresters without gaps for a.c. systems

**TC 38 Instruments transformers**

**CT 38 Trasformatori di misura**

- 60044-1 Instruments transformers - Part 1: Current transformers
- 60044-2 Instruments transformers - Part 2: Inductive voltage transformers
- 60044-3 Instruments transformers - Part 3: Combined transformers
- 60044-5 Instruments transformers - Part 5: Capacitor voltage transformers
- 60044-6 Instruments transformers - Part 6: Requirements for protective current transformers for transient performance
- 60044-7 Instruments transformers - Part 7: Electronic voltage transformers
- 60044-8 Instruments transformers - Part 8: Electronic current transformers

*Handwritten signature*

**TC 65 Industrial-process measurement and control**

**CT 65 Controllo e misura dei processi industriali**

- 61131-1 Programmable controllers - Part 1: General informations
- 61131-2 Programmable controllers - Part 2: Equipment requirements and tests

**TC 70 Degree of protection by enclosures**

**CT 70 Involucri di protezione**

- 60529 Degree of protection provided by enclosures (IP Code)

**TC 78 Live working**

**CT 78 Lavori elettrici sotto tensione**

- 60832-1 Insulating sticks and attachable devices - Part 1: Insulating sticks
- 60832-2 Insulating sticks and attachable devices - Part 2: Attachable devices
- 60855 Insulating foam-filled tubes and solid rods - Part 1: Tubes and rods of a circular cross-section
- 60984 Sleeves of insulating material for live working
- 61111 Electrical insulating matting
- 61219 Earthing or earthing and short-circuit equipment using lances as a short-circuiting device Lance earthing
- 61230 Portable equipment for earthing or earthing and short-circuiting

L'accreditamento per i settori elencati nel presente Allegato è valido fino a tutto il 2015 -05 -20  
The accreditation for the sectors listed in this Enclosure is valid until 2015 -05 -20


*Handwritten signature*

Il Direttore di Dipartimento  
The Department Director

*Handwritten signature*

Il Presidente  
The President

*Handwritten signature*



Il Direttore Generale  
The General Director

*Handwritten signature*





L'ENTE ITALIANO DI ACCREDITAMENTO

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC  
Signatory of EA, IAF and ILAC Mutual Recognition Agreements



License Number 024

**Allegato 2 al Certificato di accreditamento n° 070B Rev. 08**  
**Enclosure 2 to the accreditation Certificate n° 070B Rev. 08**

- 61235 Insulating hollow tubes for electrical purposes
- 61243-1 Voltage detectors – Part 1: Capacitive type to be used for voltages exceeding
- 61243-5 Voltage detectors – Part 5: Voltage detecting systems (VDS)

**TC 95 Measuring relays and protection equipment**

**CT 95 Relè di misura e dispositivi di protezione**

- 60255-6 Electrical relays – Part6: Measuring relays and protection equipment

**TC 96 Small transformers, reactors and power supply units and special transformers, reactors and power supply units: safety requirements**

**CT 96 Trasformatori di sicurezza ed isolamento**

- 61558-1 Safety of power transformers, power supply units and similar – Part 1: General requirements and tests

**TC 104 Environmental condition, classification and methods of test**

**CT 104 Condizioni ambientali. Classificazioni e metodi di prova**

- 60068-2-6 Environmental testing – Part 2: Test FC Vibration (sinusoidal)

Ch

L'accreditamento per i settori elencati nel presente Allegato è valido fino a tutto il 2015 -05 -20  
The accreditation for the sectors listed in this Enclosure is valid until 2015 -05 -20

  
Il Direttore di Dipartimento  
The Department Director


  
Il Presidente  
The President

Ch

  
Il Direttore Generale  
The General Director



ВАРНО С  
ОПУТУНААА





# WE THE IDEA OF PROOVEN AND CERTIFIED QUALITY

## THE VISION

LOVAG is the European Compliance Scheme providing global access to the largest worldwide markets for Low Voltage Industrial products.

Our Agreement stands for certified quality:

- minimisation of risk
- shaping of the future
- assumption of responsibility and
- enthusiasm for joint tasks.

## THE LOVAG MEMBERS

Today, 7 Certification Bodies are LOVAG Members.

[Read more](#)

## THE MISSION

We provide to our customer the most credible global compliance mark for Low Voltage Industrial products

- Based on strict application of international standards
- Based on factory audits and market surveillance actions
- Embedding the European values: Quality, Safety, Performance, Ethic, Know How, Seniority
- Without compromise on integrity, quality and honesty of our services

We provide to our customer the largest certification body and laboratories network in Europe. We provide to our customers and to our members, a network of highest expertise. Participating to the standardization and certification bodies by providing high-level added value. Contributing to peace-of-mind of our customers by guaranteeing compliance of products.

[▲ Top](#)



LOVAG Mark:  
ONE SIGN -  
WORLDWIDE

for Low Voltage Industrial  
Products

"We carry the idea of European certified quality -  
worldwide." Marie-Elisabeth d'Ornano, Chairman, LOVAG


- ▶ [Contact](#)
- ▶ [PR-News](#)
- ▶ [Imprint/Copyright/Legal](#)

ВЕРНО С  
ОРИГИНАЛА

# Nat. Accreditation + Peer Assessment

## ACCREDITATION & PEER ASSESSMENTS OF LOVAG CERTIFICATION BODIES

According to EN 45011 (ISO/IEC Guide 65)  
GUARANTY OF IMPARTIALITY AND INTEGRITY



ВЯРНО С  
ОРИГИНАЛ

159

LOVAG Certification Bodies	ACAE	ALPHA (*)	ALPHA at VDE	ASEFA	APPLUS+ Laboratories	IMQ	Intertek Semko AB	SGS CEBEC
	Accreditation Body	Reg. Code	DAKS	COFRAG	***)	No. 005B Rev.15	SWEDAC No. 1003	BEBCERT № 041 PR
LOVAG Peers Assessments after 1999 **)	SGS CEBEC	IT SEMKO		ALPHA			ALPHA	CESI
	FIMKO	ACAE		FIMKO			ASEFA	KEMA
	Year	1999		2002			2003	2000
	Assessors	SGS CEBEC	ACAE	IT SEMKO	ACAE		ALPHA	IT SEMKO
	Year	2005	2003	2006	2006		2007	2004
	Assessors	ALPHA	CEBEC	ALPHA	ALPHA		APPLUS+	IT SEMKO
	Year	2009	2007	2010	2008		2011	2009
	Assessors	IT SEMKO	ASEFA	ASEFA	ALPHA at VDE	SGS CEBEC	ALPHA at VDE	ASEFA
	Year	2013		2011	2014	2012	2012	2013
	OTHER RECOGNITIONS	Ministry of Industry G.U. 258 94A6997		NCB for CB- & CCA- Scheme			NCB for CB- & CCA- Scheme	NCB for CB- & CCA- Scheme

\*) ALPHA was taken over by ALPHA at VDE in January 2011

\*\*) LOVAG Peers Assessments have to be performed periodically every 4 years

\*\*\*) Qualification according to EN 45011 checked and approved by LOVAG Management Committee

Приложение ТС 7  
към Технически спецификации  
за обособена позиция 1  
от процедура PPD 15-033

**Инструкции за транспортиране и складиране  
въвеждане в експлоатация и поддържане**

**на триполюсни автоматични прекъсвачи НН с лят корпус, ABB SACE, серия Tmax**

Триполюсните автоматични прекъсвачи НН с лят корпус се монтират в разпределителни табла в трансформаторните постове и се използват за защита на електропроводните линии.

Триполюсните автоматични прекъсвачи НН с лят корпус представляват механични комутационни апарати от фиксиран тип с предно свързване на шинната система.

Автоматичните прекъсвачи са способни да провеждат и да включват/изключват ръчно електрически токове във вериги при нормални условия и да включват, да провеждат за определено време и да изключват автоматично посредством електромеханична защита от термомагнитен тип токове във вериги при условията на претоварване и късо съединение.

## 2. Транспорт

Електрооборудването/ електроматериалите се транспортират в оригиналната транспортна опаковка на производителя, в която стандартно се доставя.

Препоръчва се избягването на натоварване и слагане на тежки предмети/товари върху опаковките на оборудването. Така се гарантира предпазване от счупване или деформация при съхранение и транспорт.

## 3. Съхранение

Доставяното електротехническо оборудване се съхранява в сухи и затворени складови помещения предоставящи нормални условия за съхраняване на стандартно електрооборудване и електротехническа продукция.

Оборудването да се предпазва от влага и течаща вода.

## 4. Монтаж

Монтажът се извършва само от компетентен и упълномощен за работа с електротехническа продукция персонал, съгласно пълните инструкции за монтаж приложени към всяко изделие, където са посочени и стойностите на въртящия момент за затягане на резбовите съединения.

## 5. Обслужване и поддържане

Производителя на електрооборудването не предвижда специализирани дейности по обслужването и поддръжката на апаратурата.

07.08.2015 г.



Кандидат: ИНТЕРКОМПЛЕКС ООД

Ехиязар Узунян - управител



160

# SACE Tmax XT


Istruzioni di installazione XT1  
Installation instructions XT1  
Installationsanleitung XT1  
Instructions pour l'installation XT1  
Instrucciones de instalación XT1

A


XT1/III-IV



OFF



ON



TRIPPED


*cu*

B

XT1/III-IV

C

XT1/III-IV



1,1 Nm


Usare cavi o barre isolate/ o eseguire prove di tipo specifiche sull' installazione.

Use cable or insulated busbars/ or perform specific type test on the installation.

Kabel oder isolierte Sammelschienen verwenden / oder die spezifische Typprüfung auf der Installation durchführen.

Utiliser un câble ou des barres isolées/ ou réaliser un test de type spécifique sur installation.

Utilizar un cable o barras aisladas / o efectuar una prueba de tipo específico sobre instalación.



*cu* *MB*


Power and productivity  
for a better world™



*161*


D

XT1/III-IV



E

XT1-F/III-IV/F




*Handwritten signatures and marks:*

- Large handwritten signature in the center.
- Handwritten initials "es" at the bottom right.
- Handwritten number "162" at the bottom right.


F

XT1-F/III-IV/EF




G

XT1-F/III-IV/Fe CuAl



H

XT1-F/III-IV/FC Cu





*Handwritten signatures and initials.*

*Handwritten marks and numbers.*










*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*


*[Handwritten signature]*



Handwritten signatures and a date stamp: *[Signature]* *[Signature]* *[Signature]* 01/166


P

XT1-P/III-IV/Fc Cu/MC




Q

XT1-P/III-IV/Fc-CuAl



R

XT1-P/III-IV/Fc-CuAl EXT




*[Handwritten signatures and marks]*

SACE Tmax | ABB

*[Handwritten signature]*

168




		FC Cu		FC CuAl		Mc		FC CuAl Ext	
		MAX	MIN	MAX	MIN	MAX	MIN	MAX	MIN
Stranded		70 mm <sup>2</sup>	2,5 mm <sup>2</sup>	50 mm <sup>2</sup>	1,5 mm <sup>2</sup>	35 mm <sup>2</sup>	2,5 mm <sup>2</sup>	95 mm <sup>2</sup>	35 mm <sup>2</sup>
Flexible		50 mm <sup>2</sup>	2,5 mm <sup>2</sup>	50 mm <sup>2</sup>	1,5 mm <sup>2</sup>	25 mm <sup>2</sup>	2,5 mm <sup>2</sup>	<del>XXXX</del>	

*[Handwritten signatures and marks]*

1168


T

XT1/III-IV/F-P




XT1 WITH FLANGE CON MOSTRINA		A			B	C	D	E
		F	P					
			50mm	70mm				
III	74	124	144	55	81	21	40,5	
IV	74	124	144	55	106	21	40,5	
OPTIONAL FLANGE III-IV	79	129	149	73	57	30	28,5	

XT1 WITHOUT FLANGE SENZA MOSTRINA		A			B	C	D	E
		F	P					
			50mm	70mm				
III-IV	79	129	149	43	47	15	23,5	
III	71	121	141	47	73	17	36,5	
IV	71	121	141	47	98	17	36,5	



U

TMD



E' obbligatorio mettere l'interruttore in posizione Trip test prima di regolare il termomagnetico.

It is compulsory to turn the circuit breaker to Trip test mode before adjusting the thermomagnetic release.

Der Leistungsschalter muss vor Einstellung des thermomagnetischen Auslösers zwingend in die Prüfstellung geschaltet werden.

Il est obligatoire de mettre le disjoncteur en position de Test de Déclenchement avant de régler le déclencheur magnétothermique.

Es obligatorio situar el interruptor en posición "Test de Disparo" antes de realizar el ajuste del relé termomagnético.

In	I1		
	MIN (0,7)	MED (0,85)	MAX (1xIn)
16	11,2	13,6	16
20	14	17,7	20
25	17,5	21,3	25
32	22,4	27,2	32
40	28	34	40
50	35	42,5	50
63	44,1	53,6	63
80	56	68	80
100	70	85	100
125	87,5	106,3	125
160	112	136	160

For more information please contact:

ABB S.p.A.  
 ABB SACE Division  
 Via Baioni, 35  
 24123 Bergamo - Italy  
 Phone: +39 035 395 111  
 Fax: +39 035 395 306 - 433

www.abb.com


Power and productivity  
 for a better world™



169


# SACE Tmax XT

Istruzioni di Installazione XT3  
Installation Instructions XT3  
Installationsanleitung XT3  
Instructions pour l'installation XT3  
Instrucciones de instalación XT3



A

XT3/III-IV




B

XT3/III-IV

C

XT3/III-IV




Usare cavi o barre isolate/ o eseguire prove di tipo specifiche sull' installazione.

Use cable or insulated busbars/ or perform specific type test on the installation.

Kabel oder isolierte Sammelschienen verwenden / oder die spezifische Typprüfung auf der Installation durchführen.

Utiliser un câble ou des barres isolées/ ou réaliser un test de type spécifique sur installation.

Utilizar un cable o barras aisladas / o efectuar una prueba de tipo específico sobre instalación.




Power and productivity  
for a better world™

**ABB**


D

XT3/III-IV



E

XT3-F/III-IV/F




*Handwritten signatures and scribbles.*

177


F

XT3-F/III-IV/EF-ES




G

XT3-F/III-IV/Fc Cu Al 90-185mm<sup>2</sup>/2x150mm<sup>2</sup>



H

XT3-F/III-IV/Fc Cu-MC



*[Handwritten signatures and initials]*

SACE Tmax | ABB


182






L

XT3-P/III-IV/Fc-Cu Al 90-185mm<sup>2</sup>




M

XT3-P/III-IV/Fc-Cu MC



N


XT3-P/III-IV/Fc-Cu Al 2x150mm<sup>2</sup> EXT



*Handwritten signatures and initials:*  
 [Signature]  
 [Signature]  
 [Signature]  
 [Signature]

O


XT3-P/III-IV/EF



*Handwritten signature*

P

XT3-P/III-IV/HR-VR




*Handwritten signature*

*Handwritten signature*

*Handwritten signature*  
171



Q

XT3-P/III-IV/Fc Cu Al 30-150mm<sup>2</sup>




R

XT3/III-IV



	FC Cu		MC		90-185mm <sup>2</sup>		FC CuAl		EXT 2X150mm <sup>2</sup>	
	MAX	MIN	MAX	MIN	MAX	MIN	MAX	MIN	MAX	MIN
Stranded	185 mm <sup>2</sup>	6 mm <sup>2</sup>	35 mm <sup>2</sup>	2,5 mm <sup>2</sup>	185 mm <sup>2</sup>	90 mm <sup>2</sup>	150 mm <sup>2</sup>	30 mm <sup>2</sup>	160 mm <sup>2</sup>	35 mm <sup>2</sup>
Flexible	150 mm <sup>2</sup>	6 mm <sup>2</sup>	25 mm <sup>2</sup>	2,5 mm <sup>2</sup>	X	X	X	X	X	X

*[Handwritten signatures and marks]*







TMD/TMG

In	I1		
	MIN (0,7)	MED (0,85)	MAX (1xIn)
63	44,1	53,5	63
80	58	68	80
100	70	85	100
125	87,5	106,2	125
160	112	136	160
200	140	170	200
250	175	212,5	250

MA

In	I1		
	MIN (Inx6)	MED (Inx9)	MAX (Inx12)
100	600	900	1200
125	750	1125	1500
160	960	1440	1920
200	1200	1800	2400

T



XT3 WITH FLANGE CON MOSTRINA		F	A		B	C	D	E
			P					
			50mm	70mm				
III	74	124	144	55	110	17,5	55	
IV	74	124	144	55	145	17,5	55	
OPTIONAL FLANGE III-IV	79	129	149	73	57	26,5	28,5	

XT3 WITHOUT FLANGE SENZA MOSTRINA		F	A		B	C	D	E
			P					
			50mm	70mm				
III-IV	79	129	149	43	47	11,5	23,5	
III	71	121	141	47	102	13,5	51	
IV	71	121	141	47	137	13,5	51	

For more information please contact:

ABB S.p.A.  
 ABB SACE Division  
 Via Baioni, 35  
 24123 Bergamo - Italy  
 Phone: +39 035 395 111  
 Fax: +39 035 395 306 - 433  
 www.abb.com

Power and productivity  
 for a better world™







*Handwritten signatures and initials, including 'C4' and 'FAR'.*

# Tmax T5


DOC. N.° 1SDH000437R0001

L2233




Usare cavi o barre isolate/ o eseguire prove di tipo specifiche sull' installazione.  
 Use cable or insulated busbars/ or perform specific type test on the installation.  
 Kabel oder isolierte Sammelschienen verwenden / oder die spezifische Typrprüfung auf der  
 Installation durchführen.  
 Utiliser un câble ou des barres isolées/ ou réaliser un test de type spécifique sur installation.  
 Utilizar un cable o barras aisladas / o efectuar una prueba de tipo específico sobre instalación.

1




Ue	A	B	C	D	E
< 440 V	30	25	0	25	0
≥ 440 V < 500 V	60	45	0	25	0
≥ 500 V < 690 V	60	45	40	25	0
750 V	160	160	50	50	0



*Handwritten signatures and the ABB logo.*


4

F - F




5

F - FC Cu



6

F - EF








*Handwritten signature*

**ABB**

*Handwritten signature*

17C




  
**ABB**  
  
 180




10

F - R




11

P - EF 400A



12

P - HR 400A




*Handwritten signatures and marks:*

**ABB**

187


13

P - VR 400A




14

P - FC 400A



15

P - HR 630A



**ABB**


*Handwritten signature*

*Handwritten signature*

182


16

P - VR 630A




17

P - EF 630A



18

P - ES 630A



*Handwritten signature*

**ABB**


*Handwritten signature*










28



29



	A	A	B	C	D
WITH FLANGE CON MOSTRINA	107	157	115	115	64,5
WITHOUT FLANGE SENZA MOSTRINA	107	157	107	107	60,5





*Handwritten signatures and initials*

**ABB**

188

30

TMA





In	I3		
	MIN (Inx5)	MED (Inx7,5)	MAX (Inx10)
630	3150	4725	6300
500	2500	3750	5000
400	2000	3000	4000
320	1600	2400	3200

In	I1		
	MIN (0,7)	MED (0,85)	MAX (1xIn)
630	441	536	630
500	350	425	500
400	280	340	400
320	224	272	320


31

PR221DS







Esempio:  
Example:

In=400A  
I<sub>2</sub> = 400 x (1,5+2) = 1400A  
t<sub>2</sub> = 0,1 s @ 3200 A (8In)



Esempio:  
Example:

In = 400 A  
I<sub>1</sub> = 400 x (0,4+0,08+0,32) = 320A  
t<sub>1</sub> = 12 s @ 1920 A (6I<sub>1</sub>)



Esempio:  
Example:

In=400 A  
I<sub>3</sub> = 400 x (1,5+2) = 1400A

Esempio:  
Example:  
Ne=ON ; 50%

I<sub>2</sub>=OFF



ABB SACE S.p.a.  
Via Baioni, 35  
24123 Bergamo Italy  
Tel. +39 035 395.111 - Telefax +39 035 395.306-433

http://www.abb.com


*Handwritten signatures and initials.*



# Tmax T6 1000A


DOC. N.° 1SDH000511R0003

L3756





1


U <sub>0</sub>	A (T6N, T6S, T6H)	A (T6L)
< 440 V	35	100
440 V	100	100
690 V	100	100



2




3






Usare cavi o barre isolate/ o eseguire prove di tipo specifiche sull' installazione.  
 Use cable or insulated busbars/ or perform specific type test on the installation.  
 Kabel oder isolierte Sammelschienen verwenden / oder die spezifische Typprüfung auf der Installation durchführen.  
 Utiliser un câble ou des barres isolées/ ou réaliser un test de type spécifique sur installation.  
 Utilizar un cable o barras aisladas / o efectuar una prueba de tipo específico sobre instalación.

4






**ABB**



**ABB**

*Handwritten signatures and marks, including a large 'A' and a signature.*




Non valido per interruttore fisso con RHD-FLD-MOE. Vedere documentazione specifica.  
 Not valid for fixed circuit breakers with RHD-FLD-MOE. See specific documentation.  
 Gilt nicht für festen Leistungsschalter mit RHD-FLD-MOE. Siehe die spezifische Dokumentation.  
 Non valable pour disjoncteur fixe avec RHD-FLD-MOE. Voir la documentation spécifique.  
 No válido para interruptor fijo con RHD-FLD-MOE. Véase documentación específica.





11

TRIP TEST




12



PR221DS



Esempio:  
Example:  
 $I_n = 1000A$   
 $I_2 = 1000 \times (1,5+2) = 3500A$   
 $t_2 = 0,1 s @ 8000 A (8I_n)$



Esempio:  
Example:  
 $I_n = 1000 A$   
 $I_3 = 1000 \times (1,5+2) = 3500A$



Esempio:  
Example:  
 $I_n = 1000 A$   
 $I_1 = 1000 \times (0,4+0,08+0,32) = 800A$   
 $t_1 = 12 s @ 4800 A (6I_1)$

2

Esempio:  
Example:  
Ne=ON ; 50%



ABB S.p.a.  
ABB SACE Division  
Via Baioni, 35  
24123 Bergamo Italy  
Tel. +39 035 395.111 - Telefax +39 035 395.306-433



http://www.abb.com

192

# Tmax T7-T7M

DOC. N.° 1SDH000606R0001



L3194



1+5


Installation directions

1




U <sub>e</sub>	A
< 440 V	50
≥ 440 V ≤ 690 V	100

2









3








Usare cavi o barre isolate/o eseguire prove di tipo specifiche sull' installazione.  
 Use cable or insulated busbars/or perform specific type test on the installation.  
 Kabel oder isolierte Sammelschienen verwenden /oder die spezifische Typprüfung auf der  
 Installation durchführen.  
 Utiliser un câble ou des barres isolées/ou réaliser un test de type spécifique sur installation.  
 Utilizar un cable o barras aisladas /o efectuar una prueba de tipo específico sobre instalación

**ABB**

4




5




6:9

Operating sequences and resetting due to tripping of release

6



7



Trip test  
 Trip test  
 Auslöseprüfung  
 Test de déclenchement  
 Test de disparo

T7  
 PR231  
 PR232









8

		SEQUENZA DI MANOVRA OPERATING SEQUENCE SCHALTSEQUENZ SÉQUENCE DE MANŒUVRES SECUENCIA DE MANIOBRA	T7M
BIANCO WHITE WEISS BLANC BLANCO		APERTO OPEN AUS-STELLUNG OUVERT ABIERTO	
			Carica molle Spring loading Federn spannen Réarmement ressorts Carga resortes
GIALLO YELLOW GELB JAUNE AMARILLO			Molle cariche Springs loaded Federn gespannt Ressorts armés Resortes cargados
		CHIUSURA CLOSING EINSCHALTEN FERMETURE CIERRE	Chiusura interruttore Circuit breaker closing Leistungsschalter einschalten Fermeture disjoncteur Cierre interruptor
BIANCO WHITE WEISS BLANC BLANCO		CHIUSO CLOSED ENGESCHALTET FERMÉ CERRADO	Interruttore chiuso, molle scariche Circuit breaker closed, springs unloaded Leistungsschalter geschlossen, Federn entspannt Disjoncteur fermé, ressorts désarmés Interruptor cerrado, resortes descargados
APERTURA OPENING AUSSCHALTEN OUVERTURE APERTURA			Apertura interruttore Circuit breaker opening Ausschaltung Leistungsschalter Ouverture disjoncteur Apertura interruptor
		APERTO OPEN AUS-STELLUNG OUVERT ABIERTO	Interruttore aperto, molle scariche Circuit breaker open, springs unloaded Leistungsschalter ausgeschaltet, Federn entspannt Disjoncteur ouvert, ressorts désarmés Interruptor abierto, resortes descargados

*Cel*

*[Handwritten signatures]*




9	BIANCO WHITE WEISS BANC BLANC		APERTO OPEN AUS-STELLUNG OUVERT ABIERTO	RIPRISTINO PER INTERVENTO SGANCIATORE RESETTING DUE TO TRIPPING OF RELEASE RÜCKSETZUNG WEGEN AUSLÖSUNG DES AUSLÖSERS RÉTABLISSEMENT APRÈS DÉCLENCHEMENT DU DÉCLENCHEUR RESTABLECIMIENTO POR ACTUACIÓN DEL RELÉ	<b>T7M</b>
			Carica molle Spring loading Federn spannen Réarmement ressorts Carga resortes		
			Molle cariche Springs loaded Federn gespannt Ressorts armés Resortes cargados		
			CHIUSURA CLOSING EINSCHALTEN FERMETURE CIERRE		
			CHIUSO CLOSED EINGESCHALTET FERMÉ CERRADO		
			Inserire unità di test ed eseguire come in figura, premendo i pulsanti 2 e 3 in sequenza. Connect test unit and perform as shown in the figure by pressing keys 2 and 3 in sequence. Das Prüfgerät einstecken und die Prüfung wie in der Abbildung gezeigt ausführen. Hierzu nacheinander die Tasten 2 und 3 drücken. Brancher l'unité de test et agir comme indiqué sur la figure, en appuyant sur les boutons 2 et 3 en séquence. Insertar la unidad de prueba y seguir los pasos que se muestran en la figura, pulsando los botones 2 y 3 en secuencia.		
			Quando avviene lo sgancio fuoriesce come indicato l'indicazione meccanica di trip. When tripping takes place, the mechanical trip indicator comes out. Wenn die Auslösung erfolgt, tritt wie gezeigt die mechanische Auslösungsanzeige aus. Comme illustré, quand le déclenchement se produit, on a la sortie de l'indicateur mécanique. Cuando se cumple el desenganche, sale -tal y como se muestra en la indicación mecánica de disparo.		
			Per ricominciare la sequenza reinsertare manualmente l'indicatore. To restart the sequence, the indicator should be re-introduced by hand. Für den erneuten Beginn der Sequenz die Anzeige von Hand wieder hineindrücken. Pour recommencer la séquence, enfoncez de nouveau manuellement l'indicateur. Para reiniciar la secuencia, reinsertar manualmente el indicador.		




10

T7




11

T7




12

T7




13

T7 IV




14

T7IV/W




15

T7/W



16

T7/W




17-22

Disassembly sequence to install internal accessories T7M

17


T7M



*Handwritten notes and signatures:*  
 Cl  
 1997


18

T7M




19

T7M IV




20

T7MIV/W



21


T7M/W



*Handwritten signatures and initials:*  
 [Signature]  
 [Signature]  
**ABB**  
 199

22

T7/W



23+30


Connection to auxiliary circuits

23

T7

D1	C1	C13	C12	42	11	12	22	31	32
D2	C2	C3	C11	44	41	14	24	21	34

T9	T7	T6	W4	98S	W2	K15	K13	K21	K2	T3	T4
T10	T8	T5	W3	95S	W1	K14	K12	K11	K1	T2	T1




77	67	57	98						
78	68	58	95	96					

24

T7M

D1	C1	C13	C12	42	11	12	22	31	32
D2	C2	C3	C11	44	41	14	24	21	34

T9	T7	T6	W4	98S	W2	K15	K13	K21	K2	T3	T4
T10	T8	T5	W3	95S	W1	K14	K12	K11	K1	T2	T1




U1	38		98		R1	48			
U2	36	35	95	96	R2	46	45		

25

T7-T7M/W

D1	C1	C13	C12	42	11	12	22	31	32
D2	C2	C3	C11	44	41	14	24	21	34

T9	T7	T6	W4	98S	W2	K15	K13	K21	K2	T3	T4
T10	T8	T5	W3	95S	W1	K14	K12	K11	K1	T2	T1



U1	38		98		R1	48			
U2	36	35	95	96	R2	46	45		

T7M


77	67	57	98						
78	68	58	95	96					

T7


*Handwritten signatures and notes:*  
 [Signature]  
 [Signature]  
 [Signature]  
 200

26

T7-T7M




27




Esempio di cablaggio per interruttore fisso  
 Wiring example for fixed circuit breaker  
 Verdrahtungsbeispiel für festen Leistungsschalter  
 Exemple de câblage pour disjoncteur fixe  
 Ejemplo de cableado para interruptor fijo

T7-T7M



28


T7-T7M




0,6Nm

29

T7-T7M/W



Esempio di cablaggio per parte fissa  
 Wiring example for fixed part  
 Verdrahtungsbeispiel für Unterteil  
 Exemple de câblage pour partie fixe  
 Ejemplo de cableado para parte fija




*Handwritten signatures and scribbles.*


**ABB**

*Handwritten signature and date: 07/201*

30




OPZIONALE - DATI DEI CABLAGGI RIPORTABILI A CURA DEL CLIENTE  
 OPTIONAL - WIRING DATA TO BE GIVEN BY CUSTOMER  
 OPTIONAL - DIE DATEN DER VERDRAHTUNG KÖNNEN VOM KUNDEN VERMERKT WERDEN  
 OPTION - INDICATION DES DONNÉES DES CÂBLAGES À LA CHARGE DU CLIENT  
 OPCIONAL - DATOS DE LOS CABLEADOS REALIZABLES POR CUENTA DEL CLIENTE



31÷42

Connection and disconnection of withdrawable-type CBs

31




L'interruttore si può manovrare soltanto se il pulsante "PUSH BEFORE OPERATE" non è premuto, e cioè soltanto quando l'interruttore è in una di queste tre posizioni.

The circuit breaker can operate only when the "PUSH BEFORE OPERATE" button is not pressed, i.e. only when the CB is set to one of the following three positions.

Das Schalten des Leistungsschalters ist nur dann möglich, wenn die Taste "PUSH BEFORE OPERATE" nicht gedrückt ist, d.h. wenn sich der Leistungsschalter in einer dieser drei Stellungen befindet.

Le disjoncteur ne peut être manœuvré que si le bouton "PUSH BEFORE OPERATE" n'est pas enfoncé, c'est-à-dire uniquement quand le disjoncteur est dans l'une de ces trois positions.


El interruptor puede manipularse sólo si el botón "PUSH BEFORE OPERATE" no ha sido pulsado; es decir, sólo cuando el interruptor se encuentra en una de las siguientes tres posiciones.



*Handwritten signatures and notes:*  
 [Signature]  
 [Signature]  
 01 202



32

T7/W




33

T7M/W




34

Posizione di partenza (estratto)  
 Starting position (disconnected)  
 Ausgangsstellung (Trennstellung)  
 Position de départ (débroché)  
 Posición de salida (extraído)



35




*Gy*


**ABB**

*205*

36




37




38

Posizione test  
 Test position  
 Prüfstellung  
 Position de test  
 Posición de prueba




39






40


Posizione di inserito  
 Connected  
 Betriebsstellung  
 Position embroché  
 Posición de insertado



41



42



Perestrarre la parte mobile dalla parte fissa ripercorrere le operazioni descritte nelle fig. 37-41 in senso inverso. Al termine effettuare le due operazioni illustrate nella figura a lato.

To remove the moving part from fixed part, repeat the operations described in figures 37 to 41 in reverse order. When accomplished, perform the two operations shown in the figure.

Zum Herausnehmen des beweglichen Teils aus dem Unterteil die in den Abb. 37 - 41 gezeigten Vorgänge in der umgekehrten Reihenfolge ausführen. Zum Schluss die zwei in der nebenstehenden Abbildung gezeigten Vorgänge ausführen.

Pour débrocher la partie mobile de la partie fixe, refaire à l'inverse les opérations décrites sur les fig. 37 - 41. Pour finir, effectuer les deux opérations illustrées sur la figure ci-contre.


Para extraer la parte móvil de la parte fija, repetir -en sentido inverso- las operaciones que han sido descritas en las figs. 37-41. Al terminar, realizar las dos operaciones que se muestran en la figura puesta a un lado.

*CyH*  
**ABB**  
*01 20x*



45

F-ES/EF




	CON MOSTRINA WITH FLANGE	SENZA MOSTRINA WITHOUT FLANGE
A	125...141	147

Piastra isolante per T7 H/L/V.  
 Insulating plate for T7 H/L/V.  
 Isolierplatte für T7 H/L/V.  
 Plaque isolante requise pour T7 H/L/V.  
 Placa de aislamiento para T7 H/L/V.

46


F-FcCuAl  
4x240




	CON MOSTRINA WITH FLANGE	SENZA MOSTRINA WITHOUT FLANGE
A	125...141	147

*Handwritten signatures and initials:*  
 [Signature]  
 [Initials]  
**ABB**  
 207

47




48



*Handwritten signatures and notes:*  
 04  
 208


49



Plastra izolante  
Insulating plate  
Isolierplatte  
Plaque isolante  
Placa de aislamiento

	STANDARD	RONIS	PROFALUX	KIRK	CASTELL
A	290	298	306	NO	NO
B	307	311	319	318	348

50




	CON MOSTRINA WITH FLANGE	SENZA MOSTRINA WITHOUT FLANGE
A	125... 141	147

*[Handwritten signatures and initials]*

**ABB**


*[Handwritten signature]* 209

51



F-FCCuAl  
2x240

52



W-RS

	STANDARD	RONIS	PROFALUX	KIRK	CASTELL
A	307	311	319	318	348


*Handwritten signatures and notes:*  
 A signature resembling 'J. C.'  
 A signature resembling 'M. S.'  
 A signature resembling 'L. S.'  
 The number '210' written at the bottom right.





55

PR231/P






Esempio-Example-Beispiel-Exemple-Ejemplo




$I_n = 630 \text{ A}$   
 $I_1 = 630 \times 0,8 = 504 \text{ A}$   
 $t_1 = 12 \text{ s @ } 3024 \text{ A (6I}_1)$

Esempio-Example-Beispiel-Exemple-Ejemplo

$I_n N = 100\% I_n$   
 Freq. = 50 Hz



*Cu*



Esempio-Example-Beispiel-Exemple-Ejemplo

Esempio-Example-Beispiel-Exemple-Ejemplo



*Handwritten signatures and initials, including '04' and '212'.*



Prescrizioni per l'installazione	1÷5
Sequenze di manovra e ripristino per intervento sganciatore	6÷9
Sequenza di smontaggio per installazione accessori interni T7	10÷16
Sequenza di smontaggio per installazione accessori interni T7M	17÷22
Connessione ai circuiti ausiliari	23÷30
Inserzione ed estrazione degli interruttori in esecuzione estraibile	31÷42
Tabelle dimensionali	43÷54
Getting started per PR231/P	55

Installation directions	1÷5
Operating sequences and resetting due to tripping of release	6÷9
Disassembly sequence to install internal accessories T7	10÷16
Disassembly sequence to install internal accessories T7M	17÷22
Connection to auxiliary circuits	23÷30
Connection and disconnection of withdrawable-type CBs	31÷42
Dimensions table	43÷54
Getting started for PR231/P	55

Installationsvorschriften	1÷5
Schaltsequenzen und Rücksetzung wegen Auslösung des Auslösers	6÷9
Demontagesequenz für den Einbau interner Zubehöreinrichtungen T7	10÷16
Demontagesequenz für den Einbau interner Zubehöreinrichtungen T7M	17÷22
Anschluss an die Hilfsstromkreise	23÷30
Einschieben und herausfahren der Leistungsschalter in ausfahrbarer Ausführung	31÷42
Maßtabellen	43÷54
Erste Schritte für PR231/P	55

Prescriptions pour l'installation	1÷5
Séquences de manœuvre et rétablissement pour déclenchement du déclencheur	6÷9
Séquence de démontage pour installation des accessoires internes T7	10÷16
Séquence de démontage pour installation des accessoires internes T7M	17÷22
Connexion aux circuits auxiliaires	23÷30
Embrosage et débrosage des disjoncteurs en version débrosable sur chariot	31÷42
Tableaux des dimensions	43÷54
Guide de démarrage pour PR231/P	55

Disposiciones para la instalación	1÷5
Secuencias de maniobra y restablecimiento para actuación del relé	6÷9
Secuencia de desmontaje para instalación accesorios internos T7	10÷16
Secuencia de desmontaje para instalación accesorios internos T7M	17÷22
Conexión con los circuitos auxiliares	23÷30
Inserción y extracción de los interruptores en ejecución extraíble	31÷42
Tablas dimensionales	43÷54
Getting started para PR231/P	55



ABB SACE S.p.a.


Via Baloni, 35

24123 Bergamo Italy

Tel. +39 035 395.111 - Telefax +39 035 395.306-433

<http://www.abb.com>

213



Technical catalogue | January 2013

# SACE Tmax. T Generation Low voltage moulded-case circuit-breakers up to 1600 A

*Handwritten signatures and initials:*  
Cey  
C  
J  
M

# Main characteristics

**Overview of the Tmax family** 1/2

**General** 1/4

**Construction characteristics**

Modularity of the series 1/6

Distinguishing features of the series 1/8



*Handwritten signatures and initials:*  
A large stylized 'A' or 'U' at the top.  
A signature 'Ruy' on the left.  
A signature 'J' on the right.  
A signature 'MS' at the bottom right.



T2	T3	T4	T5	T6	T7
160	250	250/320	400/630	630/800/1000	800/1000/1250/1600
1.6...160	63...250	20...320	320...630	630...1000	200...1600
3/4	3/4	3/4	3/4	3/4	3/4
690	690	690	690	690	690
500	500	750	750	750	
36	36	36	36	36	
50	50	50	50	50	50
70		70	70	70	70
85		120	120	100	120
		200	200		150


T4	T5	T6	T7
250/320	400/630	630/800/1000	800/1000/1250/1600
3/4	3/4	3/4	3/4
690/1000	690/1000	690	690
■	■	■	■

T2	T3	T4	T5	T6	T7
160	250	250/320	400/630	800	800/1000/1250
3	3	3	3	3	3
690	690	690	690	690	690
■	■	■	■	■	
■		■	■	■	■

T4	T5	T6
250	400/630	630/800
3/4	3/4	3/4
20	20	12
12	12	40
40	40	40

T3D	T4D	T5D	T6D	T7D
250	250/320	400/630	630/800/1000	1000/1250/1600
200	250/320	400/630	630/800/1000	1000/1250/1600
3/4	3/4	3/4	3/4	3/4
690	690	690	690	690
500	750	750	750	750
5.3	5.3	11	30	52.2
3.6	3.6	6	15	20


The electric arc interruption system used on the Tmax circuit-breakers allows the short-circuit currents of very high value to be interrupted extremely rapidly. The considerable opening speed of the contacts, the dynamic blasting action carried out by the magnetic field and the structure of the arcing chamber contribute to extinguishing the arc in the shortest possible time, notably limiting the value of the specific let-through energy  $I^2t$  and the current peak.



*an*

*af*

*MS*



Starting from the fixed version circuit-breaker, all the other versions used for various requirements are obtained by means of mounting conversion kits.

The following are available:

- kit for converting a fixed circuit-breaker into the moving part of a plug-in and withdrawable one
- circuit-breaker fixed parts for plug-in and withdrawable circuit-breakers
- conversion kit for the connection terminals.

Various accessories are also available:

1. Breaking unit
2. Trip units
3. Front
4. Auxiliary contacts - AUX and AUX-E
5. Undervoltage release - UVR
6. Shunt opening release - SOR and P-SOR
7. Terminal covers
8. Front for lever operating mechanism - FLD
9. Direct rotary handle - RHD
10. Stored energy motor operator - MOE
11. Key lock - KLF
12. Early auxiliary contact - AUE
13. Transmitted rotary handle - RHE
14. Front terminal for copper cable - FC Cu
15. Front extended terminal - EF
16. Multi-cable terminal (only for T4) - MC
17. Front terminal for copper-aluminium - FC CuAl
18. Front extended spread terminal - ES
19. Rear orientated terminal - R
20. Conversion kit for plug-in/withdrawable versions
21. Guide of fixed part in the withdrawable version
22. Fixed part - FP
23. Auxiliary position contact - AUP
24. Phase separators
25. PR010T
26. TT1
27. Racking out crank handle
28. Residual current release.

*CM*

*27*

*[Signature]*

*[Signature]*

1SDC210015D0207

## Operating temperature


The Tmax circuit-breakers can be used in ambient conditions where the surrounding air temperature varies between -25 °C and +70 °C, and stored in ambients with temperatures between -40 °C and +70 °C.

The circuit-breakers fitted with thermomagnetic trip units have their thermal element set for a reference temperature of +40 °C. For temperatures other than +40 °C, with the same setting, there is a thermal trip threshold variation as shown in the table on page 4/50 and following.

The electronic trip units do not undergo any variations in performance as the temperature varies but, in the case of temperatures exceeding +40 °C, the maximum setting for protection against overloads L must be reduced, as indicated in the derating graph on page 4/37 and following, to take into account the heating phenomena which occur in the copper parts of the circuit-breaker passed through by the phase current.

For temperatures above +70 °C the circuit-breaker performances are not guaranteed.


To ensure service continuity of the installations, the way to keep the temperature within acceptable levels for operation of the various devices and not only of the circuit-breakers must be carefully assessed, such as using forced ventilation in the switchboards and in their installation room.




## Altitude

Up to an altitude of 2000 m the Tmax circuit-breakers do not undergo any alterations in their rated performances. As the altitude increases, the atmospheric properties are altered in terms of composition, dielectric resistance, cooling capacity and pressure. Therefore the circuit-breaker performances undergo derating, which can basically be measured by means of the variation in significant parameters such as the maximum rated operating voltage and the rated uninterrupted current.

Altitude	[m]	2000	2600	3000	3900	4000	5000
Derating on service voltage, Ue	[%]	100	93	88	79	78	68
Derating on uninterrupted current	[%]	100	99	98	94	93	90



1SDC21004070001



1SDC21004110001

### Versions and types

All the Tmax circuit breakers are available in fixed versions, T2, T3, T4 and T5 in the plug-in version and T4, T5, T6<sup>(1)</sup> and T7 also in the withdrawable one.

All the circuit breakers can be manually operated, by the operating lever or the rotary handle (direct or transmitted), and electrically operated. For this issue different solutions are available:

- The solenoid operator for T1, T2 and T3
- The stored energy motor operator for T4, T5 and T6
- T7 with the stored energy operating mechanism, gear motor for the automatic charging of the closing springs and shunt opening and closing releases.

### Installation

Tmax circuit-breakers can be installed in the switchboards, mounted in any horizontal, vertical or lying down position on the back plate or on rails, without undergoing any derating of their rated characteristics. Tmax circuit-breakers can be installed easily in all types of switchboards, above all thanks to the possibility of being supplied either by top or bottom terminals, without jeopardizing the apparatus functionality<sup>(2)</sup>.

Apart from fixing on the base plate, T1, T2 and T3 can also be installed on DIN 50022 rails, thanks to the special fixing brackets.


Furthermore, the depth of 70 mm takes Tmax T3 to the same standard as the two smaller sizes, making assembly of circuit-breakers up to 250 A in standard switchboards even simpler. In fact, it is possible to prepare standardised support structures, facilitating the design stage and construction of the switchboard metalwork.

*Handwritten signatures and scribbles*

<sup>(1)</sup> Not available on the 1000 A version.

<sup>(2)</sup> For uses at a voltage of 1000 V, T4V250 and T5V400 in the fixed version, and T4L250 and T5L400 in the plug-in version must be supplied from above.





## Compliance with Standards and company quality system

Tmax circuit-breakers and their accessories comply with the international IEC 60947-2 Standards and the EC directive:

- "Low Voltage Directives" (LVD) no. 2006/95/CE (replaces 72/23/EEC and subsequent amendments)
- Electromagnetic Compatibility Directive (EMC) no. 89/336 EEC.

Certification of compliance with the product Standards mentioned above is carried out, in accordance with the European EN 45011 Standard, by the Italian certification organisation ACAE (Association for Certification of Electrical Apparatus), member of the European organization LOVAG (Low Voltage Agreement Group) and by the Swedish certification organization SEMKO.

The Test Room at ABB SACE is accredited by SINAL (certificate No. 062). The Tmax series also has a range which has undergone certification according to the severe American UL 489 and CSA C22.2 Standards. Furthermore, the Tmax series is certified by the Russian GOST (Russia Certificate of Conformity) certification organisation. The pieces of apparatus comply with the prescriptions for on-board shipping installations and are approved by the major Naval Registers - Lloyd's Register of Shipping, Germanischer Lloyd, Bureau Veritas, Rina, Det Norske Veritas, Russian Maritime Register of Shipping, and ABS (please ask ABB SACE for confirmation about the versions available).

ABB SACE's Quality System complies with the international ISO 9001-2000 Standard (model for quality assurance in design, development, construction, installation and service assistance) and with the equivalent European EN ISO 9001 and Italian UNI EN ISO 9001 Standards.

The third certifying Organisation is RINA-QUACER. ABB SACE received the first certification in 1990 with three-year validity and this has now reached its fifth confirmation. The ABB SACE quality system complies also with IRIS International Railway Industry Standard.

The new Tmax series has a hologram on the front, obtained using special anti-imitation techniques - a guarantee of the quality and genuineness of the circuit-breaker as an ABB SACE product. Attention to protection of the environment is another priority commitment for ABB SACE, and, as confirmation of this, the environmental management system has been certified by RINA. ABB SACE - the first industry in the electromechanical sector in Italy to obtain this recognition - thanks to a revision of the production process with an eye to ecology - has been able to reduce the consumption of raw materials and waste from processing by 20%. ABB SACE's commitment to safeguarding the environment is also shown in a concrete way by Life Cycle Assessments (LCA) of the products, carried out directly by ABB SACE's Research and Development in collaboration with the ABB Research Centre. Selection of materials, processes and packing materials is made optimising the true environmental impact of the product, also foreseeing the possibility of its being recycled.

Furthermore, in 1997 ABB SACE developed its Environmental Management system and got it certified in conformity with the international ISO14001 Standard, integrating it in 1999 with the Management System for Health and Safety in the workplace according to OHSAS 18001 (Swedish National Testing and Research Institute).

ISO 14001, 18001 and SA8000 recognitions together with ISO 9001 made it possible to obtain RINA, BEST FOUR CERTIFICATION.

# Circuit-breakers for power distribution

## Electrical characteristics

		Tmax T1 1P	Tmax T1				Tmax T2		
Rated uninterrupted current	[A]	160	160				160		
Poles	[No.]	1	3/4				3/4		
Rated service voltage, U <sub>e</sub>	(AC) 50-60 Hz	240	690				690		
	(DC)	125	500				500		
Rated impulse withstand voltage, U <sub>imp</sub>	[kV]	8	8				8		
Rated insulation voltage, U <sub>i</sub>	[V]	500	800				800		
Test voltage at industrial frequency for 1 min.	[V]	3000	3000				3000		
Rated ultimate short-circuit breaking capacity, I <sub>cu</sub>		<b>B</b>	<b>B</b>	<b>C</b>	<b>N</b>	<b>N</b>	<b>S</b>	<b>H</b>	<b>L</b>
(AC) 50-60 Hz 220/230 V	[kA]	25*	25	40	50	65	85	100	120
(AC) 50-60 Hz 380/400/415 V	[kA]	-	16	25	36	36	50	70	85
(AC) 50-60 Hz 440 V	[kA]	-	10	15	22	30	45	55	75
(AC) 50-60 Hz 500 V	[kA]	-	8	10	15	25	30	36	50
(AC) 50-60 Hz 690 V	[kA]	-	3	4	6	6	7	8	10
(DC) 250 V - 2 poles in series	[kA]	25 (at 125 V)	16	25	36	36	50	70	85
(DC) 250 V - 3 poles in series	[kA]	-	20	30	40	40	55	85	100
(DC) 500 V - 2 poles in series	[kA]	-	-	-	-	-	-	-	-
(DC) 500 V - 3 poles in series	[kA]	-	16	25	36	36	50	70	85
(DC) 750 V - 3 poles in series	[kA]	-	-	-	-	-	-	-	-
Rated service short-circuit breaking capacity, I <sub>cs</sub>									
(AC) 50-60 Hz 220/230 V	[%I <sub>cu</sub> ]	75%	100%	75%	75%	100%	100%	100%	100%
(AC) 50-60 Hz 380/400/415 V	[%I <sub>cu</sub> ]	-	100%	100%	75%	100%	100%	100%	75% (70 kA)
(AC) 50-60 Hz 440 V	[%I <sub>cu</sub> ]	-	100%	75%	50%	100%	100%	100%	75%
(AC) 50-60 Hz 500 V	[%I <sub>cu</sub> ]	-	100%	75%	50%	100%	100%	100%	75%
(AC) 50-60 Hz 690 V	[%I <sub>cu</sub> ]	-	100%	75%	50%	100%	100%	100%	75%
Rated short-circuit making capacity, I <sub>cm</sub>									
(AC) 50-60 Hz 220/230 V	[kA]	52.5	52.5	84	105	143	187	220	264
(AC) 50-60 Hz 380/400/415 V	[kA]	-	32	52.5	75.6	75.6	105	154	187
(AC) 50-60 Hz 440 V	[kA]	-	17	30	46.2	63	94.5	121	165
(AC) 50-60 Hz 500 V	[kA]	-	13.6	17	30	52.5	63	75.6	105
(AC) 50-60 Hz 690 V	[kA]	-	4.3	5.9	9.2	9.2	11.9	13.6	17
Opening time (415 V)	[ms]	7	7	6	5	3	3	3	3
Utilisation category (IEC 60947-2)		A	A				A		
Reference Standard		IEC 60947-2	IEC 60947-2				IEC 60947-2		
Isolation behaviour		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>				<input checked="" type="checkbox"/>		
Trip units:	thermomagnetic								
	T fixed, M fixed	TMF	<input checked="" type="checkbox"/>	-	-	-	-	-	-
	T adjustable, M fixed	TMD	-	<input checked="" type="checkbox"/>	-	-	<input checked="" type="checkbox"/>	-	-
	T adjustable, M adjustable (5...10 x I <sub>n</sub> )	TMA	-	-	-	-	-	-	-
	T adjustable, M fixed (3 x I <sub>n</sub> )	TMG	-	-	-	-	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
	T adjustable, M adjustable (2.5...5 x I <sub>n</sub> )	TMG	-	-	-	-	-	-	-
	magnetic only	MA	-	-	-	-	<input checked="" type="checkbox"/>	(MF up to I <sub>n</sub> 12.5 A)	
	electronic	PR221DS	-	-	-	-	<input checked="" type="checkbox"/>	-	-
		PR221GP/PR221MP	-	-	-	-	<input checked="" type="checkbox"/>	-	-
		PR222DS	-	-	-	-	-	-	-
		PR223DS	-	-	-	-	-	-	-
		PR231/P	-	-	-	-	-	-	-
		PR232/P	-	-	-	-	-	-	-
		PR331/P	-	-	-	-	-	-	-
		PR332/P	-	-	-	-	-	-	-
Interchangeability									
Versions		F	F				F-P		
Terminals	fixed	FC Cu	FC Cu-EF-FC CuAl-HR				F-FC Cu-FC CuAl-EF-ES-R		
	plug-in	-	-				F-FC Cu-FC CuAl-EF-ES-R		
	withdrawable	-	-				-		
Fixing on DIN rail		-	DIN EN 50022				DIN EN 50022		
Mechanical life	[No. operations]	25000	25000				25000		
	[No. Hourly operations]	240	240				240		
Electrical life @ 415 V AC	[No. operations]	8000	8000				8000		
	[No. Hourly operations]	120	120				120		
Basic dimensions - fixed version									
	3 poles	W [mm]	25.4 (1 pole)	76	90				
	4 poles	W [mm]	-	102	120				
		D [mm]	70	70	70				
		H [mm]	130	130	130				
Weight									
	fixed	3/4 poles	0.4 (1 pole)	0.9/1.2		1.1/1.5			
	plug-in	3/4 poles	-	-		1.5/1.9			
	withdrawable	3/4 poles	-	-		-			

TERMINAL CAPTION  
 F = Front  
 EF = Front extended  
 ES = Front extended spread

FC Cu = Front for copper cables  
 FC CuAl = Front for copper-aluminium cables  
 R = Rear orientated  
 HR = Rear flat horizontal

VR = Rear flat vertical  
 HR/VR = Rear flat orientated  
 MC = Multicable  
 F = fixed circuit-breakers

P = plug-in circuit-breakers  
 W = withdrawable circuit-breakers  
<sup>1)</sup> The breaking capacity for settings I<sub>n</sub> = 16 A and I<sub>n</sub> = 20 A is 16 kA

# Circuit-breakers for power distribution

## General characteristics

2

The series of Tmax moulded-case circuit-breakers - complying with the IEC 60947-2 Standard - is divided into seven basic sizes, with an application range from 1 A to 1600 A and breaking capacities from 16 kA to 200 kA (at 380/415 V AC). For protection of alternating current networks, the following are available:

- T1B 1p circuit-breaker, equipped with TMF thermomagnetic trip units with fixed thermal and magnetic threshold ( $I_3 = 10 \times I_n$ );
- T1, T2, T3 and T4 (up to 50 A) circuit-breakers equipped with TMD thermomagnetic trip units with adjustable thermal threshold ( $I_1 = 0.7 \dots 1 \times I_n$ ) and fixed magnetic threshold ( $I_3 = 10 \times I_n$ );
- T2, T3 and T6 circuit-breakers, fitted with TMG trip units for long cables and generator protection with adjustable thermal threshold ( $I_1 = 0.7 \dots 1 \times I_n$ ) and fixed magnetic threshold ( $I_3 = 3 \times I_n$ ) for T2 and T3 and adjustable magnetic threshold ( $I_3 = 2.5 \dots 5 \times I_n$ ) for T6;
- T4, T5 and T6 circuit-breakers with TMA thermomagnetic trip units with adjustable thermal threshold ( $I_1 = 0.7 \dots 1 \times I_n$ ) and adjustable magnetic threshold ( $I_3 = 5 \dots 10 \times I_n$ );
- T2 with PR221DS electronic trip unit;
- T4, T5 and T6 with PR221DS, PR222DS/P, PR222DS/PD and PR223DS electronic trip units;
- the T7 circuit-breaker, which completes the Tmax family up to 1600 A, fitted with PR231/P, PR232/P, PR331/P and PR332/P electronic trip units. The T7 circuit-breaker is available in the two versions: with manual operating mechanism or motorizable with stored energy operating mechanism<sup>(1)</sup>.

The field of application in alternating current of the Tmax series varies from 1 A to 1600 A with voltages up to 690 V. The Tmax T1, T2, T3, T4, T5 and T6 circuit-breakers equipped with TMF,

TMD and TMA thermomagnetic trip units can also be used in direct current plants, with a range of application from 1 A to 800 A and a minimum operating voltage of 24 V DC, according to the appropriate connection diagrams.

The three-pole T2, T3 and T4 circuit-breakers can also be fitted with MF and MA adjustable magnetic only trip units, both for applications in alternating current and in direct current, in particular for motor protection (see page 2/40 and following). For all the circuit-breakers in the series, fitted with thermomagnetic and electronic trip units, the single-phase trip current is defined (see page 4/57).

<sup>(1)</sup> For motorisation, the T7 circuit-breaker with stored energy operating mechanism must be ordered, complete with geared motor for automatic spring charging, opening coil and closing coil.

### Interchangeability

The Tmax T4, T5 and T6 circuit-breakers can be equipped either with TMF, TMD, TMG or TMA thermomagnetic trip units, MA magnetic only trip units or PR221DS, PR222DS/P, PR222DS/PD, PR222MP and PR223DS electronic trip units. Similarly, Tmax T7 can also mount the latest generation PR231/P, PR232/P, PR331/P<sup>(1)</sup> and PR332/P<sup>(1)</sup> electronic trip units.

Thanks to their simplicity of assembly, the end customer can change the type of trip unit extremely rapidly, according to their own requirements and needs: in this case, correct assembly is the customer's responsibility. Above all, this means into increased flexibility of use of the circuit-breakers with considerable savings in terms of costs thanks to better rationalisation of stock management.

### Trip units

Circuit-breakers	TMD							TMA							TMG			MA							
$I_n$ [A]	20	32	50	80	100	125	160	200	250	320	400	500	630	800	320	400	500	10	25	52	80	100	125	160	200
T4 250	■	■	■	■	■	■	■	■	■									■	■	■	■	■	■	■	■
T4 320	▲	▲	▲	▲	▲	▲	▲	▲	▲									▲	▲	▲	▲	▲	▲	▲	▲
T5 400										■	■				▲	▲									
T5 630										▲	▲	■			▲	▲	▲								
T6 630												■													
T6 800													■												
T6 1000														■											
T7 800																									
T7 1000																									
T7 1250																									
T7 1600																									

■ = Complete circuit-breaker already coded  
▲ = Circuit-breaker to be assembled

<sup>(1)</sup> If ordered loose PR331/P and PR332/P must be completed with the "trip unit adapters" (see page 3/48)

*Handwritten signature*

# Circuit-breakers for power distribution

## Thermomagnetic trip units

2

The Tmax T1 1p, T1, T2, T3, T4, T5 and T6 circuit-breakers can be fitted with thermomagnetic trip units and are used in protection of alternating and direct current networks with a range of use from 1.6 A to 800 A. They allow the protection against overload with a thermal device (with fixed threshold for T1 1p and adjustable threshold for T1, T2, T3, T4, T5 and T6) realised using the bimetal technique, and protection against short-circuit with a magnetic device (with fixed threshold for T1, T2 and T3 and T4 up to 50 A and adjustable threshold for T4, T5 and T6).


The four-pole circuit-breakers are always supplied with the neutral protected by the trip unit and with protection of the neutral at 100% of the phase setting for settings up to 100 A.

For higher settings, the protection of the neutral is at 50% of the phase setting unless the protection of the neutral at 100% of the phase setting is required.


Furthermore, for Tmax T2, T3 and T5, the TMG thermomagnetic trip units with low magnetic trip threshold are available. For T2 and T3 the trip unit has adjustable thermal threshold ( $I_1 = 0.7 \dots 1 \times I_n$ ) and fixed magnetic threshold ( $I_3 = 3 \times I_n$ ), whereas for T5 the trip unit has adjustable thermal threshold ( $I_1 = 0.7 \dots 1 \times I_n$ ) and adjustable magnetic threshold ( $I_3 = 2.5 \dots 5 \times I_n$ ). The thermomagnetic trip units can be used to protect long cables and for generator protection, both in direct current and in alternating current.

### Thermomagnetic trip units TMD e TMG (for T1, T2 and T3)

**Thermal threshold**  
Adjustable from 0.7 to 1 x In



**Thermal threshold**  
Adjustable from 0.7 to 1 x In



TMD = thermomagnetic trip unit with adjustable thermal threshold ( $I_1 = 0.7 \dots 1 \times I_n$ ) and fixed magnetic threshold ( $I_3 = 10 \times I_n$ ).  
 TMG = thermomagnetic trip unit with adjustable thermal threshold ( $I_1 = 0.7 \dots 1 \times I_n$ ) and fixed magnetic threshold ( $I_3 = 3 \times I_n$ ).

*Handwritten signatures and marks:*  
 A large handwritten mark resembling a stylized 'S' or 'B' is located to the right of the second image.  
 A signature 'eg' is written below the first image.  
 A signature 'llb' is written at the bottom right of the page.

# Circuit-breakers for power distribution


## Thermomagnetic trip units

Thermomagnetic trip units TMD/TMA and TMG (for T4, T5 and T6)

2

Thermal threshold  
Adjustable

Thermal threshold  
Adjustable from 0.7 to 1 x I<sub>n</sub>



1SDC21000-90001

TMA = thermomagnetic trip unit with adjustable thermal threshold ( $I_t = 0.7...1 \times I_n$ ) and adjustable magnetic threshold ( $I_m = 5...10 \times I_n$ )  
 TMG (for T5) = thermomagnetic trip unit with adjustable thermal threshold ( $I_t = 0.7...1 \times I_n$ ) and adjustable magnetic threshold ( $I_m = 2.5...5 \times I_n$ )

*Ch*

*↓*

*07*

*all*

# Circuit-breakers for power distribution

## Electronic trip units

2

The Tmax T2, T4, T5, T6 and T7 circuit-breakers, for use in alternating current, can be equipped with overcurrent releases constructed using electronic technology. This allows protection functions to be obtained which guarantee high reliability, tripping precision and insensitivity to temperature and to the electromagnetic components in conformity with the standards on the matter.

The power supply needed for correct operation is supplied directly by the current sensors of the release, and tripping is always guaranteed, even under single-phase load conditions and in correspondence with the minimum setting.

### Characteristics of the Tmax electronic trip units

Operating temperature	-25 °C ... +70 °C
Relative humidity	98%
Self-supply	0.2 x I <sub>n</sub> (single phase)
Auxiliary power supply (where applicable)	24 V DC
Operating frequency	45...66 Hz
Electromagnetic compatibility (LF and HF)	IEC 60947-2 Annex F

For Tmax T2, T4, T5 and T6 the protection trip unit consists of:

- 3 or 4 current sensors (current transformers)
- external current sensors (e.g. for the external neutral), when available
- a trip unit
- a trip coil (for T2 housed in the right slot, for T4, T5 and T6 integrated in the electronic trip unit).

For Tmax T7 the protection trip unit consists of:

- 3 or 4 current sensors (Rogowski coils and current transformers)
- external current sensors (e.g. for the external neutral)
- interchangeable rating plug
- a trip unit
- a trip coil housed in the body of the circuit-breaker.

### Rating plugs

Circuit-breaker	GS Rated current	I <sub>n</sub> [A]					
		400	630	800	1000	1250	1600
T7	800	■	■	■			
	1000	■	■	■	■		
	1250	■	■	■	■	■	
	1600	■	■	■	■	■	■

The current sensors supply the electronic trip unit with the energy needed for correct operation of the trip unit and the signal needed to detect the current.

The current sensors are available with rated primary current as shown in the table.

# Circuit-breakers for power distribution

## Electronic trip units

### Basic protection functions

2



**(L) Protection against overload**  
This protection function trips when there is an overload with inverse long-time delay trip according to the IEC 60947-2 Standard ( $I^2t=k$ ). The protection cannot be excluded.



**(S) Protection against short-circuit with time delay**  
This protection function trips when there is a short-circuit, with long inverse time-delay trip ( $I^2t=k$  ON) or a constant trip time ( $I^2t=k$  OFF). The protection can be excluded.



**(I) Instantaneous protection against short-circuit**  
This protection function trips instantaneously in case of a short-circuit. The protection can be excluded.



**(G) Protection against earth fault**  
The protection against earth fault trips when the vectorial sum of the currents passing through the current sensors exceeds the set threshold value, with long inverse time-delay trip ( $I^2t=k$  ON) or a constant trip time ( $I^2t=k$  OFF). The protection can be excluded.

### Advanced protection functions

The PR332/P trip unit makes it possible to carry out highly developed protection against the most varied types of fault.

In fact, it adds the following advanced protection functions to the basic protection functions.



IEC 60255-3

**(L) Protection against overload (IEC 60255-3)**  
This protection trips in case of an overload with inverse long-time delay according to IEC 60255-3 Standard, for the coordination with fuses and MV protections. The protection can be excluded.



**(U) Protection against unbalanced phase**  
The protection function against unbalanced phase U can be used in those cases where a particularly precise control is needed regarding missing and/or unbalance of the phase currents. The trip time is instantaneous. The protection can be excluded.



**(OT) Protection against overtemperature**  
The protection against overtemperature trips instantaneously when the temperature inside the trip unit exceeds 85 °C, in order to prevent any temporary or continual malfunction of the microprocessor. The protection cannot be excluded.



**(Rc) Protection against residual current <sup>(1)</sup>**  
This integrated protection is based on current measurements made by an external toroid and is alternative to protection against earth fault G. The protection can be excluded.



**(ZS) Zone selectivity <sup>(2)</sup>**  
ZS zone selectivity is an advanced method for carrying out coordination of the protections in order to reduce the trip times of the protection closest to the fault in relation to the time foreseen by time selectivity. Zone selectivity can be applied to the protection functions S and G, with constant time-delay trip. The protection can be excluded.



**(UV, OV, RV) Protections against voltage**  
The three protections trip with a constant time-delay in the case of undervoltage, overvoltage and residual voltage respectively. The latter allows to detect interruptions of the neutral (or of the earthing conductor in systems with earthed neutral) and faults which cause movement of the star centre in systems with isolated neutral (e.g. large earth faults) to be identified. Movement of the star centre is calculated by vectorially summing the phase voltages. The protections can be excluded.



**(RP) Protection against reversal of power**  
The protection against reversal power causes tripping of the breaker, with constant time-delay trip, when the flow of power reverses sign and exceeds, as an absolute value, the set threshold. It is particularly suitable for protection of large machines such as generators. The protection can be excluded.



**(UF, OF) Protections of frequency**  
The two protections detect the variation in network frequency above or below the adjustable thresholds, opening the circuit-breaker, with constant time-delay trip. The protection can be excluded.

<sup>(1)</sup> It is not suitable for human protection.


<sup>(2)</sup> For further information about zone selectivity, please see the section: "Circuit-breakers for zone selectivity".

*Handwritten signatures and initials:*  
 - A large stylized signature at the top right.  
 - The initials "M" in the middle right.  
 - The initials "J" at the bottom right.  
 - The initials "OH" in the bottom right.  
 - A large signature at the bottom right.

# Circuit-breakers for power distribution

## Electronic trip units


SACE PR231/P



2

	PR231/P	PR231/P
Protection functions	L S /	

SACE PR232/P




	PR232/P
Protection functions	L S

SACE PR331/P



	PR331/P
Protection functions	L S G

SACE PR332/P



	PR332/P	PR332/P	PR332/P	PR332/P
Protection functions	L	L S	L S G	L S
Advanced protection function <sup>(1)</sup>	L U	L U	L U	L U
Opt. <sup>(2)</sup>	⓪ ⓪ ⓪ ⓪ ⓪ ⓪ ⓪ ⓪	⓪ ⓪ ⓪ ⓪ ⓪ ⓪ ⓪ ⓪	⓪ ⓪ ⓪ ⓪ ⓪ ⓪ ⓪ ⓪	⓪ ⓪ ⓪ ⓪ ⓪ ⓪ ⓪ ⓪

<sup>(1)</sup> In alternative to Rc (with external toroid).  
<sup>(2)</sup> For all versions.  
<sup>(3)</sup> Available with PR330/V Measurement module.  
<sup>(4)</sup> According to IEC 60255-3.

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*



# Circuit-breakers for power distribution

## Electronic trip units

2

### PR221GP

The PR221GP electronic release, only available on Tmax T2, is specific for protection of generators with the following rated currents:  $I_n = 63 \text{ A}$ ,  $I_n = 100 \text{ A}$ ,  $I_n = 160 \text{ A}$ .

It allows wide adjustment of the protection against overload  $L$ ,  $I_1 = 0.4 \dots 1 \times I_n$  and above all provides the possibility of selecting four trip curves.

Generator protection typically requires low trip thresholds with regard to protection against short-circuit. Thanks to the PR221GP protection with time delay adjustable up to 2.5 times the rated current,  $I_2 = 1 \dots 2.5 \times I_n$  is guaranteed, with the possibility of selecting between two trip curves.

It is also possible to set an instantaneous protection against short-circuit ( $I$ ) fixed at 4 times the trip threshold of the protection against delayed short-circuit ( $S$ ).

The  $S$  and  $I$  protection functions are not alternative to each other. As for Tmax T2 PR221DS, it is necessary to house the opening solenoid ( $SA$ ) in the right-hand slot of the circuit-breaker. Tmax T2 PR221GP can be fitted with the same electrical accessories available with PR221DS.


The functions present on this release allow the requirements imposed by the major naval registers, such as LLRRS, ABS and RINA to be satisfied.

### Protection S

Against short-circuit with delayed trip

### Protection L





Against overload



Socket for TT1 test unit

Protection I  
Against short-circuit with instantaneous trip

### Protection and parameterisation functions

Protection function <sup>(1)</sup>	Trip threshold	Trip curves	Excludability	Relation $t=f(I)$
 Against overload with long inverse time delay trip and trip characteristic according to an inverse time curve ( $I^2t=k$ ) according to IEC 60947-2 Standard	$I_1 = 0.40 - 1 \times I_n$ step = $0.04 \times I_n$	at $6 \times I_1$ $t_1 = 0.7 - 1.4 - 2.8 - 5.5 \text{ s}$ Tolerance: $\pm 10\%$ up to $2 \times I_n$ $\pm 20\%$ over $2 \times I_n$	-	-
 Against short-circuit with inverse short time delay trip and trip characteristic with inverse time ( $I^2t=k$ )	$I_2 = 1 \dots 2.5 \times I_n$ step = $0.5 \times I_n$ Tolerance: $\pm 10\%$	at $5 \times I_n$ $t_2 = 0.07 - 0.175 \text{ s}$ Tolerance: $\pm 10\%$ up to $2 \times I_n$	-	$t = k/I$
 Against short-circuit with instantaneous trip with adjustable threshold	$I_3 = 4 \times I_2$ fixed Tolerance: $\pm 20\%$	instantaneous		$t = k$

<sup>(1)</sup> The tolerances are valid with these hypotheses:  
 - self-supplied release at full power and/or auxiliary power supply (without start up)  
 - two-phase or three-phase power supply  
 For all the cases not foreseen in the above hypotheses, the following tolerance values are valid:

	Trip threshold	Trip time
S	$\pm 20\%$	$\pm 20\%$
I	$\pm 20\%$	$\leq 40\text{ms}$



# Circuit-breakers for power distribution

## Electronic trip units

2

Communication functions	PR222DS/P	PR222DS/PD	PR223DS
Protocol		Modbus RTU standard	Modbus RTU standard
Physical medium		EIA RS485	EIA RS485
Speed (maximum)		19.2 kbps	19.2 kbps
<b>Measurement functions</b>			
Phase currents	☑ <sup>(1)</sup>	☑	☑
Neutral current	☑ <sup>(1)</sup>	☑	☑
Ground current	☑ <sup>(1)</sup>	☑	☑
Voltages (phase to phase, phase to earth)			☑ <sup>(6)</sup>
Powers (active, reactive, apparent)			☑ <sup>(6)</sup>
Power factors			☑ <sup>(6)</sup>
Energies			☑ <sup>(6)</sup>
Peak factor			☑
Frequency			☑ <sup>(6)</sup>
<b>Signalling functions</b>			
L pre-alarm and alarm LED	☑ <sup>(5)</sup>	☑ <sup>(5)</sup>	☑
L alarm output contact <sup>(2)</sup>	☑	☑	☑
<b>Available data</b>			
Circuit-breaker status (open, closed) <sup>(3)</sup>		☑	☑
Mode (local, remote)		☑	☑
Protection parameters set	☑ <sup>(1)</sup>	☑	☑
<b>Alarms</b>			
Protections: L, S, I, G	☑ <sup>(1)</sup>	☑	☑
Failed tripping under fault conditions	☑ <sup>(1)</sup>	☑	☑
<b>Maintenance</b>			
Total number of operations <sup>(3)</sup>		☑	☑
Total number of trips		☑	☑
Number of trip tests		☑	☑
Number of manual operations		☑	☑
Number of trips for each individual protection function		☑	☑
Record of last trip data		☑	☑
<b>Commands</b>			
Circuit-breaker opening/closing (with motor operator)		☑	☑
Alarm reset	☑ <sup>(1)</sup>	☑	☑
Circuit-breaker reset (with motor operator)		☑	☑
Setting the curves and protection thresholds	☑ <sup>(1)</sup>	☑	☑
<b>Safety function</b>			
Automatic opening in the case of failed Trip command fail (with motor operator) <sup>(4)</sup>		☑	☑
<b>Events</b>			
Changes in circuit-breaker state, in the protections and all the alarms		☑	☑

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

<sup>(1)</sup> With PR010/T unit or BT030 unit  
<sup>(2)</sup> Typical contact: MOS photo Vmax: 48 V DC/30 V AC  
Rmax = 35 ohm  
<sup>(3)</sup> Available with AUX-E electronic auxiliary contacts  
<sup>(4)</sup> The motor operator must be in electronic version (MOE-E) and electronic auxiliary contacts (AUX-E) have to be used  
<sup>(5)</sup> Signals: - Pre-alarm L - permanently lit  
- Alarm L - flashing (0.5 s ON / 0.5 s OFF)  
- Incongruent manual setting (L > S / S > I) - flashing (1 s ON / 2 s OFF)  
- WINK (remote control to identify the relay) - flashing (0.125 s ON / 0.125 s OFF)  
<sup>(6)</sup> With VM210

# Circuit-breakers for power distribution

## Electronic trip units

### PR222DS/P, PR222DS/PD and PR223DS<sup>(5)</sup> - Protection functions and parameterisations

Protection functions	Trip threshold	Trip curves <sup>(1)</sup>	Excludability	Relation $t = f(I)$
<b>L</b> Against overload with long inverse time delay trip and trip characteristic according to an inverse time curve ( $I^2t=k$ ) according to IEC 60947-2 Standard	<b>Manual setting</b> $I_1 = 0.40...1 \times I_n$ step = $0.02 \times I_n$	<b>Manual setting</b> at $6 \times I_1$ $t_1 = 3 - 6 - 9/12 - MAX^{(2)}$	-	$t = k/I^2$
	<b>Electronic setting</b> $I_1 = 0.40...1 \times I_n$ step $0.01 \times I_n$ Trip between $1.1...1.3 \times I_1$	<b>Electronic setting</b> at $6 \times I_1$ , $t_1 = 3...18s$ step $0.5s^{(3)}$ Tolerance: $\pm 10\%$	-	
<b>S</b> Against short-circuit with inverse short time delay trip and trip characteristic with inverse time ( $I^2t=k$ ) or definite time	<b>Manual setting</b> $I_2 = 0.6-1.2-1.8-2.4-3-3.6-4.2-5.8-6.4-7-7.6-8.2-8.8-9.4-10 \times I_n^{(4)}$	<b>Manual setting</b> at $8 \times I_n$ $t_2 = 0.05 - 0.1 - 0.25 - 0.5s$	<input checked="" type="checkbox"/>	$t = k/I^2$
	<b>Electronic setting</b> $I_2 = 0.60...10 \times I_n$ step $0.1 \times I_n$ Tolerance: $\pm 10\%$	<b>Electronic setting</b> at $8 \times I_n$ , $t_2 = 0.05...0.5s$ step $0.01s$ Tolerance: $\pm 10\%^{(4)}$	<input checked="" type="checkbox"/>	
	<b>Manual setting</b> $I_2 = 0.6-1.2-1.8-2.4-3-3.6-4.2-5.8-6.4-7-7.6-8.2-8.8-9.4-10 \times I_n^{(4)}$	<b>Manual setting</b> $t_2 = 0.05 - 0.1 - 0.25 - 0.5s$	<input checked="" type="checkbox"/>	$t = k$
<b>I</b> Against short-circuit with instantaneous trip	<b>Manual setting</b> $I_3 = 1.5-2.5-3-4-4.5-5-5.5-6.5-7-7.5-8-9-9.5-10.5-12 \times I_n^{(4)}$	instantaneous	<input checked="" type="checkbox"/>	$t = k$
	<b>Electronic setting</b> $I_3 = 1.5...12 \times I_n^{(4)}$ step $0.1 \times I_n$ Tolerance: $\pm 10\%$		<input checked="" type="checkbox"/>	
<b>G</b> Against earth fault with inverse short time delay trip and trip characteristic according to an inverse time curve ( $I^2t=k$ )	<b>Manual setting</b> $I_4 = 0.2-0.25-0.45-0.55-0.75-0.8-1 \times I_n$	<b>Manual setting</b> up to $3.15 \times I_4$ up to $2.25 \times I_4$ up to $1.6 \times I_4$ up to $1.10 \times I_4$ $t_4 = 0.1s$ $t_4 = 0.2s$ $t_4 = 0.4s$ $t_4 = 0.80s$	<input checked="" type="checkbox"/>	$t = k/I^2^{(5)}$
	<b>Electronic setting</b> $I_4 = 0.2...1 \times I_n$ step $0.1 \times I_n$ Tolerance: $\pm 10\%$	<b>Electronic setting</b> $t_4 = 0.1...0.8s$ step $0.01s$ Tolerance: $\pm 15\%$	<input checked="" type="checkbox"/>	

<sup>(1)</sup> These tolerances hold in the following conditions:  
 - self-powered trip unit at full power and/or auxiliary supply  
 - two or three-phase power supply  
 In conditions other than those considered, the following tolerances hold:

	Trip threshold	Trip time
<b>S</b>	$\pm 20\%$	$\pm 20\%$
<b>I</b>	$\pm 20\%$	$\leq 50ms$
<b>G</b>	$\pm 20\%$	$\pm 20\%$

<sup>(2)</sup> t<sub>1</sub> values for MAX setting:

CB	Electronic setting	Manual setting
T4 320		
T6 630	3...10.5s Step 0.5s	3-6-9-10.5
T6 1000		
T4 250	3...18s Step 0.5s	3-6-9-18
T6 400		
T6 800	3...18s Step 0.5s	3-6-9-18
T6 630	3...18s Step 0.5s	3-6-12-18

<sup>(3)</sup> For T4  $I_n = 320 A$  and T5  $I_n = 630 A$ , T6  $I_n = 1000 A \Rightarrow I_{2,max} = 9.5 \times I_n$  and  $I_{3,max} = 9.5 \times I_n$   
 For T6  $I_n = 800 A \Rightarrow I_{3,max} = 10.5 \times I_n$

<sup>(4)</sup> Tolerance:  $\pm 10 ms$

<sup>(5)</sup> The setting of the PR223DS trip unit is electronic only (local/remote)

The L protection can be set at  $I_1 = 0.18...1 \times I_n$ . For  $I_1 < 0.4 \times I_n$  the neutral setting must be at 100% of that of the phases

<sup>(6)</sup>  $t = k/I^2$  up to the current value indicated,  $t = k$  (equating to the chosen setting) beyond the current value indicated

# Circuit-breakers for power distribution

## Electronic trip units

2


### PR231/P

The PR231/P trip unit is the basic trip unit for Tmax T7. It provides protection functions against overload L and short-circuit S/I (version PR231/P-LS/I): with this version, by moving the dedicated dip-switch, you can choose whether to have protection S or protection I. Alternatively the version with only the protection function against instantaneous short-circuit I is available (version PR231/P-I see also page 2/45 and following). Setting the trip parameters of the PR231/P trip unit is made directly on the front of the circuit-breaker by means of dip

switches, and there is only one for the phases and the neutral, so it is possible to set the protection threshold, at 50% or at 100% of the phase protection.

To guarantee protection of the installation by means of the PR231/P protection trip unit, it is necessary to select the rated network frequency (50/60 Hz), by means of the special dip-switch.

Interchangeability of PR231/P can be requested by means of the dedicated ordering code 1SDA063140R1.



### Protection functions and parameterisations

Protection function	Trip threshold	Trip curves <sup>(1)</sup>	Excludability	Relation t=f(I)
<b>L</b> Against overload with long inverse time delay trip and trip characteristic according to an inverse time curve (I <sup>2</sup> t=k) according to IEC 60947-2 Standard	I <sub>1</sub> = 0.40...1 x I <sub>n</sub> step = 0.04 x I <sub>n</sub> Trip between 1.1...1.3 x I <sub>1</sub>	at 6 x I <sub>1</sub> at 6 x I <sub>1</sub> t <sub>1</sub> = 3 - 12s Tolerance: ±10%	-	t = k/I <sup>2</sup>
<b>S</b> Against short-circuit with long inverse time delay trip and trip characteristic with inverse time (I <sup>2</sup> t= k) (selectable as an alternative to protection function I)	I <sub>2</sub> = 1-1.5-2-2.5-3-3.5-4.5-5.5-6.5-7-7.5-8-8.5-9-10 x I <sub>n</sub> Tolerance: ±10%	at 10 x I <sub>n</sub> at 10 x I <sub>n</sub> t <sub>2</sub> = 0.1 - 0.25s Tolerance: ±10%	■	t = k/I <sup>2</sup>
<b>I</b> Against short-circuit with instantaneous trip (selectable as an alternative to protection function S)	I <sub>3</sub> = 1-1.5-2-2.5-3-3.5-4.5-5.5-6.5-7-7.5-8-8.5-9-10 x I <sub>n</sub> Tolerance: ±10%	instantaneous	○	t = k

<sup>(1)</sup> These tolerances hold in the following conditions:  
 - self-powered trip unit at full power  
 - two or three-phase power supply  
 In conditions other than those considered, the following tolerances hold:

	Trip threshold	Trip time
S	± 10%	± 20%
I	± 15%	≤ 60ms

*Handwritten signatures and marks:*  
 - A large handwritten 'a' or 'A' in the middle right.  
 - A signature at the bottom right.  
 - Another signature at the bottom right.

# Circuit-breakers for power distribution


## Electronic trip units

2

There are three red LEDs available on the front of the PR232/P trip unit dedicated to signalling alarm of protections L, S, and I. Furthermore, a yellow flashing LED allows the state of pre-alarm of function L to be signalled, which is activated when 90% of the set trip threshold is reached. The yellow flashing LED every 3s indicates the normal operation.

Following circuit-breaker opening, it is possible to know which protection function made the release trip by connecting the PR030/B battery unit onto the front of the release. This is also possible thanks to the PR010/T test and configuration unit. By means of the BT030 wireless communication unit the PR232/P can be connected to a PDA or to a personal computer, extending the range of information available for the user. Infact, by means of the ABB SACE's SD-Pocket communication software, it is possible to read the values of the currents flowing through the circuit-breaker, the value of the last 20 interrupted currents, and the protection settings.

### PR232/P - Alarm and Pre-alarm LED

Protection	Colour	Pre-alarm	Alarm	Last trip
	Yellow	■	-	-
	Red	-	■	■
	Red	-	■	■

*Handwritten signatures and scribbles.*

# Circuit-breakers for power distribution

## Electronic trip units

### User interface

The user communicates directly with the trip unit by means of the dip switches. Up to four LEDs (according to the version) are also available for signalling. These LEDs (one for each protection) are active when:

- a protection is timing. For protection L the pre-alarm status is also shown;
- a protection has tripped (the corresponding LED is activated by pressing the "Info/Test" pushbutton);
- a failure in connection of a current sensor or in the trip coil is detected. The indication is active when the unit is powered (through current sensors or an auxiliary power supply);
- wrong rating plug for the circuit-breaker.

The protection tripped indication works even with the circuit-breaker open, without the need for any internal or external auxiliary power supply. This information is available for 48 hours of inactivity after the trip and is still available after reclosing. If the query is made more than 48 hours later it is sufficient to connect a PR030/B battery unit, PR010/T, or a BT030 wireless communication unit.

### Setting the neutral

Protection of the neutral can be set at 50%, 100% or 200% of the phase currents. In particular, adjustment of the neutral at 200% of the phase current is possible if the following inequality is respected:  $I_1 \times I_n \times \%Ne \leq I_u$ . The user can also switch the neutral protection OFF.

### Test function

The Test function is carried out by means of the Info/Test pushbutton and the PR030/B battery unit (or BT030) fitted with a polarized connector housed on the bottom of the box, which allows the device to be connected to the test connector

on the front of PR331/P trip units. The PR331/P electronic trip unit can be tested by using the SACE PR010/T test and configuration unit by connecting it to the TEST connector.

### Power supply

The unit does not require an external power supply either for protection functions or for alarm signalling functions. It is self-supplied by means of the current sensors installed on the circuit-breaker.

For operation, it is required for the three phases to be passed through by a current of 70 A. An external power supply can be connected in order to activate additional features, and in particular for connection to external devices: HMI030 and PR021/K.

### PR331/P - Electrical characteristics

Auxiliary power supply (galvanically insulated)	24 V DC $\pm$ 20%
Maximum ripple	5%
Inrush current @ 24 V	3 A for 5 ms
Rated power @ 24 V	.1 W

### Communication

By means of the BT030 wireless communication unit, PR331/P can be connected to a PDA or to a personal computer, extending the range of information available for the user. In fact, by means of ABB SACE's SD-Pocket communication software, it is possible to read the values of the currents flowing through the circuit-breaker, the value of the last 20 interrupted currents, and the protection settings. PR331/P can also be connected to the optional external PR021/K signalling unit, for the remote signalling of protections alarms and trips, and to HMI030, for the remote user interfacing.

*Ca*

*J*

*Q*

*llt*

# Circuit-breakers for power distribution

## Electronic trip units

### PR332/P - Protection functions and parameterisations

Protection functions	Trip threshold	Trip curves <sup>(1)</sup>	Excludability	Relation $t = f(I)$	Thermal memory <sup>(2)</sup>	Zone selectivity <sup>(2)</sup>
<b>2</b> <b>L</b>	Against overload with inverse long-time delay trip according to IEC 60947-2 Standard ( $I^2t=k$ ) or in accordance with the IEC 60255-3 Standard ( $t=f(\alpha)^{(3)}$ )	$I_1 = 0.4...1 \times I_n$ step = $0.01 \times I_n$ Trip between $1.05...1.2 \times I_1$	at $3 \times I_1$ $t_2 = 3...144s$ step = $3s$ Tolerance: up to $6 \times I_n$ $\pm 20\%$ above $6 \times I_n$	—	$t = k/I^2$ ■	—
		$I_1 = 0.4...1 \times I_n$ step = $0.01 \times I_n$ Trip between $1.05...1.2 \times I_1$	at $3 \times I_1$ $t_2 = 3...144s$ step = $3s$ Tolerance: $\pm 10\%$ up to $6 \times I_n$ $\pm 20\%$ above $6 \times I_n$	■	$t = f(\alpha)^{(3)}$ $\alpha = 0.02-1-2$ ■	—
<b>S</b>	Against short-circuit with short inverse time-delay trip and trip characteristic with inverse time ( $I^2t=k$ ) or with definite time	$I_2 = 0.6...10 \times I_n$ step = $0.1 \times I_n$ Tolerance: $\pm 7\%$ up to $6 \times I_n$ $\pm 10\%$ above $6 \times I_n$	at $10 \times I_n$ $t_2 = 0.05...0.8s$ step = $0.01s$ Tolerance: $\pm 15\%$ up to $6 \times I_n$ $\pm 20\%$ over $6 \times I_n$	■	$t = k/I^2$ ■	—
		$I_2 = 0.6...10 \times I_n$ step = $0.1 \times I_n$ Tolerance: $\pm 7\%$ up to $6 \times I_n$ $\pm 10\%$ above $6 \times I_n$	$t_2 = 0.05...0.8s$ step = $0.01s$ $t_{2\text{ sel}} = 0.04...0.2s$ step = $0.01s$ Tolerance: min ( $\pm 10\%$ ; $\pm 40ms$ )	■	$t = k$ —	■
<b>I</b>	Against short-circuit with adjustable instantaneous trip	$I_3 = 1.5...15 \times I_n$ step = $0.1 \times I_n$ Tolerance: $\pm 10\%$	$\leq 30 ms$	■	$t = k$ —	—
<b>G</b>	Against earth fault with short inverse time-delay trip and trip characteristic according to an inverse time curve ( $I^2t=k$ ) or with definite time	$I_4 = 0.2...1 \times I_n$ step = $0.02 \times I_n$ Tolerance: $\pm 7\%$	$t_4 = 0.1...1s$ step = $0.05s$ Tolerance: $\pm 15\%$	■	$t = k/I^{(4)}$ —	—
		$I_4 = 0.2...1 \times I_n$ step = $0.02 \times I_n$ Tolerance: $\pm 7\%$	$t_4 = 0.1...1s$ step = $0.05s$ $t_{4\text{ sel}} = 0.04...0.2s$ step = $0.05s$ Tolerance: min ( $\pm 10\%$ ; $\pm 40ms$ )	■	$t = k$ —	■
<b>Rd</b>	Against residual current fault with definite time-delay trip	$I\Delta = 3-5-7-10-20-30 A$ Tolerance: $0-20\%$	$t\Delta = 0.06-0.1-0.2-0.3-0.4-0.5-0.8s$ Tolerance: $\pm 20\%$	■	$t = k$ —	—
<b>OT</b>	Against overtemperature of the trip unit with instantaneous trip	Trip unit temperature over $85^\circ C$	instantaneous	—	$temp = k$ —	—
<b>U</b>	Against unbalanced phase with definite time-delay trip	$I_6 = 2\%...90\% \times I_1$ step = $1\% \times I_1$ Tolerance: $\pm 10\%$	$t_6 = 0.5...60 s$ step = $0.5s$ Tolerance: min ( $\pm 20\%$ ; $\pm 100ms$ )	■	$t = k$ —	—

### PR332/P with PR330/V - Advanced protection functions and parameterisations

Advanced protection functions	Trip threshold	Trip curves <sup>(1)</sup>	Excludability	Relation $t = f(I)$	Thermal memory <sup>(2)</sup>	Zone selectivity
<b>UV</b>	Against undervoltage with adjustable constant time	$U_8 = 0.5...0.95 \times U_n$ step = $0.01 \times U_n$ Tolerance: $\pm 5\%$	$t_8 = 0.1...5s$ step = $0.1s$ Tolerance: min ( $\pm 20\%$ $\pm 100ms$ )	■	$t = k$ —	—
<b>OV</b>	Against overvoltage with adjustable constant time	$U_9 = 1.05...1.2 \times U_n$ step = $0.01 \times U_n$ Tolerance: $\pm 5\%$	$t_9 = 0.1...5s$ step = $0.1s$ Tolerance: min ( $\pm 20\%$ $\pm 100ms$ )	■	$t = k$ —	—
<b>RV</b>	Against residual voltage with adjustable constant time	$U_{r0} = 0.1...0.4 \times U_n$ step = $0.01 \times U_n$ Tolerance: $\pm 5\%$	$t_{r0} = 0.5...30s$ step = $0.5s$ Tolerance: min ( $\pm 10\%$ $\pm 100ms$ )	■	$t = k$ —	—
<b>RP</b>	Against reversal of power with adjustable constant time	$P_{r1} = -0.3...-0.1 \times P_n$ step = $0.02 \times P_n$ Tolerance: $\pm 10\%$	$t_{r1} = 0.5...25s$ step = $0.1s$ Tolerance: min ( $\pm 10\%$ $\pm 100ms$ )	■	$t = k$ —	—
<b>UF</b>	Against underfrequency with adjustable constant time	$f_{r2} = 0.90...0.99 \times f_n$ step = $0.01 \times f_n$ Tolerance: $\pm 5\%$	$t_{r2} = 0.5...3s$ step = $0.1s$ Tolerance: min ( $\pm 10\%$ $\pm 100ms$ )	■	$t = k$ —	—
<b>OF</b>	Against overfrequency with adjustable constant time	$f_{r3} = 1.01...1.10 \times f_n$ step = $0.01 \times f_n$ Tolerance: $\pm 5\%$	$t_{r3} = 0.5...3s$ step = $0.1s$ Tolerance: min ( $\pm 10\%$ $\pm 100ms$ )	■	$t = k$ —	—

<sup>(1)</sup> These tolerances are valid under the following conditions:  
 - trip unit self-supplied at full power and/or auxiliary supply  
 - two or three-phase power supply  
 In conditions other than those considered, the following tolerances hold:

	Trip threshold	Trip time
L	Release between $1.05$ and $1.25 \times I_1$	$\pm 20\%$
S	$\pm 10\%$	$\pm 20\%$
I	$\pm 15\%$	$\leq 60ms$
G	$\pm 15\%$	$\pm 20\%$
Other	$\pm 10\%$	$\pm 20\%$

<sup>(2)</sup> Active with 24V auxiliary power supply

$$t = \frac{(3^x - 1)}{(3 - 1)} \cdot t_1 \cdot (3 \cdot x^1)$$

<sup>(3)</sup> For  $T7 I_n = 1250 A / 600 A \Rightarrow I_{2\text{ max}} = 12 \times I_n$

$$k = (2s) \cdot 0.1^2$$

# Circuit-breakers for power distribution

## Electronic trip units

### Indicator LEDs

LEDs on the front panel of the trip unit are used to indicate all the pre-alarms ("WARNING") and alarms ("ALARM"). A message on the display always explicitly indicates the type of event concerned.

Example of events indicated by the "WARNING" LED:

- unbalance between phases;
- pre-alarm for overload ( $L1 > 90\% \times I_n$ );
- first temperature threshold exceeded (70 °C);
- contact wear beyond 80%;
- phase rotation reversed (with optional PR330/V).

Example of events indicated by the "ALARM" LED:

- timing of function L;
- timing of function S;
- timing of function G;
- second temperature threshold exceeded (85 °C);
- contact wear 100%;
- timing of Reverse Power flow protection (with optional PR330/V).

### Data logger

By default PR332/P, is provided with the Data Logger function that automatically records in a wide memory buffer the instantaneous values of all the currents and voltages. Data can be easily downloaded from the unit by means of SD-Pocket or SD-TestBus2 applications and can be transferred to any personal computer for elaboration. The function freezes the recording whenever a trip occurs or in case of other events, so that a detailed analysis of faults can be easily performed. SD-Pocket and SD-TestBus2 allow also reading and downloading of all the others trip information.

- Number of analog channels: 8
- Maximum sampling rate: 4800 Hz
- Maximum sampling time: 27 s (@ sampling rate 600 Hz)
- 64 events tracking.

### Trip information and opening data

In case a trip occurs PR332/P store all the needed information:

- Protection tripped
- Opening data (current)
- Time stamp (guaranteed with auxiliary supply or self-supply with power failure no longer than 48h).

By pushing the "Info/Test" pushbutton the trip unit shows all these data directly on display.

No auxiliary power supply is needed. The information is available to user for 48 hours with the circuit breaker open or without current flowing.

The information of the latest 20 trips are stored in memory. If the information can be furthermore retrieved more than 48 hours later, it is sufficient to connect a PR030/B battery unit or a BT030 wireless communication unit.

### Load control

Load control makes it possible to engage/disengage individual loads on the load side before the overload protection L is tripped, thereby avoiding unnecessary trips of the circuit-breaker on the supply side. This is done by means of contactors or switch-disconnectors (externally wired to the trip unit), controlled by the PR332/P through PR021/K unit. Two different Load Control schemes can be implemented:

- disconnection of two separate loads, with different current thresholds
- connection and disconnection of a load, with hysteresis.

Current thresholds and trip times are smaller than those available for selection with protection L, so that load control can be used to prevent overload tripping. External PR021/K accessory unit is required for Load Control. The function is only active when an auxiliary power supply is available.

### PR330/V Measurement Module

This optional internal module, installed in PR332/P, allows the trip unit to measure the phase and neutral voltages and to process them in order to achieve a series of features, in terms of protection and measurement.

PR330/V module, when is ordered mounted on the circuit-breaker, does not require any external connection or voltage transformers since it is connected internally to the upper terminals of Tmax T7 (selector in "INT" position) through the internal voltage sockets. When necessary, the connection of voltage pick-ups can be moved to any other point (i.e. lower terminals), by using the alternative connection located in the terminal box and switching the selector to the "EXT" position. For the dielectric test of the circuit-breaker the selector must be switched to the "Insulating TEST" position. PR330/V is able to energize the PR332/P while line voltage input is above 85 V. The use of Voltage Transformers is mandatory for rated voltages higher than 690 V.

Voltage transformers shall have burdens between 5 VA and 10 VA and accuracy class 0.5 or better.

Additional Protections with PR330/V:

- Undervoltage (UV) protection
- Overvoltage (OV) protection
- Residual voltage (RV) protection
- Reversal of power (RP) protection
- Underfrequency (UF) protection
- Overfrequency (OF) protection.

All the above indicated protections can be excluded, although it is possible to leave only the alarm active when required: in this case the trip unit will indicate the "ALARM" status. With the circuit-breaker closed, these protections also operate when the trip unit is self-supplied. With the circuit-breaker open, they operate when the auxiliary power supply (24 V DC or PR330/V) is present.



# Circuit-breakers for power distribution

## Electronic trip units

### Measurement, signalling and available data functions

Details about functions available on PR332/P, trip units with PR330/D-M and EP010 - FBP - PDP22 are listed in the table below:

2

Communication functions	PR332/P +PR330/D-M	PR332/P+PR330/D-M and EP010
Protocol	Modbus RTU standard	FBP-PDP22
Physical means	RS485	Profibus-DP or DeviceNet cable
Speed (maximum)	19.2 kbps	115 kbps
<b>Measurement functions</b>		
Phase currents	☑	☑
Neutral current	☑	☑
Ground current	☑	☑
Voltage (phase-phase, phase-neutral, residual)	opt. <sup>(1)</sup>	opt. <sup>(1)(2)</sup>
Power (active, reactive, apparent)	opt. <sup>(1)</sup>	opt. <sup>(1)(3)</sup>
Power factor	opt. <sup>(1)</sup>	(4)
Frequency and peak factor	opt. <sup>(1)</sup>	(4)
Energy (active, reactive, apparent)	opt. <sup>(1)</sup>	(4)
Harmonic analysis	-	-
<b>Signalling functions</b>		
LED: auxiliary power supply, pre-alarm, alarm, transmission, reception	☑	☑
Temperature	☑	☑
Indication for L, S, I, G and other protection	☑	☑
<b>Available data</b>		
Circuit-breaker status (open, closed)	☑	☑
Circuit-breaker position (racked-in, racked-out)	☑	☑
Mode (local, remote)	☑	☑
Protection parameters set	☑	☑
Load control parameters	☑	☑
<b>Alarms</b>		
Protections: L, S, I, G	☑	☑
Undervoltage, overvoltage and residual voltage protection (timing and trip)	opt. <sup>(1)</sup>	opt. <sup>(1)</sup>
Reverse power protection (timing and trip)	opt. <sup>(1)</sup>	opt. <sup>(1)</sup>
Directional protection (timing and trip)	-	-
Underfrequency/overfrequency protection (timing and trip)	opt. <sup>(1)</sup>	opt. <sup>(1)</sup>
Phases rotation	-	-
Failed tripping under fault conditions	☑	☑
<b>Maintenance</b>		
Total number of operations	☑	☑
Total number of trips	☑	☑
Number of trip tests	☑	☑
Number of manual operations	☑	☑
Number of separate trips for each protection function	☑	☑
Contact wear (%)	☑	☑
Record data of last trip	☑	☑
<b>Commands</b>		
Circuit-breaker open/close	☑	☑
Alarms reset	☑	☑
Setting of curves and protection thresholds	☑	☑
Synchronize system time	☑	☑
<b>Events</b>		
Status changes in circuit-breaker, protections and all alarms	☑	☑

<sup>(1)</sup> with PR330/V  
<sup>(2)</sup> no residual voltage  
<sup>(3)</sup> no apparent power available  
<sup>(4)</sup> please ask ABB for further details

# Switch-disconnectors

## Electrical characteristics

The Tmax switch-disconnectors derive from the corresponding circuit-breakers, of which they keep the overall dimensions, versions, fixing systems and the possibility of mounting accessories unchanged.

This version only differs from the circuit-breakers in the absence of the protection trip units. They are characterised by a rated voltage of 690 V in alternating current and 750 V in direct current.

### Switch-disconnectors

				Tmax T1D
Conventional thermal current, I <sub>th</sub>		[A]		160
Rated service current in category AC22, I <sub>e</sub>		[A]		160
Rated service current in category AC23, I <sub>e</sub>		[A]		125
Poles		[No.]		3/4
Rated service voltage, U <sub>e</sub>	(AC) 50-60 Hz	[V]		690
	(DC)	[V]		500
Rated impulse withstand voltage, U <sub>imp</sub>		[kV]		8
Rated insulation voltage, U <sub>i</sub>		[V]		800
Test voltage at industrial frequency for 1 minute		[V]		3000
Rated short-circuit making capacity, I <sub>cm</sub>	(min) switch-disconnector only	[kA]		2.8
	(max) with circuit-breaker on supply side	[kA]		187
Rated short-time withstand current for 1s, I <sub>ow</sub>		[kA]		2
Reference Standard				IEC 60947-3
Versions				F
Terminals				FC Cu - EF - FC CuAl
Mechanical life		[No. operations]		25000
		[No. Hourly operations]		120
Basic dimensions, fixed	3 poles	W [mm]		76
	4 poles	W [mm]		102
		D [mm]		70
		H [mm]		130
Weight	fixed	3/4 poles	[kg]	0.9/1.2
	plug-in	3/4 poles	[kg]	-
	withdrawable	3/4 poles	[kg]	-

*Ch*

### Switch-disconnector coordination [380/415 V AC]

	T1		T2					T3		T4		T5 400					T5 630							
	B	C	N	N	S	H	L	N	S	N	S	H	L	V	N	S	H	L	V	N	S	H	L	V
I <sub>cu</sub> [kA]	16	25	36	36	50	70	85	36	50	36	50	70	120	200	36	50	70	120	200	36	50	70	120	200
T1D 160	16	25	36	36	50	70	85																	
T3D 250								36	50	36	50	70	120	200										
T4D 320										36	50	70	120	200										
T5D 400															36	50	70	120	200					
T5D 630																				36	50	70	120	200
T6D 630																								
T6D 800																								
T6D 1000																								
T7D 1000																								
T7D 1250																								
T7D 1600																								

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

# Switch-disconnectors

## Electrical characteristics

### Applications

They can be used as general circuit-breakers in sub-switchboards as switching and isolation parts for lines, busbars or groups of apparatus, or as bus-ties. They can be part of general isolation devices of groups of machines or of complexes for motor switching and protection.

### Isolation

The main function carried out by this apparatus consists of isolation of the circuit they are inserted in. Once the contacts are open they are at a distance which prevents an arc from striking, in accordance with the prescriptions in the standards regarding isolation behaviour. The position of the operating lever corresponds definitely with that of the contacts (positive operation).

### Protection

Each switch-disconnector must be protected on the supply side by a coordinated device which safeguards it against short-circuits. The coordination table below indicates the Tmax circuit-breaker which can carry out the protection function for each switch-disconnector. These are always pieces of apparatus of a size corresponding to or smaller than that of the switch disconnector.

### Making capacity

The making capacity Icm is a performance of notable importance since a switch-disconnector must be able to withstand the dynamic, thermal and current stresses which can occur during closure without being destroyed, up to the short-circuit closing conditions.


*Handwritten signatures and initials:*  
Cm  
J  
Pep  
MB

# Examples of curve readout

## Example 1 - T4N 250 Trip curves for power distribution (thermomagnetic trip unit)

Considering a T4N 250  $I_n = 250$  A circuit-breaker. By means of the thermal adjustment trimmer, the current threshold  $I_1$  is selected, for example at  $0.9 \times I_n$  (225 A); the magnetic trip threshold  $I_3$ , adjustable from 5 to  $10 \times I_n$ , we select at  $10 \times I_n$ , equal to 2500 A. It can be noted that, on the basis of the conditions in which the overload is presented, i.e. with the circuit-breaker at thermal running or not, the thermal relay trip varies considerably. For example, for an overload current of  $2 \times I_1$ , the trip time is between 21.4 and 105.3 s for hot trip, and between 105.3 and 357.8 s for cold trip.


For fault current values higher than 2500 A, the circuit-breaker trips instantaneously with the magnetic protection.



## Example 2 - T2S 160 Limitation curves

The following figure shows the trend of the  $T_{max}$  T2S 160,  $I_n = 160$  A circuit-breaker current-limiting curve. The r.m.s. of the prospective symmetrical short-circuit current is indicated on the abscissa of the diagram, whereas the peak short-circuit current value is indicated on the ordinates. The current-limiting effect can be assessed by comparing - at the same symmetrical short-circuit current value, the corresponding peak value at the prospective short-circuit current (curve A) with the limited peak value (curve B).

The T2S 160 circuit-breaker with thermomagnetic trip unit  $I_n = 160$  A at a voltage of 400 V limits the short-circuit current to 16.2 kA for a fault current of 40 kA, with a reduction of about 68 kA compared with the peak value of the 84 kA prospective short-circuit current.




## Example 3 - T3S 250 Specific let-through energy curves

An example of reading the graph of the specific let-through energy curve of the T3S 250  $I_n = 160$  A circuit-breaker at a voltage of 400 V is given below.

The prospective symmetrical short-circuit current is indicated on the abscissa of the diagram, whereas the ordinates show the specific let-through energy values expressed in  $A^2s$ .

In correspondence with a short-circuit current of 20 kA, the circuit-breaker lets through a value of  $I^2t$  equal to  $1.17 \cdot 10^6 \cdot A^2s$ .



- Abbreviations used
- $I_n$  = rated current of the thermomagnetic or electronic trip unit
  - $I_1$  = set trip current for overload
  - $I_3$  = trip current for short-circuit
  - $I_{cs}$  = prospective symmetrical short-circuit current



*[Handwritten signatures and scribbles]*

# Trip curves for power distribution Circuit-breakers with thermomagnetic trip units

T2 160 - TMD  
In = 125 A



T2 160 - TMD  
In = 160 A

4



T2 160 - TMG

T3 250 - TMD  
In = 63÷250 A





*Handwritten signatures and scribbles.*

# Trip curves for power distribution Circuit-breakers with thermomagnetic trip units


T5 400/630 – TMG  
In = 320÷500 A

T6 630 – TMA  
In = 630 A

4



T6 800 – TMA  
In = 800 A



*Cu*

*[Handwritten signature]*


*[Handwritten signature]*

*[Handwritten signature]*

# Trip curves for power distribution Circuit-breakers with electronic trip units


T4 250/320 - T5 400/630 - T6 630/800/1000  
PR221DS  
L-S Functions

Note: For T4 In = 320 A, T5 In = 630 A and T6 In = 1000 A  $\Rightarrow I_{max} = 9.5 \times I_n$




T4 250/320 - T5 400/630 - T6 630/800/1000  
PR222DS - PR222DS/PD - PR223DS  
L-S-I Functions


Note: The dotted curve of function L corresponds to the maximum delay (t<sub>l</sub>) which can be set at 6 x I<sub>n</sub> in the case where 320 A CTs are used for T4 and 630 A for T5. For all the CT sizes t<sub>l</sub> = 18s except with 320 A CT (T4), 630 A CT (T5) and 1000 A CT (T6) where t<sub>l</sub> = 10.5s. For T4 In = 320 A, T5 In = 630 A and T6 In = 1000 A  $\Rightarrow I_{max} = 9.5 \times I_n$ , I<sub>max</sub> = 9.5 x I<sub>n</sub>. For T6 In = 800 A  $\Rightarrow I_{max} = 10.5 \times I_n$ . For PR223DS the L protection function can be set to I<sub>l</sub> = 0.18...1 x I<sub>n</sub>.



T4 250/320 - T5 400/630 - T6 630/800/1000  
PR222DS - PR222DS/PD - PR223DS  
G Function



T7 800/1000/1250/1600 - PR231/P  
L-I Functions




# Trip curves for power distribution Circuit-breakers with electronic trip units

T7 800/1000/1250/1600 – PR332/P

L-I Functions


Note: For T7 In = 1250 A, 1600 A ⇒ I<sub>max</sub> = 12 x In



T7 800/1000/1250/1600 – PR332/P


L-S-I Functions

Note: For T7 In = 1250 A, 1600 A ⇒ I<sub>max</sub> = 12 x In




T7 800/1000/1250/1600 – PR332/P

G Function



T7 800/1000/1250/1600 – PR332/P

Rc Function




*Handwritten signature*




# Trip curves for power distribution Circuit-breakers with electronic trip units

T7 800/1000/1250/1600  
PR332/P with PR330/V  
UV Function


4




T7 800/1000/1250/1600  
PR332/P with PR330/V  
OV Function



T7 800/1000/1250/1600  
PR332/P with PR330/V  
RV Function



T7 800/1000/1250/1600  
PR332/P with PR330/V  
RP Function



*[Handwritten signatures and scribbles]*

# Wiring diagrams

## Information for reading - Circuit-breakers T1...T6

### State of operation represented

The diagram is shown in the following conditions:

- plug-in version circuit-breaker open and racked-in
- contactor for motor starting open
- circuits de-energised
- trip units not tripped
- motor operator with springs charged.

### Version

The diagram shows a circuit-breaker or switch-disconnector in the plug-in version (only T2, T3, T4 and T5) or in the withdrawable version (T6). The diagram is also valid for the fixed and withdrawable version circuit-breakers or switch-disconnectors.

With the fixed version circuit-breakers or switch-disconnectors, the applications indicated in figures 26-27-28-29-30-31 and 32 cannot be provided.

### Caption

- = Figure number of the diagram
- \* = See note indicated by the letter
- A1 = Circuit-breaker applications
- A11 = FDU interfacing unit (front display)
- A12 = AUX-E type signalling unit, with auxiliary relays for electrical signalling of circuit-breaker open and circuit-breaker tripped
- A13 = PR021/K type signalling unit, with auxiliary relays for electrical signalling of the protection functions of electronic trip unit
- A14 = MOE-E type actuation unit, with auxiliary relays for carrying out the commands coming from the dialogue unit
- A15 = PR212/CI type contactor control unit for motor starting
- A16 = Solenoid operating mechanism
- A17 = Unit for M motor electrical latching
- A18 = VM210 type voltage measuring unit
- A2 = Applications of the solenoid operator or motor operator
- A3 = Applications of the RC221, RC222 or RC223 type residual current release
- A4 = Indication apparatus and connections for control and signalling, outside the circuit-breaker
- D = Electronic time-delay device of the undervoltage release (outside the circuit-breaker)

- H, H1 = Signalling lamps
- K = Contactor for motor starting
- K51 = Electronic trip unit:
  - PR221 type overcurrent release, with the following protection functions:
    - L against overload with inverse long time delay
    - S against short-circuit with inverse or definite short time delay
    - I against short-circuit with instantaneous trip
  - PR222DS/P, PR222DS/PD, PR223DS or PR223EF, type overcurrent release, with the following protection functions:
    - L against overload with inverse long time delay
    - S against short-circuit with inverse or definite short time delay
    - I against short-circuit with instantaneous trip time
    - G against earth fault with short time trip
  - EFD protection (Earth Fault Detector Prevention) for PR223EF trip unit only
  - PR222MP motor protection type trip unit, with the following protection functions:
    - against overload (thermal protection)
    - against rotor block
    - against short-circuit
    - against missing or unbalanced current between the phases
- K51/1...8 = Contact for electrical signalling of the protection functions of the electronic trip unit
- K87 = RC221, RC222 or RC223 type residual current trip unit
- M = Motor for circuit-breaker opening and circuit-breaker closing spring charging
- M1 = Three-phase asynchronous motor
- Q = Main circuit-breaker
- Q/0,1,2,3 = Auxiliary circuit-breaker contacts
- R = Resistor (see note F)
- R1 = Motor thermistor
- R2 = Thermistor in the motor operator
- S1, S2 = Contacts controlled by the cam of the motor operator
- S3, S3/1 = Change-over contact for electrical signalling of local/remote selector status
- S4/1-2 = Contacts activated by the circuit-breaker rotary handle (see note C)
- S51/S = Contact for electrical signalling of overload in progress (start)

# Wiring diagrams

## Information for reading - Circuit-breakers T1...T6

### Description of figures

- Fig. 1 = Opening release.
- Fig. 2 = Permanent opening release.
- Fig. 3 = Instantaneous undervoltage release (see note B and F).
- Fig. 4 = Undervoltage release with electronic time-delay device outside the circuit-breaker (see note B).
- Fig. 5 = Instantaneous undervoltage release in version for machine tools with one contact in series (see note B, C, and F).
- Fig. 6 = Instantaneous undervoltage release in version for machine tools with two contacts in series (see note B, C, and F).
- Fig. 7 = One changeover contact for electrical signalling of circuit-breaker open due to RC221, RC222 or RC223 type residual current release trip.
- Fig. 8 = RC222 or RC223 type residual current release circuits.
- Fig. 9 = Two electrical signalling contacts for RC222 or RC223 type residual current release pre-alarm and alarm.
- Fig. 10 = Solenoid operator.
- Fig. 11 = Stored energy motor operator.
- Fig. 12 = Local/remote auxiliary contact for stored-energy motor operating mechanism.
- Fig. 21 = Three changeover contacts for electrical signalling of circuit-breaker open or closed and one changeover contact for electrical signalling of circuit-breaker open due to YO, YO1, YO2 and YU thermomagnetic trip unit intervention (tripped position).
- Fig. 22 = One changeover contact for electrical signalling of circuit-breaker open or closed and a changeover contact for electrical signalling of circuit-breaker open due to YO, YO1, YO2 or YU the thermomagnetic trip unit intervention (tripped position).
- Fig. 23 = Two changeover contacts for electrical signalling of circuit-breaker open or closed.
- Fig. 24 = One changeover contact for electrical signalling of circuit-breaker open due to overcurrent release trip (T2-T6).
- Fig. 25 = One contact for electrical signalling of circuit-breaker open due to overcurrent release trip (T4-T5).
- Fig. 26 = First position of circuit-breaker changeover contact, for electrical signalling of racked-in.
- Fig. 27 = Second position of circuit-breaker changeover contact, for electrical signalling of racked-in.
- Fig. 28 = Third position of circuit-breaker changeover contact, for electrical signalling of racked-in.
- Fig. 29 = First position of circuit-breaker changeover contact, for electrical signalling of isolated.
- Fig. 30 = Second position of circuit-breaker changeover contact, for electrical signalling of isolated.
- Fig. 31 = Third position of circuit-breaker changeover contact, for electrical signalling of isolated.
- Fig. 32 = Circuit of the current transformer on neutral conductor outside the circuit-breaker (for plug-in and withdrawable version circuit-breaker).
- Fig. 39 = Auxiliary circuits of the PR223DS trip units connected to VM210 voltage measuring unit.
- Fig. 40 = Auxiliary circuits of the PR223EF trip units connected to VM210 voltage measuring unit.
- Fig. 41 = Auxiliary circuits of the PR222DS/P, PR222DS/PD, PR223DS or PR223EF electronic trip unit connected with FDU front display unit.
- Fig. 42 = Auxiliary circuits of the PR222DS/PD, PR223DS or PR223EF electronic trip unit connected with PR021/K type signalling unit.
- Fig. 43 = Auxiliary circuits of the PR222DS/PD, PR223DS or PR223EF electronic trip unit connected with FDU front display unit and with PR021/K type signalling unit.
- Fig. 44 = Auxiliary circuits of the PR222DS/PD, PR223DS or PR223EF electronic trip unit connected with the AUX-E auxiliary contacts.
- Fig. 45 = Auxiliary circuits of the PR222DS/PD, PR223DS or PR223EF electronic trip unit connected with the auxiliary contacts AUX-E and with MOE-E type actuation unit.
- Fig. 46 = Auxiliary circuits of the PR222DS/PD, PR223DS or PR223EF electronic trip unit connected with FDU front display unit and with the AUX-E auxiliary contacts.
- Fig. 47 = Auxiliary circuits of the PR222MP electronic trip unit connected with PR021/K signalling unit (see note I).
- Fig. 48 = Auxiliary circuits of the PR222MP electronic trip unit connected with PR021/K signalling unit and with PR212/CI type contactor control unit for motor starting (see note I).
- Fig. 49 = Auxiliary circuits of the PR222MP electronic trip unit connected with PR021/K signalling unit and with PR212/CI type contactor control unit and an ABB series AF contactor (see note I).
- Fig. 51 = Auxiliary circuit of the PR222MP trip unit connected to SACE PR212/CI motor starting contactor control unit and 24 V DC auxiliary supply (see note I).

# Wiring diagrams

## Information for reading - Circuit-breakers T7

### Warning

Before installing the circuit-breaker, carefully read notes F and O on the circuit diagrams.

### Operating status shown

The circuit diagram is for the following conditions:

- withdrawable circuit-breaker, open and racked-in
- circuits de-energised
- releases not tripped
- motor operating mechanism with springs discharged.



### Versions

Though the diagram shows a circuit-breaker in withdrawable version, it can be applied to a fixed version circuit-breaker as well.

#### Fixed version

The control circuits are fitted between terminals XV (connectors X12-X13-X14-X15 are not supplied). With this version, the applications indicated in figure 31A cannot be provided.

#### Withdrawable version

The control circuits are fitted between the poles of connectors X12-X13-X14-X15 (terminal box XV is not supplied).

#### Version without overcurrent release

With this version, the applications indicated in figures 13A, 14A, 41A, 42A, 43A, 44A, 45A, 62A cannot be provided.

#### Version with PR231/P or PR232/P electronic trip unit

With this version, the applications indicated in figures 41A, 42A, 43A, 44A, 45A, 62A cannot be provided.

#### Version with PR331/P electronic trip unit

With this version, the applications indicated in figures 42A, 43A, 44A, 45A cannot be provided.

#### Version with PR332/P electronic trip unit

With this version, the applications indicated in figure 41A cannot be provided.

### Caption

□	= Circuit diagram figure number
*	= See note indicated by letter
A1	= Circuit-breaker accessories
A3	= Accessories applied to the fixed part of the circuit-breaker (for withdrawable version only)
A4	= Example switchgear and connections for control and signalling, outside the circuit-breaker
A13	= PR021/K signalling unit (outside the circuit-breaker)
A19	= PR330/R actuation unit
AY	= SOR TEST UNIT Test/monitoring Unit (see note R)
D	= Electronic time-delay device of the under-voltage release, outside the circuitbreaker
K51	= PR231/P, PR232/P, PR331/P, PR332/P type electronic trip unit with the following protection functions: <ul style="list-style-type: none"> <li>- L overload protection with inverse long time-delay trip - setting <math>I_1</math></li> <li>- S short-circuit protection with inverse or definite short time-delay trip - setting <math>I_2</math></li> <li>- I short-circuit protection with instantaneous time-delay trip - setting <math>I_3</math></li> <li>- G earth fault protection with inverse short time-delay trip - setting <math>I_4</math></li> </ul>
K51/1...8	= Contacts of the PR021/K signalling unit
K51/GZin (DBin)	= Zone selectivity: input for protection G or "reverse" direction input for protection D (only with Uaux. and PR332/P trip unit)
K51/GZout (DBout)	= Zone selectivity: output for protection G or "reverse" direction output for protection D (only with Uaux. and PR332/P trip unit)
K51/SZin (DFin)	= Zone selectivity: input for protection S or "direct" input for protection D (only with Uaux. and PR332/P trip unit)
K51/SZout (DFout)	= Zone selectivity: output for protection S or "direct" output for protection D (only with Uaux. and PR332/P trip unit)
K51/YC	= Closing control from PR332/P electronic trip unit with communication module PR330/D-M and PR330/R actuation unit
K51/YO	= Opening control from PR332/P electronic trip unit with communication module PR330/D-M and PR330/R actuation unit
M	= Motor for charging the closing springs
Q	= Circuit-breaker
Q/1...6	= Circuit-breaker auxiliary contacts

*[Handwritten signatures and initials]*

# Wiring diagrams

## Information for reading - Circuit-breakers T7

### Description of figures

- Fig. 1A = Motor circuit to charge the closing springs.  
Fig. 2A = Circuit of shunt closing release.  
Fig. 4A = Shunt opening release.  
Fig. 6A = Instantaneous undervoltage release (see notes B, C and Q).  
Fig. 7A = Undervoltage release with electronic time-delay device, outside the circuit-breaker (see notes B and Q).  
Fig. 8A = Second shunt opening release (see note Q).  
Fig. 11A = Contact for electrical signalling of springs charged or discharged.  
Fig. 12A = Contact for electrical signalling of circuit-breaker open, with springs charged, and ready to close.  
Fig. 13A = Contact for electrical signalling of circuit-breaker open due to tripping of the overcurrent release. The circuit-breaker may be closed only after pressing the reset pushbutton, or after energizing the coil for electronic reset (if available).  
Fig. 14A = Electrical reset control.  
Fig. 15A = Contact operated by the circuit-breaker rotary handle – for circuit-breakers with manual control only (see note C).  
Fig. 21A = Circuit-breaker auxiliary contacts (for circuit-breakers with manual control only).  
Fig. 22A = Circuit-breaker auxiliary contacts (for circuit-breakers with motor control only).  
Fig. 31A = First set of contacts for electrical signalling of circuit-breaker in racked-in, test isolated, racked out position.  
Fig. 41A = Auxiliary circuits of PR331/P trip unit (see note F).  
Fig. 42A = Auxiliary circuits of PR332/P trip units (see notes F and N).  
Fig. 43A = Circuits of the measuring module PR330/V of the PR332/P trip units internally connected to the circuit-breaker (optional).  
Fig. 44A = Circuits of the measuring module PR330/V of the PR332/P trip units externally connected to the circuit-breaker (optional; see note O).  
Fig. 45A = Circuits of the PR332/P trip unit with communication module PR330/D-M connected to PR330/V actuation unit (see notes E, F and N).  
Fig. 46A = Circuits of the PR332/P trip unit PR330/V measuring module connected internally to the three-pole circuit-breaker with external neutral conductor (optional).  
Fig. 61A = SOR TEST UNIT Test/monitoring unit (see note R).  
Fig. 62A = Circuits of the PR021/K signalling module (outside the circuit-breaker).

### Incompatibilities

The circuits indicated in the following figures cannot be supplied simultaneously on the same circuit-breaker:

- 6A - 7A - 8A  
21A - 22A  
41A - 42A - 45A  
43A - 44A - 46A

### Notes

- A) The circuit-breaker is only fitted with the applications specified in the ABB SACE order confirmation. To make out the order, please consult this catalogue.
- B) The undervoltage release is supplied for operation using a power supply branched on the supply side of the circuit-breaker or from an independent source. The circuit-breaker can only close when the release is energized (there is a mechanical lock on closing).
- C) In conformity with the Standards governing machine tools, contacts S4 shown in Fig. 15A can be used to open the Yu undervoltage release circuit (Fig. 6A) when the circuit-breaker is open and close it again upon a manual closing command from the rotary handle.
- E) For the EIA RS485 serial interface connection see document RH0298 regarding MODBUS communication.
- F) The auxiliary voltage Vaux allows actuation of all operations of the PR331/P, PR332/P and trip units. Having requested a Vaux insulated from earth, one must use "galvanically separated converters" in compliance with IEC 60950 (UL 1950) or equivalent standards that ensure a common mode current or leakage current (see IEC 478/1, CEI 22/3) not greater than 3.5 mA, IEC 60364-41 and CEI 64-8.
- G) Earth fault protection is available with the PR332/P trip unit by means of a current sensor located on the conductor connecting to earth the star centre of the MV/LV transformer.  
The connections between terminals 1 and 2 (or 3) of current transformer UI/O and poles T7 and T8 of the X (or XV) connector must be made with a two-pole shielded and stranded cable (see user manual), no more than 15 m long. The shield must be earthed on the circuit-breaker side and current sensor side.
- N) With PR332/P trip unit, the connections to the zone selectivity inputs and outputs must be made with a two-pole shielded and stranded cable (see user manual), no more than 300 m long. The shield must be earthed on the selectivity input side.

# Wiring diagrams

## Information for reading - ATS021-ATS022 for T3-T4-T5-T6-T7

### State of operation represented

The diagram indicates the following conditions:

- circuit-breakers off and connected #
- circuits de-energized
- overcurrent relays not tripped \*
- motor operator with charged springs (for T4-T5-T6 circuit-breakers)
- closing springs charged (for T7-X1-EMAX circuit-breakers).

# The diagram indicates circuit-breakers in plug-in or withdrawable version but it may be applied also to circuit-breakers in fixed version: in this case it's not necessary connect S75/1 contacts to the input X31:1 of ATS021 device or it's necessary connect the terminals X32:5 and X32:6 to the terminal X32:9 of ATS022 device.

\* The diagram indicates circuit-breakers equipped with overcurrent relay but it may be applied also to circuit-breakers without overcurrent relay (switch-disconnectors). If SY (or S51) contact is not foreseen it's necessary not consider SY /or S51) contacts to the input X31:1 of ATS021 device or it's necessary connect the terminals X32:7 and X32:8 to the terminal X32:9 of AT022 device.

- Q61/1-2 = Miniature breakers with thermomagnetic overcurrent relay for isolation and protection of the lines auxilliary circuits
- S11 = Contact for the automatic transfer enabling in the ATS021 device
- S11...S15 = Contacts for the ATS022 device inputs
- S1-S2 = Contacts controlled by the cam of the motor operator
- S3 = Change-over contact for electrical signalling of local/remote selector status
- S33M/1 = Limit contact for spring-charging motor
- S51 = Contact for electrical signalling of circuit-breaker open due to tripping of the overcurrent trip unit
- S75/1 = Contact signalling circuit-breaker connected #
- SY = Contact signalling circuit-breaker tripped through releases operation (tripped position) \*
- W1 = Serial interface with control system (MODBUS EIA RS485 interface) available with ATS022 device
- X = Delivery connector for the auxilliary circuits of EMAX withdrawable version circuit-breaker
- X12-X15 = Delivery connectors for the auxilliary circuits of T7-X1 withdrawable version circuit-breaker
- X2-XA.. = Connectors for T3-T4-T5-T6 circuit-breakers auxilliary circuits
- XF = Delivery terminal board for the position contacts of the circuit-breaker
- XV = Delivery terminal board for the auxilliary circuits of T7-X1-EMAX fixed circuit-breakers
- XV = Terminal boxes of the applications (for T3-T4-T5-T6 circuit-breakers)
- YC = Closing release
- YO = Opening release

### Caption

- A = Devices type ATS021 and ATS022 for the automatic transfer switch of two circuit-breakers
- A16 = Solenoid operating mechanism (for T3 circuit-breakers)
- A17 = Unit for M motor electrical latching (for T4-T5-T6 circuit-breakers)
- CB1-N = Circuit-breakers for normal supply line
- CB2-E = Circuit-breakers for emergency supply line
- K1 = Auxiliary contactor type NF22E for the normal supply voltage presence
- K2 = Auxiliary contactor type NF22E for the emergency supply voltage presence
- KC1-KC2 = Auxiliary contactors type AL\_\_-30 for circuit-breakers closing
- KO1-KO2 = Auxiliary contactors type AL\_\_-30 for circuit-breakers opening
- M = Closing springs charging motor (for T7-X1-EMAX circuit-breakers)
- M = Motor for opening the circuit-breaker and loading the closing springs of the circuit-breaker (for T4-T5-T6 circuit-breakers)
- Q/1 = Circuit-breaker auxiliary contact
- Q60 = Miniature breaker with thermomagnetic overcurrent relay for isolation and protection of safety auxiliary voltage supply circuit

*Handwritten signature*

*Handwritten signature*


*Handwritten signature*

*Handwritten signature*


# Wiring diagrams

## Wiring diagram of the T1...T6 circuit-breakers


### State of operation




Three-pole or four-pole circuit-breaker with thermomagnetic trip unit




Three-pole circuit-breaker with magnetic trip unit



Three-pole or four-pole switch-disconnector (on-load isolating switch)




Three-pole or four-pole circuit-breaker with PR221 electronic trip unit




Three-pole or four-pole circuit-breaker with PR222DS/P, PR222DS/PD, PR223DS or PR223EF electronic trip unit (for T4, T5 and T6)

*Ca*



Three-pole circuit-breaker with PR222MP electronic trip unit



Three-pole or four-pole circuit-breaker with RC221, RC222 or RC223 residual current trip unit


*M*

*[Handwritten signatures]*


# Wiring diagrams

## Wiring diagram of the T7 circuit-breakers


### State of operation



Three-pole circuit-breaker with PR231/P, PR232/P, PR331/P, PR332/P electronic trip unit



Three- or four-pole switch-disconnector




Four-pole circuit-breaker with PR231/P, PR232/P, PR331/P, PR332/P electronic trip unit



# Wiring diagrams

## Electrical accessories for T1...T6


### Shunt opening and undervoltage releases



1SDC210006F0001

*Cu*

### Residual current releases and remote controls




1SDC210006F0001

*[Handwritten signatures]*


# Wiring diagrams

## Electrical accessories for T1...T6

PR223DS electronic trip unit connected with the VM210 voltage measuring device



PR223EF electronic trip unit connected with the VM210 voltage measuring device



*Handwritten signature*


*Handwritten initials*

*Handwritten signature*


# Wiring diagrams

## Electrical accessories for T1...T6

PR222DS/PD, PR223DS or PR223EF electronic trip unit connected with the FDU front display unit and the PR021/K signalling unit



PR222DS/PD, PR223DS or PR223EF electronic trip unit connected with the AUX-E auxiliary contacts




*Handwritten signatures and initials:*  
 A  
 J  
 J

# Wiring diagrams


## Electrical accessories for T1...T6

PR222MP electronic trip unit connected with the PR021/K signalling unit



1SDC210015D0207

PR222MP electronic trip unit connected with the PR021/K signalling unit and with the PR212/CI contactor control unit



<sup>1)</sup> As an alternative to generic contact Q/1


1SDC210015D0207

*Handwritten signatures and initials:*  
 A  
 [Signature]  
 [Signature]

# Wiring diagrams

## Electrical accessories for T1...T6

PR222MP electronic trip unit with auxiliary power supply and PR212/CI contactor control unit



*Ca*


*Ca*

*[Handwritten signature]*


*[Handwritten signature]*

# Wiring diagrams Electrical accessories for T7

## Signalling contacts




## Auxiliary circuits of the PR331/P and PR332/P trip units



# Wiring diagrams

## Electrical accessories for T7

PR021/K signalling unit for PR331/P and PR332/P



1SDC210D02010001

*Am*

*Am*


*Am*

*Am*

# Wiring diagrams

## Automatic transfer-switch ATS021-ATS022 for T3-T4-T5-T6

ATS021-ATS022 device for the automatic transfer switch of two T3 circuit-breakers without safety auxiliary voltage supply



*Handwritten signature*


*Handwritten initials and signature*




# Wiring diagrams

## Automatic transfer-switch ATS021-ATS022 for T3-T4-T5-T6

ATS021-ATS022 device for the automatic transfer switch of two T4-T5-T6 circuit-breakers with safety auxiliary voltage supply in alternating current (AC)



ATS021-ATS022 device for the automatic transfer switch of two T4-T5-T6 circuit-breakers with safety auxiliary voltage supply in direct current (DC)




*Handwritten signatures and marks:*  
 A large handwritten mark resembling a stylized 'Z' or '2' with a long tail.  
 A signature that looks like '01' or '04'.  
 A signature that looks like 'llb'.

# Wiring diagrams

## Automatic transfer-switch ATS021-ATS022 for T7

Automatic transfer-switch ATS021-ATS022 for the automatic transfer switch of the two T7 circuit-breakers, without safety auxiliary voltage supply



1SDC210015D0207

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

AM

AM

AM





# Overall dimensions Tmax T1 and single-pole Tmax T1

## Fixed circuit-breaker

6





Fixing on sheet

Fixing on DIN EN 50022 rail



Without inserts

With inserts



T1 1P (SINGLE-POLE)


T1 1P (SINGLE-POLE)

### Caption


- ① Depth of the switchboard in the case of circuit-breaker with face not extending from the compartment door, with or without flange
- ② Depth of the switchboard in the case of circuit-breaker with face extending from the compartment door, without flange
- ③ Bracket for fixing onto rail
- ④ Bottom terminal covers with IP40 degree of protection

### Drilling templates for support sheet

For front terminals




3 POLES




4 POLES

Without inserts

With inserts




T1 1P (SINGLE-POLE)



# Overall dimensions Tmax T1 and single-pole Tmax T1


Terminals

Flange for the compartment door




## Drilling templates of the compartment door


6




With flange and circuit-breaker face flush with door (3-4 POLES)



Without flange and circuit-breaker face flush with door (3-4 POLES) or extending (3 POLES)




(SINGLE-POLE)




Without flange and circuit-breaker face extending (4 POLES)

## Drilling templates for support sheet

For rear terminals



3 POLES



4 POLES


*Cu*

*Handwritten signatures and initials.*


# Overall dimensions Tmax T2

## Terminals


Front - F



Front for copper cables - FC Cu




Front for copper/aluminium cables  
- FC CuAl 95 mm<sup>2</sup>



### Caption

- ① Front extended terminals
- ② Front terminals for cables 185 mm<sup>2</sup> CuAl
- ③ Insulating course plate (compulsory)
- ④ High terminal covers with degree of protection IP40 (compulsory)
- ⑤ Drilling templates for support sheet


Front for copper/aluminium cables - FC CuAl 185 mm<sup>2</sup>



### Caption

- ① Insulating barriers between phases (compulsory)

Front extended spread - ES




# Overall dimensions Tmax T3

## Fixed circuit-breaker

Fixing on sheet

Fixing on DIN EN 50022 rail




Caption

- ① Depth of the switchboard in the case of circuit-breaker with face not extending from the compartment door, with or without flange
- ② Depth of the switchboard in the case of circuit-breaker with face extending from the compartment door
- ③ Bracket for fixing on rail
- ④ Low terminal covers with degree of protection IP40

### Flange for compartment door

### Drilling templates of the compartment door



With flange and circuit-breaker face flush with door (3-4 POLES)


Without flange and circuit-breaker face flush with door (3-4 POLES)

Without flange and circuit-breaker face extending (3 POLES)

Without flange and circuit-breaker face extending (4 POLES)

### Drilling templates for support sheet


For front terminals



3 POLES

4 POLES

For rear terminals



3 POLES

4 POLES


# Overall dimensions Tmax T3

## Terminals

### Caption

- ① High terminal covers with degree of protection IP40
- ② Insulating barriers between phases (compulsory without 1)


Front extended - EF



### Caption

- ① Low terminal covers with degree of protection IP40

Rear horizontal - R



*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

6





# Overall dimensions


## Tmax T4

### Terminals



Front - F



Front for copper cables - FC Cu





Front for copper/aluminium cables - FC CuAl



### Caption

- ① Front terminals for cable connection 2x150 mm<sup>2</sup>
- ② Front terminals for multicable connection
- ③ High terminal covers with degree of protection IP40




Front multicable - MC



### Caption

- ① Insulating barriers between phases (compulsory)

Front extended spread - ES





# Overall dimensions Tmax T5

## Fixed circuit-breaker


### Caption

### Fixing on sheet



- ① Overall dimensions with cabled accessories mounted (SOR-C, UVR-C, RC222)
- ② Overall dimensions with cabled auxiliary contacts mounted (only 3Q 1SY)



### Flange for compartment door



### Drilling templates of the compartment door





With flange  
(3-4 POLES)

Without flange  
(3-4 POLES)

### Drilling templates for support sheet



#### For front terminals



3 POLES


4 POLES

#### For rear terminals



3 POLES

4 POLES




# Overall dimensions Tmax T5

## Terminals

### Caption

- ① Insulating barriers between phases (compulsory)

Front extended spread - ES




6

### Caption

- ① High terminal covers with degree of protection IP40
- ② Insulating barriers between phases (compulsory without 1)

Front extended - EF




*Ch*

### Caption

- ① Low terminal covers with degree of protection IP40

Rear horizontal - R




*[Handwritten signatures and marks]*


# Overall dimensions Tmax T6

## Fixed circuit-breaker Drilling templates for support sheet


For rear terminals for copper/aluminium cables - RC CuAl




630 A (3 POLES)



630 A (4 POLES)





800 A (3 POLES)



800 A (4 POLES)

For rear terminals - R



6







*Handwritten signatures and marks:*

- A large handwritten signature 'C' is located to the right of the 800 A (4 POLES) diagram.
- Two large handwritten signatures are located at the bottom right of the page.

# Overall dimensions Tmax T6

## Terminals




Front extended - EF



**Caption**

- ① Insulating barriers between phases (compulsory)

Front extended spread - ES




6



# Overall dimensions Tmax T7

## Terminals

Rear horizontal - R




*CM*

### Caption

- ① Rear horizontal terminals
- ② Rear vertical terminals
- ⑥ Drilling template for fixing onto support sheet
- ⑦ Tightening torque: 20 Nm

### Drilling templates for support sheet



	III	IV
B	70	140
C	192.5	262.5

*Handwritten signatures and initials.*

# Overall dimensions




## Tmax T7

### Terminals

Front for copper/aluminium cables - FC CuAl 2x240 mm<sup>2</sup>

**Caption**




- ① Front terminals for cables FC CuAl
- ② Tightening torque: 43 Nm
- ⑥ Drilling template for fixing onto support sheet
- ⑦ Tightening torque: 18 Nm
- ⑧ Protection plate



1SDC210015D0207

*Cu*

Front for copper/aluminium cables - FC CuAl 4x240 mm<sup>2</sup>






1SDC210015D0207

*af*  
*ME*



# Overall dimensions Tmax T7M

Rear flat horizontal or vertical - HR/VR




1SDC21015D0207

*cu*

### Caption

- ① Rear horizontal terminals
- ② Rear vertical terminals
- ⑥ Drilling template for fixing onto support sheet
- ⑦ Tightening torque 20 Nm

### Drilling templates for support sheet



1SDC21015D0207

*Be*

	III	IV
B	70	140
C	192.5	262.5


*Handwritten signatures and marks at the bottom right of the page.*

# Overall dimensions Tmax T7M


## Caption

- ① Front extended spread terminals - ES
- ② Tightening torque 18 Nm
- ③ Phase separators 200 mm
- ④ Protection plate
- ⑤ Extended front terminals - EF
- ⑥ Phase separators 100 mm
- ⑬ Overall dimensions of auxiliary contact terminal

### Front extended spread - ES



### Front extended - EF




# Overall dimensions Tmax T2

## Plug-in circuit-breaker

Fixing on sheet

### Caption

- ① Depth of the switchboard in the case of circuit-breaker with face not extending from the compartment door, with or without flange
- ② Depth of the switchboard in the case of circuit-breaker with face extending from the compartment door, without flange
- ③ Fixed part
- ④ Moving part with terminal covers, degree of protection IP40








6

### Flange for compartment door

### Drilling templates of the compartment door

*Cur*



With flange and circuit-breaker face flush with door (3-4 POLES)


Without flange and circuit-breaker face flush with door (3-4 POLES)

Without flange and circuit-breaker face extending (3 POLES)

Without flange and circuit-breaker face extending (4 POLES)

### Drilling templates for support sheet


For front terminals



3 POLES

4 POLES

For rear terminals



3 POLES

4 POLES


*Handwritten signature*

# Overall dimensions Tmax T2

**Caption**

- ① High terminal covers with degree of protection IP40
- ② Insulating barriers between phases (comptory without 1)

Front extended - EF




6

**Caption**

- ① Low terminal covers with degree of protection IP40

Rear horizontal - R



*Handwritten signature*

*Handwritten signature*

*Handwritten signature*





# Overall dimensions Tmax T3

## Terminals

Front - F

Front for copper cables - FC Cu






Front for copper/aluminium cables - FC CuAl 185 mm<sup>2</sup>



Caption

Front for copper/aluminium cables - FC CuAl 240 mm<sup>2</sup>

- ① Front extended terminals
- ② Front terminals for cables 240 mm<sup>2</sup> CuAl
- ③ Insulating courtse plate (compulsory)
- ④ High terminal covers with degree of protection IP40
- ⑤ Drilling templates for support sheet






3 POLES

4 POLES

Caption

Front extended spread - ES

- ① Insulating barriers between phases (compulsory)




# Overall dimensions Tmax T4

## Plug-in circuit-breaker


### Caption

- ① Fixed part
- ② Moving part with terminal covers, degree of protection IP40
- ③ Overall dimensions with cabled accessories mounted (SOR-C, UVR-C, RC222-223)
- ④ Overall dimensions with cabled auxiliary contacts mounted (only 3Q 1SY)


Fixing on sheet



Flange for compartment door




Drilling templates of the compartment door




## Drilling templates for support sheet

For front terminals





For rear terminals





# Overall dimensions Tmax T4

Rear flat vertical - VR



3-4 POLES

Rear flat horizontal - HR



3-4 POLES

*Ch*

*Ch*


*[Handwritten signature]*

6


# Overall dimensions Tmax T5

## Terminals

Front extended 400 A - EF



Front extended 630 A - F





6

### Caption

- ① Front terminals for cables Cu
- ② Front terminals for cables Cu/Al
- ③ High terminal covers with degree of protection IP40

Front for copper cables - FC Cu or for copper/aluminium cables - FC CuAl






*Cu*

### Caption

- ① Insulating barriers between phases (compulsory)

Front extended spread 630 A - ES



*ES*

*[Handwritten signatures]*




# Overall dimensions Tmax T4


## Withdrawable circuit-breaker Fixing on sheet

### Caption


- ① Fixed part
- ② Moving part
- ③ Lock for compartment door (available on request)
- ④ Overall dimensions with cabled accessories mounted (SOR-C, UVR-C, RC222-223)



### Flange for compartment door





### Drilling templates of the compartment door





### Drilling templates for support sheet

#### For front terminals



#### For rear terminals





04

*[Handwritten signature]*

# Overall dimensions Tmax T5

## Withdrawable circuit-breaker


## Fixing on sheet




### Caption

- ① Fixed part
- ② Moving part with terminal covers, degree of protection IP40
- ③ Lock for compartment door (available on request)
- ④ Overall dimensions with cabled accessories mounted (SOR-C, UVR-C, RC222)

### Flange for compartment door




### Drilling templates of the compartment door




### Drilling templates for support sheet

For front terminals 400 A



For front terminals 630 A  
For rear terminals 400 A - 630 A





	A	B	C	D	E
Rear 400 A	32.5	128.5	143	172.5	64.5
Front and rear 630 A	61.8	139	142	185.5	69.5



# Overall dimensions Tmax T5

Rear flat horizontal 400 A - HR

Rear flat vertical 400 A - VR







6



*Handwritten signature*

Rear flat horizontal 630 A - HR

Rear flat vertical 630 A - VR



*Handwritten signature*


*Handwritten signature*

# Overall dimensions


## Tmax T6 630 A - T6 800 A

### Terminals

Front extended - EF




Rear flat horizontal - HR



3-4 POLES

Rear flat vertical - VR



3-4 POLES

*Ch*

*04*


*[Handwritten signature]*

*[Handwritten signature]*

# Overall dimensions Tmax T7

## Withdrawable circuit-breaker


Front extended spread - ES




### Caption

- ① Drilling a hole in the sheet metal door to the compartment with the flange for the RS-VR-HR-EF-ES terminals
- ② Rear segregation for rear terminals
- ④ Flange fixing screws
- ⑤ Tightening torque: 1.5 Nm
- ⑥ Drilling template for fixing onto support sheet
- ⑧ Front terminals
- ⑪ Rear segregation for front terminals
- ⑫ Flange for compartment door
- ⑭ Insulating protection
- ⑱ Spread terminals

### Drilling templates of the compartment door



### Drilling templates for support sheet



	III	IV
A	160	230
B	206	276
C	219	289

	Standard	Ronis	Profalux	Kirk	Castell
D	287	291	299	298	328

*Handwritten signatures and marks.*

# Overall dimensions Tmax T7M


## Withdrawable circuit-breaker

Front extended spread - ES

### Caption

- ① Drilling a hole in the sheet metal door to the compartment with the flange for the RS-VR-HR-EF-ES terminals
- ② Rear segregation for rear terminals
- ④ Flange fixing screws
- ⑤ Tightening torque: 1.5 Nm
- ⑥ Drilling template for fixing onto support sheet
- ⑩ Front terminal
- ⑬ Rear segregation for front terminals
- ⑭ Flange for compartment door
- ⑮ Clamp for auxiliary contacts
- ⑯ Insulating protection
- ⑳ Spread terminals


6




1SDC210015D0207

*Handwritten signature*

### Drilling templates of the compartment door



### Drilling templates for support sheet



	III	IV
A	160	230
B	206	276
C	219	289

	Standard	Ronis	Profalux	Kirk	Castell
D	290	298	306	NO	NO
E	287	291	299	298	328

*Handwritten signature*


*Handwritten signatures*

# Overall dimensions

## Circuit-breaker with RC221/222 residual current release



### Tmax T1 - T2 - T3

Fixed version



Caption

- ① Depth of the switchboard with circuit-breaker face extending
- ② Depth of the switchboard with circuit-breaker face flush with door
- ③ Front terminals for cable connection
- ④ Low terminal covers with degree of protection IP40



# Overall dimensions

## Circuit-breaker with RC221/222 residual current release


### Tmax T1 - T2 - T3

Drilling templates of the compartment door

Without flange  
face extending


3 POLES

T1 - T2 - T3




Without flange  
face not extending

T1




With flange  
face not extending

T1 - T2 - T3




T2 - T3




*Handwritten signature*

4 POLES


T1 - T2 - T3



T1 - T2 - T3



T1 - T2 - T3



1SDC210015D0207

	A	B	C	D	E	F	G	H
T1	18	108.2	94.1	-	23.5	113	78.1	39.1
T2	18	122	106	76	23.5	120	90	46
T3	13.5	137	118.5	83.5	19	127.4	102.5	53.5

*Handwritten signature*

*Large handwritten signature*



# Overall dimensions

## Circuit-breaker with RC222 residual current release





### Tmax T4 - T5

Fixed version

Front - F, fixing on sheet

T4

T5 (400 A)



**Caption**


① Overall dimensions with cabled auxiliary contacts mounted (only 3Q 1SY)

† For T5 (630 A) ask ABB SACE


*Ch*

**Flange for the compartment door**


**Drilling templates of compartment door and fitting flange**




For circuit-breakers



For residual current release



With flange



Without flange

*Ch*  
*[Signature]*  
*[Signature]*

# Overall dimensions

## Circuit-breaker with RC222 residual current release


### Tmax T4 - T5

Plug-in version


Front - F, fixing on sheet

T4


T5 (400 A)<sup>(1)</sup>




1SDC210015D0207



1SDC210015D0207



1SDC210015D0207



1SDC210015D0207


#### Caption

- ① Fixed part
- ② Mobile part
- ③ Overall dimensions with cabled auxiliary contacts mounted (only 3Q 1SY)


<sup>(1)</sup> For T5 (630 A) ask ABB SACE

#### Flange for the compartment door


#### Drilling templates of compartment door and fitting flange




For circuit-breakers



For residual current release




With flange




Without flange

#### Drilling templates for support sheet

T5



1SDC210015D0207








1SDC210015D0207

*Handwritten signatures and marks.*

# Tmax

DOC. N.° RH0011.803- L0377

EF - Terminali anteriori prolungati T1-T2-T3 fisso/parte fissa di rimovibile  
 EF - Extended front terminals T1-T2-T3 Fixed/plug-in fixed part  
 EF - Vorderseitige verlängerte Anschlüsse T1-T2-T3 fest/ausfahrbarer festes teil  
 EF - Prises avant prolongées T1-T2-T3 fixe/parte fixe de débrochable  
 EF - Terminales anteriores prolongados T1-T2-T3 fijo/parte fija de enchufable

	T1 III	T1 IV	T2 III	T2 IV	T3 III	T3 IV
	3 (6)	4 (8)	-	-	-	-
	-	-	3 (6)	4 (8)	-	-
	-	-	-	-	3 (6)	4 (8)
	-	-	-	-	-	-
	2 (4)	3 (6)	2 (4)	3 (6)	2 (4)	3 (6)






ABB SACE S.p.A.  
 Via Baioni, 35  
 24123 Bergamo- Italy  
 Tel. +39 035.395.111 - Telefax +39 035.395.306-433

<http://www.abb.com>

**ABB**

# Emax - Tmax

DOC. N.° 1SDH000529R0804 - L3486




EF/ES - Terminali anteriori prolungati e divaricati fisso T7-T7M-X1

EF/ES - Front terminals extended and splayed fixed T7-T7M-X1

EF/ES - Vorderseitige verlängerte und verbreiterte Anschlüsse, fest T7-T7M-X1



EF/ES - Prises avant prolongées et épanouies fixe T7-T7M-X1

EF/ES - Terminales frontales prolongados y separadores fijo T7-T7M-X1



*Handwritten signatures and initials*

T7-T7M-X1



a carico del Cliente  
to be purchased by the Customer  
muß vom Kunden erworben werden  
à la charge du Client  
a cargo del Cliente



ABB SACE S.p.A.

Via Baioni, 35

24123 Bergamo Italy












Tel.: +39 035 395.111 - Telefax: +39 035 395.306-433



<http://www.abb.com>

# Tmax



DOC. N.° RH0012.806 - L0377

- ES – Terminali anteriori divaricati T2 fisso/parte fissa di rimovibile
- ES – Splayed front terminals T2 Fixed/plug-in fixed part
- ES – Vorderseitige V-förmige Anschlüsse T2 fest/ausfahrbarer festes teil
- ES - Prises avant écartées T2 fixe/partie fixe de débrochable
- ES – Terminales anteriores separados T2 fijo/parte fija de enchufable

	T2 II	T2 IV	T3 III	T3 IV
	2 (4)	3 (6)	2 (4)	3 (6)
	1 (2)	1 (2)	-	-
	1 (2)	-	-	-
	1 (2)	1 (2)	-	-
	-	1 (2)	-	-
	-	1 (2)	-	-
	-	-	1 (2)	1 (2)
	-	-	1 (2)	-
	-	-	1 (2)	1 (2)
	-	-	-	1 (2)
	-	-	-	1 (2)



*Handwritten signatures and initials*



*Cl*



**ABB SACE S.p.A.**

Via Baloni, 35

24123 Bergamo- Italy

Tel. +39 035.395.111 - Telefax +39 035.395.306-433

<http://www.abb.com>

*04*

*h*

*all*

# Tmax

DOC. N.° 1SDH000436R0.843 - L0785

- ES – Terminali anteriori divaricati T5 630A parte fissa di rimovibile  
 ES – Splayed front terminals T5 630A plug-in fixed part  
 ES – Vorderseitige V-förmige Anschlüsse T5 630A ausfahrbarer festes teil  
 ES - Prises avant écartées T5 630A partie fixe de débrochable  
 ES – Terminales anteriores separados T5 630A parte fija de enchufable






ABB SACE S.p.A.  
 Via Baioni, 35  
 24123 Bergamo Italy  
 Tel.: +39 035 395.111 - Telefax: +39 035 395.306-433

<http://www.abb.com>

*Handwritten signatures and initials.*