


5 DRAWING / PLAN



Schneider Electric 37770001

1	BOITIER	BOITIER
2	BOITIER	BOITIER
3	BOITIER	BOITIER
4	BOITIER	BOITIER
5	BOITIER	BOITIER
6	BOITIER	BOITIER
7	BOITIER	BOITIER
8	BOITIER	BOITIER
9	BOITIER	BOITIER
10	BOITIER	BOITIER

BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER



BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER BOITIER

Handwritten signature and date: 2003



Power European Laboratory

Laboratoire d'essais moyenne tension
Schneider-Electric Industries SAS
ZAC Champ Saint Ange
F-38760 Varces



Test Report / Rapport d'Essais

N° AAA26280A

To / Pour : D. CAILLET ST / 38V

Objective
Objectif

Test objective / Objectif de l'essai :
Environmental testing / Essais d'environnement

Test
Essai

Started date / Début des essais : 13/02/2008 Finished date / Fin des essais : 13/02/2008

Test performed / Détails de l'essai :
External mechanical impacts tests : 5 joules IK08 / Essais aux impacts mécaniques : 5 joules IK08

Standards / Norme
IEC 62271-200 / CEI 62271-200
IEC 62262-262 / CEI 6262-262

Apparatus / Appareil : Schneider Electric SM6 inclosure / Schneider Electric cellule SM6
Designation / Désignation : **IM**
Manufacturer / Constructeur : Schneider Electric SA – Rueil Malmaison - FRANCE

Items identification / Identification de l'appareil:

- Serial number / Numéro de série : 0738182L
- Rated voltage / Tension assignée (kV) : 24
- Rated normal current / Courant assigné (A) : 630
- Short-circuit breaking current / Pouvoir de coupure (kA) : 20


Samples / Nombre d'appareil : 1

Conclusion

Tests are in accordance with the standards IEC 62271-200
Essais conformes à la norme CEI 62271-200

Dept: LEMT 38V	Number of pages :
Written by : G. RAMI	Date : 14/02/2008
Technical manager : B. VANDENBERGUE	Testing laboratory manager : J.M. ANSELMETTI

The performance of the apparatus tested and the results obtained are shown in the tables, oscillograms and photographs enclosed. This document relate only to the items presented for testing.
This test report can only be copied as a photographic facsimile in its entirety.
COFRAC Testing Section accreditation is only to certify that the laboratory complies with the technical competence required to carry out test on the product types covered by the accreditation



CONTENT / SOMMAIRE

1	PRODUCT DESCRIPTION / DESCRIPTION DU PRODUIT	3
2	TEST DESCRIPTION / DESCRIPTION DES ESSAIS.....	4
3	RESULTS / RESULTATS.....	6
4	DRAWING / PLAN.....	6
5	DRAWING / PLAN.....	7



Schneider Electric Industries SAS – Power



AAA26280A

217

2065



1 PRODUCT DESCRIPTION / DESCRIPTION DU PRODUIT

1.1 Detailed description of the item tested / Caractéristiques de l'appareil:


Manufacturer / Constructeur		: Schneider Electric Industries SA
Designation / Désignation		: Schneider Electric SM6 Circuit breaker
Number of poles / Nombre de pôles		: 3
Phase to phase / Distance entre phases	mm	: 375
Rated voltage / Tension assignée	kV	: 24
Lightning impulse withstand voltage <i>Tension de tenue aux chocs de foudre</i>	kV	: 125
Power frequency withstand voltage <i>Tension de tenue à fréquence industrielle</i>	kV	: 50
Frequency / Fréquence	Hz	: 50/60
Rated normal current <i>Courant en service continu</i>	A	: 630
Short time withstand current <i>Courant de courte durée admissible</i>	kA	: 20
Peak withstand current <i>Courant de crête admissible</i>	kÂ	: 52
Duration of short circuit <i>Durée de court-circuit</i>	s	: 1
Short circuit making current <i>Pouvoir de fermeture en court – circuit</i>	kÂ	: 52
Short circuit breaking current <i>Pouvoir de coupure en court – circuit</i>	kA	: 20
Interrupting medium / Milieu de coupure		: SF6
SF6 mass at / Masse SF6 à 20°C	Kg	: 0.21
Operating mechanism type / Type de commande		: CIT
Drawing n° / Plan n°		: 3727000 ind H page 6 : 3728886 ind P page 20

2 TEST DESCRIPTION / DESCRIPTION DES ESSAIS

▪ Test conditions :

The test apparatus consists basically of a pendulum rotating at its upper end in such a way as to be kept in a vertical plane. The axis of the pivot is at 1 meter.

Le moyen d'essai consiste essentiellement en un pendule pivotant à son extrémité supérieure, de façon à ne se mouvoir que dans un plan vertical. L'axe du pivot est à 1 mètre au-dessus du point de mesure.



Equivalent mass / Masse équivalente	Kg	1.7
Height of fall / Hauteur de chute	mm	300

In order to avoid secondary impacts, i.e. rebounds, the hammer shall be retained after the initial impact by grasping the striking element whilst avoiding the arm so that distortion is prevented.

Afin d'éviter les impacts secondaires, le marteau doit être retenu en saisissant la pièce de frappe et non le bras pour éviter de le déformer.

Test done / Essais réalisés :

The impact energy is 5 joules / La valeur d'énergie d'impact est de 5 joules
The number of impacts is 3 / Le nombre d'impact est de 3



Tested parts

- On the earth flap of cubicle's cover
- On the switch flap of cubicle's cover of
- On the windows of the cable access panel
- On the voltage indicating enclosure

Parties testées :

- Sur le portillon de terre du capot cellule
- Sur le portillon interrupteur du capot cellule
- Sur le hublot du panneau accès câble
- Sur le boîtier de présence tension

▪ Test picture / Photo de l'essai :






3 RESULTS / RESULTATS

Tests are in accordance with the standards IEC 62271-200
 Essais conformes à la norme CEI 62271-200

4 DRAWING / PLAN




Schneider Electric
 Schneider Electric Industries SAS
 Schneider Electric

Handwritten signature and date: 2009



5 DRAWING / PLAN



Handwritten text: 01/10/2007

Handwritten signature

Handwritten signature

2070

The test reports document must be requested to the Technical Support Level 3

SM6-24 ADVAN6 test reports list

last modification : 15 10 2012

Reference	units	Test type	Standard	Date	U ₀ (kV)	I _n (A)	I _k (kA)	Comments
TR 20120291 022	IM	Internal Arc	IEC 62271-200	2012	24	630	17	In the cables compartment-With bottom exhaust configuration
TR 20120291 021	IM500	Internal Arc	IEC 62271-200	2012	24	630	17	In the busbar compartment-With bottom exhaust configuration
TR 20120291 020	IM500	Internal Arc	IEC 62271-200	2012	24	630	16	In the cables compartment-With bottom exhaust configuration
TR 20120291 019	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	20	In the switch compartment-With bottom exhaust configuration
TR 20120291 018	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	20	In the switch compartment-With bottom exhaust configuration
TR 20120291 017	IM	Internal Arc	IEC 62271-200	2012	24	630	12.5	In the cables compartment-With bottom exhaust configuration
TR 20120291 016	IM	Internal Arc	IEC 62271-200	2012	24	630	12.5	In the busbar compartment-With bottom exhaust configuration
TR 20120291 015	IM	Internal Arc	IEC 62271-200	2012	24	630	12.5	In the switch compartment-With bottom exhaust configuration
TR 20120291 014	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	12.5	In the cables compartment-With bottom exhaust configuration
TR 20120291 013	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	12.5	In the busbar compartment-With bottom exhaust configuration
TR 20120291 012	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	12.5	In the disconnecter compartment-With bottom exhaust configuration
TR 20120291 011	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	12.5	In the cables compartment-With bottom exhaust configuration
TR 20120291 010	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	12.5	In the switch compartment-With bottom exhaust configuration
TR 20120291 009	DM1-A	Internal Arc	IEC 62271-200	2011	24	630	20	In the switch compartment-With top exhaust configuration
TR 20120291 008	IM	Internal Arc	IEC 62271-200	2012	24	630	20	In the busbar compartment-With top exhaust configuration
TR 20120291 007	IM	Internal Arc	IEC 62271-200	2012	24	630	20	In the busbar compartment-With top exhaust configuration
TR 20120291 006	IM500	Internal Arc	IEC 62271-200	2012	24	630	23	In the cables compartment-With top exhaust configuration
TR 20120291 005	IM500	Internal Arc	IEC 62271-200	2012	24	630	23	In the cables compartment-With top exhaust configuration
TR 20120291 004	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	20	In the busbar compartment-With top exhaust configuration
TR 20120291 003	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	20	In the busbar compartment-With top exhaust configuration
TR 20120291 002	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	20	In the cables compartment-With top exhaust configuration
TR 20120291 001	IM	Internal Arc	IEC 62271-200	2012	24	630	16	In the cables compartment-With bottom exhaust configuration
TR 20120291 000	DM1-A	Internal Arc	IEC 62271-200	2012	17.5	435	16	In the switch compartment-With bottom exhaust configuration
TR 20120291 999	DM1-A	Internal Arc	IEC 62271-200	2012	17.5	435	16	In the busbar compartment-With bottom exhaust configuration
TR 20120291 998	DM1-A	Internal Arc	IEC 62271-200	2012	17.5	435	16	In the cables compartment-With bottom exhaust configuration
TR 20120291 997	IM	Internal Arc	IEC 62271-200	2012	24	630	16	In the switch compartment-With bottom exhaust configuration
TR 20120291 996	IM	Internal Arc	IEC 62271-200	2012	24	630	16	In the busbar compartment-With bottom exhaust configuration
TR 20120291 995	IM	Internal Arc	IEC 62271-200	2012	24	630	16	In the cable compartment-With bottom exhaust configuration
TR 20120291 994	IM	Internal Arc	IEC 62271-200	2012	24	630	16	In the busbar compartment-With bottom exhaust configuration
TR 20120291 993	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	16	In the busbar compartment-With top exhaust configuration
TR 20120291 992	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	16	In the busbar compartment-With top exhaust configuration
TR 20120291 991	IM500	Internal Arc	IEC 62271-200	2012	24	630	16	In the busbar compartment-With top exhaust configuration
TR 20120291 990	IM500	Internal Arc	IEC 62271-200	2012	24	630	16	In the cables compartment-With top exhaust configuration
TR 20120291 989	DM1-A	Internal Arc	IEC 62271-200	2012	24	630	16	In the switch compartment-With bottom exhaust configuration
TR 20120291 988	IM	Internal Arc	IEC 62271-200	2012	24	630	16	In the busbar compartment-With bottom exhaust configuration
TR 20120291 987	IM	Internal Arc	IEC 62271-200	2012	24	630	16	In the cable compartment-With bottom exhaust configuration
TR 20120291 986	DM1-A	Internal Arc	IEC 62271-200	2012	17.5	435	16	In the switch compartment-With top exhaust configuration
TR 20120291 985	DM1-A	Internal Arc	IEC 62271-200	2012	17.5	435	16	In the busbar compartment-With top exhaust configuration
TR 20120291 984	DM1-A	Internal Arc	IEC 62271-200	2012	17.5	435	16	In the cables compartment-With top exhaust configuration
TR 20120291 983	DM1-A	Internal Arc	IEC 62271-200	2012	17.5	435	16	In the busbar compartment-With top exhaust configuration
TR 20120291 982	DM1-A	Internal Arc	IEC 62271-200	2012	17.5	435	16	In the cables compartment-With top exhaust configuration
TR 20120291 981	DM1-A	Mechanical	IEC 62271-200	2012	24	630	23	P3X
TR 20120291 980	DM1-A	Mechanical	IEC 62271-200	2012	24	630	23	P3X



ACCREDITATION N° 1-0259
PORTÉE DISPONIBLE
SUR WWW.COFRAC.FR

Laboratoire Essais Moyenne Tension
Schneider-Electric Industries SAS
ZAC Champ Saint Ange
F-38760 Varcès

Test Report

N° TFR_200902405_004

To : Eric Saunier-Payerne

Objective

Temperature rise Test objective : Validation of cubicle SM6-24 QM arc proof

Test

Starting date : 25/05/2009 Completed date : 15/06/2009

Test performed : test at 130A three-phase on cubicle SM6-24 QM arc proof coupled with a cubicle SM6-24 DM1W arc proof

Standards : CEI62271-200 -

Items tested

Apparatus : SM6-24 QM ARC PROOF 16kA-1s

Designation : Schneider Electric SM6-24 QM

Manufacturer : Schneider Electric SA – Rueil Malmaison - FRANCE


Items identification :

- Serial number : 0913040
- Rated voltage (kV) : 24
- Rated normal current (A) : 200
- Short-circuit breaking current (kA) : 20
- SF6 mass at (Kg): 0,210 (switch)
- Drawing n°:373002302 ind 01 / 51238176F002 ind O2

Samples : 1

Conclusion

The tests are in accordance with the standard IEC 62271-200

Dept:	LEMT 38V	Technical manager :  B. VANDENBERGUE
Test leader	Izzo Pasquale	
Number of pages :	11	
Approval date :	30/06/2009	

The performance of the apparatus tested and the results obtained are shown in the tables, oscillograms and photographs enclosed. This document relate only to the items presented for testing.
This test report can only be copied as a photographic facsimile in its entirety.
Accreditation COFRAC attests only competence of the laboratory for the tests alone covered with accreditation.
The COFRAC is signatory of the multilateral agreement of EA (European co-operation for Accreditation) and of ILAC (International Laboratory Accreditation Cooperation) of equivalence recognition of test reports or analysis.



CONTENT


1	PRODUCT DESCRIPTION.....	3
2	TEST DESCRIPTION	5
3	RESULTS	7
4	OSCILLOGRAM	8
5	DRAWING.....	10





1 PRODUCT DESCRIPTION

1.1 Sampling:



[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

2024



1.2 Detailed description of the item tested :

SWITCH :

Manufacturer		: Schneider Electric Industries SA
Designation		: Schneider Electric SM6-24
Number of poles		: 3
Rated voltage	kV	: 24
Lightning impulse withstand voltage	kV	: 125
Power frequency withstand voltage	kV	: 50
Frequency	Hz	: 50/60
Rated normal current	A	: 200
Short circuit making current	kA	: 50
Short circuit breaking current	kA	: 20
Interrupting medium		: SF6
SF6 mass at à 20°C	Kg	: 0.210
Drawing n°		: 373002302 ind 01 : 51238176F002 ind 02

The cubicle is fitted with :

FUSARC fuses 200 A ref : 757354 CQ





2 TEST DESCRIPTION

2.1 Specific test conditions :


- The SM6-24 QM arc proof cubicle is coupled with a SM6-24 DM1W arc proof cubicle
- The SM6-24 QM arc proof cubicle is connected with 1 aluminium cable of 150 mm² per phase
- The side walls are covered with a heat insulation
- The ambient temperature rise of SM6-24 DM1W cubicle is simulated by heating resistances (correspondent with a passage of 630 A current in SM6-24 DM1W cubicle internal report N°200902407_004))
- The thermocouples used are Copper-Constantan.
- Air velocity : 0.1 m/s

200902405_004



2.2 Detailed description of the tests :

- Drawing of connections and thermocouples position :



[Handwritten signature]
2077



3 RESULTS

• Measurement of the circuit resistance (I = 100 Adc) :

- Before temperature-rise test :

Measurement between	Phase 1 ($\mu\Omega$)	Phase 2 ($\mu\Omega$)	Phase 3 ($\mu\Omega$)
R1 / R4	3050	3250	3010

- After temperature-rise test :

Measurement between	Phase 1 ($\mu\Omega$)	Phase 2 ($\mu\Omega$)	Phase 3 ($\mu\Omega$)
R1 / R4	3049	3252	3014

• Values of the temperature rise at : 130 A

- Ambient temperature : 25,5 °C


Thermocouple	Nature of the part : material, dielectric	Temperature rise (K)			Maximum Value (°)
		Phase 1	Phase 2	Phase 3	
1	Connection bare-copper in air	27,5	28,3	27,8	50
2	Connection silver-coated in air	32,4	32,8	32,1	75
3	Contact silver-coated in air	38,8	39,4	38,5	65
4	Insulating fuse	73,6	76,0	73,1	140
5	Contact silver coated in air	57,6	62,8	57,9	65
6	Connection silver-coated in air	49,3	52,1	48,4	75
7	Point TG insulated	42,3	44,5	42,3	65
8	Point TG insulated	41,8	43,7	41,8	65
9	Point TG insulated	24,1	24,5	24,1	65
Amb QM	Internal ambient		29,6		/
Amb DM1-W	Internal ambient		20,0		/

(*) : - Maximum value of the temperature rise at ambient air temperature not exceeding 40°C


2078

4 OSCILLOGRAM

Phase 1 :




Phase 2



Handwritten signature

Phase 3




Handwritten signature

Handwritten signature

Handwritten mark

5 DRAWING




+		Schneider Electric	
400V		373002402	
		Schneider Electric Industries SAS	
		10/11	

Handwritten text

Handwritten signatures and marks

2081



Schneider Electric	4 RUE HUBERD 92000
	92000 BOULOGNE FRANCE
Schneider Electric	
Produit en France	

TEST REPORT

200902678_008

page 1/16

Delivered to : SCHNEIDER ELECTRIC
SCHNEIDER ELECTRIC INDUSTRIES SAS (FRANCE) POWER BUSINESS
31 rue Pierre Mendès-France, Eybens, 38050 GRENOBLE cedex 9

Tested equipment : SM6 cubicles IM+QM with big diameter fuses (100 A)

Reference : Type - 24 kV - 630 / 200 A - 50 Hz

Manufacturer : SCHNEIDER ELECTRIC

Purpose of tests : proving of the dielectric withstand level of the cubicles with new cable repartitors
(ref AAV7603302)
according to IEC 62271-200 (2003-11)

Tests performed : according to IEC 60060-1 (1989-11)+corrigendum 1 (1992-03), IEC 62271-1 (2007-10)
standard and customers requirements for the following tests :

POWER FREQUENCY DRY TEST VOLTAGE IEC 62271-200 (2003-11) Sub-Clause 6.2
TEST WITH LIGHTNING IMPULSE VOLTAGE IEC 62271-200 (2003-11) Sub-Clause 6.2


Site of tests : VOLTA - FUNCTIONAL LABORATORY

Date of tests : from 2009/08/25 to 2009/08/28

The report contains : 16 pages


Date of issued : 2009/12/15

Testing Manager




STEPHANE GIRAUD

Technical Manager



HUGO FRANCOISE

The performance of the apparatus tested and the results obtained are shown in the tables, oscillograms and photographs enclosed.
The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer.
This record of proving test shall only be reproduced in the complete form. The accreditation by the COFRAC Testing Section attests of
the laboratory competence in the tests covered by the accreditation.



2009



1. TABLE OF CONTENTS

1. TABLE OF CONTENTS	2
2. 2. CONCLUSIONS	2
3. RATINGS OF THE SWITCHGEAR	3
3.1. SWITCH RATING	3
3.2. SWITCH / FUSE RATING	4
4. MOUNTING ARRANGEMENT	4
5. VALUES TO VERIFY	5
6. ATMOSPHERIC CONDITIONS.....	5
7. TESTS CIRCUITS	6
7.1. POWER FREQUENCY	6
7.1.1. Uncertainty of measuring chains	6
7.2. LIGHTNING IMPULSE.....	7
7.2.1. Uncertainty of measuring chains	7
8. TESTS PROCEDURES	8
8.1. APPLICATION OF TEST VOLTAGE.....	8
8.1.1. Switchgear closed	8
8.1.2. Switchgear open.....	8
8.2. POWER FREQUENCY TEST	8
8.3. TEST WITH LIGHTNING IMPULSE VOLTAGE.....	8
9. TESTS RESULTS:	9
9.1. POWER FREQUENCY TEST	9
9.2. TEST WITH LIGHTNING IMPULSE VOLTAGE	10
10. TEST PHOTOGRAPHIES	12
11. TERMINAL IDENTIFICATION	13
12. DRAWING	14
12.1. IM	14
12.2. QM	15
12.3. REPARTITOR (REF AAV7603302).....	16

2. 2. CONCLUSIONS

The SM6 cubicles IM+QM is considered satisfactory according to IEC 62271-200 (2003-11) Sub-Clause 6.2 and to the customer requirement.

Date of receipt of the device : The 2009/08/24

List of people having participated in tests

Mr S. GIRAUD
Mr

Functional laboratory



3. RATINGS OF THE SWITCHGEAR

Apparatus : SM6 cubicles IM+QM
- type : Type 24 kV
- serial number : 0928133L (IM) and 0928163L (QM)
- manufacturing year : 2009
- number of poles : 3
Manufacturer : Schneider Electric Industries SA
Rated voltage : 24 kV
power frequency withstand voltage : 50 kV
lightning impulse withstand voltage : 125 kV
Rated frequency : 50 Hz
Rated normal current : 630 A

3.1. SWITCH RATING

Manufacturer : Schneider Electric Industries SA
Designation : Schneider Electric IM375
Number of poles : 3
Phase to phase mm : 200
Rated voltage kV : 24
Lightning impulse withstand voltage kV : 125
Power frequency withstand voltage kV : 50
Frequency Hz : 50/60
Rated normal current A : 630
Short circuit making current kA : 50
Interrupting medium : SF6
SF6 mass at 20°C Kg : 0,210
Drawing n° : 373002102 ind.02



3.2. SWITCH / FUSE RATING

Manufacturer	:	Schneider Electric Industries SA
Designation	:	Schneider Electric QM375
Number of poles	:	3
Phase to phase	mm	: 200
Rated voltage	kV	: 24
Lightning impulse withstand voltage	kV	: 125
Power frequency withstand voltage	kV	: 50
Frequency	Hz	: 50/60
Rated normal current	A	: 100A (big fuses)
Short circuit making current	kA	: 50
Interrupting medium	:	SF6
SF6 mass at 20°C	Kg	: 0,210
Drawing n°	:	373002302 ind 02

4. MOUNTING ARRANGEMENT

The switchgear is mounted according to the drawings n°373002102 ind.02 and 373002302 ind 02 .

Refer to scheme page n°13 for terminal identification.
Refer to pictures page n°12





5. VALUES TO VERIFY

according to

IEC 62271-1 (2007-10)

Rated voltage level

24 kV

Power frequency dry test

To earth : 50kV 60 s
Across open switching device : 50kV 60 s
Across isolating distance : 60kV 60 s

Test with lightning impulse voltage

To earth : 125kV 15 impulses ±
Across open switching device : 125kV 15 impulses ±

6. ATMOSPHERIC CONDITIONS


The correction factors K are calculated according to IEC 60060-1 (1989-11) Sub-Clause 11 standard.
Atmospheric conditions observed during the test :

date	b : hPa	t : °C	tw : °C	Ub : kV	L : m	Hu : g/m ³	K
25/08/2009	988	24.2	18	55	0.16	12.2	0.962
26/08/2009	992	24.2	18.6	55	0.16	13.1	0.965
26/08/2009	992	24.3	18.7	138	0.16	13.2	0.965
27/08/2009	995	23.8	18	138	0.16	12.4	0.970
27/08/2009	993	24.1	17.7	138	0.16	11.9	0.967
28/08/2009	992	23.8	17.5	138	0.16	11.7	0.967
28/08/2009	992	23.8	17.5	55	0.16	11.7	0.967

2007

7. TESTS CIRCUITS

7.1. POWER FREQUENCY




- Tr : Regulating transformer 240/0-500V B. BONNEFOND 25685
- T : High voltage step up transformer 0,5/150kV 50kVA HAEFELY WO 283398
- D : Capacitive divider 50Hz 300kV 440pF HAEFELY WO 573398 n°MTC300
- Cc : Loading capacitor
- VAC : Multimeter >5.5D 2001.type AC Position KEITHLEY 0643802 n°KY936
- PC : Computer + IC card GPIB NI-488-2 type
- GPIB : Cable link GPIB IEEE-488
- I : Test object

7.1.1. Uncertainty of measuring chains

Power frequency voltage measured with D :
The uncertainty of the measure is $\pm 2.7\%$ (estimated confidence level not less than 95%)

2008

7.2. LIGHTNING IMPULSE



Generator 8 stages 800kV 40kJ HAEFELY WO 514470

Values for each stage : $C = 1,0\mu\text{F}$, $r_c = 4,8\text{k}\Omega$, $r_{pi} = 68\Omega$, $r_{pi} = 12\Omega$, $r_{se} = 350\Omega$

D : Divider 800kV $C_t = 670\text{pF}$, $R_t = 226,2\Omega$ HAEFELY WO 514470 n°CS800-670F

OSC + Visu : Transient analyser Nicolet type ACCURA 100HV n°IDA0300169

Sa : Probe 10x $Z = 10\text{M}\Omega$ P5102 type TEKTRONIX n°Red

PC : Computer + IC card GPIB NI-488-2 type

GPIB : Cable link GPIB IEEE-488

I : Test object

7.2.1. Uncertainty of measuring chains

The uncertainty of the measure is $\pm 2.31\%$ (estimated confidence level not less than 95%) Lightning impulse voltage measured with D :

[Handwritten signatures and date]

2009

8. TESTS PROCEDURES

8.1. APPLICATION OF TEST VOLTAGE

8.1.1. Switchgear closed

Test to earth and between poles :
Voltage is applied to one pole, the base and the other poles are earthed.

8.1.2. Switchgear open



Test to earth, between poles and across open switching device:
Voltage is applied successively to each terminal; the other terminals and the frame are earthed.

8.2. POWER FREQUENCY TEST

Withstand voltage test :
The specified voltage level is maintained for 60 s.

8.3. TEST WITH LIGHTNING IMPULSE VOLTAGE

Withstand voltage test:
15 impulses with the specified level are applied for both positive and negative polarities



2090

9. TESTS RESULTS:

9.1. POWER FREQUENCY TEST

Test condition	Terminals connected to earth	Voltage applied to	Test voltage kV	Correction factor		Results
				K	(1)	
Im + Qm (both open)						
Both open	F & Im + Qm vABCbc	a	50	0.962	A	Withstood 60 seconds
Both open	F & Im + Qm ABCac	b	50	0.962	A	Withstood 60 seconds
Both open	F & Im + Qm ABCab	c	50	0.962	A	Withstood 60 seconds
Qm open						
Qm open / Im closed	FBCabc	A	50	0.962	A	Withstood 60 seconds
Qm open / Im closed	FACabc	B	50	0.962	A	Withstood 60 seconds
Qm open / Im closed	FABabc	C	50	0.962	A	Withstood 60 seconds
Im open						
Qm closed / Im open	FBCabc	A	50	0.962	A	Withstood 60 seconds
Qm closed / Im open	FACabc	B	50	0.962	A	Withstood 60 seconds
Qm closed / Im open	FABabc	C	50	0.962	A	Withstood 60 seconds
Im + Qm (both closed)						
Both closed	FBbCc	Aa	50	0.962	A	Withstood 60 seconds
Both closed	FAaCc	Bb	50	0.962	A	Withstood 60 seconds
Both closed	FAaBb	Cc	50	0.962	A	Withstood 60 seconds


(1) A = The correction factor K has been Applied NA = The correction factor K has Not been Applied
AK = The correction factor K = 0.950 has been Applied (IEC 62271-1 (2007-10))

2091

9.2. TEST WITH LIGHTNING IMPULSE VOLTAGE

Test condition	Earth connected to	Voltage applied to	pol.	Voltage applied KV	Correction factor K	(1)	Results	Annex n°
Im + Qm (both closed)								
Both closed	FBbCc	Aa	pos.	100	0.962	A	Waveform 1.15/ 47.98 μ s	031548
Both closed	FBbCc	Aa	pos.	125	0.962	A	Withstood 15 Impulses	031553
Both closed	FBbCc	Aa	neg.	100	0.962	A	Waveform 1.17/ 48.07 μ s	031553
Both closed	FBbCc	Aa	neg.	125	0.962	A	Withstood 15 Impulses	031557
Both closed	FAaCc	Bb	pos.	100	0.965	A	Waveform 1.18/ 48.04 μ s	040835
Both closed	FAaCc	Bb	pos.	125	0.965	A	Withstood 15 Impulses	040841
Both closed	FAaCc	Bb	neg.	100	0.965	A	Waveform 1.18/ 48.08 μ s	040841
Both closed	FAaCc	Bb	neg.	125	0.965	A	Withstood 15 Impulses	040855
Both closed	FAaBb	Cc	pos.	100	0.965	A	Waveform 1.16/ 48.07 μ s	040857
Both closed	FAaBb	Cc	pos.	125	0.965	A	Withstood 15 Impulses	040906
Both closed	FAaBb	Cc	neg.	100	0.965	A	Waveform 1.17/ 48.19 μ s	040907
Both closed	FAaBb	Cc	neg.	125	0.965	A	Withstood 15 Impulses	040912
Im open								
Im open	FBCabc	A	pos.	100	0.965	A	Waveform 1.23/ 49.13 μ s	040941
Im open	FBCabc	A	pos.	125	0.965	A	Withstood 15 Impulses	040947
Im open	FBCabc	A	neg.	100	0.965	A	Waveform 1.23/ 49.14 μ s	040947
Im open	FBCabc	A	neg.	125	0.965	A	Withstood 15 Impulses	040952
Im open	FACabc	B	pos.	100	0.965	A	Waveform 1.22/ 49.08 μ s	041004
Im open	FACabc	B	pos.	125	0.965	A	Withstood 15 Impulses	041011
Im open	FACabc	B	neg.	100	0.965	A	Waveform 1.22/ 49.17 μ s	041011
Im open	FACabc	B	neg.	125	0.965	A	Withstood 15 Impulses	041017
Im open	FABabc	C	pos.	100	0.965	A	Waveform 1.23/ 49.14 μ s	041019
Im open	FABabc	C	pos.	125	0.965	A	Withstood 15 Impulses	041025
Im open	FABabc	C	neg.	100	0.965	A	Waveform 1.23/ 49.22 μ s	041026
Im open	FABabc	C	neg.	125	0.965	A	Withstood 15 Impulses	041031


(1) A = The correction factor K has been Applied NA = The correction factor K has Not been Applied
 AK = The correction factor K = 0.950 has been Applied (IEC 62271-1 (2007-10))



2009




Condition d'essai	Terre reliée à	Tension appliquée à	pol.	tenue appliquée kV	Facteur de correction K (1)		Résultats	Annexe n°
Qm open								
Qm open	FBCabc	A	pos.	100	0.966	A	Waveform 1.21/ 49.08 µs	041041
Qm open	FBCabc	A	pos.	125	0.966	A	Withstood 15 Impulses	041046
Qm open	FBCabc	A	neg.	100	0.966	A	Waveform 1.20/ 49.17 µs	041047
Qm open	FBCabc	A	neg.	125	0.966	A	Withstood 15 Impulses	041052
Qm open	FACabc	B	pos.	100	0.966	A	Waveform 1.20/ 49.02 µs	041054
Qm open	FACabc	B	pos.	125	0.966	A	Withstood 15 Impulses	041106
Qm open	FACabc	B	neg.	100	0.966	A	Waveform 1.20/ 49.15 µs	041106
Qm open	FACabc	B	neg.	125	0.966	A	Withstood 15 Impulses	041111
Qm open	FABabc	C	pos.	100	0.966	A	Waveform 1.20/ 49.00 µs	041114
Qm open	FABabc	C	pos.	125	0.966	A	Withstood 15 Impulses	041121
Qm open	FABabc	C	neg.	100	0.966	A	Waveform 1.20/ 49.12 µs	041121
Qm open	FABabc	C	neg.	125	0.966	A	Withstood 15 Impulses	041126
Qm open + Im open.								
Both open	F & Im + Qm ABCbc	a	pos.	100	0.965	A	Waveform 1.21/ 49.57 µs	041228
Both open	F & Im + Qm ABCbc	a	pos.	125	0.965	A	Withstood 15 Impulses	041233
Both open	F & Im + Qm ABCbc	a	neg.	100	0.965	A	Waveform 1.22/ 49.74 µs	041234
Both open	F & Im + Qm ABCbc	a	neg.	125	0.965	A	Withstood 15 Impulses	041239
Both open	F & Im + Qm ABCac	b	pos.	100	0.965	A	Waveform 1.22/ 49.70 µs	041241
Both open	F & Im + Qm ABCac	b	pos.	125	0.965	A	Withstood 15 Impulses	041247
Both open	F & Im + Qm ABCac	b	neg.	100	0.965	A	Waveform 1.22/ 49.79 µs	041247
Both open	F & Im + Qm ABCac	b	neg.	125	0.965	A	Withstood 15 Impulses	041252
Both open	F & Im + Qm ABCab	c	pos.	100	0.965	A	Waveform 1.21/ 49.64 µs	041257
Both open	F & Im + Qm ABCab	c	pos.	125	0.965	A	Withstood 15 Impulses	041302
Both open	F & Im + Qm ABCab	c	neg.	100	0.965	A	Waveform 1.21/ 49.82 µs	041302
Both open	F & Im + Qm ABCab	c	neg.	125	0.965	A	Withstood 15 Impulses	041308

(1) A = The correction factor K has been Applied NA = The correction factor K has Not been Applied
AK = The correction factor K = 0.950 has been Applied (IEC 62271-1 (2007-10))



2009

10. TEST PHOTOGRAPHIES




SM6-	Gas-insulated switchgear (GIS) equipped by Kato process	Schneider
Ur	24 kV Ud 50 kV Un 125 kV	AC12.5kV B
Ik	12.5 kA Ik-1 s	Ip 31.5 kA A-5L
Ir	630 A Un 8 kV Ir 60/60 Hz	7898882
SF6	0.210 kg	year 2009 8/N 03281931
Pre	40 kPa	TEC 62271-200

No identification picture available for Qm

[Handwritten signatures and date]
 2009

11. TERMINAL IDENTIFICATION




1095

5

12. DRAWING



12.1. IM



Handwritten signature and date: 2006

SM6 circuit-breaker IQ

12.2. QM



QM CIRCULE
Schneider Electric
373002302
02


[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

2007

12.3. REPARTITOR (REF AAV7603302)



TEST REPORT

200902678_015

page 1/14

Delivered to : SCHNEIDER ELECTRIC
SCHNEIDER ELECTRIC INDUSTRIES SAS (FRANCE) POWER BUSINESS
31 rue Pierre Mendès-France, Eybens, 38050 GRENOBLE cedex 9

Tested equipment : SM6 cubicles IM with two cables per phase

Reference : Type - 24 kV - 630 A - 50 Hz

Manufacturer : SCHNEIDER ELECTRIC

Purpose of tests : proving of the dielectric withstand level of the cubicles with new cable reparitors
(ref AAV7603302)
according to IEC 62271-200 (2003-11)

Tests performed : according to IEC 60060-1 (1989-11)+corrigendum 1 (1992-03), IEC 62271-1 (2007-10)
standard and customers requirements for the following tests :

POWER FREQUENCY DRY TEST VOLTAGE IEC 62271-200 (2003-11) Sub-Clause 6.2
TEST WITH LIGHTNING IMPULSE VOLTAGE IEC 62271-200 (2003-11) Sub-Clause 6.2

Site of tests : VOLTA - FUNCTIONAL LABORATORY


Date of tests : the 2009/10/05

The report contains : 14 pages

Date of issue : 2010/02/23


Recipient: David Pellissier

Testing Manager



STEPHANE GIRAUD

Technical Manager



HUGO FRANCOISE

g

1. TABLE OF CONTENTS

1. TABLE OF CONTENTS2

2. CONCLUSIONS2

3. RATINGS OF THE SWITCHGEAR.....3

4. MOUNTING ARRANGEMENT3

5. VALUES TO VERIFY4

6. ATMOSPHERIC CONDITIONS.....4

7. TESTS CIRCUITS5

7.1. POWER FREQUENCY5

7.1.1. Uncertainty of measuring chains5

7.2. LIGHTNING IMPULSE.....6

7.2.1. Uncertainty of measuring chains6

8. TESTS PROCEDURES.....7

8.1. APPLICATION OF TEST VOLTAGE.....7

8.1.1. Switchgear closed7

8.1.2. Switchgear open7

8.2. POWER FREQUENCY TEST7

8.3. TEST WITH LIGHTNING IMPULSE VOLTAGE7

9. TESTS RESULTS:8

9.1. POWER FREQUENCY TEST8

9.2. TEST WITH LIGHTNING IMPULSE VOLTAGE9

10. TEST PHOTOGRAPHIES11

11. TERMINAL IDENTIFICATION12

12. DRAWING13

12.1. IM CUBICLE13

12.2. REPARTITOR (REF AAV7603302)14

2. CONCLUSIONS

The SM6 cubicles IM is considered satisfactory according to IEC 62271-200 (2003-11) Sub-Clause 6.2 and to the customer requirement.

Date of receipt of the device : The 2009/08/24

List of people having participated in tests

Mr S. GIRAUD
Mr

Functional laboratory

2100


3. RATINGS OF THE SWITCHGEAR

Apparatus	:	Apparatus : SM6 cubicles IM with two cables per phase
- type	:	IM375 / 24 kV
- serial number	:	7896682
- manufacturing year	:	2009
- number of poles	:	3
Manufacturer	:	Schneider Electric Industries SA
Rated voltage	:	24 kV
power frequency withstand voltage	:	50 kV
lightning impulse withstand voltage	:	125 kV
Rated frequency	:	50 / 60 Hz
Rated normal current	:	630 A
Drawing	:	373002102 ind.02

4. MOUNTING ARRANGEMENT

The switchgear is mounted according to the drawings n°373002102 ind.02 and 373002302 ind 02.

Refer to scheme page n°12 for terminal identification.
Refer to pictures page n°11



2101


5. VALUES TO VERIFY

according to	IEC 62271-1 (2007-10)	
Rated voltage level	24 kV	
Power frequency dry test		
To earth	:	50kV 60 s
Across open switching device	:	50kV 60 s
Test with lightning impulse voltage		
To earth	:	125kV 15 impulses ±
Across open switching device	:	125kV 15 impulses ±

6. ATMOSPHERIC CONDITIONS

The correction factors K are calculated according to IEC 60060-1 (1989-11) Sub-Clause 11 standard.
Atmospheric conditions observed during the test :


date	b : hPa	t : °C	tw : °C	Ub : kV	L : m	Hu : g/m ³	K
05/10/2009	994	21.1	14.2	55	0.15	8.8	0.954
05/10/2009	993	21.2	14.4	138	0.12	9	0.959



2102

7. TESTS CIRCUITS


7.1. POWER FREQUENCY



- Tr : Regulating transformer 240/0-500V B. BONNEFOND 25685
- T : High voltage step up transformer 0,5/150kV 50kVA HAEFELY WO 283398
- D : Capacitive divider 50Hz 300kV 440pF HAEFELY WO 573398 n°MTC300
- Cc : Loading capacitor
- VAC : Multimeter >5.5D 2001.type AC Position KEITHLEY 0643802 n°KY936
- PC : Computer + IC card GPIB NI-488-2 type
- GPIB : Cable link GPIB IEEE-488
- I : Test object


7.1.1. Uncertainty of measuring chains

Power frequency voltage measured with D :
The uncertainty of the measure is $\pm 2.7\%$ (estimated confidence level not less than 95%)




2103

7.2. LIGHTNING IMPULSE



Generator 8 stages 800kV 40kJ HAEFELY WO 514470

Values for each stage : C = 1,0 μ F, rc = 4,8k Ω , rpi = 68 Ω , rpi = 12 Ω , rse = 350 Ω

D : Divider 800kV Ct = 670pF, Rt = 226,2 Ω HAEFELY WO 514470 n°CS800-670F

OSC + Visu : Transient analyser Nicolet type ACCURA 100HV n°IDA0300169

Sa : Probe 10x Z = 10M Ω P5102 type TEKTRONIX n°Red

PC : Computer + IC card GPIB NI-488-2 type

GPIB : Cable link GPIB IEEE-488

I : Test object

7.2.1. Uncertainty of measuring chains

The uncertainty of the measure is $\pm 2.31\%$ (estimated confidence level not less than 95%) Lightning impulse voltage measured with D :

2104

8. TESTS PROCEDURES

8.1. APPLICATION OF TEST VOLTAGE

8.1.1. Switchgear closed

Test to earth and between poles :
Voltage is applied to one pole, the base and the other poles are earthed.

8.1.2. Switchgear open


Test to earth, between poles and across open switching device:
Voltage is applied successively to each terminal; the other terminals and the frame are earthed.

8.2. POWER FREQUENCY TEST

Withstand voltage test:
The specified voltage level is maintained for 60 s.

8.3. TEST WITH LIGHTNING IMPULSE VOLTAGE

Withstand voltage test:
15 impulses with the specified level are applied for both positive and negative polarities



2105

9. TESTS RESULTS:

9.1. POWER FREQUENCY TEST

Test condition	Terminals connected to earth	Voltage applied to	Test voltage kV	Correction factor		Results
				K	(1)	
open	FABCbc	a	50	0.954	A	Withstood 60 seconds
open	FABCac	b	50	0.954	A	Withstood 60 seconds
open	FABCab	c	50	0.954	A	Withstood 60 seconds
open	FBCabc	A	50	0.954	A	Withstood 60 seconds
open	FACabc	B	50	0.954	A	Withstood 60 seconds
open	FABabc	C	50	0.954	A	Withstood 60 seconds
closed	FBbCc	Aa	50	0.954	A	Withstood 60 seconds
closed	FAaCc	Bb	50	0.954	A	Withstood 60 seconds
closed	FAaBb	Cc	50	0.954	A	Withstood 60 seconds


(1) A = The correction factor K has been Applied NA = The correction factor K has Not been Applied
 AK = The correction factor K = 0.950 has been Applied (IEC 62271-1 (2007-10))

2/08

9.2. TEST WITH LIGHTNING IMPULSE VOLTAGE

Test condition	Earth connected to	Voltage applied to	pol.	Voltage applied KV	Correction factor		Results	Annex n°
					K	(1)		
closed	FBbCc	Aa	pos.	100	0.959	A	Waveform 1.27/ 47.91 μ s	051238
closed	FBbCc	Aa	pos.	125	0.959	A	Withstood 15 Impulses	051242
closed	FBbCc	Aa	neg.	100	0.959	A	Waveform 1.28/ 48.14 μ s	051242
closed	FBbCc	Aa	neg.	125	0.959	A	Withstood 15 Impulses	051246
closed	FAaCc	Bb	pos.	100	0.959	A	Waveform 1.29/ 48.02 μ s	051251
closed	FAaCc	Bb	pos.	100	0.959	A	Waveform 1.27/ 48.02 μ s	051258
closed	FAaCc	Bb	pos.	125	0.959	A	Withstood 15 Impulses	051302
closed	FAaCc	Bb	neg.	100	0.959	A	Waveform 1.29/ 48.15 μ s	051303
closed	FAaCc	Bb	neg.	125	0.959	A	Withstood 15 Impulses	051307
closed	FAaBb	Cc	pos.	100	0.959	A	Waveform 1.28/ 48.02 μ s	051308
closed	FAaBb	Cc	pos.	125	0.959	A	Withstood 15 Impulses	051316
closed	FAaBb	Cc	neg.	100	0.959	A	Waveform 1.28/ 48.19 μ s	051317
closed	FAaBb	Cc	neg.	125	0.959	A	Withstood 15 Impulses	051321
open	FBCabc	A	pos.	100	0.959	A	Waveform 1.28/ 48.07 μ s	051338
open	FBCabc	A	pos.	125	0.959	A	Withstood 15 Impulses	051342
open	FBCabc	A	neg.	100	0.959	A	Waveform 1.28/ 48.12 μ s	051343
open	FBCabc	A	neg.	125	0.959	A	Withstood 15 Impulses	051347
open	FACabc	B	pos.	100	0.959	A	Waveform 1.28/ 47.99 μ s	051402
open	FACabc	B	pos.	125	0.959	A	Withstood 15 Impulses	051406
open	FACabc	B	neg.	100	0.959	A	Waveform 1.28/ 48.14 μ s	051407
open	FACabc	B	neg.	125	0.959	A	Withstood 15 Impulses	051411
open	FABabc	C	pos.	100	0.959	A	Waveform 1.27/ 47.98 μ s	051421
open	FABabc	C	pos.	125	0.959	A	Withstood 15 Impulses	051425
open	FABabc	C	neg.	100	0.959	A	Waveform 1.28/ 48.19 μ s	051426
open	FABabc	C	neg.	125	0.959	A	Withstood 15 Impulses	051430

(1) **A** = The correction factor K has been Applied **NA** = The correction factor K has Not been Applied
AK = The correction factor K = 0.950 has been Applied (IEC 62271-1 (2007-10))







Test condition	Earth connected to	Voltage applied to	pol.	Voltage applied KV	Correction factor		Results	Annex n°
					K	(1)		
open	FABCbc	a	pos.	100	0.959	A	Waveform 1.18/ 49.44 µs	051459
open	FABCbc	a	pos.	125	0.959	A	Withstood 15 Impulses	051503
open	FABCbc	a	neg.	100	0.959	A	Waveform 1.17/ 49.60 µs	051504
open	FABCbc	a	neg.	125	0.959	A	Withstood 15 Impulses	051508
open	FABCac	b	pos.	100	0.959	A	Waveform 1.17/ 49.51 µs	051519
open	FABCac	b	pos.	125	0.959	A	Withstood 15 Impulses	051523
open	FABCac	b	neg.	100	0.959	A	Waveform 1.18/ 49.62 µs	051524
open	FABCac	b	neg.	125	0.959	A	Withstood 15 Impulses	051528
open	FABCab	c	pos.	100	0.959	A	Waveform 1.18/ 49.67 µs	051530
open	FABCab	c	pos.	125	0.959	A	Withstood 15 Impulses	051534
open	FABCab	c	neg.	100	0.959	A	Waveform 1.18/ 49.59 µs	051534
open	FABCab	c	neg.	125	0.959	A	Withstood 15 Impulses	051538

(1) A = The correction factor K has been Applied NA = The correction factor K has Not been Applied
AK = The correction factor K = 0.950 has been Applied (IEC 62271-1 (2007-10))

2/2

10. TEST PHOTOGRAPHIES




IM								
Ur	24 kV	Ud	50 kV	Up	125 kV	IAC	KA	0
Ik	12,5 kA	tk	1 s	Ip	31,5 kA	A _{int}		
I _r	630 A	fr	50/60 Hz			789668Z		
SF6	0,210 kg	Pre	40 kPa			HN 64 S 41-IEC 62271-200		

[Handwritten signature]
2109

3

11. TERMINAL IDENTIFICATION




[Handwritten signature]



[Handwritten signature]

[Handwritten signature]

2110



12.2. REPARTITOR (REF AAV7603302)



Handwritten notes and signatures on the right side of the page, including a large signature and the date '2/12'.

3



Power European Laboratory



ACCREDITATION N° 1-0259
PORTÉE DISPONIBLE
SUR WWW.COFRAC.FR

Laboratoire Essais Moyenne Tension
Schneider-Electric Industries SAS
ZAC Champ Saint Ange
F-38760 Varcas

Test Report

N° TFR_200902678_019

To : David PELLISSIER

Objective

Temperature rise Test objective : Validation of the news deflector

Test

Starting date : 17/05/2010 Completed date : 20/05/2010

Test performed : Temperature rise test at 630 A three-phase 50 Hz

Standards : CEI 62271-200

Items tested

Apparatus : SM6 24 – modulars switchboard 24 KV

Designation : **Schneider Electric SM6**
Manufacturer : Schneider Electric SA – Rueil Malmaison - FRANCE

Items identification :

- Serial number : 0928133L / 0928159L / 0928135L
- Rated voltage (kV) : 24
- Rated normal current (A) : 630
- SF6 mass at (Kg) : 0,210
- Drawing n°: 373002102 ind 02 / 373002302 ind 02
- AAV7747602 ind 12 / AAV7968502 ind 11

Samples : 1

Conclusion

Tests are in accordance with the standard IEC 62271-200

*The performance of the apparatus tested and the results obtained are shown in the tables, oscillograms and photographs enclosed. This document relate only to the items presented for testing.
To declare, or not, the accordance to the specification, the results uncertainties are not taken into account.*

Dept: LEMT 38V		Technical manager :
Test leader	Izzo Pasquale	
Number of pages :	12	
Approval date :	26/05/2010	B. VANDENBERGUE

*This test report can only be copied as a photographic facsimile in its entirety.
Accreditation COFRAC attests only competence of the laboratory for the tests alone covered with accreditation.
The COFRAC is signatory of the multilateral agreement of EA (European co-operation for Accreditation) and of ILAC (International Laboratory Accreditation Cooperation) of equivalence recognition of test reports or analysis.*

2013



CONTENT

1 PRODUCT DESCRIPTION..... 3

2 TEST DESCRIPTION 4

3 RESULTS 6


4 OSCILLOGRAM 7

5 DRAWING..... 9

1
2
3
4
5
6
7
8
9

1 PRODUCT DESCRIPTION

1.1 Sampling :



1.2 Detailed description of the item tested :


SWICHT:

Manufacturer	:	Schneider Electric Industries SA
Designation	:	Schneider Electric IM375
Number of poles	:	3
Phase to phase	mm	: 200
Rated voltage	kV	: 24
Lightning impulse withstand voltage	kV	: 125
Power frequency withstand voltage	kV	: 50
Frequency	Hz	: 50/60
Rated normal current	A	: 630
Short circuit making current	kA	: 31.5
Interrupting medium	:	SF6
SF6 mass at à 20°C	Kg	: 0,210
Drawing n°	:	373002102 ind 02

2 TEST DESCRIPTION


2.1 Specific test conditions :

- The switchboard is connected with 1 Copper cable of 240 mm² per phase.
- A short-circuit is placed in end of the cables
- The thermocouples used are Copper-Constantan.
- Frequency : 50 Hz
- Air velocity : 0.1 m/s



2.2 Detailed description of the tests :

- Drawing of connections and thermocouples position :



3 RESULTS

- Measurement of the circuit resistance (I = 100 Adc) :

- Before temperature-rise test :

Measurement between	Phase 1 ($\mu\Omega$)	Phase 2 ($\mu\Omega$)	Phase 3 ($\mu\Omega$)
1 / 7	159	166	166

- After temperature-rise test :

Measurement between	Phase 1 ($\mu\Omega$)	Phase 2 ($\mu\Omega$)	Phase 3 ($\mu\Omega$)
1 / 7	156	158	161

- Values of the temperature rise at : 630 A


- Ambient temperature : 24,2 °C

Thermocouple	Nature of the part : material, dielectric	Temperature rise (K)			Maximum Value (*)
		Phase 1	Phase 2	Phase 3	
1	Connection tin-coated in air	53.9	53.5	53.6	65
2	Point TG insulated	53.5	53.1	53.1	65
3	Point TG insulated	54.9	56.3	55.8	65
4	Connection tin-coated in air	53.3	54.8	54.5	65
5	Point TG insulated	55.3	56.6	57.4	65
6	Point TG insulated	53.8	56.9	54.9	65
7	Connection tin-coated in air	55	59.6	56.3	65


(*) : - Maximum value of the temperature rise at ambient air temperature not exceeding 40°C and for 50 Hz frequency

4 OSCILLOGRAM


Phase 1 :





Phase 2 :



Phase 3 :



5 DRAWING



Schneider
Electric



110812

373002102

02



Two large, stylized handwritten signatures in black ink, located at the bottom right of the page. The first signature is more complex and larger, while the second is smaller and more fluid.






Schneider
Electric

410112


373002302

02



2127



Power European Laboratory

Laboratoire Essais Moyenne Tension
Schneider-Electric Industries SAS
ZAC Champ Saint Ange
F-38760 Varcès

Test Report

N° TFR_20090903156_003

To : Serge PONS

Objective

Dielectric test of the upper bus bar on a 6 enclosures combination.

Test

Starting date : 21/09/2009

Completed date : 24/09/2009

Test performed :
Power frequency : 65kV / 50 Hz 1min
Lightning impulse : 125kV

Standards : IEC 62271-200

Items tested

Apparatus : SM6

Designation : **Schneider Electric** SM6 electric panel composed by 6 functions :
IM - QM - DM1-A - DM1-A - IMB - GBC-A

Manufacturer : Schneider Electric SA - Rueil Malmaison - FRANCE

Items identification :

- Identification number : SM6386
- Rated voltage (kV) : 24
- Rated normal current (A) : 630
- Short-circuit breaking current (kA) : 25
- SF6 mass at (Kg): 0,210
- Drawing N°: 373002102 rev 01 - 373002302 rev 01 - 373121602 rev 01 373110602 rev 01
372984002 rev 01


Samples : 6

Conclusion

The upper bus bar dielectric test is conforme

Dept: LEMT 38V		Technical manager :
Test leader	Pascal MARTIN	
Number of pages :	18	
Approval date :	25/02/2010	B. VANDENBERGUE

The performance of the apparatus tested and the results obtained are shown in the tables, oscillograms and photographs enclosed. This document relate only to the items presented for testing.
This test report can only be copied as a photographic facsimile in its entirety.



CONTENT

1 PRODUCT DESCRIPTION..... 3


2 TEST DESCRIPTION 11

3 RESULTS 12

4 DRAWING..... 14


A large, stylized handwritten signature in black ink.

A smaller, stylized handwritten signature in black ink.




1 PRODUCT DESCRIPTION

1.1 Sampling:




[Handwritten signatures]



1.2 Detailed description of the item tested :

Switch

Manufacturer		: Schneider Electric Industries SA
Designation		: Schneider Electric SM6 IM - IMB
Number of poles		: 3
Phase to phase	mm	: 200
Rated voltage	kV	: 24
Lightning impulse withstand voltage	kV	: 125
Power frequency withstand voltage	kV	: 65
Frequency	Hz	: 50/60Hz
Rated normal current	A	: 630
Short time withstand current	kA	: 25
Peak withstand current	kA	: 65
Duration of short circuit	s	: 1
Short circuit making current	kA	: 52
Interrupting medium		: SF6
SF6 mass at à 20°C	Kg	: 0,21
Operating mechanism type		: /
Degree of protection		: IP3X
Drawing n°	: IM:	373002102rev01
	IMB:	373121602rev01




Switch

Manufacturer		: Schneider Electric Industries SA
Designation		: Schneider Electric SM6 QM
Number of poles		: 3
Phase to phase	mm	: 200
Rated voltage	kV	: 24
Lightning impulse withstand voltage	kV	: 125
Power frequency withstand voltage	kV	: 65
Frequency	Hz	: 50/60Hz
Rated normal current	A	: 200
Short time withstand current	kA	: 25
Peak withstand current	kA	: 65
Duration of short circuit	s	: 1
Short circuit making current	kA	: 52
Interrupting medium		: SF6
SF6 mass at à 20°C	Kg	: 0,21
Operating mechanism type		: /
Degree of protection		: IP3X
Drawing n°	: QM:	373002302rev01



Disconnecter :

Manufacturer		: Schneider Electric Industries SA
Designation		: Schneider Electric IM – IMB – QM
Number of poles		: 3
Phase to phase	mm	: 200
Rated voltage	kV	: 24
Lightning impulse withstand voltage		
- To earth and between poles	kV	: 125
- Accross the isolating distance	kV	: 145
Power frequency withstand voltage		
- To earth and between poles	kV	: 65
- Accross the isolating distance	kV	: 79
Frequency	Hz	: 50/60Hz
Rated normal current	A	: 630
Short time withstand current	kA	: 25
Peak withstand current	kÂ	: 65
Duration of short circuit	s	: 1
Short circuit making current	kÂ	: 52
Interrupting medium		: SF6
SF6 mass at à 20°C	Kg	: 0,21
Drawing n°		: IM: 373002102rev01 QM: 373002302rev01 IMB: 373121602 rev 01



Disconnecter :

Manufacturer		:	Schneider Electric Industries SA
Designation		:	Schneider Electric DM1A
Number of poles		:	3
Phase to phase	mm	:	200
Rated voltage	kV	:	24
Lightning impulse withstand voltage			
- To earth and between poles	kV	:	125
- Accross the isolating distance	kV	:	145
Power frequency withstand voltage			
- To earth and between poles	kV	:	65
- Accross the isolating distance	kV	:	79
Frequency	Hz	:	50/60Hz
Rated normal current	A	:	630
Short time withstand current	kA	:	25
Peak withstand current	kA	:	65
Duration of short circuit	s	:	1
Interrupting medium		:	SF6
SF6 mass at à 20°C	Kg	:	0,21
Drawing n°		:	DM1A: 372984002rev01




The bottom right section of the page contains three handwritten signatures in black ink. Above the signatures is a vertical stamp that reads 'RECEIVED' in a stylized font. The signatures are written in a cursive style.

2031



Dowstream earthing switch :

Manufacturer		: Schneider Electric Industries SA
Designation		: Schneider Electric SM6 QM – DM1A
Number of poles		: 3
Phase to phase	mm	: 200
Rated voltage	kV	: 24
Lightning impulse withstand voltage		
- To earth and between poles	kV	: 125
Power frequency withstand voltage	kV	: 65
Frequency	Hz	: 50/60Hz
Short time withstand current	kA	: 2
Peak withstand current	kÂ	: 5
Duration of short circuit	s	: 1
Short circuit making current	kÂ	: 5
Short circuit breaking current	kÂ	: 2
Drawing n°		: QM: 373002302rev01 DM1-A: 372984002rev01



Circuit breaker :

Manufacturer		: Schneider Electric Industries SA
Designation		: Schneider Electric SM6 DM1-A
Number of poles		: 3
Phase to phase	mm	: 250
Rated voltage	kV	: 24
Lightning impulse withstand voltage	kV	: 125
Power frequency withstand voltage	kV	: 65
Frequency	Hz	: 50/60Hz
Rated normal current	A	: 630
Short time withstand current	kA	: 25
Peak withstand current	kA	: 65
Duration of short circuit	s	: 1
Short circuit making current	kA	: 65
Short circuit breaking current	kA	: 25
Operating sequence		
C - 3mn - CO - 3mn - CO		: Yes
O - 0.3s - CO - 3mn - CO		: Yes
O - 0.3s - CO - 15s - CO		: Yes
Interrupting medium		: SF6
SF6 mass at à 20°C	Kg	: 0,336
Operating mechanism type		: RI
Supply Voltage		
- Motor	V	: 220
- Opening	V	: 220
- Closing	V	: 220
Drawing n°		: DM1A: 372984002rev01