




Switching surge operating duty test  
Leakage current measurements  
Power frequency voltage 9.66 kVrms  
Section No.9., rated 10.83 kVrms  
Time scale : 10.0 ms/div  
Voltage scale: 10.0 kV/div




Current scale: 10.0 mA/div  
Immediately after 2nd discharge.



Current scale: 2.0 mA/div  
30 min after 2nd discharge.



Current scale: 2.0 mA/div  
Before 1st discharge at 61.2 °C.



Current scale: 5.0 mA/div  
10 min after 2nd discharge.

This document contains confidential test data. Reproduction by unauthorized persons without written permission of ABB is prohibited.


Switching surge operating duty test  
Section No.9., rated 10.83 kVrms

Second long duration current  
impulse followed by TOV

Time scale: 20.0 ms/div

Voltage scale: 10.0 kV/div

Current scale: 500.0 A/div




Temporary overvoltage  
(TOV)  
during 10 sec followed by  
0.87 x rated voltage.

Time scale: 2.0 sec/div

Voltage scale: 10.0 kV/div  
(10.96 kVrms,  
9.66 kVrms)

Current scale: 200.0 mA/div



This document contains confidential test data. Reproduction by unauthorized persons without written permission of ABB is prohibited.

000244


ВЯРНІЙ  
ОРИГІНАЛ



Handwritten signatures and marks at the bottom left of the page.

Handwritten signature at the top right of the page.

Switching surge operating duty test  
Additional long duration current impulse  
3rd application  
Time scale : 1000.0  $\mu$ s/div  
Voltage scale: 10.0 kV/div  
Current scale: 500.0 A/div  
Energy scale : 20.0 kJ/div




Section No.9.  
rated 10.83  
Voltage: 20.05 kV  
Current 919.4 A  
Energy : 58.00 kJ


This document contains confidential business information. Its contents may not be copied, stored or printed on any unsecured process without the written permission of ABB  
10 ABB 2004

*Handwritten signature*

Switching surge operating duty test  
Additional long duration current impulse  
3rd application  
Time scale : 1000.0  $\mu$ s/div  
Voltage scale: 10.0 kV/div  
Current scale: 500.0 A/div  
Energy scale : 20.0 kJ/div



Section No.7.  
rated 10.83 kVrms  
Voltage: 20.03 kV  
Current: 917.8 A  
Energy : 55.93 kJ





Section No.8  
rated 10.83 kVrms  
Voltage: 19.98 kV  
Current 928.1 kA  
Energy : 56.52 kJ

This document contains confidential business information. Its contents may not be copied, stored or printed on any unsecured process without the written permission of ABB  
10 ABB 2004


*Handwritten signature*

*Handwritten signature*

000245




Residual voltage test at 10 kA, 8/20  $\mu$ s  
Section rated 10.83 kVrms  
Section No. 7  
Time scale: 5.0  $\mu$ s/div




This document contains confidential data. It is intended for use only by authorized personnel. Its content may not be copied, stored, or transmitted in any form without the prior written permission of ABB.

Residual voltage test at 10 kA, 8/20  $\mu$ s  
Section rated 10.83 kVrms  
Section No. 7  
Time scale: 10.0  $\mu$ s/div



This document contains confidential data. It is intended for use only by authorized personnel. Its content may not be copied, stored, or transmitted in any form without the prior written permission of ABB.




000246

ВРАНО  
ОРИГИНАЛ




Residual voltage test at 10 kA 8/20  $\mu$ s  
Section rated 10.83 kVrms  
Section No. 8  
Time scale: 10.0  $\mu$ s/div




This document contains our Restricted Data and is for internal use only. It is not to be copied, stored or passed on to any unauthorized person without written permission of M&S (4/25/2004)

*Handwritten signature*

Residual voltage test at 10 kA 8/20  $\mu$ s  
Section rated 10.83 kVrms  
Section No. 8  
Time scale: 10.0  $\mu$ s/div



This document contains our Restricted Data and is for internal use only. It is not to be copied, stored or passed on to any unauthorized person without written permission of M&S (4/25/2004)




*Handwritten signature*

*Handwritten signature*


*Handwritten signature*

000247

ВЯРНО С  
ОРИГИНАЛА





Residual voltage test at 8/20  $\mu$ s  
Section rated 10.83 kVrms  
Section No. 9  
Time scale: 10.0  $\mu$ s/div



This document contains confidential business information. Its disclosure may be illegal, harmful, or based on any unauthorized person without the permission of ABB HV ASB 2004

Residual voltage test at 10 kA 8/20  $\mu$ s  
Section rated 10.83 kVrms  
Section No. 9  
Time scale: 10.0  $\mu$ s/div




This document contains confidential business information. Its disclosure may be illegal, harmful, or based on any unauthorized person without the permission of ABB HV ASB 2004

000248


ВЯРНО  
КОПИЕ  
ОРИГИНАЛА



No 1 Principal design of circuit for reference voltage test (AC).



No 2 Principal design of circuit for reference voltage (DC) measuring.



This document contains the Intellectual Property Rights of the author. It is not to be reproduced or used in any way without the written permission of the author.

ENCLOSURE

TEST CIRCUIT - INSTRUMENT SPECIFICATION

The main test report contains only a very short description of test circuits and measuring instruments. However, a detailed specification of different test circuits, designated 1-9, is found in this enclosure. For each circuit the main components are shown by a sketch in which also all instruments for measuring of voltages, currents and temperatures could be identified. In a belonging "Equipment and Instrument Table" all important data concerning the used instruments as type identification, accuracy and calibration intervals are listed.

Note! All test circuits in the enclosure can not necessary be referred to the test report. This enclosure is used as a basic document for all test reports on surge arresters, and therefore contains a summary of all frequently used test circuits.

This document contains the Intellectual Property Rights of the author. It is not to be reproduced or used in any way without the written permission of the author.

692000

ВЯРНО  
ОРИГИНАЛ




*[Handwritten signature]*


*[Handwritten signature]*

*[Handwritten signature]*

No 5 Test circuit for transmission line discharge test. (All tests including approximately rectangular current impulses.)




No 6 Test circuit for nominal current operating duty test 5, 10, 15 or 20 kA wave shape 8/20  $\mu$ s. (Applications of an impulse current with the test section energized at power frequency voltage. Alternatives with power frequency voltage applied a short period of time after the impulses or impulse applications without any power frequency voltage are also covered by the test circuit.)




This document contains confidential technical information. Its content may not be copied, stored or passed on to any unauthorised person without written permission of ABB © ABB 2004

*[Handwritten signature]*

No 3 Principal design of circuit for current sharing test



No 4 Test circuit for residual-voltage test (discharge-voltage time characteristic). All tests including energy withstand and/or residual-voltage (discharge-voltage) tests with a current front time less than or equal to 1 ms and approximately sinusoidal wave shape.




This document contains confidential technical information. Its content may not be copied, stored or passed on to any unauthorised person without written permission of ABB © ABB 2004

*[Handwritten signature]*


000250

ВЕРНО  
ОРИГИНАЛ




*[Handwritten signature]*

No 9 Test circuit for residual voltage tests on complete arresters or arrester units. Test circuit is also used for checking of current sharing between complete arresters or arrester unit.




This document contains confidential information. Its content may not be copied, stored or passed on by any unauthorized person without written permission of ABB (© ABB 2004)

No 7 Test circuit for high current operating duty tests. (Application of a lightning impulse or switching impulse current.) Impulse current waveshape is approximately sinusoidal with an energy content higher than in tests according to fig. 6. Voltage is applied a short period of time after the impulse or during and after the impulse.



This document contains confidential information. Its content may not be copied, stored or passed on by any unauthorized person without written permission of ABB (© ABB 2004)

No 8 Test circuit for transmission line discharge tests followed by power frequency voltage. (All tests including approximately rectangular current impulse followed by power frequency voltage.)



*[Handwritten signature]*

000251

ОРГАН  
ВЯРНА



*[Handwritten signature]*



This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB (© ABB 2004)

LIST OF INSTRUMENTS AND EQUIPMENT

| Equipment or Instrument | Range of uses        | Manufacturer    | Type Identification         | Ratio   | Accuracy   | Calibration Interval times per year | Notes Model                        |
|-------------------------|----------------------|-----------------|-----------------------------|---------|------------|-------------------------------------|------------------------------------|
| A                       | Test object          | ABB             | ZnO                         |         |            |                                     | Arrester or prorated section       |
| Vd <sub>1</sub>         | Voltage div.         | -               | Resistive/Capacit., AKBP 1. | 1:1000  | ± 0.3%     | 2                                   | Resistance 5.6 M ohm               |
| Vd <sub>2</sub>         | "                    | "               | Resistive, AKBP 2.          | 1:96.00 | DC ± 0.2%  | 2                                   | 3.5 k ohm                          |
| Vd <sub>3</sub>         | "                    | "               | Resistive, E-A553           | 1:200,4 | DC ± 0.01% | 2                                   | 100.2 k ohm                        |
| Vd <sub>4</sub>         | "                    | "               | Resistive, E-E312           | 1:200   | DC ± 0.2%  | 2                                   | 7.5 k ohm                          |
| "                       | "                    | "               | "                           | 1:1000  | "          | 2                                   | "                                  |
| "                       | "                    | "               | "                           | 1:5000  | "          | 2                                   | "                                  |
| "                       | "                    | "               | "                           | 1:10000 | "          | 2                                   | "                                  |
| M <sub>1</sub>          | Multimeter           | Hewlett Packard | ZE-F587                     |         | 0.1%       | 2                                   | Digital multimeter                 |
| M <sub>2</sub>          | Multimeter           | Hewlett Packard | ZE-F784                     |         | 0.1%       | 2                                   | Digital multimeter                 |
| W <sub>1</sub>          | Wattmeter            | Ohio Brass      | ZE-A521                     |         |            | 2                                   | Lite Joule                         |
| W <sub>2</sub>          | AC/DC-Power Analyzer | Norma           | ZE-D364                     |         |            | 2                                   | D 6135                             |
| Osc 1                   | Storage osc.         | Tektronix       | E-C167                      |         | ± 2%       | 1                                   | 7623A                              |
| Osc 2                   | Transferr.           | Nicolet         | E-A410                      |         | ± 0.2%     | 1                                   | 4994                               |
| Osc 3                   | "                    | Nicolet         | E-E805                      |         | ± 0.2%     | 1                                   | 480                                |
| Osc 4                   | "                    | Nicolet         | E-F810                      |         | ± 0.2%     | 1                                   | Pro50                              |
| Osc 5                   | "                    | Nicolet         | E-J461                      |         | ± 0.2%     | 1                                   | Pro50                              |
| Osc 6                   | Storage osc.         | Tektronix       | E-A954                      |         | ± 2%       | 1                                   | 2430                               |
| Temp 1                  | Thermometer          | Tastotherm      | ZH-A656                     |         | ± 0.6%     | 1                                   | D 700 Utilizing thermocouples      |
| Temp 2                  | Recorder             | TOA             | ZE-C003                     |         | ± 0.5      | 1                                   | EPR type Chromel-Alumel            |
| T <sub>1</sub>          | Voltage transf.      | ABB             | EMFC, AKBP 3.               | 1:1000  | Class 1.0  | Test Report 83-12-05                | Ratio error 0.14%                  |
| T <sub>2</sub>          | Current transf.      | "               | TXL                         |         |            | 1                                   | Arrester leakage current meter     |
| T <sub>3</sub>          | Power transf.        | "               | EOMA 441                    | 1:150   |            |                                     | 5 kA                               |
| T <sub>4</sub>          | Power transf.        | "               | TMZ                         |         |            |                                     | 5 MVA                              |
| T <sub>5</sub>          | Power generator      | "               | G 1513                      |         |            |                                     | short-circuit gen. 2400 A at 12 kV |

HVP/AK 04-22  
Enclosure 1:7

This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB (© ABB 2004)

LIST OF INSTRUMENTS AND EQUIPMENT

| Equipment or Instrument | Range of uses | Manufacturer     | Type Identification | Ratio | Accuracy | Calibration Interval times per year | Notes Model |
|-------------------------|---------------|------------------|---------------------|-------|----------|-------------------------------------|-------------|
| Datalogger              | Thermometer   | Inlab            | M-C183              |       |          | 1                                   | AAC-2       |
| Temp 3                  | "             | Tastotherm       | M-A506              |       |          | 1                                   | D700H       |
| Temp 4                  | "             | "                | M-A175              |       |          | 1                                   | D700        |
| Temp 5                  | "             | "                | M-C011              |       |          | 1                                   | D700        |
| Temp 6                  | "             | ASEA             | M-B722              |       |          | 1                                   | Fiber 1010  |
| Temp 7                  | "             | "                | M-B723              |       |          | 1                                   | Fiber 1010  |
| F1                      | Filter        | Kron-Hite        | E-C711              |       | ± 5%     | 1                                   |             |
| P1                      | Power supply  | Deha Elektronika | E-G135              |       |          | 1                                   | SM 3004-D   |
| M1                      | Multimeter    | Fluke            | E-A322              |       | ± 0.1%   | 1                                   | 6020A       |
| CM                      | C-meter       | Doic             | E-D094              |       |          | 1                                   | 180A        |

HVP/AK 04-22  
Enclosure 1:8

000252

ВЕРНО  
ОРИГИНАЛ



This document contains confidential business information. Its content may not be copied, shared or passed on to any unauthorized person without written permission of ABB (c) ABB 2004

LIST OF INSTRUMENTS AND EQUIPMENT

| Equipment or Instrument | Range of uses | Manufacturer | Type    | Ratio | Accuracy                | Calibration Interval times per year | Notes Model |
|-------------------------|---------------|--------------|---------|-------|-------------------------|-------------------------------------|-------------|
| Sh <sub>1</sub>         | Coax shunt    | ABB          | ZE-A117 |       | ± 0.5%                  | 1                                   | 0.020 ohm   |
| Sh <sub>2</sub>         | "             | "            | ZE-A118 |       | ± 0.5%                  | 1                                   | 0.020 ohm   |
| Sh <sub>3</sub>         | "             | "            | ZE-A115 |       | ± 0.5%                  | 1                                   | 0.005 ohm   |
| Sh <sub>4</sub>         | Optical shunt | "            |         |       | ± 1% with test ± 0.5%   | In connection                       | 10 k ohm    |
| Sh <sub>5</sub>         | Shunt         | "            |         |       | ± 0.5% with test ± 0.5% | 2                                   | 1 k ohm     |
| Sh <sub>6</sub>         | "             | "            |         |       | ± 0.5% with test ± 0.5% | In connection                       | 10 k ohm    |
| Sh <sub>7</sub>         | Coax shunt    | Haefly       | ZE-B251 |       | ± 0.5%                  | 1                                   | 0.0050 ohm  |
| Sh <sub>8</sub>         | "             | "            | ZE-C115 |       | ± 0.5%                  | 1                                   | 0.0050 ohm  |
| Sh <sub>9</sub>         | "             | "            | ZE-C112 |       | ± 0.5%                  | 1                                   | 0.0050 ohm  |
| Sh <sub>10</sub>        | "             | "            | ZE-B250 |       | ± 0.5%                  | 1                                   | 0.0256 ohm  |
| Sh <sub>11</sub>        | Coax shunt    | ABB          | ZE-A487 |       | ± 0.5%                  | 1                                   | 0.0050 ohm  |
| Sh <sub>12</sub>        | "             | "            | ZE-A119 |       | ± 0.5%                  | 1                                   | 0.0050 ohm  |
| Sh <sub>13</sub>        | "             | "            | ZE-A120 |       | ± 0.5%                  | 1                                   | 0.0050 ohm  |
| Sh <sub>14</sub>        | "             | "            | ZE-A121 |       | ± 0.5%                  | 1                                   | 0.0050 ohm  |
| Sh <sub>15</sub>        | "             | "            | ZE-A116 |       | ± 0.5%                  | 1                                   | 0.020 ohm   |
| Sh <sub>16</sub>        | "             | "            | ZE-D225 |       | ± 0.5%                  | 1                                   | 0.020 ohm   |
| Sh <sub>17</sub>        | "             | "            | ZE-C546 |       | ± 0.5%                  | 1                                   | 0.020 ohm   |
| Sh <sub>18</sub>        | "             | "            | ZE-C809 |       | ± 0.5%                  | 1                                   | 0.020 ohm   |

NOTE! Values for voltage dividers and shunts are nominal values.

HVP/AK 04-22  
Enclosure 1:9

This document contains confidential business information. Its content may not be copied, shared or passed on to any unauthorized person without written permission of ABB (c) ABB 2004



LIST OF INSTRUMENTS AND EQUIPMENT

| Equipment or Instrument | Range of uses | Manufacturer | Type    | Ratio | Accuracy | Calibration Interval times per year | Notes Model |
|-------------------------|---------------|--------------|---------|-------|----------|-------------------------------------|-------------|
| Sh <sub>19</sub>        | Coax shunt    | ABB          | ZE-C807 |       | ± 0.5%   | 1                                   | 0.020 ohm   |
| Sh <sub>20</sub>        | "             | "            | ZE-C808 |       | ± 0.5%   | 1                                   | 0.020 ohm   |
| Sh <sub>21</sub>        | "             | "            | ZE-D895 |       | ± 0.5%   | 1                                   | 0.002 ohm   |
| Sh <sub>22</sub>        | "             | "            | ZE-D402 |       | ± 0.5%   | 1                                   | 0.003 ohm   |
| Sh <sub>23</sub>        | "             | "            | ZE-F045 |       | ± 0.5%   | 1                                   | 1000 ohm    |
| Sh <sub>24</sub>        | "             | "            | ZE-F043 |       | ± 0.5%   | 1                                   | 100 ohm     |
| Sh <sub>25</sub>        | "             | "            | ZE-F044 |       | ± 0.5%   | 1                                   | 10 ohm      |

NOTE! Values for voltage dividers and shunts are nominal values.

HVP/AK 04-22  
Enclosure 1:10


000253




*Handwritten signature*

HVP/AK 04-22  
Enclosure 1:11

Test section used for operating duty test



Complete prorated test section



Bottom cover, insulator and the two ZnO- blocks (top cover removed).

The document contains unclassified business information. Its content may not be copied, stored or passed on to any unauthorized person without written permission of ABB  
04 2025 2004

*Handwritten signature*

000254

ВЯНО С  
ОРИНАЛА



*Handwritten signature*



Type tests on PEXLIM P surge arresters

Test object Three ABB PEXLIM P varistors  
rated voltage 6.37 to 6.38 kV<sub>rms</sub>.

Standard IEC standard 60099-4, Edition 1.2, 2001-12

Test performed Accelerated ageing test in open air at 0.98 times  
the rated voltage during 1053 hours.

Tests completed 2004-08-04

Tests performed at ABB Power Technologies AB - Surge Arrester Laboratory

Witnessing The tests were witnessed by SATS Inspector Mr. Minoo Mobedjina.

This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB (c) ABB 2004

**SATS Certification**  
**Minoo Mobedjina**  
Inspector

на основание чл. 2 от ЗЗЛД

15/9-2004

на основание чл. 2 от ЗЗЛД

Tests reported by : Kent Riik

Report approved by : Lennart Stenström

на основание чл. 2 от ЗЗЛД

Report consists of : 10 pages

We hereby certify that the objects specified above have successfully passed the test herein reported, thereby verifying guaranteed data.

Ludvika 2004-08-27

ABB Power Technologies AB  
High Voltage Products/Surge Arresters  
Quality Department

на основание чл. 2 от ЗЗЛД



Kurt Jansson

**ABB Power Technologies AB**  
**000255**



CONTENTS

1 SUMMARY

2 ACCELERATED AGEING TEST PROCEDURE

- 2.1 General
- 2.2 Test objects
- 2.3 Test procedure
- 2.4 Results
- 2.5 Conclusion

ENCLOSURE

This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB.  
(c) ABB 2004.

000256

ВЯРНО  
ОРИГИНАЛ



## 1 SUMMARY

Accelerated ageing tests have been performed on ABB's PEXLIM P type ZnO varistors in accordance with the IEC standard 60099-4, Edition 1.2, 2001-12.

The IEC standard requires testing during 1000 hours at an elevated temperature of 115 °C with the test samples in the surrounding medium of the arrester. The power losses after 1 to 2 hours,  $P_{1ct}$  (starting value) shall be compared with the power losses after 1000 hours,  $P_{2ct}$ , and the minimum power losses,  $P_{3ct}$ , during the 1000 hours test. If the power losses after 1000 hours are less than or equal to the starting value and less than or equal to  $1.1 * P_{3ct}$ , the operating duty tests specified in the proposed standard shall be performed on new varistor blocks without the use of correction factors to be applied to power frequency test voltages. If  $P_{2ct} > P_{1ct}$  and  $P_{2ct} \leq 1.1 * P_{3ct}$  correction factors are used to obtain the same increase in power losses on new varistor blocks as measured on blocks subjected to the accelerated ageing test. Finally, if  $P_{2ct} > 1.1 * P_{3ct}$  aged samples shall be used in the operating duty test.

ABB PEXLIM P surge arresters are equipped with a polymeric housing comprising glass-fiber reinforced plastic and silicon rubber. The rubber is bonded to the varistor surface by vulcanization. The arresters are used in open air, therefore, the tests were performed on sections (including the polymeric housing) in open air. The arrester were pretensioned to a total force of 40 kN before the test. A drawing of the used test section is shown in Enclosure 5.

## 2 ACCELERATED AGEING TEST PROCEDURE

### 2.1 General

The reference current for the ABB PEXLIM P surge arrester is defined at a peak value of 3 mA of the resistive component of the power frequency current. The reference voltage ( $U_{ref}$ ) is the peak value of power frequency voltage divided by  $\sqrt{2}$  measured at the reference current. The resistive current may be slightly asymmetrical in this current region. The reference voltage, therefore, always is defined as the minimum voltage measured at the reference current independent of polarity. The reference voltage ( $U_{ref}$ ) measured at  $23 \pm 5$  °C is checked on all complete assembled arrester units and must be equal to or higher than the rated voltage, ( $U_r$ ).

Furthermore, the reference voltage measurement is used to determine test stresses on prorated test sections. The rated voltage of a prorated test section is determined as  $U_r = U_{ref}$  in order to ensure that the prorated test section is exposed to higher or equal stresses than any complete surge arrester or surge arrester unit.

### 2.2 Test objects

Three prorated sections each comprising a polymeric housing and a single PEXLIM P varistor were tested.

The dimensions of the varistors were  $D=73.8$  mm and  $H=42.5$  mm.

Drawing for the varistor type is 5681 018-601.

The reference voltages, measured at a resistive peak current of 3 mA, and corresponding rated voltages are given in Table 1.

This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB (c) ABB 2004

000257

ВЯРНОЕ  
ОРИГИНАЛ

### 2.3 Test procedure

Prior to the accelerated ageing test, the reference voltage for each varistor was measured.

The test voltage for each of the three varistors was set individually to 0.98 times the measured reference voltage.

| Varistor No. | $U_{ref}$ (kV <sub>rms</sub> ) | $U_r$ (kV <sub>rms</sub> ) | Test voltage (kV <sub>rms</sub> ) |
|--------------|--------------------------------|----------------------------|-----------------------------------|
| 1            | 6.37                           | 6.37                       | 6.25                              |
| 2            | 6.38                           | 6.38                       | 6.25                              |
| 3            | 6.37                           | 6.37                       | 6.24                              |

Table 1.

The factor 0.98 was chosen in order to take into account maximum possible local voltage stress due to non-linear voltage distribution occurring in any PEXLIM P arrester.

The test-cycle was supervised by a data acquisition system connected to a computer. The system measured each test object individually with respect to test time, temperature, voltage, current, and power losses.

### 2.4 Results

The power losses during the accelerated ageing test are shown in Enclosure 1 as the ratio of the measured power losses to the starting value. The starting value is defined as the power losses measured 1 hour after the voltage application.

Complete a.c. characteristics (resistive leakage current vs. voltage) at room temperature and 120°C, both before and after the ageing test, are shown in Enclosures 2 to 4. For PEXLIM P arresters  $U_C$  (Continuous Operating Voltage) is less than or equal to  $0.8 \times U_r$ .

Thus, as can be seen from the Diagrams, the characteristics are improved after the tests.

The measured test voltage for each varistor is shown in Enclosure 1 as % of nominal test voltage. The temperature deviation for each varistor is shown in the same Enclosure as the difference between nominal temperature and measured temperature in °C.

| Varistor No. | $P_{1ct}$ [W] | $P_{2ct}$ [W] | $P_{3ct}$ [W] | $P_{2ct} / P_{1ct}$ | $P_{2ct} / P_{3ct}$ |
|--------------|---------------|---------------|---------------|---------------------|---------------------|
| 1            | 15.467        | 7.563         | 7.020         | 0.489               | 1.077               |
| 2            | 12.015        | 6.640         | 6.265         | 0.563               | 1.060               |
| 3            | 10.935        | 7.152         | 6.691         | 0.654               | 1.069               |

Table 2.

This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB (c) ABB 2004

000258

ВЯРНО С  
ОРИГИНАЛА

## 2.5 Conclusion

Power losses at start of the test,  $P_{1ct}$ , and after 1053 hours,  $P_{2ct}$ , as well the minimum value during the test,  $P_{3ct}$ , are shown in Table 2. The power losses after 1053 hours' testing ( $P_{2ct}$ ) are less than the power losses measured after 1 hour ( $P_{1ct}$ ). In addition ( $P_{2ct}$ ) is less than 1.1 times the minimum power losses ( $P_{3ct}$ ).




Hence, new PEXLIM P varistors shall be used in all type (design) tests without applying any correction factors.

This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB.  
(c) ABB 2004

000259

ВЯРНОЕ  
ОРИГИНАЛ






This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB (c) ABB 2004

000260

ВЪРНОС  
ОРИГИНАЛА





This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB (c) ABB 2004

This document must not be copied without our written permission, and the contents thereof must not be imparted to third party nor be used for any unauthorized purpose. Contributions will be provided. ABB Switzerland Ltd

000261


ВЕРНО С  
ОРИГИНАЛА



**ABB**  
AC/DC Test on  
ZnO Varistors

AC-CHARACTERISTICS AT 20 AND 120 °C.  
BEFORE AND AFTER ACCELERATED AGEING  
TEST ON P 6 kV VARISTORS.  
NO. 2.

Date 04-08-24  
HVP/AK 04-28  
Enclosure 3




This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB (c) ABB 2004

The document may not be copied without our written permission, and the contents thereof may not be prepared in this party nor be used for any unauthorized purposes. Confidentiality will be preserved. ABB Switzerland Ltd

000262

ВАРНИК  
ОРИГИНАЛ




**ABB**  
AC/DC Test on  
ZnO Varistors

AC-CHARACTERISTICS AT 20 AND 120 °C.  
BEFORE AND AFTER ACCELERATED AGEING  
TEST ON P 6 KV VARISTORS.  
NO. 3.

Date 04-08-24  
HVP/AK 04-28  
Enclosure 4

This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB.  
(c) ABB 2004

This document must not be copied without our written permission, and the contents thereof must not be imparted to any party, nor be used for any purpose other than that for which it was prepared. Compensation will be paid for any unauthorized copying.




000263

ЗАЯВНО С  
ОРИГИНАЛА



This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB  
(c) ABB 2004



Test section

000264

ВЯНО С  
ОРМПАЛА

КРАСИ  
СМОЛЯН  
ООД

**Обобщение на типовите изпитания на вентилен отвод PEXLIM P-X**

Металоокоисен ограничител на пренапрежения със силиконова външна обвивка.

| Извършени типови изпитания                                      | Стандарт                 | Доклад No.   | Издание    | Бележка/проверка  |
|---|--------------------------|--------------|------------|---|
| <b>Електрически тестове</b>                                     |                          |              |            |   |
| Изпитване на външна изолация                                    | IEC 60060-1, ANSI Std 4  | HVP/AK 02-03 | 2002-01-08 | Всички размери модули (36, 72 and 120kV)                              |
| Изпитване на ускорено стареене                                  | IEC 60099-4              | HVP/AK 04-28 | 2004-08-27 | Дългосрочна устойчивост при стрес с най-високо напрежение (0.98*Uref) |
| Изпитване на ускорено стареене                                  | ANSI/IEEE C62.11         | HVP/AK 04-29 | 2004-08-27 | Защитните нива  |
| Изпитване на остатъчно напрежение                               | IEC 60099-4              | HVP/AK 04-22 | 2004-06-11 | Възможност за покриване на клас 4                                     |
| Издръжливост на продължителен ток импулс                        | IEC 60099-4              | HVP/AK 04-22 | 2004-06-11 | Устойчивост на импулс и термична устойчивост                          |
| Изпитване за експлоатационни характеристики                     | IEC 60099-4              | HVP/AK 04-22 | 2004-06-11 |   |
| <b>Изпитване на ток на късо съединение</b>                      |                          |              |            |   |
| Тест на к.с. с голям ток (65kA)                                 | IEC 60099-4, Amendment 2 | HVP/AK 02-02 | 2002-01-08 | Метод за свръхнапрежение  |
| Тест на к.с. с малък ток (600A)                                 | IEC 60099-4, Amendment 2 | HVP/AK 02-02 | 2002-01-08 | Метод за свръхнапрежение  |
| <b>Изпитвания за стареене под въздействие на околната среда</b> |                          |              |            |   |
| Тест стареене от времето (1000 h солена мъгла)                  | IEC 60099-4, Amendment 2 | SATS 02-S01  | 2002-01-21 | Тест на 120 kV модул  |
| Тест за проникване на влага                                     | IEC 60099-4, Amendment 2 | HVP/AK 01-06 | 2001-12-20 | Тест на 120 kV модул  |
| Проверка на нискотемпературните характеристики                  |                          | HVP/AK 02-01 | 2002-01-07 | Тест на 120 kV модул при 2500Nm -50°C                                 |
| <b>Механични изпитания</b>                                      |                          |              |            |   |
| Изпитване на издръжливост на огъване                            |                          | HVP/AK 01-09 | 2001-12-10 | Проверява максимално използваемото огъване                            |
| Изпитване на разрушаване при огъване                            |                          | HVP/AK 01-07 | 2001-12-10 | при момент от ≥ 2500 Nm   |
| <b>Технически данни</b>   |                          |              |            |   |
| Защитни характеристики  |                          | Документ No. | Издание    |   |
| Характеристики при едновременно пренапрежение (TOV)             |                          | LAK 5882     | 2003-04-09 |   |
|   |                          | LAK 5881     | 2002-01-08 |   |

000265

ВАРНО С  
ОРИГИНАЛА


**ABB Силови Технологии АВ**

С настоящото удостоверяваме, че горните тестове, проверяват гарантираните данни за вентилен отвод тип PEXLIM P-X

Людвика 2002-01-25

ABB Силови Технологии

Напрежение/  
дел Качество



Handwritten signature

# SATS Certification

Scandinavian Association for Testing of Electric Power Equipment  
c/o – SINTEF Energy Research, Sem Saelandsv. 11, NO – 7465 Trondheim, Norway  
Telephone: + 47 73 59 72 00 Telefax: + 47 73 59 72 50 E-mail: SATS@energy.sintef.no

---

**Report of Performance No.: 02-S01**

**Title: Salt fog test 1000 hours on one surge arrester  
type PEXLIM P120-XH145**

Trondheim 2002-01-21

Place and date

Rolf Hegerberg


SATS Certification: Rolf Hegerberg

Copyright: SATS

000266

~~RoP 02-S01~~

ВЕРНО  
ОРИГИНАЛ



**REPORT OF PERFORMANCE No. 02-S01**

**Client** ABB Power Technology Products AB  
S-771 80 Ludvika, Sweden

**Test object** One surge arrester of composite material

**Designation** PEXLIM P120-XH145, Product number P3620

**Manufacturer** ABB Power Technology Products AB  
S-771 80 Ludvika, Sweden

**Ratings assigned by the manufacturer** Rated voltage 120 kV  
Maximum continuous operating voltage,  $U_c$  96 kV  
Creepage distance 3625 mm

**Tests performed** 1000 hours salt fog test at 98 kV AC, 50Hz

**Standards** IEC 60099-4, Amendment 2, October 2001

**Testing station** STRI AB, Ludvika Sweden.  
The laboratory is accredited (no: 1534) by SWEDAC

**Date of tests** November 8 – December 21, 2001

**Test results** The test object fulfilled the requirements in accordance with the standard.

**The documents forming this report** Title page and 7 numbered pages



Ludvika 2002-01-15  
Place and Date

на основание чл. 2 от ЗЗЛД

Laboratory Manager: Lars-Olof Gunnarsson

Göran Olsson  
SATS Inspector: Göran Olsson

000267





| <b>CONTENTS</b>                                 | <b>Page</b> |
|---|-------------|
| List of drawing numbers                         | 3           |
| 1. Test object                                  | 4           |
| 2. Tests  | 4           |
| 2.1. Test conditions                            | 4           |
| 2.2. Test procedure                             | 4           |
| 2.3. Water flow rate                            | 4           |
| 2.4. Test results                               | 4           |
| 3. Test set-up in chamber                       | 5           |
| 4. Conclusions                                  | 5           |
| 5. Dimension drawing                            | 6           |
| 6. Photograph of the test object after the test | 7           |

The tests were witnessed by mr Göran Olsson, representing SATS Certification, Norway

000268

ВЯРНО С  
ОРИГИНАЛА



**LIST OF DRAWING NUMBERS OF THE TEST OBJECT**

The manufacturer guarantees that the equipment submitted for tests is manufactured in accordance with the following drawing:

| Description       | Type             | Drawing  | Revision |
|-------------------|------------------|----------|----------|
| Dimension Drawing | Assembly drawing | LAK 5862 | 0        |

Manufacturers Representative

на основание чл. 2 от ЗЗЛД

Lennart Stenström

ABB Power Technology Products AB,  
Department AK

The dimension drawing is included in this report.

000269

ВЯРНО С  
ОРИГИНАЛА



## 1. TEST OBJECT

|                     |                                      |
|---------------------|--------------------------------------|
| Product description | Surge arrester of composite material |
| Designation         | PEXLIM P120-XH145                    |
| Product number      | P3620                                |

## 2. TESTS

1000h salt fog test with 98 kV AC, 50Hz with routine test before and after the salt fog test

### 2.1 Test conditions

|  |                              |
|--|------------------------------|
| Test chamber:                          | 3 x 3 x 5 (m) (W x L x H)    |
| Test voltage:                          | 98 kV AC                     |
| Test duration:                         | 1020 hours                   |
| Salinity:                              | 4 and 5 kg/m <sup>3</sup>    |
| Flow rate salt fog:                    | 4 l/h                        |
| Nozzles salt fog:                      | 4 pcs type acc. to IEC 60507 |
| Temperature:                           | 16 - 21°C                    |
| Number of test objects in the chamber: | 4                            |

### 2.2 Test procedure

The NaCl content of the water was 5 kg/m<sup>3</sup> from the start. According to IEC 60099-4, Amendment 2, the salt content was reduced when the second flashover occurred. The routine tests were carried out by ABB Power Technology Products AB, Surge Arresters. The routine tests before and after the salt fog test were witnessed by a SATS Inspector.

### 2.3 Water flow rate

As the chamber is large, the concentration of salt fog in the vertical direction is uneven. For the actual test the water flow rate was chosen in such a way that the condensation rate at the test object was about 1.5 - 2.0 ml/h on 80 cm<sup>2</sup> in accordance with IEC 60068-2-11. This condensation rate also corresponds to a flow rate of 0.4 l/m<sup>3</sup> per hour in a chamber with a volume of about 10 m<sup>3</sup>.

### 2.4 Test results

The first flashover occurred after 690 hours. The second flashover occurred after 734 hours and the salinity was then reduced to 4 kg/m<sup>3</sup>.

| Routine tests        | Ref. Voltage | Internal Corona |    |
|----------------------|--------------|-----------------|----|
|                      | kV rms       | kV rms          | pC |
| Before salt fog test | 124.4        | 108.0           | <5 |
| After salt fog test  | 125.5        | 108.0           | <5 |


000270

ВЯРНО  
ОРИГИНАЛ



*[Handwritten signature]*

### 3. Test set-up in chamber



### 4. Conclusions

The test object P3620 fulfilled the requirements in accordance with IEC 60099-4, Amendment 2.

The reference voltage had not decreased after the salt fog test  
Partial discharge level <5 pC both before and after the salt fog test.  
Two over-current trip-outs caused by test object P3620 occurred, at the salinity of 5 kg/m<sup>3</sup>.  
No erosion exceeding the thickness of external coating.  
No puncture of sheds was observed.  
No tracking was found on external coating.

*[Handwritten signature]*

*[Handwritten signature]*


*[Handwritten signature]*

000271

ВЯРНОС  
ОРИГИНАЛ



5. Dimension drawing of the test object



The object is used for testing of the test object. The object is used for testing of the test object. The object is used for testing of the test object.

PEXLIM P120-XH145  
Creepage distance: 3625 mm  
Weight: 44 kg


000272

ВАРПАС  
ОРИГИНАЛ

"КРАСН"   
 "СМОЛ"   
 "ТОО"

*Ed*

**6. Photograph of the test object after the test**



*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

000273

ВЕРНО  
ОРИГИНАЛ



**Summary of type tests and documentation for arrester type PEXLIM P-X**

Zinc-oxide surge arrester with HTV silicone rubber housing.

| Type tests performed                         | Standard                 | Report No.   | Issued     | Note/verification   |
|--|--------------------------|--------------|------------|---|
| <b>Electrical tests</b>                      |                          |              |            |   |
| External insulation test                     | IEC 60060-1, ANSI Std 4  | HVP/AK 02-03 | 2002-01-08 | All module sizes (36, 72 and 120kV)                           |
| Accelerated ageing test                      | IEC 60099-4              | HVP/AK 04-28 | 2004-08-27 | The long term stability at highest voltage stress (0.98*Uref) |
| Accelerated ageing test                      | ANSI/IEEE C62.11         | HVP/AK 04-29 | 2004-08-27 | The protection levels   |
| Residual voltage test                        | IEC 60099-4              | HVP/AK 04-22 | 2004-06-11 | Class 4 capability  |
| Long duration current impulse withstand test | IEC 60099-4              | HVP/AK 04-22 | 2004-06-11 | The impulse strength and thermal stability                    |
| Operating duty test                          | IEC 60099-4              | HVP/AK 04-22 | 2004-06-11 |   |
| <b>Short-circuit current tests</b>           |                          |              |            |   |
| High-current short-circuit test (65kA)       | IEC 60099-4, Amendment 2 | HVP/AK 02-02 | 2002-01-08 | Overvoltage method  |
| Low-current short-circuit test (600A)        | IEC 60099-4, Amendment 2 | HVP/AK 02-02 | 2002-01-08 | Overvoltage method  |
| <b>Environmental ageing tests</b>            |                          |              |            |   |
| Weather ageing test (1000 h salt fog)        | IEC 60099-4, Amendment 2 | SATS 02-S01  | 2002-01-21 | Test on 120 kV module   |
| Moisture ingress test                        | IEC 60099-4, Amendment 2 | HVP/AK 01-06 | 2001-12-20 | Test on 120 kV module   |
| Verification of low temperature performance  |                          | HVP/AK 02-01 | 2002-01-07 | Test on 120 kV module at 2500 Nm -50°C                        |
| <b>Mechanical tests</b>                      |                          |              |            |   |
| Bending strength test                        |                          | HVP/AK 01-09 | 2001-12-10 | Verifies a maximum usable bending moment of ≥ 2500 Nm         |
| Bending fatigue test                         |                          | HVP/AK 01-07 | 2001-12-10 |   |

**Data sheets**

Protective characteristics  
Temporary overvoltage (TOV) characteristics

**ABB Power Technologies AB**

на основании чл. 2 от 33ЛД

**Document No.**

LAK 5882  
LAK 5881


**Issued**

2003-04-09  
2002-01-08

The tests listed above verify guaranteed data for PEXLIM P-X arresters



ABB Power Technologies AB  
Surge Arresters



2002-01-25

Rev 2 (Revision date 2005-10-16)



Kurt Jansson

0000274



## Type tests on PEXLIM P Surge Arresters

Test objects: Surge arrester modules rated 36, 72 and 120 kV with the ZnO blocks replaced by insulating material

Standards: IEC 60099-4, first edition 1991-11  
IEC 60060-1, second edition 1989-11  
ANSI/IEEE Std C62.11-1993  
ANSI/IEEE Std 4-1978

Tests performed: Insulation withstand tests

Test report: Q 99-281

Validation: The test objects initially represented arrester modules used for arrester type PEXLIM Q. However, the physical dimensions for the modules used for arrester type PEXLIM P-X are identical. The test results, therefore, also are valid for arresters of type PEXLIM P-X.

Tests completed: 1999-10-21

Tests performed at: ABB Transformers AB/High Voltage Laboratory

Report consists of: 37 pages (Report Q 99-281, 36 pages)

We hereby certify that the objects specified above have successfully passed the test herein reported, thereby verifying guaranteed data.

Ludvika 2002-01-08

ABB Power Technology Products AB  
High Voltage Products/Surge Arresters  
Quality Department

This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB (c) ABB 2002

на основание чл. 2 от ЗЗЛД


Kurt Jansson



ABB Power Technology Products AB



000275







Type tests on PEXLIM P surge arresters

Test object            Three ABB PEXLIM P varistors  
                              rated voltage 6.37 to 6.38 kVrms

Standard                IEC standard 60099-4, Edition 1.2, 2001-12

Test performed        Accelerated ageing test in open air at 0.98 times  
                              the rated voltage during 1053 hours.

Tests completed        2004-08-04

Tests performed at    ABB Power Technologies AB - Surge Arrester Laboratory

Witnessing             The tests were witnessed by SATS Inspector Mr. Minoo Moberdjina.

SATS Certification  
Minoo Moberdjina  
Inspector

*Signature*

13/9-2004

This document contains confidential business information. Its content may not be copied, reprinted or otherwise disseminated without written permission of ABB.  
© ABB 2004

Tests reported by     : Kent Riik

Report approved by : Lennart Stenstrom

Report consists of    : 10 pages

We hereby certify that the objects specified above have successfully passed the test herein reported, thereby verifying guaranteed data.

Ludvika 2004-08-27

ABB Power Technologies AB  
High Voltage Products/Surge Arresters  
Quality Department

на основании чл. 2 от 33ЛД



Kurt Jansson



JI 1111

ABB Power Technologies AB

000276





Type tests on PEXLIM P surge arresters

Test object : Three ABB PEXLIM P varistors  
Duty-Cycle voltage rating 6.37 to 6.38 kVrms

Standard : ANSI/IEEE C62.11-1999

Test performed : Accelerated ageing test in open air at 0.98 times  
the duty-cycle voltage rating during 1053 hours.

Tests completed : 2004-08-04

Tests performed at : ABB Power Technologies AB - Surge Arrester Laboratory

Witnessing : The tests were witnessed by SATS Inspector Mr. Minoa Mobedjina.

**SATS Certification**  
Minoa Mobedjina

на основание чл. 2 от ЗЗЛД

1:1-2004

This document contains confidential business information. Its content may not be copied, altered or passed on to any unauthorized person without written permission of ABB © ABB 2004

About SATS : SATS "Scandinavian Association for Testing of Electric Power Equipment" is a member of Short circuit Liaison (STL) and a member of EOTC, European Electric Sector Committee ELSECOM, Agreement Group No. 0007.

Tests reported by : Kent Riik

Report approved by : Lennart Stenstrom

Report consists of : 10 pages

We hereby certify that the objects specified above have successfully passed the test herein reported, thereby verifying guaranteed data.

Ludvika 2004-08-27

ABB Power Technologies AB  
High Voltage Products/Surge Arresters  
Quality Department

на основание чл. 2 от  
ЗЗЛД

Kurt Jansson



ABB Power Technologies AB  
000277



*[Handwritten signature]*

Type tests on PEXLIM P-X surge arresters.

Test objects Prorated arrester sections acc. to IEC,  
rated voltage 6.29 to 10.85 kV

Standard IEC 60099-4, Edition 1.2, 2001-12

Test performed Residual voltage test  
Long duration current impulse withstand test, class 4  
Operating duty test, nominal current 20 kA

Tests completed 2004-04-23

Tests performed at ABB Power Technologies AB -Surge Arrester Laboratory

Tests reported by Jan-Erik Almen *J11i2-*

Report approved by : Lennart Stenstrom *[Signature]*

Report consists of : 69 pages

Witnessing : The tests were witnessed by Mr Mino Mobejdina.

Mino Mobejdina  
на основание чл. 2 от ЗЗЛД  
*[Redacted signature box]*

About SATS : SATS "Scandinavian Association for Testing of Electric Power Equipment" is a member of Short circuit Liaison (STL) and a member of EOTC, European Electric Sector Committee ELSECOM, Agreement Group No. 0007

We hereby certify that the objects specified above have successfully passed the test herein reported, thereby verifying guaranteed data.

*[Signature]*  
Ludvika 2004-06-11  
ABB Power Technologies AB  
High Voltage Products/Surge Arresters  
Quality Department

на основание чл. 2 от ЗЗЛД  
*[Redacted signature box]*

Kurt Jansson



*[Signature]*  
ABB Power Technologies AB  
000278

*[Signature]*  
J1 1111  
1-1  
ОРИГИНАЛ  
"КРАСИН"  
СМОЛЯН  
БООД

content may not be copied, in permission of ABB

altered or passed on to any unit, (c) ABB 2004



### Type tests on PEXLIM P Surge Arresters

Test objects: Surge arresters of type PEXLIM P120-XH145 with rated voltage 120 kV.

Standards: IEC 60099-4, Amendment 2 (Annex O) of October 2001 (Same requirements as per earlier IEC document 37/231/CDV)

Tests performed: Pressure relief tests

| <u>Current</u> | <u>Report</u> |
|----------------|---------------|
| 65 kA          | KEMA 566-01 * |
| 25 kA          | KEMA 566-01   |
| 12 kA          | KEMA 566-01   |
| 600 A          | KEMA 566-01   |

\*) First current peak  $\geq$  2.5 times 65 kA

Validation: The test objects represent the longest electrical and mechanical sections used for PEXLIM P-X surge arresters. The tests therefore verify the performance of all arresters of type PEXLIM P-X.

Tests completed: 2001-11-22

Tests performed at: KEMA Arnhem - High Power Laboratory


Report consists of: 46 pages (KEMA 566-01, 45 pages)

We hereby certify that the objects specified above have successfully passed the test herein reported, thereby verifying guaranteed data.

Ludvika 2002-01-08

ABB Power Technology Products AB  
High Voltage Products/Surge Arresters  
Quality Department

на основание чл. 2 от ЗЗЛД





Kurt Jansson



ABB Power Technology Products AB

000279



# SATS Certification

Scandinavian Association for Testing of Electric Power Equipment  
c/o-SINTEF Energy Research, Sem Saelandsv. 11, NO-7465 Trondheim, Norway  
Telephone: +47 73 59 72 00 Telefax: +47 73 59 72 50 E-mail: SATS@energy.sintef.no

---

Report of Performance No.:02-801

Title: Salt fog test 1000 hours on one surge arrester  
type PEXLIM P120-XH145

( )

( )

Trondheim 2002-01-21

---

Р на основание чл. 2 от ЗЗЛД

SATS Certification: Rolf Hegerberg

Copyright: SATS

RoP 02-801

000280

ВЯРНОС  
ОРИГИНАЛ



**ABB Power Technology Products**

Författare - Author

на основание чл. 2 от 33ЛД

Lennart Stenström

Gunnar Persson

на основание чл. 2 от 33ЛД

Uppdragsgivare - Requested by

Titel - Title

Moisture ingress test on surge arresters PEXLIM P120-XH145

**Rapport Report**

Från - From

PTHVP/AKB

Datum - Date

2001-12-20

Reg.

Sida - Page

1(3)

R HVP/AK 01-06 rev1

Utredning teoretisk undersökning - Analysis, theoretical investigation

Provnig, experim. under- No. sökning - Test experimental investigation

Delrapport Partial report

Slutrapport Final report

Provnig/undersökning avslutad Test/investigation finished 01-11-19

Ordernr - Ref. No.

Debiteras ordernr - Debit Order

Pk/Ak

Antal textsidor - No. of text pages

3

Antal bilagesidor - No. of supplem. pages

4

Sammanfattning - Summary

**TEST METHOD**

Moisture ingress test in accordance with IEC 60099-4, Amendment 2 of 2001-10, Clause 9.7.9 (Same requirements as per earlier IEC Committee Draft for Vote 37/231/CDV, Clause 9.7.8)

**TEST OBJECT**

Surge arresters PEXLIM P120-XH145 according to dimension drawing 1HSA303 000-CA (enclosed)

**TEST PROCEDURE**

Initial measurements of power losses, residual voltage and partial discharge level according to Clause 9.7.9.1 as well as check of reference voltage.

Preconditioning according to Clause 9.7.9.2

Water immersion according to Clause 9.7.9.3

Verification tests including visual inspection, measurements of power losses, residual voltage and partial discharges according to Clause 9.7.9.4 as well as check of reference voltage.

**TEST RESULT**

The surge arresters passed the test successfully.

Ludvika 2001-12-20

ABB Power Technology Products AB  
High Voltage Products/Surge Arresters  
Quality Department

на основание чл. 2 от 33ЛД


[Redacted signature box]

Kurt Jansson



This document must not be copied without our written permission, and the contents thereof must not be imparted to a third party nor be used for any unauthorized purpose. Contravention will be prosecuted

000281



**ABB Power Technology Products AB**

Författare - Author

Roger Siljeholm

Godkännare - Approved by

Lennart Stenstrom

Uppdragsgivare - Requested by

Gunnar Persson

Titel - Title

Test of low temperature performance at

-50°C for surge arresters on type

PEXLIM P120-XH145.

на основании чл. 2 от 33ЛД

**Rapport**

**Report**

Från - From

HVP/AK

Datum - Date

2002-01-07

Reg.

Sida - Page

1

R HVP/AK 02-01

Utredning teoretisk undersökning - Analysis, theoretical investigation

Provnings, experim. undersökning - Test experimental investigation

Delrapport Partial report

Slutrapport Final report

Provnings/undersökning avslutad

Test/investigation finished

Ordernr - Ref. No.

Debiteras ordernr - Debit Order No.

Pkd/Ak

Antal textsidor - No. of text pages

1

Antal bilagesidor - No. of supplm. pages

4

**PURPOSE**

The purpose was to verify the low temperature performance of the arrester type PEXLIM P-X.

**TEST OBJECT**

One arrester of type PEXLIM P120-XH145 with rated voltage 120 kV, serial number P-X30. The arresters comprise the longest mechanical sections used for the arrester type PEXLIM P-X.

**TEST PERFORMED**

The modules were placed in a bending fixture and loaded with a bending moment of 2500 Nm while the ambient temperature was cycled from +20° C to -50° C. (See enclosed test report SPL 01-239)

**RESULT**

The test objects withstood the test without any damage. (See report SPL 01-239.)

Before and after the mechanical test the modules were electrically routine tested, result as per Table 1. No significant changes in the electrical characteristics were observed.

| Arrester | Reference Voltage (Uref) at 3 mA resistive current |               | Partial discharge level at 0.9*Uref |               | Power losses at 0.8*Uref |              |
|----------|--|---------------|-------------------------------------|---------------|--------------------------|--------------|
|          | Before test kV                                     | After test kV | Before test pC                      | After test pC | Before test W            | After test W |
| P-X30    | 128.9  | 128.4         | <5                                  | <5            | 4.3                      | 4.1          |

Table 1. Electrical routine tests.

Ludvika 2002-01-07

ABB Power Technology Products AB  
High Voltage Products/Surge Arresters  
Quality Department

на основании чл. 2 от 33ЛД

Kurt Jansson



000282




ABB Power Technology на основание чл. 2 от 33ЛД

Författare - Author  
Roger Siljeholm  
Godkännare - Approved by  
Lennart Stenstrom  
Uppdragsgivare - Requested  
Gunnar Persson

Titel - Title  
Bending strength test on surge arrester type  
PEXLIM P120-XH145

### Rapport Report

Från - From  
HVP/AK

Datum - Date  
2001-12-10

R HVP/AK 01-09

Reg. Sida - Page  
1

Utredning teoretisk  
undersökning - Analysis,  
theoretical investigation

Provning, experim. under-  
sökning - Test experi-  
mental investigation

Delrapport  
Partial report

Slutrapport  
Final report

Provning/undersökning avslutad  
Test/investigation finished

Ordernr - Ref. No.

Debiteras ordernr - Debit Order No.

Pkt/Akt

Antal textsidor - No. of text pages  
1

Antal bilagesidor - No. of supplm. pages  
5

### PURPOSE

The purpose was to verify a bending strength of 4000 Nm of the arrester type PEXLIM P-X.

### TEST OBJECT

Two arresters of type PEXLIM P120-XH145 with rated voltage 120 kV, serial numbers P-X28 and P-X29 were tested. The arresters comprise the longest mechanical sections used for the arrester type PEXLIM P-X.

### TEST PERFORMED

The arresters were loaded until failure with rate of 2500 Nm/min. The deflection was measured during the test. See report SPL 01-220.

### RESULT

The two arresters failed at 6020 Nm and 5870 Nm respectively. See report SPL 01-220.

Ludvika 2001-12-10

ABB Power Technology Products AB  
High Voltage Products/Surge Arresters  
Quality Department

на основание чл. 2 от 33ЛД

Kurt Jansson



000283

ВЯРНО С  
ОРИГИНАЛА



ABB Power Technology AB на основание чл. 2 от ЗЗЛД

Rapport Report

R HVP/AK 01-07

Författare - Author  
Roger Siljeholm  
Godkännare - Approved by  
Lennart Stenstrom  
Uppdragsgivare - Requester  
Gunnar Persson

Från - From  
HVP/AK  
Datum - Date  
2001-12-10

Reg. Sida - Page  
1

Utredning teoretisk undersökning - Analysis, theoretical investigation

Ordernr - Ref. No.

Provnig, experim. undersökning - Test experimental investigation

Debiteras ordernr - Debit Order No.

Delrapport Partial report

Pkt/Akt

Slutrapport Final report

Antal textsidor - No. of text pages

1

Provnig/undersökning avslutad Test investigation finished

Antal bilagesidor - No. of supplm. pages

4

Titel - Title  
Bending fatigue test on surge arrester type  
PEXLIM P120-XH145

PURPOSE

The purpose was to verify the bending fatigue strength of the arrester type PEXLIM P-X.

TEST OBJECT

Two arresters of type PEXLIM P120-XH145 with rated voltage 120 kV, serial numbers P-X22 and P-X24 were tested. The arresters comprise the longest mechanical sections used for the arrester type PEXLIM P-X.

TEST PERFORMED

The modules were subjected to a cyclic bending test consisting of 1000 cycles at a bending moment level of 2500 Nm at the frequency 0.3 Hz. See report SPL 01-218.

RESULT

The test objects withstood the test without any damage. See report SPL 01-218.

Before and after the mechanical test the modules were electrically routine tested, result as per Table 1. No significant changes in the electrical characteristics were observed.

| Arrester | Reference Voltage (Uref) at 3 mA resistive current |               | Partial discharge level at 0.9*Uref |               | Power losses at 0.8*Uref |              |
|----------|--|---------------|-------------------------------------|---------------|--------------------------|--------------|
|          | Before test kV                                     | After test kV | Before test pC                      | After test pC | Before test W            | After test W |
| P-X22    | 129.5  | 129.2         | <5                                  | <5            | 4.2                      | 4.0          |
| P-X24    | 128.9  | 128.8         | <5                                  | <5            | 4.4                      | 4.2          |

Table 1. Electrical routine tests.

Ludvika 2001-12-10

ABB Power Technology Products AB  
High Voltage Products/Surge Arresters  
Quality Department

на основание чл. 2 от  
ЗЗЛД




Kurt Jansson

Handwritten signature

000284

ВЯРНО С  
ОРУДИНАТА




LAK 5882 Rev 1

PTHVP/AKB 02-01-18

Rev. date 2003-04-09

**PROTECTIVE CHARACTERISTICS FOR ARRESTERS  
TYPE EXLIM & PEXLIM P  
(external inductive effects neglected)**

Max residual voltage in per cent of residual voltage at 10kA 8/20 impulse




000285

ОРГАНИЗАЦИЯ



TOV capability for arresters type PEXLIM P-X  
Expressed in multiples of the rated voltage  $U_r$ , ( $T_r$ )



000286

ВЯРНО С  
ОРИГИНАЛА



за участие в открита процедура за възлагане на обществена поръчка с предмет:

„Подмяна на маслонапълнена кабелна електропроводна линия 110 kV „Зенит“ от линеен ножов разединител 110 kV на ПС „Хаджи Димитър“ до линеен ножов разединител 110 kV в ПС „Подуяне“, реф. № РРС 17 – 169



## Техническо предложение




### Техническа документация

Приложение № 1 към Предложение за изпълнение на поръчката по т.15.1. от Техническото предложение – Заверени копия на документи за Ограничител на пренапрежение (вентилен отвод) за нова КЕЛ 110 kV:

- Приложение № 1.2. към т.15.1.2. от Техническото предложение – Заверено копие на Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания

000287



Brochure

# High Power Laboratory, Ludvika, Sweden

## Testing and third party certification of power transmission and distribution equipment

Power and productivity  
for a better world™



000288

БЯРНО С  
ОРУЖИЈАТА



2010-11-18 08.52

# Integrity and Independence

– well established and documented

Various kinds of high voltage electrical equipment such as circuit breakers, disconnectors, earthing switches, power transformers, instrument transformers, surge arresters, switchgear cubicles etc; are tested at the High Power Laboratory in accordance with the international or regional standards.

### Accreditation

The High Power Laboratory, Ludvika is accredited by SWEDAC (Swedish Government Body) in accordance with ISO/IEC 17025. The quality system, competence of personnel, adequacy of test equipment and calibration of measuring equipment are checked and assessed periodically by SWEDAC for their compliance to ISO/IEC 17025. This assures that the tests are performed correctly and impartially.

### Affiliation and International cooperation

The laboratory is affiliated to SATS, an independent certification body based in Scandinavia and accredited according to EN 45011. SATS Certification issues Reports of Performance/ Type Test Certificates for tests performed at the High Power Laboratory, Ludvika, under the supervision of its inspectors.


SATS is a member of STL (Short-circuit Testing Liaison), an international organization of similar testing and certification bodies. STL has framed the guidelines for uniform application of the standards with regard to the test methods, measurement, evaluation and issue of type test reports/certificates.

Strengthened by its long experience and reputation, the High Power Laboratory, Ludvika lives up to the trustworthiness and professionalism demanded of it by the clients.



**SATS**  
Certification



1297  
ISO/IEC 17025



Affiliated to SATS Certification, an independent certification body accredited acc. to EN 45011 and a member of the STLA (Short-circuit Testing Liaison Agreement). Accredited by SWEDAC



2 High Power Laboratory, Ludvika, Sweden

High Power.indd 2

000289


ВЯРНІС  
ОРИГИНАЛ



20.04.18 09.52

Latest technology combined with long experience

Short-circuit testing was started in Ludvika 75 years ago in 1933 with the installation of the first short-circuit generator, at that time the largest in the world. The testing technology since then has been developed continuously contributing to the long collective experience in the field. The present test station was established 50 years ago. The test and measuring equipment has been upgraded and modernized since then to meet the demands imposed by the ever increasing capacity of products to be tested and their stringent standards.



#### High expectations and preparedness

The Laboratory is well geared to meet the requirements of the clients for the development tests which require advanced test and measuring equipment, experienced test engineers with adequate knowledge of the products to be tested in order to support the development process.

The type tests for certification needs the complete range test circuits and measuring equipment fulfilling the requirements of the standards. The Laboratory is equipped and accredited for a wide range of such certification tests.

#### At the forefront

A fully automated modern synthetic test facility was established in 1996 replacing the first generation of synthetic test circuit from the sixties. This combined with the two s.c. generators permit testing of high voltage circuit-breakers of voltage ratings up to 800 kV.

Measurement, data collection and analysis system is of the most advanced technology available. With highly reliable and accurate optically isolated measurements, automated calculation and presentation of test data, the Laboratory has been in the forefront of development activities in this area.

The Laboratory has also established test facilities for the operational tests of HVDC and SVC valves, a unique resource, using both direct and synthetic test methods.

High Power Laboratory, Ludvika, Sweden 3

## Adequate resources – a basic requirement

The large base of installed equipment is a necessity for performing the requested tests on various products. The laboratory's resources have been augmented over the years in order to meet with the changing requirements.

The laboratory is equipped with two short-circuit generators which together can deliver 4,000 MVA of short-circuit power for direct testing. Together with the synthetic test circuit a short-circuit power of over 75,000 MVA can be realized in the laboratory.

There are nine test cells of different dimensions for testing of various kinds of products. Apart from the high speed measuring system there exist facilities to record the test with high speed digital video camera which can be synchronized with the test oscillogram during playback to give a better understanding of the happenings during test.


In the High Current Laboratory, which is an integral part of the High Power Laboratory, tests are performed with continuous high currents to check the temperature rise limits of the power equipment under normal operation conditions.

In the Mechanical Test Laboratory, also a part of the High Power Laboratory, tests are performed on switching equipment such as circuit breakers in order to verify their mechanical endurance. Tests are also performed here to verify the mechanical withstand properties of the components and the fully assembled products.


## Site overview

The High Power Laboratory is situated on the banks of Lake Väsman as a part of the ABB industrial complex in Ludvika. ABB in Ludvika has been a leading center for development and manufacturing of various high voltage transmission equipment for more than 100 years. The laboratory is spread over an area of 15 000 sq. m which includes the high power, high current and mechanical testing with over 20 test bays and a large workshop.

The high voltage laboratory STRI, located next door, completes the type test facilities available in the location.




4 High Power Laboratory, Ludvika, Sweden






# Synthetic test circuit



*Handwritten signature*



000292

ВЪРХНО СЪОБЩЕНИЕ  
ОРИГИНАЛА



# Test facilities


| Direct testing               |                |
|------------------------------|----------------|
| Max. short-circuit power     | 4 000 MVA      |
| Max. test voltage – 3 $\phi$ | 145 kV         |
| Max. test voltage – 1 $\phi$ | 250 kV         |
| Frequency                    | 16 2/3 – 60 Hz |
| Max. test current            | 100 kA rms     |

| Other test facilities                              |  |
|--|--|
| Temperature-rise test                              | Up to 25 kA rms  |
| HVDC thyristor valves (direct and synthetic tests) |  |
| Power frequency voltage test                       | 600 kV rms   |
| Mechanical tests                                   | <ul style="list-style-type: none"> <li>– endurance</li> <li>– snap-back</li> <li>– cantilever</li> <li>– tightness</li> <li>– environmental</li> </ul> |


| Synthetic testing  |                   |
|--|-------------------|
| Single-phase test  | 550 kV, 80 kA     |
| Three-phase test   | 245 kV, 63 kA     |
| Main capacitor banks   | 6.7 MJ            |
| Two circuits   | $\pm$ 880 kV d.c. |
| 4-parameter TRV and a.c. recovery voltage                      |                   |
| Short-circuit making tests with time delay less than 5 $\mu$ s |                   |
| Capacitive current switching tests                             |                   |

| Measurement and control   |  |
|---|--|
| Fast digital transient recorders with optic-fibre isolated digitizers located in test cells |  |
| High speed digital video recording system   |  |
| Automated data processing system, in accordance with IEC and STL guidelines                 |  |
| Fully-automated control systems for short-circuit generators and synthetic test circuits    |  |
| High current measurements traceable to the STL reference shunt                              |  |

## New generation measurement system





Optic fiber isolation and high speed recording (100 MSA/s) in all channels



Automatic measurements for quicker evaluation

6 High Power Laboratory, Ludvika, Sweden





## Feasible tests

Equipment

*[Signature]*

| Test                            | MV circuit breakers | HV circuit breakers | Metal enclosed switchgear | Power transformers | Surge arresters | Disconnectors & earthing switch | Current transformer | High voltage switches | Switch-fuse units | Voltage transformers | On-load tap changers | Insulators sets | Reactor & line-traps |
|---------------------------------|---------------------|---------------------|---------------------------|--------------------|-----------------|---------------------------------|---------------------|-----------------------|-------------------|----------------------|----------------------|-----------------|----------------------|
| Short time withstand current    | •                   | •                   | •                         | •                  |                 | •                               | •                   | •                     | •                 | •                    |                      |                 | •                    |
| Short-circuit making capacity   | •                   | •                   |                           |                    |                 |                                 |                     | •                     |                   |                      |                      |                 |                      |
| Short-circuit breaking capacity | •                   | •                   |                           |                    |                 |                                 |                     |                       | •                 |                      |                      |                 |                      |
| Short-line fault                |                     |                     | •                         |                    |                 |                                 |                     |                       |                   |                      |                      |                 |                      |
| Out-of-phase                    | •                   | •                   |                           |                    |                 |                                 |                     |                       |                   |                      |                      |                 |                      |
| Line-charging switching         | •                   | •                   |                           |                    |                 |                                 |                     |                       |                   |                      |                      |                 |                      |
| Cable-charging switching        | •                   | •                   |                           |                    |                 |                                 |                     |                       |                   |                      |                      |                 |                      |
| Capacitor bank switching        | •                   | •                   |                           |                    |                 |                                 |                     |                       |                   |                      |                      |                 |                      |
| Shunt reactor switching         |                     | •                   |                           |                    |                 |                                 |                     |                       |                   |                      |                      |                 |                      |
| Temperature-rise tests          | •                   | •                   | •                         |                    |                 | •                               | •                   | •                     | •                 | •                    | •                    |                 |                      |
| Internal-arc tests              |                     |                     | •                         |                    |                 |                                 |                     |                       | •                 |                      |                      |                 |                      |
| Bus-transfer current switching  |                     |                     |                           |                    |                 | •                               |                     |                       |                   |                      |                      |                 |                      |
| Induced current switching       |                     |                     |                           |                    |                 | •                               |                     |                       |                   |                      |                      |                 |                      |
| Pressure-relief                 |                     |                     |                           |                    | •               |                                 |                     |                       |                   |                      |                      |                 |                      |
| Transient performance           |                     |                     |                           |                    |                 |                                 | •                   |                       |                   | •                    |                      |                 |                      |
| Ferro-resonance                 |                     |                     |                           |                    |                 |                                 |                     |                       |                   | •                    |                      |                 |                      |
| Breaking capacity               |                     |                     |                           |                    |                 |                                 |                     |                       |                   |                      | •                    |                 |                      |
| Service duty tests              |                     |                     |                           |                    |                 |                                 |                     |                       |                   |                      | •                    |                 |                      |
| Power arc tests                 |                     |                     |                           |                    |                 |                                 |                     |                       |                   |                      |                      | •               |                      |
| Mechanical endurance            | •                   | •                   |                           |                    |                 | •                               |                     | •                     | •                 |                      |                      |                 |                      |

*[Signature]*

High Power Laboratory, Uppsala, Sweden 7



# Contact us

ABB AB  
 High Power Laboratory  
 SE-771 80 LUDVIKA, SWEDEN  
 Tel: +46 (0)240 78 26 06  
 Fax: +46 (0)240 78 26 19  
 E-mail: [highpowerlab@se.abb.com](mailto:highpowerlab@se.abb.com)  
[www.abb.com/highvoltage](http://www.abb.com/highvoltage)


NOTE! ABB AB is working continuously to improve the products.  
 We therefore reserve the right to change designs, dimensions and  
 data without prior notice.

©Copyright 2010 ABB. All right reserved. Publication 1-HSM 95-43 52-01en, High Power Laboratory, Edition 2, 2010-11. Design: byBrock. Print: www.hanningsons.se

High Power, Inc. 8

000295


Power and productivity  
for a better world™



2010-11-18 08.53

SWEDAC 

Styrelsen för ackreditering och teknisk kontroll  
Swedish Board for Accreditation and Conformity Assessment



ACCREDITATION CERTIFICATE

**STRI Högspänningslaboratorium**

har genom beslut den  
*following the decision on*

**30 september 1998**


ackrediterats som  
*is accredited as*

provningslaboratorium  
*testing laboratory*

och därvid erhållit registreringsnummer  
*and has been assigned registration number*

**1534**

Styrelsen  
*Swedish Board* на основание чл. 2 от ЗЗД *ent*




Lars Eklarf  
Generaldirektör  
*Director general*

Akrediterat organ har rätt att använda nedanstående märke.  
*An accredited body is entitled to use the following logotype.*



Akrediteringens omfattning och villkor framgår av akrediteringsbeslutet.  
*The scope and conditions of accreditation are specified in the accreditation decision.*

000296



EV/DI/532067843/ALTERATION OF ARTICLES OF ASSOCIATION  
(unofficial translation)

On this third day of May two thousand and four, appeared before me,  
Cornelis Everardus Martinus van Steenderen, civil law notary, resident at Rijswijk,  
South Holland:

Diana Schreur, secretary, for the purposes hereof residing at 2281 AJ Rijswijk, South-  
Holland, Haagweg 175, born at 's-Gravenhage on November eighteenth nineteen  
hundred and seventy-two,


acting herein in his capacity of attorney in fact authorised to represent:

1. Daniel Georges Marcel Pierre, living at 77470 Trilport (France), 3 Chemin de  
Peuplin, born in Trilport (France) on the eleventh day of April nineteen  
hundred and forty-eight and married;
2. Thomas Georg Facklam, living at 63450 Hanau (Germany), Lallienstrasse 34,  
born in Steinhein (Germany) on the twenty-second day of January nineteen  
hundred and fifty-three and married;
3. Jozef Gerardus Victor Marie Leferink, living at 5103 GK Dongen (The  
Netherlands), Vossendonk 11, born in Roermond (The Netherlands) on the  
twenty-sixth day of April nineteen hundred and forty-four and married,

acting, when granting the power of the attorney, in their capacity of chairman,  
vice-chairman and member respectively of the **EUROPEAN CO-OPERATION  
FOR ACCREDITATION(EA)**, registered offices at Utrecht (The Netherlands),  
place of business 3511 CJ Utrecht (The Netherlands), Radboudkade 223, registered  
with the commercial register under number 30166411.

- 3/. The powers of attorney have been granted in writing; the documents in question will  
be appended to this deed.

The appearer declared that the General Assembly of the EUROPEAN  
CO-OPERATION FOR ACCREDITATION (EA) have resolved to amend the  
Articles of Association in a meeting held in London on the twenty-sixth and twenty-  
seventh day of November two thousand and three, and that she, acting in her



- 2 -

aforementioned capacity, in pursuance of this resolution, now proceeds to its execution.

./ The appearer, acting as aforementioned, declared to amend the Articles of Association of said company as follows:

1. Paragraph 3 of article 10 is renumbered into 3a;
2. After paragraph 3a a new paragraph numbered 3b is inserted which reads:  
In case of election of persons, the person may be elected by a majority of one half of the votes cast at a meeting at which at least three quarters of the members of the General Assembly is represented.

Furthermore the statement was made that the articles of association after implementation of the alteration shall read:

**ARTICLES.**

NAME, REGISTERED OFFICE AND DURATION

Article 1

1. The name of the association is **EUROPEAN CO-OPERATION FOR ACCREDITATION (EA).**

Its registered office is in the municipality of Utrecht, The Netherlands. The Association is governed by the Law of the Netherlands.

2. The association has been established for an indefinite period of time.

OBJECTIVES

Article 2

The objectives of the association are:

- to define, harmonise and build consistency in accreditation of e.g calibration, certification, inspection and testing as a service to European trade and industry according to its needs and in line with economic conditions with the aim to further reduce barriers to trade;
- to build up and maintain a multilateral agreement on mutual recognition between the Accreditation Schemes operated by Full Members of EA and to promote the international acceptance of this agreement;
- to promote the establishment of agreements on mutual recognition between accreditation schemes on the international level;
- to promote confidence in the European infrastructure, competence and services in calibration, certification, inspection, testing and other activities covered by EA;

- to be a resource on technical matters related to the implementation and operation of the European policies in the field of conformity assessment.

CAPITAL

Article 3


The association's capital shall be made up of:

- a. contributions from members
- b. monies otherwise obtained by the association.

MEMBERS OF THE ASSOCIATION

Article 4

1. The membership shall have two types of members:
  - a. FULL MEMBERS are nationally recognised accreditation bodies in a country (economy) being:
    - a member state of the European Economic Area, or
    - a member state of EFTA, or
    - a country which has been formally identified by the EU or EFTA as a candidate country for membership in EU or EFTA, and can provide evidence that they are operational and comply with the requirements set out in relevant European Standards and EA application documents.
  - b. ASSOCIATE MEMBERS are nationally recognised accreditation bodies in a European country (economy) not being:
    - a member state of the European Economic Area, or
    - a member state of EFTA, or
    - a country which has been formally identified by the EU or EFTA as a candidate country for membership in EU or EFTA, and can provide evidence that they are operational and comply with the requirements set out in relevant European Standards and EA application documents.
2. Application for membership should be submitted to the Secretariat. The General Assembly decides whether to accept an applicant or not as a member.
3. Members subscribe for a period of twelve months -- the member contribution period -- commencing on the first of January the year following the acceptance by EA.





- 4 -

4. A member shall be obliged to pay annually a contribution. The level of contribution shall be established by the General Assembly not later than first December the year before the membership due has to be paid for.
5. A member shall be entitled to terminate membership of the association at the end of the member contribution period, with due observance of a period of notice of at least two months, by sending written notification to this effect to the Secretariat, on the condition that the member has met all his financial obligations in relation to the association or shall have met them by the end of the member contribution period concerned.
6. The General Assembly may terminate the membership of a member if the latter no longer complies with the requirements under the Articles or the Rules of Procedure as indicated under Article 20, or if the member acts in conflict with the Articles, the rules of procedure, lawfully adopted resolutions or the interests of association.
7. The General Assembly shall notify the member concerned in writing of such a resolution, stating reasons and the date on which membership will be terminated.
8. More detailed rules concerning membership are contained in a separate document.

THE GENERAL ASSEMBLY

Article 5


The General Assembly is the highest decision-making body of the association.

Article 6

The General Assembly shall give instructions in respect of the policy and shall supervise the management and the general course of affairs in the association.

Article 7

1. Each full and associate member of the association appoints a delegation of maximum two persons to represent it in the General Assembly. If there are more than one member from the same country (economy) these members must agree on a delegation of maximum 2 persons to represent them in the General Assembly.
2. Each delegation in the General Assembly, representing full members is entitled to one vote.



3. Associate members may contribute to the meetings but have no voting rights.
4. The Chairman, Vice Chairman, committee chairmen and further members of the Executive Committee shall be elected from the full members.

REPRESENTATION

Article 8

The Executive Committee, or alternatively the Chairman together with two other members of the Executive Committee, shall be entitled to represent the association at law and otherwise.

Article 9

The Executive Committee shall have the power to authorise the Chairman to represent the association at law and otherwise.

MEETINGS

Article 10

1. The General Assembly shall meet at least once per year and further as often and as many times as the chairman or one tenth of the members shall deem desirable.
2. The Secretary shall convene the meetings, giving written notification, which shall be understood to include a facsimile or e-mail.
- 3a. Unless otherwise stated in these Articles, valid resolutions may be adopted by a majority of two thirds of the votes cast at a meeting at which at least three quarters of the members of the General Assembly is represented.
- 3b. In case of election of persons, the person may be elected by a majority of one half of the votes cast at a meeting at which at least three quarters of the members of the General Assembly is represented.
4. More detailed rules concerning the General Assembly and the Executive Committee shall be contained in a set of Rules of Procedures.


Article 11

Resolutions may be adopted by the Committees otherwise than at a meeting. Votes may only be cast by ballot, which shall be understood to include facsimile and e-mail.

THE EXECUTIVE COMMITTEE

Article 12

In furtherance of the objectives of the association, its policy and management shall be implemented by the Executive Committee between the meetings of the General



- 6 -

Assembly.

Article 13

Members of the Executive Committee shall be elected and dismissed by the General Assembly in accordance with Rules of Procedure adopted by the General Assembly, and shall represent the EA full membership in a well balanced manner.

Article 14

The Chairman shall chair the Executive Committee, in his absence the Executive Committee shall be chaired by the Vice Chairman.

Article 15

Following endorsement by the General Assembly, the Executive Committee shall have the authority to enter into agreements to purchase, dispose of or encumber registered property, or to enter into agreements by which the association commits itself as guarantor or joint and several debtor, warrants performance by a third party or undertakes to provide security for a debt of a third party.

ADVISORY BOARD

Article 16

Feedback from all parties concerned in accreditation shall be brought to the association and its members by an independent EA Advisory Board to ensure that the work of the association meets the needs of the market place.

Article 17

The responsibilities, terms of reference and composition of the EA Advisory Board are defined in separate documents.

SECRETARY

Article 18

The General Assembly shall have the power, upon proposal of the Executive Committee, to appoint and to dismiss the Secretary.


Article 19

The responsibilities, tasks and duties of the secretary are defined in a separate document.

RULES OF PROCEDURES

Article 20

The Executive Committee draw up one or more sets of rules and regulations for the implementation of the provisions of the Articles and with regard to matters not dealt



with therein, in particular concerning appeals and complaints. These rules and regulations shall be approved by the General Assembly. The rules and regulations may not be in conflict with the legal provisions and the Articles.

FINANCIAL YEAR, ACCOUNTS & DISCHARGE AND BUDGET

Article 21

1. The financial year of the association shall run from 1 January to 31 December.
2. The Executive Committee shall render to the General Assembly an account of affairs during the preceding financial year no later than in the month of November.
3. An independent registered accountant, proposed by the Executive Committee, and accepted by the General Assembly, shall for its purpose draw up a financial report containing all income and expenditure in the financial year concerned. This financial report shall be submitted to the General Assembly for approval.
4. Approval of the financial report by the General Assembly shall discharge the Executive Committee from liability in respect of their conduct of affairs, during the financial year concerned.
5. The Executive Committee proposes the budget for the next financial year for approval by the General Assembly.
6. The General Assembly may appoint one person from among its members to review the annual financial statements with the purpose of verifying that the financial provision has been spent in accordance with the decisions of the General Assembly.

AMENDMENT OF THE ARTICLES


Article 22

The General Assembly shall be entitled to amend the Articles.

WINDING-UP AND LIQUIDATION

Article 23

1. The Executive Committee shall be entitled, upon decision by the General Assembly, to wind up the association.
2. Liquidation shall be carried out by the Executive Committee.
3. The association shall continue to exist after being wound up if and in so far as this is necessary for the settlement of affairs.
4. During the liquidation the provisions of the Articles shall remain in force as far



- 8 -

as possible and necessary.

5. The General Assembly shall determine how any surplus should be allocated, doing so as far as possible in accordance with the objectives of the association.

**CLOSING STATEMENT**

This deed, drawn up in one original copy, was executed in Rijswijk, South-Holland, on the date first before written.

After the substance of this deed had been stated and the content thereof had been explained to the person appearing, that person declared to have taken cognizance of this deed and not to require this deed to be read out in full.

Subsequently, after a reading in part in accordance with the law, this deed was signed by the person appearing, who is known to me, and by me, Notary.

00 141 801.doc


000304

ВЯРНО С  
ОРИГИНАЛА



SWEDAC 

Styrelsen för ackreditering och teknisk kontroll  
Swedish Board for Accreditation and Conformity Assessment



ACKREDITERINGSBEVIS

ACCREDITATION CERTIFICATE

**ABB Switchgear AB**  
**High Power Laboratory**

har genom beslut den  
*following the decision on*

**10 mars 1994**


ackrediterats som  
*is accredited as*

**provningslaboratorium**  
*testing laboratory*

och därvid erhållit registreringsnummer  
*and has been assigned registration number*

**1297**


Styrelsen för ackreditering och teknisk kontroll  
*Swedish Board for Accreditation and Conformity Assessment*



Generaldirektör  
*Director General*




Akrediterat organ har rätt att använda nedanstående märke.  
*An accredited body is entitled to use the following logotype.*



Akrediteringens omfattning och villkor framgår av ackrediteringsbeslutet.  
*The scope and conditions of accreditation are specified in the accreditation decision.*



000305



Industry division  
Ann-Louise Skoglund  
Direktnr: +46 33 177706  
E-post: ann-louise.skoglund@swedac.se

ABB AB  
STRI  
-  
771 32 Ludvika

**Decision on accreditation**  
(2 appendices)

**Decision**

Swedish Board for Accreditation and Conformity Assessment (Swedac) accredits ABB AB (registration number 556029-7029) as testing laboratory for electric testing and calibration. The scope of accreditation is specified in the "Field of accreditation" on the web page.

ABB AB will use the accreditation number 1297.  
The accreditation is valid until further notice.

**Flexible scope of accreditation**

ABB AB shall always keep an updated list of methods used within its accreditation. For the upcoming assessments you shall provide Swedac a list of changes introduced since the latest assessment.

Flexible scope of accreditation implies that the laboratory within its accreditation, without applying to Swedac, may do changes in all ready accredited methods as follows:

- Introduce new properties, variables, analysis or range of measurement within an existing accredited method
- Introduce new methods within a specified area
- Introduce new products/new test types within an existing accredited method
- Introduce new versions of standard methods


The changes introduced by flexible scope accreditation should not imply new measurement principles, new accreditation or technical areas than those already existing in the accreditation decision.


Additional constraints are as follows: Flexibles scope of accreditation is only valid for testing. The calibration laboratory has fixed scope, and is not included in flexible scope of accreditation.

**Applicable provisions**

The provisions used in Swedacs accreditation process and which are applicable to activities are set out in the appendix.

1 (2)





**Reason for decision**

ABB AB has applied for accreditation as testing laboratory. Swedac assesses that the requirements are fulfilled for accreditation for the scope set out in the application and which was reviewed during the assessment.

**Information**

The scope of accreditation is specified in the "Field of accreditation" on the web page. Application for changed scope, except to the flexible accreditation, must be made to Swedac.

Regular surveillance visit will be performed as described in the applicable regulations on accreditation.

Accredited laboratories pay an annual fee in accordance with Swedac's regulations.

The organization carries out accredited activities in their own premises. Activities outside the laboratory's own premises, so-called field activities, are not included in the accreditation.

---


This decision has been made by Division Manager Tomas Holm in consultation with the Technical Officer Per Fällström.

Tomas Holm

Appendices

Applicable provisions  
Accreditation certificates, Testing and Calibration

Please notice that this is a translation, in case of any discrepancies between the English version and the original Swedish version the latter will prevail.



2 (2)  
000307

ВЯНО С  
ОРИГИНАЛА

КРАСИН  
СМОЛЯН  
ООО



**Applicable provisions**

**EU legislation and national legislation**

Regulation (EC) No 765/2008 of the European Parliament and of the Council of 9 July 2008 setting out the requirements for accreditation and market surveillance relating to the marketing of products and repealing Regulation (EEC) No 339/93

Act (SFS 2011:791) concerning Accreditation and Conformity Assessment

Ordinance (2011:811) concerning Accreditation and Conformity Assessment

STAFS 2011:33 Swedac's Regulations and General Guidelines for the Accreditation of Laboratories

STAFS 2015:8 Swedac's Regulations and General Guidelines (STAFS 2015:8) on Accreditation

STAFS 2011:33 includes all requirements in SS-EN ISO/IEC 17025:2005

1 (1)

000308

ВЯНО С  
ОРИГИНАЛ



ACCREDITATION CERTIFICATE



Akred. nr. 1297  
Testing  
ISO/IEC 17025

**ABB AB**  
**STRI**  
Registration number 556029-7029

is accredited as a testing laboratory for the scope specified in appendix 2. The applicable terms of the accreditation are specified in appendix 1.

This laboratory is accredited in accordance with the International Standard ISO/IEC 17025:2005. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system. The accredited laboratory is responsible for the results of performed testing and submitted judgements as well as, where applicable, for the selection and application of work methods within the scope of the granted accreditation.

The accreditation is valid until further notice. The Swedish Board for Accreditation and Conformity Assessment (Swedac) regularly carries out surveillance, and a full reassessment every fourth year, in order to verify that the applicable terms of accreditation, see appendix 1, are continually fulfilled.

This accreditation certificate was issued **2017-12-21** by  
Tomas Holm,  
Manager of the Industry division

Accreditation was granted in accordance with article 5 (1) or Regulation (EC) No 765/2008 regarding accreditation and market surveillance etc. and the Act (SFS 2011:791) concerning Accreditation and Conformity Assessment. Swedac is the national accreditation body responsible for the assessment of the competence of certification bodies, inspection bodies, laboratories and environmental verifier applying for accreditation. This accreditation has been issued under the EA MLA and is therefore recognised as equivalent to other accreditations issued under the EA MLA within the same accreditation scope.

1 (1)  
000309

ВАЖНО С  
ОРИГИНАЛА



**ACCREDITATION CERTIFICATE**



Akkred. nr. 1297  
Calibration  
ISO/IEC 17025

**ABB AB**  
**STRI**  
Registration number 556029-7029

is accredited as a calibration laboratory for the scope specified in appendix 2. The applicable terms of the accreditation are specified in appendix 1.

This laboratory is accredited in accordance with the International Standard ISO/IEC 17025:2005. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system. The accredited laboratory is responsible for the results of performed calibration and submitted judgements as well as, where applicable, for the selection and application of work methods within the scope of the granted accreditation.

The accreditation is valid until further notice. The Swedish Board for Accreditation and Conformity Assessment (Swedac) regularly carries out surveillance, and a full reassessment every fourth year, in order to verify that the applicable terms of accreditation, see appendix 1, are continually fulfilled.

This accreditation certificate was issued **2017-12-21** by  
Tomas Holm,  
Manager of the Industry division

Accreditation was granted in accordance with article 5 (1) or Regulation (EC) No 765/2008 regarding accreditation and market surveillance etc. and the Act (SFS 2011:791) concerning Accreditation and Conformity Assessment. Swedac is the national accreditation body responsible for the assessment of the competence of certification bodies, inspection bodies, laboratories and environmental verifier applying for accreditation. This accreditation has been issued under the EA MLA and is therefore recognised as equivalent to other accreditations issued under the EA MLA within the same accreditation scope.

1 (1)  
**000310**

ВЯНО С  
ОРИГИНАЛ



за участие в открита процедура за възлагане на обществена поръчка с предмет:

„Подмяна на маслонапълнена кабелна електропроводна линия 110 kV „Зенит“ от линеен ножов разединител 110 kV на ПС „Хаджи Димитър“ до линеен ножов разединител 110 kV в ПС „Подуяне“, реф. № РРС 17 – 169



## Техническо предложение



### Техническа документация

Приложение № 1 към Предложение за изпълнение на поръчката по т.15.1. от Техническото предложение – Заверени копия на документи за Ограничител на пренапрежение (вентилен отвод) за нова КЕЛ 110 kV:

- Приложение № 1.3. към т.15.1.3. от Техническото предложение – Последно издание на части от каталога на производителя

000311

# Zinc Oxide Surge Arrester PEXLIM P-X

Protection of switchgear, transformers and other equipment in high voltage systems against atmospheric and switching overvoltages.

- in areas with very high lightning intensity
- where grounding or shielding conditions are poor or incomplete
- for important installations
- where energy requirements are very high (e.g. very long lines, capacitor protection).

Superior where low weight, reduced clearances, flexible mounting, non-fragility and additional personnel safety is required.


Major component in PEXLINK™ concept for transmission line protection.



Other data can be ordered on request. Please contact your local sales representative.

## Brief performance data

|  |                           |
|--|---------------------------|
| Arrester classification as per IEC 60099-4 Ed 3.0                                      | Station; SH               |
| Arrester classification as per IEEE Std C62.11-2012                                    | Station                   |
| System voltages ( $U_s$ )  | 52 - 420 kV               |
| Rated voltages ( $U_r$ )   | 42 - 360 kV               |
| Nominal discharge current (IEC)  | 20 kA <sub>peak</sub>     |
| Lightning impulse classifying current (ANSI/IEEE)                                      | 10/15 kA <sub>peak</sub>  |
| <b>Charge, energy and current withstand:</b>   |                           |
| Repetitive charge transfer rating, $Q_{rs}$ (IEC)                                      | 3.2 C                     |
| Thermal energy rating, $W_{th}$ (IEC)  | 11 kJ/kV ( $U_r$ )        |
| Single impulse energy capability (2 ms to 4 ms impulse)                                | 7.0 kJ/kV ( $U_r$ )       |
| <b>Discharge current withstand strength:</b>   |                           |
| High current 4/10 $\mu$ s  | 100 kA <sub>peak</sub>    |
| Low current 2000 $\mu$ s, (based on $Q_{rs}$ )   | 1600 A <sub>peak</sub>    |
| Energy class as per IEEE standard (switching surge energy rating)                      | G                         |
| Single-impulse withstand rating as per IEEE standard                                   | 3.2 C                     |
| Repetitive charge transfer test value - sample tests on all manufactured block batches | 4.0 C                     |
| <b>Short-circuit/Pressure relief capability</b>  | 65 kA <sub>rms(sym)</sub> |
| <b>Mechanical strength:</b>  |                           |
| Specified long-term load (SLL)   | 2500 Nm                   |
| Specified short-term load (SSL)  | 4000 Nm                   |
| <b>Service conditions:</b>   |                           |
| Ambient temperature  | -50 °C to +45 °C          |
| Design altitude  | max. 1000 m               |
| Frequency  | 15 - 62 Hz                |
| Line discharge class (as per IEC60099-4, Ed. 2.2)                                      | Class 4                   |



Further data according to the IEEE standard can be supplied on request

# PEXLIM P-X

Guaranteed protective data 24 - 145 kV


| Max. system voltage<br>$U_s$ | Rated voltage<br>$U_r$ | Max. continuous operating voltage <sup>1)</sup> |                          | TOV capability <sup>2)</sup> |                   | Max. residual voltage with current wave |                    |                    |                    |                    |                    |                    |     |
|------------------------------|------------------------|---|--------------------------|------------------------------|-------------------|---|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|-----|
|                              |                        | as per IEC<br>$U_c$                             | as per ANSI/IEEE<br>MCOV | 1 s                          | 10 s              | 30/60 $\mu$ s                           |                    |                    | 8/20 $\mu$ s       |                    |                    |                    |     |
|                              |                        |   |                          |                              |                   | 1 kA                                    | 2 kA               | 3 kA               | 5 kA               | 10 kA              | 20 kA              | 40 kA              |     |
| kV <sub>rms</sub>            | kV <sub>rms</sub>      | kV <sub>rms</sub>                               | kV <sub>rms</sub>        | kV <sub>rms</sub>            | kV <sub>rms</sub> | kV <sub>peak</sub>                      | kV <sub>peak</sub> | kV <sub>peak</sub> | kV <sub>peak</sub> | kV <sub>peak</sub> | kV <sub>peak</sub> | kV <sub>peak</sub> |     |
| 24 <sup>3)</sup>             | 24                     | 19.2  | 19.5                     | 26.5                         | 25.2              | 46.8                                    | 48.5               | 49.7               | 51.9               | 54.6               | 59.8               | 65.6               |     |
| 36 <sup>3)</sup>             | 30                     | 24.0  | 24.4                     | 33.1                         | 31.5              | 58.5                                    | 60.7               | 62.2               | 64.9               | 68.3               | 74.8               | 81.9               |     |
|                              | 33                     | 26.4  | 26.7                     | 36.4                         | 34.6              | 64.4                                    | 66.7               | 68.4               | 71.4               | 75.1               | 82.3               | 90.1               |     |
|                              | 36                     | 28.8  | 29.0                     | 39.7                         | 37.8              | 70.2                                    | 72.8               | 74.6               | 77.9               | 81.9               | 89.7               | 98.3               |     |
|                              | 39                     | 31.2  | 31.5                     | 43.0                         | 40.9              | 76.1                                    | 78.8               | 80.8               | 84.3               | 88.8               | 97.2               | 107                |     |
|                              | 42                     | 34  | 34.0                     | 46.4                         | 44.1              | 81.9                                    | 84.9               | 87.0               | 90.8               | 95.6               | 105                | 115                |     |
| 52                           | 48                     | 38  | 39.0                     | 53.0                         | 50.4              | 93.6                                    | 97.0               | 99.4               | 104                | 110                | 120                | 132                |     |
|                              | 51                     | 41  | 41.3                     | 56.3                         | 53.5              | 99.5                                    | 104                | 106                | 111                | 117                | 128                | 140                |     |
|                              | 54                     | 43  | 43.0                     | 59.6                         | 56.7              | 106                                     | 110                | 112                | 117                | 123                | 135                | 148                |     |
|                              | 60                     | 48  | 48.0                     | 66.3                         | 63.0              | 117                                     | 122                | 125                | 130                | 137                | 150                | 164                |     |
|                              | 72                     | 58  | 58.0                     | 79.5                         | 75.6              | 141                                     | 146                | 150                | 156                | 164                | 180                | 197                |     |
|                              | 72                     | 54  | 43                       | 43.0                         | 59.6              | 56.7                                    | 106                | 110                | 112                | 117                | 123                | 135                | 148 |
|                              |                        | 60  | 48                       | 48.0                         | 66.3              | 63.0                                    | 117                | 122                | 125                | 130                | 137                | 150                | 164 |
| 63                           |                        | 50  | 51.0                     | 69.6                         | 66.1              | 123                                     | 128                | 131                | 137                | 144                | 157                | 172                |     |
| 66                           |                        | 53  | 53.4                     | 72.9                         | 69.3              | 129                                     | 134                | 137                | 143                | 151                | 165                | 181                |     |
| 72                           |                        | 58  | 58.0                     | 79.5                         | 75.6              | 141                                     | 146                | 150                | 156                | 164                | 180                | 197                |     |
| 75                           |                        | 60  | 60.7                     | 82.8                         | 78.7              | 147                                     | 152                | 156                | 163                | 171                | 187                | 205                |     |
| 78                           |                        | 62  | 63.1                     | 86.1                         | 81.9              | 153                                     | 158                | 162                | 169                | 178                | 195                | 213                |     |
| 81                           |                        | 65  | 65.6                     | 89.5                         | 85.0              | 158                                     | 164                | 168                | 176                | 185                | 202                | 222                |     |
| 84                           |                        | 67  | 68.0                     | 92.8                         | 88.2              | 164                                     | 170                | 174                | 182                | 192                | 210                | 230                |     |
| 100                          |                        | 72  | 58                       | 58.0                         | 79.5              | 75.6                                    | 141                | 146                | 150                | 156                | 164                | 180                | 197 |
|                              | 75                     | 60  | 60.7                     | 82.8                         | 78.7              | 147                                     | 152                | 156                | 163                | 171                | 187                | 205                |     |
|                              | 78                     | 62  | 63.1                     | 86.1                         | 81.9              | 153                                     | 158                | 162                | 169                | 178                | 195                | 213                |     |
|                              | 81                     | 65  | 65.6                     | 89.5                         | 85.0              | 158                                     | 164                | 168                | 176                | 185                | 202                | 222                |     |
|                              | 84                     | 67  | 68.0                     | 92.8                         | 88.2              | 164                                     | 170                | 174                | 182                | 192                | 210                | 230                |     |
| 123                          | 90                     | 72  | 72.0                     | 99.4                         | 94.5              | 176                                     | 182                | 187                | 195                | 205                | 225                | 246                |     |
|                              | 96                     | 77  | 77.0                     | 106                          | 100               | 188                                     | 194                | 199                | 208                | 219                | 240                | 263                |     |
|                              | 102                    | 78  | 82.6                     | 112                          | 107               | 199                                     | 207                | 212                | 221                | 233                | 255                | 279                |     |
|                              | 108                    | 78  | 84.0                     | 119                          | 113               | 211                                     | 219                | 224                | 234                | 246                | 270                | 295                |     |
|                              | 114                    | 78  | 92.3                     | 125                          | 119               | 223                                     | 231                | 237                | 247                | 260                | 284                | 312                |     |
|                              | 120                    | 78  | 98.0                     | 132                          | 126               | 234                                     | 243                | 249                | 260                | 273                | 299                | 328                |     |
|                              | 129                    | 78  | 104                      | 142                          | 135               | 252                                     | 261                | 268                | 279                | 294                | 322                | 353                |     |
|                              | 132                    | 78  | 106                      | 145                          | 138               | 258                                     | 267                | 274                | 286                | 301                | 329                | 361                |     |
|                              | 138                    | 78  | 111                      | 152                          | 144               | 270                                     | 279                | 286                | 299                | 314                | 344                | 377                |     |
|                              | 144                    | 78  | 115                      | 159                          | 151               | 281                                     | 291                | 299                | 312                | 328                | 359                | 394                |     |
|                              | 150                    | 78  | 121                      | 165                          | 157               | 293                                     | 304                | 311                | 325                | 342                | 374                | 410                |     |

1) The continuous operating voltages  $U_c$  (as per IEC) and MCOV (as per IEEE) differ only due to deviations in type test procedures.  
 $U_c$  has to be considered only when the actual system voltage is higher than the tabulated.  
 Any arrester with  $U_c$  higher than or equal to the actual system voltage divided by  $\sqrt{3}$  can be selected.

2) With prior duty equal to the thermal energy rating of 11 kJ/kV ( $U_r$ )

3) Arresters for system voltages 36 kV or below can be supplied, on request, when the order also includes arresters for higher system voltages.

Arresters with lower or higher rated voltages may be available on request for special applications.



000313

# PEXLIM P-X

Guaranteed protective data 145 - 420 kV




| Max. system voltage<br>$U_s$ | Rated voltage<br>$U_r$ | Max. continuous operating voltage <sup>1)</sup> |                   | TOV capability <sup>2)</sup> |                   | Max. residual voltage with current wave |                    |                    |                    |                    |                    |                    |
|------------------------------|------------------------|---|-------------------|------------------------------|-------------------|---|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
|                              |                        | as per IEC                                      | as per ANSI/IEEE  | 1 s                          | 10 s              | 30/60 $\mu$ s                           |                    |                    | 8/20 $\mu$ s       |                    |                    |                    |
|                              |                        | $U_c$   | MCOV              |                              |                   | 1 kA                                    | 2 kA               | 3 kA               | 5 kA               | 10 kA              | 20 kA              | 40 kA              |
| kV <sub>rms</sub>            | kV <sub>rms</sub>      | kV <sub>rms</sub>                               | kV <sub>rms</sub> | kV <sub>rms</sub>            | kV <sub>rms</sub> | kV <sub>peak</sub>                      | kV <sub>peak</sub> | kV <sub>peak</sub> | kV <sub>peak</sub> | kV <sub>peak</sub> | kV <sub>peak</sub> | kV <sub>peak</sub> |
| 145                          | 108                    | 86  | 86.0              | 119                          | 113               | 211                                     | 219                | 224                | 234                | 246                | 270                | 295                |
|                              | 120                    | 92  | 98.0              | 132                          | 126               | 234                                     | 243                | 249                | 260                | 273                | 299                | 328                |
|                              | 132                    | 92  | 106               | 145                          | 138               | 258                                     | 267                | 274                | 286                | 301                | 329                | 361                |
|                              | 138                    | 92  | 111               | 152                          | 144               | 270                                     | 279                | 286                | 299                | 314                | 344                | 377                |
|                              | 144                    | 92  | 115               | 159                          | 151               | 281                                     | 291                | 299                | 312                | 328                | 359                | 394                |
|                              | 150                    | 92  | 121               | 165                          | 157               | 293                                     | 304                | 311                | 325                | 342                | 374                | 410                |
|                              | 162                    | 92  | 131               | 179                          | 170               | 316                                     | 328                | 336                | 351                | 369                | 404                | 443                |
|                              | 168                    | 92  | 131               | 185                          | 176               | 328                                     | 340                | 348                | 364                | 383                | 419                | 459                |
| 170                          | 132                    | 106   | 106               | 145                          | 138               | 258                                     | 267                | 274                | 286                | 301                | 329                | 361                |
|                              | 144                    | 108   | 115               | 159                          | 151               | 281                                     | 291                | 299                | 312                | 328                | 359                | 394                |
|                              | 150                    | 108   | 121               | 165                          | 157               | 293                                     | 304                | 311                | 325                | 342                | 374                | 410                |
|                              | 162                    | 108   | 131               | 179                          | 170               | 316                                     | 328                | 336                | 351                | 369                | 404                | 443                |
|                              | 168                    | 108   | 131               | 185                          | 176               | 328                                     | 340                | 348                | 364                | 383                | 419                | 459                |
|                              | 180                    | 108   | 144               | 198                          | 189               | 351                                     | 364                | 373                | 390                | 410                | 449                | 492                |
| 245                          | 192                    | 108   | 152               | 212                          | 201               | 375                                     | 388                | 398                | 415                | 437                | 479                | 525                |
|                              | 180                    | 144   | 144               | 198                          | 189               | 351                                     | 364                | 373                | 390                | 410                | 449                | 492                |
|                              | 192                    | 154   | 154               | 212                          | 201               | 375                                     | 388                | 398                | 415                | 437                | 479                | 525                |
|                              | 198                    | 156   | 160               | 218                          | 207               | 387                                     | 400                | 410                | 428                | 451                | 494                | 541                |
|                              | 210                    | 156   | 170               | 232                          | 220               | 410                                     | 425                | 435                | 454                | 478                | 524                | 574                |
|                              | 214                    | 156   | 173               | 237                          | 225               | 419                                     | 434                | 445                | 464                | 488                | 535                | 586                |
|                              | 216                    | 156   | 175               | 238                          | 226               | 422                                     | 437                | 448                | 467                | 492                | 539                | 590                |
|                              | 219                    | 156   | 177               | 241                          | 229               | 427                                     | 443                | 454                | 474                | 499                | 546                | 598                |
|                              | 222                    | 156   | 179               | 245                          | 233               | 433                                     | 449                | 460                | 480                | 506                | 554                | 607                |
|                              | 228                    | 156   | 180               | 251                          | 239               | 445                                     | 461                | 473                | 493                | 519                | 568                | 623                |
| 300                          | 216                    | 173   | 175               | 238                          | 226               | 422                                     | 437                | 448                | 467                | 492                | 539                | 590                |
|                              | 228                    | 182   | 182               | 251                          | 239               | 445                                     | 461                | 473                | 493                | 519                | 568                | 623                |
|                              | 240                    | 191   | 191               | 265                          | 252               | 468                                     | 485                | 497                | 519                | 546                | 598                | 656                |
|                              | 258                    | 191   | 209               | 285                          | 270               | 504                                     | 522                | 535                | 558                | 587                | 643                | 705                |
|                              | 264                    | 191   | 212               | 291                          | 277               | 515                                     | 534                | 547                | 571                | 601                | 658                | 721                |
|                              | 276                    | 191   | 220               | 304                          | 289               | 539                                     | 558                | 572                | 597                | 628                | 688                | 754                |
|                              | 258                    | 206   | 209               | 285                          | 270               | 504                                     | 522                | 535                | 558                | 587                | 643                | 705                |
| 362                          | 264                    | 211   | 212               | 291                          | 277               | 515                                     | 534                | 547                | 571                | 601                | 658                | 721                |
|                              | 276                    | 221   | 221               | 304                          | 289               | 539                                     | 558                | 572                | 597                | 628                | 688                | 754                |
|                              | 288                    | 230   | 230               | 318                          | 302               | 562                                     | 582                | 597                | 623                | 656                | 718                | 787                |
|                              | 300                    | 230   | 230               | 318                          | 302               | 562                                     | 582                | 597                | 623                | 656                | 718                | 787                |
| 420                          | 330                    | 264   | 267               | 364                          | 346               | 644                                     | 667                | 684                | 714                | 751                | 823                | 901                |
|                              | 336                    | 267   | 272               | 371                          | 352               | 656                                     | 679                | 696                | 727                | 765                | 838                | 918                |
|                              | 342                    | 267   | 277               | 377                          | 359               | 667                                     | 691                | 709                | 740                | 779                | 852                | 934                |
|                              | 360                    | 267   | 291               | 397                          | 378               | 702                                     | 728                | 746                | 779                | 819                | 897                | 983                |

1) The continuous operating voltages  $U_c$  (as per IEC) and MCOV (as per IEEE) differ only due to deviations in type test procedures.  $U_c$  has to be considered only when the actual system voltage is higher than the tabulated. Any arrester with  $U_c$  higher than or equal to the actual system voltage divided by  $\sqrt{3}$  can be selected.

2) With prior duty equal to the thermal energy rating of 11 kJ/kV ( $U_r$ )

Arresters with lower or higher rated voltages may be available on request for special applications.

000314



# PEXLIM P-X

## Technical data for housings


*Handwritten signature*

| Max. system voltage<br>$U_s$ | Rated voltage<br>$U_r$ | Housing | Creepage distance | External insulation <sup>1)</sup> |                               |                               |                                     | Dimensions |                 |         |         |         |      |
|------------------------------|------------------------|---------|-------------------|-----------------------------------|-------------------------------|-------------------------------|-------------------------------------|------------|-----------------|---------|---------|---------|------|
|                              |                        |         |                   | 1.2/50 $\mu$ s dry<br>$kV_{peak}$ | 50 Hz wet (60s)<br>$kV_{rms}$ | 60 Hz wet (10s)<br>$kV_{rms}$ | 250/2500 $\mu$ s wet<br>$kV_{peak}$ | Mass<br>kg | $A_{max}$<br>mm | B<br>mm | C<br>mm | D<br>mm | Fig. |
| 24                           | 24                     | XV024   | 1363              | 283                               | 126                           | 126                           | 235                                 | 19         | 481             | -       | -       | -       | 1    |
| 36                           | 30-36                  | XV036   | 1363              | 283                               | 126                           | 126                           | 235                                 | 19         | 481             | -       | -       | -       | 1    |
|                              | 39                     | XV036   | 2270              | 400                               | 187                           | 187                           | 330                                 | 30         | 736             | -       | -       | -       | 1    |
| 52                           | 42-72                  | XV052   | 2270              | 400                               | 187                           | 187                           | 330                                 | 30         | 736             | -       | -       | -       | 1    |
| 72                           | 54-72                  | XV072   | 2270              | 400                               | 187                           | 187                           | 330                                 | 29         | 736             | -       | -       | -       | 1    |
|                              | 75-84                  | XV072   | 3625              | 578                               | 293                           | 293                           | 462                                 | 44         | 1080            | -       | -       | -       | 1    |
| 100                          | 75-96                  | XV100   | 3625              | 578                               | 293                           | 293                           | 462                                 | 44         | 1080            | -       | -       | -       | 1    |
| 123                          | 90-120                 | XH123   | 3625              | 578                               | 293                           | 293                           | 462                                 | 43         | 1080            | -       | -       | -       | 1    |
|                              | 90-144                 | XV123   | 4540              | 800                               | 374                           | 374                           | 660                                 | 54         | 1397            | -       | -       | -       | 2    |
|                              | 150                    | XV123   | 4988              | 861                               | 419                           | 419                           | 697                                 | 55         | 1486            | -       | -       | -       | 2    |
| 145                          | 108-120                | XH145   | 3625              | 578                               | 293                           | 293                           | 462                                 | 42         | 1080            | -       | -       | -       | 1    |
|                              | 108-144                | XV145   | 4540              | 800                               | 374                           | 374                           | 660                                 | 53         | 1397            | -       | -       | -       | 2    |
|                              | 150                    | XV145   | 4988              | 861                               | 419                           | 419                           | 697                                 | 55         | 1486            | -       | -       | -       | 2    |
|                              | 162-168                | XV145   | 5895              | 978                               | 480                           | 480                           | 792                                 | 66         | 1741            | -       | -       | -       | 2    |
| 170                          | 132-144                | XH170   | 4540              | 800                               | 374                           | 374                           | 660                                 | 53         | 1400            | 400     | -       | 160     | 3    |
|                              | 150                    | XV170   | 4988              | 861                               | 419                           | 419                           | 697                                 | 57         | 1489            | 400     | -       | 160     | 3    |
|                              | 132-192                | XV170   | 5895              | 978                               | 480                           | 480                           | 792                                 | 70         | 1744            | 400     | -       | 160     | 3    |
| 245                          | 180-192                | XM245   | 5895              | 978                               | 480                           | 480                           | 792                                 | 66         | 1744            | 400     | -       | 160     | 3    |
|                              | 180-228                | XH245   | 7250              | 1156                              | 586                           | 586                           | 924                                 | 83         | 2088            | 400     | -       | 160     | 3    |
|                              | 180-198                | XV245   | 8613              | 1439                              | 712                           | 712                           | 1159                                | 101        | 2647            | 800     | -       | 500     | 4    |
|                              | 210-228                | XV245   | 8613              | 1439                              | 712                           | 712                           | 1159                                | 98         | 2617            | 600     | -       | 300     | 4    |
| 300                          | 216-276                | XH300   | 8613              | 1439                              | 712                           | 712                           | 1159                                | 101        | 2617            | 800     | -       | 500     | 4    |
|                              | 216-276                | XV300   | 9520              | 1556                              | 773                           | 773                           | 1254                                | 110        | 2872            | 800     | -       | 500     | 4    |
| 362                          | 258-288                | XH362   | 9520              | 1556                              | 773                           | 773                           | 1254                                | 118        | 2872            | 1200    | 1000    | 600     | 5    |
|                              | 258-288                | XV362   | 11790             | 1956                              | 960                           | 960                           | 1584                                | 148        | 3533            | 1400    | 1000    | 700     | 6    |
| 420                          | 330-360                | XH420   | 10875             | 1734                              | 879                           | 879                           | 1386                                | 131        | 3216            | 1400    | 1000    | 700     | 5    |

### Neutral-ground arresters

|     |         |       |      |     |     |     |     |    |      |   |   |   |   |
|-----|---------|-------|------|-----|-----|-----|-----|----|------|---|---|---|---|
| 52  | 30-36   | XN052 | 1363 | 283 | 126 | 126 | 235 | 19 | 481  | - | - | - | 1 |
| 72  | 42-54   | XN072 | 2270 | 400 | 187 | 187 | 330 | 29 | 736  | - | - | - | 1 |
| 100 | 60      | XN100 | 2270 | 400 | 187 | 187 | 330 | 30 | 736  | - | - | - | 1 |
| 123 | 72      | XN123 | 2270 | 400 | 187 | 187 | 330 | 28 | 736  | - | - | - | 1 |
|     | 75-120  | XN123 | 3625 | 578 | 293 | 293 | 462 | 43 | 1080 | - | - | - | 1 |
| 145 | 84-120  | XN145 | 3625 | 578 | 293 | 293 | 462 | 42 | 1080 | - | - | - | 1 |
| 170 | 96-120  | XN170 | 3625 | 578 | 293 | 293 | 462 | 42 | 1080 | - | - | - | 1 |
| 245 | 108     | XN245 | 3625 | 578 | 293 | 293 | 462 | 41 | 1080 | - | - | - | 1 |
|     | 132-144 | XN245 | 4540 | 800 | 374 | 374 | 660 | 50 | 1397 | - | - | - | 2 |

<sup>1)</sup> Sum of withstand voltages for empty units of arrester.





# PEXLIM P-X

## Technical data for housings




Figure 1




Figure 2




Figure 3




Figure 4




Figure 5




Figure 6

*[Handwritten signature]*

000316

ВЯРНИК  
ОРИГИНАЛ




# PEXLIM P-X


## Accessories




### Line terminals




1HSA410 000-L  
Aluminium



1HSA410 000-M  
Aluminium flag with other  
items in stainless steel




1HSA410 000-N  
Aluminium




1HSA410 000-P  
Stainless steel

### Earth terminals




1HSA420 000-A  
Stainless steel





1HSA420 000-B  
Stainless steel

### Drilling plans





NOTE! Alternative drilling plan  
3 slotted holes (120°), n14 at R111-127

Without insulating base  
Aluminium



Insulating base  
1HSA430 000-A  
Epoxy resin

M12 bolts for connection to structure  
are not supplied by ABB. Required  
threaded grip length is 15-20 mm.



000317

# PEXLIM P-X

## Shipping data


| Rated voltage<br>$U_r$<br>$kV_{rms}$ | Housing | Number of arresters per crate |             |                          |             |                        |             |
|--------------------------------------|---------|-------------------------------|-------------|--------------------------|-------------|------------------------|-------------|
|                                      |         | One<br>Volume<br>$m^3$        | Gross<br>kg | Three<br>Volume<br>$m^3$ | Gross<br>kg | Six<br>Volume<br>$m^3$ | Gross<br>kg |
| 24                                   | XV024   | 0.1                           | 42          | 0.5                      | 86          | 0.9                    | 152         |
| 30-36                                | XV036   | 0.1                           | 42          | 0.5                      | 86          | 0.9                    | 152         |
| 39                                   | XV036   | 0.5                           | 52          | 0.5                      | 116         | 0.9                    | 212         |
| 42-72                                | XV052   | 0.5                           | 52          | 0.5                      | 116         | 0.9                    | 212         |
| 54-72                                | XV072   | 0.5                           | 52          | 0.5                      | 116         | 0.9                    | 212         |
| 75-84                                | XV072   | 0.7                           | 71          | 0.7                      | 163         | 1.2                    | 301         |
| 75-96                                | XV100   | 0.7                           | 71          | 0.7                      | 163         | 1.2                    | 301         |
| 90-120                               | XH123   | 0.7                           | 71          | 0.7                      | 163         | 1.2                    | 301         |
| 90-144                               | XV123   | 0.9                           | 87          | 0.9                      | 201         | 1.5                    | 372         |
| 150                                  | XV123   | 0.9                           | 87          | 0.9                      | 201         | 1.5                    | 372         |
| 108-120                              | XH145   | 0.7                           | 68          | 0.7                      | 154         | 1.2                    | 283         |
| 108-144                              | XV145   | 0.9                           | 87          | 0.9                      | 201         | 1.5                    | 372         |
| 150                                  | XV145   | 0.9                           | 87          | 0.9                      | 201         | 1.5                    | 372         |
| 162-168                              | XV145   | 1.1                           | 98          | 1.1                      | 239         | 1.9                    | 443         |
| 132-144                              | XH170   | 0.9                           | 89          | 0.9                      | 207         | 1.5                    | 384         |
| 150                                  | XH170   | 0.9                           | 89          | 0.9                      | 207         | 1.5                    | 384         |
| 132-192                              | XV170   | 1.1                           | 102         | 1.1                      | 251         | 1.9                    | 443         |
| 192                                  | XM245   | 1.1                           | 98          | 1.1                      | 239         | 1.9                    | 443         |
| 180-228                              | XH245   | 1.1                           | 115         | 1.1                      | 290         | 1.9                    | 545         |
| 180-198                              | XV245   | 0.9                           | 133         | 1.5                      | 339         | -                      | -           |
| 210-228                              | XV245   | 0.9                           | 133         | 1.5                      | 339         | -                      | -           |
| 216-264                              | XH300   | 1.0                           | 155         | 1.7                      | 358         | -                      | -           |
| 276                                  | XH300   | 1.0                           | 155         | 1.7                      | 358         | -                      | -           |
| 216-276                              | XV300   | 1.0                           | 163         | 1.7                      | 382         | -                      | -           |
| 258-288                              | XH362   | 1.6                           | 207         | 2.3                      | 435         | -                      | -           |
| 258                                  | XV362   | 2.1                           | 242         | 2.9                      | 497         | -                      | -           |
| 264-288                              | XV362   | 2.1                           | 258         | 2.3                      | 545         | -                      | -           |
| 330-360                              | XH420   | 2.1                           | 242         | 2.3                      | 497         | -                      | -           |
| 30-36                                | XN052   | 0.1                           | 42          | 0.5                      | 86          | 0.9                    | 152         |
| 42-54                                | XN072   | 0.5                           | 52          | 0.5                      | 116         | 0.9                    | 212         |
| 60                                   | XN100   | 0.5                           | 52          | 0.5                      | 116         | 0.9                    | 212         |
| 72                                   | XN123   | 0.5                           | 52          | 0.5                      | 116         | 0.9                    | 212         |
| 75-120                               | XN123   | 0.7                           | 71          | 0.7                      | 163         | 1.2                    | 301         |
| 84-120                               | XN145   | 0.7                           | 71          | 0.7                      | 163         | 1.2                    | 301         |
| 96-120                               | XN170   | 0.7                           | 71          | 0.7                      | 163         | 1.2                    | 301         |
| 108-120                              | XN245   | 0.7                           | 71          | 0.7                      | 163         | 1.2                    | 301         |
| 132-144                              | XN245   | 0.9                           | 87          | 0.9                      | 201         | 1.5                    | 372         |

Each crate contains a certain number of arrester units and accessories for assembly and erection. A packing list is attached externally on each crate.

Each separate crate is numbered and the numbers of all crates and their contents are listed in the shipping specification.

ABB reserves the right to pack arresters in the most effective/economic combination. Alternate or non-standard crates may involve additional charges.

**i** The table above is to be seen as an approximation and specific data for deliveries may differ from the values given.



за участие в открита процедура за възлагане на обществена поръчка с предмет:

„Подмяна на маслонапъгълена кабелна електропроводна линия 110 kV „Зенит“ от линеен ножов разединител 110 kV на ПС „Хаджи Димитър“ до линеен ножов разединител 110 kV в ПС „Подуяне“, реф. № РРС 17 – 169



## Техническо предложение



### Техническа документация

Приложение № 1 към Предложение за изпълнение на поръчката по т.15.1. от Техническото предложение – Заверени копия на документи за Ограничител на пренапрежение (вентилен отвод) за нова КЕЛ 110 kV:

- Приложение № 1.4. към т.15.1.4. от Техническото предложение – Други по преценка на участника (декларации за съответствие и др.)

000319



Date  
2017-June-14  
Dealt with by, telephone  
Anders Ahlström, +46 240 7834 56  
E-mail  
anders.ahlstrom@se.abb.com  
Fax  
+46 240 78 38 91  
Our ref.  
17BG365611

## CERTIFICATE OF CONFORMITY WITH STANDARDS AND ORIGIN

To Whom it May Concern,

We ABB AB, Ludvika, Sweden, hereby declare under our sole responsibility, that all our surge arresters type PEXLIM P096-XV123 are designed, manufactured and tested in accordance and in compliance with the following standards, directives or other normative documents:

Directive: EMC directive 2004/108/EC

Applied EC IEC 60099-4, Surge arresters – Part 4 – Metal oxide Harmonized surge arresters without gaps for a.c. systems.

ANSI/IEEE C62.11 and the requirements laid down in our proposal for the above mentioned project.

The equipment is manufactured in our factory ABB in Ludvika, Sweden.

The Process of Engineering, Manufacturing and Testing of the mentioned goods will be accomplished according to our Quality and Management Systems as certified by ISO 9001/ISO 14001.

This has been issued for any purpose it may serve.

Yours faithfully,

Anders Ahlström  
Area Marketing Manager  
ABB AB  
High Voltage Products

000320

Превод от английски език, извършен от Даниела Кирилова Тодорова:

[Лого – не се чете]

Дата  
2017 – Юни -14  
Съгласувано от, телефон  
Андерс Ахлщрьом, +46 240 7834 56  
И-мейл  
anders.ahlstrom@se.abb.com  
Факс:  
+ 46 240 78 38 91  
Наш реф.:  
17BG365611

## ДЕКЛАРАЦИ ЗА СЪОТВЕТСТВИЕ СЪС СТАНДАРТИ И ПРОИЗХОД

На вниманието на всички заинтересовани,

Ние, АББ АЛ, Лудвика, Швеция, с настоящото декларираме, че всички наши вентилни отводи тип PEXLIM PO96-XV123 са проектирани, произведени и тествани, съгласно и в съответствие със следните стандарти, директиви и други нормативни документи:

Директива: EMC директива 2004/108/ЕС

Приложим ЕС IEC 60099-4, Вентилни отводи – Част 4 – Металоокисни хармонизирани вентилни отводи без отвори за а.с. системи.

ANSI/IEEE C62.11 и изискванията посочени по-долу в нашето предложение за горепосочения проект. Оборудването се произвежда в нашата фабрика АББ в Лудвика, Швеция.

Процесът по Инженеринг, Производство и Тестване на посочените стоки ще бъде извършен съгласно нашите Системи за качество и управление, съгласно сертификацията по ISO 9001/ISO 14001.

Настоящото се издава да послужи, където е необходимо.


Искрено Ваш,

[подпис-не се чете]

Андерс Ахлщрьом  
Локален Маркет Мениджър  
АББ АБ  
Високоволтови Продукти

000321

ВЯРНО С  
ОРИГИНАЛА



Data Schedule

Tender ID: Pos:

## ABB High Voltage Products

Data schedule: Surge Arresters

DIMENSION DRAWING: 1HSA134-8664

|  |                                 |
|--|---------------------------------|
|  | PEXLIM P-X<br><b>P096-XV123</b> |
| <b>1 General data</b>  |                                 |
| Design   | ZnO, Gapless                    |
| Manufacturer, country  | ABB                             |
| Applied standards  | IEC                             |
| Catalogue  | 1HSM 9543 12-00en               |
| Maximum system voltage (Us)  | kVrms 123                       |
| Arrester classification as per IEC 60099-4 Ed 3.0  | Station; SH                     |
| Nominal discharge current  | kApeak 20                       |
| Rated voltage (Ur)   | kVrms 96                        |
| Maximum continuous operating voltage (Uc)  | kVrms 77                        |
| Frequency  | Hz 15-62                        |
| TOV capability (after thermal energy rating, Wth)  |                                 |
| 1 s  | kVrms 106                       |
| 10 s   | kVrms 100                       |
| <b>2 Charge, energy and current withstand data</b>   |                                 |
| Repetitive charge transfer rating, Qrs   | C 3.2                           |
| Thermal energy rating, Wth   | kJ/kV (Ur) 11                   |
| Discharge current withstand strength   |                                 |
| High current, 4/10 µs  | kApeak 100                      |
| Low current, 2000 µs   | Apeak 1600                      |
| Single-impulse withstand rating (IEEE), Repetitive charge transfer test value (IEC) - sample tests on all manufactured block batches | C 4                             |
| <b>Energy data as per previous IEC standard IEC 60099-4, Ed 2.2</b>  |                                 |
| Line discharge class   | Class 4                         |
| Energy capability - thermal energy capability (as per IEC 60099-4 Ed 2.2, clause 8.5.5)  | kJ/kV (Ur) 11                   |
| <b>3 Guaranteed max. protective data</b>   |                                 |
| Maximum residual/discharge voltage   |                                 |
| with current wave 30/60 µs (slow-front/switching)  |                                 |
| 0.5 kA   | kVpeak 182                      |
| 1.0 kA   | kVpeak 188                      |
| 2.0 kA   | kVpeak 194                      |
| with current wave 8/20 µs (fast-front/lightning)   |                                 |
| 5.0 kA   | kVpeak 208                      |
| 10 kA  | kVpeak 219                      |
| 20 kA  | kVpeak 240                      |
| with current wave 1/(2-20) µs (FOW as per IEEE, steep front as per IEC)  |                                 |
| External inductive effects neglected.  |                                 |
| 10 kA  | kVpeak 233                      |
| <b>4 Technical data for housing</b>  |                                 |
| Short-circuit capability   |                                 |
| High current, 0.2 s  | kArms 65                        |
| Low current  | Arms 600                        |
| External insulation  |                                 |
| Requirements as per IEC 60099-4  |                                 |
| LIWL, 1.2/50 µs  | kVpeak 312                      |
| 50 Hz, wet (60 s)  | kVrms 146                       |
| SIWL, wet (250/2500 µs)  | kVpeak 243                      |
| Tested values on empty units/modules housings  |                                 |
| LIWL, 1.2/50 µs  | kVpeak 800                      |
| 50 Hz, wet (60 s)  | kVrms 374                       |
| SIWL, wet (250/2500 µs)  | kVpeak 660                      |
| Creepage distance (nominal)  | mm 4540                         |
|  | mm/kV (Us) 36.9                 |
| Specified long-term load (SLL)   | Nm 2500                         |
| Specified short-term load (SSL)  | Nm 4000                         |
| Insulator colour / material  | Grey Silicone                   |

000322

ОРИГИНАЛ



за участие в открита процедура за възлагане на обществена поръчка с предмет:

„Подмяна на маслонапълнена кабелна електропроводна линия 110 kV „Зенит“ от линеен ножов разединител 110 kV на ПС „Хаджи Димитър“ до линеен ножов разединител 110 kV в ПС „Подуяне“, реф. № РРС 17 – 169



## Техническо предложение




### Техническа документация

Приложение № 2 към Предложение за изпълнение на поръчката по т.15.2. от Техническото предложение – Заверени копия на документи за Оптичен кабел:

- Приложение № 2.1. към т.15.2.1. от Техническото предложение – Последно издание на каталога на производителя.

000323





# Fiber optic cables

Product catalogue 2018

