




New generation of three pole LV fuse switches type NH

Neue Generation - Pronutec NH Sicherungslastschaltleisten

Triver +



pronutec  
görlan team



148.3



## NEW GENERATION OF THREE POLE LV FUSE SWITCHES TYPE NH TRIVER + NEUE GENERATION - PRONUTEC NH - Sicherungslastschaltleisten TRIVER +

As the market leader in fuse rails and fuse switches and thank to its policy innovation and constant development, Pronutec has designed a new generation of vertical fuse rails and switches NH-1/2/3 TRIVER+.

TRIVER+ is the new range of TRIVER, which aims to meet our customer needs in the recent years; anticipating the needs of the future.

Als Marktführer im Bereich der NH-Sicherungsleisten und NH-Sicherungslastschaltleisten und getreu der Unternehmensphilosophie "stetige Weiterentwicklung und Innovation", präsentiert Pronutec die neue NH-Sicherungslastschaltleisten Generation "TRIVER+" in den Größen NH-1/2/3.

Mit der neue "TRIVER+" Generation kommt Pronutec den sich gewandelten Kundenbedürfnissen nach und erfüllt schon heute zukünftige Bedürfnisse.

### Fully compatible - Voll Kompatibel

TRIVER+ is a fuse switch / fuse rail 100% compatible with the current range. It maintains the same external dimensions so they can be installed in any currently installed LV panels in the market (valid fuse switches and fuse rails for front panels of 600mm or 650mm in height).

It has also been designed and tested under the IEC 60947-3 standard and in accordance with major national and international standards of different utilities.



Die neuen "TRIVER+" NH-Sicherungslastschaltleisten sind 100%-ig kompatibel zum bestehenden Programm, die äußeren Abmessungen bleiben identisch, so dass keine Änderungen im Bereich der Konstruktion vorgenommen werden müssen.

Die Entwicklung und Prüfung erfolgte gemäß der internationalen Norm IEC 60947-3. Des Weiteren werden die Kundenanforderungen nationaler wie internationaler Energieversorger erfüllt.

### Adapted to future - Startklar für die Zukunft

This new generation of three pole switches are prepared to meet the market's needs that will appear in the near future with the implementation of Intelligent Networks (Smart Grids). For such purpose, it incorporates features and accessories for remote control such as integrated or independent metering sets, Fuse Supervision Control, etc...

Die neue Generation der NH-Sicherungslastschaltleisten erfüllt schon heute die Anforderungen für zukünftige intelligente Netzwerke (Smart Grids) z. B. gibt es Zubehörteile zur Fernkontrolle, integrierte oder unabhängige Mess-Sets, Sicherungsüberwachung, usw...



1224

## Energy efficiency - Energie-Effizienz

The new TRIVER+, has been designed to achieve greater energy efficiency in real operation conditions. On one hand, it reduces power losses (thanks to the new design of the contact) and second, the heat dissipation of the fuse switch is higher (due to ventilation granted by the new housing of the switching unit).

Mit der neue "TRIVER+" Reihe steigert Pronotec die Energieeffizienz unter realen Bedingungen.

- Reduktion der Verlustleistung durch neu entwickelte Kontakte.
- Bessere Wärmeabfuhr durch einen intelligenten Aufbau des Oberteils.

Fuse switch heat reduction  
Reduzierung der Verlustleistung


11%

## Safety against accidental contacts - Berührungsschutz

Safety is the main aspect for the development of new products in Pronotec. The new TRIVER+, provides a IP30 protection degree in the closed position and IP20 in the open position, ensuring maximum protection against accidental contacts.

Sicherheit ist der Hauptaspekt für Neuentwicklungen des Hauses Pronotec. Die neue "TRIVER+"-Reihe bietet maximalen Berührungsschutz, so wird ein Schutzgrad von IP30 in der geschlossenen und IP20 in der geöffneten Position erreicht.

Front protection degree  
Schutzgrad Frontbedienung



Closed: IP 30  
Geschlossen: IP 30

Open: IP 20  
Geöffnet: IP 20

## Ecodesign - Ecodesign

The reduction of power losses thanks to the new design of the TRIVER+ has a positive effect on the environment by saving energy.

At the same time, with the design of this new TRIVER+, the impact of the product on the environment has been reduced throughout its whole life cycle.

This reflects Pronotec's commitment in terms of sustainable development and respect for the environment.

Neben der Reduktion von Verlustleistungen hat das neue Design "TRIVER+" auch einen positiven Umwelteffekt, da diese durch die Einsparung von Energie entlastet wird. Gleichzeitig wurde mit der Neuentwicklung "TRIVER+" dafür gesorgt, dass die Belastung der Umwelt während des gesamten Lebenszyklus reduziert wird.

Dieses spiegelt Pronotec's Engagement im Sinne der Nachhaltigkeit wieder.

Recycling - Recycling

Acquisition and Consumption of materials and components  
Akkquisition und Verbrauch von Materialien und Komponenten

Production in factory  
Produktion

Distribution and disposal  
Vertrieb und Entsorgung

Usage or utilisation  
Benutzung und Verwendung

Commissioning  
Kommisionierung



1385

## Ergonomic, Modern and Functional Design - Ergonomisches, Modernes und Funktionales Design


Better maneuverability. Faster to install and handle. More effective. Safer.

Steigerung der Bedienerfreundlichkeit. Schneller zu installieren. Effizienter. Sicherer.

### Applications - Anwendungen

Retractable handle / More compact panels. Depth reduces from 190mm to 165mm. LV panels can be designed with less depth.

Versenkbare Griffe / kompaktere Verteilungen. Reduzierung der Tiefe von 190mm auf 165mm. Verteilungen können mit einer geringeren Tiefe gebaut werden.




**REVERSIBILITY**  
Connections can be done either in the upper part or lower part, with a simple turn of the base upside down.


**ABGANG OBEN/UNTEN FREI WÄHLBAR**  
Durch eine einfache Drehung des Unterteils entscheiden Sie selbst ob der Abgang ober- oder unterhalb sein soll.

### Safety in its handling - Sicherheit in der Handhabung


The new TRIVER+ has other elements that make the installation and maintenance operation even safer for people. Höhere Sicherheit bei den neuen TRIVER+ bei Installation und Wartung.




Safety and comfort in the extraction of the fuse. Sicherheit und Komfort bei der Entnahme des Sicherungseinsatzes.




Fuse removed without touching with the use of an external drive. Berührungslose Entfernung des Sicherungseinsatzes.




Cover including a device to allow direct access to the blade of the fuse in order to make stress testing. Oberteil ermöglicht direkte Messung auf den Messern des Sicherungseinsatzes.




Easy to place the switching case. Einfache Installation des Oberteils.



Live work is possible thanks to removable black windows in the switching unit. Öffnungsfenster im Oberteil ermöglichen die Installation unter Spannung.




Release of fuse. More space in the handle. Entriegelung des Sicherungseinsatzes. Mehr Komfort beim Schalten durch einen größeren Griffbereich.






**Blocking elements - Verriegelung & Plombierbarkeit**


Valid for both, single and three pole switching versions.  
Verfügbar in den Versionen 1- und 3-polig schaltbar.




Closed position with padlock in each phase.  
Jede Phase in geschlossener Position verriegelbar.



Open position with padlock.  
Verriegelung in geöffneter Position.




Sealed lock of each phase in its closed position as well as in the cable connection area.  
Jede Phase in geschlossener Position plombierbar, zusätzlich kann der Anschlussraum plombiert werden.



**Accessories - Zubehör**




Large range of accessories that provide greater benefits inside the new TRIVER+.  
Große Auswahl von Zubehörtteilen, die weitere Vorteile der neuen "TRIVER+" Reihe bieten.

Permanent or temporary metering by means of a combined set of fuse - current transformer - ammeter.  
Dauerhafte oder temporäre Messungen mittels eines kombinierten Sets von Stromwandlern und Amperemeter.




Microswitch which enables electronic open / close indicator.  
LED - Integrated blown fuse indicator.  
Mikroschalter für Positionsanzeige der NH-Sicherungslastschaltleiste.  
LED - Integrierte Zustandsanzeige des Sicherungseinsatzes.

Upper/Lower rating plate.  
Obers- und unteres Beschriftungsfeld.




Fuse protected auxiliary supply (up to 160A fuses) used to provide temporary supply with no need for installing an additional fuse rail.  
Huckepacksicherung - abgesicherter temporäre Hilfsanschluss (bis 160A) für die vorübergehende Versorgung ohne Installation einer zusätzlichen NH-Sicherungslastschaltleiste.



The blade of the earthing link is housed in the position of the fuse in the base.  
The base is grounded by means of a copper braid.  
Möglichkeit zur Erdung der angeschlossenen Kabel mit Hilfe unserer isolierten Erdungsgarnitur.

Examples - Beispiele:




Large range of terminals adapted to suit several type of cable terminations in International markets.  
Hohe Vielfalt von Anschlussvarianten.




1388

Triver+ - Range - Triver+ - Produktpalette


BTVC one pole switching - BTVC 1-polig-schaltbar



BTVC three pole switching - 1 handle - BTVC 3-polig-schaltbar / ein-hand-betrieben



BTVC three pole switching - 2 handles - BTVC 3-polig-schaltbar / zwei-hand-betrieben



Triver+ Range - Triver+ Produktpalette

Description Beschreibung	Fuse Link Sicherungseinsatz	Current Strom	Reference* Artikelnummer*
BTVC-DU	NH-1	250	438.51.10.XX.YY
BTVC-DU	NH-2	400	438.5210.XX.YY
BTVC-DU	NH-3	630	438.53.10.XX.YY
BTVC-DU DOUBLE - BTVC-DU DOPPEL	NH-2	800	438.54.70.XX.YY
BTVC-DU DOUBLE - BTVC-DU DOPPEL	NH-3	1260	438.56.70.XX.YY
BTVC-DT 1 HANDLE - BTVC-DT - EIN-HAND-BETRIEBEN	NH-1	250	438.71.10.XX.YY
BTVC-DT 1 HANDLE - BTVC-DT - EIN-HAND-BETRIEBEN	NH-2	400	438.72.10.XX.YY
BTVC-DT 1 HANDLE - BTVC-DT - EIN-HAND-BETRIEBEN	NH-3	630	438.73.10.XX.YY
BTVC-DT 2 HANDLES - BTVC-DT - ZWEI-HAND-BETRIEBEN	NH-1	250	438.61.10.XX.YY
BTVC-DT 2 HANDLES - BTVC-DT - ZWEI-HAND-BETRIEBEN	NH-2	400	438.62.10.XX.YY
BTVC-DT 2 HANDLES - BTVC-DT - ZWEI-HAND-BETRIEBEN	NH-3	630	438.63.10.XX.YY

\*Reference = Article Reference + XX (Terminal code) + YY (Accessories code).  
Please, see the terminals and accessories in the Pronutec General Catalogue.  
For other options, please consult.

\*Artikelnummer = Artikelnummer + XX (Anschlussvariante) + YY (Zubehör).  
Die Anschlussvarianten und Zubehörteile entnehmen Sie bitte unserem Hauptkatalog.

Technical data - Technische Daten

Electrical Characteristics Elektrische Eigenschaften	Type Typ	250 A		400 A		630 A	
Rated operation voltage - Bemessungsbetriebsspannung	Ue (V)	AC 500	AC 690	AC 500	AC 690	AC 500	AC 690
Rated operation current - Bemessungsbetriebsstrom	Ie (A)	250	200	400	315	630	500
Conventional free air thermal current with fuses Konventioneller thermischer Strom mit Sicherungen	Ith (A)	250	200	400	315	630	500
Conventional free air thermal current with solid links Konventioneller thermischer Strom mit Trennmessern	Ith(A)	400	400	510	510	800	800
Rated frequency - Bemessungsfrequenz	(Hz)	40-60	40-60	40-60	40-60	40-60	40-60
Rated insulation voltage - Bemessungsisolationsspannung	Ui (V)	AC 1000	AC 1000	AC 1000	AC 1000	AC 1000	AC 1000
Rated conditional short-circuit current - Bedingter Bemessungskurzschlussstrom	(kAeff)	80	80	80	80	80	80
Utilization category - Gebrauchskategorie		AC-22B*	AC-22B	AC-22B*	AC-22B	AC-22B	AC-22B
Rated making capacity - Bemessungseinschaltvermögen	(A)	1200	600	1890	945	1890	750
Rated breaking capacity - Bemessungsausschaltvermögen	(A)	1200	600	1890	945	1890	750
Rated impulse withstand voltage - Bemessungsstossspannung	Uimp /kV	20	20	20	20	20	20
Operating cycles with current - Elektrische Lebensdauer (Schaltspiele)		200	200	200	200	200	200
Total power loss at Ith Ges. - Verlustleistung bei Ith (ohne NH-SEI)	Pv (W)	25	16	52	32	98	62

\* AC23B for rated operation voltage AC 400

Characteristics of the materials - Materialeigenschaften

The new TRIVER+ fuse switch maintains one of the most valued aspects by our costumers: high quality materials to ensure product reliability.

- UP-BMC thermostable Polyester reinforced fibreglass socket.
- High-performance self extinguishing technical plastic housing.
- All live parts are made out of SE-CU57 electrolytic copper according to DIN 1787.
- Contacts are silver plated and conductive parts are tin-plated.
- Stainless steel springs.


Die Nutzung von hochwertigen Materialien stellt die Basis unserer neuen TRIVER+ Produktreihe dar.

- Grundkörper bestehend aus UP-BMC temperaturbeständiges, glasfaserverstärktes Polyester.
- Einsatz von leistungsstarken, selbstverlöschenden Kunststoffen.
- Alle spannungsführende Teile bestehen aus SE-CU57 Elektrolytkupfer gemäß DIN1787.
- Die Kontakte sind versilbert und alle weiteren leitenden Teile verzinkt.
- Kontaktfedern aus nichtrostendem Edelstahl.




1389

*Handwritten signature*



> Tiefenbroicher Weg, 35  
40472 Düsseldorf - GERMANY



> Tel.: +49 (0 211) 30 21 91 5  
> Fax: +49 (0 211) 30 33 20 9  
> e-mail: info@pronotec.com



> Parque Empresarial Boroa, Parcela 2C-1  
48340 Amorebieta (Vizcaya) - SPAIN

>> Tel.: +34 94 631 32 86  
>> Fax: +34 94 631 38 32

>> e-mail: 4ex@pronotec.com  
>> www.pronotec.com



*Handwritten signature*

1392

## Списък на отделните изпитвания на български език

### **Изследван образец:**


Вертикален разединител с предпазители от типа BTVC 400A , триполюсен

### **Производител:**

Pronutec S.A. , Испания

Изпълнени тестове (съгласно IEC/EN 60947-3; IEC 60947-1.Експлоатационни характеристики по комутационна способност .

- 1) Проверка на оборудването при тестване по комутационна способност при категория на приложение AC 22В/500V
- 2) Поведение на оборудването при тестване по комутационна способност
- 3) Състояние на оборудването след тестване по комутационна способност
- 4) Проверка на диелектричните свойства
- 5) Проверка на загубите
- 6) Проверка за ток на утечка
- 7) Тест за повишаване на температурата – проверка на нагряването
- 8) Проверка на задействащия механизъм за издръжливост
- 9) Зависими и независими ръчни операции (задействаща сила при отваряне и затваряне)





Accredited by BMWA with GZ: 92714/237-IV/9/00 as test- and inspection body  
and with BGBl. II Nr. 244/2005 as certification body for personnel



**AUSTRIAN INSTITUTE  
OF TECHNOLOGY**

# Test Report

Project Designation

**PERFORMANCE OF  
MAKING AND BREAKING CAPACITY  
AT LOW-VOLTAGE  
FUSE-SWITCH-DISCONNECTORS  
TYPE BTVC 400A  
THREE POLE OPERATED  
(AC-22B at 500V / 400A)**

Client

**PRONUTEC S.A.  
Parque Empresarial Boroa  
Parcela 2c-1  
E-48340 Amorebieta - VIZCAYA  
SPAIN**

Order from / No.

06/2010 / ---

Project Number

2.03.02087.1.0/BTVC400/AC22/500V/400A/3-pole

Test Engineer

Ing. J. Ainetter

Date of issue	22.11.2010
Total number of issues / No.	1 / 1
Number of pages	10
Annex; Number of pages	---

The results relate exclusively to the terms tested.

This report may only be reproduced or published in full, without omissions, alterations or additions.

The reproduction or publishing of extracts from this report require the written approval of the research center.

Österreichisches Forschungs- und Prüfzentrum Arsenal Ges.m.b.H. | 1210 Wien, Gießgasse 2, Austria | +43 (0) 50 550-0 | www.ars.at  
Court of jurisdiction Vienna | FN 165088b | DVR 0037532 | UID: ATU 46677208 | ISO 9001 2008-Certified | Bank details: Erste Bank der  
Österreichischen Sparkassen AG | Account No. 26226773802 | BIC: 20111 | IBAN AT95 2011 1287 2677 3802 | BIC: GIBA AT 3300



1891



AUSTRIAN INSTITUTE  
OF TECHNOLOGY

## Test item

### Identification:

Low-voltage fuse-switch-disconnectors type BTVC 400A, three pole operated

Trademark: pronutec  
Manufacturer: PRONUTEC S.A.  
Size: 2  
Number of poles: 3  
Busbar system: 185mm  
Rated operational voltage: 400V a.c. up to 690V a.c.  
Rated operational current: 400A  
Rated frequency: 50Hz

## Testing location, Period of testing

### Testing location:

Österreichisches Forschungs- und Prüfzentrum Arsenal Ges.m.b.H.  
Business Unit Electric Energy Systems  
Power Service Center  
Giefinggasse 2  
1210 Vienna  
AUSTRIA

### Period of testing:

09/2010

## Test(s)

### Test(s) performed:

Performance of making and breaking capacity (AC-22B at 500V / 400A)

### Test standard(s):

IEC 60947-1:2007 (Edition 5.0) and IEC 60947-3:2008 (Edition 3.0)  
EN 60947-1:2007 and EN 60947-3:2009

### Test procedure(s):

CB-Scheme and CCA-Scheme

### Possible test case verdicts:

P (Pass): Test object does meet the requirement  
F (Fail): Test object does not meet the requirement  
N (Not applicable): Test case does not apply to the test object

## Result

The low-voltage fuse-switch-disconnectors type BTVC 400A, three pole operated, have passed the performance of making and breaking capacity (AC-22B at 500V / 400A) successfully.

Test Engineer

на основание чл. 2 от 33ЛД

Ing. J. Ainetter

Project Engineer,

на основание чл. 2 от 33ЛД

Ing. K. Farthofer




13921





AUSTRIAN INSTITUTE OF TECHNOLOGY



### Testing laboratory




ACCREDITED according to EN ISO/IEC 17025 No. BMWA-92.714/0504-1/12/2007




CERTIFICATED according to ISO 9001 Reg. No. 12769




RECOGNIZED CB TESTING LABORATORY under the responsibility of OVE as the National Certification Body



### POWER SERVICE CENTER:



Control station for tests up to 15kA



Control station for tests above 15kA




1202




### Technical data and description

Test item	Low-voltage fuse-switch-disconnectors
Trademark	pronutec
Model/Type reference	BTVC 400A
Manufacturer	PRONUTEC S.A.
Place of manufacture	Vizcaya, Spain
Type of operation	Three pole operated
Method of operation	Dependent manual operation
Size	2
Busbar system	185mm
Type of terminals	Bolt terminals M12
Switching positions	ON / OFF
Number of poles	3
Nature of supply	AC
Utilization category	AC-22B
Rated operational voltage	400V a.c. up to 690V a.c.
Rated operational current	400A (up to 500V a.c.) 315A (at 690V a.c.)
Rated frequency	50Hz
Conventional free air thermal current	400A (with 500V fuse-links)
Rated insulation voltage	1000V
Rated impulse withstand voltage	12kV
Rated conditional short-circuit current	80kA (up to 500V a.c.) 50kA (at 690V a.c.)
Kind of protective device	Fuse-links NH2
Maximim power dissipation of the protective device	34W
Degree of protection	IP 20



1394

Picture of test item



*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

1395






Test performance / Test values

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS		P
8.3.3.3	Making and breaking capacity		P
	- utilization category.....	AC-22B	-
	- rated operational voltage $U_e$ (V) .....	500	-
	- rated operational current $I_e$ (A) .....	400	-
	Conditions for make operation, AC-23A and AC-23B only:		N
	- test voltage, $U = 1,05 U_e$ (V) .....	L1: - L2: - L3: -	-
	- test current, $I = \dots \times I_e$ (A) .....	L1: - L2: - L3: -	-
	- power factor .....	L1: - L2: - L3: -	-
	Conditions for break operation, AC-23A and AC-23B only:		N
	- test voltage, $U = 1,05 U_e$ (V) .....	L1: - L2: - L3: -	-
	- test current, $I = \dots \times I_e$ (A) .....	L1: - L2: - L3: -	-
	- power factor .....	L1: - L2: - L3: -	-
	Conditions for make/break operations, other than AC-23A and AC-23B:		P
	- test voltage, $U = 1,05 U_e$ (V) .....	L1: 526 L2: 528 L3: 526	-
	- test current, $I = 3 \times I_e$ (A) .....	L1: 1217 L2: 1228 L3: 1212	-
	- power factor / time-constant (ms) .....	L1: 0,64 L2: 0,64 L3: 0,64	-
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration $\geq 50$ ms (ms) .....	Permanent	P
	- current duration (ms) .....	240	-
	- time interval between operations (s) .....	30	-
	Oscillogram .....	1 (5 <sup>th</sup> operation)	-

*[Handwritten signature]*



1396




IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Characteristic of transient recovery voltage for AC-22 and AC-23 only:		P
	- oscillatory frequency (kHz) .....	57,24	-
	- measured oscillatory frequency (kHz) .....	L1: 57,1 L2: 57,1 L3: 57,1	P
	- factor n.....	L1: 1,1 L2: 1,1 L3: 1,1	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		-
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		P
	test voltage $2 U_e$ with a minimum of 1000V~ (V)....	1400	-
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage $1,1 U_e$ (V).....	760	-
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole (mA) :	-	N
	Leakage current (other utilization categories) $\leq 2$ mA/pole (mA).....	< 1	P

*Handwritten signature and scribbles across the table.*

*Handwritten signature.*

*Handwritten signature and scribbles.*

1397



IEC / EN 60947-3				
Clause	Requirement - Test	Result - Remark		Verdict
8.3.3.6	Temperature-rise verification			P
	- conductor cross-section (mm <sup>2</sup> ).....	240		-
	- test current I <sub>e</sub> (A).....	400		-
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 61	80	P
	Manual operating means: non-metallic	5	35	P
	Parts intended to be touched but not hand-held: non-metallic	37	50	P
	Parts which need not be touched during normal operation: non-metallic	45	60	P
8.3.3.7	Strength of actuator mechanism			P
8.2.5	Verification of the strength of actuator mechanism and position indicating device			P
	- actuator type (fig.).....	1e		-
8.2.5.2.1	Dependent and independent manual operation			P
	- actuating force for opening (N).....	210		-
	- test force with blocked main contacts (N).....	400		-
	- used method to keep the contact closed.....	Fixed by brazing		-
	During and after the test, open position not indicated.....	No open position indicated		P
	Equipment with locking mean, no locking in the open position while test force is applied.....	No locking in open position		P
8.2.5.2.2	Dependent power operation			N
	- main contacts fixed together in the closed position.....	-		N
	- used method to keep the contact closed.....	-		N
	- 110% of the rated supply voltage applied to the equipment (3 times).....	-		N
	During and after the test, open position not indicated.....	-		N
	Equipment show no damage impairing its normal operation.....	-		N
	Equipment with locking mean, no locking in the open position while test force is applied.....	-		N





IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.2.5.2.3	Independent power operation		N
	- main contacts fixed together in the closed position .....	-	N
	- used method to keep the contact closed .....	-	N
	- stored energy of the power operator released (3 times) .....	-	N
	During and after the test, open position not indicated .....	-	N
	Equipment show no damage impairing its normal operation .....	-	N
	Equipment with locking mean, no locking in the open position while test force is applied .....	-	N

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

1399


*[Faint stamp]*





### Oscillogram(s)

Oscillogram 1:



*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*



## Confirmation of Accreditation

The Federal Ministry of Economics, Family and Youth confirms that

### Österreichisches Forschungs- und Prüfzentrum Arsenal Ges.m.b.H

Giefinggasse 2, A-1210 Wien

Identification number: 1

Initial date of Accreditation: December 01, 1993



is accredited as Testing Laboratory and Inspection Body and fulfills the requirements of ÖVE/ÖNORM EN ISO/IEC 17025:2007 and ÖVE/ÖNORM EN ISO/IEC 17020:2004 Type A.

The detailed scope of accreditation is given in the currently valid decree.

The accredited technical fields are published in the list of accredited bodies at [www.bmwfj.gv.at/akkreditierung](http://www.bmwfj.gv.at/akkreditierung).


Vienna, May 07, 2010

на основании чл. 2 от 33ЛД

Dipl.-Ing. Günter P. Friers



Division 1/12 - Accreditation Body  
Stubenring 1 | 1011 Vienna | Austria | phone: +43 (0)1 711 00 - 8236 | fax: +43 (0)1 711 00 937-82564 | DVR 0032257  
e-mail: [akkreditierung@bmwfj.gv.at](mailto:akkreditierung@bmwfj.gv.at) | [www.bmwfj.gv.at/akkreditierung](http://www.bmwfj.gv.at/akkreditierung)





**PRONUTEC, S.A.**  
Parque Empresarial Boroa Parc. 2c-1  
48340 Amorebieta - VIZCAYA (SPAIN)  
NIF.: ES-A-48/217.962

*Declaro bajo su responsabilidad que el producto:  
Declare under our sole responsibility that the product:  
Eigenverantwortliche Erklärung zu unserem Produkt:*

*Bases tripolares verticales cerradas (BTVC) tamaños 1/2/3, desconexión unipolar y tripolar.  
Three poles fuse rails (BTVC) size 1/2/3, one and three pole Switching.  
Dreipolige Sicherungslustschaltleisten (BTVC) Größe 1/2/3, ein und dreipolig schulthar.*

*Referencias 438xxxxxx fabricados según la Especificación Técnica de Pronutec ET-438.  
References 438xxxxxx manufactured according Pronutec's ET-438 Technical Specification.  
Die Referenznummern 438xxxxxx sind alle gefertigt gemäß den technischen Spezifikationen der Pronutec ET-438.*

*Son conformes con las exigencias de la Directiva de Seguridad del material eléctrico destinado a ser utilizado  
bajo determinados límites de tensión 2006/95/EC.*

*Are in accordance with the requirements of the Low Voltage Directive 2006/95/EC  
Diese sind in Übereinstimmung mit den Anforderungen der Niederspannungsanweisung 2006/95/EC.  
Y de la Directiva de Compatibilidad Electromagnética 2004/108/CE.  
And with the Electromagnetic Compatibility Directive 2004/108/CE.  
Und mit der Elektromagnetischen Verträglichkeitsanweisung 2004/108/CE.*

*De acuerdo a la siguiente norma armonizada:  
According to the following harmonised standard:  
Gemäß der folgenden Norm:*

**UNE - EN 60947-3: 2009**

*Cualquier montaje, ya sea inicial o posterior que no respete las instrucciones generales de puesta en servicio y  
uso dadas por Pronutec, anula este documento.  
Any initial or subsequent installation that will not observe the general instructions given by Pronutec will  
cancel this document.  
Jegliche Änderungs oder Nachinstallationen, die nicht den generellen Anweisungen der Firma Pronutec  
entspricht, widerruft diese Erklärung.*


En Amorebieta / In Amorebieta

Fdo. Diego Martín Imbert  
Director Técnico  
Technical Director / Technischer Direktor

**Pronutec**  
LABORATORIO

Tel: +34 94 681 32 34  
Fax: +34 94 681 35 33

на основании чл. 2 от 33ЛД



*[Handwritten signatures and initials]*

## Декларация за съответствие

**Pronutec, S.A.**

*Parque Empresarial Boroa Parc. 2c-1*

*48340 Amorebieta-VIZCAYA (SPAIN)*

*NIF.: ES-A-48/217.962*

Декларирам на своя лична отговорност, че продуктите:

Триполюсните основи с предпазители (BTVC) размери 1/2/3, еднополюсните и триполюсни разединители, с референции 438xxxxxx произведени съгласно техническата спецификация на Pronutec ET-438

са в съответствие с изискванията на Директива за ниско напрежение 2006/95/EC

и с Директива за електромагнитна съвместимост 2004/108/CE

в съответствие със следния хармонизиран стандарт: *UNE - EN 60947-3: 2009*



Всяко първоначално или последващо инсталиране, които няма да спазват общите инструкции, дадени от Pronutec ще отмени този документ.

En Amorebieta


Fdo. Diego Martin Imbert

Технически директор

/подпис не се чете/



1403



## ДЕКЛАРАЦИЯ

на основание чл. 2 от ЗЗЛД

Долуподписаният Петър Иванов Данчев, Т

на основание чл. 2 от ЗЗЛД

МВР ул. " " на основание чл. 2 от ЗЗЛД

ачеството си на Изпълнителен Директор и представляващ "ИНЖЕНЕРИНГ" ЕАД

### ДЕКЛАРИРАМ, ЧЕ :

Предлаганите от "Инженеринг" ЕАД триполюсни вертикални разединители за предпазители 400 А - NH2 са изцяло в съответствие с изискванията на техническата спецификация на стандартите за материала , включително на параграфи „Характеристика на материала“ и "Съответствие на предложеното изпълнение с нормативно – техническите документи" по процедура с референтен № PPD 18-063.

01.08.2018 г.  
гр.Пловдив

Подпис

на основание чл. 2 от ЗЗЛД




1404

**TRIVER 4.**

**INSTRUCCIONES DE MONTAJE  
ASSEMBLY INSTRUCTIONS / ИНСТРУКЦИЯ ЗА МОНТАЖ**

**ВТУС / ВТУС-ОТ / ВТУС-ДУ ПН 1-2-3**

**DESCONEXIÓN UNIPOLAR / ONE POLE SWITCHING / Премагнитване единполносно  
DESCONEXIÓN TRIPOLAR / THREE POLE SWITCHING / Премагнитване трета полюсен**



**1.**

**E** EXTRAER LA TAPA DE CONEXIONES GB REMOVE CONNECTION COVER

**B** Отстраняване предпазната капак на клемите




**2.**

**E** TIRAR DE LAS ASAS GB PULL THE HANDLES



**B** Издърпайте ръкохватките

**E** TIRAR DE LAS 2 ASAS AL MISMO TIEMPO GB PULL BOTH HANDLES AT THE SAME TIME

**B** Издърпайте едновременно двата ръкохватки




**3a)**  
**CONEXIÓN A EMBARRADO EN TENSION**  
**INSTALLING ON LIVE BUSBARS**  
Монтаж при шинна система под напрежение



185 mm  
165 mm

**3b)**  
**CONEXIÓN A EMBARRADO SIN TENSION**  
**INSTALLING ON CURRENT FREE BUSBARS**  
Монтаж при шинна система без напрежение





**TENER EN CUENTA EL MARCADO DE LAS FASES EN LA ZONA DE CONEXIONES DEL ZOCALO. AL HACER LAS UNIONES ELÉCTRICAS.**  
**CONSIDER THE PHASES MARKING IN THE TERMINAL ZONE OF THE FUSE RAIL HOLDER, WHEN DOING ELECTRIC UNIONS.**  
Вземете под внимание маркировката на фазите при съществуване на електрически контакт.



**4**  
**E CONECTAR LOS CABLES UTILIZANDO HERRAMIENTA AISLADA GB FASTEN THE CABLE LUGS BY USING AN ISOLATED TOOL**


**B** В При монтажа кабелите и при оставяните монтажни операции използвайте изолирани инструменти и защитни средства



M10 - 32 Nm  
M12 - 40 Nm




E Pronites no se hace responsable de cualquier daño causado por un uso incorregido de este producto. / GB Pronites is not responsible for any damage caused by a wrong use of this product. / В Pronites не носи отговорност за всички щети, причинени от неправилно използване на този продукт.



1305


**INTRODUCCION / EXTRACCION DEL FUSIBLE  
INSTALLING / REMOVAL OF FUSE**  
Инсталиране и смяна на предпазителя




**E INSERTAR LOS FUSIBLES Y  
CERRAR LA TAPA  
GB INSERT THE FUSES AND  
CLOSE THE COVERS**  
В Поставяне  
предпазителята и  
затваряете капачицата

**E EXTRACCION DEL FUSIBLE  
GB REMOVAL OF FUSE**  
В Смяна на предпазителя


**ON / OFF. MANIOBRAR RAPIDAMENTE!  
ON / OFF. MOVE LEVER QUICKLY!**  
Дв се включва и изключва бързо!




**PRESENCIA DE TENSION  
VOLTAGE MEASUREMENT**  
Измерване на напрежение




**INSTALACION DE SALIDA AUXILIAR PROTEGIDA POR FUSIBLE  
INSTALLING A PROTECTED AUXILIARY OUTPUT**  
Монтаж на спомогателен изолиран изход



**BLOQUEO DE CANDADO LOCKING DEVICE** Заключващо устройство



**ASA ESCAMOTEABLE BTVC-E / RETRACTABLE HANDLE BTVC-E/**  
Прибираща се ръкохватка за BTVC-E/



TRIMER+			
CARACTERISTICAS ELECTRICAS/MECANICAS ELECTRICAL/MECHANICAL CHARACTERISTICS Технически данни и характеристики	250 A	400 A	630 A
INTENSIDAD NOMINAL Ie (A) RATED OPERATIONAL CURRENT Ie (A) / Номинален ток Ie (A)	250	400	630
TENSION NOMINAL Ue (V) RATED OPERATIONAL VOLTAGE Ue (V) / Номинално напрежение Ue (V)	690	690	690
TENSION DE AISLAMIENTO Ui (V) WITH ISOLATION VOLTAGE Ui (V) / Номинално изолационно напрежение Ui (V)	1000	1000	1000
TENSION DE FRECUENCIA INDUSTRIAL TEST VOLTAGE 50 Hz (kV) / Асинхронно напрежение 50 Hz (kV)	10	10	10
Entre polos activos y masa - 1 min. Between phases and earth - 1 min. Entre polos activos - 1 min. Between phases - 1 min.	3.5	3.5	3.5
Entre polos activos - 1 minuto Between phases - 1 min.	20	20	20
TENSION ONDA DE CHOQUE Uimp (kV) SURGE VOLTAGE Uimp (kV) / Импулсно напрежение Uimp (kV)	>50	>50	>50
Capacidad de corte (kA) Corte de carga (kA) / Изолационна способност (kA)	>5	>5	>5
Capacidad de corte (kA) Corte de carga (kA) / Изолационна способност (kA)	800	800	800
Capacidad de corte (kA) Corte de carga (kA) / Изолационна способност (kA)	200	200	200
CATEGORIA DE EMPLEO UTILIZATION CATEGORY / Категория на приложение	AC23B / AC23B AC23R / AC23R AC23B / AC23B	AC23B / AC23B AC23R / AC23R AC23B / AC23B	AC23B / AC23B AC23R / AC23R AC23B / AC23B
Grado de protección PROTECTION DEGREE / Степен на защита	IP-30	IP-30	IP-30


IP43801-BLG-B0



1406

ПРИЛОЖЕНИЕ

**“ЕЛПРОМ ЕМЗ” ООД град ШАБЛА**



ТЕЛЕФОНИ ЗА КОНТАКТИ :  
Управител 05743 / 45 - 68  
Пласмент 05743 / 42 - 84  
Факс/тел.секретар 05743 / 50 - 20  
[www.elpromemz.dir.bg](http://www.elpromemz.dir.bg)  
E-mail : [elpromemz@mbox.infotel.bg](mailto:elpromemz@mbox.infotel.bg)

**ФИРМЕН ПРОФИЛ  
НА “ЕЛПРОМ ЕМЗ” ООД град ШАБЛА**

**ОБЩА ИНФОРМАЦИЯ ЗА „ЕЛПРОМ ЕМЗ“ ООД град Шабла:**

“ЕЛПРОМ ЕМЗ” ООД град Шабла е регистрирано по ф.д. № 481/1991 година при Добрички окръжен съд като правопреемник на ДФ “Елпром София и ДФ “Елпром АВН” град Добрич.


**ПРОИЗВОДСТВО:** “ЕЛПРОМ ЕМЗ” ООД град Шабла има за свой предмет на дейност :

**1.Производство и реализация на токови измерителни трансформатори** за НН до 1 кV и СрН до 24 кV за вътрешен монтаж с клас на точност 0.2; 0.2S; 0.5; 0.5S и 5P10 и номинална мощност до 50VA в диапазона от номинални токове от 5/5/5A до 3000/5/5A съгласно БДС EN 60044-1:2001 и IEC 60044-1:1999. Произвеждат се следните типове токови измервателни трансформатори:

1. тип СТ-1; тип СТ-2; тип СТ-3; тип СТ-4 са с най-високо работно напрежение до 1 кV
2. тип 7.2СТ-1;тип 7.2СТ-2; тип 7.2СТ-3 са с най-високо работно напрежение до 7.2 кV.
3. тип 7.2СТ-1 PR; тип 7.2СТ-2 PR; тип 7.2СТ-3 PR – трансформатори с външно превключване на първичната намотка с най-високо работно напрежение до 7.2 кV.
4. тип 12СТ-1; тип 12СТ-2; тип 12СТ-3 - са с най-високо работно напрежение до 12 кV.
5. тип 12СТ-1 PR; тип 12СТ-2 PR; тип 12СТ-3 PR – трансформатори с външно превключване на първичната намотка с най-високо работно напрежение до 12 кV.
6. тип 24СТ-1; тип 24СТ-2; тип 24СТ-3 - са с най-високо работно напрежение до 24 кV.
7. тип 24СТ-1 PR; тип 24СТ-2 PR; тип 24СТ-3 PR – трансформатори с външно превключване на първичната намотка с най-високо работно напрежение до 24 кV

08.2.2012 г.

1407



“ЕЛПРОМ ЕМЗ” ООД град ШАБЛА, БУЛГАРИЯ, УЛИЦА БЪЛГАРИЯ, ШАБЛА, БУЛГАРИЯ  
ПРОИЗВОДСТВО НА ТОКОВИ ИЗМЕРВАТЕЛНИ ТРАНСФОРМАТОРИ

2. През 2002 година започнахме да произвеждаме ТОКОВИ ТРАНСФОРМАТОРИ ТИП "ФЕРАНТИ" за номинално напрежение до 24 KV и честота 50 Hz за вътрешен монтаж на кабели.

Произвеждаме три типа трансформатори :  
Тип FER-1 за монтаж на кабел с диаметър до 30 мм ;  
Тип FER-2 за монтаж на кабел с диаметър до 40 мм ;  
Тип FER-3 за монтаж на кабел с диаметър до 80 мм.

3. През 2002 година започнахме да произвеждаме също и БЪРЗОНАСИЩАЩИ СЕ ТОКОВИ ТРАНСФОРМАТОРИ ТИП SBP-1 за номинално работно напрежение до 24 KV и честота 50 Hz за вътрешен монтаж използвани в релейните защити.

4. "ЕЛПРОМ ЕМЗ" ООД ГРАД ШАБЛА ПРОИЗВЕЖДА ГАМА ЕДНОФАЗНИ МАСЛЕНИ ТРАНСФОРМАТОРИ ЗА СТЬЛБОВ МОНТАЖ Тип 1ТМ20/□3/0.23-20Си и Тип 2ТМ20/20/0.23-Си с номинални мощности съответно 0.5 кVA, 1 кVA, 2 кVA, 5 кVA, 10 кVA, 16 кVA, 20 кVA, 25 кVA, 40 кVA и 50 кVA, номинално работно напрежение на намотка ВН 20 кV и с номинално работно напрежение на намотка НН 0.23 кV. Предназначен за използване в енергийните системи, като понижаващ трансформатор, за захранване на мрежи НН с общо предназначение

МОНТАЖ НА ТРАНСФОРМАТОРА : Трансформаторите са пригодени за открит стълбов монтаж. Трансформаторът може да бъде монтиран или на предварително подготвена площадка закрепена на метален решетъчен стълб или направо върху бетонният или дървен стълб. Закрепването в този случай към стълба става посредством две метални скоби, предвидено е закрепващите скоби в зависимост от диаметъра на стълба да се регулират в рамките на диаметър от 80 до 330 мм.

КЪМ ГАМА МОНОФАЗНИ МАСЛЕНИ ТРАНСФОРМАТОРИ Тип 1ТМхх/□3/0.23-20Си и Тип 2ТМхх/20/0.23-Си при желание на КЛИЕНТА ПРЕДЛАГАМЕ - еднофазен или двуфазен разединител за открит стълбов монтаж от серията РОМ за номинално напрежение 20 кV и номинален ток 200А, окомплектовани с хибридна стойка за високоволтови предпазители за открит монтаж на 20 кV и с катодни отводници за 20 кV 10кА в комплект с високоволтови предпазители за напрежение 20 кV и РЛЗ.

Имаме разработка на АВТОМАТИЧЕН СТЬПАЛЕН РЕГУЛАТОР НА НАПРЕЖЕНИЕ към ГАМАТА ЕДНОФАЗНИ МАСЛЕНИ ТРАНСФОРМАТОРИ ЗА СТЬЛБОВ МОНТАЖ Тип 2ТМ20/20/0.23-Си, който гарантира стабилно изходно напрежение 220 V при колебание на входното напрежение 20кV в границите на -20% до +10%.

5. "ЕЛПРОМ ЕМЗ" ООД гр. ШАБЛА извършва цялостен или частичен основен ремонт на силови маслени високоволтови трансформатори с мощност от 25 KVA до 1250 KVA включително на 20 KV, 10 KV или 6 KV.

От 2000 година " ЕЛПРОМ ЕМЗ " ООД град Шабла започна да предлага за продажба на клиенти свои налични заводски рециклирани трифазни силови, маслени, високоволтови трансформатори с мощност от 160 KVA до 1000 KVA на 20 KV, 10 KV и на 6 KV, като дава 12 месеца гаранция на продаваните трансформатори.

През 2003 година " ЕЛПРОМ ЕМЗ " ООД град Шабла започна да произвежда и да продава НОВИ трифазни, силови, маслени, високоволтови трансформатори с мощност от 25 KVA до 100 KVA на 20 KV, 10 KV или на 6 KV, като дава 18 месеца гаранция на продаваните трансформатори.

Произвеждат се следните мощности /25, 40, 50, 63, 100 KVA/.



6. “ ЕЛПРОМ ЕМЗ “ ООД град Шабла произвежда сухи трансформатори за електрозадвижване с високомоментни постоянно - токови двигатели с номинална мощност от 0.25кVA до 20 кVA отговарящи на изискванията на ОН 0470427-84, те са комплектовъчни изделия в електрозадвижвания с високомоментни постояннотокови двигатели, които се използват в металорежещите машини, робототехниката и други.


7. “ ЕЛПРОМ ЕМЗ “ ООД град Шабла произвежда монофазни и трифазни дросели с ВЪЗДУШНА МЕЖДИНА и номинална мощност до 400kVAR , които са комплектовъчни изделия в уредбите за компенсиране на cosφ. Произвеждат се и дросели с номинална индуктивност до 1.5 H и номинален ток до 100 A отговарящи на изискванията на ОН 0477415-87, които са комплектовъчни изделия за електрозадвижвания с високомоментни постояннотокови двигатели за задвижване на металорежещи машини, работи и други.

8. “ЕЛПРОМ ЕМЗ “ ООД град Шабла произвежда трансформатори еднофазни и трифазни изпълнени по заявка или по заявка и конструктивна документация на клиента отговарящи на нормативни документи посочени от клиента.


на основание чл. 2 от ЗЗЛД

УПРАВИТЕЛ

/ ии



1409





# "ЕЛПРОМЕМЗ" ООД ГРАД ШАБЛА

ГАМА ТОКОВИ ИЗМЕРВАТЕЛНИ ТРАНСФОРМАТОРИ НН ТИП СТ-1; СТ-2, СТ-3 И СТ-4

И. П. ФОНН ЗА КОНТАКТИ:  
 Управител: 05743745-18  
 Технически: 05743742-84  
 Тел. Офис: 05743741-84  
 Факс/Телексертир: 05743750-20  
 E-mail: elpromemz@mbx.infotel.bg





таблица 1.



Тип Type	Преводно отношение Ipn/Isn Rated current ratio A/A	Най-високо работно напрежение Rated voltage power network kV	Клас на точност Class of accuracy %	Номинална мощност Sn Rated power VA	Номинален ток на терм. устойчивост Rated short-time thermal stability Ith, kA	Номинален ток на дин. устойчивост Rated short-time dynamic stability Idyn, kA	Номинален коефициент на безоп. for apparatus Fs	Заводски шифър Serial number
1	2	3	4	5	6	7	8	9
СТ-1 първич и вторич	30/5	0,72	0,2; 0,5; 0,5S	5; 10	60 Ipn	2,5 Ith	5; 10	1210302 - XXXX
	50/5	0,72	0,2; 0,5; 0,5S	5; 10	60 Ipn	2,5 Ith	5; 10	1210502 - XXXX
	75/5	0,72	0,2; 0,5; 0,5S	5; 10	60 Ipn	2,5 Ith	5; 10	1210732 - XXXX
	100/5	0,72	0,2; 0,5; 0,5S	5; 10	60 Ipn	2,5 Ith	5; 10	1211002 - XXXX
	150/5	0,72	0,2; 0,5; 0,5S	5; 10	60 Ipn	2,5 Ith	5; 10	1211502 - XXXX
СТ-2 шина 30x10 40x10 кабел ф36	160/5	0,72	0,5	5	60 Ipn	2,5 Ith	5; 10	1221505 - XXXX
	200/5	0,72	0,5	5	60 Ipn	2,5 Ith	5; 10	1222005 - XXXX
	250/5	0,72	0,5	5	60 Ipn	2,5 Ith	5; 10	1222505 - XXXX
	300/5	0,72	0,5	6	60 Ipn	2,5 Ith	5; 10	1223005 - XXXX
СТ-3 шина 30x10 40x10 ф36	300/5	0,72	0,2; 0,5; 0,5S	5; 10	60 Ipn	2,5 Ith	5; 10	1233005 - XXXX
	400/5	0,72	0,2; 0,5; 0,5S	5; 10	60 Ipn	2,5 Ith	5; 10	1234005 - XXXX
	500/5	0,72	0,2; 0,5; 0,5S	5; 10	60 Ipn	2,5 Ith	5; 10	1235005 - XXXX
	600/5	0,72	0,2; 0,5; 0,5S	5; 10	60 Ipn	2,5 Ith	5; 10	1236005 - XXXX
СТ-3 шина 50x10 ф46	800/5	0,72	0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	1235005 - XXXX
	600/5	0,72	0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	1236005 - XXXX
	750/5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	1237005 - XXXX
	800/5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	1238005 - XXXX
СТ-4 за шина 80x10 или кабел ф75	300/5	0,72	0,5; 0,5S	5	60 Ipn	2,5 Ith	5; 10	1243005 - XXXX
	400/5	0,72	0,5; 0,5S	5	60 Ipn	2,5 Ith	5; 10	1244005 - XXXX
	500/5	0,72	0,5; 0,5S	5	60 Ipn	2,5 Ith	5; 10	1245005 - XXXX
	600/5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	1246005 - XXXX
	750/5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	1247005 - XXXX
	800/5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	1248005 - XXXX
	1000/5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	1249005 - XXXX
	1200/5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	12412005 - XXXX
	1250/5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 Ipn	2,5 Ith	5; 10	12412505 - XXXX
	1500/5	0,72	0,2; 0,5; 0,5S	5; 10; 16	60 Ipn	2,5 Ith	5; 10	12415005 - XXXX

*[Handwritten signature]*


*[Large handwritten signature]*

410





(http://elpromemz.bg/wp-content/uploads/2015/09/DS\_22.jpg)



(http://elpromemz.bg/wp-content/uploads/2015/09/DS\_32.jpg)

SHARE IT (HTTP://WWW.FACEBOOK.COM/SHARE.PHP?U=<URL>)

TWEET IT (HTTP://TWITTER.COM/HOME/?STATUS=ТИП СТ-4 · HTTP://ELPROMEMZ.BG/PORTFOLIO/%D1%82%D0%BF-%D1%81%D1%82-4)

## ТИП СТ-4

Категория: НН (<http://elpromemz.bg/portfolio-category/nn/>)

### ТОКОВИ ИЗМЕРВАТЕЛНИ ТРАНСФОРМАТОРИ НН

Токови измервателни трансформатори за НН тип СТ-4

са преходни трансформатори за вътрешен монтаж с една вторична намотка с клас на точност 0.2, 0.5, 0.5S и номинална мощност от 5 VA, 10 VA и 15 VA в диапазона на номинални токове от 750/5, 800/5, 1000/5, 1200/5, 1250/5 и 1500/5 A и максимално работно напрежение 0.72kV. Отговарят на изискванията на БДС EN 61869-2:2012, БДС EN 60044-1:2001.

Одобрени от БИС с удостоверения за одобрен тип средство за измерване №05 04.4547 от 03.04.2006 година.

Скрий

Технически характеристики на Тип СТ-4

обхват 750/5A, 800/5A, 1000/5A, 1200/5A, 1250/5A, 1500/5A

1 Номинално напрежение - 0.72 KV

2 Честота - 50 Hz

3 Номинален първичен ток I<sub>pn</sub> - 750, 800, 1000, 1200, 1250, 1500 A

4 Номинален вторичен ток I<sub>sn</sub> - 5 A

5 Клас на точност - 0.2, 0.5, 0.5S

6 Номинална мощност - 5, 10, 15 VA

7 Ток на термична устойчивост - 60 x I<sub>pn</sub>

8 Ток на динамична устойчивост - 2.5 x I<sub>pn</sub>

9 Маса - 0.920 до 1.00 kg

10 Изпълнение - суха, клас на топлоустойчивост B

Условия на работа

<http://elpromemz.bg/portfolio/%d1%82%d0%bf-%d1%81%d1%82-4/>

27.11.2017



1411

Товарите трансформатори ниско напрежение се монтират на закрито при температура на околната среда от -350 С до +450 С и височина над морското равнище до 1000м

Стандартизирани документи ; Изделието отговаря на БДС EN 51869-2 2012  
БДС EN 60044-1:2001 IEC 60044-1:1999

Габаритни размери ([http://elpromemz.bg/wp-content/uploads/2015/12/CT\\_4\\_HH\\_GABARITNI\\_RAZMERE.pdf](http://elpromemz.bg/wp-content/uploads/2015/12/CT_4_HH_GABARITNI_RAZMERE.pdf))

Удостоверения за одобрени типове. Схрий





Удостоверение (<http://elpromemz.bg/%D1%83%D0%B4%D0%BE%D1%81%D1%82%D0%BE%D0%B2%D0%B5%D1%80%D0%B5%D0%BD%D0%88%D0%B5%D0%B7%D0%B0-%D0%BD%D0%BD/>)

[% VIEW PROJECT](#)

### КАТАЛОГ ПРОДУКТИ

нашата продуктува гама

Е



*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

<http://elpromemz.bg/portfolio/%d1%82%d0%b8%d0%bc-%d1%81%d1%82-4/>

*Handwritten signature*





РЕПУБЛИКА БЪЛГАРИЯ  
Български институт по метрология  
REPUBLIC OF BULGARIA  
Bulgarian Institute of Metrology



**УДОСТОВЕРЕНИЕ  
ЗА ОДОБРЕН ТИП СРЕДСТВО ЗА ИЗМЕРВАНЕ**  
*Measuring Instrument Type-approval Certificate*


**№ 16.03.5100**

**Издадено на производител:** „ЕЛПРОМ ЕМЗ“ ООД, гр. Шабла, ул. Нефтяник № 38  
*Issued to manufacturer:*

**На основание на:** чл. 32, ал. 1 от Закона за измерванията (ДВ, бр. 46 от 2002 г., изм. бр. 88 от 05 г., изм. и доп. бр. 95 от 2005 г.)  
*In Accordance with:*

**Относно:** измервателен токов трансформатор тип СТ-х  
*In Respect of:*

**Знак за одобрен тип:**  
*Type Approval Mark:*



**Технически и метрологични характеристики:**  
*Technical and metrological characteristics:*

приложение, неразделна част от настоящето удостоверение за одобрен тип средство за измерване

**Срок на валидност:** 14.03.2026 г.  
*Valid until:*


**Вписва се в регистъра на одобрените за използване типове средства за измерване под №:** 5100  
*Reference №:*

**Дата на издаване на удостоверението за одобрен тип:** 14.03.2016 г.  
*Date:*

**И. Д. ПРЕДСЕДАТЕЛ:**  
Иван Ил

на основание чл. 2 от ЗЗЛД

страница 1 от 3



4413

**Приложение към удостоверение за одобрен тип № 16.03.5100**

Издадено на производител: „ЕЛПРОМ ЕМЗ“ ООД; гр. Шабла, ул. Нефтяник № 38

Относно: измервателен токов трансформатор тип СТ-х

**1. Описание на типа:**

Измервателните токови трансформатори тип СТ-х се използват за измерване и защита на електрически мрежи с максимално работно напрежение 0,72 kV.

Измервателните токови трансформатори тип СТ-1 се състоят от тороидален магнетопровод с първична и вторична намотки, поместени в кутия от пластмаса. Магнетопровода е направен от силициева ламарина, Му-метал или пермалой. Върху магнетопровода е намотана вторичната намотка равномерно по целия обем. Това осигурява ефективното магнитно взаимодействие на първичната и вторичната намотки. Броят на навивките на вторичната намотка се определя от отношението между първичния и вторичния номинален ток. Първична и вторична намотки са поместени в кутийка от пластмаса, изработена от пластмаса тип Tecomid NB40 NL E с клас на възпламеняемост съгласно IEC 707-V-0. Началото и края на вторичната намотка са изведени на клемите разположени в горната част на трансформатора и са защитени с прозрачна пластмасова капачка, която е отваряема и има възможност за пломбиране.


Измервателните токови трансформатори тип СТ-2, тип СТ-3 и тип СТ-4 са проходен тип, пригодени за монтаж за шина или за кабел. Състоят се от магнетопровод с вторична намотка и са поместени в пластмасова кутия, изработена от пластмаса тип Tecomid NB40 NL E с клас на възпламеняемост съгласно IEC 707-V-0.

Измервателните токови трансформатори тип СТ-х са предназначени за експлоатация на закрито, при надморска височина до 1000 m, температура на околната среда от минус 35 °C до 45 °C и относителна влажност до 70 %. Изолацията спрямо магнетопровода и намотките е суха, с клас на топлоустойчивост B.

При измервателните токови трансформатори тип СТ-х има възможност да се пломбира кутията на трансформатора с цел предотвратяване на неправомерен достъп до магнетопровода и намотките. Има възможност да се пломбира и капачката, която предпазва клемите на вторичната намотка на трансформатора.

**2. Технически и метрологични характеристики:**

Характеристики	Тип на трансформатора			
	СТ-1	СТ-2	СТ-3	СТ-4
Максимално работно напрежение, kV	0,72			
Честота, Hz	50			
Номинален първичен ток, A	30; 50; 75; 100; 150	100; 150; 200; 250; 300	400; 500; 600	750; 800; 1000; 1200; 1250; 1500; 1600; 2000; 2500; 3000
Клас на точност	0,2; 0,2S; 0,5; 0,5S	0,5; 0,5S	0,2; 0,2S; 0,5 0,5S	0,2; 0,2S; 0,5; 0,5S
Номинален вторичен ток, A	5			
Мощност, VA	5; 10	5; 10	5; 10; 15	5; 10; 15
Коефициент на сигурност, FS	FS5; FS10			







14/14

Приложение към удостоверение за одобрен тип № 16.03.5100


3. Типово означение: СТ-х (СТ-1; СТ-2; СТ-3; СТ-4)

4. Описание на местата, предназначени за поставяне на знаци от метрологичен контрол:

- 1 - Знак за одобрен тип;
- 2 - Знак за първоначална проверка (марка за залепване).



0415



страница 3 от 3





РЕПУБЛИКА БЪЛГАРИЯ  
Български институт по метрология  
REPUBLIC OF BULGARIA  
Bulgarian Institute of Metrology



**УДОСТОВЕРЕНИЕ**  
**ЗА ОДОБРЕН ТИП СРЕДСТВО ЗА ИЗМЕРВАНЕ**  
Measuring Instrument Type-approval Certificate

№ 16.03.5101

Издадено на производител: „ЕЛПРОМ ЕМЗ“ ООД, гр. Шабла, ул. Нефтяник № 38  
Issued to manufacturer:


На основание на:  
In Accordance with:

чл. 32, ал. 1 от Закона за измерванията (ДВ, бр. 46 от 2002 г., изм. бр. 88 от 05 г., изм. и доп. бр. 95 от 2005 г.)

Относно:  
In Respect of:

измервателен токов трансформатор тип ХХСТ-х РР

Знак за одобрен тип:  
Type Approval Mark:



Технически и метрологични характеристики:  
Technical and metrological characteristics:

приложение, неразделна част от настоящото удостоверение за одобрен тип средство за измерване

Срок на валидност:  
Valid until:

14.03.2026 г.

Вписва се в регистъра на одобрените за използване типове средства за измерване под №:  
Reference №:

5101


Дата на издаване на удостоверението за одобрен тип:  
Date:

14.03.2016 г.

на основание чл. 2 от ЗЗЛД

И. Д. ПРЕДСЕД

Пълн. длъжност



1416

**Приложение към удостоверение за одобрен тип № 16.03.5101**

**Издадено на производител:** „ЕЛПРОМ ЕМЗ“ ООД; гр. Шабла, ул. Нефтяник № 38

**Относно:** измервателен токов трансформатор тип ххСТ-х PR

**1. Описание на типа:**

Измервателните токови трансформатори тип ххСТ-х PR се използват за измерване и защита на електрически мрежи с максимално работно напрежение 7,2 kV; 12 kV и 24 kV.

Измервателните токови трансформатори тип ххСТ-1 са с тороидален магнитопровод с една първична и две вторични намотки, които могат да бъдат за измерване или за защита в произволна комбинация.

Измервателните токови трансформатори тип ххСТ-2 са с тороидален магнитопровод с една първична и една вторична намотка за измерване.

Измервателните токови трансформатори тип ххСТ-3 са с тороидален магнитопровод с една първична и една вторична намотка за защита.

Измервателните токови трансформатори тип ххСТ-4 са с тороидален магнитопровод с една първична и три вторични намотки, които могат да бъдат за измерване или за защита в произволна комбинация.

Измервателните токови трансформатори тип ххСТ-5 са с тороидален магнитопровод с една първична и четири вторични намотки, които могат да бъдат за измерване или за защита в произволна комбинация.

Измервателните токови трансформатори тип ххСТ-хPR са с тороидален магнитопровод с външно превключване на първичната или вторичната намотка.

Изоляцията на измервателните токови трансформатори тип ххСТ-х PR между магнитопровода и намотките е суха със силикон.

Измервателните токови трансформатори тип ххСТ-хPR са предназначени за експлоатация на закрито, при надморска височина до 1000 m, температура на околната среда от минус 35 °C до 45 °C.

При измервателните токови трансформатори тип ххСТ-хPR има възможност да се plombира както кутията на трансформатора, с цел предотвратяване на неправомерен достъп до магнитопровода и намотките, така и plombиране на капачката, която предпазва клемите на вторичната намотка на трансформатора.

**2. Технически и метрологични характеристики:**

Характеристика	Тип на трансформатора					
	ххСТ-1	ххСТ-2	ххСТ-3	ххСТ-4	ххСТ-5	ххСТ-хPR
Максимално работно напрежение, kV	7,2; 12; 24					
Честота, Hz	50					
Номинален първичен ток, A	от 5 до 3000					
Номинален вторичен ток, A	1; 5					
Клас на точност: - измервателна намотка - защитна намотка	0,2; 0,2S; 0,5; 0,5S; 5P10; 5P20; 10P10; 10P20;	0,2; 0,2S; 0,5; 0,5S	5P10; 5P20; 10P10; 10P20;	0,2; 0,2S; 0,5; 0,5S; 5P10; 5P20; 10P10; 10P20;	0,2; 0,2S; 0,5; 0,5S; 5P10; 5P20; 10P10; 10P20;	0,2; 0,2S; 0,5; 0,5S; 5P10; 5P20; 10P10; 10P20;
Мощност, VA	5; 10; 15; 30; 40; 50					
Коефициент на сигурност, FS	5; 10					

*Handwritten signature and scribbles over the table.*

*Handwritten signature at the bottom left.*

*Handwritten signature and scribbles at the bottom center.*

1417






Приложение към удостоверение за одобрен тип № 16.03.5101

3. Типово означение: ххСТ-х PR;

хх	СТ	х	PR
7,2 kV 12 kV 24 kV	Токов трансформатор	1 - Две вторични намотки за измерване или защита в произволна комбинация; 2 - Една вторична намотка за измерване; 3 - Една вторична намотка за защита; 4 - Три вторични намотки за измерване или защита в произволна комбинация; 5 - Четири вторични намотки за измерване или защита в произволна комбинация.	Трансформатор с външно превключване на първичната или на вторичната намотка

4. Описание на местата, предназначени за поставяне на знаци от метрологичен контрол:

- 1 - Знак за първоначална проверка (марка за залепване);
- 2 - Знак за одобрен тип.



*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*


*[Handwritten signature]*

418

ИНТЕРНИ  
ПРОЦЕДУРИ



# “ЕЛПРОМ ЕМЗ” ООД град ШАБЛА



**ТЕЛЕФОНИ ЗА КОНТАКТИ:**

Управител 05743 / 45 - 68  
 Гл.счетоводител 05743 / 42 - 84  
 Търг. Отдел 05743 / 41 - 84  
 Факс/тел.секретар 05743 / 50 - 20  
 E-mail : elpromemz@mbox.infotel.bg

## ТЕХНИЧЕСКО ОПИСАНИЕ

**ГАМА ТОКОВИ ИЗМЕРВАТЕЛНИ ТРАНСФОРМАТОРИ**  
 тип СТ-1, СТ-2, СТ-3 и СТ-4 за НН до 1000V  
 ПРОИЗВОДСТВО НА " ЕЛПРОМ ЕМЗ " ООД град ШАБЛА

Токови измервателни трансформатори тип СТ-1; тип СТ-2, тип СТ-3 и тип СТ-4 са за ниско напрежение до 1000V за вътрешен монтаж с клас на точност 0.2; 0.5 или 0.5S и номинална мощност до 50VA в диапазона от номинални токове до 3000A съгласно БДС EN 60044-1:2001 и IEC 60044-1:1999.

■ Тип СТ-1 се състои от тороидален магнитопровод с първична и вторична намотки, поместени в кутийка от пластмаса изработена от пластмаса тип Rosap - B4235 с клас на възпламеняемост съгласно IEC 707 - V-0.

Произвежданите токови трансформатори са в диапазона от 30/5 A до 150/5 A с клас на точност 0.2, 0.5 или 0.5S с мощност 5VA и 10VA.

○ Тип СТ-2 Тип, СТ-3 и Тип СТ-4 са проходни типове токови измервателни трансформатори пригодени съответно за шина или кабел - състоят се от тороидален магнитопровод с вторична намотка, поместени в кутийка от пластмаса изработена от пластмаса тип Rosap - B4235 с клас на възпламеняемост съгласно IEC 707 - V-0.

Произвежданите токови трансформатори са в диапазона от 150/5A до 2000/5A с клас на точност 0.5 или 0.5S и мощност 5VA; 10VA и 15VA.

07.2.2012 г.



ТЕХНИЧЕСКИ ДАННИ Тип СТ-1, Тип СТ-2, Тип СТ-3 и Тип СТ-4

Условия на работа: Токовете измервателни трансформатори за средно напрежение се монтират на закрито при температура на околната среда от -35С до +45С и височина над морското равнище до 1000м.

- |  |                  |
|--|------------------|
| 1. Номинално напрежение                                  | - до 0,75 KV     |
| 2. Честота   | - 50 Hz          |
| 3. Номинален първичен ток $I_{pn}$                       | - до 2000 A      |
| 4. Номинален вторичен ток $I_{sn}$                       | - 5 A            |
| 5. Клас на точност на ядрото за мерене                   | - 0,2, 0,5, 0,5S |
| 6. Номинална мощност                                     | - 5, 10, 15VA    |
| 7. Номинален ток на термична устойчивост $I_{th}$ , kA   | - 60 $I_{pn}$    |
| 8. Номинален ток на динамична устойчивост $I_{dyn}$ , kA | - 2,5 $I_{th}$   |
| 9. Номинален коефициент на безопасност $F_s$             | - 5 или 10       |
| 10. Маса, в кг в зависимост от преводното отношение от   | - 0,485 до 1,070 |
| 11. Изолация - суха, клас на топлоустойчивост В          |                  |

Стандартизирани документи: Изделието отговаря на БДС EN 60044-1:2001 и IEC 60044-1:1999

При всичките произведени от " ЕЛПРОМ ЕМЗ " ООД град Шабла токови измервателни трансформатори е предвидена възможност за пломбиране както на кутията на трансформатора с цел предотвратяване на неправомерен достъп до магнитопровода и самите намотки, така и на предпазната капачка, която предпазва клемите на вторичната намотка на трансформатора.

на основание чл. 2 от ЗЗЛД

УПРАВИТЕЛ :

/ инж. Д. Димитров



Др. Г. Димитров: Д.

# БЪЛГАРСКИ ИНСТИТУТ ПО МЕТРОЛОГИЯ

Главна дирекция Мерки и измервателни уреди  
отдел "Изследване на типа на средства за измерване"  
сектор "Електрични величини"  
София, бул. Г.М.Димитров 52 Б, тел. 873-52-98

## ПРОТОКОЛ ОТ ИЗПИТВАНЕ

№ 19-ЕВ / 13.07.2006 г.

1. **Обект на изпитването:** Токов измервателен трансформатор тип СТ-Х
2. **Номер и дата на заявката:** АУ-03-654/27.06.2006 г.
3. **Заявител:** "ЕЛПРОМ - ЕМЗ" ООД гр. Шабла
4. **Производител:** "ЕЛПРОМ - ЕМЗ" ООД гр. Шабла
5. **Метод на изпитване:** БДС EN 60044-1 Измервателни трансформатори  
Част 1: Токови трансформатори.
6. **Период на изпитване:** 07.07.2006 г. до 14.07.2006 г.
7. **Изпитани образци:** ф. № 20218, 33063, 29967, 29477, 34805, 32820
8. **Описание на типа:**  
Гамата измервателни токови трансформатори тип СТ-х са за мрежи ниско напрежение.  
Токовите трансформатори тип СТ-1 се състоят от тороидален магнитопровод с първична и вторична намотка, а тип СТ-2, тип СТ-3 и тип СТ-4 са проходен тип трансформатори, пригодени за шина или кабел, с вторична намотка.

Резултатите в протокола се отнасят само за изпитваните образци.


на основание чл. 2 от ЗЗЛД

Началник отдел ИТСИ:

/инж. Хр. Соколова/

Протокола може да бъде разпечатван единствено и само с разрешение на началник отдел "Изследване на типа на средствата за измерване"

Върно с върната с образци  
1421



*Кричанова: 4*

**9. Технически и метрологични характеристики:**

Тип на трансформатора	СТ-1	СТ-2	СТ-3	СТ-4
Номинален първичен ток, А	30, 50, 75, 100,150	200, 250, 300	400, 500, 600	1200, 1250, 1500
Номинален вторичен ток, А	5			
Клас на точност	0,5 S			
Максимално работно напрежение, kV	0,72			
Честота, Hz	50			
Номинална мощност, VA	5, 10	5, 10	5, 10, 15	5, 10, 15

**10. Технически средства използвани при изпитването:**

10.1. Уредба за проверка на токови трансформатори тип АИТ ф. № 45/1972 с еталонен трансформатор тип Т1 50 ф. № 7210453, свидетелство за калибриране № 037- ЕЕИ/ 16.03.2005 год.

10.2. Уредба за изпитване на диелектрична якост тип РЕО 3/50 ф. № 671897308

10.3. Мегаометър тип Ф 41/2, ф. № 62862.

**11. Резултати от изпитванията:**

**11.1. Проверка на маркировката**

**11.1.1. Маркировка на изводите –**

Протоколи № 01÷ 03 /10.07.2006 г.  
Протоколи № 04÷ 06 /11.07.2006 г.  
Протокол № 12/12.07.2006 г.

БДС EN 60044-1  
т. 10.1.1 и 10.1.2

**11.1.2 Означение на полярностите –**

Протоколи № 01÷ 03 /10.07.2006 г.  
Протоколи № 04÷ 06 /11.07.2006 г.  
Протокол № 12/12.07.2006 г.

БДС EN 60044-1  
т. 10.1.3

**11.2. Маркировка на табелките с технически данни –**

Протоколи № 01÷ 03 /10.07.2006 г.  
Протоколи № 04÷ 06 /11.07.2006 г.  
Протокол № 12/12.07.2006 г.

БДС EN 60044-1  
т. 10.2 и т. 11.7

*Срещу*

*Съгласно с оригинала*

*1420*



*Приложение: 4.*

11.3. Проверка на диелектричната якост на първичната намотка – /3 kV за 60 s/

БДС EN 60044-1  
т. 5.1.4

Протоколи № 01÷ 03 /10.07.2006 г.  
Протоколи № 04÷ 06 /11.07.2006 г.  
Протокол № 12/12.07.2006 г.

11.4. Проверка на диелектричната якост на вторичната намотка – /3 kV за 60 s/

БДС EN 60044-1  
т. 5.1.4

Протоколи № 01÷ 03 /10.07.2006 г.  
Протоколи № 04÷ 06 /11.07.2006 г.  
Протокол № 12/12.07.2006 г.

11.5. Определяне грешките на трансформаторите –

БДС EN 60044-1  
т.11.2

Протоколи № 01÷ 03 /10.07.2006 г.  
Протоколи № 04÷ 06 /11.07.2006 г.  
Протокол № 12/12.07.2006 г.

11.6. Проверка – коефициент на безопасност -

БДС EN 60044-1  
т.11.6

Протоколи № 01÷ 03 /10.07.2006 г.  
Протоколи № 04÷ 06 /11.07.2006 г.

Присъствали на изпитването:

на основание чл. 2 от ЗЗЛД

Младши експерт: ..

/инж. Р. Малинова/

на основание чл. 2 от ЗЗЛД

Началник сектор "ЕВ":



/инж.Л. Сотирова/

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

1413



# "ЕЛПРОМ ЕМЗ" ООД град ШАБЛА

## ПАСПОРТ - СЕРТИФИКАТ

### ИЗПИТАТЕЛЕН ПРОТОКОЛ

За трансформатор токов измерителен лиско напрежение

Тип СТ - 4 обхват 800/5А, 1000/5А, 1200/5А

Заводски № 12410605 - хххх

1. Услови на работа: Токовите трансформатори ниско напрежение се монтират на закрито при температура на околната среда от  $-35^{\circ}\text{C}$  до  $+45^{\circ}\text{C}$  и височина над морското равнище до 1000м.

#### II. Технически данни:

1. Номинално напрежение	0.72 kV
2. Честота	50 Hz
3. Номинален първичен ток $I_{p1}$	800 : 1000 : 1200 A
4. Номинален вторичен ток $I_{p2}$	5 A
5. Клас на точност	0.5
6. Номинална мощност	5 VA
7. Ток на термична устойчивост	60 x $I_{p1}$
8. Ток на динамична устойчивост	2.5 x $I_{p1}$
9. Маса	0.9 : 1.0 : 1.1 кг
10. Използване	суха, клас на топлоустойчивост В

#### III. Създаващият документ: Именното отстояние на БДС EN 60044-1:2001;

IEC 60044-1:1999.

#### IV. Резултати от изпитанията:

- Проверка клас на точност: Отговора на клас на точност - 0.5
- Изпитание на изолацията между първичната и вторичната намотка с променливо напрежение 1 kV за 1 минута, извършено

V. Сертификат за качество: Настоящият сертификат за качество се дава въз основа на приемо - предавателния заводски изпитания от ... 2012 година.  
НАСТОЯЩИЯ ТИП ТОКОВ ИЗМЕРИТЕЛЕН ТРАНСФОРМАТОР Е ОДОБРЕН ОТ ДАМТИ С УДОСТОВЕРЕНИЕ № 4547 от 05.04.2006 година

VI. Компетентност на доставителя: Запасни части към изделието не се продаждат

#### ИНСТРУКЦИЯ ЗА МОНТАЖ И ЕКСПЛУАТАЦИЯ НА ТОКОВИ ИЗМЕРИТЕЛНИ ТРАНСФОРМАТОРИ ТИП СТ - 4

- Място на монтаж - на закрито.
- Изпитане на издръжливост: Първичната намотка на токовите трансформатори се свързва последователно към захранващите проволони на мотажна, а релетата и апаратите - последователно на вторичната намотка
- Експлуатационни условия на работата: При ползване на токовите трансформатори трябва да се спазват следните условия:

A) Трансформаторите да се монтират в закрити помещения.

## ПРИЛОЖЕНИЕ №5

В) Съединителите проволони да са свързани добре към източника и консуматора. Когато изолацията са на винтове, съединителните проволони трябва да се затегнат здраво между две месингови шайби или кабелна обука.

В) Токът, който се черпи от трансформатора, по специално молещостта на трансформатора, да не е по-голям от мощността, посочена на табелката. Преговарянето на трансформаторите се ограничава от допустимите температури на зареждане на изолациите.

Г) Токовите трансформатори трябва да работят при непрекъснат или периодичен контрол

Д) При обслужване на токовите трансформатори е задължително да се спазва следното условие:

**ПРИ ВКЛЮЧЕНА ВЪВ ВЕРИГАТА ПЪРВИЧНА НАМОТКА ВТОРИЧНАТА НАМОТКА НА ТРАНСФОРМАТОРА НЕ ТРЯБА ДА ОСТАВА ОТВОРЕНА!**

Когато се налага прекъсване на вторичната верига, вторичните клеми на трансформаторите трябва да се свържат на късо с проводник със сечение 2.5 кв. мм. Във вторичната верига на тока трансформатор провадите не се поставят.

Е) При работа на трансформатора елиминат извод на вторичната намотка със задочна.

4. Безопасност и хигиена на труда: За осигуряване на безопасна работа на обслужващия персонал е необходимо да се спазват следните условия:

A) Единият извод на вторичната намотка да се заключи

Б) При включване на първичната намотка във веригата, вторичната намотка да не е оставена отворена.

В) След извършване на монтажа на трансформаторите към табелта и уредите, върху клемите НИ на първичната намотка, да се постави предпазна капачка и да се plombира

Г) При ревизия на трансформаторите, електриците да не са под напрежение.

Д) При проверка на трансформаторите откъм ниската страна обслужващия персонал да работи с лични предпазни средства.

При добри условия на работа и при периодичен контрол, трансформаторите могат да работят продължително време без повреда.

5. Опаковка, транспорт и съхранение: Трансформаторите се поставят в специални кутии от картон. Имените Трансформатор се във всякаква вид транспортни средства

**ПРИ НЕСПАЗВАНЕ НА НАСТАВЛЕНИЯТА, ДАДЕНИ В НАСТОЯЩАТА ИНСТРУКЦИЯ, ЗАВОДЪТ ПРОИЗВОДИТЕЛ НЕ ПРИЕМА РЕКЛАМАЦИИ, НАПРАВЕНИ В ГАРАНЦИОННИЯ СРОК НА ИЗДЕЛИЕТО.**


## ГАРАНЦИОННА КАРТА

"ЕЛПРОМ ЕМЗ" ООД град Шабла се задължава да замени или ремонтира безвъзмездно токови измерителни трансформатори, които в продължение на 36 месеца от датата на продажбата им от завода, са показали дефекти или потребителът е констатирал несъответствия на трансформатора с изискванията на съответния стандарт.

Заменила или ремонтът се извършва при условие, че са спазени изискванията за транспорт, съхранение, монтаж и експлоатация, дадени от производителя в приложените документи и е запазен оригиналният паспорт - сертификат с гаранционната карта на трансформатора.

Дата на продажба  
" ЕЛПРОМ ЕМЗ" ООД




на основание чл. 2 от ЗЗЛД



4424


ПРИСЪЕДИНИТЕЛНИ РАЗМЕРИ ЗА ТОКОВИ ИЗМЕРВАТЕЛНИ ТРАНСФОРМАТОРИ

тип СТ-4 включващи преводните отношения 800/5А, 1000/5А, и 1200/5А




*[Handwritten signature]*

*[Handwritten signature]*  
425







31 110	31 123	31 273	31 274
--------	--------	--------	--------

## AMBUS®Panel

IEC-compatible holder for cylindrical fuses  
with box terminals, clip-on mounting, contact protection in accordance with DIN 50274

### AMBUS®Panel, holder for cylindrical fuses, standard model, without neutral conductor

Size	Rated current	Type	Width	Connection	Pack size	Weight kg/100 u.	Part no.
10x38	32A	1-pole	18	0.75 - 25mm <sup>2</sup> / AWG 18 - 4	12	5.2	31 110
		2-pole	36	0.75 - 25mm <sup>2</sup> / AWG 18 - 4	6	10.3	31 112
		3-pole	54	0.75 - 25mm <sup>2</sup> / AWG 18 - 4	4	15.5	31 113
14x51	50A	1-pole	27	1.5 - 35mm <sup>2</sup> / AWG 14 - 2	6	9.7	31 115
		2-pole	54	1.5 - 35mm <sup>2</sup> / AWG 14 - 2	3	20.2	31 117
		3-pole	81	1.5 - 35mm <sup>2</sup> / AWG 14 - 2	2	30.4	31 118
22x58	100A	1-pole	36	4 - 50mm <sup>2</sup> / AWG 10 - 1/0	6	15.8	31 120
		2-pole	72	4 - 50mm <sup>2</sup> / AWG 10 - 1/0	3	32.2	31 122
		3-pole	108	4 - 50mm <sup>2</sup> / AWG 10 - 1/0	2	48.6	31 124

### AMBUS®Panel, holder for cylindrical fuses, standard model, neutral conductor on the right

10x38	32A	1-pole+N	36	0.75 - 25mm <sup>2</sup> / AWG 18 - 4	6	11.3	31 126
		3-pole+N	72	0.75 - 25mm <sup>2</sup> / AWG 18 - 4	3	21.7	31 127
14x51	50A	1-pole+N	54	1.5 - 35mm <sup>2</sup> / AWG 14 - 2	3	21.8	31 128
		3-pole+N	108	1.5 - 35mm <sup>2</sup> / AWG 14 - 2	1	42.7	31 129
22x58	100A	1-pole+N	72	4 - 50mm <sup>2</sup> / AWG 10 - 1/0	3	35.8	31 130
		3-pole+N	144	4 - 50mm <sup>2</sup> / AWG 10 - 1/0	1	67.5	31 131

### AMBUS®Panel, holder for cylindrical fuses, standard model, neutral conductor on the left

14x51	50A	3-pole+N	108	1.5 - 35mm <sup>2</sup> / AWG 14 - 2	1	42.7	31 132
22x58	100A	3-pole+N	144	4 - 50mm <sup>2</sup> / AWG 10 - 1/0	1	67.5	31 133


### AMBUS®Panel, holder for cylindrical fuses, N-module

10x38	32A	N	18	0.75 - 25mm <sup>2</sup> / AWG 18 - 4	12	6.2	31 134
-------	-----	---	----	---------------------------------------	----	-----	--------

### AMBUS®Panel, holder for cylindrical fuses, standard model, with integrated neutral conductor (on the left)


10x38	32A	1-pole+N	18	1.5 - 10mm <sup>2</sup>	12	9.0	31 135
		3-pole+N	54	1.5 - 10mm <sup>2</sup>	4	22.0	31 136

*Handwritten signature*  
КОРПУС СОРТИМЕНТА




Accessories	7 15-1/
Technical data	8 24
Dimensions	9 41,4


31 115 - 31 119  
 31 135 - 31 138  
 31 168  
 31 278 - 31 280



31 120 - 31 124  
 31 140 - 31 143  
 31 171  
 31 281 - 31 283





	a	b	c	d
31 940	27			96
31 941			81	96
31 942	36			118
31 943			108	118
31 957		72		118
31 972		54		96





wöhner


	a	b	c	d	e	f		a	b	Полюс	Дивизион	
01 198	42	32	68	23	6.5	4		31 012	17	16	3	27
01 228	42	32	91	23	6.5	4		31 014	5	15	1	27
31 028	17	26	37	20	6	2		31 024	5	15	1	27
31 029	17	26	49	20	6	2		31 056	30	15	3	27
31 039	21	29	42	16	6.5	3		31 057	6	26	1	27
31 085	20	26	53	17	6	2		31 101	5	15	1	18
31 103	13	18	45	17	4	2		31 102	18	16	3	18
31 157	13	17	50	13	4	2		31 309	5	15	1	40
31 550	21	29	60	16	6.5	3		31 310	17	16	3	40
								31 311	5	15	1	50
								31 312	17	16	3	50
								31 548	5	15	1	18
								31 549	23	22	3	18
								31 561	23	22	2	18




31 555	a
31 570	30
31 572	20



- 31 110 - 31 114
- 31 130 - 31 133
- 31 258
- 31 273 - 31 277
- 31 295 - 31 300
- 31 929 - 31 930
- 31 971
- 31 973
- 31 974



wöhner



## AMBUS® Panel Holder for cylindrical fuses 10 x 38, 14 x 51, 22 x 58



1, 2- and 3-pole, 1 and 3-pole + N as required  
 IFD: 12 - 72V AC/DC resp. 110 - 690V AC/DC resp. 400 - 1000V DC

1 Pilot switch:  
 1 changeover switch 250V AC (5A), 30V DC (4A)  
 1 lat lug 2.8x0.5mm (e.g. DIN 46 245)

Clip-on mounting on EN 60715 mounting rail

### Conductor terminals:


Size	Conductor terminals according to IEC		Conductor terminals according to IEC UL / CSA	
10x38	1x Cu 0.75 - 25mm <sup>2</sup>	f, f+AE	1x AWG 18 - AWG 4	str
	2x Cu 0.75 - 10mm <sup>2</sup> *	f, f+AE	2x AWG 18 - AWG 6 *	str
Integrated N-pole	1x Cu 1.5 - 10mm <sup>2</sup>	f, f+AE		
14x51	1x Cu 1.5 - 35mm <sup>2</sup>	f, f+AE	1x AWG 14 - AWG 2	str
22x58	1x Cu 4 - 50mm <sup>2</sup>	f, f+AE	1x AWG 10 - AWG 1/0	str

\* 2 identical conductors next to each other in the contact position

Overall size		10 x 38 PV	10 x 38	14 x 51	22 x 58
According to standard	IEC/EN	IEC 60269-2	IEC 60947-3, EN 60947-3, VDE 0660 part 107		
	UL/CSA	UL 4248-1, 4248-18	UL 4248-1		
Current type		DC	AC (50/60Hz)/DC	AC (50/60Hz)/DC	AC (50/60Hz)/DC
Maximum rated operating voltage (U <sub>e</sub> )	IEC/EN	1000V DC	690V AC	690V AC	690V AC
	UL/CSA	1000V DC	600V AC/DC	600V AC/DC	600V AC/DC
Rated insulation voltage (U <sub>i</sub> )	IEC/EN	1000V DC	800V	800V	800V
Rated surge withstand capacity (U <sub>imp</sub> )	IEC/EN	6kV	6kV	6kV	6kV
Rated operating current (I <sub>e</sub> )	IEC/EN	30A	32A	50A	100A
	UL/CSA	30A	30A	50A/40A	80A
Application category, version 1P, 1P+N, 2P	IEC/EN	-	AC-22B (400V)	AC-22B (400V)	AC-20B (690V)
	UL/CSA		only applicable as fuse holder		
Application category, version 3P, 3P+N	IEC/EN	-	AC-22B (690V)	AC-21B (690V)	AC-20B (690V)
	UL/CSA		only applicable as fuse holder		
Conditional rated short-circuit current (AC) version 1P, 1P+N, 2P	IEC/EN	20kA**	100kA (500V)*	100kA (400V)*	100kA (500V)*
	UL/CSA	33kA	100kA (600V)	100kA (600V)	100kA (600V)
Conditional rated short-circuit current (AC) version 3P, 3P+N	IEC/EN	-	100kA (500V)*	100kA (400V)*	100kA (500V)*
	UL/CSA		100kA (600V)	100kA (600V)	100kA (600V)
Allowable power dissipation for each fuse, standard version			3W (gC)	5W (gC)	9.5W (gC)
Allowable power dissipation for each fuse, semi-conductor protection version		4.0W (gPV)	4.3W (aR/gR) (10mm <sup>2</sup> , 25A)	6.5W (aR/gR) (25mm <sup>2</sup> , 40A)	11W (aR/gR) (50mm <sup>2</sup> , 80A)

\* Type tested with fuses of characteristic gI/gC (IEC 60269-2)

\*\* Type tested with fuses of characteristic gPV (IEC 60269-6)



# EC Conformity Declaration

**wöhner**  
Sales/Marketing

Manufacturer: Wöhner GmbH & Co. KG  
Address: Mönchrödener Str. 10  
D - 96472 Rödentel

Product designation: **NH fuse-switch disconnectors**  
**Switch disconnectors with fuses D0 or 10x38**  
**Fuse-switch disconnectors for cylindrical fuses**

The designated product(s) conform(s) to the provisions of the following European directive:

Number: 73/23/EWG

Text: Directive of the Council for Adapting the Legislative Provisions of the member states concerning electric equipment for application within determined voltage limits modified by RL 93/68/EWG

For further information about compliance with this directive, see annex.

Attachment of the CE-marking: 96

Issuer: **Wöhner GmbH & Co. KG**

Place, date: Rödentel, 15.05.2003

Legally binding signature:

на основание чл. 2 от ЗЗЛД

на основание чл. 2 от ЗЗЛД



Alex Büttner  
Managing Director

Holger Schulte  
Marketing & Sales

The annex is part of this declaration.

This declaration certifies the conformance with the mentioned directives, but it does not include any assurances of definite properties.

Please pay special attention to the safety regulations of the delivered product documentation.



## Декларация за съответствие

Производител: WÖHNER GmbH и Co KG

Адрес: ул. Mönchrödener 10

D-96472 Rödental

Обозначение на продукта: NH предпазител-разединител

Разединител със предпазители D0 или 10x38

Разединител с цилиндрични предпазители

Конструираният продукт(и) отговаря на разпоредбите на следната европейска директива:

Номер: 73/23/EWG

Текст: Директива на Съвета за адаптиране на законовите разпоредби на държавите-членки относно електрическото оборудване за прилагане в определени граници на напрежение модифициран от RL 93/68/EWG

За допълнителна информация съгласно тази директива , виж анекс.

Прикрепване на маркировката "CE" 96



Емитент: WÖHNER GmbH и Co KG

Място, дата: Rödental, 15.05.2003

Правно обвързващ подпис:

Alex Büttner  
Управляващ директор

Holger Schulte  
Маркетинг и продажби







Ref. Certif. No.

DE1-49452

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product  
Produit

Fuse-switch-disconnector

Name and address of the applicant  
Nom et adresse du demandeur

Wöhner GmbH & Co. KG Elektrotechnische Systeme  
Mönchrödener Straße 10, 96472 Rödental  
GERMANY

Name and address of the manufacturer  
Nom et adresse du fabricant

Wöhner GmbH & Co. KG Elektrotechnische Systeme  
Mönchrödener Straße 10, 96472 Rödental  
GERMANY

Name and address of the factory  
Nom et adresse de l'usine

Wöhner GmbH & Co. KG Elektrotechnische Systeme  
Mönchrödener Straße 10, 96472 Rödental  
GERMANY

Note: When more than one factory, please report on page 2  
Note: Lorsque il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Additional information on page 2  
Utilization category: AC-21B, AC-22B  
Rated voltage: 400 V, 500 V, 690 V a.c.  
Rated current: 10 A, 25 A, 32 A

Trademark (if any)  
Marque de fabrique (si elle existe)

**wöhner**

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais constructeur

Model / Type Ref.  
Ref. De type

AES 10x38

Additional information (if necessary may also be reported on page 2)  
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2<sup>ème</sup> page)

Numbers of poles: 1/2/3-pol. and 1/3-pol.+Neutral

Additional information on page 2

PUBLICATION


EDITION

A sample of the product was tested and found to be in conformity with  
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 60947-1(ed.5);am1:2010-12  
IEC 60947-3(ed.3)

As shown in the Test Report Ref. No. which forms part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

249800-4402-0705/152633



This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

VDE Prüf- und Zertifizierungsinstitut GmbH  
VDE Testing and Certification Institute  
Zertifizierungsstelle / Certification

на основание чл. 2 от ЗЗЛД

Date: 2011-12-13

Signature:

M. Bausch

## Списък на отделните изпитвания на български език

### Изследван образец:

Разединител с цилиндрични предпазители н.н. 32А ,10х38 , еднополюсен и триполюсен, тип AES 10х38

### Производител:



WÖHNER GmbH, Германия

### Изпълнени тестове съгласно IEC/EN 60947-3

- 1) Маркировка на апаратурата
- 2) Инструкция за монтаж и експлоатация
- 3) Материали и конструкция
- 4) Устойчивост на топлина и огън
- 5) Минимални разстояния
- 6) Задвижващо устройство
- 7) Изолация
- 8) Посока на задвижване
- 9) Индикация на позицията на контакта
- 10) Допълнителни изисквания за безопасност
- 11) Допълнителни конструктивни изисквания
- 12) Клеми , проверка за мех. якост
- 13) Възможност за присъединяване
- 14) Идентификация и маркировка на клемите

#### *Тест глава I: Общи експлоатационни характеристики*

- 1) Покачване на температурата
- 2) Проверка на диелектричните свойства
- 3) Включваща и изключваща способност
- 4) Поведение на апаратурата по време включване и изключване
- 5) Състояние след теста за включване и изключване
- 6) Ток на утечка
- 7) Зависими и независими ръчни операции
- 8) Сила на задвижващия механизъм





***Тест глава II: Способност за оперативна дейност***



- 1) Тест –оперативна ефективност
- 2) Включване и изключване без товар
- 3) Включване и изключване с товар
- 4) Поведение на апаратурата по време тест за оперативна ефективност
- 5) Състояние на апаратурата след теста за включвателна и изключвателна способност.
- 6) Ток на утечка
- 7) Проверка на диелектричните характеристики
- 8) Тест -повишаване на температурата

***Тест глава III: Не се използва***

***Тест глава IV: Условен ток на късо съединение***

- 1) Защита с предпазител от късо съединение
- 2) Поведение на апарата по време теста
- 3) Състояние на апарата след тестове на включване и изключване
- 4) Диелектрични свойства
- 5) Ток на утечка
- 6) Проверка на температурата






Test Report issued under the responsibility of:





<b>TEST REPORT</b> <b>IEC 60947-3</b> <b>Low-voltage switchgear and controlgear</b> <b>Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units</b>	
Report Reference No. ....	249800-4402-0705/152633
Date of issue.....	2011-12-12
Total number of pages .....	116
CB Testing Laboratory.....	VDE Prüf- und Zertifizierungsinstitut GmbH VDE Testing and Certification Institute
Address .....	Merianstraße 28 · 63069 Offenbach , Germany
Applicant's name.....	Wöhner GmbH & Co. KG Elektrotechnische Systeme
Address .....	Mönchrödener Straße 10, 96472 Rödental, Germany
<b>Test specification:</b>	
Standard .....	IEC 60947-3: 3 <sup>rd</sup> Edition (2008) in conjunction with IEC 60947-1: 5 <sup>th</sup> Edition (2007)
Test procedure .....	CB
Non-standard test method.....	N/A
Test Report Form No. ....	IEC60947_3B
Test Report Form(s) Originator .....	OVE
Master TRF .....	Dated 2009-08
<b>Copyright © 2009 Worldwide System for Conformity Testing and Certification of Electrical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.</b>	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.	
<b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b>	
Test item description .....	Fuse-switch-disconnector
Trade Mark .....	<b>wöhner</b>
Manufacturer .....	Wöhner GmbH & Co. KG Elektrotechnische Systeme
Model/Type reference.....	AES 10x38
Ratings .....	See page 6 and 7

Testreport-FG32-2-152633.DOC



<b>Testing procedure and testing location:</b>	
<input checked="" type="checkbox"/> <b>CB Testing Laboratory:</b>	<b>VDE Prüf- und Zertifizierungsinstitut GmbH</b> VDE Testing and Certification Institute
Testing location/ address .....	Merianstraße 28 , 63069 Offenbach , Germany
<input checked="" type="checkbox"/> <b>Associated CB Test Laboratory:</b>	<b>IPH Institut "Prüffeld für elektrische Hochleistungstechnik" GmbH</b>
Testing location/ address .....	Landsberger Allee 378 A , 12681 Berlin , Germany
Tested by (name + signature) .....	H. Schmidt
Approved by (+ signature) .....	T. Köhshölter
на основание чл. 2 от 33ЛД	
<input type="checkbox"/> Testing procedure: TMP	
Testing location/ address .....	
Tested by (name + signature) .....	
Approved by (+ signature) .....	
<input type="checkbox"/> Testing procedure: WMT	
Testing location/ address .....	
Tested by (name + signature) .....	
Witnessed by (+ signature) .....	
Approved by (+ signature) .....	
<input type="checkbox"/> Testing procedure: SMT	
Testing location/ address .....	
Tested by (name + signature) .....	
Approved by (+ signature) .....	
Supervised by (+ signature) .....	
<input type="checkbox"/> Testing procedure: RMT	
Testing location/ address .....	
Tested by (name + signature) .....	
Approved by (+ signature) .....	
Supervised by (+ signature) .....	

**Summary of testing:**

The tests are carried-out according to IEC 60947-1 (ed.5);am1:2010-12 and IEC 60947-3 (ed.3).

**Tests performed (name of test and test clause):**

**Testing location:**

**Clause 7.1 (Construction) .....**

**VDE Testing and Certification Institute**

**Test sequence I: .....**

**IPH Institut**

Sample No.1: AC-21B, 500 V, 25 A, 1-pole

see page 16 - 20

Sample No.2: AC-21B, 690 V, 10 A, 1-pole

see page 21 - 25

Sample No.3: AC-22B, 400 V, 32 A, 1-pole

see page 26 - 30

Sample No.4: AC-22B, 400 V, 32 A, 2-pole

see page 31 - 35

Sample No.5: AC-22B, 500 V, 25 A, 2-pole

see page 36 - 40

Sample No.6: AC-22B, 690 V, 10 A, 2-pole

see page 41 - 45

Sample No.7: AC-22B, 690 V, 32 A, 3-pole+N

see page 46 - 50

**Test sequence II: .....**

**IPH Institut**

Sample No.8: AC-21B, 500 V, 25 A, 1-pole

see page 51 - 52

Sample No.9: AC-21B, 690 V, 10 A, 1-pole

see page 53 - 54

Sample No.10: AC-22B, 400 V, 32 A, 1-pole

see page 55 - 56

Sample No.11: AC-22B, 400 V, 32 A, 2-pole

see page 57 - 58

Sample No.12: AC-22B, 500 V, 25 A, 2-pole

see page 59 - 60

Sample No.13: AC-22B, 690 V, 10 A, 2-pole

see page 61 - 62

Sample No.14: AC-22B, 690 V, 32 A, 3-pole+N

see page 63 - 64

**Test sequence IV: .....**

**IPH Institut**

Sample No.15: 400 V a.c., 100 kA, 1-pole  
(with fuse-link 32 A / 400 V)

see page 68 - 69

Sample No.16: 400 V a.c., 100 kA, 1-pole+N  
(with fuse-link 32 A / 400 V)



see page 70 - 71

Sample No.17: 400 V a.c., 100 kA, 2-pole  
(with fuse-link 32 A / 400 V)

see page 72 - 73

Sample No.18: 400 V a.c., 100 kA, 3-pole+N  
(with fuse-link 32 A / 400 V)

see page 74 - 75




**Summary of testing: (Continuation)**

The tests are carried-out according to IEC 60947-1 (ed.5);am1:2010-12 and IEC 60947-3 (ed.3).

Tests performed (name of test and test clause):	Testing location:
<b>Test sequence IV:</b> .....	<b>IPH Institut</b>
Sample No.19: 500 V a.c., 100 kA, 1-pole (with fuse-link 25 A / 500 V)	see page 76 - 77
Sample No.20: 500 V a.c., 100 kA, 1-pole+N (with fuse-link 25 A / 500 V)	see page 78 - 79
Sample No.21: 500 V a.c., 100 kA, 2-pole (with fuse-link 25 A / 500 V)	see page 80 - 81
Sample No.22: 500 V a.c., 100 kA, 3-pole+N (with fuse-link 25 A / 500 V)	see page 82 - 83
Sample No.23: 690 V a.c., 50 kA, 1-pole (with fuse-link 10 A / 690 V)	see page 84 - 85
Sample No.24: 690 V a.c., 50 kA, 1-pole+N (with fuse-link 10 A / 690 V)	see page 86 - 87
Sample No.25: 690 V a.c., 50 kA, 2-pole (with fuse-link 10 A / 690 V)	see page 88 - 89
Sample No.26: 690 V a.c., 50 kA, 3-pole+N (with fuse-link 32 A / 400 V)	see page 90 - 91
<b>Test sequence V:</b> .....	<b>IPH Institut</b>
Sample No.27: 690 V, 32 A, 1-pole (with fuse-link 32 A / 400 V)	see page 92 - 93
Sample No.28: 690 V, 32 A, 2-pole (with fuse-link 32 A / 400 V)	see page 94 - 95
Sample No.29: 690 V, 32 A, 3-pole+N (with fuse-link 32 A / 400 V)	see page 96 - 97.

**Summary of compliance with National Differences:**

Not applicable



Copy of marking plate

Front printing: (for example a single pole device)

# wöhner

## AES10x38

## 32A 10x38

## 31 110 1P




Side printing:


IEC 60947-3 AC-22B 32A 400V 50/60Hz Ui:AC800V

**CU**® US  
 30A 600V  
 Do not operate  
 under load

gG	32A	6 <sup>□</sup>	3,0W
aM	32A	6 <sup>□</sup>	1,2W
aR/gR	consult		


 IEC 60269 690V

18...4AWG  
 0.75...25mm<sup>2</sup>  
 Cu only.  
 75°C wire  
 PZ2 2,5Nm  
 22lb-in




When two conductors per terminal are used, only stranded wires of the same size within the range of 18-6AWG, may be used

Picture of the fuse-switch-disconnector: (for example a single pole device)



ИЗГОТОВИТЕЛ

TRF No. IEC60947\_3B



<b>Test item particulars</b> .....	
- method of operation .....	Dependent manual operation
- suitability for isolation .....	Suitable / not-suitable
- degree of protection .....	IP20
- number of poles.....	1; 2; 3; 1+N; 3+N
- kind of current.....	a.c.
- number of positions of the main contacts.....	2 (open and closed)
Rated and limiting values, main circuit:	
- rated operational voltage $U_e$ (V) .....	400 V a.c. 500 V a.c. 690 V a.c.
- rated insulation voltage $U_i$ (V) .....	800 V
- rated impulse withstand voltage $U_{imp}$ (kV) .....	6 kV
- conventional free air thermal current $I_{th}$ (A) .....	32 A
- conventional enclosed thermal current $I_{the}$ (A) .....	—
- rated operational current $I_e$ (A) .....	See utilization category
- rated uninterrupted current $I_u$ (A).....	See utilization category
- rated frequency (Hz).....	50/60 Hz
- utilization category.....	

	$U_e$ [V]	$I_e$ [A]	Number of poles
AC-21B	500	25 <sup>*)</sup>	1; 1+N
	690	10 <sup>*)</sup>	1; 1+N
AC-22B	400	32 <sup>*)</sup>	1; 2; 3; 1+N; 3+N
		25 <sup>*)</sup>	2; 3; 3+N
	500	32 <sup>*)</sup>	3; 3+N
		10 <sup>*)</sup>	2
690	32 <sup>*)</sup>	3; 3+N	

<sup>\*)</sup> Corresponding short circuit current: 50 kA  
<sup>\*\*)</sup> Corresponding short circuit current: 100 kA

Short-circuit characteristic:	
- rated short-time withstand current $I_{cw}$ (kA) .....	—
- rated short-time making capacity $I_{cm}$ (kA) .....	—
- rated conditional short-circuit current.....	50 kA; 100 kA (See utilization category)
Control circuits .....	—
Auxiliary circuits .....	—
Relays and releases .....	—

*[Handwritten signature]*

ЕДИНО С ОРИГИНАЛА

*[Handwritten signature]*  
 ИНЖЕНЕРНИ  
 ПЛОСДЪ  
 ЕАД

Co-ordination of short-circuit protective devices:

- kind of protective device.....: Fuse-links with cylindrical contact caps for fuse system F (size 10,3 x 38)  
 Rated currents: 10 A (gR),  
 25 A (gG) and  
 32 A (gG)

**Possible test case verdicts:**

- test case does not apply to the test object.....: N/A  
 - test object does meet the requirement.....: P (Pass)  
 - test object does not meet the requirement.....: F (Fail)

**Testing .....**

Date of receipt of test item .....: 2011-06  
 Date (s) of performance of tests .....: 2011-06 up to 2011-11

**General remarks:**

The test results presented in this report relate only to the object tested.  
 This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.  
 "(see appended table)" refers to a table appended to the report.

Throughout this report a comma (point) is used as the decimal separator.


**General product information:**

The fuse-switch-disconnectors of type AES10x38 are available for DIN-rail mounting with cable connection on the line and load side.

The cable connection is possible by screw terminals (box terminal connection).  
 The box terminal connection is suitable for cable cross-sections between 0,75mm<sup>2</sup> and 25mm<sup>2</sup>.

**Upon the tests of the making and breaking capacities and the performance under short-circuit conditions the distances between the metallic screen and the test items were 0 mm to the sides and 0 mm to the top.**



ENTPAC O OPIBETNAEA



*Mus*



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
5.2	MARKING		P
	Marking on equipment itself or on nameplate or nameplates attached to the equipment and legible from the front after mounting		—
	- indication of the open and closed position		P
	- suitability for isolation		P
	- disconnectors AC-20 and DC-20 only: marked "Do not operate under load"		N/A
	Marking on equipment not needed to be visible after mounting:		—
	- manufacturer's name or trademark	<b>wöhner</b>	P
	- type designation or serial number	AES 10x38	P
	- rated operational currents	10 A, 25 A, 32 A	P
	- rated operational voltage	400 V, 500 V, 690 V a.c.	P
	- utilization category	See page 6	P
	- rated frequency	50/60 Hz	P
	- manufacturer's claim for compliance with IEC 60947-3		P
	- degree of protection	IP20	P
	Marking on fuse-combination units:		—
	- fuse type	Fuse System F (size 10,3x38)	P
	- maximum rated current	32 A	P
	- power loss of the fuse-link	< 3 W	P
	Identification of terminals:		—
	- line terminals, unless connection is immaterial	Not labelled, free line and load connection choice	P
	- load terminals, unless connection is immaterial		P
	- neutral pole terminal		N/A
	- protective earth terminal		N/A
	Data in the manufacturer's published information:		—
	- rated insulation voltage	800 V	P
	- rated impulse withstand voltage for equipment suitable for isolation or when determined	6 kV	P
	- pollution degree, if different from 3	3	P <i>Am</i>
	- rated duty	uninterrupted	P
	- rated short-time withstand current and duration		N/A
	- rated short-circuit making capacity		N/A




IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	- rated conditional short-circuit current	50 kA, 100 kA	P
5.3	Instructions for installation, operation and maintenance		P
6	Normal service, mounting and transport conditions		P
7.1	CONSTRUCTIONAL AND PERFORMANCE REQUIREMENTS		P
7.1.2	Materials		P
7.1.2.2	Resistance to abnormal heat and fire		P
	Test performed on .....	- the equipment - sections taken from the equipment - samples of identical material	P
	Glow-wire test according to IEC 60695-2-10 and IEC 60695-2-11		—
	Parts made of insulating material necessary to retain current-carrying parts in position: test temperature 960 °C		P
	No visible flame and no sustained glowing		P
	Flames and glowing extinguish within 30 s		P
	No ignition of the tissue paper		P
	Parts of insulating material not necessary to retain current-carrying parts in position, even though in contact with them: test temperature 650 °C		P
	No visible flame and no sustained glowing		P
	Flames and glowing extinguish within 30 s		P
	No ignition of the tissue paper		P
7.1.3 of Part 1	Current-carrying parts and their connection		P
7.1.4	Clearances .....	see appended table 7.1.4 on page 103	P
	Creepage distances .....	see appended table 7.1.4 on page 103	P
	Pollution degree .....	3	—
	Comparative tracking index (V) .....	CTI 600 (housing) CTI 575 (actuator)	—
	Material group .....	II	—

TRF No. IEC60947\_3B

EMHO C OPMERATA


IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
7.1.5 of Part 1	Actuator		P
7.1.5.1	Insulation		—
	Actuator insulated from live parts for		—
	- rated insulation voltage	800 V	P
	- rated impulse withstand voltage	6 kV	P
	Actuator made of metal		—
	- connected to a protective conductor or provided with an additional insulation		P
	Actuator made of or covered by insulating material :		—
	- internal metal parts, which might become accessible in the event of an insulation failure, are also insulated from live parts for the rated insulation voltage		P
7.1.5.2	Direction of movement		P
	The direction of operation for actuators shall where applicable conform to IEC 60447		P
	There is no doubt of the "I" and "O" position and the direction of operation		P
7.1.6 of Part 1	Indication of contact position		P
7.1.6.1	Indicating means		N/A
7.1.6.2	Indication by the actuator		P
7.1.7	Additional safety requirements for equipment suitable for isolation		P
7.1.7.1	Additional constructional requirements		P
	- marking according to 5.2.1b		P
	- indication of the position of the contacts		N/A
	- construction of the actuating mechanism		P
	- minimum clearances across open contacts (see Table 13, Part 1) (mm) .....	2 mm	—
	- measured clearances (mm) .....	> 5,5 mm	P
	- test Uimp across gap (kV) .....	9,8 kV	P

ОБЪЕКТ С ОПИТОМ



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
7.1.7.2	Supplementary requirements for equipment with provision for electrical interlocking with contactors or circuit-breakers:		N/A
	Auxiliary switch is rated according to IEC 60947-5-1 (unless the equipment is rated AC-23)		N/A
	Time interval between opening of the contacts of the auxiliary contact and the contacts of the main poles: $\geq 20$ ms .....		—
	Measured time interval (ms) .....		N/A
	During the closing operation the contacts of the auxiliary switch closes after or simultaneously with the contacts of the main poles		N/A
7.1.7.3	Supplementary requirements for equipment provided with means for padlocking the open position:		N/A
	The locking means is so designed that it cannot be removed with the appropriate padlock(s) installed		N/A
	Test force F applied to the actuator in an attempt to operate to the closed position (N) .....		—
	Rated impulse withstand voltage (kV) .....		—
	Test Uimp on open main contacts at the test force		N/A
7.1.8 of Part 1	Terminals		P
7.1.8.1	All parts of terminals which maintain contact and carry current are of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections are such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals are so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminals do not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage is not reduced below the rated value	(see 8.2.4 below)	P


ОПЕРАТОРСКА



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.4	Mechanical properties of terminals (box terminal connection)		P
	Mechanical strength of terminals		P
	Maximum cross-sectional area of conductor (mm <sup>2</sup> )		—
	Diameter of thread (mm)	Screw M5	—
	Torque (Nm)	2,75 Nm (manufacturer indicates: 2 – 2,5 Nm)	—
	5 times on 2 separate clamping units		P
	Testing for damage to and accidental loosening of conductor (flexion test)		P
	Conductor of the smallest cross-sectional area (mm <sup>2</sup> )	0,75 mm <sup>2</sup>	—
	Number of conductor of the smallest cross section	1	—
	Diameter of bushing hole (mm)	6,5 mm	—
	Height between the equipment and the platen	260 mm	—
	Mass at the conductor(s) (kg)	0,4 kg	—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		P
	Pull-out test		P
	Force (N), applied for 1 min.	30 N	—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		P
	Conductor of the largest cross-sectional area (mm <sup>2</sup> )	25 mm <sup>2</sup>	—
	Number of conductor of the largest cross section	1	—
	Diameter of bushing hole (mm)	13 mm	—
	Height between the equipment and the platen	300 mm	—
	Mass at the conductor(s) (kg)	4,5 kg	—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		P
	Pull-out test		P
	Force (N), applied for 1 min.	135 N	—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		P

TRF No. IEC60947\_3B

ВЕРИМО С ОРИГИНАЛОМ





IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conductor of the largest and smallest cross-sectional area (mm <sup>2</sup> ) .....		—
	Number of conductor of the smallest cross section, number of conductor of the largest cross section ..		—
	Diameter of bushing hole (mm) .....		—
	Height between the equipment and the platen .....		—
	Mass at the conductor(s) (kg) .....		—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
	Pull-out test		N/A
	Force (N), applied for 1 min.....		—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
7.1.8.2	Connection capacity		P
	Type of conductors .....	Rigid, stranded or flexible	—
	Minimum cross-sectional area of conductor (mm <sup>2</sup> ) :	0,75 mm <sup>2</sup>	—
	Maximum cross-sectional area of conductor (mm <sup>2</sup> ) .....	25 mm <sup>2</sup>	—
	Number of conductors simultaneously connectable to the terminal .....		—
7.1.8.3	Connection		P
	Terminals for connection to external conductors are readily accessible during installation		P
	Clamping screws and nuts do not serve to fix any other component		P
7.1.8.4	Terminal identification and marking		P
	Terminal intended exclusively for the neutral conductor	Only if applicable	P
	Protective earth terminal		N/A
	Other terminals		P

ОБЪЕКТ С ОРИГИНАЛ



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
7.1.9	Additional requirements for equipment provided with a neutral pole		P
	Equipment provided with a pole intended for the connection of neutral, this pole shall be clearly marked by the letter "N"		P
	The switched neutral pole does not break before and does not make after the other poles except		N/A
	- a pole having the appropriate short-circuit breaking and making capacity is used as neutral pole, all poles may operate together	The connection is given by a dummy (piece of copper), which is inside the actuator.	P
	Conventional thermal current of neutral pole	32 A	P
7.1.10	Provisions for protective earthing		N/A
7.1.10.1	The exposed conductive parts are electrically interconnected and connected to a protective earth terminal		N/A
7.1.10.2	Protective earth terminal is readily accessible		N/A
	Protective earth terminal is suitably protected against corrosion		N/A
	Electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N/A
	Protective earth terminal has no other functions		N/A
7.1.10.3	Protective earth terminal marking and identification		N/A
7.1.11	Enclosure for equipment		N/A
7.1.11.1	Design		N/A
	When the enclosure is opened, all parts requiring access for installation and maintenance are readily accessible		N/A
	Sufficient space is provided inside the enclosure		N/A
	The fixed parts of a metal enclosure are electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N/A
	Under no circumstances a removable metal part of the enclosure is insulated from the part carrying the earth terminal when the removable part is in place		N/A
	The removable parts of the enclosure are firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N/A



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means is provided to prevent loss of the fastening devices		N/A
	If the enclosure is used for mounting push-buttons, it is not possible to remove the buttons from the outside of the enclosure		N/A
7.1.11.2	Insulation		N/A
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining is securely fixed to the enclosure		N/A
7.1.12	Degree of protection of enclosed equipment		N/A
	Degree of protection .....: IP		N/A
7.1.13	Conduit pull-out, torque and bending with metallic conduits		N/A
	Withstand the stress occurring during its installation .....: IP		N/A

ВЪРНО С ОРИГИНАЛА



*[Handwritten signature]*


*[Handwritten signature]*

*[Handwritten signature]*



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS (Sample No. 1: AC-21B, 500 V, 25 A, 1-pole)		P
8.3.3.1	Temperature-rise		P
	ambient temperature 10-40 °C .....	22,7 °C	—
	test enclosure W x H x D (mm x mm x mm) .....		—
	material of enclosure .....		—
	Main circuits, test conditions:		—
	- rated operational current $I_e$ (A) .....	25 A	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) .....	4 mm <sup>2</sup> cables / 1000 mm long	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page 103	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....		—
	- cable cross-section (mm <sup>2</sup> ) .....		—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page —	N/A
8.3.3.2	Test of dielectric properties		P
	Rated impulse withstand voltage (kV) .....	6 kV	—
	- test $U_{imp}$ main circuits (kV) .....	7,3 kV	P
	- test $U_{imp}$ auxiliary circuits (kV) .....		N/A
	- test $U_{imp}$ on open main contacts (equipment suitable for isolation) (kV) .....	9,8 kV	P
	Power-frequency withstand voltage (V) .....	800 V	—
	- main circuits, test voltage for 5 sec. (V) .....	2000 V	P
	- control and auxiliary circuits, test voltage for 5 sec. (V) .....		N/A


TRF No. IEC60947\_3B



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Devices, which have been disconnected for the power-frequency withstand voltage test.....		N/A
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V).....	550 V (tested with 759 V)	—
	Measured leakage current (mA).....	0,001 mA	P
8.3.3.3	Making and breaking capacity		P
	- utilization category .....	AC-21B	—
	- rated operational voltage Ue (V) .....	500 V	—
	- rated operational current Ie (A) or power (kW) .....	25 A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Conditions for make/break operations or make operation, AC-23A and AC-23B only:		N/A
	- test voltage, $U = 1,05 U_e$ .....	L1: L2: L3:	—
	- test current, $I = \dots \times I_e$ (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—
	Conditions for break operation, AC-23A and AC-23B only:		N/A
	- test voltage, $U = 1,05 U_e$ .....	L1: L2: L3:	—
	- test current, $I = \dots \times I_e$ (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—

TRF No. IEC60947\_3B

ПРОТОКОЛ ПРОВЕРКИ





IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditions for make/break operations, other than AC-23A/B:		P
	- test voltage, $U = 1,05 U_e$ ..... (V):	L1: 525 V L2: — L3: —	—
	- test current, $I =$ ..... $1,5 \times I_e$ (A):	L1: 38 A L2: — L3: —	—
	- power factor/ time constant .....	0,91	—
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms)	> 50 ms	P
	- current duration (ms) .....	70 ms	—
	- time interval between operations .....	30 s	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		N/A
	- oscillatory frequency (kHz) .....		—
	- measured oscillatory frequency (kHz) .....	L1: L2: L3:	N/A
	- factor $\gamma$ .....	L1: L2: L3:	N/A
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	13,2 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P

TRF No. IEC60947\_3B

ЗАДАЧА С ОЦЕНКА




IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.4	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	550 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories): $\leq 2$ mA/pole .....	< 2 mA	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	4 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	25 A	—
	Measured temperature-rise .....	see appended table 8.3.3.6 on page 103	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		—
	- actuator type (fig.) .....	figure 1b (one-finger operated)	—
8.2.5.2.1	Dependent and independent manual operation	dependent manual operation	P
	- actuating force for opening (N) .....	10,2 N	—
	- test force with blocked main contacts (N) .....	50 N	—
	- used method to keep the contact closed .....	Fuse links were held tight with a piece of wire	—
	During and after the test, open position not indicated .....		P
	Equipment with locking mean, no locking in the open position while test force is applied .....		P




IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- stored energy of the power operator released (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A

*[Handwritten signature]*



*[Handwritten signature]*




*[Handwritten signature]*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS (Sample No. 2: AC-21B, 690 V, 10 A, 1-pole)		P
8.3.3.1	Temperature-rise		P
	ambient temperature 10-40 °C .....	22,7 °C	—
	test enclosure W x H x D (mm x mm x mm) .....		—
	material of enclosure .....		—
	Main circuits, test conditions:		—
	- rated operational current I <sub>e</sub> (A) .....	10 A	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ..	1,5 mm <sup>2</sup> cables / 1000mm long	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page 104	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....		—
	- cable cross-section (mm <sup>2</sup> ) .....		—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page ___	N/A
8.3.3.2	Test of dielectric properties		P
	Rated impulse withstand voltage (kV) .....	6 kV	—
	- test U <sub>imp</sub> main circuits (kV) .....	7,3 kV	P
	- test U <sub>imp</sub> auxiliary circuits (kV) .....		N/A
	- test U <sub>imp</sub> on open main contacts (equipment suitable for isolation) (kV) .....	9,8 kV	P
	Power-frequency withstand voltage (V) .....	800 V	—
	- main circuits, test voltage for 5 sec. (V) .....	2000 V	P
	- control and auxiliary circuits, test voltage for 5 sec. (V) .....		N/A

TRF No. IEC60947\_3B

ВНЕШНЕГО ОПЫТА



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Devices, which have been disconnected for the power-frequency withstand voltage test .....		N/A
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V) .....	759 V	—
	Measured leakage current (mA) .....	0,001 mA	P
8.3.3.3	Making and breaking capacity.		P
	- utilization category .....	AC-21B	—
	- rated operational voltage Ue (V) .....	690 V	—
	- rated operational current Ie (A) or power (kW) ....	10 A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	Conditions for make/break operations or make operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—
	Conditions for break operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—

TRF No. IEC60947\_3B

*[Handwritten signature]*

249800-4402-0705/152633

*[Handwritten signature]*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditions for make/break operations, other than AC-23A/B:		P
	- test voltage, $U = 1,05 U_e$ ..... (V):	L1: 725 V L2: — L3: —	—
	- test current, $I =$ ..... $1,5 \times I_e$ (A):	L1: 15,3 A L2: — L3: —	—
	- power factor/ time constant .....	0,95	—
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms)	> 50 ms	P
	- current duration (ms) .....	70 ms	—
	- time interval between operations .....	30 s	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		N/A
	- oscillatory frequency (kHz) .....		—
	- measured oscillatory frequency (kHz) .....	L1: L2: L3:	N/A
	- factor $\gamma$ .....	L1: L2: L3:	N/A
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	17,6 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P

52713 СОРТНОВА





IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.4	Dielectric verification		P
	test voltage: 2*Ue with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 Ue) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): ≤ 0,5 mA/pole .....		N/A
	Leakage current (other utilization categories): ≤ 2 mA/pole) .....	< 2 mA	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	- conductor cross-section (mm²) .....	1,5 mm²	—
	- test current Ie (A) .....	10 A	—
	Measured temperature-rise .....	see appended table 8.3.3.6 on page 104	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		
	- actuator type (fig.) .....	figure 1b (one-finger operated)	—
8.2.5.2.1	Dependent and independent manual operation	dependent manual operation	P
	- actuating force for opening (N) .....	11 N	—
	- test force with blocked main contacts (N) .....	50 N	—
	- used method to keep the contact closed .....	Fuse-links were held tight with a piece of wire	—
	During and after the test, open position not indicated .....		P
	Equipment with locking mean, no locking in the open position while test force is applied .....		P


TRF No. IEC60947\_3B

5

6

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- stored energy of the power operator released (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A

РЕПНО С ОПИШОМ




*Handwritten signature*

*Handwritten signature*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS (Sample No. 3: AC-22B, 400 V, 32 A, 1-pole)		P
8.3.3.1	Temperature-rise		P
	ambient temperature 10-40 °C .....	22,7 °C	—
	test enclosure W x H x D (mm x mm x mm) .....		—
	material of enclosure .....		—
	Main circuits, test conditions:		—
	- rated operational current I <sub>e</sub> (A) .....	32 A	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ...	6 mm <sup>2</sup> cables / 1000mm long	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page 104	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....		—
	- cable cross-section (mm <sup>2</sup> ) .....		—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page ___	N/A
8.3.3.2	Test of dielectric properties		P
	Rated impulse withstand voltage (kV) .....	6 kV	—
	- test U <sub>imp</sub> main circuits (kV) .....	7,3 kV	P
	- test U <sub>imp</sub> auxiliary circuits (kV) .....		N/A
	- test U <sub>imp</sub> on open main contacts (equipment suitable for isolation) (kV) .....	9,8 kV	P
	Power-frequency withstand voltage (V) .....	800 V	—
	- main circuits, test voltage for 5 sec. (V) .....	2000 V	P
	- control and auxiliary circuits, test voltage for 5 sec. (V) .....		N/A

TRF No. IEC60947\_3B

27.05.2014




IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Devices, which have been disconnected for the power-frequency withstand voltage test .....		N/A
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V) .....	440 V (tested with 759 V)	—
	Measured leakage current (mA) .....	0,001 mA	P
8.3.3.3	Making and breaking capacity		P
	- utilization category .....	AC-22B	—
	- rated operational voltage Ue (V) .....	400 V	—
	- rated operational current Ie (A) or power (kW) ....	32 A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Conditions for make/break operations or make operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—
	Conditions for break operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—

DATE: 07.07.2014

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditions for make/break operations, other than AC-23A/B:		P
	- test voltage, $U = 1,05 U_e$ ..... (V):	L1: 420 V L2: — L3: —	—
	- test current, $I =$ ..... $3 \times I_e$ (A):	L1: 98 A L2: — L3: —	—
	- power factor/ time constant .....	0,66	—
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms)	> 50 ms	P
	- current duration (ms) .....	90 ms	—
	- time interval between operations .....	30 s	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		P
	- oscillatory frequency (kHz) .....	41,29 kHz	—
	- measured oscillatory frequency (kHz) .....	L1: 40,5 kHz L2: — L3: —	P
	- factor $\gamma$ .....	L1: 1,1 L2: — L3: —	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	8,4 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P

TRF No. IEC60947\_3B



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.4	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories): $\leq 2$ mA/pole) .....	< 2 mA	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.3.6 on page 105	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		—
	- actuator type (fig.) .....	figure 1b (one-finger operated)	—
8.2.5.2.1	Dependent and independent manual operation	dependent manual operation	P
	- actuating force for opening (N) .....	10,4 N	—
	- test force with blocked main contacts (N) .....	50 N	—
	- used method to keep the contact closed .....	Fuse-links were held tight with a piece of wire	—
	During and after the test, open position not indicated .....		P
	Equipment with locking mean, no locking in the open position while test force is applied .....		P


TRF No. IEC60947\_3B

ВЕРНО СОСТАВЛЕНА



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- stored energy of the power operator released (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A

БЕЗПЛОДНО С ОПАСНОСТТА



*Handwritten signature*

*Large handwritten signature*



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS (Sample No. 4: AC-22B, 400 V, 32 A, 2-poles)		P
8.3.3.1	Temperature-rise		P
	ambient temperature 10-40 °C .....	22,7 °C	—
	test enclosure W x H x D (mm x mm x mm) .....		—
	material of enclosure .....		—
	Main circuits, test conditions:		—
	- rated operational current I <sub>e</sub> (A) .....	32 A	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) .....	6 mm <sup>2</sup> cables / 1000mm long	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page 105	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....		—
	- cable cross-section (mm <sup>2</sup> ) .....		—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page 105	N/A
8.3.3.2	Test of dielectric properties		P
	Rated impulse withstand voltage (kV) .....	6 kV	—
	- test U <sub>imp</sub> main circuits (kV) .....	7,3 kV	P
	- test U <sub>imp</sub> auxiliary circuits (kV) .....		N/A
	- test U <sub>imp</sub> on open main contacts (equipment suitable for isolation) (kV) .....	9,8 kV	P
	Power-frequency withstand voltage (V) .....	800 V	—
	- main circuits, test voltage for 5 sec. (V) .....	2000 V	P
	- control and auxiliary circuits, test voltage for 5 sec. (V) .....		N/A

TRF No. IEC60947\_3B


PHOTO COPY PROHIBITED

*Mus*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Devices, which have been disconnected for the power-frequency withstand voltage test .....		N/A
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V) .....	440 V (tested with 759 V)	—
	Measured leakage current (mA).....	0,001 mA	P
8.3.3.3	Making and breaking capacity		P
	- utilization category .....	AC-22B	—
	- rated operational voltage Ue (V) .....	400 V	—
	- rated operational current Ie (A) or power (kW) .....	32 A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Conditions for make/break operations or make operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—
	Conditions for break operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—

TRF No. IEC60947\_3B


ВЕРИТЕЛЬНОСТЬ



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditions for make/break operations, other than AC-23A/B:		P
	- test voltage, $U = 1,05 U_e$ ..... (V):	L1: 420 V ( $242,5 V \times \sqrt{3}$ ) L2: 420 V ( $242,5 V \times \sqrt{3}$ ) L3: —	—
	- test current, $I =$ ..... $3 \times I_e$ (A):	L1: 98 A L2: 98 A L3: —	—
	- power factor/ time constant .....	0,66	—
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms)	> 50 ms	P
	- current duration (ms) .....	70 ms	—
	- time interval between operations .....	30 s	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		P
	- oscillatory frequency (kHz) .....	41,29 kHz	—
	- measured oscillatory frequency (kHz) .....	L1: 40,5 kHz L2: 40,5 kHz L3: —	P
	- factor $\gamma$ .....	L1: 1,1 L2: 1,1 L3: —	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	17,8 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P

TRF No. IEC60947\_3B

ПРОТОКОЛ С ОПИТИМАТА




*Handwritten signature*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.4	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories): $\leq 2$ mA/pole) .....	< 2 mA	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.3.6 on page 105	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		
	- actuator type (fig.) .....	figure 1b (one-finger operated)	—
8.2.5.2.1	Dependent and independent manual operation	dependent manual operation	P
	- actuating force for opening (N) .....	22 N	—
	- test force with blocked main contacts (N) .....	66 N	—
	- used method to keep the contact closed .....	Fuse-links were held tight with a piece of wire	—
	During and after the test, open position not indicated .....		P
	Equipment with locking mean, no locking in the open position while test force is applied .....		P

TRF No. IEC60947\_3B

ПРОТВО С ОПИШВАТА



mus

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- stored energy of the power operator released (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A


ВОПРОС О ПРОВЕРКЕ

ИНЖЕНЕРИ  
ПЛОДИБ  
ЕА

TRF No. IEC60947\_3B

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS (Sample No. 5: AC-22B, 500 V, 25 A, 2-pole)		P
8.3.3.1	Temperature-rise		P
	ambient temperature 10-40 °C .....	22,7 °C	—
	test enclosure W x H x D (mm x mm x mm) .....		—
	material of enclosure .....		—
	Main circuits, test conditions:		—
	- rated operational current $I_e$ (A) .....	25 A	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ..:	4 mm <sup>2</sup> cables / 1000 mm long	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page 106	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....		—
	- cable cross-section (mm <sup>2</sup> ) .....		—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page —	N/A
8.3.3.2	Test of dielectric properties		P
	Rated impulse withstand voltage (kV) .....	6 kV	—
	- test $U_{imp}$ main circuits (kV) .....	7,3 kV	P
	- test $U_{imp}$ auxiliary circuits (kV) .....		N/A
	- test $U_{imp}$ on open main contacts (equipment suitable for isolation) (kV) .....	9,8 kV	P
	Power-frequency withstand voltage (V) .....	800 V	—
	- main circuits, test voltage for 5 sec. (V) .....	2000 V	P
	- control and auxiliary circuits, test voltage for 5 sec. (V) .....		N/A


СЕРТИФИКАТ




IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Devices, which have been disconnected for the power-frequency withstand voltage test .....		N/A
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V) .....	550 V (tested with 759 V)	—
	Measured leakage current (mA) .....	0,001 mA	P
8.3.3.3	Making and breaking capacity		P
	- utilization category .....	AC-22B	—
	- rated operational voltage Ue (V) .....	500 V	—
	- rated operational current Ie (A) or power (kW) ....	25 A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Conditions for make/break operations or make operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—
	Conditions for break operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—

TRF No. IEC60947\_3B

КОПИО С ОРГАНИЗАТА




*Handwritten mark*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditions for make/break operations, other than AC-23A/B:		
	- test voltage, $U = 1,05 U_e$ ..... (V):	L1: 525 V (303 V x $\sqrt{3}$ ) L2: 525 V (303 V x $\sqrt{3}$ ) L3: —	—
	- test current, $I =$ ..... 3 x $I_e$ (A):	L1: 78 A L2: 78 A L3: —	—
	- power factor/ time constant .....	0,68	—
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms)	> 50 ms	P
	- current duration (ms) .....	70 ms	—
	- time interval between operations .....	30 s	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		P
	- oscillatory frequency (kHz) .....	32,88 kHz	—
	- measured oscillatory frequency (kHz) .....	L1: 32,2 kHz L2: 32,2 kHz L3: —	P
	- factor $\gamma$ .....	L1: 1,1 L2: 1,1 L3: —	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily	P	
	- required opening force not greater than the test force of 8.2.5.2 and table 8	20,4 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P

TRF No. IEC60947-3B

*Handwritten signature*

**ОБЪЕКТ**








IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.4	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	550 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories): $\leq 2$ mA/pole .....	$< 2$ mA	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	4 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	25 A	—
	Measured temperature-rise .....	see appended table 8.3.3.6 on page 106	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		
	- actuator type (fig.) .....	figure 1b (one-finger operated)	—
8.2.5.2.1	Dependent and independent manual operation	dependent manual operation	P
	- actuating force for opening (N) .....	22,6 N	—
	- test force with blocked main contacts (N) .....	67,8 N	—
	- used method to keep the contact closed .....	Fuse-links were held tight with a piece of wire	—
	During and after the test, open position not indicated .....		P
	Equipment with locking mean, no locking in the open position while test force is applied .....		P

TRF No. IEC60947\_3B

ВЕРНО С ОПИТОВАНА




IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- stored energy of the power operator released (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS (Sample No. 6: AC-22B, 690 V, 10 A, 2-pole)		P
8.3.3.1	Temperature-rise		P
	ambient temperature 10-40 °C .....	22,7 °C	—
	test enclosure W x H x D (mm x mm x mm) .....		—
	material of enclosure .....		—
	Main circuits, test conditions:		—
	- rated operational current I <sub>e</sub> (A) .....	10 A	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ..	1,5 mm <sup>2</sup> cables / 1000mm long	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page 106	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....		—
	- cable cross-section (mm <sup>2</sup> ) .....		—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page ___	N/A
8.3.3.2	Test of dielectric properties		P
	Rated impulse withstand voltage (kV) .....	6 kV	—
	- test U <sub>imp</sub> main circuits (kV) .....	7,3 kV	P
	- test U <sub>imp</sub> auxiliary circuits (kV) .....		N/A
	- test U <sub>imp</sub> on open main contacts (equipment suitable for isolation) (kV) .....	9,8 kV	P
	Power-frequency withstand voltage (V) .....	800 V	—
	- main circuits, test voltage for 5 sec. (V) .....	2000 V	P
	- control and auxiliary circuits, test voltage for 5 sec. (V) .....		N/A


TRF No. IEC60947\_3B



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Devices, which have been disconnected for the power-frequency withstand voltage test .....		N/A
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V) .....	759 V	—
	Measured leakage current (mA) .....	0,001 mA	P
8.3.3.3	Making and breaking capacity		P
	- utilization category .....	AC-22B	—
	- rated operational voltage Ue (V) .....	690 V	—
	- rated operational current Ie (A) or power (kW) ....	10 A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	Conditions for make/break operations or make operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue ..... (V):	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—
	Conditions for break operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue ..... (V):	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—

TRF No. IEC60947\_3B

СТІСНО С ОФІЦІАЛА




*Handwritten mark*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditions for make/break operations, other than AC-23A/B:		
	- test voltage, $U = 1,05 U_e$ ..... (V):	L1: 725 V ( $418,5 V \times \sqrt{3}$ ) L2: 725 V ( $418,5 V \times \sqrt{3}$ ) L3: —	—
	- test current, $I =$ ..... $3x I_e$ (A):	L1: 31 A L2: 31 A L3: —	—
	- power factor/ time constant .....	0,65	—
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms)	> 50 ms	P
	- current duration (ms) .....	80 ms	—
	- time interval between operations .....	30 s	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		P
	- oscillatory frequency (kHz) .....	21,15 kHz	—
	- measured oscillatory frequency (kHz) .....	L1: 21,0 kHz L2: 21,0 kHz L3:	P
	- factor $\gamma$ .....	L1: 1,1 L2: 1,1 L3:	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	22,5 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P

TRF No. IEC60947\_3B

ПРОЦЕДУРА



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.4	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories): $\leq 2$ mA/pole .....	< 2 mA	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	1,5 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	10 A	—
	Measured temperature-rise .....	see appended table 8.3.3.6 on page 107	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		
	- actuator type (fig.) .....	figure 1b (one-finger operated)	—
8.2.5.2.1	Dependent and independent manual operation	dependent manual operation	P
	- actuating force for opening (N) .....	24,4 N	—
	- test force with blocked main contacts (N) .....	73,2 N	—
	- used method to keep the contact closed .....	Fuse-links were held tight with a piece of wire	—
	During and after the test, open position not indicated .....		P
	Equipment with locking mean, no locking in the open position while test force is applied .....		P

РЕЗУЛТАТ НА ТЕСТА


IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- stored energy of the power operator released (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A

*Handwritten signature*

*Handwritten signature*



*Handwritten signature*


ВЪЗНЕСЕНО С ОРГАНИЗАЦИЯ



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS (Sample No. 7: AC-22B, 690 V, 32 A, 3-pole+N)		P
8.3.3.1	Temperature-rise		P
	ambient temperature 10-40 °C .....	22,7 °C	—
	test enclosure W x H x D (mm x mm x mm) .....		—
	material of enclosure .....		—
	Main circuits, test conditions:		—
	- rated operational current I <sub>e</sub> (A) .....	32 A	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ..	6 mm <sup>2</sup> cables / 1000mm long	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page 107	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....		—
	- cable cross-section (mm <sup>2</sup> ) .....		—
	Measured temperature-rise .....	see appended table 8.3.3.1 on page ___	N/A
8.3.3.2	Test of dielectric properties		P
	Rated impulse withstand voltage (kV) .....	6 kV	—
	- test U <sub>imp</sub> main circuits (kV) .....	7,3 kV	P
	- test U <sub>imp</sub> auxiliary circuits (kV) .....		N/A
	- test U <sub>imp</sub> on open main contacts (equipment suitable for isolation) (kV) .....	9,8 kV	P
	Power-frequency withstand voltage (V) .....	800 V	—
	- main circuits, test voltage for 5 sec. (V) .....	2000 V	P
	- control and auxiliary circuits, test voltage for 5 sec. (V) .....		N/A

TRF No. IEC60947\_3B








IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Devices, which have been disconnected for the power-frequency withstand voltage test .....		N/A
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V) .....	759 V	—
	Measured leakage current (mA) .....	0,001 mA	P
8.3.3.3	Making and breaking capacity		P
	- utilization category .....	AC-22B	—
	- rated operational voltage Ue (V) .....	690 V	—
	- rated operational current Ie (A) or power (kW) ....	32 A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Conditions for make/break operations or make operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—
	Conditions for break operation, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: L2: L3:	—
	- test current, I = ..... x Ie (A):	L1: L2: L3:	—
	- power factor .....	L1: L2: L3:	—

TRF No. IEC60947\_3B

СТВОРОВАНО



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditions for make/break operations, other than AC-23A/B:		
	- test voltage, $U = 1,05 U_e$ ..... (V):	L1: 725 V ( $418,5 V \times \sqrt{3}$ ) L2: 725 V ( $418,5 V \times \sqrt{3}$ ) L3: 725 V ( $418,5 V \times \sqrt{3}$ )	—
	- test current, $I =$ ..... $3 \times I_e$ (A):	L1: 99 A L2: 98 A L3: 100 A	—
	- power factor/ time constant .....	0,63	—
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms)	> 50 ms	P
	- current duration (ms) .....	70 ms	—
	- time interval between operations .....	30 s	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		P
	- oscillatory frequency (kHz) .....	26,69 kHz	—
	- measured oscillatory frequency (kHz) .....	L1: 27,5 kHz L2: 27,5 kHz L3: 27,5 kHz	P
	- factor $\gamma$ .....	L1: 1,1 L2: 1,1 L3: 1,1	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	46,2 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.4	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories): $\leq 2$ mA/pole) .....	< 2 mA	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.3.6 on page 107	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		
	- actuator type (fig.) .....	figure 1b (one-finger operated)	—
8.2.5.2.1	Dependent and independent manual operation	dependent manual operation	P
	- actuating force for opening (N) .....	41,2 N	—
	- test force with blocked main contacts (N) .....	123,6 N	—
	- used method to keep the contact closed .....	Fuse-links were held tight with a piece of wire	—
	During and after the test, open position not indicated .....		P
	Equipment with locking mean, no locking in the open position while test force is applied .....		P

TRF No. IEC60947\_3B


*Handwritten signature*

ПРАВО С ОВЕРНАТА

*Handwritten signature*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position:		N/A
	- used method to keep the contact closed .....		N/A
	- stored energy of the power operator released (3 times) .....		N/A
	During and after the test, open position not indicated .....		N/A
	Equipment show no damage impairing its normal operation .....		N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....		N/A

ΕΠΙΣΤΗΜΟΝΙΚΟ ΚΕΝΤΡΟ ΕΡΕΥΝΑΣ




*[Handwritten signature]*

*[Handwritten signature]*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY (Sample No. 8: AC-21B, 500 V, 25 A, 1-pole)		P
8.3.4.1	Operational performance test		P
	- utilization category .....	AC-21B	—
	- rated operational voltage (V) .....	500 V	—
	- rated operational current (A) .....	25 A	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 506 V L2: — L3: —	—
	- test current (A) .....	L1: 25,6 A L2: — L3: —	—
	- power factor/time constant .....	L1: 0,95 L2: — L3: —	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	Without current	—
	Second test sequence (with/without current) .....	With current	—
	- time interval between first and second test sequence .....	515 minutes	—
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P

ИЗДАНО С ОПРАВДАНИЯ




*[Handwritten signature]*

*[Handwritten signature]*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	11,2 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.4.2	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	550 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2$ mA/pole .....	< 2 mA	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	4 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	25 A	—
	Measured temperature-rise .....	see appended table 8.3.4.4 on page 108	P

ВЪРНО С ОПИТНАТА


*[Handwritten signature]*



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY (Sample No. 9: AC-21B, 690 V, 10 A, 1-pole)		P
8.3.4.1	Operational performance test		P
	- utilization category .....	AC-21B	—
	- rated operational voltage (V) .....	690 V	—
	- rated operational current (A) .....	10 A	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 690 V L2: — L3: —	—
	- test current (A) .....	L1: 10,2 A L2: — L3: —	—
	- power factor/time constant .....	L1: 0,95 L2: — L3: —	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	Without current	—
	Second test sequence (with/without current) .....	With current	—
	- time interval between first and second test sequence .....	1125 minutes	—
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P

TRF No. IEC60947\_3B


2012.06.07 14:10:10



Handwritten signature

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	8,0 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.4.2	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1380 V	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2$ mA/pole .....	0,005 mA	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	1,5 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	10 A	—
	Measured temperature-rise .....	see appended table 8.3.4.4 on page 108	P

ЗАТВОР С ОРИГИНАЛА




*Handwritten signature*



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY (Sample No. 10: AC-22B, 400 V, 32 A, 1-pole)		P
8.3.4.1	Operational performance test		P
	- utilization category .....	AC-22B	—
	- rated operational voltage (V) .....	400 V	—
	- rated operational current (A) .....	32 A	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 414 V L2: L3: —	—
	- test current (A) .....	L1: 32,1 A L2: L3: —	—
	- power factor/time constant .....	L1: 0,79 L2: L3: —	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	Without current	—
	Second test sequence (with/without current) .....	With current	—
	- time interval between first and second test sequence .....	315 minutes	—
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P

TRF No. IEC60947\_3B



ПРИЛОЖЕНИЕ



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	11,4 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.4.2	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2$ mA/pole .....	0,006 mA	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.4.4 on page 108	P




ВЕРНО КОПИРАНАТА

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY (Sample No. 11: AC-22B, 400 V, 32 A, 2-poles)		P
8.3.4.1	Operational performance test		P
	- utilization category .....	AC-22B	—
	- rated operational voltage (V) .....	400 V	—
	- rated operational current (A) .....	32 A	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 414 V (239 V x $\sqrt{3}$ ) L2: 414 V (239 V x $\sqrt{3}$ ) L3: —	—
	- test current (A) .....	L1: 32,2 A L2: 32,2 A L3: —	—
	- power factor/time constant .....	L1: 0,8 L2: 0,8 L3: —	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	Without current	—
	Second test sequence (with/without current) .....	With current	—
	- time interval between first and second test sequence .....	315 minutes	—
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P

TRF No. IEC60947\_3B


ИЗДАНО С ОПРАВОМ



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	21,4 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.4.2	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2$ mA/pole .....	0,006 mA	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.4.4 on page 109	P

TRF No. IEC60947\_3B


ΣΥΜΠΛΗΡΩΣΗ



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY (Sample No. 12: AC-22B, 500 V, 25 A, 2-poles)		P
8.3.4.1	Operational performance test		P
	- utilization category .....	AC-22B	—
	- rated operational voltage (V) .....	500 V	—
	- rated operational current (A) .....	25 A	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 510 V (294,4 V x $\sqrt{3}$ ) L2: 510 V (294,4 V x $\sqrt{3}$ ) L3:—	—
	- test current (A) .....	L1: 24,9 A L2: 24,9 A L3: —	—
	- power factor/time constant .....	L1: 0,78 L2: 0,78 L3: —	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	Without current	—
	Second test sequence (with/without current) .....	With current	—
	- time interval between first and second test sequence .....	315 minutes	—
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P



TRF No. IEC60947\_3B

ИСПИТО С ОРИГИНАЛА



mus


IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	21,6 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.4.2	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	550 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2$ mA/pole .....	< 2 mA	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	4 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	25 A	—
	Measured temperature-rise .....	see appended table 8.3.4.4 on page 109	P



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY (Sample No. 13: AC-22B, 690 V, 10 A, 2-poles)		P
8.3.4.1	Operational performance test		P
	- utilization category .....	AC-22B	—
	- rated operational voltage (V) .....	690 V	—
	- rated operational current (A) .....	10 A	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 690 V (398,4 V x √3) L2: 690 V (398,4 V x √3) L3:—	—
	- test current (A) .....	L1: 10 A L2: 10 A L3:—	—
	- power factor/time constant .....	L1: 0,78 L2: 0,78 L3:—	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	Without current	—
	Second test sequence (with/without current) .....	With current	—
	- time interval between first and second test sequence .....	315 minutes	—
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P

TRF No. IEC60947\_3B

БИРО С ОПЕКТАТА



*ms*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	21,8 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.4.2	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1380 V	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2$ mA/pole .....	0,008 mA	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	1,5 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	10 A	—
	Measured temperature-rise .....	see appended table 8.3.4.4 on page 109	P

TRF No. IEC60947\_3B

ИНЖЕНЕРИ  
ПЛОВДИВ  
БАН



ms



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY (Sample No. 14: AC-22B, 690 V, 32 A, 3-poles+N)		P
8.3.4.1	Operational performance test		P
	- utilization category .....	AC-22B	—
	- rated operational voltage (V) .....	690 V	—
	- rated operational current (A) .....	32 A	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 690 V (398,4 V × $\sqrt{3}$ ) L2: 690 V (398,4 V × $\sqrt{3}$ ) L3: 690 V (398,4 V × $\sqrt{3}$ )	—
	- test current (A) .....	L1: 33 A L2: 33 A L3: 33 A	—
	- power factor/time constant .....	L1: 0,8 L2: 0,8 L3: 0,8	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	Without current	—
	Second test sequence (with/without current) .....	With current	—
	- time interval between first and second test sequence .....	315 minutes	—
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P

ИЗДАНО С ОРИГИНАЛА

*[Handwritten signature]*



*[Handwritten signature]*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	44,6 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.4.2	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1380 V	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2$ mA/pole .....	0,01 mA	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.4.4 on page 110	P

ВЕРНО СОПРАВНАТА




TRF No. IEC60947\_3B

*[Handwritten signature]*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5	TEST SEQUENCE III: SHORT-CIRCUIT PERFORMANCE CAPABILITY		N/A
8.3.5.1	Short-time withstand current test		N/A
	Rated short-time withstand current $I_{cw}$ (A) ( $>12 \cdot I_e$ max) .....		N/A
	test voltage (V) .....	L1: L2: L3:	—
	r.m.s. test current (A) .....	L1: L2: L3:	—
	peak test current (A) .....	L1: L2: L3:	—
	power factor/time constant .....	L1: L2: L3:	—
	test duration (s) .....		—
8.3.5.1.5	Behaviour of the equipment during the test		N/A
	Test performed without:		—
	- endanger to the operator		N/A
	- cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.5.1.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A

TRF No. IEC60947\_3B

ПРОЕКТ  
С ОРИГИНАЛА




ИИ

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.2	Short-circuit making capacity		N/A
	Rated short-circuit making capacity $I_{cm}$ (A) .....		N/A
	test voltage ( $1.05 \times U_e$ ) ..... (V):	L1: L2: L3:	—
	r.m.s. test current (A) .....	L1: L2: L3:	—
	maximum peak test current (factor n)		N/A
	power factor/time constant .....	L1: L2: L3:	N/A
	current duration (s) .....		—
	Time interval between the cycles		—
8.3.5.2.5	Behaviour of the equipment during the test		N/A
	Test performed without:		—
	- endanger to the operator		N/A
	- cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.5.2.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A
8.3.5.3	Dielectric verification		N/A
	test voltage: $2 \times U_e$ with a minimum of 1000V~ .....		—
	No flashover or breakdown		N/A

TRF No. IEC60947\_3B

РЕЗУЛТАТЪТ Е ПОЛОЖИТЕЛЕН



Handwritten signature

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.4	Leakage current		N/A
	test voltage (1,1 Ue) (V) .....		—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....		N/A
8.3.5.5	Temperature-rise verification		N/A
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....		—
	- manufacturer's model or type reference .....		—
	- rated current (A) .....		—
	- power loss (W) .....		—
	- rated breaking capacity (kA) .....		—
	- conductor cross-section (mm <sup>2</sup> ) .....		—
	- test current I <sub>e</sub> (A) .....		—
	Measured temperature-rise .....	see appended table 8.3.5.5 on page __	N/A

TRF No. IEC60947\_3B

*[Handwritten signature]*

**ВЕРИТЕ С ОЧИМАТА**






*[Handwritten signature]*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 15: 400 V, 32 A, 1-pole)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated voltage (V) .....	400 V	—
	- rated current (A) .....	32 A (gG)	—
	- rated breaking capacity (kA) .....	120 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 420 V L2: — L3: —	—
	test current (kA) .....	L1: 101 kA L2: — L3: —	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,19	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 6,5 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 7000 A <sup>2</sup> s L2: — L3: —	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 4,94 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 5000 A <sup>2</sup> s L2: — L3: —	—

TRF No. IEC60947-3B

ВНЕШНЯЯ КОМПЕТЕНЦИЯ

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	8,7 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V- .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,008 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 110	P 



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 16: 400 V, 32 A, 1-pole+N)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated voltage (V) .....	400 V	—
	- rated current (A) .....	32 A (gG)	—
	- rated breaking capacity (kA) .....	120 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 420 V L2: — L3: —	—
	test current (kA) .....	L1: 101 kA L2: — L3: —	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,19	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 6,54 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 7000 A <sup>2</sup> s L2: — L3: —	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 3,7 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 4000 A <sup>2</sup> s L2: — L3: —	—



TRF No. IEC60947\_3B

ВЕРНО КОПИРОВАНО



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	24,8 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,002 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 111	P

TRF No. IEC60947 13B



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 17: 400 V, 32 A, 2-poles)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated voltage (V) .....	400 V	—
	- rated current (A) .....	32 A (gG)	—
	- rated breaking capacity (kA) .....	120 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 420 V (242,5 V x $\sqrt{3}$ ) L2: 420 V (242,5 V x $\sqrt{3}$ ) L3: —	—
	test current (kA) .....	L1: 101 kA L2: 101 kA L3: —	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,19	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		—
	- max. let-through current (kA) .....	L1: 6,35 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 5000 A <sup>2</sup> s L2: — L3: —	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 6,15 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 5000 A <sup>2</sup> s L2: — L3: —	—


TRF No. IEC60947\_3B

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	22 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,001 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 111	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 18: 400 V, 32 A, 3-poles+N)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated voltage (V) .....	400 V	—
	- rated current (A) .....	32 A (gG)	—
	- rated breaking capacity (kA) .....	120 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 420 V (242,5 V x $\sqrt{3}$ ) L2: 420 V (242,5 V x $\sqrt{3}$ ) L3: 420 V (242,5 V x $\sqrt{3}$ )	—
	test current (kA) .....	L1: 103 kA L2: 100 kA L3: 101 kA	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,19	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 0,4 kA L2: 4,8 kA L3: 4,8 kA	—
	- Joule integral $I^2dt$ (A <sup>2</sup> s) .....	L1: 0 A <sup>2</sup> s L2: 4000 A <sup>2</sup> s L3: 4000 A <sup>2</sup> s	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 1,6 kA L2: 4,2 kA L3: 4,4 kA	—
	- Joule integral $I^2dt$ (A <sup>2</sup> s) .....	L1: 0 A <sup>2</sup> s L2: 4000 A <sup>2</sup> s L3: 4000 A <sup>2</sup> s	—

TRF No. IEC60947\_3B


СЕРТИФИКАТ



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	49,1 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,001 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 111	P

TRF No. IEC60947\_3B


ПРОТВО С ОРИГИНАЛ



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 19: 500 V, 25 A, 1-pole)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated voltage (V) .....	500 V	—
	- rated current (A) .....	25 A (gG)	—
	- rated breaking capacity (kA) .....	120 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 537 V L2: — L3: —	—
	test current (kA) .....	L1: 107 kA L2: — L3: —	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,2	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 2,59 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1000 A <sup>2</sup> s L2: — L3: —	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 3,56 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 2000 A <sup>2</sup> s L2: — L3: —	—

TRF No. IEC60947\_3B

СЕРТИФИКАТ



Handwritten signature


IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	11,4 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	550 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,001 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	4 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	25 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page-112	P

TRF No. IEC60947\_3B

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 20: 500 V, 25 A, 1-pole+N)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated voltage (V) .....	500 V	—
	- rated current (A) .....	25 A (gG)	—
	- rated breaking capacity (kA) .....	120 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 537 V L2: — L3: —	—
	test current (kA) .....	L1: 107 kA L2: — L3: —	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,2	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 3,8 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 2000 A <sup>2</sup> s L2: — L3: —	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 2,22 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1000 A <sup>2</sup> s L2: — L3: —	—

TRF No. IEC60947\_3B

BRAND С ОПИТНАМА





my



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	20,6 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	550 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,001 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	4 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	25 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 112	P


TRF No. IEC60947\_3B

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 21: 500 V, 25 A, 2-poles)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated voltage (V) .....	500 V	—
	- rated current (A) .....	25 A (gG)	—
	- rated breaking capacity (kA) .....	120 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 537 V (310 V x $\sqrt{3}$ ) L2: 537 V (310 V x $\sqrt{3}$ ) L3: —	—
	test current (kA) .....	L1: 107 kA L2: 107 kA L3: —	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,2	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 3,71 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1000 A <sup>2</sup> s L2: — L3: —	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 3,64 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1000 A <sup>2</sup> s L2: — L3: —	—

TRF No. IEC60947\_3B

ВЕРНО С ОРИГИНАЛА




ms

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	31,2 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	550 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,005 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	4 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	25 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 112	P

TRF No. IEC60947\_3B

ВЕРИФИКАЦИОННО СЕРТИФИКАТ



Handwritten signature

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 22: 500 V, 25 A, 3-poles+N)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated voltage (V) .....	500 V	—
	- rated current (A) .....	25 A (gG)	—
	- rated breaking capacity (kA) .....	120 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 730 V (421,5 V x $\sqrt{3}$ ) L2: 730 V (421,5 V x $\sqrt{3}$ ) L3: 730 V (421,5 V x $\sqrt{3}$ )	—
	test current (kA) .....	L1: 102 kA L2: 102 kA L3: 101 kA	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,2	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 1,9 kA L2: 3,8 kA L3: 2,0 kA	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1000 A <sup>2</sup> s L2: 2000 A <sup>2</sup> s L3: 1000 A <sup>2</sup> s	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,4 m/s	—
	- max. let-through current (kA) .....	L1: 0 kA L2: 3,16 kA L3: 3,16 kA	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 0 A <sup>2</sup> s L2: 1000 A <sup>2</sup> s L3: 1000 A <sup>2</sup> s	—

TRF No. IEC60947\_3B


СЕРТИФИКАТ  
С ОРИГИНАЛА



Handwritten signature or mark.



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	46,4 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1000 V (tested with 1380 V)	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	550 V (tested with 759 V)	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,002 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G25	—
	- rated current (A) .....	25 A (gG)	—
	- power loss (W) .....	2,6 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	4 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	25 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 113	P


TRF No. IEC60947\_3B



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 23: 690 V, 10 A, 1-pole)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated voltage (V) .....	690 V	—
	- rated current (A) .....	10 A (gR)	—
	- rated breaking capacity (kA) .....	200 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 725 V L2: — L3: —	—
	test current (kA) .....	L1: 52,7 kA L2: — L3: —	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,13	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		—
	- max. let-through current (kA) .....	L1: 2,0 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 0 A <sup>2</sup> s L2: — L3: —	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 0,77 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 0 A <sup>2</sup> s L2: — L3: —	—

TRF No. IEC60947\_3B










Handwritten signature



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	18,8 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,002 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	1,5 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	10 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 113	P

TRF No. IEC60947\_3B


IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 24: 690 V, 10 A, 1-pole+N)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated voltage (V) .....	690 V	—
	- rated current (A) .....	10 A (gR)	—
	- rated breaking capacity (kA) .....	200 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 726 V L2: — L3: —	—
	test current (kA) .....	L1: 52,7 kA L2: — L3: —	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,13	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 1,02 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 0 A <sup>2</sup> s L2: — L3: —	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 0,78 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 0 A <sup>2</sup> s L2: — L3: —	—

TRF No. IEC60947\_3B








IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	25,4 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,001 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	1,5 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	10 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 113	P



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 25: 690 V, 10 A, 2-poles)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated voltage (V) .....	690 V	—
	- rated current (A) .....	10 A (gR)	—
	- rated breaking capacity (kA) .....	200 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 726 V (419,16 V x $\sqrt{3}$ ) L2: 726 V (419,16 V x $\sqrt{3}$ ) L3: —	—
	test current (kA) .....	L1: 52,7 kA L2: 52,7 kA L3: —	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,13	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 0,61 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 0 A <sup>2</sup> s L2: — L3: —	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,5 m/s	—
	- max. let-through current (kA) .....	L1: 0,55 kA L2: — L3: —	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 0 A <sup>2</sup> s L2: — L3: —	—


TRF No. IEC60947\_3B

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	34,2 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,003 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIBA	—
	- manufacturer's model or type reference .....	50 179 06.10	—
	- rated current (A) .....	10 A (gR)	—
	- power loss (W) .....	2,3 W	—
	- rated breaking capacity (kA) .....	200 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	1,5 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	10 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 114	P

TRF No. IEC60947\_3B

ИНЖЕНЕРСКА  
ПЛОДДИВ  
ЕАД




Handwritten signature

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 26: 690 V, 32 A, 3-poles+N)		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated voltage (V) .....	400 V	—
	- rated current (A) .....	32 A (gG)	—
	- rated breaking capacity (kA) .....	120 kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 Ue) (V) .....	L1: 726 V (419,16 V x $\sqrt{3}$ ) L2: 726 V (419,16 V x $\sqrt{3}$ ) L3: 726 V (419,16 V x $\sqrt{3}$ )	—
	test current (kA) .....	L1: 50,9 kA L2: 52,2 kA L3: 51,0 kA	—
	rated frequency (Hz) .....	50 Hz	—
	power factor .....	0,23	—
	Time constant (ms) .....	—	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 0,9 kA L2: 5,6 kA L3: 5,6 kA	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 2000 A <sup>2</sup> s L2: 8000 A <sup>2</sup> s L3: 6000 A <sup>2</sup> s	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	1,6 m/s	—
	- point at which the measurement is made .....	point of rotation	—
	- test speed during the fuse protected short-circuit making (m/s) .....	1,4 m/s	—
	- max. let-through current (kA) .....	L1: 5,3 kA L2: 5,3 kA L3: 0 kA	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 5000 A <sup>2</sup> s L2: 5000 A <sup>2</sup> s L3: 0 A <sup>2</sup> s	—

TRF No. IEC60947\_3B

ИЗВЕЩЕНИЕ  
О РЕЗУЛЬТАТАХ




Handwritten signature

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8	51,6 N (required opening force) 150 N (test force acc. tab. 8)	P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0,002 mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current $I_e$ (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.6.5 on page 114	P




ВЕРНО С ОРИГИНАЛОМ





IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY (Sample No. 27: 690 V, 32 A, 1-pole)		P
8.3.7.1	Overload test		P
	ambient temperature 10-40 °C .....	25,6 °C	—
	test enclosure W x H x D (mm x mm x mm) .....	—	—
	material of enclosure .....	—	—
	test current 1,6xI <sub>th</sub> or 1,6xI <sub>th</sub> (A) .....	52	—
	cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ...	6 mm <sup>2</sup> cable / 1000 mm long	—
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- time duration of the overload test (s) .....	824 s	—
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed		P
	Required opening force not greater than the test force of 8.2.5.2 and table 8	14 N (required opening force) 150 N (test force acc. tab. 8)	P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage: 2*U <sub>e</sub> with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage (1,1 U <sub>e</sub> ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole .....		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole .....	0,002 mA	P

КОПИЕ С ОПРИТНАЛНА





IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Fuse links aged during the overload test are replaced by new fuse-links .....		P
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current I <sub>e</sub> (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.7.4 on page 114	P





СЪГЛАСОВАНО С ОПИТНАТА

TRF No. IEC60947\_3B






IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY (Sample No. 28: 690 V, 32 A, 2-poles)		P
8.3.7.1	Overload test		P
	ambient temperature 10-40 °C .....	23,6 °C	—
	test enclosure W x H x D (mm x mm x mm) .....	—	—
	material of enclosure .....	—	—
	test current 1,6xI <sub>th</sub> or 1,6xI <sub>th</sub> (A) .....	52	—
	cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ....	6 mm <sup>2</sup> cable / 1000 mm long	—
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- time duration of the overload test (s) .....	573 s	—
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed		P
	Required opening force not greater than the test force of 8.2.5.2 and table 8	17,2 N (required opening force) 150 N (test force acc. tab. 8)	P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage: 2*U <sub>e</sub> with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage (1,1 U <sub>e</sub> ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole .....		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole .....	0,001 mA	P





IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Fuse links aged during the overload test are replaced by new fuse-links .....		P
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current I <sub>e</sub> (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.7.4 on page 115	P



TRF No. IEC60947\_3B



ВЕРНО С ОПРИМНАТА





IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY (Sample No. 29: 690 V, 32 A, 3-poles+N)		P
8.3.7.1	Overload test		P
	ambient temperature 10-40 °C .....	23,6 °C	—
	test enclosure W x H x D (mm x mm x mm) .....	—	—
	material of enclosure .....	—	—
	test current 1,6xI <sub>th</sub> e or 1,6xI <sub>th</sub> (A) .....	52	—
	cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ...	6 mm <sup>2</sup> cable / 1000 mm long	—
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	- time duration of the overload test (s) .....	540 s	—
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed		P
	Required opening force not greater than the test force of 8.2.5.2 and table 8	35,2 N (required opening force) 150 N (test force acc. tab. 8)	P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage: 2*U <sub>e</sub> with a minimum of 1000V~ .....	1380 V	—
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage (1,1 U <sub>e</sub> ) (V) .....	759 V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole .....		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole .....	0,001 mA	P

TRF No. IEC60947\_3B

ИНЖЕНЕРИ  
ПЛОВДИВ  
ЕАВ

2023.08.07



Handwritten signature

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units):		—
	- manufacturer's name, trademark or identification mark .....	Bussmann	—
	- manufacturer's model or type reference .....	C10G32	—
	- rated current (A) .....	32 A (gG)	—
	- power loss (W) .....	2,9 W	—
	- rated breaking capacity (kA) .....	120 kA	—
	Fuse links aged during the overload test are replaced by new fuse-links .....		P
	- conductor cross-section (mm <sup>2</sup> ) .....	6 mm <sup>2</sup>	—
	- test current I <sub>e</sub> (A) .....	32 A	—
	Measured temperature-rise .....	see appended table 8.3.7.4 on page 115	P

8.4	ELECTROMAGNETIC COMPATIBILITY TESTS		N/A
8.4.1	Immunity		N/A
8.4.1.1	Equipment not incorporating electronic circuits: no tests necessary		N/A
8.4.1.2	Equipment incorporating electronic circuits:		N/A
	Equipment utilizing circuits in which all components are passive are not required to be tested		N/A
	All other equipment, requirements according to 7.3.3.2 and limits according table 6 apply		N/A
	Performed tests.....	see _____	N/A
	No unintentional separation or closing of contacts has occurred during these tests .....		N/A
8.4.2	Emission		N/A
8.4.2.1	Equipment not incorporating electronic circuits: no tests necessary		N/A
8.4.2.2	Equipment incorporating electronic circuits:		N/A
	Equipment utilizing circuits in which all components are passive are not required to be tested		N/A
	All other equipment, requirements according to 7.3.3.2 and limits according table 7 apply		N/A
	Performed tests.....	see _____	N/A

TRF No. IEC60947\_3B


ВЕРНО С ОРИГИНАЛА



Handwritten signature or mark.

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
<b>Annex A (normative)</b>			N/A
A	Equipment for direct switching of a single motor		N/A
A.1	Additional rated duties.....:		N/A
A.1.1	- intermittent periodic duty		N/A
	- intermittent duty		N/A
A.1.1.1	Classes of intermittent duty .....		N/A
	-class 1: up to 1 operating cycle per hour		N/A
	-class 3: up to 3 operating cycle per hour		N/A
	-class 12: up to 12 operating cycles per hour		N/A
	-class 30: up to 30 operating cycles per hour		N/A
	-class 120: up to 120 operating cycles per hour		N/A
A.1.2	Temporary duty.....:		N/A
A.5	Mechanical durability:		N/A
	Equipment mounted according to manufacturer's instruction		N/A
	Preferred number of no-load operating cycles expressed in millions.....:		N/A
	0,001 – 0,003 – 0,01 – 0,03 – 0,1 – 0,3 - 1		N/A
	If no mechanical endurance is stated by the manufacturer, a minimum mechanical endurance according to the class of intermittent duty shall be tested.	Class of intermittent duty:	N/A
	Number of no-load operating cycles performed.....:	_____	N/A
A.6	Electrical durability:		N/A
	- test according to manufacturer's instruction		N/A
A.7	Verification of making and breaking capacities:		N/A
	- utilization category .....		—
	- rated operational voltage $U_e$ (V) .....		—
	- rated operational current $I_e$ (A) or power (kW) .....		—
	Conditions for make/break operations or make operations:		—
	- test voltage, $U = 1,05 U_e$ ..... (V):	L1: L2: L3:	—
	- test current, $I =$ ..... x $I_e$ (A):	L1: L2: L3:	—

ЗЕРНО С ОПИТИВАТА




*Handwritten signature*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	- power factor .....	L1: L2: L3:	—
	Conditions for make/break operations:		N/A
	- test voltage, $U = 1,05 U_e$ ..... (V):	L1: L2: L3:	—
	- test current, $I =$ ..... x $I_e$ (A):	L1: L2: L3:	—
	- power factor/ time constant .....	L1: L2: L3:	—
	Number of make/break or make and break operations .....		N/A
	- recovery voltage duration ( $\geq 50$ ms)		N/A
	- current duration (ms) .....		—
	- time interval between operations .....		N/A
	Characteristic of transient recovery voltage if necessary:		N/A
	- oscillatory frequency (kHz) .....		—
	- measured oscillatory frequency (kHz) .....	L1: L2: L3:	N/A
	- factor $\gamma$ .....	L1: L2: L3:	N/A
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		N/A
	Test performed without:		—
	- endanger to the operator		N/A
	- cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A


TRF No. IEC60947\_3B

ВЕРНО С ОРИГИНАЛА



*[Handwritten signature]*

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A
8.3.3.4	Dielectric verification		N/A
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....		—
	No flashover or breakdown		N/A
8.3.3.5	Leakage current		N/A
	test voltage (1,1 $U_e$ ) (V) .....		—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories): $\leq 2$ mA/pole .....		N/A
8.3.3.6	Temperature-rise verification		N/A
	- conductor cross-section ( $\text{mm}^2$ ) .....		—
	- test current $I_e$ (A) .....		—
	Measured temperature-rise .....	see __	N/A
A.8	Operational performance test:		N/A
	- utilization category .....		—
	- rated operational voltage (V) .....		—
	- rated operational current (A) .....		—
	Test conditions for electrical operation cycles:		N/A
	- test voltage (V) .....	L1: L2: L3:	—
	- test current (A) .....	L1: L2: L3:	—
	- power factor/time constant .....	L1: L2: L3:	—
	Number of cycles with current .....		N/A
	Number of cycles without current .....		N/A



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	First test sequence (with/without current) .....		—
	Second test sequence (with/without current) .....		—
	- time interval between first and second test sequence .....		—
8.3.4.1.5	Behaviour of the equipment during the operational performance test		N/A
	Test performed without:		—
	- endanger to the operator		N/A
	- cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A
8.3.4.2	Dielectric verification		N/A
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....		—
	No breakdown or flashover		N/A
8.3.4.3	Leakage current		N/A
	test voltage (1,1 $U_e$ ) (V) .....		—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2$ mA/pole .....		N/A
8.3.4.4	Temperature-rise verification		N/A
	- conductor cross-section ( $\text{mm}^2$ ) .....		—
	- test current $I_e$ (A) .....		—
	Measured temperature-rise .....	see ___	N/A
A.9	Special tests:	see ___	N/A

TRF No. IEC60947\_3B



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
Annex C (normative)			N/A
C	Single pole operated three pole switches		N/A
C.1	Three pole operated switches of fundamentally the same design, already successfully tested are deemed to satisfy the requirements of individually operated three pole devices.		N/A
C.2	Additional-tests to be performed on single pole operated three pole switches		N/A
	Test "8.3.3.3 Making and breaking capacities" according to test sequence I with following modifications		N/A
	L1 and L2 are closed, L3 is subjected to the required make-break operation cycle .....		N/A
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle .....		N/A
	Test performed in a three phase circuit		N/A
	Test "8.3.4.1 Operational performance" according to test sequence II with following modifications		N/A
	L1 and L2 are closed, L3 is subjected to the required make-break operation cycle .....		N/A
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle .....		N/A
	Test performed in a three phase circuit		N/A
	Test "8.3.6.2 Fuse protected short circuit test" according to test sequence IV with following modifications		N/A
	For the making test L1 shall be open and L2 closed, L3 is subjected to the required make operation cycle .....		N/A
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle .....		N/A
	Test performed in a three phase circuit		N/A
C.5	Instruction for use		N/A
	The product literature includes following statement :		N/A
	These devices are intended for power distribution systems where switching and/or isolating of an individual phase may be necessary and shall not be used for the switching of the primary circuit of three-phase equipment.		N/A

ИНЖЕНЕРИ  
ПЛОВДИВ  
ЕАД






IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

7.1.4	TABLE: Clearance and creepage distance measurements					
clearance cl and creepage distance dcr at/of:	Up (V)	U r.m.s. (V)	required cl (mm)	cl (mm)	required dcr (mm)	dcr (mm)
Between active parts and parts intended to be touched	7300	800	2	>5,5	11	>11
Between active parts and enclosure	7300	800	2	>5,5	11	>11
Between active parts and fuse-link with the contacts in open position	9800	800	2	>5,5	11	>11
supplementary information:						


8.3.3.1	TABLE: Temperature-rise (measurements) (Sample No. 1: I <sub>e</sub> = 25 A)		P
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Above terminals (cable connection)	39,3	70	
Below terminals (cable connection)	35,3	70	
Manual operating means: metallic / non-metallic	4,3	25	
Parts intended to be touched but not hand-held: metallic / non-metallic	8,5	40	
Parts which need not be touched during normal operation: metallic / non-metallic	12,8	50	
supplementary information:		Ambient temperature:	22,7 °C

8.3.3.6	TABLE: Temperature-rise (measurements) (Sample No. 1: I <sub>e</sub> = 25 A)		P
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals	37,2	80	
Manual operating means: metallic / non-metallic	4,6	35	
Parts intended to be touched but not hand-held: metallic / non-metallic	6,1	50	
Parts which need not be touched during normal operation: metallic / non-metallic	17,0	60	
supplementary information:		Ambient temperature:	22,9 °C

TRF No. IEC60947\_3B



МННО С ОПИТНАТА




IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict


8.3.3.1	TABLE: Temperature-rise (measurements) (Sample No. 2: $I_b = 10$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Above terminals (cable connection)		31,7	70
Below terminals (cable connection)		29,8	70
Manual operating means: <del>metallie</del> / non-metallic		5,0	25
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		8,8	40
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		15,3	50
<b>supplementary information:</b>		Ambient temperature:	22,7 °C

8.3.3.6	TABLE: Temperature-rise (measurements) (Sample No. 2: $I_b = 10$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		32,9	80
Manual operating means: <del>metallie</del> / non-metallic		3,7	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		5,4	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		19,4	60
<b>supplementary information:</b>		Ambient temperature:	23,8 °C

8.3.3.1	TABLE: Temperature-rise (measurements) (Sample No. 3: $I_b = 32$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Above terminals (cable connection)		45,0	70
Below terminals (cable connection)		37,5	70
Manual operating means: <del>metallie</del> / non-metallic		5,5	25
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		13,8	40
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		12,0	50
<b>supplementary information:</b>		Ambient temperature:	22,7 °C

TRF No. IEC60947\_3B

ВЕРНО С ОРИГИНАЛОМ



Handwritten signature

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.3.6	TABLE: Temperature-rise (measurements) (Sample No. 3: $I_e = 32$ A)	P	
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		39,0	80
Manual operating means: <del>metallie</del> / non-metallic		4,8	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		5,4	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		21,1	60
<b>supplementary information:</b>		Ambient temperature: 24,3 °C	

8.3.3.1	TABLE: Temperature-rise (measurements) (Sample No. 4: $I_e = 32$ A)	P	
Temperature rise dT of part:		dT (K) measured	dT (K) required
Above terminals (cable connection)		48,5	70
Below terminals (cable connection)		47,3	70
Manual operating means: <del>metallie</del> / non-metallic		7,8	25
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		21,8	40
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		14,5	50
<b>supplementary information:</b>		Ambient temperature: 22,7 °C	

8.3.3.6	TABLE: Temperature-rise (measurements) (Sample No. 4: $I_e = 32$ A)	P	
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		49,0	80
Manual operating means: <del>metallie</del> / non-metallic		8,8	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		12,9	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		26,9	60
<b>supplementary information:</b>		Ambient temperature: 24,4 °C	

TRF No. IEC60947\_3B

ИНЖЕНЕРИ  
ПЛОВДИ  
ЕАД

ИНЖЕНЕРИ  
ПЛОВДИ  
ЕАД



Handwritten signature

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict


8.3.3.1	TABLE: Temperature-rise (measurements) (Sample No. 5: $I_e = 25$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Above terminals (cable connection)		44,3	70
Below terminals (cable connection)		42,9	70
Manual operating means: <del>metallie</del> / non-metallic		10,6	25
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		13,3	40
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		15,2	50
<b>supplementary information:</b>		Ambient temperature: 22,7 °C	

8.3.3.6	TABLE: Temperature-rise (measurements) (Sample No. 5: $I_e = 25$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		47,5	80
Manual operating means: <del>metallie</del> / non-metallic		8,9	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		16,2	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		22,8	60
<b>supplementary information:</b>		Ambient temperature: 22,9 °C	

8.3.3.1	TABLE: Temperature-rise (measurements) (Sample No. 6: $I_e = 10$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Above terminals (cable connection)		44,5	70
Below terminals (cable connection)		40,8	70
Manual operating means: <del>metallie</del> / non-metallic		9,3	25
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		19,5	40
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		14,8	50
<b>supplementary information:</b>		Ambient temperature: 22,7 °C	

TRF No. IEC60947\_3B

ВЕРНО С ОПЫТОМ



Handwritten signature or initials.

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.3.6	TABLE: Temperature-rise (measurements) (Sample No. 6: $I_e = 10$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		50,4	80
Manual operating means: <del>metallie</del> / non-metallic		6,3	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		13,8	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		27,0	60
<b>supplementary information:</b>		Ambient temperature:	23,8 °C


8.3.3.1	TABLE: Temperature-rise (measurements) (Sample No. 7: $I_e = 32$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Above terminals (cable connection)		63,8	70
Below terminals (cable connection)		63,9	70
Manual operating means: <del>metallie</del> / non-metallic		16,9	25
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		32,8	40
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		22,3	50
<b>supplementary information:</b>		Ambient temperature:	22,7 °C

8.3.3.6	TABLE: Temperature-rise (measurements) (Sample No. 7: $I_e = 32$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		59,9	80
Manual operating means: <del>metallie</del> / non-metallic		11,2	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		23,7	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		27,6	60
<b>supplementary information:</b>		Ambient temperature:	24,4 °C

TRF No. IEC60947\_3B

ИНЖЕНЕРИ  
ПРОЕКТИ  
ЕАД

ОБРАЗЛОЖЕНИЕ



ms

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.4.4	TABLE: Temperature-rise (measurements) (Sample No. 8: I <sub>e</sub> = 25 A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		39,6	80
Manual operating means: <del>metallie</del> / non-metallic		5,5	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		17,6	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		25,9	60
<b>supplementary information:</b>		Ambient temperature: 25,3 °C	

8.3.4.4	TABLE: Temperature-rise (measurements) (Sample No. 9: I <sub>e</sub> = 10 A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		43,1	80
Manual operating means: <del>metallie</del> / non-metallic		3,3	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		14,0	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		20,3	60
<b>supplementary information:</b>		Ambient temperature: 25,3 °C	

8.3.4.4	TABLE: Temperature-rise (measurements) (Sample No. 10: I <sub>e</sub> = 32 A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		47,5	80
Manual operating means: <del>metallie</del> / non-metallic		10,8	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		24,4	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		26,1	60
<b>supplementary information:</b>		Ambient temperature: 25,3 °C	

TRF No. IEC60947\_3B

ВЕРНО С ОРИГИНАЛОМ







IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.4.4	TABLE: Temperature-rise (measurements) (Sample No. 11: $I_b = 32 A$ )		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		42,5	80
Manual operating means: <del>metallie</del> / non-metallic		9,2	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		22,1	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		22,5	60
<b>supplementary information:</b>		Ambient temperature: 25,3 °C	

8.3.4.4	TABLE: Temperature-rise (measurements) (Sample No. 12: $I_b = 25 A$ )		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		48,9	80
Manual operating means: <del>metallie</del> / non-metallic		8,4	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		28,8	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		30,4	60
<b>supplementary information:</b>		Ambient temperature: 25,3 °C	

8.3.4.4	TABLE: Temperature-rise (measurements) (Sample No. 13: $I_b = 10 A$ )		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		43,8	80
Manual operating means: <del>metallie</del> / non-metallic		9,3	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		28,5	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		28,7	60
<b>supplementary information:</b>		Ambient temperature: 25,3 °C	

TRF No. IEC60947\_3B

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.4.4	TABLE: Temperature-rise (measurements) (Sample No. 14: $I_e = 32$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		44,1	80
Manual operating means: <del>metallie</del> / non-metallic		14,5	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		34,0	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		23,3	60
<b>supplementary information:</b>		Ambient temperature: 25,3 °C	

8.3.5.5	TABLE: Temperature-rise (measurements)		N/A
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals			
Manual operating means: metallic / non-metallic			
Parts intended to be touched but not hand-held: metallic / non-metallic			
Parts which need not be touched during normal operation: metallic / non-metallic			
<b>supplementary information:</b>			

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 15: $I_e = 32$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		53,5	80
Manual operating means: <del>metallie</del> / non-metallic		6,0	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		16,8	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		26,3	60
<b>supplementary information:</b>		Ambient temperature: 23,5 °C	

TRF No. IEC60947\_3B

ИНЖЕНЕРИ ИТ  
ПЛОДИВ  
ЕАН

СТРНО С ОРГИЗАЦИЯ



Handwritten signature.







IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 16: $I_e = 32$ A)		P
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals	58,5	80	
Manual operating means: <del>metallie</del> / non-metallic	10,2	35	
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic	21,8	50	
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic	40,5	60	
<b>supplementary information:</b>	Ambient temperature: 24,9 °C		

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 17: $I_e = 32$ A)		P
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals	65,9	80	
Manual operating means: <del>metallie</del> / non-metallic	14,1	35	
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic	28,4	50	
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic	44,7	60	
<b>supplementary information:</b>	Ambient temperature: 24,6 °C		

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 18: $I_e = 32$ A)		P
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals	60,3	80	
Manual operating means: <del>metallie</del> / non-metallic	16,6	35	
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic	35,0	50	
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic	33,5	60	
<b>supplementary information:</b>	Ambient temperature: 24,2 °C		

TRF No. IEC60947\_3B

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 19: $I_b = 25$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		35,6	80
Manual operating means: <del>metallie</del> / non-metallic		6,5	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		15,7	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		22,0	60
<b>supplementary information:</b>		Ambient temperature: 24,6 °C	

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 20: $I_b = 25$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		42,1	80
Manual operating means: <del>metallie</del> / non-metallic		8,6	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		19,1	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		24,3	60
<b>supplementary information:</b>		Ambient temperature: 24,6 °C	

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 21: $I_b = 25$ A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		46,6	80
Manual operating means: <del>metallie</del> / non-metallic		12,9	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		26,5	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		28,2	60
<b>supplementary information:</b>		Ambient temperature: 24,6 °C	

TRF No. IEC60947\_3B

ВЯРНО С ОРИГИНАЛА

МПКЕВЕР

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 22: $I_b = 25$ A)	P	
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		57,7	80
Manual operating means: <del>metallie</del> / non-metallic		16,8	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		33,8	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		30,6	60
<b>supplementary information:</b>		Ambient temperature: 24,6 °C	

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 23: $I_b = 10$ A)	P	
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		33,5	80
Manual operating means: <del>metallie</del> / non-metallic		3,5	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		13,0	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		19,0	60
<b>supplementary information:</b>		Ambient temperature: 23,3 °C	

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 24: $I_b = 10$ A)	P	
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		31,9	80
Manual operating means: <del>metallie</del> / non-metallic		6,1	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		17,1	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		19,3	60
<b>supplementary information:</b>		Ambient temperature: 23,3 °C	

TRF No. IEC60947\_3B

ВЕРНО С ОРИГИНАЛА



*Handwritten signature*



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 25: $I_b = 10\text{ A}$ )		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		45,7	80
Manual operating means: <del>metallie</del> / non-metallic		8,4	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		24,1	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		25,3	60
<b>supplementary information:</b>		Ambient temperature: 23,3 °C	

8.3.6.5	TABLE: Temperature-rise (measurements) (Sample No. 26: $I_b = 32\text{ A}$ )		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		56,8	80
Manual operating means: <del>metallie</del> / non-metallic		13,5	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		33,0	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		30,8	60
<b>supplementary information:</b>		Ambient temperature: 24,6 °C	

8.3.7.4	TABLE: Temperature-rise (measurements) (Sample No. 27: $I_b = 32\text{ A}$ )		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		42,5	80
Manual operating means: <del>metallie</del> / non-metallic		2,8	35
Parts intended to be touched but not hand-held: <del>metallie</del> / non-metallic		14,0	50
Parts which need not be touched during normal operation: <del>metallie</del> / non-metallic		21,6	60
<b>supplementary information:</b>		Ambient temperature: 22,6 °C	


TRF No. IEC60947\_3B


IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.7.4	TABLE: Temperature-rise (measurements) (Sample No. 28: I <sub>e</sub> = 32 A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		46,8	80
Manual operating means: <del>metallic</del> / non-metallic		11,7	35
Parts intended to be touched but not hand-held: <del>metallic</del> / non-metallic		31,8	50
Parts which need not be touched during normal operation: <del>metallic</del> / non-metallic		35,4	60
<b>supplementary information:</b>		Ambient temperature:	23,4 °C

8.3.7.4	TABLE: Temperature-rise (measurements) (Sample No. 29: I <sub>e</sub> = 32 A)		P
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals		53,6	80
Manual operating means: <del>metallic</del> / non-metallic		17,5	35
Parts intended to be touched but not hand-held: <del>metallic</del> / non-metallic		33,4	50
Parts which need not be touched during normal operation: <del>metallic</del> / non-metallic		41,5	60
<b>supplementary information:</b>		Ambient temperature:	23,8 °C



TRF No. IEC60947\_3B

*[Handwritten signature]*


*[Handwritten signature]*

**List of test equipment used:**

(Note: This is an example of the required attachment. Other forms with a different layout but containing similar information are also acceptable.)

Clause	Measurement / testing	Testing / measuring equipment / material used	Range used	Calibration date
		Not applicable, only required for the MT programs		

ВЪРНО С ОРИГИНАЛА



A large handwritten signature in black ink.

A smaller handwritten signature in black ink.

## Deutsche Akkreditierungsstelle GmbH

Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1 subsection 1 AkkStelleGBV

Signatory to the Multilateral Agreements of EA, ILAC and IAF for Mutual Recognition

# Accreditation



The Deutsche Akkreditierungsstelle GmbH attests that the testing laboratory

**IPH Institut "Prüffeld für elektrische Hochleistungstechnik" GmbH**  
**Landsberger Allee 378 A, 12681 Berlin**

is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out tests in the following fields:

**High-voltage equipment and components**  
**Low-voltage equipment and components**  
**Installation, switching, control and protective equipment**  
**High-voltage, medium-voltage and low-voltage cables and their accessories**

The accreditation certificate shall only apply in connection with the notice of accreditation of 2015-11-11 with the accreditation number D-PL-12107-01 and is valid until 2020-11-10. It comprises the cover sheet, the reverse side of the cover sheet and the following annex with a total of 42 pages.

Registration number of the certificate: D-PL-12107-01-00

ВЪРНО С ОРИГИНАЛА

Frankfurt, 2015-11-11

Dipl.-Ing. (FH) Ralf Egner  
Head of Division



This document is a translation. The definitive version is the original German accreditation certificate.

See notes overleaf.




Extract from the online catalog

# URTK/S


Order No.: 0311087

*Handwritten signature*




<http://eshop.phoenixcontact.net/phoenix/treeViewClick.do?UID=0311087>

Test disconnect terminal block, Connection method: Screw connection, Cross section: 0.5 mm<sup>2</sup> - 10 mm<sup>2</sup>, AWG: 20 - 10, Width: 8.2 mm, Mounting type: NS 35/7.5, NS 35/15, NS 32, Color: gray

Commercial data	
EAN	 4 017918 001292
Pack	50 pcs.
Customs tariff	85369010
Gross weight in pieces	0.035996 KG
Net weight per piece (exclusive packing)	0.03581 KG
Catalog page information	Page 463 (CL1-2011)

**Product notes**


WEEE/RoHS-compliant since: 01/01/2003



<http://www.download.phoenixcontact.com>  
Please note that the data given here has been taken from the online catalog. For comprehensive information and data, please refer to the user documentation. The General Terms and Conditions of Use apply to Internet downloads.

Technical data	
<b>General</b>	
Number of levels	1
Number of connections	2
Color	gray

**ВЯРНО С ОРГИНАЛА**



*Handwritten signature*

*Handwritten number: 440*



URTK/S Order No.: 0311087

<http://eshop.phoenixcontact.net/phoenix/treeViewClick.do?UID=0311087>

Insulating material	PA
Inflammability class according to UL 94	V0

#### Dimensions


Length	72 mm
Width	8.2 mm
Height NS 35/7,5	51.5 mm
Height NS 35/15	59 mm
Height NS 32	56 mm

#### Technical data

Rated surge voltage	6 kV
Pollution degree	3
Surge voltage category	III
Insulating material group	I
Connection in acc. with standard	IEC 60947-7-1
Nominal current $I_n$	41 A
Nominal voltage $U_n$	400 V
Open side panel	ja
Shock protection test specification	DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection	guaranteed
Surge voltage test setpoint	7.3 kV
Result of surge voltage test	Test passed
Power frequency withstand voltage setpoint	1.89 kV
Result of power-frequency withstand voltage test	Test passed
Checking the mechanical stability of terminal points (5 x conductor connection)	Test passed
Bending test rotation speed	10 rpm
Bending test turns	135
Bending test conductor cross section/weight	0.5 mm <sup>2</sup> / 0.3 kg 6 mm <sup>2</sup> / 1.4 kg 10 mm <sup>2</sup> / 2 kg
Result of bending test	Test passed
Conductor cross section tensile test	0.5 mm <sup>2</sup>
Tractive force setpoint	20 N
Conductor cross section tensile test	6 mm <sup>2</sup>
Tractive force setpoint	80 N



1441



Conductor cross section tensile test	10 mm <sup>2</sup>
Tractive force setpoint	90 N
Tensile test result	Test passed
Tight fit on carrier	NS 32/NS 35
Setpoint	5 N
Result of tight fit test	Test passed
Result of voltage drop test	Test passed
Temperature-rise test	Test passed
Conductor cross section short circuit testing	6 mm <sup>2</sup>
Short-time current	0.72 kA
Conductor cross section short circuit testing	10 mm <sup>2</sup>
Short-time current	1.2 kA
Short circuit stability result	Test passed
Proof of thermal characteristics (needle flame) effective duration	30 s
Result of thermal test	Test passed
Temperature index, insulating material (DIN EN 60216-1 (VDE 0304-21))	130 °C
Static insulating material application in cold	-60 °C

**Connection data**

Conductor cross section solid min.	0.5 mm <sup>2</sup>
Conductor cross section solid max.	10 mm <sup>2</sup>
Conductor cross section stranded min.	0.5 mm <sup>2</sup>
Conductor cross section stranded max.	6 mm <sup>2</sup>
Conductor cross section AWG/kcmil min.	20
Conductor cross section AWG/kcmil max	8
Conductor cross section stranded, with ferrule without plastic sleeve min.	0.5 mm <sup>2</sup>
Conductor cross section stranded, with ferrule without plastic sleeve max.	6 mm <sup>2</sup>
Conductor cross section stranded, with ferrule with plastic sleeve min.	0.5 mm <sup>2</sup>
Conductor cross section stranded, with ferrule with plastic sleeve max.	4 mm <sup>2</sup>
2 conductors with same cross section, solid min.	0.5 mm <sup>2</sup>
2 conductors with same cross section, solid max.	2.5 mm <sup>2</sup>
2 conductors with same cross section, stranded min.	0.5 mm <sup>2</sup>

*Handwritten signature and scribbles*

*Handwritten signature*

*Handwritten initials*

**ВЯРНО С  
ОРИГИНАЛА**

Page 3/4  
 Feb 6, 2013  
 ПРОСМОТРЕНО  
 528

2 conductors with same cross section, stranded max.	6 mm <sup>2</sup>
2 conductors with same cross section, stranded, ferrules without plastic sleeve, min.	0.5 mm <sup>2</sup>
2 conductors with same cross section, stranded, ferrules without plastic sleeve, max.	4 mm <sup>2</sup>
2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, min.	0.5 mm <sup>2</sup>
2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, max.	4 mm <sup>2</sup>
Connection method	Screw connection
Stripping length	13 mm
Internal cylindrical gage	A5
Screw thread	M4
Tightening torque, min	1.2 Nm
Tightening torque max	1.5 Nm

**Certificates / Approvals**



Certification

CSA, cULus Recognized, GOST, KEMA-KEUR, DNV LR, PRS, RS, CCA

Certifications applied for:

Certification Ex:

**Accessories**

Item	Designation	Description
<b>Assembly</b>		
3034361	AP-ME METER	Cover profile, for covering terminal strips, snapped onto APT-ME cover profile carrier or APH-ME end bracket. A cover profile carrier should be positioned at the ends and at intervals of around 40 cm. Length supplied: 1 m
3034374	APH-ME	Cover profile carrier for mounting on NS 35/7.5 DIN rail for attaching the cover profile AP-ME
3034358	APT-ME	Cover profile carrier for mounting on NS 35/7.5 DIN rail for attaching the cover profile AP-ME



1443

ВЯРНО С  
ОРИГИНАЛА

Page 4 of 11  
Feb 6, 2013

ПЛОДНА

0310224	ATS-RTK	Partition plate, Length: 72 mm, Width: 0.8 mm, Height: 51.5 mm, Color: gray
3022218	CLIPFIX 35	Snap-on end bracket, for 35 mm NS 35/7.5 or NS 35/16 DIN rail, can be fitted with Zack strip ZB 8 and ZB 8/27, terminal strip marker KLM 2 and KLM, width: 9.5 mm, color: gray
3022276	CLIPFIX 35-5	Quick mounting end clamp for NS 35/7.5 DIN rail or NS 35/16 DIN rail, can be fitted with ZB 5 and ZBF 5 zack marker strip, KLM 2, KLM3, and KML3L terminal strip marker, parking option for FBS...5, FBS...6, KSS 5, KSS 6, width: 5.15 mm, color: gray
0310020	D-URTK	End cover, Length: 72 mm, Width: 2.2 mm, Height: 41.5 mm, Color: gray
1201442	E/UK	End clamp, for assembly on NS 32 or NS 35/7.5 DIN rail
1201413	E/UK 1	End clamps, for supporting the ends of double-level and three-level terminal blocks, width: 10 mm, color: gray
1201002	NS 32 PERF 2000MM	G-profile DIN rail, material: Steel, perforated, height 15 mm, width 32 mm, length 2 m
1201015	NS 32 UNPERF 2000MM	G-profile DIN rail, material: Steel, unperforated, height 15 mm, width 32 mm, length 2 m
0801704	NS 35/ 7,5 AL UNPERF 2000MM	DIN rail, material: Aluminum, unperforated, height 7.5 mm, width 35 mm, length: 2 m
1206560	NS 35/ 7,5 CAP	DIN rail end piece, for DIN rail NS 35/7,5
0801762	NS 35/ 7,5 CU UNPERF 2000MM	DIN rail, material: Copper, unperforated, height 7.5 mm, width 35 mm, length: 2 m
0801733	NS 35/ 7,5 PERF 2000MM	DIN rail, material: steel galvanized and passivated with a thick layer, perforated, height 7.5 mm, width 35 mm, length: 2000 mm
0801681	NS 35/ 7,5 UNPERF 2000MM	DIN rail, material: Steel, unperforated, height 7.5 mm, width 35 mm, length: 2 m
1204119	NS 35/ 7,5 WH PERF 2000MM	DIN rail 35 mm (NS 35)
1204122	NS 35/ 7,5 WH UNPERF 2000MM	DIN rail 35 mm (NS 35)
1206421	NS 35/ 7,5 ZN PERF 2000MM	DIN rail, material: Galvanized, perforated, height 7.5 mm, width 35 mm, length: 2 m
1206434	NS 35/ 7,5 ZN UNPERF 2000MM	DIN rail, material: Galvanized, unperforated, height 7.5 mm, width 35 mm, length: 2 m
1201756	NS 35/15 AL UNPERF 2000MM	DIN rail, deep drawn, high profile, unperforated, 1.5 mm thick, material: aluminum, height 15 mm, width 35 mm, length 2000 mm
1206573	NS 35/15 CAP	DIN rail end piece, for DIN rail NS 35/15
1201895	NS 35/15 CU UNPERF 2000MM	DIN rail, material: Copper, unperforated, 1.5 mm thick, height 15 mm, width 35 mm, length: 2 m
1201730	NS 35/15 PERF 2000MM	DIN rail, material: steel galvanized and passivated with a thick layer, perforated, height 15 mm, width 35 mm, length: 2000 mm
1201714	NS 35/15 UNPERF 2000MM	DIN rail, material: Steel, unperforated, height 15 mm, width 35 mm, length: 2 m



*[Handwritten signature]*

*[Handwritten signature]*

0806602	NS 35/15 WH PERF 2000MM	DIN rail 35 mm (NS 35)
1204135	NS 35/15 WH UNPERF 2000MM	DIN rail 35 mm (NS 35)
1206599	NS 35/15 ZN PERF 2000MM	DIN rail, material: Galvanized, perforated, height 15 mm, width 35 mm, length: 2 m
1206586	NS 35/15 ZN UNPERF 2000MM	DIN rail, material: Galvanized, unperforated, height 15 mm, width 35 mm, length: 2 m
1201798	NS 35/15-2,3 UNPERF 2000MM	DIN rail, material: Steel, unperforated, 2.3 mm thick, height 15 mm, width 35 mm, length: 2 m
0310211	TS-RTK	Separating plate, Length: 72 mm, Width: 0.8 mm, Color: gray

**Bridges**



0311281	ASB 2-RTK/S	Switching jumper, Number of positions: 2, Color: silver
0202154	EB 2- 8	Insertion bridge, Number of positions: 2, Color: gray
0202141	EB 3- 8	Insertion bridge, Number of positions: 3, Color: gray
0202142	EB 4- 8	Insertion bridge, Number of positions: 4, Color: gray
0202138	EB 10- 8	Insertion bridge, Number of positions: 10, Color: gray
0311171	FB 10- RTK/S	Fixed bridge, Number of positions: 10, Color: silver
0308359	S	Switching lock, Length: 12 mm, Width: 8.2 mm, Color: white
0311236	SB 2-RTK/S	Switching jumper, Number of positions: 2, Color: silver
0311265	SB 4-RTK/S	Switching jumper, Number of positions: 4, Color: silver
0311278	USB 2-RTK/S	Switching jumper, Number of positions: 2, Color: silver

**General**

0800886	E/NS 35 N	End clamp, width: 9.5 mm, color: gray
---------	-----------	---------------------------------------

**Marking**

1007235	SBS 8:UNBEDRUCKT	Marker cards, Card, white, Unlabeled, Can be labeled with: Plotter, Mounting type: Snap into tall marker groove, Snap into flat marker groove, For terminal block width: 8.2 mm, Lettering field: 6 x 8.1 mm
0818072	UC-TM 8	Marker for terminal blocks, Sheet, white, Unlabeled, Can be labeled with: BLUEMARK CLED, Bluemark, Plotter, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 7.6 x 10.5 mm
0824597	UC-TM 8 CUS	Marker for terminal blocks, Can be ordered: By sheet, white, Labeled according to customer specifications, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 7.6 x 10.5 mm
0828740	UCT-TM 8	Marker for terminal blocks, Sheet, white, Unlabeled, Can be labeled with: Thermomark C+, Thermomark C, BLUEMARK CLED, Bluemark, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 7.6 x 10.5 mm



*[Handwritten signature]*

*[Handwritten initials]*

URTK/S Order No.: 0311087

<http://eshop.phoenixcontact.net/phoenix/treeViewClick.do?UID=0311087>

0829616	UCT-TM 8 CUS	Marker for terminal blocks, Can be ordered: By sheet, white, Labeled according to customer specifications, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 7.6 x 10.5 mm
0825011	ZB 8 CUS	Zack marker strip, Can be ordered: Strip, white, Labeled according to customer specifications, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 10.5 x 8.15 mm
1052002	ZB 8:UNBEDRUCKT	Zack marker strip, Strip, white, Unlabeled, Can be labeled with: Plotter, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 10.5 x 8.15 mm

**Plug/Adapter**

0311728	PSBJ-URTK/S BK	Female test connector, Color: black
0311757	PSBJ-URTK/S BU	Female test connector, Color: blue
0311760	PSBJ-URTK/S GN	Female test connector, Color: green
0311744	PSBJ-URTK/S RD	Female test connector, Color: red
0311773	PSBJ-URTK/S VT	Female test connector, Color: violet
0311731	PSBJ-URTK/S YE	Female test connector, Color: yellow


**Tools**

1205066	SZS 1,0X4,0 VDE	Screwdriver, bladed, VDE insulated, size: 1.0 x 4.0 x 100 mm, 2-component grip, with non-slip grip
---------	-----------------	--

*Handwritten signature*


*Handwritten signature*

*Handwritten signature*



Diagrams/Drawings

Circuit diagram





- a = open
- 1 = cover
- 3 = fixed bridge
- 4 = switch bar, for 2 terminal blocks, useable on both sides of the disconnect point, inward switching motion
- 5 = switch bar, for 2 terminal blocks, useable on both sides of the disconnect point, outward switching motion
- 7 = switch bar, for 3-phase short-circuiting of linked current transformer sets, only on the right
- 8 = switching lock, prevents disconnect slide from being actuated
- 9 = separating plate, for electrical separation of neighboring bridges in terminal center
- 10 = partition plate


*Handwritten signature*

*Handwritten signature*


*Handwritten signature*



Schematic diagram



Three-phase transducer test set




Three-phase linked transducer test set

*Handwritten signature*

*Handwritten signature*


**ВАРНО С  
ОПТИКАЛНА**



*Handwritten signature*

1448






Simple current transformer test circuit

- a = normal operation
- b = measured value testing
- c = transformer short-circuit
- d = relay testing

*Handwritten signature*



*Handwritten signature*

*Handwritten number 1449*

URTK/S Order No.: 0311087

<http://eshop.phoenixcontact.net/phoenix/treeViewClick.do?UID=0311087>

**Address**

PHOENIX CONTACT GmbH & Co. KG  
Flachsmarktstr. 8  
32825 Blomberg, Germany  
Phone +49 5235 3 00  
Fax +49 5235 3 41200  
<http://www.phoenixcontact.com>





© 2013 Phoenix Contact  
Technical modifications reserved;

*Handwritten signature*


PHOENIX CONTACT GmbH & Co. KG  
<http://www.phoenixcontact.com>

Page 11/11  
Feb 6, 2013



450


*Handwritten signature*



Page 12-2

**AC FUSE HOLDERS**


- Version without indicator: 1P, 1P+N, 2P, 3P, 3P+N
- Version with indicator: 1P
- For fuses 10x38, 14x51 and 22x58mm IEC class gG or aM.
- Rated current: 32A, 50A, 125A
- Rated voltage: 690VAC.



Page 12-2

**AC FUSE HOLDERS CLASS CC FOR NORTH AMERICAN MARKET**

- Version without indicator: 1P, 2P, 3P
- Version with indicator: 1P
- For 10x38mm UL/CSA class CC fuses
- Rated current: 30A
- Rated voltage: 600VAC.



Page 12-3

**DC FUSE HOLDERS FOR PHOTOVOLTAIC APPLICATIONS**

- Version without indicator: 1P, 2P
- Version with indicator: 1P, 2P
- For 10x38mm IEC class gPV fuses
- Rated current: 32A
- Rated voltage: 1000VDC
- IEC utilisation category: DC20B.



Page 12-3

**DC FUSES FOR PHOTOVOLTAIC APPLICATIONS**

- 10x38mm, IEC class gPV
- Rated current: 20A
- Rated voltage: 1000VDC.


*Handwritten signature*

*Handwritten signature*

**ВЯРНО С  
ОРИГИНАЛА**



1451




- Modular size for 10x38, 14x51 and 22x58mm fuses
- Finger safe - IP20 IEC degree of protection against accidental contact with live parts and with sealable cover for operators' safety
- Version with status indicator to quickly determine if the fuse is still operative or needs to be replaced
- UL and CSA certified versions.

	Sec. - PAGE
<b>Fuse holders</b>	
AC fuse holders.....	12 - 2
DC fuse holders for photovoltaic applications.....	12 - 3
<b>Fuses for photovoltaic applications</b> .....	12 - 3
<b>Accessories</b> .....	12 - 3
<b>Dimensions</b> .....	12 - 4
<b>Wiring diagrams</b> .....	12 - 4
<b>Technical characteristics</b> .....	12 - 5

*[Handwritten signature]*

*[Handwritten signature]*  
modulo

*[Handwritten signature]*  
BRAFHO C  
LOVATO  
1452






CIRCUIT PROTECTION AND ISOLATION

# Fuse holders

## AC fuse holders



### Fuse holders UL Recognized and CSA certified



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt [kg]
------------	------------------	------------------	----------	-------------	---------

For 10x38mm fuses.  
32A rated current at 690VAC.

FB01 A 1P	1P	—	1	12	0.066
FB01 A 1PL	1P	YES	1	12	0.065
FB01 A 1MØ	1P+N	—	1	12	0.062
FB01 A 1N	1P+N	—	2	6	0.134
FB01 A 2P	2P	—	2	6	0.132
FB01 A 3P	3P	—	3	4	0.188
FB01 A 3N	3P+N	—	4	3	0.260

For 14x51mm fuses.  
50A rated current at 690VAC.

FB02 A 1P	1P	—	1	12	0.113
FB02 A 1PL	1P	YES	1	12	0.114
FB02 A 1N	1P+N	—	2	6	0.237
FB02 A 2P	2P	—	2	6	0.224
FB02 A 3P	3P	—	3	4	0.335
FB02 A 3N	3P+N	—	4	3	0.460

For 22x58mm fuses.  
125A rated current at 690VAC.

FB03 A 1P	1P	—	1	12	0.167
FB03 A 1PL	1P	YES	1	12	0.167
FB03 A 1N	1P+N	—	2	6	0.354
FB03 A 2P	2P	—	2	6	0.334
FB03 A 3P	3P	—	3	4	0.500
FB03 A 3N	3P+N	—	4	3	0.720

⊖ Not certified.

#### Operational characteristics

- IEC rated voltage  $U_e$ :
  - 690VAC (FB01 A 1M excluded)
  - 400VAC (FB01 A 1M only)
- IEC rated current  $I_e$ :
  - FB01 A: 32A
  - FB02 A: 50A
  - FB03 A: 125A
- IEC utilisation category:
  - FB01 A: AC22B 500V, AC21B 690V (except FB01 A 1M: AC22B 400V)
  - FB02 A: AC22B 500V, AC21B 690V
  - FB03 A: AC21B 690V
- Suitable for IEC fuse class: gG and aM
- IEC degree of protection: IP20.

#### Certifications and compliance

Certifications obtained:


Type	UL Recognized for USA (File E343395)	CSA certified (File 252040 class 6255)	UL Recognized for USA and Canada (File E343395)
FB01 A 1P, FB01 A 1PL, FB01 A 1N	⊙	⊙	—
FB02 A...	—	—	⊙
FB03 A...	—	—	⊙

⊙ Certification obtained.

"UL Recognized": Products having this type of marking are intended for use as components of complete workshop-assembled equipment.

Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3, UL 4248-1, UL 4248-4, CSA C22.2 n°4248.1, CSA C22.2 n°4248.4.

### Fuse holders



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt [kg]
------------	------------------	------------------	----------	-------------	---------

For 10x38mm fuses.  
32A rated current at 690VAC.

FB01 B 1P	1P	—	1	12	0.062
FB01 B 1PL	1P	YES	1	12	0.064
FB01 B 1N	1P+N	—	2	6	0.127
FB01 B 2P	2P	—	2	6	0.128
FB01 B 3P	3P	—	3	4	0.185
FB01 B 3N	3P+N	—	4	3	0.247


#### Operational characteristics

- IEC rated voltage  $U_e$ : 690VAC
- IEC rated current  $I_e$ : 32A
- IEC utilisation category: AC22B 500V, AC21B 690V
- Suitable for IEC fuse class: gG and aM
- IEC degree of protection IP20.

#### Reference standards

Compliant with standards: IEC/EN 60947-1, IEC/EN 60947-3, IEC/EN 60269-1, IEC/EN 60269-2.

### Fuse holders UL Listed and CSA certified for class CC fuses for North American market



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt [kg]
------------	------------------	------------------	----------	-------------	---------

For 10x38mm fuses.  
30A rated current at 600VAC.

FB01 C 1P	1P	—	1	12	0.070
FB01 C 1PL	1P	YES	1	12	0.072
FB01 C 2P	2P	—	2	6	0.140
FB01 C 3P	3P	—	3	4	0.210

NOTE: UL Listed and CSA certified as "Fuseholders, Cartridge Fuse" for use with Class CC fuses. Interrupting rating 200-600 Amps rms symmetrical. Voltage rating 600V. Current rating 30A.

#### Operational characteristics

- IEC rated voltage  $U_e$ : 600VAC
- IEC rated current  $I_e$ : 30A
- IEC utilisation category: AC22B 500V, AC21B 690V
- Suitable for UL/CSA fuse class: CC
- IEC degree of protection IP20.

#### Certifications and compliance

Certifications obtained: UL Listed (File E343395) and CSA certified (File 252040 class 6255)

Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3, UL 4248-1, UL 4248-4, CSA C22.2 n°4248.1, CSA C22.2 n°4248.4.


1453

# Fuse holders

## DC fuse holders for photovoltaic applications.

### Accessories

### Fuse holders for photovoltaic applications



FB01 D...  
FB01 D 1PL

Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt
			n°	n°	[kg]

For 10x38mm fuses.  
32A rated current at 1000VDC.

FB01 D 1P	1P	—	1	12	0.064
FB01 D 1PL	1P	YES	1	12	0.065
FB01 D 2P	2P	—	2	6	0.127
FB01 D 2PL	2P	YES	2	6	0.130

#### Operational characteristics

- IEC rated voltage Ue: 1000VDC
- IEC rated current Ie: 32A
- IEC utilisation category: DC20B 1000VDC
- Suitable for IEC fuse class: gPV
- IEC degree of protection: IP20.

#### Reference standards

Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3.

### Fuses for photovoltaic applications



FE01 D...

Order code	Rated current In	Qty per pkg	Wt
	[A]	n°	[kg]

For 10x38mm fuses.  
30kA breaking capacity at 1000VDC.

FE01 D 00200	2	10	0.008
FE01 D 00400	4	10	0.008
FE01 D 00600	6	10	0.008
FE01 D 00800	8	10	0.008
FE01 D 01000	10	10	0.008
FE01 D 01200	12	10	0.008
FE01 D 01600	16	10	0.008
FE01 D 02000	20	10	0.008

#### Operational characteristics

- IEC rated voltage Ue: 1000VDC
- IEC rated current Ie: 2-20A
- IEC fuse class: gPV.


#### Reference standards

Compliant with standards: IEC/EN 60269-6.


### Accessories



FBX 00  
FBX 01  
FBX 02



FBX 05



FBX 07

FBX 08



FBX 11

Order code	Description	Qty per pkg	Wt
	[A]	n°	[kg]

FBX 00	Coupling clip for 10x38, 14x51 and 22x58mm sizes	100	0.003
FBX 01	Coupling pin for 10x38mm size	100	0.005
FBX 02	Coupling pin for 14x51 and 22x58mm sizes	100	0.008

For FB01 A... and FB01 B... types.

FBX 05	Three-phase connection busbar, for 57 modules in total, 1m/3.3ft long	10	0.465
FBX 07	One-pole terminal for 25mm² max conductor	25	0.010
FBX 08	One-pole terminal for 50mm² max conductor	25	0.020
FBX 11	End cap for FBX05 busbar	50	0.001

ⓘ Not suitable for FB01 B1N, FB01 B2P, FB01 B3P and FB01 B3N types.


#### General and operational characteristics

##### THREE-PHASE BUSBAR

- Central point of power supply: 130A max
- Side point of power supply: 80A max
- Pitch: 18mm/0.7in
- Busbar section: 10mm²
- Number of module/poles: 3
- For paralleling connection
- Length (standard supplied): 1m/3.3ft which can be cut in shorter sections.

12

#### Fuse holder assembly in multiple pole configuration



ⓘ Not suitable for FB01 B1N, FB01 B2P, FB01 B3P and FB01 B3N types.

1454


# Fuse holders

Dimensions [mm (in)]




## FUSE HOLDERS


FB01 A... FB01 B... FB01 C... FB01 D...



FB02 A...



FB03 A...




12


*Handwritten signature*

## FUSES

FE01 D O...



## Wiring diagrams



*Handwritten signature*

*Large handwritten signature*

**ВАРНО С  
ОРИГИНАЛ**



*Handwritten signature*

# Fuse holders

## Technical characteristics



TYPE	FB01 A...	FB01 B...	FB02 A...	FB03 A...	FB01 C...	FB01 D...
Range	AC				Class CC (AC)	DC
IEC maximum rated current I <sub>n</sub>	32A		50A	125A	30A	32A
IEC maximum rated voltage I <sub>n</sub>	690VAC; 400VAC ⊕	690VAC			600VAC	1000VDC
IEC utilisation category	AC22B 500V; AC21B 690V; AC22B 400V ⊕			AC21B 690V	AC22B 500V; AC21B 690V	DC20B 1000VDC
Maximum power dissipation	3W		5W	9.5W	3W	4W
Derating factor of current I <sub>n</sub> for different ambient temperatures	20°C	1				
	30°C	0.95				
	40°C	0.9				
	50°C	0.8				
	60°C	0.7				
	70°C	0.5				
Derating factor of current I <sub>n</sub> for side-by-side fuse holders - n° poles	1-4	1				
	5-6	0.8				
	7-9	0.7				
	≥10	0.6				
Voltage for status indicator	120...690VAC		230...690VAC		120...600VAC	350...1000VDC

### CONNECTIONS

Maximum tightening torque	2.5Nm; 2Nm ⊕ / 22lbin	3Nm / 26lbin	4Nm / 35lbin	2.5Nm / 22lbin		
Maximum conductor cross section	flexible/stranded	1x16mm <sup>2</sup> ; 1-15mm <sup>2</sup> ⊕ / 8AWG	1x25mm <sup>2</sup> / 6AWG	1x35mm <sup>2</sup> / 2AWG	1x16mm <sup>2</sup> / 8AWG	1x16mm <sup>2</sup> / 6AWG
	rigid/solid	1x25mm <sup>2</sup> ; 1-10mm <sup>2</sup> ⊕ / 8AWG	1x35mm <sup>2</sup> / 8AWG	1x50mm <sup>2</sup> / 1AWG	1x25mm <sup>2</sup> / 10AWG	1x25mm <sup>2</sup> / 4AWG

### AMBIENT CONDITIONS

Operating temperature	-20...+70°C
Storage temperature	-40...+80°C
Maximum altitude	3,000m
Operation position	Any
Fixing	On 35mm DIN rail (IEC/EN 60715)


⊕ Values valid only for FB01 A 1M type.

12

### TECHNICAL CHARACTERISTICS FOR FE01 D... FUSES

TYPE	Rated current [A]	Power consumption at 0.7 I <sub>n</sub> [W]	Power consumption at I <sub>n</sub> [W]	Prearcing I <sup>2</sup> t [A <sup>2</sup> s]	Total I <sup>2</sup> t at 1000VDC [A <sup>2</sup> s]
FE01 D 00200	2	0.62	1.54	1.78	6.5
FE01 D 00400	4	0.73	1.84	3	11
FE01 D 00600	6	0.96	2.4	8.5	32
FE01 D 00800	8	1.02	2.55	25	93
FE01 D 01000	10	1.03	2.58	11	52
FE01 D 01200	12	1.04	2.6	25	116
FE01 D 01600	16	1.08	2.7	33	152
FE01 D 02000	20	1.16	2.9	85	390

### TIME-CURRENT CHARACTERISTICS FOR FE01 D... FUSES





OPW/100 C  
INDONESIA



1-516





## Fuse holders and fuses

*Handwritten signature*


**Lovato**  
**electric**  
 100% electricity

**OPERAZIONALE**  
**OPERAZIONALE**



1457

# FUSE HOLDERS




- ◆ Modular concept for quick assembly of different versions based on various requirements.
- ◆ Compact size compliant with standards for electrical equipment.
- ◆ DIN rail mounting and removal ease.
- ◆ IP20 protection degree, finger safe.
- ◆ Sealable cover in open or closed position to increase user's safety.
- ◆ Version with status indicator to quickly determine if the fuse is still operative or needs to be replaced.
- ◆ Ergonomic grip for easy cover opening.
- ◆ Dedicated cylindrical 10x38 DC fuses for photovoltaic systems.
- ◆ UL and CSA certified versions.


Range	AC			DC	DC FUSES	CLASS CC
Fuse size	10x38	14x51	22x58	10x38	10x38	10x38
Type	gG or aM			gPV	gPV	Class CC
Rated voltage	690VAC			1000VDC / 690VAC	1000VDC	690VAC
Rated current	32A	50A	125A	32A	20A	30A
Utilisation category	AC-22B 500V AC-21B 690V		-	DC-20B 1000VDC AC-21B 690V	DC-20B 1000VDC	AC-22B 500V AC-21B 690V

*Handwritten signature*

1458



# and fuses




LOVATO Electric fuse holders can be used to protect against overloads and short circuits of electric lines, for motor protection and control and for the protection of electric installations.

This equipment can assure the disconnect function but is not suitable for isolation so cannot be used as switch disconnecter.

The range is available in two versions: with or without fuse status indicator. If the fuse fitted on the holder blows, the failure status is shown by the indicator on the fuse-holder front.

All the fuse holders are certified for the North-American market (UL Listed, UL Recognized and CSA). Furthermore, there is a non-certified version in 10x38mm size available too.

**LOVATO**  
electric



459


**Fuse holders**  
RANGE

**AC**

LOVATO Electric AC fuse-holder range is suitable for class gG fuses, to protect cables and conductors, and for class aM fuses, to protect motor starting.


Function: Overload and short-circuit protection of control circuits, motor controls, electric installations.

Usage: Service industry, electric panels onboard machinery, electric installations in general.




Fuse size	FB01 A...	FB01 B...	FB02 A...	FB03 A...
Version without indicator	10x38		14x51	22x58
Version with indicator			1P, 1P+N, 2P, 3P, 3P+N	1P
<b>Main characteristics</b>				
- Rated voltage			690VAC	
- Rated current	32A		50A	125A
- Utilisation category	AC-22B 500V, AC-21B 690V		AC-22B 500V, AC-21B 690V	
- Suitable for fuses	10x38 gG or aM		14x51 gG or aM	22x58 gG or aM
- Maximum conductor cross section	16mm <sup>2</sup> flexible/stranded; 25mm <sup>2</sup> rigid/solid		25mm <sup>2</sup> flexible/stranded; 35mm <sup>2</sup> rigid/solid	35mm <sup>2</sup> flexible/stranded; 50mm <sup>2</sup> rigid/solid
Certifications obtained	UR, CSA	-	cURus	cURus
Compliant with standards	IEC/EN 60947-1, IEC/EN 60947-3, RoHS directive, UL512, CSA C22.2 n°39			

UR: UL Recognized; cURus: UL Recognized for USA and Canada.



**Fuse holders**  
RANGE

**CLASS CC**





FB01 C...

LOVATO Electric fuse holders for class CC fuses are used to protect branch circuits, consisting of conductors and components following the last overcurrent protective device protecting a load, in industrial applications which require high breaking capacity.

Suitable only and exclusively for fitting fuses defined as "class CC", quite common on the North American market.

Usage: Service industry, electric panels onboard machinery, electric installations in general.


Fuse size	Class CC
Version without indicator	1P, 2P, 3P
Version with indicator	1P
<b>Main characteristics</b>	
- Rated voltage	600VAC
- Rated current	30A
- Utilisation category	AC-22B 500V, AC-21B 690V
- Suitable for fuses	10x38 class CC
- Maximum conductor cross section	16mm <sup>2</sup> flexible/stranded; 25mm <sup>2</sup> rigid/solid
Certifications obtained	UL, CSA
Compliant with standards	IEC/EN 60947-1, IEC/EN 60947-3, UL512, RoHS directives, CSA C22.2 n° 39



1460

## Fuse holders

# DC




FB01 D...

LOVATO Electric DC fuse holder range is suitable for 1000VDC rated voltage and gPV class.

Used for overload and short-circuit protection of photovoltaic modules (strings) and the relative connecting cables.

Fuse size	10x38
Version without indicator	1P, 2P
Version with indicator	1P
<b>Main characteristics</b>	
- Rated voltage	1000VDC / 690VAC
- Rated current	32A
- Utilisation category	DC-20B 1000VDC, AC-21B 690V
- Suitable for fuses	10x38 gPV
- Maximum conductor cross section	16mm <sup>2</sup> flexible/stranded, 25mm <sup>2</sup> rigid/solid
<b>Compliant with standards</b>	IEC/EN 60947-1, IEC/EN 60947-3, RoHS directive



## Fuses

# DC





FE01 D...

LOVATO Electric offers a range of cylindrical 10x38 fuses dedicated to photovoltaic duty and designed for 1000VDC maximum use.

Contrary to AC type fuses that blow for high overcurrent values, this type of DC fuse is designed to blow with low-intensity overcurrent values, created on photovoltaic cells and panels.

Fuses for photovoltaic application	
Breaking capacity	30kA
<b>Mains characteristics</b>	
- Rated voltage	1000VDC
- Rated current	2...20A



**LOVATO**  
electric

146A




## TECHNICAL CHARACTERISTICS


Type	FB01 A...	FB01 B...	FB02 A...	FB03 A...	FB01 C...	FB01 D...	
Range	AC	AC	AC	AC	Class CC (AC)	DC	
Certifications obtained	UR, CSA	-	cURus	cURus	UL, CSA	-	
Maximum power dissipation	3W	3W	5W	9.5W	3W	4W	
Derating factor of current I <sub>e</sub> for different ambient temperatures	20°C	1	1	1	1	1	
	30°C	0.95	0.95	0.95	0.95	0.95	
	40°C	0.9	0.9	0.9	0.9	0.9	
	50°C	0.8	0.8	0.8	0.8	0.8	
	60°C	0.7	0.7	0.7	0.7	0.7	
	70°C	0.5	0.5	0.5	0.5	0.5	
Derating factor of current I <sub>e</sub> for sid-by-side fuse holders - n° poles	1-3	1	1	1	1	1	
	4-6	0.8	0.8	0.8	0.8	0.8	
	7-9	0.7	0.7	0.7	0.7	0.7	
	>10	0.6	0.6	0.6	0.6	0.6	
Voltage for status indicator	120...690VAC	120...690VAC	230...690VAC	230...690VAC	120...600VAC	350...1000VDC	
<b>CONNECTIONS</b>							
Maximum tightening torque	2.5Nm/22lbin	2.5Nm/22lbin	3Nm/26lbin	4Nm/35lbin	2.5Nm/22lbin	2.5Nm/22lbin	
Maximum conductor cross section	flexible/stranded	1-16mm <sup>2</sup> /8 AWG	1-16mm <sup>2</sup> /6 AWG	1-25mm <sup>2</sup> /4 AWG	1-35mm <sup>2</sup> /2 AWG	1-16mm <sup>2</sup> /8 AWG	1-16mm <sup>2</sup> /6 AWG
	rigid/solid	1-25mm <sup>2</sup> /8 AWG	1-25mm <sup>2</sup> /4 AWG	1-35mm <sup>2</sup> /2 AWG	1-50mm <sup>2</sup> /1 AWG	1-25mm <sup>2</sup> /10 AWG	1-25mm <sup>2</sup> /4 AWG
<b>AMBIENT CONDITIONS</b>							
Operating temperature	-20...+70°C	-20...+70°C	-20...+70°C	-20...+70°C	-20...+70°C	-20...+70°C	
Storage temperature	-40...+80°C	-40...+80°C	-40...+80°C	-40...+80°C	-40...+80°C	-40...+80°C	
<b>HOUSING</b>							
Din rail mount version	Yes	Yes	Yes	Yes	Yes	Yes	
Degree of protection	IP20	IP20	IP20	IP20	IP20	IP20	

## DIMENSIONS


FB01 A... FB01 B... FB01 C... FB01 D...



FB02 A...




FB03 A...



## ASSEMBLY

Accessories: Coupling elements (clips and pins) to mount and fix fuse holders side by side



**Lovato**  
electric

1462

## HOW TO ORDER

### FUSE HOLDERS

Order code	Pole arrangement	DIN modules n°	Status indicator	Rated voltage Ue [V]	Rated nominal current Ie [A]	Qty per pkg n°	Weight [kg]
Fuse holder (fuse disconnecter), 10x38, certified by UR and CSA.							
FB01 A 1P	1 pole	1	-	690VAC	32	12	0.750
FB01 A 1PL	1 pole	1	Yes	690VAC	32	12	0.750
FB01 A 1N	1 pole + N	2	-	690VAC	32	6	0.750
FB01 A 2P	2 poles	2	-	690VAC	32	6	0.750
FB01 A 3P	3 poles	3	-	690VAC	32	4	0.750
FB01 A 3N	3 poles + N	4	-	690VAC	32	3	0.750
Fuse holder (fuse disconnecter), 14x51, certified by cURus.							
FB02 A 1P	1 pole	1.5	-	690VAC	50	6	1.000
FB02 A 1PL	1 pole	1.5	Yes	690VAC	50	6	1.000
FB02 A 1N	1 pole + N	3	-	690VAC	50	3	1.000
FB02 A 2P	2 poles	3	-	690VAC	50	3	1.000
FB02 A 3P	3 poles	4.5	-	690VAC	50	2	1.000
FB02 A 3N	3 poles + N	6	-	690VAC	50	1	0.650
Fuse holder (fuse disconnecter), 22x58, certified by cURus.							
FB03 A 1P	1 pole	2	-	690VAC	125	6	1.050
FB03 A 1PL	1 pole	2	Yes	690VAC	125	6	1.050
FB03 A 1N	1 pole + N	4	-	690VAC	125	3	1.050
FB03 A 2P	2 poles	4	-	690VAC	125	3	1.050
FB03 A 3P	3 poles	6	-	690VAC	125	2	1.050
FB03 A 3N	3 poles + N	8	-	690VAC	125	1	0.700
Fuse holder (fuse disconnecter), class CC, certified by UL and CSA.							
FB01 C 1P	1 pole	1	-	600VAC	30	12	0.750
FB01 C 1PL	1 pole	1	Yes	600VAC	30	12	0.750
FB01 C 2P	2 poles	2	-	600VAC	30	6	0.750
FB01 C 3P	3 poles	3	-	600VAC	30	4	0.750
Fuse holder (fuse disconnecter), 10x38.							
FB01 B 1P	1 pole	1	-	690VAC	32	12	0.750
FB01 B 1PL	1 pole	1	Yes	690VAC	32	12	0.750
FB01 B 1N	1 pole + N	2	-	690VAC	32	6	0.750
FB01 B 2P	2 poles	2	-	690VAC	32	6	0.750
FB01 B 3P	3 poles	3	-	690VAC	32	4	0.750
FB01 B 3N	3 poles + N	4	-	690VAC	32	3	0.750
Fuse holder (fuse disconnecter), 10x38, for photovoltaic applications.							
FB01 D 1P	1 pole	1	-	1000VDC	32	12	0.750
FB01 D 1PL	1 pole	1	Yes	1000VDC	32	12	0.750
FB01 D 2P	2 poles	2	-	1000VDC	32	6	0.750

### FUSES FOR PHOTOVOLTAIC APPLICATIONS


Order code	Rated breaking capacity [kA]	Rated voltage Ue [V]	Rated current Ie [A]	Qty per pkg n°	Weight [kg]
FE01 D 00200	30	1000VDC	2	10	0.130
FE01 D 00400	30	1000VDC	4	10	0.130
FE01 D 00600	30	1000VDC	6	10	0.130
FE01 D 00800	30	1000VDC	8	10	0.130
FE01 D 01000	30	1000VDC	10	10	0.130
FE01 D 01200	30	1000VDC	12	10	0.130
FE01 D 01500	30	1000VDC	16	10	0.130
FE01 D 02000	30	1000VDC	20	10	0.130

### ACCESSORIES

Order code	Description	Qty per pkg n°	Weight [kg]
FBX 00	Coupling clip for 10x38, 14x51 and 22x58 sizes	100	0.050
FBX 01	Coupling pin for 10x38 size	100	0.130
FBX 02	Coupling pin for 14x51 and 22x58 sizes	100	0.150


N.B. Two clips FBX 00 and one pin FBX 01 are needed to couple two fuse holder FB01 types.  
Three clips FBX 00 and one pin FBX 02 are needed to couple two fuse holder FB02 and FB03 types.


### WIRING DIAGRAMS



1453

Lovato electric











2011




Switch disconnectors  
16 to 1600A




Modular digital multimeters



Flush-mount digital multimeters  
and power analyzers




Energy meters



Automatic transfer switch  
controllers



Switching power supplies



100% electricity


Switch

DTM

Logic

- Motor protection circuit breakers
- Switch disconnectors
- Contactors
- Motor protection relays
- Electromechanical starters
- Control and signalling units
- Limit, micro and foot switches
- Rotary cam switches
- Modular contactors
- Time relays
- Protection relays
- Level control relays
- Earth leakage relays
- Fuse holders
- Metering instruments and current transformers
- Soft starters
- AC motor drives
- Automatic power factor controllers
- Automatic battery chargers
- Automatic transfer switch controllers
- Programmable logic relays
- Switching power supplies
- Expansion modules and accessories

*Handwritten signature*



[www.LovatoElectric.com](http://www.LovatoElectric.com)

LOVATO ELECTRIC S.P.A.  
CONTROL SOLUTIONS FOR INDUSTRY  
VIA DON E. MAZZA, 12 - 24020 GORLE (BERGAMO) ITALY  
Tel. +39 035 4282111 Fax +39 035 4282200  
E-mail: [info@LovatoElectric.com](mailto:info@LovatoElectric.com)

Sales department: Tel. +39 035 4282354 Fax +39 035 4282400

LOVATO Electric offices in the world

United Kingdom  
LOVATO (UK) LTD  
Tel. +44 8458 110023  
[www.Lovato.co.uk](http://www.Lovato.co.uk)

Czech Republic  
LOVATO S.R.O.  
Tel. +420 382 265482  
[www.Lovato.cz](http://www.Lovato.cz)

Germany  
DELTEC LOVATO GmbH  
Tel. +49 7237 1732  
[www.Deltec-lovato.de](http://www.Deltec-lovato.de)

USA  
LOVATO ELECTRIC INC  
Tel. +1 757 546 4700  
[www.LovatoUsa.com](http://www.LovatoUsa.com)

Spain  
LOVATO ELECTRIC S.L.U.  
Tel. +34 93 7842616  
[www.LovatoElectric.es](http://www.LovatoElectric.es)

Canada  
LOVATO ELECTRIC  
CORPORATION  
Tel. +1 450 681 9200  
[www.Lovato.ca](http://www.Lovato.ca)

Poland  
LOVATO ELECTRIC SP. Z O.O.  
Tel. +48 71 7979010  
[www.LovatoElectric.pl](http://www.LovatoElectric.pl)

Mexico  
LOVATO ELECTRIC  
DE MEXICO, S.A. DE C.V.  
Tel. +52 555 3415662  
[www.LovatoElectric.com.mx](http://www.LovatoElectric.com.mx)

The products described in this publication are subject to be revised or improved at any moment. Catalogue descriptions and details, such as technical and operational data, drawings, diagrams and instructions, etc., do not have any contractual value. In addition, products should be installed and used by qualified personnel and in compliance with the regulations in force for electrical systems in order to avoid damages and safety hazards.

[ClaroEmporitoCreativo@gmail.com](mailto:ClaroEmporitoCreativo@gmail.com)

PROB 08 01 11

1464

## ТЕХНИЧЕСКИ ХАРАКТЕРИСТИКИ

Предлаганите клемми са производство на фирма Phoenix Contact – Германия. Фирмата е сертифицирана по ISO 9001. Клемите са тествани и са в съответствие с IEC 60 947-7-1, IEC 60947-1, IEC 60695-2-2, EN 50019, а също така притежават и други сертификати, които са дадени за всяка клемма в каталога.

Клемите на Phoenix Contact са с универсална основа за закрепване както към симетрична шина NS 35/7,5, NS 35/15, така и към несиметрична - NS 32. Кабелните входове на клемата са затворени фунии, което улеснява въвеждането на проводника. Всички клемми имат гнезда за индивидуално и рационално маркиране.

Предлаганите клемми, производство на Phoenix Contact притежават следните по-важни качества:

- **всички метални части са устойчиви на електролитна корозия и ръжда**

Всички метални елементи на клемите са изработени от медна сплав, с високо съдържание на мед, като напълно се избягва използването на стомана. Това елиминира две възможни причини за корозия: Едната е електролитна корозия, която възниква между медния проводник и стоманата, при наличие на влага. Втората е ръждата и последиците от нея – ненадежден електрически контакт, блокирани винтчета. Използването само на медна сплав има и допълнителни предимства като: 1) ниско температурно повишение, поради високата електрическа проводимост и 2) по-малко вероятно е разхлабване на винтчетата, тъй като практически няма относително термично разширение между проводника и притискащата част.

Повърхността на металните части е защитена с калаено или никелово галванично покритие.

- **блокиране на винтчетата срещу саморазвиване**


Phoenix Contact притежава патент, наречен "Reakdyn principle" за предпазване на винтчетата от саморазвиване. Конструкцията на притискащата част е на принципа на движеща се клетка. При завъртане на винта, той натиска тоководещата част и издърпва проводника в клетката към тоководещата част. Поради високата притискаща сила проводника се интегрира в мекото калаено покритие на тоководещата част. Така се постига контактното съпротивление което превишава изискванията на IEC 60 947-7-1, като за клемма 4 mm<sup>2</sup> то е 0,3mΩ.

Поради специалната си форма при затягане на винтчето горната част на клетката се деформира еластично и предизвиква нарастваща триеща сила в главата на винтчето, която не му позволява да се саморазвие.

- **надежна механична и електрическа връзка, съгласно IEC 60 947-7-1**

Конструкцията на притискащата част на клемата не само удовлетворява тези изисквания, но дори ги надвишава, поради следните качества: 1) Равната основа на притискащата част гарантира, че дори и най-тънкия проводник ще бъде стегнат както трябва., 2) напречните жлебове на тоководещата част гарантират нарушаване оксидацията по проводника, без да го извиват и така осигуряват добър контакт., 3) стабилната конструкция на притискащите части, заедно с високата точност при изработка, осигуряват връзка, недопускаща проникването на газ, както и голяма

1465



сила на притискане. Това означава, че условията за контакт могат да се поддържат стабилни за дълъг период от време, дори в агресивна атмосфера.

**- качества на изолационния материал**


Изолационния материал на клемите, които са предмет на настоящия търг е Полиамид 6.6. Този материал е одобрен от всички оторизирани лаборатории като CSA, NEMKO, KEMA, VDE и др. Той има отлични електрически, механични, химически и други качества, дори при високи температури. Позволени са кратковременно температури до 200° С. Полиамида абсорбира вода до 2,8%, но тази влага не е във формата на кристализирана вода в пластмасата, а е химически свързана в молекулната структура. Това прави пластмасата гъвкава и нечуплива, дори при ниски температури от -40° С. Полиамида има клас на негоримост V0, съгласно UL 94.

Максималния допустим ток на клемите зависи от максимално допустимото сечение на проводника и е в съответствие с IEC 60947-7-1.

**Съответствие на техническите изисквания**

Съгласно горното, предлаганите клемите притежават следните характеристики в съответствие с техническите изисквания:

1. Проводниците се присъединяват към клемите чрез винтова връзка, осигуряваща необслабваща електрическа връзка при вибрации и стареене;
2. Проводимите и притискащи части са устойчиви срещу електролитна корозия и ръжда. Гарантиран клас на негоримост – V0 съгласно UL 94;
3. Повишена механична устойчивост;
4. Изолационният материал не абсорбира влага;
5. Клемите са с гнезда за поставяне на етикети от двете страни;
6. Клемите се монтират върху универсална монтажна рейка. Възможен е монтаж както както към симетрична шина NS 35/7,5, NS 35/15, така и към несиметрична - NS 32
7. Токови клемите:
  - Пофазно шунтиране на токовете вериги към ТТ с подвижни (фиксиращи към клемата) или преносими изолирани мостове, съгласно приложената схема;
  - Видимо разкъсване на токовете вериги след шунтиране;
  - Включване на товарно устройство за тестване – монтирана или с възможност за монтаж на тест бокса с диаметър 4mm;
  - Видимо разделяне на токовете вериги по предназначение (ядра);
8. Напреженови вериги:
  - Видимо разкъсване ;
  - Включване на товарно устройство за тестване – монтирана или с възможност за монтаж на тест бокса с диаметър 4mm;
  - Възможност за видимо разделяне на напрежените вериги по фази и предназначение;
  - Възможност за включване на измервателни уреди от двете страни на клемата;



1/4 GG

## Кратко описание на предложените клеми и аксесоари към тях

### 1. URTK/S

Клеми с винтова връзка за присъединяване на кръгъл твърд проводник до  $10\text{mm}^2$  или гъвкав проводник с/без накрайник до  $6\text{mm}^2$ . Клемата е с възможност за фиксирано разкъсване на връзката, с гнезда за присъединяване на тестови проводници или за поставяне на шунтиращи мостчета от двете страни на клемата - щифт  $4\text{mm}$ . Тази клема е универсална и удовлетворява всички изисквания за яснота на веригата, удобства за превключване. Клемата предлага няколко типа на замостване: чрез конектори с изолирана ръкохватка (2, 4 поз.), превключващи мостове (2, 4 поз.) за окъсяване на трансформаторни вериги, фиксиран мост – 10 позиционен, делим, окомплектован с винтове. Гнездата за тестови проводник или шунтиращ конектор всяка страна са независими от винта за присъединяване на проводника.

### 2. URTK/SP

Клеми с винтова връзка за присъединяване на кръгъл твърд проводник до  $10\text{mm}^2$  или гъвкав проводник с/без накрайник до  $6\text{mm}^2$ . Клемата е с възможност за фиксирано разкъсване на връзката, с гнезда за присъединяване на тестови проводници или за поставяне на шунтиращи мостчета от двете страни на клемата - щифт  $4\text{mm}$ . Тази клема е универсална и удовлетворява всички изисквания за яснота на веригата, удобства за превключване и защита от допир до тоководещи части. Клемата предлага няколко типа на замостване: чрез изолирани превключващи мостове (2, 3, 4, 10 поз.), неизолиран фиксиран мост, конектори с изолирана ръкохватка (2, 4 поз.) Гнездата за тестови проводник или шунтиращ конектор са напълно изолирани.

### 3. D-URTK

Крайна капачка за клема URTK/S.

### 4. Разделителна пластина ATP-URTK/SP.

Секционна разделителна пластина за визуално и електрическо разделяне на клемни групи за директен монтаж на DIN шина. Дебелина: 2 мм.

Подходяща за използване с всички токови и напреженови клеми.

### 5. Шунтиращ мост SB 2-RTK/S.

Двупозиционен подвижен, шунтиращ мост за клеми URTK/S.

### 6. Шунтиращ мост SB 2-URTK/SP.

Двупозиционен изолиран, подвижен, шунтиращ мост за клеми URTK/SP.

### 7. Фиксатор за клемен пакет CLIPFIX 35.

Фиксатор със зацепване за симетрични шини  $35/7,5\text{ мм}$ ,  $35/15\text{ мм}$ .

Ширина:  $9,5\text{ мм}$ . Материал: полиамид.

Клас на запалимост: V0. Цвят: сив.

Може да се маркира със стандартни клемни маркировки ZB, маркировки: KLM, KLM 2.


на основание чл. 2 от ЗЗЛД

Съставил:



Инж  
"Ви"



1477



*Handwritten signature*



*Handwritten number 1478*

**ВИБ ИЗОМОТИК ООД**  
 1680 София, ул. "Тинек" №10А  
 тел. 02 558 63 40, 558 63 44, 558 31 11, факс 558 22 70

СЪГЛАСВАЛИ

ЧАСТИ	Лист №1 / 1
КОДОС РЪ	Индустриал -

ВЪЗДУХИТЕЛИ

Чертежи  
 Р-1, фирмен инж. Вл. Давидов

*Handwritten signature*



PHOENIX CONTACT GmbH & Co. KG  
 Flachmarktstraße 8  
 32825 Blomberg, Germany  
 Telefon: +49 5235 300  
 Telefax: +49 5235 3-41200  
 Internet: <http://www.phoenixcontact.com>  
 USt-Id-Nr.: DE124613250  
 WEEE-Reg.-Nr.: DE50738265

PHOENIX CONTACT GmbH & Co. KG · 32823 Blomberg

TO WHOM IT MAY CONCERN

Development Quality Laboratory  
 Business Unit  
 Industrial Connection Technology

Phone: ++49 / (0) 52 35/34 20 71  
 Fax: ++49 / (0) 52 35/341 2 06

04<sup>st</sup> of Decembre 2009

**Confirmation**

Dear Sir or Madam,

We hereby confirm that the universal test disconnect terminal block URTK/S (031 1087) is applicable at the rated insulation voltage up to 500 V in accordance to IEC 60947-7-1:2002-07 (partly)

Yours sincerely

PHOENIX CONTACT GmbH & Co. KG  
 на основании чл. 2 от 33ЛД

i.V. Dipl.-Phys. Ing. Alessandro Alberani  
 Head of Development  
 Quality Laboratory  
 Business Unit ICT

i.V. Dipl.-Phys. Ing. Alessandro Alberani


PHOENIX CONTACT GmbH & Co. KG  
 Flachmarktstraße 8  
 32825 Blomberg, Germany  
 Development Quality Laboratory  
 Business Unit  
 Industrial Connection Technology

Pers. haftende Gesellschafterin:  
 Phoenix Contact Verwaltungs GmbH  
 Amtsgericht Lemgo HRB 5273  
 Kom. Ges. Amtsgericht Lemgo HRA 3746

Geschäftsführer: Klaus Eisert,  
 Roland Bent, Dr. Martin Heubeck,  
 Prof. Dr. Gunther Olesch,  
 Frank Stührenberg, Dr. Heinz Wesch

Deutsche Bank AG Essen  
 (BLZ 360 700 50) 226 266 500  
 Commerzbank Lemgo  
 (BLZ 476 400 51) 226 030 500

Stadtparkasse Blomberg  
 (BLZ 476 512 25) 44 008  
 Postbank Essen  
 (BLZ 360 100 43) 75 054 34



He 79



PHOENIX CONTACT GmbH & Co. KG  
 Flachsmarktstraße 8  
 32825 Blomberg, Germany  
 Telefon: ++49 / (0) 52 35/300  
 Telefax: ++49 / (0) 52 35/34 12 00  
 Internet: <http://www.phoenixcontact.com>  
 USt-Id-Nr.: DE124613250

PHOENIX CONTACT GmbH & Co. KG · 32823 Blomberg

TO WHOM IT MAY CONCERN

Development Quality Laboratory  
 Business Unit  
 Industrial Connection Technology

Telefon: ++49 / (0) 52 35/34 20 71  
 ++49 / (0) 52 35/34 10 97  
 Telefax: ++49 / (0) 52 35/34 12 06

04<sup>th</sup> of Decembre 2009

**Certification regarding the static use of modular terminal blocks in the temperature range from -60°C to +120°C**

Dear Sir or Madam,

Based on the available documentation of our plastic suppliers, we herewith certify for the non-reinforced polyamide plastics used in the area of CLIPLINE (Industrial Connection Technology) as follows:

Considering self-heating, articles made of the above materials can be used in static operation from -60°C to +120°C.

Best regards

PHOENIX CONTACT GmbH & Co. KG

PHOENIX CONTACT GmbH & Co. KG  
 Flachsmarktstraße 8  
 Germany  
 Laboratory  
 на основание чл. 2 от 33ЛД

на основание чл. 2 от 33ЛД

i.v. Dipl.-Phys. Ing. Alessandro Alberanti  
 Head of Development  
 Quality Laboratory  
 Business Unit ICT

i.A. Dipl.-Chem. Ing. J. Jacke



Pers. haftende Gesellschafterin:  
 Phoenix Contact Verwaltungs GmbH  
 Amtsgericht Lemgo HRB 5273  
 Kom. Ges. Amtsgericht Lemgo HRA 3746

Geschäftsführer: Klaus Eisert,  
 Roland Bent, Dr. Martin Heuback,  
 Prof. Dr. Günther Olesch,  
 Frank Stührenberg, Dr. Heinz Wesch

Deutsche Bank AG Essen  
 (BLZ 360 700 50) 226 266 500  
 Commerzbank Lemgo  
 (BLZ 476 400 51) 226 039 600

Stadtsparkasse Blomberg  
 (BLZ 476 512 25) 44 006  
 Postbank Essen  
 (BLZ 360 100 43) 75 954 34

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*



# CERTIFICATE

Contract No. 97413715

Client:  
Phoenix Contact GmbH & Co.  
Rathenowerstrasse 6-28  
BLOMBERG, Germany

Manufacturer/Supplier:  
Phoenix Contact GmbH & Co.  
Rathenowerstrasse 6-28  
BLOMBERG, Germany

Product: Terminal Blocks

Trade name: PHOENIX CONTACT  
Types/models: URTK/S-BEN BU, URTK/S-BEN, URTK/S, URTK/SP,  
USLKG 10, USLKG 8N

The product and any applicable standards referred to is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above mentioned product has been certified on the basis of:

- a type test according to the standards EN 60947-1:1991, EN 60947-7-2:1995
- an inspection of the production process according to CCA Group Operational Document OCA 207
- a certification agreement with the number 900469

KEMA hereby grants the right to use the KEMA certification mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: August 6, 1999

на основании чл. 2 от 33ЛД

C. M. Boschloo  
Certification Manager

\* Integral publication of this certificate is allowed

N.V. KEMA  
Utrechtseweg 310, 6812 AR Arnhem, The Netherlands  
P.O. Box 9036, 6800 ET Arnhem, The Netherlands  
Telephone +31 26 3 56 28 50, Telefax +31 26 3 51 49 22

ACCREDITED BY  
THE DUTCH COUNCIL  
FOR ACCREDITATION



*[Handwritten signature]*

1481



## SPECIFICATION OF THE CERTIFIED PRODUCT

**Product data**  
product : terminal blocks  
trade name : PHOENIX CONTACT  
types : URTK/S-BEN BU, URTK/S-BEN, URTK/S,  
URTK/SP, USLKG 10, USLKG 6N  
material : thermoplastic material  
mounting : top hat rail 35 mm (EN 50022) and G-profile  
rail 32 mm (EN 50035)

### Additional Information

#### Markings

Trademark, type designation, rated connection capacity and rated insulation voltage are indented in the insulation material.


#### Product data – type USLKG 6N

rated connection capacity : 6 mm<sup>2</sup>  
connectable conductors : one conductor  
0,2 - 10 mm<sup>2</sup> solid  
0,2 - 6 mm<sup>2</sup> flexible without ferrule  
0,25 - 6 mm<sup>2</sup> flexible with ferrule  
two conductors  
0,2 - 2,5 mm<sup>2</sup> solid  
0,2 - 2,5 mm<sup>2</sup> flexible without ferrule  
0,25 - 1,5 mm<sup>2</sup> flexible with ferrule  
description : protective conductor terminal block with 2  
screw-type clamping units, 1-pole

#### Product data – type URTK/S

rated voltage : 400 V  
rated connection capacity : 6 mm<sup>2</sup>  
connectable conductors : one conductor  
0,5 - 10 mm<sup>2</sup> solid  
0,5 - 6 mm<sup>2</sup> flexible without ferrule  
0,5 - 10 mm<sup>2</sup> flexible with ferrule  
two conductors  
0,5 - 2,5 mm<sup>2</sup> solid  
0,5 - 6 mm<sup>2</sup> flexible without ferrule  
0,5 - 4 mm<sup>2</sup> flexible with ferrule  
rated impulse withstand voltage : 6 kV  
description : disconnect terminal block with 2 screw-type  
clamping units, 1-pole

N.V. KEMA  
Utrechtseweg 310, 6812 AR Arnhem, The Netherlands  
P.O. Box 9036, 6800 ET ARNHEM, The Netherlands  
Telephone +31 26 3562850, Telefax +31 26 3514922



1482

**Product data – type USLKG 10**

rated connection capacity : 6 mm<sup>2</sup>  
connectable conductors : one conductor  
0,5 - 10 mm<sup>2</sup> solid  
0,5 - 6 mm<sup>2</sup> flexible without ferrule  
0,5 - 6 mm<sup>2</sup> flexible with ferrule  
two conductors  
0,5 - 2,5 mm<sup>2</sup> solid  
0,5 - 2,5 mm<sup>2</sup> flexible without ferrule  
0,5 - 2,5 mm<sup>2</sup> flexible with ferrule  
description : protective conductor terminal block with 2  
screw-type clamping units, 1-pole

**Product data – type URTK/S-BEN**

rated voltage : 500 V  
rated connection capacity : 6 mm<sup>2</sup>  
connectable conductors : one conductor  
0,5 - 10 mm<sup>2</sup> solid  
0,5 - 6 mm<sup>2</sup> flexible without ferrule  
0,5 - 10 mm<sup>2</sup> flexible with ferrule  
two conductors  
0,5 - 2,5 mm<sup>2</sup> solid  
0,5 - 6 mm<sup>2</sup> flexible without ferrule  
0,5 - 4 mm<sup>2</sup> flexible with ferrule  
rated impulse withstand voltage : 6 kV  
description : disconnect terminal block with 2 screw-type  
clamping units, 1-pole

**Product data – type URTK/S-BEN BU**

rated voltage : 500 V  
rated connection capacity : 6 mm<sup>2</sup>  
connectable conductors : one conductor  
0,5 - 10 mm<sup>2</sup> solid  
0,5 - 6 mm<sup>2</sup> flexible without ferrule  
0,5 - 10 mm<sup>2</sup> flexible with ferrule  
two conductors  
0,5 - 2,5 mm<sup>2</sup> solid  
0,5 - 6 mm<sup>2</sup> flexible without ferrule  
0,5 - 4 mm<sup>2</sup> flexible with ferrule  
rated impulse withstand voltage : 6 kV  
description : disconnect terminal block with 2 screw-type  
clamping units, 1-pole

N.V. KEMA  
Utrechtseweg 310, 6812 AR Arnhem, The Netherlands  
P.O. Box 9035, 6800 ET ARNHEM, The Netherlands  
Telephone +31 26 3562850, Telefax +31 26 3514922

COPIED FROM ORIGINAL  
KEMA



1483

**Product data – type URTK/SP**

rated voltage : 500 V  
rated connection capacity : 6 mm<sup>2</sup>  
connectable conductors : one conductor  
0,5 - 10 mm<sup>2</sup> solid  
0,5 - 6 mm<sup>2</sup> flexible without ferrule  
0,5 - 6 mm<sup>2</sup> flexible with ferrule  
two conductors  
0,5 - 2,5 mm<sup>2</sup> solid  
0,5 - 4 mm<sup>2</sup> flexible without ferrule  
0,5 - 2,5 mm<sup>2</sup> flexible with ferrule  
rated impulse withstand voltage : 6 kV  
description : disconnect terminal block with 2 screw-type clamping units, 1-pole

**TESTS**

**Test requirements**

EN 60947-7-1:1991 + C:1997-06 + A11:1997  
EN 60947-7-2:1995 + C:1996-01

**Test results**

The test results are laid down in KEMA test file 97.4117.13.

**Conclusion**

The examination proved that all test requirements were met.


на основание чл. 2 от ЗЗЛД

Tested by : H.L. Schendstok  
Checked by : L.J.W. van Mege




**FACTORY-LOCATION(S)**


Phoenix Contact GmbH & Co.  
Flachmarktstrasse 8-28, BLOMBERG, Germany



N.V. KEMA  
Utrechtseweg 310, 6812 AR Arnhem, The Netherlands  
P.O. Box 9035, 6800 ET ARNHEM, The Netherlands  
Telephone +31 26 3562850, Telefax +31 26 3514922



0484



DEVICE UNDER TEST ..... Fuse holder *FB01B types*

MANUFACTURER ..... Lovato Electric S.p.A.

TYPE OF TEST ..... Temperature rise test on FB01B fuse holders

DATE OF DEVICE RECEIPT ..... 27/04/2011

START / END TESTING ..... 29/04/2011 – 13/05/2011




SAMPLES STORING .....  Eliminated / returned to customer     Storage :

INDEX .....	1. PURPOSE OF TESTING .....	2
	2. TEST SAMPLES .....	2
	3. TEST METHOD .....	2
	4. TEST PROCEDURES .....	2
	5. TEST RESULTS .....	3
	6. TEST EQUIPMENT .....	5
	7. REMARKS & ANALYS .....	5
	8. ANNEX .....	6


ISSUE ..... 16/05/2011

COMPILED ..... STAFF LPR

APPROVED ..... RESP. LPR



The test results are related only to the exemplary tested and listed under the "test samples".



1485

**1. PURPOSE OF TESTING**

Requested test (according to the customer specification):  
Temperature rise at 690V – 32A on FB01B fuse holders

Test purpose:  
"Verify the good function of FB01B fuse holders ."

Test target:  
Pass the test.

**2. TEST SAMPLES**


- N. 1 FB01B1P fuse holder - 32A (10 x 38 mm), batch production number ...<sup>1</sup>
- N. 1 FB01B2P fuse holder - 32A (10 x 38 mm), batch production number ...<sup>1</sup>
- N. 1 FB01B3P fuse holder - 32A (10 X 38 mm), batch production number ...<sup>1</sup>

**3. TEST METHOD**

IEC 60947-3 (2008-08) Ed. 3.0 + IEC 60947-1 Ed. 5.1 (2011-03)  
Temperature rise (§ 8.3.3.1)




**4. TEST PROCEDURES**

Temperature rise ..... Test instruction LPR 051-1, rev. 4, dated 11/10/2010.



<sup>1</sup> not available  
<sup>1</sup> not available  
<sup>1</sup> not available

The test results are related only to the exemplary tested and listed under the "test samples".



114 86

**5. TEST RESULTS**

**5.1 TEMPERATURE RISE**

**5.1.1 WITH LEGRAND FUSE 32 A gG 400 V**

Sample under test .....N. 1 FB01B1P - 32A  
 N. 1 FB01B2P - 32A  
 N. 1 FB01B3P - 32A

**Test conditions**

Ambient temperature.....21 °C  
 Relative humidity.....46 %  
 Installation .....in vertical way, on DIN RAIL 35mm

Data sheet fusible used:

- Supplier .....Legrand
- Code .....cod, 133 32

**Test parameters**

Wiring of the main circuit

- cables section / length.....6,0 mm<sup>2</sup> / 1,0 m
- screws tightening nominal torque .....2,0 ÷ 2,5 N.m
- screws applied tightening torque .....2,0 N.m

Supply of the main circuit

- rated current.....I<sub>th</sub> = 25 - 32 A
- test current.....I = 32 A
- supply frequency.....50 Hz



**Test results**

See next page.

*[Handwritten signature]*

*[Handwritten signature]*

The test results are related only to the exemplary tested and listed under the "test samples".



*[Handwritten signature]*

1487



Temperature rise main circuit

	[K]			Standard limit EN60947-1 tab. 2
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Terminal L1	43	54	57	65
Terminal T1	39	51	52	65
Terminal L2	-	55	61	65
Terminal T2	-	49	58	65
Terminal L3	-	-	57	65
Terminal T3	-	-	50	65
Note .....	Silver plated-brass terminal			

Temperature rise for accessible parts

	[K]			Standard limit EN60947-1 tab. 3
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Line side	14	24	29	40
Load side	10	19	21	40
Left side	24	30	32	40
Right side	22	30	31	40
On front	18	24	29	40
Léver	9	16	17	40

The test results are related only to the exemplary tested and listed under the "test samples"



6. TEST EQUIPMENT AND INSTRUMENTS

6.1. TEST EQUIPMENT

Description	Used for	Full scale	Code
Current supply station	Power supply main circuit	20V – 50A	LPRA 065

6.2. MEASURING INSTRUMENTS

Description	Used to measure	Full scale	Code	Calibration expiration date
Thermohygrometer	Ambient temperature	-5 ÷ 50 °C	LPR 165	27/10/2011
Thermohygrometer	Relative humidity	10 ÷ 90%	LPR 165	27/10/2011
Termometric instrument	Temperature rise	-30 ÷ +200 °C	LPR 201	10/01/2012
Termocouple T type	Temperature rise	-30 ÷ +200 °C	LPR 201	10/01/2012
Termocouple T type	Temperature rise	-30 ÷ +200 °C	LPR 201.13	10/01/2012
Current transformer	Main circuit current	1.004/50 A	LPR 155	11/05/2012
Digital multimeter	Main circuit current	10 A	LPR 55	11/05/2012
Digital multimeter	Drop voltage	mV - Autom.	LPR 125	11/05/2012
Dynamometric screw driver	Main terminal screw tightening	6,0 Nm	LPR 231	07/01/2012

7. REMARKS & ANALYS

Temperature rise test 690V – 32A: test passed

The test results are related only to the exemplary tested and listed under the "test samples".





1489




8. ANNEX

Picture 1: Temperature rise – test setup



Picture 1a: Temperature rise – test setup




The test results are related only to the exemplary tested and listed under the "test samples"


*[Handwritten signature]*

1490

**LABORATORIO DI PROVA LOVATO ELECTRIC S.P.A.**  
CORTESE



Picture 2: Catalogue Legrand fuses





**Informazioni tecniche, curve e quote (p. 122)**

Inchiodato		Astrali		Inchiodato		Astrali		Tipo "aM"						
Series	Con	Interruttore (A)	Tensione (V~)	Potenza Interruttore (kVA)	Series	Con	Interruttore (A)	Tensione (V~)	Potenza Interruttore (kVA)	Dimensione (mm)				
<p><b>10,5 x 23 mm</b></p> <p>Conformi alle norme CEI 32-1, CEI 32-5 - EN 60 269-1, EN 60 269-3</p>														
10	0113 02	0114 02	2	250	10	0120 01	1	400	20	8,5 x 31,5 mm				
10	0113 04	0114 04	4		10	0120 02	2							
10	0113 06	0114 06	6		10	0120 04	4							
100	0113 10	0114 10	10		10	0120 06	6							
10	0123 01	0124 01	1	10	0120 08	8								
10	0123 02	0124 02	2	10	0120 10	10								
10	0123 04	0124 04	4	<p><b>10,5 x 38 mm</b></p> <p>Conformi alle norme CEI 32-1 e 32-4 - IEC 60 269-1, 2 e 2-1 - EN 60 269-1</p> <p>Approvazioni Bureau Veritas</p>										
10	0123 06	0124 06	6	400	20	10,5 x 38 mm	10	0130 02	0,25	100				
10	0123 08	0124 08	8				10	0130 04	0,50					
10	0123 10	0124 10	10				10	0130 01	1					
10	0123 12	0124 12	12				10	0130 02	2					
100	0123 16	0124 16	16	10	0130 04	4	10	0130 08	6					
100	0123 20	0124 20	20	10	0130 06	6	10	0130 10	8					
<p><b>14 x 51 mm</b></p> <p>Conformi alle norme CEI 32-1 e 32-4 - IEC 60 269-1, 2 e 2-1 - EN 60 269-1</p> <p>Approvazioni Bureau Veritas</p>														
10	0133 04	0134 04	4	500	100	14 x 51 mm	10	0140 02	0141 02		2			
10	0133 06	0134 06	6				10	0140 04	0141 04		4			
10	0133 08	0134 08	8				10	0140 06	0141 06		6			
10	0133 10	0134 10	10				10	0140 08	0141 08		8			
10	0133 12	0134 12	12				10	0140 10	0141 10	10				
10	0133 16	0134 16	16				10	0140 12	0141 12	12				
10	0133 20	0134 20	20				10	0140 16	0141 16	16				
10	0133 25	0134 25	25				10	0140 20	0141 20	20				
10	0143 02	0145 04	2				500	100	22 x 58 mm	10	0150 16	0151 16	16	
10	0143 04	0145 06	4							10	0150 20	0151 20	20	
10	0143 06	0145 10	6							10	0150 25	0151 25	25	
10	0143 10	0145 16	10	10	0150 32	0151 32				32				
10	0143 16	0145 20	16	10	0150 40	0151 40				40				
10	0143 20	0145 25	20	10	0150 50	0151 50				50				
10	0143 25	0145 32	25	10	0150 63	0151 63				63				
10	0143 32	0145 40	32	10	0150 80	0151 80				80				
10	0143 40	0145 40	40	10	0150 85	0151 85				85				
10	0143 50	0145 50	50	10	0150 95	0151 95				95				
10	0143 63	0145 63	63	10	0150 97	0151 97				97				
10	0143 80	0145 80	80	<p><b>Neutri</b></p>										
10	0143 96	0145 96	96	10	0123 00	8,5 x 31,5								
10	0143 97	0145 97	97	10	0133 00	10,5 x 38								
				10	0143 00	14 x 51								
				10	0153 00	22 x 58								

*Handwritten signature*

The test results are related only to the exemplary tested and listed under the "test samples".



1491


Annex to ISO/IEC 17025 declaration of accreditation  
for registration number: K 006

of **KEMA Nederland B.V.**  
**Calibration & Metering**  
**Arnhem**

This annex is valid from: **30-03-2010** to **01-03-2014**

Replaces annex dated: **30-06-2009**

Premises: **n.a.**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ( $k=2$ )	Remarks
LF 0 0	DC/LF Quantities			
LF 1 0	DC Voltage			
	Standard cells		3 $\mu$ V	
	Up to 1 mV		0,4 $\mu$ V	
	1 mV to 10 mV		$3 \cdot 10^{-4} \cdot U$	
	10 mV to 100 mV		$3 \cdot 10^{-5} \cdot U$	
	100 mV to 10 V		$5 \cdot 10^{-6} \cdot U$	
	10 V to 100 V		$1 \cdot 10^{-5} \cdot U$	
	100 V to 1100 V		$2 \cdot 10^{-6} \cdot U$	
	Zener Reference Standards			
	1 V and 1,018 V		3 $\mu$ V	
	10 V		20 $\mu$ V	
	High Voltage			Measuring
	1 kV to 6 kV		$2 \cdot 10^{-3} \cdot U$	
LF 2 0	DC Current			
	10 $\mu$ A to 3 A		$2 \cdot 10^{-5} \cdot I$	
	3 A to 10 A		$2,5 \cdot 10^{-5} \cdot I$	
	10 A to 20 A		$6 \cdot 10^{-5} \cdot I$	

This annex has been approved by:



Mr. J.C. van der Pijp  
Chief Executive



Annex to ISO/IEC 17025 declaration of accreditation  
for registration number: K 006

of **KEMA Nederland B.V.**  
**Calibration & Metering**  
**Arnhem**

This annex is valid from: **30-03-2010 to 01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ( $k=2$ )	Remarks
LF 3 1	20 A to 100 A		$1 \cdot 10^{-4} \cdot I$	
	AC Voltage			
	60 mV to 1000 V	40 Hz to 20 kHz	$2 \cdot 10^{-4} \cdot U$	
	60 mV to 1000 V	20 kHz to 50 kHz	$3 \cdot 10^{-4} \cdot U$	
	60 mV to 220 V	20 kHz to 50 kHz 50 kHz to 100 kHz	$4 \cdot 10^{-4} \cdot U$	
	220 V to 1000 V	50 kHz to 100 kHz	$4 \cdot 10^{-4} \cdot U$	
LF 3 2	High Voltage 1 kV tot 6 kV	50 Hz	$2 \cdot 10^{-3} \cdot U$	Measuring
	AC Voltage Ratio (instrument transformers) Primary: (10-600)V Secondary: (0,1-240)V	50 Hz and 60 Hz	$3 \cdot 10^{-5} \cdot U_{out}/U_{in}$ and $90 \mu\text{rad}$	
LF 3 3	AC Current			
	0,1 mA to 300 mA	40 Hz to 5 kHz	$3 \cdot 10^{-4} \cdot I$	
	300 mA to 20 A 20 A to 50 A	40 Hz to 1 kHz 40 Hz to 1 kHz	$3 \cdot 10^{-4} \cdot I$ $6 \cdot 10^{-4} \cdot I$	
LF 4 2	AC Current Ratio (instrument transformers)	50 Hz and 60 Hz	$3 \cdot 10^{-5} \cdot I_{out}/I_{in}$ and $90 \mu\text{rad}$	ambient temp. ( $23 \pm 2$ ) °C Measuring



1493


Annex to ISO/IEC 17025 declaration of accreditation  
for registration number: K 006

of **KEMA Nederland B.V.**  
**Calibration & Metering**  
**Arnhem**

This annex is valid from: 30-03-2010 to 01-03-2014

Replaces annex dated: 30-06-2009

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ( $k=2$ )	Remarks
	Primary: 5 A to 6000 A Secondary: 1A or 5A			
LF 4 3	High Current 10 A to 6000 A	50 Hz, 60 Hz	$3 \cdot 10^{-4} \cdot I$	
LF 5 0	Power and Energy			10 mV to 1100 V 10 $\mu$ A to 100 A
	Power			
	0,1 $\mu$ W to 1 $\mu$ W		$1 \cdot 10^{-4} \cdot P$	
	1 $\mu$ W to 1 kW		$5 \cdot 10^{-5} \cdot P$	
	1 kW tot 10 kW		$1 \cdot 10^{-4} \cdot P$	
	10 kW tot 110 kW		$2 \cdot 10^{-4} \cdot P$	
	3 W to 57,6 kW	50 Hz and 60 Hz	$\frac{3 \cdot 10^{-4}}{\cos \varphi} \cdot P$	on site to be performed at ambient temperature; voltage and current as mentioned above
	3 W to 2,9 MW	50 Hz and 60 Hz	$\frac{2 \cdot 10^{-4}}{\cos \varphi} \cdot P$	measuring 20 V to 1100 V 100 mA to 6000A $\cos \varphi = 0$ to 1
	Reactive Power ( $P_r$ ) 6 var to 1,8 Mvar	50 Hz and 60 Hz	$\frac{5 \cdot 10^{-4}}{\sin \varphi} \cdot P_r$	60 V to 300 V 100 mA to 6000 A
	Electrical (reactive-) energy			see (reactive-) power and time
LF 5 1	Power Factor $\cos \varphi : 0$ to 1	40 Hz to 100 Hz	$\frac{2 \cdot 10^{-3}}{\cos \varphi} \cdot PF$	




(1494)

Annex to ISO/IEC 17025 declaration of accreditation  
for registration number: K 006



of **KEMA Nederland B.V.**  
**Calibration & Metering**  
**Arnhem**

This annex is valid from: 30-03-2010 to 01-03-2014

Replaces annex dated: 30-06-2009

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ( $k=2$ )	Remarks
LF 6	Impedance (DC/LF)			
LF 6 2	DC Resistance			Non-decadic values
	20 $\mu\Omega$ to 50 $\mu\Omega$		$3 \cdot 10^{-4} \cdot R$	
	50 $\mu\Omega$ to 100 $\mu\Omega$		$1 \cdot 10^{-4} \cdot R$	
	100 $\mu\Omega$ to 20 k $\Omega$		$1,2 \cdot 10^{-5} \cdot R$	
	1 m $\Omega$ to 10 m $\Omega$		$6,5 \cdot 10^{-6} \cdot R$	
	10 m $\Omega$ to 1000 m $\Omega$		$7 \cdot 10^{-6} \cdot R$	
	1 $\Omega$ to 10 k $\Omega$		$5 \cdot 10^{-6} \cdot R$	
	10 k $\Omega$ to 1 M $\Omega$		$1 \cdot 10^{-5} \cdot R$	
	1 M $\Omega$ to 10 M $\Omega$		$1,2 \cdot 10^{-5} \cdot R$	
	10 M $\Omega$ to 100 M $\Omega$		$3 \cdot 10^{-5} \cdot R$	
	100 $\mu\Omega$ to 10 k $\Omega$		$6 \cdot 10^{-6} \cdot R$	Decadic Values
LF 6 4	Capacitance			accuracy depends on dissipation factor at 1 kHz
	LF Capacitance			
	10 pF to 100 pF	100 Hz, 1 kHz, 10 kHz	$1 \cdot 10^{-3} \cdot C$	
	1 $\mu$ F	50 Hz, 200 Hz, 1 kHz	$1 \cdot 10^{-3} \cdot C$	
LF 6 7	Inductance			
	1 mH to 10 mH	1 kHz, (400-1692)Hz	$1 \cdot 10^{-3} \cdot L$	
	100 mH	100 Hz, 1 kHz, 1,592 kHz	$1 \cdot 10^{-3} \cdot L$	
	1 H	100 Hz, 200 Hz, 400 Hz and 1 kHz	$1 \cdot 10^{-3} \cdot L$	
RF 0 0	RF Quantities			
RF 3 0	RF Power			
	-9 dBm to +30 dBm	0,1 MHz to 4200 MHz	0,5 dB	Measuring: 50 ohm coaxial VSWR:1
	+30 dBm to +57 dBm	0,1 MHz to 500 MHz	0,6 dB	
	-60 dBm to -10 dBm	10 MHz to 10000 MHz	0,5 dB	

1495




Annex to ISO/IEC 17025 declaration of accreditation  
for registration number: K 006

of **KEMA Nederland B.V.**  
**Calibration & Metering**  
**Arnhem**

This annex is valid from: **30-03-2010** to **01-03-2014**

Replaces annex dated: **30-06-2009**



HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ( $k=2$ )	Remarks
RF 5 0	-80 dBm to -10 dBm Rise time (10% to 90%) 1 ns to 1 ms	0,1 MHz to 2700 MHz	1,1 dB $2 \cdot 10^{-2} \cdot \tau + 200$ ps	source < 2 Generating: (0,09 - 3200) MHz 10 mV/div to 1 kV/div
TF 0 0	TIME and FREQUENCY			
TF 2 1	Frequency	1 Hz to 1,2 GHz	$5 \cdot 10^{-10} \cdot f$	
TF 2 2	Time interval	1 $\mu$ s to $\infty$	$5 \cdot 10^{-10} \cdot t + 100$ ns	
TF 3 2	Harmonic Distortion			
	< 0,1 % 0,1 % to 1 % 1 % to 10 % 10 % to 30 % 30 % to 100 %	20 Hz to 2,5 kHz 20 Hz to 2,5 kHz 20 Hz to 2,5 kHz 20 Hz to 2,5 kHz 20 Hz to 2,5 kHz	$3 \cdot 10^{-4}$ $1 \cdot 10^{-3}$ $3 \cdot 10^{-3}$ $1 \cdot 10^{-2}$ $3 \cdot 10^{-2}$	

Part II, Mechanical quantities and Temperature

Measured quantity, Instrument, Gauge	Range	Best measurement capabilities ( $k=2$ )	Remarks
PV 1 0 Pressure Relative Pressure	(-10 to 10) kPa (-98 to 100) kPa 100 kPa to 10 MPa (10 to 70) MPa	$3 \cdot 10^{-4} \cdot p_e + 4$ Pa $3 \cdot 10^{-4} \cdot p_e + 5$ Pa $3 \cdot 10^{-4} \cdot p_e$ $3 \cdot 10^{-4} \cdot p_e$	(2) medium: air medium: nitrogen medium: nitrogen medium: oil



1496





Annex to ISO/IEC 17025 declaration of accreditation  
for registration number: K 006

of **KEMA Nederland B.V.**  
**Calibration & Metering**  
**Arnhem**

This annex is valid from: **30-03-2010** to **01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ( $k=2$ )	Remarks
	Absolute Pressure	(80 to 110) kPa (2 to 200) kPa 200 kPa to 10 MPa (10 to 70) MPa	$3 \cdot 10^{-4} \cdot p$ $3 \cdot 10^{-4} \cdot p + 5 \text{ Pa}$ $3 \cdot 10^{-4} \cdot p$ $3 \cdot 10^{-4} \cdot p$	medium: air medium: nitrogen medium: nitrogen medium: oil
TE 00	TEMPERATURE, HUMIDITY AND THERMOPHYSICAL PROPERTIES			
TE 10	Resistance thermometers	-50 °C to 20 °C 20 °C to 50 °C 50 °C to 300 °C 300 °C to 550 °C 550 °C to 650 °C	0,02 K 0,05 K 0,05 K 0,16 K 0,50 K	 Including C.J. references 
TE 30	Thermocouples	-50 °C to 20 °C 20 °C to 50 °C 50 °C to 300 °C 300 °C to 550 °C 550 °C to 650 °C 650 °C to 1000 °C	0,16 K 0,16 K 0,16 K 0,21 K 0,6 K 1,6 K	
TE 40	Liquid-in-glass thermometers	-50 °C to 50 °C 20 °C to 50 °C 50 °C to 300 °C	0,02 K 0,04 K 0,02 K	
	Differential Temperature	-50 °C to 200 °C	0,05 K	
TE 41	Self indicating thermometers			



1498

**LABORATOIRE KEMA**  
**Calibration & Metering**  
**Arnhem**





Annex to ISO/IEC 17025 declaration of accreditation  
for registration number: K 006

of **KEMA Nederland B.V.**  
**Calibration & Metering**  
**Arnhem**

This annex is valid from: **30-03-2010 to 01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ( $k=2$ )	Remarks
	Dry Block Calibrators	-20 °C to 650 °C	$(8 \cdot 10^{-4} \cdot t_{60} + 0,06) \text{ K}$	including C.J. references resolution 1 digit
	Writing thermometers	15 °C to 50 °C	0,5 K	
	Digital thermometers	-50 °C to 20 °C	0,02 K	
		20 °C to 50 °C	0,05 K	
		50 °C to 300 °C	0,05 K	
		300 °C to 550 °C	0,16 K	
		550 °C to 630 °C	0,50 K	
		630 °C to 1000 °C	1,5 K	

Remarks:



The ambient temperature during calibration is, unless specified otherwise, for:  
 LF measurements @  $(23 \pm 1)^\circ\text{C}$   
 TF measurements @  $(23 \pm 1)^\circ\text{C}$   
 Pressure measurements @  $(23 \pm 2)^\circ\text{C}$   
 Temperature measurements @  $(23 \pm 2)^\circ\text{C}$

- (1) The stated best measurement capabilities are based on the fundamental frequency of the input signal. If desired the distortion can be specified as a rang number of the harmonics.
- (2)  $p_a = p - p_{amb}$ ;  $p_a$  is the relative pressure,  $p_{amb}$  is the local air pressure,  $p$  is the absolute pressure.

The best measurement capability is the highest achievable accuracy for a given measuring value or measuring range, expressed as the total positive and negative measurement uncertainty.

The uncertainty is calculated according to EA-4/02 "Expression of the Uncertainty of Measurement in Calibration".

Calibrations are performed inside the laboratory, unless specified otherwise.



1498



EA MLA Signatory  
Český institut pro akreditaci, o.p.s.  
Olšanská 54/3, 130 00 Praha 3

issues

according to section 16 of Act No. 22/1997 Coll., on technical requirements for products, as amended

## CERTIFICATE OF ACCREDITATION

No. 421 / 2016

**Zkušebnictví, a.s.**  
with registered office Podnikatelská 547, 190 11 Praha 9 - Běchovice, Company Registration  
No. 45274355

to the Testing Laboratory No. 1035  
KEMA Laboratories Prague

### Scope of accreditation:

Testing of making and breaking capacity, testing of short-circuit resistance, testing of electric arc resistance, temperature-rise tests by continuous flow of electric current, dielectric tests, determination of degree of protection, verification of equipment design and routine tests of heavy current equipment to the extent as specified in the appendix to this Certificate.

This Certificate of Accreditation is a proof of Accreditation issued on the basis of assessment of fulfillment of the accreditation criteria in accordance with

ČSN EN ISO/IEC 17025:2005


In its activities performed within the scope and for the period of validity of this Certificate, the Body is entitled to refer to this Certificate, provided that the accreditation is not suspended and the Body meets the specified accreditation requirements in accordance with the relevant regulations applicable to the activity of an accredited Conformity Assessment Body.

This Certificate of Accreditation replaces, to the full extent, Certificate No.: 743/2015 of 02 November 2015, or any administrative acts building upon it.

The Certificate of Accreditation is valid until: **15 July 2021**

Prague: 15 July 2016

на основании чл. 2 от 33ЛД



Jiří Ruzička  
Director  
Czech Accreditation Institute  
Public Service Company



1499

**Инструкция за транспорт, съхранение, монтаж и експлоатация  
на клемореди за вторични вериги за измервателни групи на ниво средно напрежение**

1. Транспорт

Клеморедите трябва да се транспортират опаковани в оригиналната опаковка.

Няма специфични изисквания към начина на транспорт.

2. Съхранение

Клемите и аксесоарите към тях трябва да се съхраняват в сухи, закрити помещения опаковани в оригиналната опаковка.

Температура на съхранение: от -25 до +55 °С.

Няма специфични изисквания към начина на съхранение.

3. Монтаж и експлоатация

Монтажа и експлоатационната поддръжка на клеморедата е необходимо да се извърва от правоспособен ел.монтажор с минимум III та квалификационна група.

Необходимо е да се спазват следните изисквания.

Да се използва изолирана отверка от т.н тип Philips с дебелина 1мм и широчина 4мм

Да не се прави опит да се монтира проводник, ако клемата не е отворена достатъчно

Да не се прави опит да се монтира проводник с по-голямо сечение от 6мм<sup>2</sup>, същия трябва да бъде с отстранена изолация 13мм



Да не се прилагат ток и напрежение по-големи от указаните.

Да се спазват въртящите моменти за затягане на жилата от минимум 1,2Nm и максимум 1,5Nm.

Периодично ( веднъж месечно) да се прави проверка за замърсяване и ако е необходимо, клеморедата да се почисти, като се спазват инструкциите за безопасна работа.

Клеморедата да не се мокри или подлага на атака от химически реагенти.

Да не се прилагат механични удари



1587

ВЪРЪНА С  
ОРИГИНАЛ

ИНЖЕН.  
ПЛОВДИВ  
ЕАБ





**pronutec**  
gorlan team

Bases portafusibles para fusibles tipo NH  
*NH type Low Voltage Fuse bases*





> > [www.pronutec.com](http://www.pronutec.com)

**gorlan**  
CORPORATION

1501


# Bases portafusibles para fusibles tipo NH

NH type fuses for TRIVER bases



- Bases tripolares verticales abiertas TRIVER
- Bases tripolares verticales cerradas TRIVER<sup>+</sup>
- Bases de seccionamiento tripolares verticales cerradas TRIVER<sup>+</sup>
- Bases unipolares abiertas para AC
- Bases tripolares horizontales abiertas
- Bases unipolares desconectables en carga – NHC
- Bases tripolares horizontales cerradas
- Bases de neutro
- Bases portafusibles para DC

- LV Three pole Vertical design fuse rails TRIVER
- LV Three pole Vertical design fuse switches TRIVER<sup>+</sup>
- LV Three pole Vertical design disconnectors TRIVER<sup>+</sup>
- LV One pole AC fuse bases
- LV Three pole Horizontal design fuse bases
- LV One pole fuse switches – NHC
- LV Three pole Horizontal design fuse switches
- Neutral links
- LV fuse bases for DC





*[Handwritten signature]*

# Índice / Contents

Página / Page

<b>1. Bases tripolares verticales abiertas-TRIVER / Vertical design fuse rails TRIVER</b>	6
- Ventajas / Features	7
- Gama / Range	
- Tipo 423 / Type 423	8
- Tipo 443 / Type 443	14
- Tipo 415 / Type 415	20
<b>2. Bases tripolares verticales cerradas y bases de seccionamiento tripolares verticales cerradas - TRIVER+</b>	
<i>Vertical design fuse switches and disconnectors TRIVER+</i>	28
- Ventajas / Features	29
- Gama / Range	
- Tipo 423 / Type 423	34
- Tipo 443 / Type 443	41
- Tipo 438 / Type 438	49
- Aplicaciones / Applications	73
<b>3. Bases unipolares y tripolares horizontales abiertas/protegidas</b>	
<i>One pole and three pole horizontal open /protected fuse bases</i>	76
- Ventajas / Features	77
- Gama / Range	
- NH-00	78
- NH-1 / NH-2	84
- NH-3	91
- NH-4	94
<b>4. Bases unipolares desconectables en carga - NHC / One pole LV fuse switches - NHC</b>	96
- Ventajas / Features	97
- Gama / Range	98
<b>5. Bases tripolares horizontales cerradas / Three pole horizontal design fuse switch disconnectors</b>	106
- Ventajas / Features	107
- Gama / Range	
- NH-000	108
- NH-00	111
- NH-1	115
- NH-2	119
- NH-3	123
<b>6. Bases de neutro / Neutral links</b>	130
- Gama / Range	131
<b>7. Bases portafusibles DC / LV fuse bases for DC</b>	134
- Ventajas / Features	135
- Gama / Range	
- Tipo 434 / Type 434	136
- Tipo 422 / Type 422	140
- Tipo 439 / Type 439	141
<b>8. Datos técnicos / Technical data</b>	144

1903



## Abreviaturas / Abbreviations

Base tripolar vertical abierta	Vertical design fuse rail
Base tripolar vertical abierta protegida	Vertical design protected fuse rail
Base tripolar vertical cerrada desconexión unipolar	Vertical design fuse switch one pole switching
Base tripolar vertical cerrada desconexión tripolar	Vertical design three pole switching fuse switch
Base tripolar vertical cerrada doble	Vertical design double fuse switch
Base tripolar vertical cerrada de seccionamiento	Vertical design disconnecter
Base tripolar vertical cerrada de seccionamiento de desconexión tripolar	Vertical design three pole switching disconnecter
Base tripolar vertical cerrada doble de seccionamiento	Vertical design double disconnecter
Base portafusibles NH unipolar cerrada desconectable en carga	One pole LV fuse switch
Base portafusible unipolar abierta	One pole LV fuse base
Doble desconexión tripolar	Double three pole switching
Base bipolar vertical abierta NH-1 / 1XL / 2XL / 3L	Vertical design 2 pole fuse rail NH-1 / 1XL / 2XL / 3L
Base bipolar vertical abierta protegida NH-1 / 1XL / 2XL / 3L	Vertical design 2 pole protected fuse rail NH-1 / 1XL / 2XL / 3L
Base bipolar vertical cerrada NH-1XL / 2XL / 3L	Vertical design 2 pole fuse switch NH-1XL / 2XL / 3L
Base tripolar horizontal cerrada NH-000 / 00 / 1 / 2 / 3	Three pole LV fuse switches - Horizontal design NH-000 / 00 / 1 / 2 / 3

## Códigos / General codes

- |   |  |
|---|--|
| - Bases tripolares verticales abiertas y cerradas NH-00 / 160 A / 100mm distancia de embarrado  | - Vertical design 3P fuse rails and fuse switches NH-00 / 160 A / 100mm busbar spacing |
| - Bases tripolares verticales abiertas y cerradas NH-00 / 160 A / 185mm distancia de embarrado  | - Vertical design 3P fuse rails and fuse switches NH-00 / 160 A / 185mm busbar spacing |
| - Bases tripolares verticales abiertas NH-1/2/3, 250 / 400 / 630 A 185mm distancia de embarrado | - Vertical design 3P fuse rails NH-1/2/3, 250/400/630 A 185mm busbar spacing           |
| - Bases tripolares verticales cerradas NH-1/2/3, 250 / 400 / 630 / 800 / 910 / 1260 A           | - Vertical design 3P fuse switches NH-1/2/3, 250/400/630/800/910/1260 A                |
| - Base tripolar vertical cerrada de seccionamiento NH-2 / 3, 400 / 630 / 1000 / 2000 A          | - Vertical design 3P disconnectors NH-2 / 3, 400/630/1000/2000 A                       |
| - Base portafusibles NH unipolar desconectable en carga - NHC                                   | - One pole LV fuse switches - NHC  |
| - Bases unipolares abiertas para AC / DC  | - One pole AC / DC fuse bases  |
| - Bases tripolares horizontales abiertas  | - Three pole horizontal design fuse bases  |
| - Bases de neutro   | - Neutral links  |
| - Bases tripolares horizontales cerradas NH-000 / 00 / 1 / 2 / 3                                | - Three pole LV fuse switches - Horizontal design NH-000 / 00 / 1 / 2 / 3              |
| - Base bipolar vertical NH-1 / 1XL / 2XL / 3L   | - 2 pole fuse rail disconnecter NH-1 / 1XL / 2XL / 3L                                  |



## Configuración de referencias / Configuration

### COMO AGREGAR LOS CODIGOS DE LOS TERMINALES Y DE LOS ACCESORIOS PARA CONSTRUIR LAS REFERENCIAS:

REFERENCIA DEL ARTÍCULO = Código del artículo + XX (Código del terminal) + YY (Código del accesorio).

(Código del artículo= familia de producto/ tipo de maniobra / amperaje / tipo de base)

Por ejemplo:

**REFERENCIA DE ARTÍCULO = 438.52.10. 01. 02**

CÓDIGO DE ARTÍCULO	CÓDIGO XX	CÓDIGO YY
-----------------------	--------------	--------------

Familia 438, BTVC, 400 A, NH-2 (438.52.10) + Tornillo M10 inoxidable (CÓDIGO 01) + Tapa de conexión (CÓDIGO 02)

CÓDIGO  
DEL ARTÍCULO

CÓDIGO  
XX

CÓDIGO  
YY

Para conocer la información sobre los códigos de accesorios y terminales compatibles, planos y datos técnicos, consultar las notas a pie de página en cada artículo.

### HOW TO ADD TERMINALS AND ACCESSORIES CODES TO MAKE ARTICLE REFERENCES:

ARTICLE REFERENCE = article code + XX (Terminal code) + YY (Accessories code).

(article code= product family/ type of switching / Amp.rating / type of fuse switch)

For example:

**ARTICLE REFERENCE = 438.52.10. 01. 02**

ARTICLE CODE	XX CODE	YY CODE
-----------------	------------	------------

Type 438, BTVC, 400 A, NH-2 (438.52.10) + M10 Bolt Stainless Steel (CODE 01) + Connection cover (CODE 02)


ARTICLE  
CODE

XX  
CODE

YY  
CODE

For information about compatible terminal and accessory codes, drawings and technical data, refer to notes below which indicate the pages to be consulted.

150B




PRONUTEC  
CORPORATION



2,

**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER +**

*Vertical design fuse switches and disconnectors -TRIVER +*



Pronutec presenta su nueva generación de Bases Portafusibles verticales cerradas NH-00/1/2/3 TRIVER+  
Esta nueva gama pretende satisfacer las necesidades actuales y futuras de nuestros clientes.

*Pronutec presents the latest generation of vertical fuse switches NH-00/1/2/3 TRIVER+. This new range  
aims to meet our customers present and future requirements.*

1506

PRONUTEC S.A.  
CALLE 1506  
BOGOTÁ, COLOMBIA



2

## Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER+ Vertical design fuse switches and disconnectors TRIVER+

### Ventajas / Features


#### TOTALMENTE COMPATIBLES / FULLY COMPATIBLE

TRIVER+ es 100% compatible con la anterior gama de bases portafusibles. Mantiene las mismas dimensiones exteriores por lo que puede ser instalada en cualquier tipo de cuadro que actualmente hay en el mercado. Bases validas para paneles frontales de 600mm ó 650mm de altura.

Así mismo, ha sido diseñada y ensayada según la norma IEC 60947-3 y acorde con las normas de las principales compañías eléctricas del mundo.

*TRIVER+ is 100% compatible with the previous range. It maintains the same external dimensions so they can be assembled in any already installed LV panels in the market. The fuse switches are also valid for 600mm and 650mm front frame panels.*



*It has also been designed and tested according to IEC 60947-3 standard and in accordance with the specifications of the main electric utilities all around the world.*



#### ADAPTADAS AL FUTURO / ADAPTED TO FUTURE

Esta nueva generación de bases tripolares está preparada para cubrir las necesidades del mercado que aparecerán en un futuro próximo con la implantación de redes inteligentes (Smart Grids). Para ello incorpora soluciones y accesorios para la telegestión como pueden ser conjuntos de medida integrados o independientes, el control electrónico de fusión, etc.

*This new generation of three pole vertical fuse switches are prepared to meet the market's future requirements with regard to implementation of smart grids. For such purpose, it incorporates features and accessories for remote supervision such as integrated or independent metering sets, Fuse Supervision Control, etc.*



1507

**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER +**  
*Vertical design fuse switches and disconnectors - TRIVER+*

**Ventajas / Features**

**EFICIENCIA ENERGETICA**  
*ENERGY EFFICIENCY*

La nueva base TRIVER+, ha sido diseñada para conseguir un mayor rendimiento energético en las condiciones reales de trabajo.

Por una parte se reducen las pérdidas de la base (gracias al nuevo diseño del contacto) y por otra, la disipación de calor de la misma es mayor (gracias a la ventilación que ofrece la nueva carcasa aislante).

*The new TRIVER+ has been designed to achieve an optimal energy efficiency in real working conditions.*


*This is achieved by the combined effect of both lower power losses in the contacts and improved self ventilation of the insulating parts.*

**SEGURIDAD FRENTE A CONTACTOS ACCIDENTALES**  
*SAFETY AGAINST ACCIDENTAL CONTACTS*

Grado de protección IP frontal  
*Front protection degree*

La seguridad es el aspecto principal sobre el cual gira el desarrollo del producto de Pronutec. La nueva base TRIVER+, presenta un grado de protección IP 30 en posición cerrada e IP 20 en posición abierta, garantizando una máxima protección frente a contactos accidentales.

*Safety is the main aspect for the development of new products in Pronutec. The new TRIVER+ provides an IP30 protection degree in the closed position and IP20 in the open position, ensuring maximum protection against accidental contacts.*



Cerrada: IP30  
 Closed: IP 30

Abierta: IP20  
 Open: IP 20


1508

**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER +**  
*Vertical design fuse switches and vertical - TRIVER+*



**Ventajas / Features**

**SEGURIDAD Y MANIPULACIÓN / SAFETY & HANDLING**


Mayor seguridad en la instalación y el manejo en todos los tamaños.  
*Increased safety in installation and handling to all sizes.*





Seguridad y comodidad en la extracción del fusible sin tocarlo mediante un accionamiento exterior.  
*Safety and comfort in the removal of the fuse. Unlocking tag prevents from touching any internal part.*





Tapa con un dispositivo que permite acceder directamente a la cuchilla del fusible para realizar pruebas de tensión.  
*Cover including provision to allow direct access to the blade of the fuse in order to make voltage testing.*



Fácil montaje del lateral.  
*Easy to install the switching case.*




Posibilidad de montaje en tensión a través de las ventanas de acceso a embarrados.  
*Installation in live panels possible by means of busbar access window.*




Gran espacio en la maneta.  
*Big space in the handle.*




**BLOQUEO / PROVISION FOR PADLOCK**



Posición cerrada con bloqueo de candado en cada fase.  
*Closed position with padlock in each phase.*



Bloqueo sellado de cada fase en posición cerrada así como de la zona del terminal y del tarjetero.  
*Provision for installing a sealing plumb for each phase and sealing plumb in the card holder.*



Posición abierta con bloqueo de candado en DT.  
*Open position with padlock in DT.*



*Handwritten signature*

1509

**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER+**  
*Vertical design fuse switches and disconnectors - TRIVER+*

**Ventajas / Features**


**ECODISEÑO / ECODESIGN**

La reducción de pérdidas de energía con la que nos beneficia el nuevo diseño de la base TRIVER+, tiene un efecto positivo sobre el medio ambiente.

Al mismo tiempo, con el diseño de esta nueva base TRIVER+, se ha conseguido reducir el impacto ambiental del producto a lo largo de todo su ciclo de vida.

*The reduction of power losses thanks to the new design of the TRIVER+ has a positive effect on the environment.*

*Additionally, with the design of this new TRIVER+, the impact of the product on the environment has been reduced throughout its whole life cycle.*



**UN DISEÑO ERGONÓMICO, MODERNO Y FUNCIONAL**


*ERGONOMIC, MODERN AND FUNCTIONAL DESIGN*

Mejor maniobrabilidad. Mayor rapidez de montaje y manipulación. Mayor efectividad. Más seguridad.

*Better maneuverability. Faster to install and operate. More effective. Safer.*

Diseño compatible con marcos de cuadros de distribución.

*Design compatible with LV distribution panels frames*



**ASA ESCAMOTEABLE / CUADROS MÁS COMPACTOS**  
 La profundidad se reduce de 192 a 166mm. Se pueden diseñar cuadros con menos profundidad.

*RETRACTABLE HANDLE / MORE COMPACT PANELS.*  
 Depth reduces from 192mm to 166mm.  
 LV panels can be designed with less depth.



**REVERSIBILIDAD**

Las conexiones de los cables se pueden hacer tanto en la parte superior como inferior, solo girando

**REVERSIBILITY**

Connections can be done either in the top or bottom by simply turning the base upside down.



15/10

## Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER +

Vertical design fuse switches and disconnectors - TRIVER+

### Ventajas / Features

### ACCESORIOS / ACCESSORIES

Amplia gama de accesorios que aportan mayores beneficios sobre la nueva base TRIVER +

Wide range of accessories that provides additional advantages inside the new TRIVER +.



Medida permanente/temporal a través del conjunto fusible-transformador de intensidad-amperímetro.

Permanent or temporary metering by means of a combined set of fuse - current transformer - ammeter.



Dispositivo que permite la indicación del estado abierto/cerrado de la tapa en cada fase. Indicador de fusión de fusibles, integrado en el lateral (ILF).  
Microswitch which enables open / close indicator.  
LED - Integrated blown fuse indicator.

Tarjetero superior / inferior  
Top / Bottom card holders




Salida auxiliar protegida con fusibles hasta 160 A para consumos temporales sin tener que instalar una base adicional.  
Fuse protected auxiliary supply (up to 160A fuses) used to provide temporary supply with no need for installing an additional fuse rail.



Preparada para la conexión de puestas a tierra para los cables de salida. La cuchilla de puesta a tierra se aloja en la posición del fusible. La base se pondrá a tierra a través de una trenza de cobre.

It is possible to connect earthing kits for outgoing cables. The blade of the earthing link is located in the position of the fuse in the base. The base is earthed by means of a copper braid.



Amplia gama de terminales que se adapta a todas las necesidades de secciones y tipos de conexión (páginas 35, 42 y 59).

Large range of terminals adapted to fit several type of cable terminations (pages 35, 42 & 59).



1514

**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER\***  
*Vertical design fuse switches and disconnectors TRIVER\**

**Gama / Range**

**Bases de seccionamiento, BTVC-S, BTVC-S, 400 / 630 / 1000 A**

438

*Disconnectors, BTVC-S, 400 / 630 / 1000 A*

Referencia <i>Reference</i>	Tipo <i>Type</i>	Intensidad <i>Current</i>	Desconexión <i>Disconnection</i>	Terminales <i>Terminal type</i>	Conexiones <i>Connections</i>	Cuchillas de Seccionamiento <i>Solid Links</i>
438.52.12.XX.02*	BTVC-S	400 A	Unipolar <i>One pole</i>	Terminales código XX <i>XX Code Terminal</i>	Superior / Inferior <i>Top / Bottom</i>	NH-2
438.53.12.XX.02*		630 A		Terminales código XX <i>XX Code Terminal</i>	Superior / Inferior <i>Top / Bottom</i>	NH-3
438.55.12.04.02*		1000 A		Tuerca inoxidable M12 <i>M12 inserted nut stainless steel</i>	Superior / Inferior <i>Top / Bottom</i>	NH-3
438.55.12.36.00		1000 A		∅14 mm	Superior / Top	NH-3
438.62.12.XX.02*	BTVC-SDT 2 asas <i>BTVC-SDT 2 handles</i>	400 A	Tripolar <i>Three pole</i>	Terminales código XX <i>XX Code Terminal</i>	Superior / Inferior <i>Top / Bottom</i>	NH-2
438.63.12.XX.02*		630 A		Terminales código XX <i>XX Code Terminal</i>	Superior / Inferior <i>Top / Bottom</i>	NH-3
438.65.12.04.02*		1000 A		Tuerca inoxidable M12 <i>M12 inserted nut stainless steel</i>	Superior / Inferior <i>Top / Bottom</i>	NH-3
438.65.12.36.00		1000 A		∅14 mm	Superior / Top	NH-3
438.72.12.XX.02*	BTVC-SDT 1 asa <i>BTVC-SDT 1 handle</i>	400 A	Tripolar <i>Three pole</i>	Terminales código XX <i>XX Code Terminal</i>	Superior / Inferior <i>Top / Bottom</i>	NH-2
438.73.12.XX.02*		630 A		Terminales código XX <i>XX Code Terminal</i>	Superior / Inferior <i>Top / Bottom</i>	NH-3
438.75.12.04.02*		1000 A		Tuerca inoxidable M12 <i>M12 inserted nut stainless steel</i>	Superior / Inferior <i>Top / Bottom</i>	NH-3
438.75.12.36.00		1000 A		∅14 mm	Superior / Top	NH-3

\* Con tapa de conexiones / *With connection cover*

185 mm



**BTVC-S**



**BTVC-SDT 2 ASAS  
BTVC-SDT 2 HANDLES**



**BTVC-SDT CONEXION SUPERIOR  
BTVC-SDT TOP CONNECTION**

Terminales código XX / *Terminals XX Code: P. 60*  
 Accesorios código YY / *Accessories YY Code: P. 61-63*

Datos Técnicos / *Technical Data: P. 35-6-15*  
 Planos y esquemas eléctricos / *P. 70-71*  
 Dimension drawing and wiring diagrams: P. 70-71



15/12

**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER\***  
*Vertical design fuse switches and disconnectors -TRIVER\**


**Gama / Range**

438

**Bases de seccionamiento, BTVC-S, 400/630/1000 A seccionamiento de embarrados**

*Disconnectors, BTVC-S, 400 / 630 / 1000 A busbar connection*

Referencia <i>Reference</i>	Tipo <i>Type</i>	Intensidad <i>Current</i>	Desconexión <i>Disconnection</i>	Terminales <i>Terminal type</i>	Conexiones <i>Connections</i>	Cuchillas de Seccionamiento <i>Solid Link</i>
438.52.65.08.00	BTVC-S	400 A	Unipolar <i>One pole</i>	ø14 mm	Seccionamiento de embarrado <i>Busbar connection</i>	NH-2
438.53.65.08.00*		630 A				NH-3
438.55.65.08.00		1000 A				NH-3
438.62.65.08.00	BTVC-SDT 2 asas <i>BTVC-SDT</i> 2 handles	400 A	Tripolar <i>Three pole</i>	ø14 mm	Seccionamiento de embarrado <i>Busbar connection</i>	NH-2
438.63.65.08.00		630 A				NH-3
438.65.65.08.00		1000 A				NH-3
438.72.65.08.00	BTVC-SDT 1 asa <i>BTVC-SDT</i> 1 handle	400 A	Tripolar <i>Three pole</i>	ø14 mm	Seccionamiento de embarrado <i>Busbar connection</i>	NH-2
438.73.65.08.00		630 A				NH-3
438.75.65.08.00		1000 A				NH-3



*Handwritten signature*

Terminales código XX / *Terminals XX Code: P. 60*  
 Accesorios código YY / *Accessories YY Code: P- 61-63*

Datos Técnicos / *Technical Data: P. 156-157*  
 Planos y esquemas eléctricos: P. 71  
*Dimension drawing and wiring diagrams: P. 71*

**PRONUTEC**  
 S.A. DE C.V.  
 CALLE DE LA INDUSTRIA 1000  
 SAN JUAN DE LOS RIOS, GUANAJUATO, GTO.  
 C.P. 37000



*Handwritten signature*

15/13



**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER\***  
*Vertical design fuse switches and disconnectors - TRIVER\**

**Gama / Range**


**Bases de seccionamiento dobles, BTVC-DS, 2000 A**

438

*NH-Double Disconnectors, BTVC-DS, 2000 A*


Referencia Reference	Tipo Type	Intensidad Current	Distancia entre BTVC (mm) Fuse switch distance(mm)	Terminales Terminal type	Conexiones Connections	Cuchillas de Seccionamiento Solid Link
438.57.70.04.02*	BTVC-DS	2000 A	100	Tuerca M12 inoxidable <i>M12 inserted nut stainless steel</i>	Superior / Inferior <i>Top / Bottom</i>	NH-3
438.57.71.04.02*			105			
438.57.13.07.02			110	2 x M14 <i>2 x M14</i>		
438.57.80.04.00	BTVC-DS	2000 A	100	Tuerca M12 inoxidable <i>M12 inserted nut stainless steel</i>	Seccionamiento de embarrado <i>Busbar connection</i>	NH-3

\* Con tapa de conexiones / *With connection cover*



Terminales código XX / *Terminals XX Code: P. 60*  
 Accesorios código YY / *Accessories YY Code: P. 61-63*

Datos Técnicos / *Technical Data: P. 156-157*  
 Planos y esquemas eléctricos: P. 72  
*Dimension drawing and wiring diagrams: P. 72*




**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER\***

*Vertical design fuse switches and disconnectors -TRIVER\**


438

**BTVC / BTVC-DT & BTVC / BTVC-DT acometida lateral, NH-1/2/3**

*NH fuse switches BTVC/BTVC-DT & BTVC/BTVC-DT lateral input, NH-1/2/3*




**TORNILLO M10**  
*M10 BOLT*




**TORNILLO M10 INOXIDABLE**  
*M10 BOLT STAINLESS STEEL*



**TORNILLO M12**  
*M12 BOLT*



**TORNILLO M12 INOXIDABLE**  
*M12 BOLT STAINLESS STEEL*




**TUERCA M12 INOXIDABLE**  
*M12 NUT STAINLESS STEEL*




**TERMINAL V REVERSIBLE CON PIEZA DE PRESION**  
*V-TERMINAL WITH REVERSIBLE PRESSURE PAD*

	rm	re	sm	se
mm <sup>2</sup>	50-185	70-240	70-240	95-300
Nm	25			




**TERMINAL BIMETÁLICO**  
*BIMETALLIC TERMINAL*

	rm	re	sm	se
mm <sup>2</sup>	35-70	50	35-150	50-185
Nm	32			




**TERMINAL V CON TORNILLO DE ROTURA CONTROLADA**  
*V-TERMINAL WITH SHEAR HEAD SCREW*

	rm	re	sm	se
mm <sup>2</sup>	50-185	70-240	70-240	95-300
Nm	25			




**PLETINA PARA TERMINAL V (SIN TERMINAL)**  
*V SHAPED OUTGOING PLATE WITHOUT V TERMINAL*



**TERMINAL V**  
*V-TERMINAL*

	rm	re	sm	se
mm <sup>2</sup>	35-70	35-50	50-185	50-240
Nm	25			



**TERMINAL V DE ACERO**  
*STEEL V TERMINAL*

	rm	re	sm	se
mm <sup>2</sup>	35-185	35-150	50-240	50-300
Nm	35			



**TERMINAL V DOBLE**  
*DOUBLE V TERMINAL*

	rm	re	sm	se
mm <sup>2</sup>	50-185	70-240	50-185	70-240
Nm	25			

Handwritten signature and stamp area. Includes a circular stamp with text: "ИНЖЕНЕРИТ", "ЕАР", "ПРОНУТЕК".

Para otros terminales o secciones de cable consultar código  
For other options or other cable sections consult code

1545

**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER\***  
*Vertical design fuse switches and disconnectors - TRIVER\**

438

**para bases especiales**


*for special fuse switches*

**BTVC / BTVC-DT salida lateral**  
*BTVC / BTVC-DT lateral output*




**TUERCA M 12 INOXIDABLE**  
*M12 INSERTED NUT STAINLESS STEEL*


**BTVC / BTVC-DT 910 A**



**TUERCA M 12 INOXIDABLE**  
*M12 INSERTED NUT STAINLESS STEEL*



**Ø 14 ACOMETIDA TRASERA**  
*Ø 14 REAR PLATE*




**Ø 14 ACOMETIDA SUPERIOR**  
*Ø 14 TOP CONNECTION*

**BTVC - D 800 / 1260 A**



**TORNILLO M 12**  
*M12 BOLT*



**TORNILLO M12 INOXIDABLE**  
*M12 BOLT STAINLESS STEEL*



**TUERCA M 12 INOXIDABLE**  
*M12 INSERTED NUT STAINLESS STEEL*


**Bases de seccionamiento BTVC-S / BTVC - DS**

438


*BTVC-S / BTVC-DS Disconnectors*

**BTVC - S 1000 A**

**TUERCA M 12 INOXIDABLE**  
*M12 INSERTED NUT STAINLESS STEEL*




**BTVC-S 1000 A seccionamiento de embarrados**  
*BTVC-S 1000 A busbar connection*



**DIAMETRO 14 MM**  
*14 MM HOLE DIAMETER*


**BTVC - DS 2000 A**

**TUERCA M 12 INOXIDABLE**  
*M12 INSERTED NUT STAINLESS STEEL*



**BTVC-DS 2000 A seccionamiento de embarrados**  
*BTVC-DS 2000 A busbar connection*

**TORNILLO M 14**  
*M14 BOLT*



**TUERCA M 12 INOXIDABLE**  
*M12 INSERTED NUT STAINLESS STEEL*









1546


**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER\***  
**Vertical design fuse switches and disconnectors -TRIVER\***

438

NH-1/2/3, 250/400/630 A; BTVC 910 A; BTVC-D 400/630/800/1260 A; BTVC-S 1000-2000 A

fuse switches NH-1/2/3, 250/400/630 A; BTVC 910 A; BTVC-D 400/630/800/1260 A; BTVC-S 1000-2000A

Artículo Item	Descripción Description	Referencia Reference	Código YY YY Code
			00= Sin accesorios 00= No Accessories
	Indicador luminoso de fusión (ILF) Blown fuse indicator		01
	Tapa de conexiones para NH-1/2/3 BTVC y BTVC-DT / BTVC-S 400 / 630A Connection cover for NH-1/2/3 BTVC & BTVC-DT/ BTVC-S 400/ 630A	4380425	02
	Tapa de conexiones para BTVC 910 A y terminales salida superior Connection cover for BTVC 910 A and top outgoing terminals	42804103	
	Tapa de conexiones para BTVC-S 1000A Connection cover for BTVC-S 1000A	42801027	
	Tapa de conexiones para BTVC doble y BTVC-DS 2000 A (100mm) Connection cover for Double BTVC-D and BTVC-DS 2000 A (100mm)	STD 42801028 FS 42804100	
	Tapa de conexiones para BTVC doble y BTVC-DS 2000 A (105mm) Connection cover for Double BTVC-D (100mm) and BTVC-DS 2000 A (105 mm)	STD 42801029 FS 42804100	
	Tapa de conexiones para BTVC-D (110 mm) Connection cover for Double BTVC-D (110 mm)	STD 42801030 FS 4280485	
	Código 01 + código 02 / Code 01 + code 02		
Artículo Item	Descripción Description	Referencia Reference	
	Tapa de conexiones corta para NH-1/2/3 BTVC y BTVC-DT Short connection cover for NH-1/2/3 BTVC & BTVC-DT	4280410	
	Salida auxiliar protegida Slip on fuse	4280810	
	Maletín medida temporal (con tapas) para NH-1 BTVC y BTVC-DT Temporary metering set suitcase (with fuse holders) for NH-1 BTVC & BTVC-DT	42808119	
	Maletín medida temporal (con tapas) para NH-2 BTVC y BTVC-DT Temporary metering set suitcase (with fuse holders) for NH-2 BTVC & BTVC-DT	42808100	
	Maletín medida temporal (con tapas) para NH-3 BTVC y BTVC-DT Temporary metering set suitcase (with fuse holders) for NH-3 BTVC & BTVC-DT	42808102	
	Protección frontal de embarrados; ancho 100mm con escuadras Front cover for busbars: 100mm width with fixing brackets	4150804	
	Conjunto protección lateral izquierdo / derecho Front cover for busbars: 100mm width	4150807	
	Conjunto protección lateral izquierdo / derecho Protecting polyester strip left/right angle	4150808S	
	Micro-Interruptor señalización abierto / cerrado Micro-switch (open / closed indicator)	1013406	
	Base con control electrónico de fusión para BTVC y BTVC-DT F5 fuse switch fuse supervision control for BTVC & BTVC-DT	Referencia estándar + F5 Standard fuse switch reference + F5	
	Tapa de conexiones con amperímetro para conjunto medida permanente para NH-1/2/3 BTVC y BTVC-DT Top cover with maximeter for permanent metering set for NH-1/2/3 BTVC & BTVC-DT		



1517

**2 Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER\***  
*Vertical design fuse switches and disconnectors -TRIVER\**

438

**NH-1/2/3, 250/400/630 A; BTVC 910 A; BTVC-D 400/630/800/1260 A; BTVC-S 1000-2000 A**

*fuse switches NH-1/2/3, 250/400/630 A; BTVC 910 A; BTVC-D 400/630/800/1260 A; BTVC-S 1000-2000A*

Artículo Item	Descripción Description	Referencia Reference	
	Escuadra fijación protección frontal para NH-1/2/3 BTVC & BTVC-DT <i>Fixing bracket for front cover for NH-1/2/3 BTVC &amp; BTVC-DT</i>	4150420	
	Separador central para terminales de salida: 80 mm <i>Central barrier for outgoing terminals: 80 mm</i>	4150426	
	Separador central para terminales de salida: 120 mm <i>Central barrier for outgoing terminals: 120 mm</i>		
	Kit 3 pletinas salida para 3 tornillos M12 inoxidable por fase <i>Set of 3 adaptor plates to connect 3 cables lugs M12 stainless steel per phase</i>	4150126	
	Kit 3 pletinas salida para 3 terminales en "V" por fase <i>Set of 3 adaptor plates to connect 3 V-terminals per phase</i>	4150107	
	Caperuza protección terminal "V" <i>Insulating cover for V-terminal</i>	4380454	
	Dispositivo de puesta a tierra NH-1/2/3 <i>Earthing device NH-1/2/3</i>	42808104	
	Conjunto medida temporal (sin tapas) para BTVC y BTVC-DT <i>Temporary metering set (withouth fuse holders) for BTVC &amp; BTVC-DT</i>	NH-1	42808118
		NH-2	42808111
		NH-3	42808112
		250 A	42808105
	Conjunto medida permanente para BTVC y BTVC-DT <i>3 phase permanent metering set for BTVC &amp; BTVC-DT</i>	400 A	42808108
		630 A	42808109
	Cuchilla de seccionamiento NH-1 <i>Solid link for NH-1</i>	2400302	
	Cuchilla de seccionamiento NH-2 <i>Solid link for NH-2</i>	2400402	
	Cuchilla de seccionamiento NH-3 <i>Solid link for NH-3</i>	2400502	
	Garra de fijación (3 unidades) <i>Hook-on clamp (set of 3)</i>	4150820	
	Pletinas de adaptación para conectar dos cables de M12 inoxidable por fase <i>Adaptor plates to connect 2 cable lugs M12 stainless steel per phase</i>	4150812	
	Pletinas en "V" para neutro <i>Plate for "V" Neutral link</i>	4280538	
	Pletinas plana en "V" para neutro <i>Flat plate for "V" Neutral link</i>	4280547	
	Kit para doble desconexión unipolar en BTVC-D (2 piezas x 3 polos = 6 piezas) <i>Kit for double one pole switching for BTVC-D (2 piezas x 3 poles = 6 piezas)</i>	100mm	4380801
		105mm	4380802
		110mm	4380803
	Tarjetero para terminal V doble. Referencia del accesorio sin marcado. Para tarjetero con marcado consultar referencia. <i>Card holder for Double V-Terminals. Accessorie reference without marking. For Cardholder including marking, consult reference</i>	4280480	

**PRONUTEC**  
 S.A. DE C.V.  
 CALLE DE LA INDUSTRIA 1000  
 COL. INDUSTRIAL  
 CIUDAD DE GUAYMAS  
 SONORA  
 MEXICO  
 C.P. 87000

PRONUTEC  
 S.A. DE C.V.  
 CALLE DE LA INDUSTRIA 1000  
 COL. INDUSTRIAL  
 CIUDAD DE GUAYMAS  
 SONORA  
 MEXICO  
 C.P. 87000



1548

**Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER\***  
*Vertical design fuse switches and disconnectors - TRIVER\**

438

NH-1/2/3, 250/400/630 A; BTVC 910 A; BTVC-D 400/630/800/1260 A; BTVC-S 1000-2000 A

fuse switches NH-1/2/3, 250/400/630 A; BTVC 910 A; BTVC-D 400/630/800/1260 A; BTVC-S 1000-2000 A

Artículo Item	Descripción Description	Referencia Reference	
	Soporte de embarrado 185mm, tripolar para embarrados perforados <i>Busbar support 185mm, 3 pole for drilled flat busbars</i>	4380811	
	Soporte de embarrado universal 185mm, tripolar para embarrado sin perforar 30...120x10mm <i>Universal busbar support 185mm, 3 pole for undrilled flat busbars 30...120 x10 mm</i>	4380812	
	Tapa para la protección del final del embarrado para referencia 4380812 <i>Cover, for busbar ends for reference 4380812</i>	4380813	
	Transformador de intensidad para integrar en zócalo. Solo para bases especiales. <i>Current transformer to join in base board. Exclusive for special fuse switches.</i>	200/5, 1...3 VA 0,5 S	Consultar <i>Consult</i>
		300/5, 1...5 VA 0,5 S	Consultar <i>Consult</i>
		400/5, 1...5 VA 0,5 S	Consultar <i>Consult</i>
		600/5, 1...5 VA 0,5 S	Consultar <i>Consult</i>
		1000/5, 1...5 VA 0,5 S	Consultar <i>Consult</i>
	Terminal de conexión para embarrados 30 x 10, y conexión de cables 95-300 mm <sup>2</sup> <i>Connection terminal for busbars 30 x 10, and cable connection 95-300 mm<sup>2</sup></i>	4230812	

TRIVER



*[Handwritten signature]*


1519

## 2 Bases tripolares verticales cerradas y bases de seccionamiento - TRIVER® Vertical design fuse switches and disconnectors - TRIVER®

NH-1/2/3, 250/400/630 A; BTVC 910 A; BTVC-D 400/630/800/1260 A; BTVC-S 1000-2000 A

438

fuse switches NH-1/2/3, 250/400/630 A; BTVC 910 A; BTVC-D 400/630/800/1260 A; BTVC-S 1000-2000 A



Ref. 4280821	Tapa de conexiones con amperímetro para conjunto medida permanente para NH-1/2/3 BTVC y BTVC-DT <i>Top cover with maximeter for permanent metering set for NH-1/2/3 BTVC &amp; BTVC-DT</i>	Ref. 42808105	Conjunto medida permanente para BTVC y BTVC-DT 250 A <i>3 phase permanent metering set for BTVC &amp; BTVC-DT 250 A</i>
Ref. 4150804	Protección frontal de embarrados: ancho 100mm con escuadras <i>Front cover for busbars: 100 mm width with fixing brackets</i>	Ref. 42808108	Conjunto medida permanente para BTVC y BTVC-DT 400 A <i>3 phase permanent metering set for BTVC &amp; BTVC-DT 400A</i>
Ref. 42808118 42808111 42808112	Conjunto medida temporal (sin tapas) para NH-1 BTVC y BTVC-DT <i>Temporary metering set (withouth fuse holders) for NH-1 BTVC &amp; BTVC-DT</i>	Ref. 42808109	Conjunto medida permanente para BTVC y BTVC-DT 630 A <i>3 phase permanent metering set for BTVC &amp; BTVC-DT 630A</i>
Ref. 4380425	Conjunto medida temporal (sin tapas) para NH-2 BTVC y BTVC-DT <i>Temporary metering set (withouth fuse holders) for NH-2 BTVC &amp; BTVC-DT</i>	Ref. 4280810	Salida auxiliar protegida <i>Slip on fuse</i>
Ref. 4150812	Conjunto medida temporal (sin tapas) para NH-3 BTVC y BTVC-DT <i>Temporary metering set (withouth fuse holders) for NH-3 BTVC &amp; BTVC-DT</i>	Ref. 4150807	Protección frontal de embarrados: ancho 100mm fijación al embarrado con tornillos nylon <i>Front cover for busbars: 100 mm width with nylon bolts for busbar fixing</i>
Ref. 4380425	Tapa de conexiones para NH-1/2/3 BTVC y BTVC-DT / BTVC-S 400 / 630 A <i>Connection cover for NH-1/2/3 BTVC &amp; BTVC-DT / BTVC-S 400/ 630 A</i>	Ref. 4150426	Separador central para terminales de salida <i>Central barrier for outgoing terminals</i>
Ref. 4150812	Pletinas de adaptación para conectar dos cables de M12 inoxidable por fase <i>Adaptor plates to connect 2 cable lugs M12 stainless steel per phase</i>	Ref. 4150107	Kit 3 pletinas salida para 3 terminales en "V" por fase <i>Set of 3 adaptor plates to connect 3 V-terminals per phase</i>
		Ref. 42808104	Dispositivo de puesta a tierra NH-1/2/3 <i>Earthing device NH-1/2/3</i>

1220



Datos Técnicos / Technical Data

438

Bases de seccionamiento tripolares verticales cerradas BTVC-S NH-3 y dobles BTVC-DS NH-3  
Vertical design disconnectors BTVC-S NH-3 and BTVC-DS NH-3

IEC / EN 60947-3	Tipo / Type →	BTVC / BTVC-DS Tipo / Type 438				
		400 A	630 A	1000 A	2000 A	
Datos eléctricos Electrical characteristics	Tensión asignada de empleo Rated operational voltage	U <sub>o</sub> (V) AC 500 / AC 690				
	Intensidad asignada de empleo Rated operational current	I <sub>o</sub> (A) 400	630	1000	2000	
	Intensidad térmica convencional al aire libre con fusibles Conventional free air thermal current with fuses	I <sub>th</sub> (A) 400	630	1000	2000	
	Frecuencia asignada Rated frequency	(Hz)	40 - 60			
	Tensión asignada de aislamiento Rated insulation voltage	U <sub>i</sub> (V)	1000			
	Intensidad asignada de cortocircuito condicional Rated conditional short-circuit current	(kA <sub>eff</sub> )	11 *(2)			
	Categoría de empleo Utilization category	-	AC-20B	AC-20B	AC-20	AC-20B
	Intensidad asignada de cierre Rated making capacity	(A)	-	-	1500	-
	Intensidad asignada de corte Rated breaking capacity	(A)	-	-	1500	-
	Tensión asignada de resistencia a los impulsos Rated impulse withstand voltage	U <sub>imp</sub> (kV)	20			
Potencia disipada sin fusibles Total power loss at I <sub>th</sub> (without fuse)	P <sub>v</sub> (W)	52	98	280	600	
Datos mecánicos Mechanical characteristics	Peso Weight	(kg)	5,430	6,240	9,316	20,010
	Distancia de embarrado Busbar distance	(mm)	185			
	Panel frontal Panel front opening	(mm)	600/650			
Cuchilla Solid link	Tamaño según CEI / EN 60269 Size to CEI / EN 60269	-	2	3		
	Intensidad asignada máxima Max. rated current	I <sub>n</sub> (A)	400	630	1000	

Handwritten signature and scribbles on the right side of the table.

Handwritten signature and stamp: "Pronutec S.A. BARRIO SAN JUAN DE LOS RIOS" (rotated).



Handwritten number: 1521



**Datos Técnicos / Technical Data**

**Bases de seccionamiento tripolares verticales cerradas BTVC-S NH-3 y dobles BTVC-DS NH-3**

438

*Vertical design disconnectors BTVC-S NH-3 and BTVC-DS NH-3*

IEC / EN 60947-3		Tipo / Type	BTVC / BTVC-DS Tipo / Type 438			
			400 A	630 A	1000 A	2000 A
Terminales Terminals	Terminal de tornillo Bolt terminal	Diametro Diameter	M10/M12		M12	
		Terminal de compresión (S/DIN 46235) Cable lug (S/DIN 46235)	(mm <sup>2</sup> )	2x25-300	2x95-300	4x95-300
		Par de apriete Torque	(Nm)	32		
Grado de protección Protection degree	Frontal Front operated switchgear fitted	-	IP30			
Condiciones de servicio Operating Conditions	Temperatura de ambiente Ambient temperature	(°C)	de -25 hasta +55 *(1) / -25 to +55 *(1)			
	Servicio asignado Rated operating mode	-	ininterrumpido continuous operation			
	Maniobra Actuation	-	manual dependiente dependant manual operation			
	Altitud Altitude	(m)	hasta 2000 / up to 2000			
	Grado de contaminación Pollution degree	-	3			
	Categoría de sobretensión Overvoltage category	-	IV			

\*(1) 35° C temperatura media, a 55° C con intensidad asignada de empleo reducida / \*(1) 35° C normal temperature, at 55° C with reduced operating current  
 \*(2) 25kA con accesorio especial / \*(2) 25KA with special accessory

*[Handwritten signature]*

**PRONUTEC**  
 S.A. DE C.V.  
 CALLE DE LOS RIOS 1000  
 SAN JUAN DE LOS RIOS, QROO.  
 C.P. 70700

**PRONUTEC**  
 S.A. DE C.V.  
 CALLE DE LOS RIOS 1000  
 SAN JUAN DE LOS RIOS, QROO.  
 C.P. 70700



438 Type / Typ  
1000|2000

Switch disconnecter able to withstand High Short circuit currents  
NH-trennleiste mit erhöhter Kurzschlussfestigkeit  
(BTVC-S/BTVC-DS/BTVC-SDT)


Dimensions / Abmessungen

BTVC-S 1 pole disconnection  
BTVC-S 1-polig-schaltbar

BTVC-DS 1 pole disconnection  
BTVC-DS 1-polig-schaltbar



BTVC-SDT 2 handles  
BTVC-SDT 2-hand-betrieben



Width A / Breite A  
100 mm  
105 mm  
110 mm

*Handwritten signature*



# Списък на отделните изпитвания на български език

## **Изследван образец:**



Вертикален разединител с предпазители от типа BTVC 1000A ,400V а.с.,50Hz  
триполюсен размер 3

## **Производител:**

Pronutec S.A. , Испания

Изпълнени тестове съгласно IEC/EN 60947-3; IEC 60947-1)

- 1) Проверка на конструкцията
- 2) Тест за повишаване на температурата –проверка на нагряването
- 3) Проверка на диелектричните свойства
- 4) Проверка на включвателна и изключвателна способност
- 5) Проверка на оперативна ефективност
- 6) Проверка на тока на термична устойчивост  $I_{cw}$
- 7) Проверка на включвателна възможност (върхова)  $I_{cm}$





AUSTRIAN INSTITUTE  
OF TECHNOLOGY

Accredited by BMWA with GZ: 92714/237-IV/9/00 as test- and inspection body  
and with BGBl. II Nr. 244//2005 as certification body for personnel

# Test Report

Project Designation

## TYPE TEST AT LOW-VOLTAGE SWITCH-DISCONNECTOR TYPE BTVC-S:

- 400V a.c. up to 690V a.c. / 1000A / size 3
- single pole operated three pole device
- 185mm busbar system

Client

PRONUTEC S.A.  
Parque Empresarial Boroa  
Parcela 2c-1  
E-48340 Amorebieta – VIZCAYA  
SPAIN

Order from / No. 01/2011 / ---

Project Number 2.03.02216.1.0/BTVC-S/size3/1p-operated/185


Test Engineer Ing. J. Ainetter

Date of issue	29.03.2011
Total number of issues / No.	1 / 1
Number of pages	18
Annex: Number of pages	---

The results relate exclusively to the terms tested.

This report may only be reproduced or published in full, without omissions, alterations or additions.

The reproduction or publishing of extracts from this report require the written approval of the research center.



1529