

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

PRODUCT RANGE




Size 000 gG 400VAC

Catalog number	Item number	Rated voltage AC (IEC)	Rated current I _n	Power dissipation at I _n	Width	Package	Weight
NH000GG40V2	Z223674	400 V	2 A	0.7 W	20.8 mm	3	0.13 kg
NH000GG40V4	A223675	400 V	4 A	0.9 W	20.8 mm	3	0.13 kg
NH000GG40V6	B223676	400 V	6 A	1.2 W	20.8 mm	3	0.13 kg
NH000GG40V10	C223677	400 V	10 A	1.3 W	20.8 mm	3	0.13 kg
NH000GG40V16	D223678	400 V	16 A	1.6 W	20.8 mm	9	0.13 kg
NH000GG40V20	E223679	400 V	20 A	1.9 W	20.8 mm	9	0.13 kg
NH000GG40V25	F223680	400 V	25 A	2.2 W	20.8 mm	9	0.13 kg
NH000GG40V32	G223681	400 V	32 A	2.7 W	20.8 mm	9	0.13 kg
NH000GG40V35	H223682	400 V	35 A	3.1 W	20.8 mm	9	0.13 kg
NH000GG40V40	J223683	400 V	40 A	3.5 W	20.8 mm	9	0.13 kg
NH000GG40V50	K223684	400 V	50 A	3.9 W	20.8 mm	9	0.13 kg
NH000GG40V63	L223685	400 V	63 A	5.2 W	20.8 mm	9	0.13 kg
NH000GG40V80	M223686	400 V	80 A	5.3 W	20.8 mm	9	0.13 kg
NH000GG40V100	N223687	400 V	100 A	5.7 W	20.8 mm	9	0.13 kg




Size 00 gG 400VAC

Catalog number	Item number	Rated voltage AC (IEC)	Rated current I _n	Power dissipation at I _n	Width	Package	Weight
NH00GG40V125	E223702	400 V	125 A	7.4 W	29.5 mm	3	0.2 kg
NH00GG40V160	F223703	400 V	160 A	8.3 W	29.5 mm	3	0.2 kg



Size 1 gG 400VAC

Catalog number	Item number	Rated voltage AC (IEC)	Rated current I _n	Power dissipation at I _n	Width	Package	Weight
NH1GG40V35	J223706	400 V	35 A	4 W	29.5 mm	3	0.28 kg
NH1GG40V50	K223707	400 V	50 A	5.2 W	29.5 mm	3	0.28 kg
NH1GG40V63	L223708	400 V	63 A	6.8 W	29.5 mm	3	0.28 kg
NH1GG40V80	M223709	400 V	80 A	6.2 W	29.5 mm	3	0.28 kg
NH1GG40V100	N223710	400 V	100 A	8.6 W	29.5 mm	3	0.28 kg
NH1GG40V125	P223711	400 V	125 A	9.8 W	29.5 mm	3	0.28 kg
NH1GG40V160	Q223712	400 V	160 A	12.4 W	39.5 mm	3	0.41 kg
NH1GG40V200	R223713	400 V	200 A	14.4 W	39.5 mm	3	0.41 kg
NH1GG40V224	S223714	400 V	224 A	15.6 W	39.5 mm	3	0.41 kg
NH1GG40V250	T223715	400 V	250 A	17.6 W	39.5 mm	3	0.41 kg



Size 2 gG 400VAC

Catalog number	Item number	Rated voltage AC (IEC)	Rated current I _n	Power dissipation at I _n	Width	Package	Weight
NH2GG40V35	T227257	400 V	35 A	4.1 W	29.5 mm	3	0.42 kg
NH2GG40V50	V227258	400 V	50 A	5.4 W	29.5 mm	3	0.42 kg
NH2GG40V63	W227259	400 V	63 A	6.8 W	29.5 mm	3	0.42 kg
NH2GG40V80	F223726	400 V	80 A	6.4 W	29.5 mm	3	0.42 kg
NH2GG40V100	G223727	400 V	100 A	8.1 W	29.5 mm	3	0.42 kg
NH2GG40V125	H223728	400 V	125 A	10.2 W	29.5 mm	3	0.42 kg
NH2GG40V160	J223729	400 V	160 A	10.8 W	29.5 mm	3	0.42 kg
NH2GG40V200	K223730	400 V	200 A	15.2 W	29.5 mm	3	0.42 kg
NH2GG40V224	L223731	400 V	224 A	14.7 W	29.5 mm	3	0.42 kg
NH2GG40V250	M223732	400 V	250 A	17.1 W	29.5 mm	3	0.42 kg
NH2GG40V315	N223733	400 V	315 A	20.1 W	39.5 mm	3	0.64 kg
NH2GG40V355	P223734	400 V	355 A	22.6 W	39.5 mm	3	0.64 kg
NH2GG40V400	Q223735	400 V	400 A	25.4 W	39.5 mm	3	0.64 kg

ВЯРНО С
КОПИРИНАЛА



NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

PRODUCT RANGE


Size 3 gG 400VAC

Catalog number	Item number	Rated voltage AC (IEC)	Rated current (A)	Power dissipation (W)	Width	Number of poles	Weight (kg)
NH3GG40V250	R223736	400 V	250 A	15.4 W	39.5 mm	1	0.65 kg
NH3GG40V315	S223737	400 V	315 A	19.8 W	39.5 mm	1	0.65 kg
NH3GG40V400	T223738	400 V	400 A	25.1 W	39.5 mm	1	1.05 kg
NH3GG40V500	V223739	400 V	500 A	31.1 W	51 mm	1	1.05 kg
NH3GG40V630	W223740	400 V	630 A	39 W	51 mm	1	1.05 kg

TECHNICAL DATA

	Size 000 gG 400VAC	Size 00 gG 400VAC	Size 1 gG 400VAC	Size 2 gG 400VAC	Size 3 gG 400VAC
Rated current	2 ... 100 A	125 ... 160 A	35 ... 250 A	35 ... 400 A	250 ... 630 A
Rated breaking capacity AC	100 kA	100 kA	100 kA	100 kA	100 kA
Rated voltage AC	400 V	400 V	400 V	400 V	400 V
Indication System	double indicator	double indicator	double indicator	double indicator	double indicator
Width	21 mm	30 mm	40 mm	51 mm	70 mm

ВЯРНО С
ОРИГИНАЛА




MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

TIME CURRENT CHARACTERISTIC CURVES

Size 000



Mersen reserves the right to change, update or correct, without notice, any information contained in this datasheet.


NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

TIME CURRENT CHARACTERISTIC CURVES

Size 00

Handwritten signature




Mersen preserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

TIME CURRENT CHARACTERISTIC CURVES

Size 1



MERSEN reserves the right to change the contents of the data sheet, without notice, any information contained in this data sheet.


NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

TIME CURRENT CHARACTERISTIC CURVES

Handwritten signature

Size 2



MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.


NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

TIME CURRENT CHARACTERISTIC CURVES


Handwritten signature

Size 3



RMS value of prospective current (A) +/- 8%

ВЯРНО С
ОРИГИНАЛА



Handwritten signature

MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.


NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3


CUT-OFF CURRENT CHARACTERISTIC

Size 000


Handwritten signature



Size 00



ВЯРНО С
ОРИГИНАЛА



MERSER reserves the right to change, update or correct, without notice, any information contained in this datasheet.

Handwritten signature


NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3


CUT-OFF CURRENT CHARACTERISTIC

Handwritten signature


Size 1



Size 2



**ВЯРНО С
ОРИГИНАЛА**



MERSEN reserves the right to change, update or correct, without notice, any information contained in this database.


NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

CUT-OFF CURRENT CHARACTERISTIC

Size 3

Handwritten signature



Handwritten signature

ВЯРНО С
ОРИГИНАЛА



MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

Handwritten signature


NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

PRE-ARCING AND OPERATING I²t CHARACTERISTICS

Handwritten signature

Size 000



ВЪРХО С
ОРИГИНАЛА




MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

PRE-ARCING AND OPERATING I²t CHARACTERISTICS


Size 00




Handwritten signature

Handwritten mark

Size 1



ВЯРНО С
ОРИГИНАЛА



The document reserves the right to change, update or correct, without notice, any information contained in this datasheet.


NH fuse-links gG 400VAC

double indicator/live gripping-fugs size 000, 00, 1, 2, 3

PRE-ARCING AND OPERATING I^2t CHARACTERISTICS

Handwritten signature

Size 2



**ВЯРНО С
ОРИГИНАЛА**




MERSEN reserves the right to change the data or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

PRE-ARCING AND OPERATING I²T CHARACTERISTICS


Size 3



[Handwritten signature]

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА





MERSEN reserves the right to change, update or correct, without notice, any info contained in this datasheet.

NH fuse-links gG 400VAC


double indicator/live gripping-lugs size 000, 00, 1, 2, 3

DIMENSIONS



Size 000 with double indicator (0118997C)



Visibility of red indicator signals conduction of the fuse-link. After operation the red indicator is no longer visible



Dimensions in mm





MERSEN reserves the right to change, delete or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC


double indicator/live gripping-lugs size 000, 00, 1, 2, 3

DIMENSIONS


Size 00 with double indicator (118998 D)




• Visibility of red indicator signals conduction of the fuse-link.
After operation the red indicator is no longer visible



Dimensions in mm



ВЯРНО С
ОРИГИНАЛА




NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

DIMENSIONS

Size 1 compact with double indicator (35-125A) (1000413B)



Visibility of red Indicator signals conduction of the fuse-link.
After operation the red indicator is no longer visible

Dimensions in mm

ВЯРНО С
ОРИГИНАЛА




MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC


double indicator/live gripping-lugs size 000, 00, 1, 2, 3

DIMENSIONS



Size 1 with double indicator (160-250A) (118997 D)



Handwritten signature




Visibility of red indicator signals conduction of the fuse-link. After operation the red indicator is no longer visible



Dimensions in mm

ВЯРНО С
ОРИГИНАЛА



Handwritten signature


MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC



double indicator/live gripping-lugs size 000, 00, 1, 2, 3

DIMENSIONS


Size 2 compact with double indicator (35-250A) (1000412C)



Handwritten signature



Visibility of red indicator signals conduction of the fuse-link. After operation the red indicator is no longer visible



Dimensions in mm

ВЯРНО С
ОРИГИНАЛА





MERSEN reserves the right to change specifications or correct, without notice, any information contained in this document.

NH fuse-links gG 400VAC


double indicator/live gripping-lugs size 000, 00, 1, 2, 3

DIMENSIONS


Size 2 with double indicator (315-400A) (119001 C)



Visibility of red indicator signals conduction of the fuse-link.
After operation the red indicator is no longer visible



Dimensions in mm



ВЯРНО С
ОРИГИНАЛА






MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3


DIMENSIONS

Size 3 compact with double indicator (250-400A) (1000411B)



Visibility of red indicator signals conduction of the fuse-link.
After operation the red indicator is no longer visible

Dimensions in mm



ВЯРНО С
ОРИГИНАЛА



MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.



NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3


DIMENSIONS

Size 3 with double indicator (500-630A) (119D02 C)


Handwritten signature



Visibility of red indicator signals conduction of the fuse-link.
After operation the red indicator is no longer visible



Dimensions in mm



ВЯРНО С
ОРИГИНАЛА




Mersen reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

LOW VOLTAGE IEC FUSES

IEC NH FUSE-LINKS



FEATURES & BENEFITS

- Dimensions according to DIN 43 620 Parts 1 to 4
- Non-isolated gripping lugs
- Double indicator
- Lead free contact blades
- 0% cadmium

APPLICATIONS

- gG: general purpose cable and line protection

STANDARDS

- VDE 0636 Part 201
- IEC 60269-1 and -2

The NH system is classified among plug-in fuse systems and is composed of:

- fuse-base (possibly including terminal covers and phase barriers)
- fuse-link with blade contact
- fuse-link replacement device (LV HRC fuse puller)

Since the design of this system cannot guarantee non-interchangeability of rated current it must be handled by a qualified professional.


Type "gG" NH fuse-links are full range breaking capacity fuse-links and are used to protect cables and equipment. They can interrupt any current surge, from the lowest fusing current up to their breaking capacity, and so can be used alone as protection. They also protect electrical devices and industrial set-ups from the electrodynamic effects of very high short-circuit currents.

Rated Power Dissipation values of Mersen NH fuse-links 400VAC are below the maximum values required by standard IEC 60269.

TECHNICAL DATA OVERVIEW

Voltage AC	400 VAC
Ampere Range (A)	2 ... 630 A
Size per Standard	Sizes 000 to 3
Speed/Characteristic	gG
I.R. AC (IEC)	100 kA
Body Material	ceramic
Contact Materials	copper, silver-plated

ВАРНО С
ОРИГИНАЛА



MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

PRODUCT RANGE



Size 000 gG 400VAC

Catalog number	Item number	Rated voltage AC (IEC)	Rated current I _n	Power dissipation at I _n	Width	Package	Weight
NH000GG40V2	Z223674	400 V	2 A	0.7 W	20.8 mm	3	0.13 kg
NH000GG40V4	A223675	400 V	4 A	0.9 W	20.8 mm	3	0.13 kg
NH000GG40V6	B223676	400 V	6 A	1.2 W	20.8 mm	3	0.13 kg
NH000GG40V10	C223677	400 V	10 A	1.3 W	20.8 mm	3	0.13 kg
NH000GG40V16	D223678	400 V	16 A	1.6 W	20.8 mm	9	0.13 kg
NH000GG40V20	E223679	400 V	20 A	1.9 W	20.8 mm	9	0.13 kg
NH000GG40V25	F223680	400 V	25 A	2.2 W	20.8 mm	9	0.13 kg
NH000GG40V32	G223681	400 V	32 A	2.7 W	20.8 mm	9	0.13 kg
NH000GG40V35	H223682	400 V	35 A	3.1 W	20.8 mm	9	0.13 kg
NH000GG40V40	J223683	400 V	40 A	3.5 W	20.8 mm	9	0.13 kg
NH000GG40V50	K223684	400 V	50 A	3.9 W	20.8 mm	9	0.13 kg
NH000GG40V63	L223685	400 V	63 A	5.2 W	20.8 mm	9	0.13 kg
NH000GG40V80	M223686	400 V	80 A	5.3 W	20.8 mm	9	0.13 kg
NH000GG40V100	N223687	400 V	100 A	5.7 W	20.8 mm	9	0.13 kg




Size 00 gG 400VAC

Catalog number	Item number	Rated voltage AC (IEC)	Rated current I _n	Power dissipation at I _n	Width	Package	Weight
NH00GG40V125	E223702	400 V	125 A	7.4 W	29.5 mm	3	0.2 kg
NH00GG40V160	F223703	400 V	160 A	8.3 W	29.5 mm	3	0.2 kg



Size 1 gG 400VAC


Catalog number	Item number	Rated voltage AC (IEC)	Rated current I _n	Power dissipation at I _n	Width	Package	Weight
NH1GG40V35	J223706	400 V	35 A	4 W	29.5 mm	3	0.28 kg
NH1GG40V50	K223707	400 V	50 A	5.2 W	29.5 mm	3	0.28 kg
NH1GG40V63	L223708	400 V	63 A	6.8 W	29.5 mm	3	0.28 kg
NH1GG40V80	M223709	400 V	80 A	6.2 W	29.5 mm	3	0.28 kg
NH1GG40V100	N223710	400 V	100 A	8.6 W	29.5 mm	3	0.28 kg
NH1GG40V125	P223711	400 V	125 A	9.8 W	29.5 mm	3	0.28 kg
NH1GG40V160	Q223712	400 V	160 A	12.4 W	39.5 mm	3	0.41 kg
NH1GG40V200	R223713	400 V	200 A	14.4 W	39.5 mm	3	0.41 kg
NH1GG40V224	S223714	400 V	224 A	15.6 W	39.5 mm	3	0.41 kg
NH1GG40V250	T223715	400 V	250 A	17.6 W	39.5 mm	3	0.41 kg



Size 2 gG 400VAC

Catalog number	Item number	Rated voltage AC (IEC)	Rated current I _n	Power dissipation at I _n	Width	Package	Weight
NH2GG40V35	T227257	400 V	35 A	4.1 W	29.5 mm	3	0.42 kg
NH2GG40V50	V227258	400 V	50 A	5.4 W	29.5 mm	3	0.42 kg
NH2GG40V63	W227259	400 V	63 A	6.8 W	29.5 mm	3	0.42 kg
NH2GG40V80	F223726	400 V	80 A	6.4 W	29.5 mm	3	0.42 kg
NH2GG40V100	G223727	400 V	100 A	8.1 W	29.5 mm	3	0.42 kg
NH2GG40V125	H223728	400 V	125 A	10.2 W	29.5 mm	3	0.42 kg
NH2GG40V160	J223729	400 V	160 A	10.8 W	29.5 mm	3	0.42 kg
NH2GG40V200	K223730	400 V	200 A	15.2 W	29.5 mm	3	0.42 kg
NH2GG40V224	L223731	400 V	224 A	14.7 W	29.5 mm	3	0.42 kg
NH2GG40V250	M223732	400 V	250 A	17.1 W	29.5 mm	3	0.42 kg
NH2GG40V315	N223733	400 V	315 A	20.1 W	39.5 mm	3	0.64 kg
NH2GG40V355	P223734	400 V	355 A	22.6 W	39.5 mm	3	0.64 kg
NH2GG40V400	Q223735	400 V	400 A	25.4 W	39.5 mm	3	0.64 kg

ВЪРНО
ОРИГИНАЛ



MERSEN reserves the right to check, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

PRODUCT RANGE

Size 3 gG 400VAC

Model number	Item number	Rated voltage AC (IEC)	Rated current	Power dissipation (W)	Width	Packages	Weight
NH3GG40V250	R223736	400 V	250 A	15.4 W	39.5 mm	1	0.65 kg
NH3GG40V315	S223737	400 V	315 A	19.8 W	39.5 mm	1	0.65 kg
NH3GG40V400	T223738	400 V	400 A	25.0 W	39.5 mm	1	1.05 kg
NH3GG40V500	V223739	400 V	500 A	31.1 W	51 mm	1	1.05 kg
NH3GG40V630	W223740	400 V	630 A	39 W	51 mm	1	1.05 kg

TECHNICAL DATA

	Size 000 gG 400VAC	Size 00 gG 400VAC	Size 1 gG 400VAC	Size 2 gG 400VAC	Size 3 gG 400VAC
Rated current	2 ... 100 A	125 ... 160 A	35 ... 250 A	35 ... 400 A	250 ... 630 A
Rated breaking capacity AC	100 kA	100 kA	100 kA	100 kA	100 kA
Rated voltage AC	400 V	400 V	400 V	400 V	400 V
Indication System	double indicator	double indicator	double indicator	double indicator	double indicator
Width	21 mm	30 mm	40 mm	51 mm	70 mm

ВЯРНО С
ОРИГИНАЛА




MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC


double indicator/live gripping-lugs size 000, 00, 1, 2, 3

TIME CURRENT CHARACTERISTIC CURVES

Size 2



RMS value of prospective current (A) +/- 8%




MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

TIME CURRENT CHARACTERISTIC CURVES

Size 3




NH fuse-links gG 400VAC


double indicator/live gripping-lugs size 000, 00, 1, 2, 3

CUT-OFF CURRENT CHARACTERISTIC

Size 1



Size 2



ВЯРНО С
ОРИГИНАЛА




MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

CUT-OFF CURRENT CHARACTERISTIC

Size 3



Handwritten signature

Handwritten signature

ВЯРНО С
ОРИГИНАЛА




MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

PRE-ARCING AND OPERATING I²T CHARACTERISTICS

Size 2



ВЯРНО С
ОРИГИНАЛА




MERSEN reserves the right to change, update or correct, without notice, any info contained in this datasheet.

NH fuse-links gG 400VAC

double indicator/live gripping-lugs size 000, 00, 1, 2, 3

PRE-ARCING AND OPERATING I²T CHARACTERISTICS


Size 3



[Handwritten signature]

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА






MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC


double indicator/live gripping-lugs size 000, 00, 1, 2, 3

DIMENSIONS

Size 2 compact with double indicator (35-250A) (1000412C)




Visibility of red indicator signals conduction of the fuse-link. After operation the red indicator is no longer visible



Dimensions in mm

ВЯРНО С
ОРИГИНАЛА





MERSEN reserves the right to change, update or correct, without notice, any info contained in this datasheet.

NH fuse-links gG 400VAC


double indicator/live gripping-lugs size 000, 00, 1, 2, 3

DIMENSIONS


Size 2 with double indicator (315-400A) (119001 C)



Visibility of red indicator signals conduction of the fuse-link.
After operation the red indicator is no longer visible



Dimensions in mm



ВЯРНО С
ОРИГИНАЛА





MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.

NH fuse-links gG 400VAC


double indicator/live gripping-lugs size 000, 00, 1, 2, 3

DIMENSIONS


Size 3 with double indicator (500-630A) (119002 C)



Visibility of red indicator signals conduction of the fuse-link.
After operation the red indicator is no longer visible



Dimensions in mm



ВЯРНО С
ОРИГИНАЛА



MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.



EU DECLARATION OF CONFORMITY / DECLARATION DE CONFORMITE UE

We / Nous **Mersen France SB** sas 15, Rue Jacques Vaucanson 69720 Saint Bonnet de Mure France
Website / Site web **ep-fr.mersen.com** (this declaration is downloadable / cette déclaration est téléchargeable)

Certify that products with the registered trade mark / Certifions que les produits de la marque Mersen ® or / ou FERRAZ SHAWMUT ® ,

Blade type fuses w-w/o indicator- striker / Fusibles à couteaux avec-ou sans indicateur-percuteur
NH000, NH00, NH0, NH1, NH2, NH3, NH4, NH4a, AM, GG, GTR & accessories / et accessoires

Provided that they are installed, maintained and used as intended and in accordance with the current installation standards according to manufacturer's recommendations, comply with the following Directives

Sous réserve d'installations, d'entretien et d'utilisation conformes à leur destination, aux normes d'installations applicables et aux instructions du constructeur, satisfont aux exigences des Directives suivantes:

Low Voltage 2014/35/EU
Rohs 2011/65/EU

Basse Tension 2014/35/UE
Rohs 2011/65/UE

And are in compliance with the following standards / et sont conformes aux normes suivantes:

EN 60269-1 Ed.2007 / A1:2009 / A2:2014
HD 60269-2 Ed.2013

DIN 43620 Ed. 1984


ВЯРНО С
ОРИГИНАЛА

на основание чл. 2 от ЗЗЛД

Saint Bonnet de Mure le 05 Septembre 2017 Name / Nom


Position / Fonction : Product Certification Manager

Signature / Signature на основание чл. 2 от ЗЗЛД



DECLARATION CE N° 0 0 3 4 V

Декларация за съответствие
Ние Mersen france SB
интернет страница en-fr.mersen.com



че продуктите с регистрирана търговска марка Mersen или FERRAZ SHAWMUT

Ножови предпазители със и/или без индикатори-ударник типове

NH000, NH00, NH0, MN1, MN2, NH3, NH4, NH4a, AM, GG, GTR и аксесоарите към тях

При условие че са инсталирани, поддържани и използвани по предназначение и в съответствие с стандарти и препоръки на производителя, отговарят на следните директиви:

Ниско напрежение 2014/35/EU
Rohs 2011/65/EU

И отговарят на изчисленията на следните стандарти:
EN 60269-1 ed.2007 / A1 : 2009 / A2 : 2014
DIN 43260 ed. 1984
HD 60269-2 ed.2013

Дата 05.09.2017 Подписи и печати

16.03.2018 г.
ГР. ШУМЕН

на основание чл. 2 от ЗЗЛД

/ИНЖ. И. НИКОЛОВ/



Reach status DECLARATION

Nous/We **Mersen France SB SAS 15, Rue de Vaucanson 69720 Saint Bonnet de Mure Cedex France**

Hereby declare that products with the registered trade mark FERRAZ SHAWMUT ®, or Mersen
 Certifions par ce document que les produits de la marque FERRAZ SHAWMUT ®, or Mersen

Blade type fuses , fusibles à couteaux (catalog number structure)					
type	size/taille	class/classe	voltage/tension	rating/calibre (A or KVA)	suffixes
NH	000 or 00 or 0 or 1 or 2 or 3 or 4 or 4a	AM or GG or GTR	xxV	xxx	divers

Neutral blade type NH sizes / Cartouches neutres à couteaux NH tailles : 0, 00, 1, 2, 3, 4

do not contain any of the 174 SVHC substances at a rate of more than 0.1% by weight according to the current valid candidate list nor any substance of Annex 17, according to ECHA since July 07, 2017 .

The present declaration is based on a permanent communication with our suppliers .

In case of any change, we would inform ECHA and our customers according to Reach requests.

Mersen France SB is not concerned by the Reach registration procedure, (being neither a producer nor an importer of substances/preparations).

We periodically review the ECHA candidate list , and we ask our suppliers to commit to deliver pieces , parts and products , free of SVHC substances at a rate of more than 0.1% by weight , for every order .

As an article Downstream user in the value chain, Mersen will :

- Continue to drive a strict policy of Occupational Health and Safety based on up to date versions of Safety Data Sheets.
- Monitor by-the-supplier-identified uses of Substances and Preparations contained in our products.
- Seek out possibilities to substitute or reformulate in anticipation of possible disappearances of Substances or products.

Mersen's active communication policy with our suppliers and customers may help avoid any adverse effect of the Reach Regulation on our products, in order to continue ensuring and enhancing the safety of people and property.

Ne contiennent aucune des 174 substances SVHC à plus de 0,1% en masse de la liste candidate, ni substance de l'Annexe 17 de l' ECHA depuis le 07 juillet 2017 .

La déclaration présente est basée sur une communication permanente avec nos fournisseurs .

En cas de changement, nous informerions l'ECHA et nos clients selon les exigences Reach .

Mersen France SB n'est pas concernée par la procédure d'enregistrement (ni producteur ni importateur de substance/préparation).

Nous vérifions périodiquement la liste candidate de l'ECHA , et demandons à nos fournisseurs leur engagement de nous livrer des pièces/produits libres de substance SVHC à plus de 0,1% en masse à chaque commande.

En tant qu'utilisateur aval d'articles dans la chaîne d'approvisionnement , Mersen

- Poursuit avec rigueur une politique de Santé/Sécurité sur la base des versions à jour des Fiches de Données de Sécurité.
- Surveille les usages identifiés par les fournisseurs des Substances et Préparations utilisées dans nos produits.
- S'informe des possibilités de substitution/reformulation pour anticiper d'éventuelles disparitions de Substances/Préparations.

La politique active de communication de Mersen avec ses fournisseurs et clients doit permettre d'éviter tout impact négatif de Reach sur nos produits, afin de continuer à servir la Sécurité des biens et des personnes.

Saint Bonnet de Mure le : 19 juillet 2017 Nom / Name :

Fonction / Position : Europe Product Certification and High Concerned Material Manager

Signature / Signature : на основание чл. 2 от 33ЛД

DECLARATION REACH N° 0 0 0 3 Q

ВЯРНО С
ОРИГИНАЛ

CESTRUL
BULGARIA

4



Marine & Offshore
Division

Certificate number: 03924/E1 BV
File number: ACE 03/017/01
Product code: 2645H

This certificate is not valid when presented without the full attached schedule composed of 7 sections

www.veristar.com

TYPE APPROVAL CERTIFICATE

This certificate is issued to
MERSEN FRANCE SB S.A.S
SAINT BONNET DE MURE - FRANCE

for the type of product
FUSES / FUSES COMBINATION UNITS (LOW VOLTAGE)
Fuse links with indicator NH00, NH0, NH1, NH2, NH3 series (aM, gG).

Requirements:
BV Rules for the Classification of Steel Ships.
IEC 60269-1 (2009).

This certificate is issued to attest that BUREAU VERITAS did undertake the relevant approval procedures for the product identified above which was found to comply with the relevant requirements mentioned above.

This certificate will expire on: 23 Dec 2020

For BUREAU VERITAS,
At BV LYON, on 03 Apr 2017,
Jean-Marc Cabuzel

на основание чл. 2 от ЗЗЛД



This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with BUREAU VERITAS. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. This certificate is issued within the scope of the General Conditions of BUREAU VERITAS Marine & Offshore Division available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against BUREAU VERITAS for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

THE SCHEDULE OF APPROVAL

1. PRODUCT DESCRIPTION :

Designation/Fuse-link	Rated voltage(V)	Rated current (A)	Breaking capacity (kA)
Knife-Cartridge			
NH00 gG	690	8-100	120 kA 400/500V
NH00 gG	500	125-160	
NH00 aM	690	16-100	
NH00 aM	500	125-160	
NH0 gG	690	10-100	80 kA 690V
NH0 gG	500	125-160	
NH0 aM	690	40-160	
NH1 gG	690	16-200	
NH1 gG	500	224-355	
NH1 aM	690	50-250	
NH2 gG	690	32-315	
NH2 gG	500	355-500	
NH2 aM	690	100-400	
NH3 gG	690	315-500	
NH3 gG	500	630-800	
NH3 aM	690	315-500	
NH3 aM	500	630	

2. DOCUMENTS AND DRAWINGS :

Specification ref. DS-LFBCA5-05-0416_EN, dated 21.Jun.2016.
 Specification ref. DS-LFBCA54-03-0616_EN, dated 21.Jun.2016.
 Specification ref. DS-LFBCA6-05-0416_EN, dated 21.Jun.2016.
 Specification ref. DS-LFBCS4-06-0616_EN, dated 21.Jun.2016.
 Specification ref. DS-LFBCG5-04-0416_EN, dated 22.Jun.2016.
 Specification ref. DS-LFBCG6-04-0416_EN, dated 21.Jun.2016.

3. TEST REPORTS :


According to test reports filed in ACE 03/017/01.

4. APPLICATION / LIMITATION :

- 4.1 - BV Rules for the Classification of Steel Ships.
 4.2 - Approval also valid for ships to be granted with the notations: AUT-UMS, AUT-CCS, AUT-PORT and AUT-IMS.

5. PRODUCTION SURVEY REQUIREMENTS :

- 5.1 - The NH series are to be supplied by MERSEN FRANCE SB S.A.S in compliance with the type description in this certificate.
 5.2 - This type of product is within the category HBV of Bureau Veritas Rule Note NR320 and as such does not require a BV product certificate.
 5.3 - MERSEN FRANCE SB S.A.S has to make the necessary arrangements to have its works recognised by Bureau Veritas in compliance with the requirements of NR320 for HBV products.



6. MARKING OF PRODUCT :

The items prescribed below shall be marked on a easily visible place of fuse surface in an indelible way.

- 1 - Rated voltage (V)
- 2 - Rated current (A)
- 3 - Rated breaking capacity
- 4 - Fusing Factor
- 5 - Manufacturer's name
- 6 - Model N°
- 7 - Approved class name.

7. OTHERS :

7.1 - It is **MERSEN FRANCE SB S.A.S** responsibility to inform shipbuilders or their sub-contractors of the proper methods of fitting, use and general maintenance of the approved equipment and the conditions of this approval.

7.2 - This certificate supersedes the Type Approval Certificate N° 03924/E0 BV issued on 23 Dec.2015. by the Society.

*** END OF CERTIFICATE ***



ВЯРНО С
ОРИГИНАЛА



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Rating and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional Information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

Fuse-link, NH-System

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE
FRANCE

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE
FRANCE

FUSETECH Kft.
Guba Sandor ut. 38, 7400 KAPOSVAR
HUNGARY

Additional Information on page 2

see additional information on page 2



NH3GG50Vxxx; NH3GG50Vxxx-1,
NH32GG50Vxxx; NH32GG50Vxxx-1

Additional Information on page 2

IEC 60269-1:2006
IEC 60269-1:2006/AMD1:2009
IEC 60269-1:2006/AMD2:2014
IEC 60269-2:2013
IEC 60269-2:2013/AMD1:2016

230314-CG2-1 to -2




VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
 Zertifizierung Produkte / Certification Products

Date: 2017-01-30

Signature: J. Richter

на основание чл. 2 от ЗЗЛД

IEC

TECEE
CB
SCHEME

Ref. Certif. No.

DE1-58281

Additional information (if necessary)

Un: 500V a.c.

Breaking capacity: 120 kA

Characteristic: gG

Size 3

Type / In:

NH3GG50Vxxx (energized / compact size) 250 ... 400A

NH3GG50Vxxx-1 (de-energized / compact size) 250 ... 400A


NH32GG50Vxxx (energized / normal size) 250 ... 400A

NH32GG50Vxxx-1 (de-energized / normal size) 250 ... 400A

NH3GG50Vxxx (energized / normal size) 500 ... 630A

NH3GG50Vxxx-1 (de-energized / normal size) 500 ... 630A.

ВЯРНО С
ОРИГИНАЛА



VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

на основание чл. 2 от ЗЗЛД

Date: 2017-01-30

Signature:



J. Richter

Списък на изпитанията

Към Сертификат №DE1-58281 с тестови протокол №230314-CC2-1:2

На Високомощни ножови предпазители NH3 500V

1. Изпитания съгласно стандарт IEC 60269-1:2006;
2. Изпитания съгласно стандарт IEC 60269-1:2006/AMD1:2009;
3. Изпитания съгласно стандарт IEC 60269-1:2006/AMD2:2009;
4. Изпитания съгласно стандарт IEC 60269-2:2013;
5. Изпитания съгласно стандарт IEC 60269-2:2013/AMD2:2006;





Ref. Certif. No.

DE1-58279

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (If any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional Information (If necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Fuse-link, NH-System

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

FUSETECH Kft.
Guba Sandor ut. 38, 7400 KAPOSVAR HUNGARY

Additional Information on page 2

see additional information on page 2

MERSEN

NH2GG50Vxxx; NH2GG50Vxxx-1, NH2GG50Vxxx; NH2GG50Vxxx-1


see additional information on page 2

Additional Information on page 2

IEC 60269-1:2006
IEC 60269-1:2006/AMD1:2009
IEC 60269-2:2013
IEC 60269-2:2013/AMD1:2016

230292-CC2-1; 230292-CC2-2

ВЕРНО С
ОРИГИНАЛА



This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

на основание чл. 2 от ЗЗЛД

Date: 2017-01-30

Signature: J. Richter



Ref. Certif. No.

DE1-58279

Additional information (if necessary)

Un: 500V a.c.
 Breaking capacity: 120 kA
 Characteristic: gG
 Size: 2
 Type / In:
 NH2GG50Vxxx (energized / compact size) 35 ... 250A
 NH2GG50Vxxx-1 (de-energized / compact size) 35 ... 250A

 NH2GG50Vxxx (energized / normal size) 315 ...400A
 NH2GG50Vxxx-1 (de-energized / normal size) 315 ...400A

 NH2GG50Vxxx (energized / normal size) 63 ...250A
 NH2GG50Vxxx-1 (de-energized / normal size) 63 ...250A

ВЯРНО С
ОРИГИНАЛА



VDE Prüf- und Zertifizierungsinstitut GmbH
 VDE Testing and Certification Institute
 Zertifizierung Produkte / Certification Products

на основание чл. 2 от ЗЗЛД

Date: 2017-01-30



Signature: J. Richter

Списък на изпитанията

Към Сертификат №DE1-58279 с тестови протокол №230292-CC2-1; №230292-CC2-2

На Високомощни ножови предпазители NH2 500V

1. Изпитания съгласно стандарт IEC 60269-1:2006;
2. Изпитания съгласно стандарт IEC 60269-1:2006/AMD1:2009;
3. Изпитания съгласно стандарт IEC 60269-2:2013;
4. Изпитания съгласно стандарт IEC 60269-2:2013/AMD2:2006;

A large, stylized handwritten signature in black ink, located to the right of the list of tests.A large, stylized handwritten signature in black ink, located in the middle-right area of the page.A large, stylized handwritten signature in black ink, located at the bottom right of the page.

VDE Prüf- und Zertifizierungsinstitut

ZEICHENGENEHMIGUNG MARKS APPROVAL

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson
69720 SAINT BONNET DE MURE
FRANCE

ist berechtigt, für Ihr Produkt /
is authorized to use for their product
Sicherungseinsatz, NH-System

Fuse-link, NH-System
NH3GG40Vxxx
NH3GG40Vxxx-1

die hier abgebildeten markenrechtlich geschützten Zeichen
für die ab Blatt 2 aufgeführten Typen zu benutzen /
the legally protected Marks as shown below for the types referred to on page 2 ff.



Geprüft und zertifiziert nach /
Tested and certified according to

DIN EN 60269-1 (VDE 0636-1):2015-05; EN 60269-1:2007 + A1:2009 + A2:2014
DIN VDE 0636-2 (VDE 0636-2):2014-09 HD 60269-2:2013

ВЯРНО С
ОРИГИНАЛА



Aktenzeichen: 5003214-1150-0012 / 217877
File ref.:


VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification

Ausweis-Nr. 40041833
Certificate No.

Blatt
Page

Weitere Bedingungen siehe Rückseite und Folgeblätter /
further conditions see overleaf and following pages

Offenbach, 2015-03-05
(letzte Änderung / updated: 2015-12-21)



на основание чл. 2 от ЗЗЛД

Verantwortung unter:
VDE certificates are valid only when polished on:

<http://www.vde.com/zertifikat>
<http://www.vda.com/certificate>



VDE Prüf- und Zertifizierungsinstitut Zeichengenehmigung

Ausweis-Nr. / Blatt /
Certificate No. / Page
40041833 2

Name und Sitz des Genehmigungs-Inhabers / Name and registered seat of the Certificate holder
Mersen France SB S.A.S., 15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

Aktenzeichen / File ref.
5003214-1150-0012 / 217877 / CC2 / KOH

letzte Änderung / updated Datum / Date
2015-12-21 2015-03-05

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 40041833.
This supplement is only valid in conjunction with page 1 of the Certificate No. 40041833.

Sicherungseinsatz, NH-System

Fuse-link, NH-System

NH3GG40Vxxx
NH3GG40Vxxx-1

Typ(en) / Type(s)

NH3GG40Vxxx
NH3GG40Vxxx-1

Bemessungsspannung Rated voltage	400 V a.c.
Bemessungsstrom Rated current	250 A; 315 A; 400 A; 500 A; 630 A
Bemessungsfrequenz Rated frequency	45 bis/to 62 Hz
Bemessungsausschaltvermögen Rated breaking capacity	100 kA
Baugröße Size	3
Abmessung	Typen mit Maßen der kleineren Baugröße: NH3GG40V250(-1); NH3GG40V315(-1); NH3GG40V400(-1)
Dimension	Typen mit Standardmaßen: NH3GG40V500(-1); NH3GG40V630(-1) Types with dimensions of smaller size: NH3GG40V250(-1); NH3GG40V315(-1); NH3GG40V400(-1) Types with standard dimensions: NH3GG40V500(-1); NH3GG40V630(-1)
Betriebsklasse Utilization category	gG
Griffflasche Gripping lug	spannungsführend (NH3GG40Vxxx) spannungsfrei (NH3GG40Vxxx-1) energized (NH3GG40Vxxx) de-energized (NH3GG40Vxxx-1)
Anzeigevorrichtung Indicating device	Anzeiger vorne und oben Indicator in front and at the top

Fortsetzung siehe Blatt 3 /
continued on page 3



ВЯРНО С
ОРИГИНАЛА



VDE Prüf- und Zertifizierungsinstitut Zeichengenehmigung

Ausweis-Nr. / Blatt /
Certificate No. / Page
40041833 3

Name und Sitz des Genehmigungs-Inhabers / Name and registered seat of the Certificate holder
Mersen France SB S.A.S., 15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

Aktenzeichen / File ref.
5003214-1150-0012 / 217877 / CC2 / KOH

letzte Änderung / updated Datum / Date
2015-12-21 2015-03-05

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 40041833.
This supplement is only valid in conjunction with page 1 of the Certificate No. 40041833.

Dieser Zeichengenehmigungs-Ausweis bildet eine Grundlage für die EG-Konformitätserklärung und CE-Kennzeichnung durch den Hersteller oder dessen Bevollmächtigten und bescheinigt die Konformität mit den grundlegenden Schutzanforderungen der **EG-Niederspannungsrichtlinie (2006/95/EG bis 19.04.2016, 2014/35/EU ab 20.04.2016)**.

This Marks Approval is a basis for the EC Declaration of Conformity and the CE Marking by the manufacturer or his agent and proves the conformity with the essential safety requirements of the EC Low-Voltage Directive (2006/95/EC until 2016-04-19, 2014/35/EU from 2016-04-20).

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Fachgebiet CC2
Section CC2

ВЯРНО С
ОРИГИНАЛА



VDE Prüf- und Zertifizierungsinstitut Zeichengenehmigung

Ausweis-Nr. / Beiblatt /
Certificate No. Supplement
40041833

Name und Sitz des Genehmigungs-Inhabers / Name and registered seat of the Certificate holder
Mersen France SB S.A.S., 15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

Aktenzeichen / File ref.
5003214-1150-0012 / 217877 / CC2 / KOH

letzte Änderung / updated Datum / Date
2015-12-21 2015-03-05

Dieses Beiblatt ist Bestandteil des Zeichengenehmigungsausweises Nr. 40041833.
This supplement is part of the Certificate No. 40041833.

Sicherungseinsatz, NH-System


Fuse-link, NH-System
NH3GG40Vxxx
NH3GG40Vxxx-1

Fertigungsstätte(n)
Place(s) of manufacture

Referenz/Reference FUSETECH Kft.
30008637 Guba Sandor ut. 38
H-7400 KAPOSVAR

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Fachgebiet CC2
Section CC2

ВЯРНО С
ОРИГИНАЛА



VDE Prüf- und Zertifizierungsinstitut Zeichengenehmigung

Ausweis-Nr. / Infoblatt /
Certificate No. / Info sheet
40041833

Name und Sitz des Genehmigungs-Inhabers / Name and registered seat of the Certificate holder
Mersen France SB S.A.S., 15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

Aktenzeichen / File ref.
5003214-1150-0012 / 217877 / CC2 / KOH

letzte Änderung / updated
2015-12-21

Datum / Date
2015-03-05

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 40041833.
This supplement is only valid in conjunction with page 1 of the Certificate No. 40041833.

Genehmigung zum Benutzen des auf Seite 1 abgebildeten markenrechtlich geschützten Zeichens des VDE:

Grundlage für die Benutzung sind die Allgemeinen Geschäftsbedingungen (AGB) der VDE Prüf- und Zertifizierungsinstitut GmbH (www.vde.com\AGB-Institut). Das Recht zur Benutzung erstreckt sich nur auf die bezeichnete Firma mit den genannten Fertigungsstätten und die oben aufgeführten Produkte mit den zugeordneten Bezeichnungen. Die Fertigungsstätte muss so eingerichtet sein, dass eine gleichmäßige Herstellung der geprüften und zertifizierten Ausführung gewährleistet ist.

Die Genehmigung ist so lange gültig wie die VDE-Bestimmungen gelten, die der Zertifizierung zugrunde gelegen haben, sofern sie nicht auf Grund anderer Bedingungen aus der VDE Prüf- und Zertifizierungsordnung (PM102) zurückgezogen werden muss.

Der Gültigkeitszeitraum einer VDE-GS-Zeichengenehmigung kann auf Antrag verlängert werden. Bei gesetzlichen und / oder normativen Änderungen kann die VDE-GS-Zeichengenehmigung ihre Gültigkeit zu einem früheren als dem angegebenen Datum verlieren.

Produkte, die das Biozid Dimethylfumarat (DMF) enthalten, dürfen gemäß der Kommissionsentscheidung 2009/251/EG nicht mehr in den Verkehr gebracht oder auf dem Markt bereitgestellt werden.

Der VDE-Zeichengenehmigungsausweis wird ausschließlich auf der ersten Seite unterzeichnet.

Approval to use the legally protected Mark of the VDE as shown on the first page:

Basis for the use are the general terms and conditions of the VDE Testing and Certification Institute (www.vde.com\terms-institute). The right to use the mark is granted only to the mentioned company with the named places of manufacture and the listed products with the related type references. The place of manufacture shall be equipped in a way that a constant manufacturing of the certified construction is assured.


The approval is valid as long as the VDE specifications are in force, on which the certification is based on, unless it is withdrawn according to the VDE Testing and Certification Procedure (PM102E).

The validity period of a VDE-GS-Mark Approval may be prolonged on request. In case of changes in legal and / or normative requirements, the validity period of a VDE-GS-Mark Approval may be shortened.

Products containing the biocide dimethylfumarate (DMF) may not be marketed or made available on the EC market according to the Commission Decision 2009/251/EC.

The approval is solely signed on the first page.

ВАРНО С
ОРИГИНАЛА



VDE Prüf- und Zertifizierungsinstitut

ZEICHENGENEHMIGUNG MARKS APPROVAL

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson
69720 SAINT BONNET DE MURE
FRANCE

ist berechtigt, für ihr Produkt /
is authorized to use for their product
Sicherungseinsatz, NH-System

Fuse-link, NH-System
NH3GG40Vxxx
NH3GG40Vxxx-1

die hier abgebildeten markenrechtlich geschützten Zeichen
für die ab Blatt 2 aufgeführten Typen zu benutzen /
the legally protected Marks as shown below for the types referred to on page 2 ff.



Geprüft und zertifiziert nach /
Tested and certified according to

DIN EN 60269-1 (VDE 0636-1):2015-05; EN 60269-1:2007 + A1:2009 + A2:2014
DIN VDE 0636-2 (VDE 0636-2):2014-09 HD 60269-2:2013




ВЯРНО С
ОРИГИНАЛА

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification

на основание чл. 2 от ЗЗЛД

Aktenzeichen: 5003214-1150-0012 / 21788
File ref.:
Ausweis-Nr.: 40041833
Certificate No.
Weitere Bedingungen siehe Rückseite und Folgeblätter /
further conditions see overleaf and following pages
Offenbach, 2015-03-05
(letzte Änderung / updated 2015-12-21)



Verantwortung unter:
signed on:

<http://www.vde.com/zertifikat>
<http://www.vde.com/certificate>

VDE



VDE Prüf- und Zertifizierungsinstitut Zeichengenehmigung

Ausweis-Nr. / Blatt /
Certificate No. / Page
40041833 2

Name und Sitz des Genehmigungs-Inhabers / Name and registered seat of the Certificate holder
Mersen France SB S.A.S., 15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

Aktenzeichen / File ref.
5003214-1150-0012 / 217877 / CC2 / KOH

letzte Änderung / updated
2015-12-21

Datum / Date
2015-03-05

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 40041833.
This supplement is only valid in conjunction with page 1 of the Certificate No. 40041833.

Sicherungseinsatz, NH-System

Fuse-link, NH-System

NH3GG40Vxxx
NH3GG40Vxxx-1


Typ(en) / Type(s)

NH3GG40Vxxx
NH3GG40Vxxx-1

Bemessungsspannung Rated voltage	400 V a.c.
Bemessungsstrom Rated current	250 A; 315 A; 400 A; 500 A; 630 A
Bemessungsfrequenz Rated frequency	45 bis/to 62 Hz
Bemessungsausschaltvermögen Rated breaking capacity	100 kA
Baugröße Size	3
Abmessung	Typen mit Maßen der kleineren Baugröße: NH3GG40V250(-1); NH3GG40V315(-1); NH3GG40V400(-1)
Dimension	Typen mit Standardmaßen: NH3GG40V500(-1); NH3GG40V630(-1) Types with dimensions of smaller size: NH3GG40V250(-1); NH3GG40V315(-1); NH3GG40V400(-1) Types with standard dimensions: NH3GG40V500(-1); NH3GG40V630(-1)
Betriebsklasse Utilization category	gG
Griff flasche Gripping lug	spannungsführend (NH3GG40Vxxx) spannungsfrei (NH3GG40Vxxx-1) energized (NH3GG40Vxxx) de-energized (NH3GG40Vxxx-1)
Anzeigevorrichtung Indicating device	Anzeiger vorne und oben Indicator in front and at the top

Fortsetzung siehe Blatt 3 /
continued on page 3

VDE Prüf- und Zertifizierungsinstitut GmbH * Testing and Certification Institute



VDE Prüf- und Zertifizierungsinstitut Zeichengenehmigung

Ausweis-Nr. / Blatt /
Certificate No. / Page
40041833 3

Name und Sitz des Genehmigungs-Inhabers / Name and registered seat of the Certificate holder
Mersen France SB S.A.S., 15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

Aktenzeichen / File ref.
5003214-1150-0012 / 217877 / CC2 / KOH

letzte Änderung / updated Datum / Date
2015-12-21 2015-03-05

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 40041833.
This supplement is only valid in conjunction with page 1 of the Certificate No. 40041833.

Dieser Zeichengenehmigungs-Ausweis bildet eine Grundlage für die EG-Konformitätserklärung und CE-Kennzeichnung durch den Hersteller oder dessen Bevollmächtigten und bescheinigt die Konformität mit den grundlegenden Schutzanforderungen der **EG-Niederspannungsrichtlinie (2006/95/EG bis 19.04.2016, 2014/35/EU ab 20.04.2016)**.

*This Marks Approval is a basis for the EC Declaration of Conformity and the CE Marking by the manufacturer or his agent and proves the conformity with the essential safety requirements of the **EC Low-Voltage Directive (2006/95/EC until 2016-04-19, 2014/35/EU from 2016-04-20)**.*

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Fachgebiet CC2
Section CC2

ВЯРНО С
ОРИГИНАЛА



VDE Prüf- und Zertifizierungsinstitut Zeichengenehmigung

Ausweis-Nr. /
Certificate No.
40041833

Beiblatt /
Supplement

Name und Sitz des Genehmigungs-Inhabers / *Name and registered seat of the Certificate holder*
Mersen France SB S.A.S., 15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

Aktenzeichen / *File ref.*
5003214-1150-0012 / 217877 / CC2 / KOH

letzte Änderung / *updated* Datum / *Date*
2015-12-21 2015-03-05

Dieses Beiblatt ist Bestandteil des Zeichengenehmigungsausweises Nr. 40041833.
This supplement is part of the Certificate No. 40041833.


Sicherungseinsatz, NH-System

Fuse-link, NH-System
NH3GG40Vxxx
NH3GG40Vxxx-1

Fertigungsstätte(n)
Place(s) of manufacture

Referenz/*Reference* FUSETECH Kft.
30008637 Guba Sandor ut. 38
H-7400 KAPOSVAR

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Fachgebiet CC2
Section CC2



VDE Prüf- und Zertifizierungsinstitut Zeichengenehmigung

Ausweis-Nr. / Infoblatt /
Certificate No. / Info sheet
40041833

Name und Sitz des Genehmigungs-Inhabers / Name and registered seat of the Certificate holder

Mersen France SB S.A.S., 15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE, FRANCE

Aktenzeichen / File ref.

5003214-1150-0012 / 217877 / CC2 / KOH

letzte Änderung / updated

2015-12-21

Datum / Date

2015-03-05

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 40041833.

This supplement is only valid in conjunction with page 1 of the Certificate No. 40041833.

Genehmigung zum Benutzen des auf Seite 1 abgebildeten markenrechtlich geschützten Zeichens des VDE:

Grundlage für die Benutzung sind die Allgemeinen Geschäftsbedingungen (AGB) der VDE Prüf- und Zertifizierungsinstitut GmbH (www.vde.com\AGB-Institut). Das Recht zur Benutzung erstreckt sich nur auf die bezeichnete Firma mit den genannten Fertigungsstätten und die oben aufgeführten Produkte mit den zugeordneten Bezeichnungen. Die Fertigungsstätte muss so eingerichtet sein, dass eine gleichmäßige Herstellung der geprüften und zertifizierten Ausführung gewährleistet ist.

Die Genehmigung ist so lange gültig wie die VDE-Bestimmungen gelten, die der Zertifizierung zugrunde gelegen haben, sofern sie nicht auf Grund anderer Bedingungen aus der VDE Prüf- und Zertifizierungsordnung (PM102) zurückgezogen werden muss.

Der Gültigkeitszeitraum einer VDE-GS-Zeichengenehmigung kann auf Antrag verlängert werden. Bei gesetzlichen und / oder normativen Änderungen kann die VDE-GS-Zeichengenehmigung ihre Gültigkeit zu einem früheren als dem angegebenen Datum verlieren.

Produkte, die das Biozid Dimethylfumarat (DMF) enthalten, dürfen gemäß der Kommissionsentscheidung 2009/251/EG nicht mehr in den Verkehr gebracht oder auf dem Markt bereitgestellt werden.


Der VDE-Zeichengenehmigungsausweis wird ausschließlich auf der ersten Seite unterzeichnet.

Approval to use the legally protected Mark of the VDE as shown on the first page:

Basis for the use are the general terms and conditions of the VDE Testing and Certification Institute (www.vde.com\terms-institute). The right to use the mark is granted only to the mentioned company with the named places of manufacture and the listed products with the related type reference. The place of manufacture shall be equipped in a way that a constant manufacturing of the certified construction is assured. The approval is valid as long as the VDE specifications are in force, on which the certification is based on, unless it is withdrawn according to the VDE Testing and Certification Procedure (PM102E).

The validity period of a VDE-GS-Mark Approval may be prolonged on request. In case of changes in legal and / or normative requirements, the validity period of a VDE-GS-Mark Approval may be shortened. Products containing the biocide dimethylfumarate (DMF) may not be marketed or made available on the EC market according to the Commission Decision 2009/251/EC.

The approval is solely signed on the first page.



„ПС електрик“ ООД

Рутинни изпитания


Предпазители със стопяема вложка ниско напрежение NH2 и NH 3

1. Измерване на съпротивлението, проверка за функция на непрекъснатост на стопяемата нишка.
2. Визуална проверка за наранявания, пукнатини и счупвания по тялото.

Дата: 14.03.2018 г

Съставил: Н. Николов

на основание чл. 2 от ЗЗЛД



A large, stylized handwritten signature.

A large, stylized handwritten signature.

7

MULTIVERT® 400A


Size 2, 690VAC

DIMENSIONS

MULTIVERT® 250A, 400A, 630A NH-vertical fuse switch disconnecter, 3 x single pole switching.

direct installation with screws on to 185mm bus bar system

(M01152b)



1) dimension from upper edge of bus bar

- * 158 mm handle in closed position (folded) = total installation depth of MULTIVERT
- ** 190 mm handle in open position (fixed) = switching position


Dimensions in mm

ВЯРНО С
ОРИГИНАЛА

MULTIVERT® 250A, 400A, 630A NH-vertical fuse switch disconnecter, 1 x triple pole switching

direct installation with screws on to 185mm bus bar system

(M01153b)



IEC Fuse Switch Disconnectors / 98-146-11-11-03-0317-EN

EP.MERSEN.COM

MERSEN
Expertise, our source of energy

MERSEN reserves the right to change, without notice, any information contained in this datasheet.


MULTIVERT® 400A

Size 2, 690VAC

DIMENSIONS

MULTIVERT® 250A, 400A, 630A NH-vertical fuse switch disconnecter, 3 x single pole switching
 direct installation without drilling with hooked clamps on to 185mm bus bar system

(M01154b)



ВЯРНО С
ОРИГИНАЛА



MERSEN reserves the right to change without notice, any information contained in this datasheet.


MULTIVERT® 400A

Size 2, 690VAC

DIMENSIONS

MULTIVERT® 250A, 400A, 630A bus bar coppler switch with lateral terminals
3 x single pole switching

(M01159a)




1) dimensions form upper edge of bus bar

- * 158 mm handle in closed position (folded) = total installation depth of MULTIVERT
- ** 190 mm handle in open position (fixed) - switching position

Dimensions in mm

ВЯРНО С
ОРИГИНАЛА



MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.


MULTIVERT® 630A

Size 3, 690VAC

DIMENSIONS

MULTIVERT® 250A, 400A, 630A NH-vertical fuse switch disconnecter, 3 x single pole switching
direct installation with screws on to 185mm bus bar system

(M01152b)



1) dimension from upper edge of bus bar

* 158 mm handle in closed position (folded) = total installation depth of MULTIVERT


** 190 mm handle in open position (fixed) = switching position

Dimensions in mm

ВЯРНО С
ОРИГИНАЛА

MULTIVERT® 250A, 400A, 630A NH-vertical fuse switch disconnecter, 1 x triple pole switching
direct installation with screws on to 185mm bus bar system

(M01153b)



EP.MERSEN.COM

central cover
MERSEN
Expertise, our source of energy

MERSEN reserves the right to change, update or correct, without notice, any information contained in this datasheet.


MULTIVERT® 630A

Size 3, 690VAC

DIMENSIONS

MULTIVERT® 250A, 400A, 630A NH-vertical fuse switch disconnecter, 3 x single pole switching direct installation without drilling with hooked clamps on to 185mm bus bar system

(M01154b)




1) dimensions form upper edge of bus bar

- * 158 mm handle in closed position (folded) = total installation depth of MULTIVERT
- ** 190 mm handle in open position (fixed) - switching position

Dimensions in mm

ВЯРНО С
ОРИГИНАЛА



MERSEN reserves the right to change, update or correct without notice, any data contained in this datasheet.


MULTIVERT® 630A

Size 3, 690VAC

DIMENSIONS

MULTIVERT® 250A, 400A, 630A bus bar coppler switch with lateral terminals
3 x single pole switching

(M01159a)




1) dimensions form upper edge of bus bar

* 158 mm handle in closed position (folded) = total installation depth of MULTIVERT
** 190 mm handle in open position (fixed) - switching position

Dimensions in mm

ВЯРНО С
ОРИГИНАЛА



ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният, “ПС ЕЛЕКТРИК” ООД,

(име на производителя или неговия упълномощен представител, наименование на дружеството /фирмата производител или негов представител)

9700 гр. Шумен, бул. “Мадара” № 12,
(адрес)

декларирам на собствена отговорност, че продуктът

Предпазители със стояема вложка ниско напрежение размер NH-2 250A , NH-2 400A , NH3-630A,
характеристика gG

(наименование и търговска марка, тип или модел, предназначение)

произведен от

Mersen France SB

(място на производство на разглеждания продукт)

за който се отнася тази декларация, е произведен в условията на въведена и поддържана от производителя система за производствен контрол и е в съответствие със следния(те) стандарт(и), Българско техническо одобрение (БТО) или друг(и) нормативен(ни) акт(актове):

- БДС EN 60269-1:2007 – „Стояеми предпазители за ниско напрежение. Част 1: Общи изисквания (IEC 60269-1:2006)

- БДС EN 60269-2:2013 – „Стояеми предпазители за ниско напрежение. Част 2: Допълнителни изисквания за стояеми предпазители, предназначени за използване от квалифицирани лица (стояеми предпазители предимно за промишлено приложение). (наименование и/или номер и дата на издаване на стандарта(тите), БТО или друг(и) нормативен(ни) акт (актове)

и е оценен положително по реда и условията на Наредбата за съществените изисквания и оценяване на съответствието на електрически съоръжения, предназначени за използване в определени граници на напрежението, приета с ПСМН№182 от 06.07.2001г., обн. ДВ, бр.62 от 13.07.2001г.

Продуктът отговаря на Техническата спецификация на стандарта за материал, вкл. на „Характеристика на материала“ и „Съответствие на предложеното изпълнение с нормативно-техническите документи.


Декларирам, че ми е известна отговорността, която нося съгласно чл. 313 от НК.

13.03.2018 год.

гр. Шумен

(място и дата на издаване)

Божидар Маринов
Управител(фамилия и име на производителя)
на основание чл. 2 от ЗЗЛД
зводителя



ПАПКА 10

ПРИЛОЖЕНИЕ 10 Други документи за
Позиция 1 и Позиция 2

ПРИЛОЖЕНИЕ 10.5 Други


Приложение 1

Приложение 2

Приложение 3

Приложение 4

Приложение 5




МИНИСТЕРСТВО НА ВЪТРЕШНИТЕ РАБОТИ
ГЛАВНА ДИРЕКЦИЯ „ПОЖАРНА БЕЗОПАСНОСТ И ЗАЩИТА НА НАСЕЛЕНИЕТО“

„ОТДЕЛ „ЦЕНТЪР ЗА ИЗСЛЕДВАНИЯ И ЕКСПЕРТИЗИ“

1619 -София, ул. „Огнеборец“ №1, тел.: 857 03 26, 857 46 89, факс: 857 02 14

Рег. № 110-5214 Екз. №
..... 14.06. 2012 г.



КЛАСИФИКАЦИОНЕН ПРОТОКОЛ

№ 3/11.06.2012 г.


Класификация за реакция на огън

Заявител: „ПАВЕЛ И СИНОВЕ ЕЛЕКТРИК“ ООД, гр. Шумен 9700, област Шумен,
община Шумен, бул. „Мадара“, № 12
Писмо вх. № 12569/08.06.2012 г.

Подготвен от: ОТДЕЛ „ЦЕНТЪР ЗА ИЗСЛЕДВАНИЯ И ЕКСПЕРТИЗИ“
ГДПБЗН-МВР, 1619 София, ул. „Огнеборец“ № 1.




Име на продукта: Полиестер Menzolit SMC 0200, марка Incobex,
електрически табла ST, SST, STN, SSTN, KK и KKD.



Издание номер: 1

Този класификационен протокол съдържа 3 (три) страници и може да бъде използван
или издаден отново само в пълния си вид.

Класификационен протокол № 3/11.06.2012 г Екземпляр № 2	Лист 1 от 3	НАЧАЛНИК НА ОЦИЕ: КОМИСАР / Хрисимир Губчев
---	-------------	---



2. Детайли на класифицирания продукт

Полиестер Menzolit SMC 0200, марка Incobex тип за електрически табла ST, SST, STN, SSTN, KK и KKD. Състав: стъклонапълнен полиестер със съдържание на стъклени влакна 23%, производство на Incobex Sp.zoo, ul Grazynskiego 71, 43-300 Bielsko-Biala, Poland.

3. Протоколи от изпитванията и резултати от изпитванията в съответствие с класификацията.


3.1 Протоколи от изпитванията

Име на лабораторията	Име на заявителя	Изпитване и дата	Метод на изпитване
Изпитвателен център по "Пожарна и аварийна безопасност"	„ПАВЕЛ И СИНОВЕ ЕЛЕКТРИК” ООД, гр. Шумен	Протокол № ИЦ-62-122 23.12.2010 г.	БДС EN 60695-11-10

3.2 Резултати от изпитванията

Метод и номер на изпитването	Параметър	Протокол №	Резултати	
			Постоянен параметър – означение	Съответствие с параметрите
БДС EN 60695-11-10	t_1 и t_2 по-малко от 10 s;	№ ИЦ-62-122/ 23.12.2010 г.	t_1 и $t_2 = 0$ s	Съответства
	t_f по-малко от 50 s;		$t_f = 0$ s	Съответства
	$(t_2 + t_3)$ по-малко от 30 s;		$(t_2 + t_3) = 0$ s	Съответства
	достигане до мястото на закрепване;		не	Съответства
	запалване на памучния тампон.		не	Съответства

Класификационен протокол № 3/11.06.2012 г Екземпляр № 2	Лист 2 от 3	НАЧАЛНИК НА ОЦИ КОМИСАР	на основание чл. 2 от ЗЗЛД
--	-------------	----------------------------	----------------------------



4 Класификация и област на приложение

4.1 Съответствие на класификацията:

Полиестер Menzolit SMC 0200, марка Incobex тип за електрически табла ST, SST, STN, SSTN, KK и KKD със състав: стъклонапълнен полиестер със съдържание на стъклени влакна 23%, производство на Incobex Sp.zoo, ul Grazynskiego 71, 43-300 Bielsko-Biala, Poland се класифицира в категория V-0, съгласно БДС EN 60695-11-10.

4.2 Класификация

Класификация за реакция на огън КАТЕГОРИЯ V-0


4.3 Област на приложение

Тази класификация е валидна за полиестер Menzolit SMC 0200, марка Incobex тип за електрически табла ST, SST, STN, SSTN, KK и KKD със състав: стъклонапълнен полиестер със съдържание на стъклени влакна 23%, производство на Incobex Sp.zoo, ul Grazynskiego 71, 43-300 Bielsko-Biala, Poland

5. Ограничения

Този класификационен документ не представлява вид одобрение или сертификация на продукта.

Изпитвателната лаборатория обаче не взема участие при вземането на проби от изпитвания продукт, въпреки че притежава съответните препоръки, предоставени от производителя за осигуряване на проследимост на изпитваните проби.



ИЗВЪРШИЛ
КЛАСИФИКАЦИЯТА:

/ инж. Е. Хлебарова/

на основание чл. 2 от ЗЗЛД


НАЧАЛНИК НА ОЦЕНКАТА
И САР

на основание чл. 2 от ЗЗЛД

на основание чл. 2 от ЗЗЛД

на основание чл. 2 от ЗЗЛД

Класификационен протокол № 3/11.06.2012 г Екземпляр № 2	Лист 3 от 3	НАЧАЛНИК НА ОЦЕНКАТА КОМИСАР
--	-------------	---------------------------------



2

МИНИСТЕРСТВО НА ВЪТРЕШНИТЕ РАБОТИ
ГЛАВНА ДИРЕКЦИЯ "ПОЖАРНА БЕЗОПАСНОСТ И СПАСЯВАНЕ"
ИЗПИТВАТЕЛЕН ЦЕНТЪР ПО ПОЖАРНА И АВАРИЙНА БЕЗОПАСНОСТ
1619 -София, ул."Огнеборец" №1, тел.: 857 03 26, 857 46 89, факс: 857 02 14

Лист 1
Вс.листа 3

ПРОТОКОЛ
ОТ ИЗПИТВАНЕ

№ ИЦ-62-122/23.12.2010 г.



валиден до 28.02.2014 г.

1. МАТЕРИАЛИ КОНСТРУКТИВНИ И ЗА ВЪТРЕШНО ОБЗАВЕЖДАНЕ
/ПЛАСТМАСИ И ДРУГИ НЕМЕТАЛНИ МАТЕРИАЛИ/

Полестер Menzolit SMC 0200, марка Incobex тип за електрически табла ST, SST, STN, SSTN, KK и KKD, с дебелина 8,5 mm. Състав: стъкловлакна полестер със съдържание на стъквени влакна 23%. Производител на продукта е Incobex Sp.zoo. ul. Grazynskiego 71, 43-300 Bielsko-Biala, Poland.

2. ЗАЯВИТЕЛ НА ИЗПИТВАНЕТО: фирма „ПАВЕЛ И СИНОВЕ ЕЛЕКТРИК“ ООД, гр. Шумен. Писмо вх. № ИЦ-62/09.11.2010 г.

ВЯРНО С
ОРИГИНАЛА

3. МЕТОД ЗА ИЗПИТВАНЕ И СПЕЦИФИЧНИ УСЛОВИЯ:

БДС EN 60695-11-10 "Изпитване на опасност от пожар. Част 11-10. Изпитвателни пламъци. Хоризонтален и вертикален метод за изпитване с пламък с мощност 50W".
Образците за изпитване са кондиционирани при Rh=(50±5)% и температура (23±2)°C за 48h.

4. ДАТА НА ПОЛУЧАВАНЕ НА ОБРАЗЦИТЕ ЗА ИЗПИТВАНЕ: 20.12.2010 г.

5. КОЛИЧЕСТВО НА ИЗПИТВАНИТЕ ОБРАЗЦИ: 5 бр. от проба № ИЦ-62/2010 г. № 62-1 до № 62-5.

6. ДАТА НА ИЗВЪРШВАНЕ НА ИЗПИТВАНЕТО: 22.12.2010 г.

на основание чл. 2 от ЗЗЛД

РЪКОВОДИТЕЛ НА ИЦ ПО ПАБ:



Инж. Б. Розанов

Лист 2
Вс. листове 3

7. РЕЗУЛТАТИ ОТ ИЗПИТВАНЕТО:

№ по ред	Наименование на показателя	Единица на величината	Стандарти/валидирани методи	№ на образеца по вх.-изх.дневник	Резултати от изпитването (стойност, неопределена)	Стойност и допуск на показателя	Условия на изпитването	
1	2	3	4	5	6	7	8	
1.	Категория на горимост					Категория V-0 съгласно БДС EN 60695-11-10 БДС EN 60695-11-10 т.9.4 $t_1 \leq 10$	Категория V-2 съгласно БДС EN 60695-11-10 БДС EN 60695-11-10 т.9.4 $t_1 \leq 30$	$t^{\circ} = 25^{\circ}C \pm 0,4^{\circ}C$ $RH = 60,0\% \pm 1,5\%$
	- Продължителност на пламъка;			ИЦ-62-1 ИЦ-62-2 ИЦ-62-3 ИЦ-62-4 ИЦ-62-5	0 0 0 0 0	Категория V-1 съгласно БДС EN 60695-11-10 т.9.4 $t_1 \leq 30$		
	- t_1 ;			ИЦ-62-1 ИЦ-62-2 ИЦ-62-3 ИЦ-62-4 ИЦ-62-5	0 0 0 0 0	$t_1 \leq 30$		
	- t_2 ;	s	БДС EN 60695-11-10	ИЦ-62-1 ИЦ-62-2 ИЦ-62-3 ИЦ-62-4 ИЦ-62-5	0 0 0 0 0	$t_1 \leq 30$		
	- t_1 ;			ИЦ-62-1 ИЦ-62-2 ИЦ-62-3 ИЦ-62-4 ИЦ-62-5	0 0 0 0 0	$t_1 \leq 50$		
	- $t_2 + t_3$;			ИЦ-62-1 ИЦ-62-2 ИЦ-62-3 ИЦ-62-4 ИЦ-62-5	0 0 0 0 0	$(t_2 + t_3) \leq 60$	$(t_2 + t_3) \leq 60$	

БЯРНО С
ОРИГИНАЛ



ФК 510-1

Лист 3
Вс.листа 3

1	2	3	4	5	6	7	8	
- Достигане до мястото на закрепване; - Запалване на памучния тампон.			БДС EN 60695-11-10	ИЦ-62-1 ИЦ-62-2 ИЦ-62-3 ИЦ-62-4 ИЦ-62-5 ИЦ-62-1 ИЦ-62-2 ИЦ-62-3 ИЦ-62-4 ИЦ-62-5	не не не не не не не не не не	БДС EN 60695-11-10 т.9.4 БДС EN 60695-11-10 т.9.4 БДС EN 60695-11-10 т.9.4	БДС EN 60695-11-10 т.9.4 БДС EN 60695-11-10 т.9.4 БДС EN 60695-11-10 т.9.4	не не не да
							t°=25°C±0,1 4 °C RH=60,0%±1, 3%	



ЗАБЕЛЕЖКА I: Ако е необходимо, протоколът от изпитване може да включва мнения и интерпретации за определени изпитвания (заключения не се допускат) само в съответствие с изискванията на т. 5.10.5 от БДС EN ISO/IEC 17025:2006

ЗАБЕЛЕЖКА II: Резултатите от изпитванията се отнасят само за изпитваните образци. Извлечения от изпитвателни писмено съгласие на ИЦ по ПАБ.

ПРОВЕЛИ ИЗПИТВАНЕТО: 1.

2.
3.
4.

РЪКОВОДИТЕЛ НА ИЦ ПО ПАБ:



на основание чл. 2 от ЗЗЛД

на основание чл. 2 от ЗЗЛД

не могат да се размножават без



STOWARZYSZENIE ELEKTRYKÓW POLSKICH BIURO BADAWCZE DS. JAKOŚCI

04-703 Warszawa, ul. Mieczysława Pożaryskiego 28
tel.: +48 22 812 69 38; fax: +48 22 815 65 80; e-mail: bbj@bbj.pl

CERTYFIKAT ZGODNOŚCI CE CE CERTIFICATE OF CONFORMITY

nr CE/040/12
No. CE/040/12

Dostawca: INCOBEX Sp. z o.o.
(Nazwa i adres) ul. Grażyńskiego 71
Supplier: 43-300 Bielsko-Biała, Poland
(Name and address)

Producent: INCOBEX Sp. z o.o.
(Nazwa i adres) ul. Grażyńskiego 71
Manufacturer: 43-300 Bielsko-Biała, Poland
(Name and address)

Nazwa wyrobu: Obudowy do rozdzielnic niskiego napięcia z materiału
(Name of the product) izolacyjnego termoutwardzalnego.
Empty enclosures for low-voltage switchgear and controlgear
assemblies made of insulating thermohardening material.

Typ (model): STN., SSTN.,
(wykaz odmian na odwrocie)
(Type (model)) (list of variations on the back page)

Dane techniczne: Stopień ochrony: IP44; IK10
(Technical data) Degree of protection: IP44; IK10

Wymieniony powyżej wyrób spełnia wymagania norm(-y) zharmonizowanych(-ej):
Aforesaid product complies with the requirements of the harmonized standard(s):

Norma(-y) Standard(s)	Raport(-y) z badań nr Test report(s) No.	Wydany(-e) przez Issued by
EN-EN 62208:2006 (EN 62208:2003)	LA-07.193/1, LA-07.193/2, LA-11.040/1, LA-11.040/2	BBJ

Spełnienie wymagań powyższych(-ej) norm(-y) daje domniemanie zgodności z zasadniczymi wymaganiami określonymi w:

- Compliance with the requirements of the aforesaid standard(s) gives presumption of conformity with the essential requirements specified in:
- Dyrektywę LVD 2006/95/WE (wdrożonej do prawa polskiego rozporządzeniem Ministra Gospodarki z 2007-08-21, Dz. U. nr 155, poz. 1089);
- LVD Directive 2006/95/EC (implemented into Polish law by MG decree of 2007-08-21, OJ No. 155, item 1089);

stanowiąc niezbędny warunek dla oznakowania CE,
accomplishing mandatory terms of CE marking.

Niniejszy certyfikat dotyczy wyłącznie wyrobów mających identyczne właściwości (parametry) jak przedstawiony do badań wzór i spełniających wymagania ww. norm(-y).

This certificate covers only the products with characteristics same as of the tested sample and those complying with the requirements of the aforesaid standard(s).


Ponadto, znakowanie CE powinno być umieszczone na wyrobach po sporządzeniu niezbędnej dokumentacji technicznej oraz wystawieniu deklaracji zgodności WE, zgodnie z postanowieniami ww. dyrektyw(-y) (rozporządzenia/ustawy).

Moreover, CE marking shall be affixed on the products after technical documentation was prepared and EU declaration of conformity was issued, according to the aforesaid directive(s) (decree) regulations.


Niniejszy certyfikat traci ważność z datą ustania domniemanie zgodności ww. norm(-y) zharmonizowanych(-ej) z zasadniczymi wymaganiami ww. dyrektyw(-y) (rozporządzenia/ustawy).

This certificate is valid until the date of cessation of presumption of conformity of the aforesaid harmonized standard(s) under the aforesaid directive(s) (decree/act).

ВЯРНО С
ОЗНАЧЕНИЕ



Kierownik
на основание чл. 2 от ЗЗЛД
Teodor Pysznik



Warszawa, 2012-10-01

Firma nagrodzona Złotą Odznaką Honorową SEP
Company granted with SEP Gold Honour Award

BBJ

Informacje dodatkowe:
 Additional information:

Wykaz odmian:
 List of variations:

Obudowy: <i>cabinets:</i>					
STN 26x42	SSTN 26x42	STN 26x58	SSTN 26x58	STN 26x84	SSTN 26x84
STN 40x42	SSTN 40x42	STN 40x58	SSTN 40x58	STN 40x84	SSTN 40x84
STN 53x42	SSTN 53x42	STN 53x58	SSTN 53x58	STN 53x84	SSTN 53x84
STN 53x42/2	SSTN 53x42/2	STN 53x58/2	SSTN 53x58/2	STN 53x84/2	SSTN 53x84/2
STN 66x42	SSTN 66x42	STN 66x58	SSTN 66x58	STN 66x84	SSTN 66x84
STN 66x42/2L	SSTN 66x42/2L	STN 66x58/2L	SSTN 66x58/2L	STN 66x84/2L	SSTN 66x84/2L
STN 66x42/2P	SSTN 66x42/2P	STN 66x58/2P	SSTN 66x58/2P	STN 66x84/2P	SSTN 66x84/2P
STN 80x42	SSTN 80x42	STN 80x58	SSTN 80x58	STN 80x84	SSTN 80x84
STN 80x42/2	SSTN 80x42/2	STN 80x58/2	SSTN 80x58/2	STN 80x84/2	SSTN 80x84/2
STN 80x42/2L	SSTN 80x42/2L	STN 80x58/2L	SSTN 80x58/2L	STN 80x84/2L	SSTN 80x84/2L
STN 80x42/2P	SSTN 80x42/2P	STN 80x58/2P	SSTN 80x58/2P	STN 80x84/2P	SSTN 80x84/2P
STN 80x42/3	SSTN 80x42/3	STN 80x58/3	SSTN 80x58/3	STN 80x84/3	SSTN 80x84/3
STN 106x58	SSTN 106x58	STN 106x84	SSTN 106x84	STN 106x58/2	SSTN 106x58/2
STN 106x84/2	SSTN 106x84/2	STN 106x58/3L	SSTN 106x58/3L	STN 106x58/3P	SSTN 106x58/3P
STN 106x84/3L	SSTN 106x84/3L	STN 106x84/3P	SSTN 106x84/3P	STN 106x58/4	SSTN 106x58/4
STN 106x84/4	SSTN 106x84/4	STN 40x84/2	SSTN 40x84/2		
Fundamenty: <i>pedestals:</i>					
FTN 26	FTN 40	FTN 53	FTN 66	FTN 80	FTN 106
Kieszonki kablowe: <i>cable bases:</i>					
KKN 26	KKN 40	KKN 53	KKN 66	KKN 80	KKN 106
KKDN 26	KKDN 40	KKDN 53	KKDN 66	KKDN 80	KKDN 106

ВЯРНО С
 ОПРИГИНАЛА



CW-TA 12.318
 Nr rej. S-A-12-037
 Reg. No. S-A-12-037

Rozdzielnik:
 Copy to:

- INCOBEX Sp. z o.o.,
 ul. Grażyńskiego 71
 43-300 Bielsko-Biała, Poland
- CW



Since 1933 r.

ASSOCIATION OF POLISH ELECTRICIANS
QUALITY TESTING OFFICE
ul. M. Pożaryskiego 28, 04-703 Warszawa, Poland

tel./fax: +48 22 815 65 80

TESTING LABORATORY



AB 044



TEST REPORT
EN 60695-11-10

Title of the Standard: Fire hazard testing
Part 11-10: Test flames - 50 W horizontal and vertical flame test methods

Report reference No.....: LA-12.088/1/E

Date of issue: 2012-09-28

Total number of page: 9 pages

Tested by (name + function + signature): Zbigniew Ostrowski
Senior Specialist

на основании чл. 2 от 33ЛД

Authorizing by (name + function + signature): Dariusz Szczepanowski
Manager of LA Laboratory

Testing application number: N-A-12-8163

Test items reference: N-A-12-8163

Scope of test: - type test - partial test

Test specification:

Standard/procedure: EN 60695-11-10:1999+A1:2003,
 IEC 60695-11-10: 1999+A1:2003 Ed. 1


Non-standard test methods: N/A

Non-accredited test method: N/A

ВЯРНО С
ОРИГИНАЛА

Applicant's name: INCOBEX sp. z o.o.

Address: 43-300 Bielsko-Biała,
ul. Grażyńskiego 71.



Test item description: The sample of isolating material

Trade Mark: **INCOBEX**


Manufacturer: INCOBEX sp. z o.o.
43-300 Bielsko-Biała,
ul. Grażyńskiego 71.

Model/Typ reference: Thermosetting material, glass-fiber reinforced polyester (SMC 190).



Ratings: V-0 category of flammability or determination of other	
List of Attachments:	
Attachment	Name of Attachments
No. 1	Summary of testing
No. 2	List of test equipment used
No. 3	The photos
Summary of testing:	
Testing performed (in the case of partial tests): ---	Testing location/address (if different from page 1) Zakład Aparatów Niskiego Napięcia 20-150 Lublin, ul. M. Rapackiego 13, POLAND
Number of tests with F (Fail) verdict	0
Summary conformity/non-conformity with standardization document (if apply)	N/A
Summary of compliance with National Differences (if apply): ---	N/A
Opinions and interpretation, if needed:	N/A
Other additional information (as requested by the applicant): ---	N/A
Copy of marking plate: ---	
Test item particulars: 20 bar test specimens cut by milling method from one sample No. 1 of material SMC 190 supplied for the test. Selected bar test specimens were marked as samples 1/A1 to 1/A10 and 1/B1 to 1/B10 to carry out the test.	
Date(s) of receipt of test item	2012-09-21
Date(s) of performance of tests	2012-09-28
Possible test case verdicts:	
Test case does not apply to the test object	N/A
Test item does meet the requirement	P(Pass)
Test item does not meet the requirement	F(Fail)
Test report general remarks:	
1. The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the issuing testing laboratory.	
2. "(See Enclosure #)" refers to additional information appended to the report.	
3. "(See appended table)" refers to a table appended to the report.	
4. Throughout this report a comma is used as the decimal separator.	
5. Test Report Form is based on TRF No.: N/A	
Production place(s)	
General product information: The samples of thermosetting isolating material made of glass-fiber reinforced polyester (SMC 190 - samples No.1).	

ОПРИЯТНА





IEC/EN 60695-11-10			
Clause	Requirement + Test	Result - Remark	Verdict
	MARKING		P
7	Specimens		P
7.1	Test specimens shall be cut from a representative sample of the moulded material taken from a product;	Test specimens cut from a representative sample of the moulded material taken from a product	P
	Or the specimens shall be produced using the same fabrication process as would be used to mould a part of a product		N/A
	Or using the appropriate ISO method		N/A
	If above methods are not possible perform the needle flame test in accordance with IEC 60695-2-2		N/A
	After any cutting operation, all dust and any particles shall be taken from surface.		P
	Cut edges shall be fine sanded to a smooth finish		P
7.2	Material testing		P
	Specimens of different colors, thicknesses, densities, molecular masses, anisotropy directions, or different addition, fillers	Homogeneous samples	P
	Testing the specimens of different density, fillers content are representative,		N/A
	When the flame test classification are different estimation is limited to the tested materials		N/A
	Specimens not dyed and specimens with maximum pigment content are to be representative, when test results give the same flame test classification		N/A
	If some pigments influence flame burning characteristic the specimens with this pigments shall be tested		N/A
	There shall be tested specimens:		N/A
	a) Without dyeing means		N/A
	b) With maximum organic pigments		N/A
	c) With maximum inorganic pigments		N/A
	d) With pigments influencing flame burning characteristic		N/A
7.3	Bar-shaped specimen		P
	Bar-shaped specimens shall be:	Bar-shaped specimens	P
	125 mm \pm 5 mm long	125 mm	P
	13 mm \pm 5 mm wide	13 mm	P

I-POB-07/01_Z3w9



IEC/EN 60695-11-10

Clause	Requirement + Test	Result - Remark	Verdict
	Provided with the minimum normally supplied thickness		P
	Edges shall to be smooth, and the radius of the corners shall not exceed 1,3 mm.		P
	Other thickness may be used by agreement between interested parties and noticed in test report		N/A
	Minimum 6 specimens shall be prepared for A method test		N/A
	Minimum 20 specimens for method B	20 specimens	P
8	Method A – horizontal burning test		N/A
	This clause is not involved in the scope of testing		
9	Method B – vertical burning test		P
9.1	Conditioning		P
	Unless otherwise required by relevant specification, following requirements apply		P
9.1.1	Sets of five bar test specimens shall be conditioned for minimum 48 hours at 23 °C ± 2 °C and 50 % ± 5 %	23 °C; 55 % RH; 48 h	P
	Once removed from conditioning chamber specimens shall be tested within no longer than 1 h	No longer than 1 h	P
9.1.2	Sets of five bar test specimens shall be aged in the air-circulated oven for 168 h ± 2 h at 70 °C ± 2 °C and then cooled in the desiccator chamber for at least 4 hour	70 °C; 168 h	P
	Once removed from desiccator chamber specimens shall be tested within no longer than 30 min	No longer than 30 min	P
9.1.3	Alternatively for aged method given in 9.1.2 industrial laminates may be conditioned for 24 h in temperature 125 °C ± 2 °C		N/A
9.1.4	All the test specimens shall tested in a laboratory atmosphere of 15 °C to 35 °C and 45 % to 75 % relative humidity	23 °C; 55 % RH	
9.2	Procedure		
9.2.1	Clamp the bar test specimen using the upper 6 mm of its length with longitudinal axis vertical so that the lower end of the bar test specimen is 300 mm ± 10 mm above a horizontal layer of cotton which is approximately 50 mm x 50 mm x 6 mm uncompressed and has a maximum mass of 0,08 g (see figure 3)		P

I-POB-07/01_Z3w9

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE d/s JAKOŚCI O/Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Rapackiego 13/15

ВЯРНО С
 ОПРИГІНАЛА



IEC/EN 60695-11-10			
Clause	Requirement + Test	Result - Remark	Verdict
9.2.2	With the central axis of the burner tube vertical, burner placed remote from the bar test specimen and set the burner to produce a standardized 50 W nominal test flame, conforming to IEC 60695-11-4, flames A, B or C.		P
	Wait for a minimum of 5 min. to allow the burner conditions to reach equilibrium	5 minutes	P
	In case a dispute flame A shall be used as the reference test flame.	Flame: A has been used	P
9.2.3	Emplacement of bar test specimen and the burner shall be as in figure 6		P
9.2.4	Keeping the central axis of the burner tube vertically, apply the flame of the burner centrally to the lower front of the bar test specimen, so that the end of the burner tube is 10 mm \pm 1 mm below that point.	Distance between the lower front of the bar test specimen and the end of the burner tube: 10 mm	P
	Apply the flame for 5 s \pm 0,5 s. If the bar test specimens shrinks or elongates during the test, adjust the burner position vertically.	The flame applied for 5 s	P
	If, when applying the flame, the bar test specimens drips particles, shrinks or elongates during the test, to avoid dropping into the tube, position the burner tube at angle 45° and carefully remove it, keeping 10 mm \pm 1 mm distance between nozzle center and the specimen.	Elongation and position changes of the specimen was not noticed	N/A
	Immediately after 10 s \pm 0,5 s flame facing the specimen withdraw the burner sufficiently so that there is no effect on bar test specimen and begin the measurement of time t_1	Time of flame facing the specimen: 10 s	P
	Read and record time t_1:	See appended Table 9	P
	NOTE: Withdrawing the burner a distance of 150 mm from the bar test specimen following flame application has been found satisfactory		P
9.2.5	Once the flame on the specimen extinguishes, face the test burner flame to the bar test specimen for 10 s \pm 5 s keeping the central axis of burner tube vertically in a distance of 10 mm \pm 1 mm below lower part of specimen	10 s, 10 mm	P
	If necessary, move burner to avoid from dripping particles into burner tube as in 9.2.3	 	N/A
	Immediately after second facing flame to the specimen for 10 s \pm 5 s extinguish the burner or withdraw the burner from the bar test specimen for satisfactory distance and start:	The burner was withdrawn for distance of 150 mm	P
	- measure afterflame time t_2		P

I-POB-07/01_Z3w9



IEC/EN 60695-11-10			
Clause	Requirement + Test	Result - Remark	Verdict
	- and afterglow time t_3		N/A
	Read and record values: t_2 , t_3 and $t_2 + t_3$	See appended Table 9	P
	Note and record whether any flaming particles or drops fall from bar test specimen		N/A
	And, if so, whether they ignite the cotton		N/A
	NOTE1: Measuring and recording the afterflame time t_2 , and then continuing the measurement of the sum of the afterflame time t_2 and afterglow t_3 time, specifically t_2 plus t_3 (without resetting the time device) has been found satisfactory in the recording of t_3		P
	NOTE 2: Withdrawing the burner a distance of 150 mm from the bar test specimen while measuring t_2 and t_3 has been found satisfactory		P
9.2.6	Repeat the procedure until five bar test specimens conditioned in accordance with 9.1.1 has been tested		P
	And five bar test specimens conditioned in accordance with 9.1.2 has been tested as well		P
9.2.7	If only one test specimen from a set of five specimens for a given conditioning treatment does not conform to all the criteria for a category, another set of five bar test specimens, subjected to the same conditioning, shall be tested	Repeated the procedure until five test specimens conditioned in accordance with 9.1.2 were tested	P
	To measure the total time t_f [s] additional set of five test specimens shall be tested if the total times for category:		
	V-0 are in a range from 51 s to 55 s	See appended Table 9	P
	or for category V-1 and V-2 form 251 s to 255 s		N/A
	All specimens from the second set shall conform to all the criteria for a category		N/A
9.2.8	Some materials, due to its thickness, may during testing get deformed, shrinks or burning up to clamps. These materials may be tested according to ISO 9773, under condition that there is a possibility of shaping the specimen		N/A
9.3	Counting the results		
	For each set of five test bar specimen taken from both ways of conditioning, the total time t_f , in seconds, shall be counted from equation		
	$t_f = \sum_{i=1}^5 (t_{1,i} + t_{2,i})$ where		P
	t_f - total time of flaming of five specimens set		P

I-POB-07/01_Z3w9



IEC/EN 60695-11-10			
Clause	Requirement + Test	Result - Remark	Verdict
	$t_{1,i}$ – first time of flaming, in seconds, of i-numbered specimen		P
	$t_{2,i}$ – second time of flaming, in seconds, of i-numbered specimen		P
9.4	Classification		P
	Material shall be classified as V-0, V-1 or V-2 (V-vertical burning), according to criteria given in table 1, based on specimen behavior		P
9.5	Test report		P
	The test report shall include the following particulars:		P
	a) a reference to this international standard	EN 60695-11-10	P
	b) all details necessary to identify the product tested, including the manufacturer's name, number or code, and color		P
	c) the thickness, to the nearest 0,1 mm, of the test specimen,	See appended Table 9	P
	d) the nominal apparent density (cellular materials only)		N/A
	e) the direction of any anisotropy relative to the dimensions of the test specimen		N/A
	f) the conditioning treatment	Climatic chamber	P
	g) any treatment before testing, other than cutting, trimming and conditioning	The specimens has been cut by milling method. Specimen sanded using P180, P600 and P2000 sandpaper in turns	P
	h) the individual values of afterflame time t_1 , t_2 and afterglow time t_3 , and $t_2 + t_3$	See appended Table 9	P
	i) total flaming time t_f for each set of five specimens from two ways of conditioning (see 9.1.1 and 9.1.2)	See appended Table 9	P
	j) a note as to whether any particles or drops fell from the bar test specimen and whether they ignited the cotton		N/A
	k) a note as to whether any specimen showed burning up to clamp		N/A
	l) the assigned classification acc. 9.4	V-0 after conditioning the specimens acc. cl.9.1.1 and cl.9.1.2	P

I-POB-07/01_Z3w9




IEC/EN 60695-11-10

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Number of specimen	Thickness mm	Measured time in s			Criteria			Category	
		$t_{1,i}$	$t_{2,i}$	$t_f = \sum_{i=1}^n (t_{1,i} + t_{2,i})$	Single specimen afterflame time ($t_{1,i}$ & $t_{2,i}$)	Afterflame time and afterglow time of single specimen after second flame facing the specimen ($t_{1,i}$ + $t_{3,i}$)	Did the burning or glowing broaden up to the clamps?		t_f
		s	s	s	s	s	Yes/No	s	
1/A1	3,47	0,0	2,0	7,5	≤ 10 s	≤ 30 s	No	≤ 50 s	V-0 ¹⁾
1/A2	3,30	0,0	1,5						
1/A3	3,60	0,0	1,2						
1/A4	3,28	0,0	1,1						
1/A5	3,26	0,0	1,7						

Note: 1) cut surfaces of bar test specimen sanded using P180, P600 and P2000 sandpaper in turns



ВЯРНО С
ОРИГИНАЛА



IEC/EN 60695-11-10

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Number of specimens	Thickness mm	Measured time in s			Criteria			Category
		$t_{1,i}$	$t_{2,i}$	$t_{f,i} = \sum_{i=1}^5 (t_{1,i} + t_{2,i})$	Single specimen afterflame time ($t_{1,i}$ & $t_{2,i}$)	Afterflame time and afterglow time of single specimen after second flame facing the specimen ($t_{2,i} + t_{3,i}$)	Did the burning or glowing broaden up to the clamps?	
		s	s	s	s	s	Yes/No	s
1/B1	3,39	1,0	0,0	7,0	≤ 10 s	≤ 30 s	No	P
1/B2	3,49	1,0	1,0					
1/B3	3,46	0,0	2,5					
1/B4	3,23	1,0	0,0					
1/B5	3,51	0,5	0,0					

Note: 1) cut surfaces of bar test specimen sanded using P180, P600 and P2000 sandpaper in turns.

ВЯРНО С
ОРИГИНАЛА

menzolit

Handwritten signature

Firma / company: INCOBEX Sp.z.o.o

Fax / facsimile: 0048 338227063

Datum / date: 28.07.2013

Betr. /Subj.: Menzolit SMC 0200 3311- Color index 735

Confirmation for SMC Menzolit

Menzolit confirmed that SMC contains the following material properties:



- the length of the glass fibers = 25 mm
- the density of the glass fibers = 2,45 - 2,58 g/cm³
- the density of the material SMC = 1,8 g/cm³

Handwritten signature

Person:

Jiri Rysanek
Handelsvertretung Menzolit, s.r.l


на основание чл. 2 от ЗЗЛД



Handwritten signature

ВЯРНО С
ОРИГИНАЛА

Handwritten signature



PS ELECTRIC LTD.
12, Madara Blvd., 9700 Shumen, Bulgaria

Bureau Veritas Certification Holding SAS – UK Branch certify that the Management System of the above organization has been audited and found to be in accordance with the requirements of the management system standards detailed below

ISO 9001:2008

Scope of certification

Design, manufacturing, supply and service of complete transformer substation and switching devices (switching boards).



Certification cycle start date: 01 May 2015

Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: 01 May 2018

Original certification date: 02 May 2006

Certificate No: BG120487Q

Version 1, Revision date: 29 April 2015



на основание чл. 2 от ЗЗЛД

Signed on behalf of BVCH SAS UK Branch

Certification body address: 5th Floor, 66 Prescott Street, London, E1 8HG, United Kingdom
Local Office: 81A, Bulgaria Blvd., 1404 Sofia, Bulgaria

Further clarifications regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organization.
To check this certificate validity please call: +359 (2) 983 60 44




008



Handwritten signature in the bottom right corner.

BUREAU VERITAS
Certification



ПС ЕЛЕКТРИК ООД

бул. Мадара 12, 9700 Шумен, България

*Bureau Veritas Certification Holding SAS – UK Branch удостоверява,
че системата за управление на горепосочената организация е оценена
и е установено нейното съответствие с изискванията
на стандарта за управление, указан по-долу*

ISO 9001:2008

Обхват на сертификация

**Проектиране, изработка, доставка и поддръжка на комплексни
трансформаторни подстанции и комутационни устройства
(комутационни табла).**

Начало на сертификационния цикъл: 01 Май 2015

При постоянно поддържане на системата за управление, този сертификат е валиден
до: 01 Май 2018

Първоначална дата на сертификация: 02 Май 2006

Сертификат №: BG120487Q

Версия 1, Дата на ревизия: 29 Април 2015

на основание чл. 2 от ЗЗЛД

**ВЯРНО С
ОРИГИНАЛА**

Signed on behalf of BVCH SAS UK Branch

Certification body address: 5th Floor, 66 Prescot Street, London, E1 8HG, United Kingdom
Local Office: 81A, Bulgaria Blvd., 1404 Sofia, Bulgaria

Информация за обхвата на сертификата и приложението на изискванията
на системата за управление могат да бъдат получени от организацията.
За валидността на настоящия сертификат моля обадете се на: +359 (2) 983 60 44



008

C

C