

**ABB**

Приложение 2 - Изисквани документи от Технически изисквания и спецификации




ABB Bulgaria EOOD
Main Office
9, Hristofor Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com

UIC: 831133152
VAT Nr.: BG 831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13INGB91451000027317 (BGN)
IBAN: BG60INGB91451400027311 (EUR)
BIC: INGDBG5F



03.2017





8




Power Transformers

8




It's time..



... and this





company
profile

KOLEKTOR ETRA has been acting as transformer manufacturer over more than 75 years. Specializing in the manufacturing of power transformers rating up to 500 MVA and 420 kV, the company is focusing its activities mainly in technical areas like loss and noise level reduction. Innovation, competence, reliability and after sales service are the words which characterize the company by our valued customers over the years.

time belongs to us.




It's direction..

Modern manufacturing and testing equipment together with high skilled employees dedicated to creating innovative solutions are the basis of KOLLEKTOR-ETRA's competence. Furthermore, a well established supply chain with highly optimized in-house production process of a technically excellent product within extremely short delivery times.



... the one






International


With highly experienced and professionally trained group of employees we can perform all routine type and special tests required by international standards.


and only



It's satisfaction...

KOLEKTOR ETIRA's objective is to supply products that convince the client with their technical parameters and high quality as well as an optimum price-performance ratio. Along-term commitment to research and development guarantees continuous improvements in performance and efficiency, cost optimization and a prolonged life of the existing products. KOLEKTOR ETIRA also continuously develops new high-tech products to contribute to the evolving market and to satisfy even the most demanding customer requirements. The entire R&D process is integrated into a collaborative network with universities and research institutes. Both widespread use of sophisticated design software and high-end test equipment offer the client a guarantee of fully developed products at the cutting edge of technology.





Innovation

The company's R & D focuses on:


- Electromagnetics
- Structural mechanics
- Thermodynamics
- Acoustics
- Anticorrosion

creating excellence.




It's something...

KOLEKTOR ETRA offers a complete range of power and special transformers designed to grant the reliability, durability, and efficiency required in industrial and commercial applications. KOLEKTOR ETRA's liquid filled transformers are manufactured in accordance with the most demanding international industry standards like IEC, EN or ANSI.



... you should

Reliability &






never forget.

The logo for ETRA, consisting of the letters 'ETRA' in a bold, stylized font with a horizontal line through the middle of the letters, set against a dark square background.

It's somebody...


After Sales Service by KOLEKTOR IETRA means being able to draw on a customer-oriented transformer services to the full extent. Our customers benefit from over 75 years of experience in the manufacture and service of transformers, concentrated in our individual quotations. As the original equipment manufacturer (OEM) we're familiar with all technical solutions for sophisticated power transformer engineering.


A handwritten signature in the bottom left corner of the page.



... who cares.

After
Sales
Service







KOLEKTOR ETRA
Energetski transformatorji d.o.o.

Slandrova ulica 10 | 1000 Ljubljana | Slovenija
tel: +386 1 530 28 00 | fax: +386 1 530 28 30
www.etras3.si



Technical catalogue






[Handwritten scribble]

About





KOLEKTOR: ETRA has been acting as transformer manufacturer over more than 75 years. Specializing in the manufacturing of power transformers rating up to 500 MVA and 420 kV the company is focusing its activities mainly in technical areas like loss and noise level reduction. Innovation, competence, reliability and after sales service are the words which characterize the company by our valued customers over the years.



ETRA



Power transformers

Power transformers and auto-transformers of rated power up to 500 MVA and rated voltage up to 420 kV, filled with mineral oil or environment friendly, biodegradable, unflammable insulating liquid.



Special transformers

- Furnace transformers with on-load tap-changing used for arc furnaces
- Furnace transformers with off-load tap-changing used for induction furnaces
- Rectifier transformers
- Grounding transformers for the neutral point earthing





ETRA

Knowledge

All our products
are result of our own
design



In our archives we preserve more than 4000 different designs. Most of them are currently used for the performance of our servicing activities, but taken as a whole, they are a unique source of tradition, experience and excellence. With modern and approved computer techniques, use of new materials and technologies, we are constantly developing new products.



*Magnetic field between conductors
and ferrous beam*

Our aim is to supply our customers with reliable, environment friendly products. Thus, transformers manufactured in KOLEKTOR ETRA have low losses and low noise levels.

Numerical simulation of mechanical stresses in transformer tank



Environment

Our contributions to the protection of environment


In modern society human beings and machines often share their common life and working space. Operation of each machine or appliance is felt by human beings and the nature as a disturbance. In our factory we do our best that the operation of our transformers is safe, long lasting, economic and with least possible effects upon environment.



- Mineral oils used for oil immersed transformers do not contain PCBs or other harmful substances.
- In transformers located in fire-resistant and water conservation areas we use synthetic oils, i.e. environment-friendly liquids. Main characteristics of these liquids are: higher flash point and biodegradability.
- We are qualified for repair works, reconstructions, different reworks of transformers, their constituent parts and equipment.
- Our special attention is paid to reduction of noise level of the transformer. Noise levels achieved for transformers are low enough to decrease substantially the costs for the construction of anti-noise barriers in transformer stations.
- Our special contribution to preservation of the environment is safe and environmental friendly decommission of transformers after their life cycle expiration.



Handwritten scribble




Handwritten scribbles




ETRA


Magnetic core

Three quality classes of magnetic steel sheets are in use: oriented conventional magnetic steel sheets of class C.G.O., steel sheets of high magnetic orientation H.H.B. and laser treated magnetic steel sheets. Magnetic core is stacked by overlapping of individual steel sheets according to the step-lap system. So called core type with two, three or five limbs is used. With accurate cutting and careful stacking of the magnetic steel low no-load loss, low no-load current, low amplitudes of the in-rush current and low noise level is obtained.




The core laminations are securely held together by means of heat shrinkable polyglass bands and tightening facilities made from anti-magnetic steel in such a way that movement of laminations during transportation and vibrations during operation are prevented.





The lower yoke and the limbs are coated with glue varnish. Oscillations and vibrations caused by magnetostriction forces are thus reduced to minimum. The frame formed by yoke and limb clamps around the magnetic core enables safe transporting of the transformer and adequate resistance to electromagnetic short-circuit forces.

Big units have individual packages of steel separated with insulation barriers, and those with higher flux density in core with cooling channels. In such cases all with insulation separated packages are galvanically connected and earthed. Earthing of all iron parts on the magnetic cores is performed separately.




ETRA

Windings

The windings are made from electrolytic copper of high purity (Cu-ETP signed). Specific electric conductivity is 58 Sm/mm^2 . Conductors are in strength by RPO-2 from 90 to 160 N/mm^2 . For higher currents are used foil and rectangular conductors insulated with paper or enamel. For the highest powers and currents is used transposed cable.

Three thermal classes of insulation are in use:

- enamel insulation (PVA), thermal class F (120°C) in compliance with standard IEC 60317-0-2;
- Paper insulation 5A2-1M3, thermal class A (105°C) in compliance with standard IEC 554-3-5;
- Thermal upgraded paper insulation 5B1-2M3, thermal class E (120°C) in compliance with standard IEC 554-3-5;



The windings are manufactured in different variants:

Single-layer or multy-layer windings are used for phase currents up to 1000 A and rated voltages up to 72/5 kV.




For higher and the highest voltage classes disc windings are used: helical, continuous disc or interleaved.

[Handwritten signature]

Helical windings are made in form of single or double spirals across the total height of windings. They are suitable for the currents up to 2000 A and voltage up to 36 kV.

Continuous disc windings are made of several numbers of equal coils or sections connected in series. These windings are of advantage when used for transformers rated above 2500 kVA and voltages up to 145 kV.

Interleaved windings are used in case when the transformer has to be tested by lightning impulse voltage above 11325 kV. Similar as continual disc windings are made of equal coils composed of higher number of equal disks and sections respectively. The connections between the disks are interleaved. After the completion of windings the procedure of thermal stabilization of insulation and the adjustment of specified dimensions follows. Windings are first dried in the drying furnace, after that their height is set by hydraulic pressing device.



[Handwritten signature]



[Handwritten signature]

ETRA

Assembly of active part

After thermal and mechanical stabilization of windings, follows the assembly of all windings forming one phase of the transformer. They are clamped between special laminated wooden plates, enabling simple installation of windings on the magnetic core limbs. After closure of the upper magnetic core yoke follows the insertion of both yoke clamps, and afterwards of screws and shock absorbers between both yoke clamps and windings for permanent pressure of windings.

Plates and screws for longitudinal pressing of all windings for one phase and the radial tightening cylinder form a compact unit resistant to forces in case of eventual short circuit in the network.



Clamping of windings and of the magnetic core is also important for the transport, where compactness of design assures safe transport without damages, internal movements or slipping transformer within the active part.

Adequate drying of insulation according to vapour phase system and filling of the active part with oil under vacuum are the final phases determining the high dielectric, thermal and dynamic strength of the transformer.






Insulation system

The insulation system in oil-immersed transformers is made of hard insulation and liquid dielectric. The liquid dielectric is usually mineral or synthetic oil. Hard insulation is made of concentric cylinders or barriers from special high-pressure cardboard. We use only high-quality stabilized insulation produced by renown producers.


Calculations of dielectric insulation loads are performed according to modern methods based on computer-aided design. This enables a fast and more accurate calculation and optimum design of insulation, especially for high-voltage transformers.



Tank

Tanks are designed with reinforced plane walls to withstand full vacuum and 70 kPa overpressure. We manufacture two types of tanks: the classic tank and the tank in the shape of a bell. The active part in the classic tank is lifted together with the cover, while in the bell-shaped tank only the bell is lifted without the bottom and active part. Corrosion protection of the tank and equipment is standardized and is defined in dependence on climatic conditions in which the transformer shall be in operation or according to the customer's requirements.

Materials used for the production of tanks are classified into the category of construction steels. The required strength calculations for the tank are performed in accordance with modern methods. With the help of computer-aided engineering work and numerical strength tests we assure optimal construction design, perfect safety and safe transport of the transformer to the location of its installation.




The standard corrosion protection is often adapted to the requirements of our customers; thus they can choose the thickness of individual layers, their combination and the top coat shade. Parts of equipment for large transformers and radiators are often protected with the hot-zincing procedure enabling transformers to operate under hardest climatic conditions.


ETRA

Cooling system

Transformers are equipped with a cooling system which can efficiently dissipate the heat emerging during operation. The cooling system is designed and tested for permanent operation with declared capacity within the limits of specified temperature rises. If there are no special overloading requirements, the cooling system is designed in correspondence with the IEC 60076-7. It comprises radiators, varied types of oil coolers or heat exchangers.

They can be separated from the tank and divided into several batteries or coolers what enables fast assembly or dismantling of installations. The cooling system can be separated from the tank and situated in separate facilities with better conditions for the heat dissipation. In such cases the system has installed pumps for faster circulation of oil. Only the OF and OD types of cooling can be applied.






ETRA

Testing and quality assurance

Each individual core, winding, tank and other parts are subjected to the mechanical and electrical inspection prior to mounting. During the mounting procedure the following is performed: interphase measurement of voltage ratio, measurement of resistance, insulation resistance, measurement of short circuit loss prior to drying process, supervision of drying process and transformer oil dielectric strength testing.

The interphase measurements are carried out in the workshops. The final testing of transformers is carried out in our own, well equipped, up to date designed high voltage laboratory located near the production plant. By using the metal plate cage in the laboratory walls and electrical supply through filters a very low frequency disturbance is achieved which is of great importance. When partial discharges are tested, corona measured etc.




Upon the completion the transformer is subjected to routine test and measurement required by the standards, while each new transformer type also demands type testing.

With highly experienced and professionally trained group of employees we can perform routine, type and special tests required by international standards.

The main equipment of the high voltage laboratory is:

- Motor-generator group 3500/1200/500 kVA, 12/6/3 kV, 50/200/500 Hz
- Test transformer 500 kV, with a regulation transformer, compensating reactor, capacity divider and control panel with digital measuring instrument
- Computer controlled impulse voltage generator 2000 kV, 200 kJ provided with a RC divider and chopped wave device
- Mobile equipment for measurement of resistance and temperature rise test with automatic temperature readings
- Digital partial discharge measuring system
- Equipment for measuring tgo and the transformer capacitance



- Precision wide band power analyser
- Frequency response analyser (FRA)
- Three phase transformer turns ratio meter
- Noise source identification system with automated microphone positioning system
- Sound intensity analyser
- Sound level meter
- Automated test unit for testing of transformer oil dielectrical strength
- Testing unit for dissolved gas analyses



Service activities


Our factory performs also various service activities such as: repair of transformers of different manufacturers; reconstruction of vital parts of used transformers and reworking of transformers; maintenance of transformers and reactors; supervision of installation and putting into operation of transformers; execution of measurements on transformers and reactors in our own HV laboratory or at site; replacement of transformer oil with new oil or treatment of used oil; and organization of transport; installation and dismantling of transformers and reactors.

Our service department has several service groups always ready for fast interventions at site. Special service vehicles are equipped with the required equipment, tools and spare parts for fast interventions.





Advantages of our service groups are: fast reaction; professional inspection and diagnosis of failure; performance of repair works within the agreed upon terms and quality technical documentation referring to the performed work.

[Handwritten scribble]



[Handwritten scribbles]



KOLEKTOR ETRA


Energetski transformatorji d.o.o.

Slandrova ulica 10 | 1231 Ljubljana črnuče | Slovenija

tel: +386 1 530 28 00 | fax: +386 1 530 28 30

www.etra33.si

[Handwritten signature]



1ZSE 2750-111 en, Rev. 9

Transformer bushings, type GSA-OA

Technical guide

[Handwritten mark]

[Handwritten mark]

[Handwritten signature]

ABB
[Handwritten signature]

Original instruction

The information provided in this document is intended to be general and does not cover all possible applications. Any specific application not covered should be referred directly to ABB, or its authorized representative.

ABB makes no warranty or representation and assumes no liability for the accuracy of the information in this document or for the use of such information. All information in this document is subject to change without notice.

This document must not be copied without our written permission, and the contents thereof must not be imparted to a third party nor be used for any unauthorized purpose. Contravention will be prosecuted.

CC

CC

Content

Design.....	4
Standards.....	4
Features and benefits.....	4
Transportation and long term storage.....	5
General specifications.....	5
Testing.....	6
Routine testing.....	6
Type tests.....	6
Special tests.....	6
Test tap.....	6
Test tap adapter.....	6
Electrical data.....	7
Dimensions.....	8
Connection details.....	10
Outer terminal.....	10
Inner terminal.....	10
Solid rod conductor.....	11
Ordering particulars for solid rod conductor.....	11
Conductor Insulation.....	11
Separate terminal plate with bolts.....	12
Arcing horns.....	12
Conductor loading.....	13
Overloading of bushings.....	13
Short-time current.....	13
Ordering particulars.....	14
Recommendations for positioning.....	15

Design

GSA-OA is a Resin Impregnated Paper (RIP) bushing with Silicone Rubber (SiR) insulator. The condenser core is bonded directly to the silicone rubber to give a compact and lightweight bushing, containing no gas, oil or other liquids.

The GSA bushings are produced by winding a crêped paper web onto a mandrel, with aluminium foil inserts for electrical stress control. The core is impregnated and cured under vacuum, giving a partial discharge free bushing with low tan δ (dissipation factor). After curling, the core is machined and the flange is fitted.

The inner terminal is fixed to the top piece with a divided ring (patented by ABB) and can be connected to leads by brazing. For maximum current rating, a solid copper rod is used.

Outer terminals are available in a number of standard configurations in aluminium and copper, but can also be modified to suit any connection need.

The standard colour of the mounting flange and of the insulator is ANSI 70, light grey.

Standards

The GSA bushing is designed and tested according to IEC 60137 and IEEE C57.19.00/01 in applicable parts.

Features and benefits

Solid

Reduced risk for fire, any mounting angle possible, oil leakage from the bushing eliminated, no monitoring of pressure and oil level.

Seals the transformer

Reduced risk for fire, risk for oil leakage from the transformer reduced.

Non-shattering materials

Protection of personell and equipment, easy handling, safe transport - also when mounted on the transformer, high seismic withstand

Light weight, compact

Easy handling, small requirements on space inside transformer, low life cycle environmental impact.

Silicone rubber insulator

Superior electrical performance, cleaning normally not needed.




Fig. 1. Transformer bushing type GSA-OA.

Transportation and long term storage

The bushing is surrounded by a sealed moisture-proof wrapping material together with a drying agent upon delivery. The supplied protective wrapping shall not be opened if the bushings are intended to be stored. After transformer test, it is also important to reseal the bushing with the supplied protective wrapping or a similar moisture-proof wrapping, together with a drying agent. The wrapping works as protection for transportation and storage (≤ 6 months). Note that bushings with standard wrapping shall be stored protected from precipitation.

For longer storage times (>6 months) a container have to be ordered separately.

General specifications

For conditions exceeding the standard specification, please consult the supplier.

Application:	Transformers
Classification:	Resin Impregnated paper, capacitance graded, outdoor Immersed bushing
Ambient temperature:	+40 °C to -40 °C, minimum value acc. to temperature class 3 of IEC 60137
Altitude of site:	< 1000 m
Level of rain and humidity:	1-2 mm rain/min. horizontally and vertically, as per IEC 60060-1, and 5 mm/min. as per IEEE
Pollution level:	According to specific creepage distance and IEC 60815
Immersion medium:	Transformer oil. Maximum daily mean oil temperature +90 °C. Maximum temporary oil temperature +115 °C.
Oil level in transformer:	Not lower than 25 mm from the bushing flange
Max pressure of medium:	100 kPa (over pressure)
Angle of mounting:	Horizontal to vertical
Test tap:	Test tap with 4 mm male contact pin
Capacitance C_2 of test tap:	< 5000 pF
Arclng horns:	Optional
Conductor:	Solid or flexible draw lead conductor
Markings:	Conforming to IEC/IEEE.

Testing

Routine testing

The bushing is routine tested according to applicable standards. The tests include measurement of partial discharge quantity, $\tan \delta$, capacitance, dry power frequency voltage withstand test. The flange is separately tightness tested with helium. A visual inspection is performed.

An individual routine test protocol is delivered with each bushing from ABB.

Type tests

Complete type tests have been performed and reports are available on request.

Special tests

A number of tests not specified by international standards have also been performed and reports are available on request.

Test tap

The outer conducting layer of the condenser core is connected to an insulated test tap on the flange. During operation the protective cap must be fitted to earth the outer layer to the flange. The maximum test voltage is 2 kV, 50 Hz for 1 minute. The maximum service voltage is 600 V.

Test tap adapter

For testing, a special test adapter is required for permanent connection of the test tap to the measuring circuits.




Fig. 2. Test tap.




Fig. 3. Test tap adapter, 1ZSC003881-AAC.

Electrical data

Ratings GSA-OA	52	73	123	145	170
Rated voltage IEC (kV)	52	72.5	123-170	145-170	170
Rated phase-to-ground voltage IEC (kV)	30	42	98	98	98
Insulation class IEEE (kV)	48	69	115	138	161
Rated line-to-ground voltage IEEE (kV)	29	44	88	88	102
Basic Insulation Level (kV) (Equal to dry lightning impulse withstand voltage.)	250	350	550	650	750
Rated current (A)	2000	2000	1600	1600	1600
Draw lead current (A)	1250	1250	1250	1250	1250
Rated frequency (Hz)	50/60	50/60	50/60	50/60	50/60
Temporary over voltage (kV)	52	73	170	170	170
Wet power frequency AC (kV)	95	140	230	275	325
Dry power frequency, Routine test 1 minute (kV)	120	160	260	310	385
Nominal capacitance between conductor and test tap C1 ±10 % (pF)	215/417/543	325/512/636	216/319/369	233/326/386	311/404/467
Space for current transformer (mm) 0/300/500					

Dimensions

Dimensions are subject to modification without notice.

Type GSA	Cat. No.	Dimensions in mm													
		Total L	Oil side L1	Air side L2	Draw lead L4	Top part L5	Arcing distance L7	Flange height L8	Condenser core outer D1	Centre hole D2	Min. gasket surface inner diameter D5	Hole circle D6	Flange D7	Insulator sheds D8	Top piece diameter D9
52	LF 130 052-BA	734	145	589	583	56	467	101	98	51	110	185	225	230	120
	-BB	1034	445												
	-BC	1234	645												
73	LF 130 073-BA	1029	260	769	763	56	647	101	98	51	110	185	225	230	120
	-BB	1329	660												
	-BC	1529	760												
123	LF 130 123-BA	1444	255	1189	1183	56	1067	101	136	51	150	250	290	270	160
	-BB	1744	555												
	-BC	1944	755												
145	LF 130 145-BA	1731	362	1369	1363	56	1247	101	136	51	150	250	290	270	160
	-BB	2031	662												
	-BC	2231	862												
170	LF 130 170-BA	2019	410	1609	1603	56	1487	101	136	51	150	250	290	270	160
	-BB	2319	710												
	-BC	2519	910												

Type GSA	Rated current (A)	Cat. No.	Space for current transformer (mm)	Net mass (kg)	Number of holes n1	Flange thickness T	Creepage distance		Cantilever load Max. permitted loading perpendicular to the terminal	
							total (mm)	protected (mm)	(N)	Test (N)
52	2000	LF 130 052-BA	0	13	6	15	1642	700	2000 ¹⁾	4000
		-BB	300	16						
		-BC	500	17						
73	2000	LF 130 073-BA	0	18	6	15	2323	1000	2000 ¹⁾	4000
		-BB	300	20						
		-BC	500	21						
123	1600	LF 130 123-BA	0	45	8	15	3913	1700	2000 ²⁾	4000
		-BB	300	50						
		-BC	500	53						
145	1600	LF 130 145-BA	0	52	8	15	4595	2000	2000 ²⁾	4000
		-BB	300	57						
		-BC	600	60						
170	1600	LF 130 170-BA	0	61	8	15	5504	2400	2000 ²⁾	4000
		-BB	300	66						
		-BC	500	69						

1) Exceeding IEC 60137 Cantilever load Level II.

2) Conforming to IEC 60137 Cantilever load Level II.

[Handwritten signature]




Fig. 5. Dimensions.

[Handwritten signature]

[Handwritten signature]

Connection details

Outer terminal

The outer terminal needs to be specified in each case. The outer terminal is then used together with either a solid rod, for maximum current capacity, or a flexible lead for greater ease of assembly, when the required current capacity is lower.

The outer terminal is available in a number of standard configurations. Other configurations can be supplied on request.

Material	Plating	Stud diameter (mm)	Cat. No. LF 170 079	Mass (kg)
Aluminium	-	60	-A (standard)	2,3
	-	30	-B (standard)	1,6
Copper	-	60	-C (standard)	6,2
	-	30	-D (standard)	3,6
	Tin	60	-E	6,2
	Tin	30	-F	3,6
	Silver	60	-G	6,2
	Silver	30	-H	3,6




Fig. 8. Outer terminal.

Inner terminal

The inner terminal is made of copper for connection of a draw lead.

Material and design	Conductor diameter (mm)	Cat. No. LF 170 080	Mass (kg)
Copper for brazing	5 (pilot hole)	-A	1
	11	-B	1
	13	-C	1
	15	-D	1
	18	-E	1
	30	-F	1
	42	-G	1
	45	-H	1




Fig. 9. Inner terminal.

Solid rod conductor

The rod is produced from electrolytical copper and divided into two parts for ease of assembly. The parts are joined with a screw joint with undroppable screws. The lower part of the solid rod is designed to enable connection by brazing. The solid rod is available with two alternative dividing points, 20 mm below the bushing flange or 20 mm below the space for current transformer. The solid rod is delivered without paper insulation.

Conductor insulation

Draw leads and solid rods must be insulated with vacuum oil-impregnated insulating paper or equivalent, to give sufficient insulation integrity. The paper insulation must be min. 2 mm

Draw lead: The paper insulation must be brought min. 50 mm inside the bushing centre hole.

Solid rod: The paper must fill the recess and cover the whole solid rod end downwards.




Fig. 10. Solid rod conductor.

Ordering particulars for solid rod conductor

Bushing Cat. No.	Division at flange			Division at current transformer			Mass (kg)	
	Upper part LF 170 081	1600 A Lower part LF 170 082	2000 A Lower part LF 170 082	Upper part LF 170 081	1600 A Lower part LF 170 082	2000 A Lower part LF 170 082	1600 A	2000 A
LF 130 052	-BA	-ABA	-DABA	-ABA	-	-	13	13.5
	-BB	-BABA	-DABB	-ABB	-ABB	-DBABA	18	18.5
	-BC	-CABA	-DABC	-ABC	-ABC	-DCABA	21.5	22
LF 130 073	-BA	-BBA	-DBBA	-BBA	-	-	18	18.5
	-BB	-BBBA	-DBBB	-BBB	-BBB	-DBBBA	23	23.5
	-BC	-CBBA	-DBBC	-BBC	-BBC	-DCBBA	26	26.5
LF 130 123	-BA	-DBA	-DADBA	-	-	-	25	-
	-BB	-BDBA	-DDBB	-	-DBB	-DBDBA	30	-
	-BC	-CDBA	-DDBC	-	-DBC	-DDBA	33	-
LF 130 145	-BA	-EBA	-DEBA	-	-	-	29.5	-
	-BB	-BEBA	-DEBB	-	-EBB	-DEBEA	33.7	-
	-BC	-CEBA	-DEBC	-	-EBC	-DCEBA	37.1	-
LF 130 170	-BA	-FBA	-DAFBA	-	-	-	34.5	-
	-BB	-BFBA	-DFBB	-	-FBB	-DBFBA	39.5	-
	-BC	-CFBA	-DFBC	-	-FBC	-DFBA	42.5	-

Separate terminal plate with bolts

The separate terminal plate is available for stud with $\varnothing 30$ mm, and used for connecting the bushing to the line conductor.

Material	Cat. No.
Aluminium	LF 170 014-A
Nickel plated copper	LF 170 021-A




Fig. 11. Separate terminal plate with bolts.

Arcing horns

Arcing horns made of galvanised steel can be mounted on the bushing. The arcing horns are available for stud with $\varnothing 30$ mm.

The lower rod is fastened onto the flange with one of the fixing screws and the upper rod by means of a bracket on the outer terminal.

The gap distances for standard arcing horns are shown in the table. Other gap distances on request.

Bushing type	K (mm)	C (mm)	H (mm)
GSA 52	230-440	315	112
GSA 73	400-620	315	112
GSA 123	620-960	315	114
GSA 145	700-1080	380	224
GSA 170	820-1290	380	224





Fig. 12. Arcing horns.



Conductor loading

The GSA bushings fulfill the temperature rise test requirements according to IEC and IEEE for the currents below:

Bushing type	Conductor	Permissible current	
		IEC (A)	IEEE (A)
GSA-OA			
52-73 kV	Solid rod	2000	2000
123-170 kV	Solid rod	1600	1600
All types	Stranded cable		
	185 mm ²	400	400
	740 mm ²	1250	1250


Overloading of bushings

If the conductor for the bushing is selected with 120 % of the rated current of the transformer, the bushing is considered to be able to withstand the overload conditions stated in IEC 60354 without further clarifications or tests, according to IEC 60137.

Short-time current

The rated thermal short-time current (I_{st}) is calculated according to IEC 60137.

Conductor	Rated current A	Area mm ²	Short-time current (I_{st})		Dynamic current (I_d) kA, peak
			kA, rms		
			1 s	2 s	
Solid rod Ø 49 mm Cu	2000.. 1600	1888	100	96	240
Stranded draw-lead	1250	740	61	43	107



Ordering particulars

When ordering, please state:

- Type and catalogue number for bushing.
- Catalogue number for inner terminal or conductor, lower and upper part.
- Catalogue number for outer terminal.
- Additional accessories or modifications.
- Test required, in addition to the normal routine tests.




Fig. 13. Nameplate with marking example.

Recommendations for positioning

The maximum stresses in the oil at the surface of the conductor insulation must be limited to those values normal for insulated conductors and similar components in the same transformer.

The adjacent recommendations are intended as guide lines when complete calculations are not carried out.

Type GSA	Internal insulation level of transformer (kV)	Distance to earthed parts R (mm)
52	250-95	75
73	350-140	90
123	550-230	145
145	650-275	165
170	750-325	190




Fig. 14. Recommendations for positioning.

Contact us

ABB AB

Components

SE-771 80 Ludvika, Sweden

Phone: +46 240 78 20 00

Fax: +46 240 121 57

E-Mail: sales@se.abb.com

www.abb.com/electricalcomponents

© Copyright 2017 ABB, All rights reserved. 1ZSE 2750-111 en, Rev. 9, 2017-02-15

ABB

[Handwritten signature]




TECHNICAL DATA

TYPE CM2 VACUUM ON-LOAD TAP CHANGER

FOR OIL-IMMERSED TRANSFORMER

HM0.154.5701



SHANGHAI HUAMING POWER EQUIPMENT CO., LTD.



[Handwritten signature]

[Handwritten signature]

General

1. General	3
2. Technical specification	4
3. Model designation	5
4. Terms and definitions	7
5. Special designs	10
6. Motor drive unit	12
7. Controllers for On-Load tap changer	13
8. OLTC accessories	13
9. Appendixes	14
9.1 CM2 III 500Y/600Y without change-over selector, overall dimensions	15
9.2 CM2 III 500Y / 600Y with reversing switch, overall dimensions	16
9.3 CM2 III 500Y / 600Y with coarse change-over selector, overall dimensions	17
9.4 CM2 II 500 / 600 without change-over selector, overall dimensions	18
9.5 CM2 II 500 / 600 with reversing switch, overall dimensions	19
9.6 CM2 II 500 / 600 with coarse change-over selector, overall dimensions	20
9.7 CM2 I 500 / 600 without change-over selector, overall dimensions	21
9.8 CM2 I 500 / 600 with reversing switch, overall dimensions	22
9.9 CM2 I 500 / 600 with coarse change-over selector, overall dimensions	23
9.10 CM2 I 800 without change-over selector, overall dimensions	24
9.11 CM2 I 800 with reversing switch, overall dimensions	25
9.12 CM2 I 800 with coarse change-over selector, overall dimensions	26
9.13 CM2 I 1200 / 1500 without change-over selector, overall dimensions	27
9.14 CM2 I 1200 / 1500 with reversing switch, overall dimensions	28
9.15 CM2 I 1200 / 1500 with coarse change-over selector, overall dimensions	29
9.16 CM2 OLTC mounted with tie-in resistor, overall dimensions	30
9.17 CM2 OLTC General layout Drawing (With Insulated bottom)	31
9.18 CM2 Tap selector contacts arrangement	32
9.19 CM2 OLTC head flange for standard tank type, overall dimensions	33
9.20 CM2 OLTC head flange with pressure relief valve, overall dimensions	34
9.21 CM2 OLTC head flange with pressure relief valve, overall dimensions (with raised seat)	35
9.22 Transformer connection flange for CM2 OLTC, overall dimensions	36
9.23 CM2 OLTC head flange installation for bell-type, overall dimensions	37
9.24 Upper gear unit, arrangement and swiveling range	38
9.25-1 CM2 OLTC arrangement drawing-1	39
9.25-2 CM2 OLTC arrangement drawing-2	40
9.26 CM2 OLTC, general layout drawing	41
9.27 Bevel gear unit, overall & installation dimensions	42



9.28 CM2 I 800 / 1200 / 1500 OLTC,
parallel connection plate of tap selector terminals, overall dimensions.....43

9.29 Protective relay, overall & installation dimensions.....44

9.30 CM2(10070) operating position table and connection diagram45

9.31 CM2(10090) operating position table and connection diagram46

9.32 CM2(10071W) operating position table and connection diagram47

9.33 CM2(10091W) operating position table and connection diagram48

9.34 CM2(10191W) operating position table and connection diagram49

9.35 CM2(10193W) operating position table and connection diagram50

9.36 CM2(10191G) operating position table and connection diagram.....51

9.37 CM2(10193G) operating position table and connection diagram.....52

9.38 CM2(12110) operating position table and connection diagram53

9.39 CM2(12111W) operating position table and connection diagram.....54

9.40 CM2(12233W) operating position table and connection diagram55

9.41 CM2(12233G) operating position table and connection diagram.....56

9.42 CM2(14130) operating position table and connection diagram57

9.43 CM2(14131W) operating position table and connection diagram58

9.44 CM2(14273W) operating position table and connection diagram59

9.45 CM2(14273G) operating position table and connection diagram.....60

9.46 CM2(16150) operating position table and connection diagram61

9.47 CM2(16151W) operating position table and connection diagram62

9.48 CM2(16313W) operating position table and connection diagram63

9.49 CM2(16313G) operating position table and connection diagram.....64

9.50 CM2(18170) operating position table and connection diagram65

9.51 CM2(18171W) operating position table and connection diagram66

9.52 CM2(18353W) operating position table and connection diagram67

9.53 CM2(18353G) operating position table and connection diagram.....68

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

2

1. General

Type CM2 Vacuum On-Load Tap Changer (hereinafter referred as CM2 or CM2 OLTC) is a typical combined-structure tap changer applicable in oil-immersed transformer, comprising of two major parts: diverter switch and tap selector. The CM2 OLTC is put in transformer oil tank and its diverter switch has a separate oil compartment from transformer tank, while tap selector, together with transformer windings, is completely laid inside the tank. OLTC's installation is divided into two types - standard tank flange and bell-type flange.

Three-phase CM2 OLTC could be used at neutral point of star-connection, and a combination of three units of single-phase CM2 OLTC is designed for any selectable winding connection.

Basic connections of tap winding as in fig.1




Fig.1 Basic Connections of Tap Winding

a) without change-over selector

This linear regulation can be designed by a maximum of 9, 11, 13, 15 or 17 steps, namely 10, 12, 14, 16 or 18 operating positions at maximum.

b) with change-over selector

With reversing switch or coarse tap selector, the regulating range will be doubled to maximum ± 9 , ± 11 , ± 13 , ± 15 or ± 17 steps, namely 19, 23, 27, 31 or 35 operating positions at maximum, when actual positions are less than above mentioned ones, it can be easily realized by passing over continuous operation of motor drive unit or equal potential connection of multiple operating positions.

2. Technical specification

Type CM2 OLTC complies with IEC60214-1: 2003 standard, please refer to below table 1.

Table 1 CM2 Series OLTC Main Technical Specifications

Item	Specification	CM2III 500Y CM2I 500	CM2III 600Y CM2I 600	CM2I 800	CM2I 1200	CM2I 1500	
1	Max. rated through-current (A)	500	600	800	1200	1500	
2	Rated frequency	50 or 60					
3	Connection	Three-phases for neutral point of star connection Single-phase for any selectable winding connection					
4	Max. rated step voltage (V)	3300					
5	Rated step capacity (kVA)	1400	1500	2000	3100	3500	
6	Short-circuit current test (kA)	Thermal (3s)	8	8	16	24	24
		Dynamic (Peak)	20	20	40	60	60
7	Max. Operating Positions	Without change-over selector	18				
		With change-over selector	35				
8	Insulation to ground (kV)	Highest voltage for equipment Um	72.5	126	170	252	
		Rated separate source AC withstand voltage(kV/50Hz,1min)	140	230	325	460	
		Rated lightning impulse withstand voltage (kV,1.2/50µs)	350	550	750	1050	
9	Tap selector	4 grades of B, C, D and DE according to insulation level					
10	Mechanical life	Not less than 1,500,000 operations					
11	Contact life	Not less than 600,000 operations					
12	Oil compartment of diverter switch	Service pressure	0.03MPa				
		Leakage test	No leakage under 0.08MPa for 24 hours				
		Over pressure protection	Bursting cap bursts at 300 ± 20%kPa				
		Protection relay	Oil flow speed set at 1.0m/s ±10%				
13	Motor drive unit	SHM-III or CMA7					

3. Model designation

3.1 Model designation

Type CM2 OLTC models varies with number of phase, maximum.rated through current, the highest voltage for equipment, insulation grade of tap selector and connection mode, etc.The parameters are represented as in Fig.2 below.




Fig.2 Designation of CM2 OLTC

3.2 Designation of basic connection of tap selector

The tap selector may have different spec with respect to the number of the steps required and connection of the tap winding. The basic connection model reflects the relevant pitch of the contact circuit, the number of operating positions, the number of pitches of tap selector, the number of operating positions, the number of mid-positions and change-over selector type. See below Fig.3 for the indications of tap selector model.





Fig.3 Designation of Basic Connection Diagram of Tap Selector

3.3 Survey of basic connection diagram of tap selector

Different numbers of taps correspond to different connection diagram. Fig.4 shows regular basic connection diagrams of the tap selector, and special design depends on the from customers.



TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

Fig.4 Survey of Basic Connection Diagram of Tap Selector

4. Terms and definitions

4.1 Through current

Rated through current (I_u): The current flowing through an on-load tap-changer towards the external circuit, which is capable of transferring from one tap to the other at the relevant rated step voltage and which can be carried continuously while meeting the requirements of the standard.

Max. rated through-current (I_{um}): The highest rated through-current for which the tap-changer is designed for and which is the current reference for all related test.

4.2 Step voltage

Rated step voltage (U_j): For each rated through-current, the max. permitted voltage between two terminals which connect to two adjacent taps of the transformer.

Maximum rated step voltage (U_{jm}): The highest value of the rated step voltage for which the tap-changer is designed. The maximum rated step voltage of type CM2 is 3300 volt.

4.3 Rated step capacity P_{stn}

The step capacity equals to the product of step voltage multiplied by current. While the rated step capacity of OLTC is a permissible maximum step capacity during continuous operation. That is $P_{stn} = U_j \times I_u$. The rated step capacity refers to Fig.5.




Fig. 5 Curve of The Rated Step Capacity of CM2 OLTC

4.4 Breaking capacity

The breaking capacity refers to the maximum switching capacity under the safe changeover load, according to IEC60214-1(2003) stipulation, 40-time breaking switches shall be performed at a current corresponding to twice the maximum rated through-current (I_{um}) and at its relevant rated step voltage (U_j).

The breaking capacity of CM2 OLTC: $P_{stmax} = 2P_{stn} \approx 2I_{um} \times U_{stn}$

P_{stn} : Rated step capacity

I_{um} : Max. rated through current

U_{stn} : relevant step voltage



4.5 Electrical life of vacuum interrupter

The electrical life of vacuum interrupter is 600,000 operations.

4.6 Short-circuit current test

According to IEC 60214-1: 2003, all contacts continuously carrying the current shall be able to withstand 2s ($\pm 10\%$) short circuit test current without melting, deformation or mechanical damage. Meanwhile the starting peak current value shall be 2.5 ($\pm 5\%$) times of the root means square value of rated short circuit test current. Refer the short circuit test current values to Table 1. CM2 Series of OLTC Main Technical Specifications.

4.7 Conditions for OLTC's operations

4.7.1 Oil temperature for OLTC's operation ranges from -25°C to 105°C .

4.7.2 Ambient air temperature for OLTC's operation ranges from -25°C to 40°C .

4.7.3 The vertical inclination level of OLTC being installed into transformer towards ground should be less than 2%.

4.7.4 The installation site should be free of heavy dust, explosive or corrosive gas.

Note: Please contact us if special application required.


4.8 Internal insulation level

The internal insulation of CM2 OLTC is divided into four levels from low to high: B, C, D and DE. The withstand voltage is different between adjacent taps, max. and min. taps and between phases for tap changers with different insulation grade, Fig.6 shows the potential distribution of various parts after tap changer has been connected to voltage regulation winding. Table 2 shows CM2 OLTC power frequency withstand voltages and BIL values according to different insulation distance.

4.9 Insulation level to ground

The insulation level to ground refers to insulation of OLTC live parts against grounding parts, the rated value of which depends on dielectric tests according to IEC-60214-1(2003), please refer to Table 3.

The requirement of insulation to earth for OLTC is relevant to OLTC connection location at transformer tap winding, regulation range and mode, tap winding connection model and structure, as well as the rated voltage of transformer tap winding, anyhow. It is determined by insulation to ground of transformer voltage regulating winding.



Explanation of designation code:

- a: across regulation winding for the same phase
- a1: between any selected and preselected taps of the tap selector
- b: between any two taps of different phases
- a0: between any adjacent taps of diverter switch
- c1: between the beginning of coarse tap winding and neutral of fine tap winding of the same phase
- c2: between beginnings of coarse tap winding of different phases
- d: between beginning and end of coarse tap winding of the same phase
- SF: spark gap

Fig. 6 The Rated Voltage Stress on Tap Winding

Table 2 CM2 OLTC Internal Insulation

(unit: kV)

Designation code	Tap selector size B		Tap selector size C		Tap selector size D		Tap selector size DE	
	1.2/50 μ s	50Hz 1min	1.2/50 μ s	50Hz 1min	1.2/50 μ s	50Hz 1min	1.2/50 μ s	50Hz 1min
a	265	50	350	82	460	105	550	120
b	265	50	350	82	460	146	550	160
a ₀	90	20	90	20	90	20	90	20
a ₁	150	30	150	30	150	30	150	30
c ₁	485	143	545	178	590	208	660	230
c ₂	495	150	550	182	590	225	660	250
d	265	50	350	82	460	105	550	120

a₀: The inherent insulation level refers to insulation level with spark gap protection when full wave voltage impulse is 130kV, the spark gap will response 100%

Table 3 Insulation Level to Ground of OLTC

(unit: kV)

The highest voltage for equipment U _m	Rated separate source AC withstand voltage(kV/50Hz,1min)	Rated lightning impulse withstand voltage (1.2/50 μ s)
72.5	140	350
126	230	550
170	325	750
252	460	1050

4.10 Installation models

Type CM2 OLTC is mounted onto the transformer cover by tap changer head, a mounting flange (see appendix) must be provided by transformer producer for connection. CM2 OLTC is suitable for either standard tank or bell-type mounting. For bell-type tank transformer, the OLTC support flange is supplied as a temporary support, OLTC will be secured onto transformer mounting flange after complete installation of transformer bell-tank.

5 Special designs

5.1 Potential connection of the tap winding

For high voltage or wide regulation range on-load regulating transformer, during the operation of the change-over selector the tap winding is disconnected momentarily from the main winding, the regulating section will be broken away from the main coil and at status of "suspend", thus voltage regulating winding will gain the new potential that depends upon coupling capacities C_e (to ground) and C_w (between adjacent tap winding), refer to Fig.8. Generally this potential is different from the one of voltage regulating winding before change-over selector acting, the difference of them is designated as recovery voltage. This recovery voltage is produced at the breaking point of the separated contacts during the operation of change-over selector. If these differential voltages exceed a certain limit value, it may cause flashover on change-over selector and bring gas, it will be the serious problem. Therefore measures regarding potential connection of the winding must be taken.

CM2 OLTC could withstand a limit value of recovery voltage of 35 kV, when the potential is expected to overrun the limit value, tap winding should be permanently connected to a fixed potential resistance via a tie-in resistor, see Fig.7. For mounting location and dimensions of CM2 OLTC tie-in resistors, please refer to appendix 9.16

For calculating the change-over selector stress and dimensioning the tie-in resistors, the following details of the transformer specifications required when ordering:

- a) Complete transformer parameter: rated capacity, rated voltage, voltage regulating range, winding connection mode, insulation level and so on.
- b) Arrangement of the windings, i.e. the relative position of the tap winding to the adjacent coil or winding parts
- c) Operating A.C.voltage across windings or layers of windings adjacent to the tap windings
- d) Capacitance of the tap winding to adjacent windings(C_w)
- e) Capacitance of the tap winding to ground or grounded adjacent windings (if exist) (C_e)
- f) Voltage stress across half the tap winding at lightning impulse voltage test
- g) A.C.voltage across half the tap winding under operation and test conditions.(Normally derived from order specification sheet for tap changer)




Fig.7 Potential Connection by Tie-In Resistor R_p





Fig.8 Arrangement of Winding and Coupling Capacitance

5.2 Special CM2 OLTC combinations ($3 \times \text{CM2I}$ or $\text{CM2I} + \text{CM2II}$), driven by one or separated motor drive units and used for delta connection of windings or others except neutral point.


Fig.9 Connection Diagram for Multiple CM OLTC Applications

6. Motor drive unit

CM2 OLTC may operated by SHM-III or CMA7 motor drive unit according to the requirement, please refer to Table 4 for technical data.

Table 4 Technical Data of Motor Drive Unit

Motor drive unit		SHM-III		CMA7	
Motor	Rated power (W)	750	1100	750	1100
	Rated voltage (V)	380,3AC/N		380/3AC	
	Rated current (A)	2.1	2.8	2.0	2.8
	Rate frequency(Hz)	50 or 60		50 or 60	
	Rotate speed (r.p.m.)	1400		1400	
Rated torque on drive shaft (Nm)		45	66	18	26
Revolution of the drive shaft per switching operation		33		33	
Revolution of the hand crank per switching operation		33		33	
Running time per switching operation (S)		5.6		About 5	
Max. operation positions		35		107	
Voltage for control circuit and heater circuit (V)		220/AC		220/AC	
Heater power (W)		50		50	
A.C. voltage test to ground (kV/50Hz, 1min)		2		2	
Approx. weight (kg)		73		90	
Protective degree		IP66		IP56	
Mechanical endurance (operations)		Not less than 2,000,000		Not less than 800,000	

Note: Please specify if special voltage required for motor, and control & heater circuit.

7. Controllers for On-Load tap changer

7.1 HMK8 controller

HMK8 controller is the device for remote control of SHM-III motor drive unit; it realizes OLTC switching operation through SHM-III. HMK8 can display the OLTC switching operation status and tap positions.

HMK8 has BCD code position signal output (contact capacity: AC250V/5A or DC30V/5A) and remote control signal input (non potential contact), it can also communicate with host computer via RS485 interface to realize remote supervising of OLTC position.

HMK8 main technical data is as below, refer to HMK8 manual for more details.

Working voltage: 380V, 3AC/N

Power frequency: 50Hz/60Hz

Maximum operation positions: 35

Environment temperature: -10°C to 40°C Indoor

7.2 HMC-3C position indicator

HMC-3C OLTC position indicator is a support fitting for CMA7 and CMA9 motor drive unit, it can be used to indicate the OLTC step, and has the function of "1-N", "STOP", "N-1" control as well as remote control indicator lamp, its input is decimal code and output is BCD code. Please refer to HMC-3C manual for details.

HMC-3C technical data is as below, refer to manual for more details.

Working voltage: 220V AC

Power frequency: 50/60Hz

Maximum operation positions: 107

Environment temperature: -10°C to 40°C Indoor

7.3 Automatic voltage regulator ET-SZ6 and HMK-2A

Automatic voltage regulator ET-SZ6 and HMK-2A is adopted for OLTC automatic voltage regulation, ET-SZ6 can be used for parallel operation in model of master and slave, please refer to relevant manual for details.

If you have any special technical requirements of above controller, please specify when ordering.

8. OLTC accessories


8.1 Bevel gear unit

Bevel gear unit is used for connection horizontal shaft and vertical shaft between OLTC body and motor drive unit, thus driving torque of motor drive unit can be transmitted to on-load tap changer, the overall dimensions of bevel gear unit is shown on appendix 9.25

8.2 Protective relay

Protective relay is the one of protective devices for oil-immersed on-load tap changer, when OLTC interior failure produces gas and oil surge, the protective relay contact acts, and switches on to the tripping circuit of the transformer circuit breaker, the transformer will be cut off at once.

Protective relay is mounted onto the connection pipe between OLTC head and conservator; make sure that protective relay marked with arrowhead side shall be connected to conservator. Huaming provides two types of protective relay which are QJ4-25 and QJ4-25 A, both of them have gas signal contact and trip contact, especially QJ4-25A can be equipped gas release device to man position. Please refer to Appendix.



8.3 Pressure relief devices


Pressure relief valve and pressure release cover is the security protective device for oil-immersed OLTC, when any failure happens inside the OLTC, oil in oil chamber is gasified to produce plenty of gas, thus oil pressure of oil chamber is increased rapidly, OLTC oil compartment will be deform or even explode if the pressure inside is not released in time, therefore, pressure relief device is necessary be installed to avoid failures extending.

Pressure relief valve is an auto-sealed valve, when over pressure, the cover is open and pressure will be released, and then it will close again. It can be used repeatedly, and the liquid loss could be controlled to be minimum volume when it is acting.


Pressure release cover is the weak portion on the OLTC head cover, once oil chamber pressure exceeds adjusted value, the pressure release cover will be broken, thus over-pressure is released, and OLTC oil compartment is protected.

Pressure relief valve is a device for low energy failure, and pressure release cover is the device for high energy failure, whereas most of failure of OLTC body is of high energy failure, so our standard offer is OLTC equipped with pressure release cover, and pressure relief valve is only provided when customer specifies.

9. Appendixes

9.1. CM2 III 500Y/600Y without change-over selector, overall dimensions


Model	CM2 III 500Y/600Y-72.5-252/B				CM2 III 500Y/600Y-72.5-252/C				CM2 III 500Y/600Y-72.5-252/D/DE			
U_m in kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252
h	1897	2027	2157	2257	2072	2202	2332	2432	2527	2657	2767	2887
i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
k			897				1072				1527	
n			233				258				323	
o			190				240				370	
t			95				120				185	
m			197				247				377	
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190
Displacement (dm ³)	194	219	239	259	195	220	240	260	198	223	243	263
Weight (kg)			260				265				275	


9.2. CM2 III 500Y / 600Y with reversing switch, overall dimensions


(A) Current take-off terminal

(L) Potential connection (only for OLTC with reversing switch and 3 middle positions such as 10193W...18353W)

Model	CM2 III 500Y/600Y-72.5-252/B				CM2 III 500Y/600Y-72.5-252/C				CM2 III 500Y/600Y-72.5-252/D/DE			
U_m in kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252
h	1897	2027	2157	2257	2072	2202	2332	2432	2527	2657	2787	2887
i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
k		897				1072				1527		
n		233				258				323		
o		190				240				370		
t		95				120				185		
m		197				247				377		
r		190				240				370		
q		255				305				435		
p		783				958				1413		
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190
Displacement (dm ³)	199	224	244	264	200	225	245	265	207	232	252	272
Weight (kg)		275				285				310		

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA


9.3. CM2 III 500Y / 600Y with coarse change-over selector, overall dimensions


Ⓐ Current take-off terminal

Model	CM2 III 500Y/600Y-72.5-252/B				CM2 III 500Y/600Y-72.5-252/C				CM2 III 500Y/600Y-72.5-252/D(DE)				
	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252	
U _m In kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252	
Dimensions (mm)	h	1897	2027	2157	2257	2072	2202	2332	2432	2527	2657	2787	2887
	l	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
	k			897				1072				1527	
	n			233				258				323	
	o			190				240				370	
	t			95				120				185	
	m			197				247				377	
	r			190				240				370	
	q			276.5				301.5				366.5	
	p			892				1067				1522	
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190	
Displacement (dm ³)	199	224	244	264	199	224	244	264	207	232	252	272	
Weight (kg)			275				280				305		

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA


Unit: mm

9.4. CM2 II 500 / 600 without change-over selector, overall dimensions



(A) Current take-off terminal

Model	CM2II500/600-72.5-252/B				CM2II500/600-72.5-252/C				CM2II500/600-72.5-252/D/DE				
U_m in kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252	
Dimensions (mm)	h	1707	1837	1967	2067	1832	1962	2092	2192	2157	2287	2417	2517
	i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
	k	707				832				1157			
	n	233				258				323			
	o	190				240				370			
	t	95				120				185			
	m	197				247				377			
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190	
Displacement (dm ³)	194	219	239	259	195	220	240	260	198	223	243	263	
Weight (kg)	260				265				275				

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

9.5. CM2 II 500 / 600 with reversing switch, overall dimensions



Model	CM2 II 500/600-72.5-252/B				CM2 II 500/600-72.5-252/C				CM2 II 500/600-72.5-252/D(E)				
	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252	
U _m in kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252	
Dimensions (mm)	h	1707	1837	1987	2067	1832	1962	2092	2192	2157	2287	2417	2517
	i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
	k		707				832				1157		
	n		233				258				323		
	o		190				240				370		
	t		95				120				185		
	m		197				247				377		
	r		190				240				370		
	q		255				305				435		
	p		783				958				1413		
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190	
Displacement (dm ³)	199	224	244	264	200	225	245	265	207	232	252	272	
Weight (kg)		275				285				310			

9.6. CM2 II 500 / 600 with coarse change-over selector, overall dimensions


(A) Current take-off terminal


Model	CM2 II 500/600-72.5-252/B				CM2 II 500/600-72.5-252/C				CM2 II 500/600-72.5-252/D(DE)				
U_m in kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252	
Dimensions (mm)	h	1707	1837	1967	2067	1832	1962	2092	2192	2157	2287	2417	2517
	l	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
	k	707				832				1157			
	n	233				258				323			
	o	190				240				370			
	t	95				120				185			
	m	197				247				377			
	r	190				240				370			
	q	276.5				301.5				366.5			
	p	892				1067				1622			
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190	
Displacement (dm ³)	199	224	244	264	199	224	244	264	207	232	252	272	
Weight (kg)	275				280				305				

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

9.7. CM2 I 500 / 600 without change-over selector, overall dimensions


(A) Current take-off terminal


Model	CM2 I 500/600-72.5-252/B				CM2 I 500/600-72.5-252/C				CM2 I 500/600-72.5-252/D(DE)				
U_m in kV	72.5	128	170	252	72.5	128	170	252	72.5	128	170	252	
Dimensions (mm)													
h	1517	1647	1777	1877	1592	1722	1852	1952	1787	1917	2047	2147	
i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360	
k			517				592				787		
n			233				258				323		
t			95				120				185		
m			102				127				192		
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190	
Displacement (dm ³)	189	214	234	254	189	214	234	254	190	215	235	255	
Weight (kg)			240				240				245		

9.8. CM2 I 500 / 600 with reversing switch, overall dimensions


- (A) Current take-off terminal
- (L) Potential connection (only for OLTC with reversing switch and 3 middle positions such as 10193W...18353W)


Model	CM2 I 500/600-72.5-252/B				CM2 I 500/600-72.5-252/C				CM2 I 500/600-72.5-252/D(DE)			
U _m in kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252
h	1517	1647	1777	1877	1592	1722	1852	1952	1787	1917	2047	2147
i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
k	517				592				787			
n	233				258				323			
m	102				127				192			
t	95				120				185			
q	160				185				250			
p	403				478				673			
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190
Displacement (dm ³)	191	216	244	264	192	217	237	257	193	218	238	258
Weight (kg)	250				255				260			

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

9.9. CM2 I 500 / 600 with coarse change-over selector, overall dimensions



(A) Current take-off terminal

Model		CM2 I 500/600-72.5-252/B				CM2 I 500/600-72.5-252/C				CM2 I 500/600-72.5-252/D(DE)			
U _m in kV		72.5	126	170	252	72.5	126	170	252	72.5	126	170	252
Dimensions (mm)	h	1517	1647	1777	1877	1592	1722	1852	1952	1787	1917	2047	2147
	i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
	k	517				592				787			
	n	233				258				323			
	m	102				127				192			
	t	95				120				185			
	q	276.5				301.5				366.5			
	p	512				587				782			
Oil filling (dm ³)		130	150	170	190	130	150	170	190	130	150	170	190
Displacement (dm ³)		193	218	238	258	193	218	238	258	195	220	240	260
Weight (kg)		260				260				285			

9.10. CM2 I 800 without change-over selector, overall dimensions


(A) Current take-off terminal


Model	CM2 I 800-72.5-252/B				CM2 I 800-72.5-252/C				CM2 I 800-72.5-252/D(DE)				
U _m in kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252	
Dimensions (mm)	h	1702	1832	1962	2062	1777	1907	2037	2137	1972	2102	2232	2332
	i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
	k			702				777				972	
	n			233				258				323	
	o			95				120				185	
	m			102				127				192	
	t1			105				105				105	
	t2			80				80				80	
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190	
Displacement (dm ³)	191	216	236	256	191	216	236	256	193	218	238	258	
Weight (kg)			250				250				260		

9.11. CM2 I 800 with reversing switch, overall dimensions


(A) Current take-off terminal

(L) Potential connection (only for OLTC with reversing switch and 3 middle positions such as 10193W...18353W)


Model	CM21800-72.5-252/B				CM21800-72.5-252/C				CM21800-72.5-252/D(DE)				
	U _m in kV												
Dimensions (mm)	h	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252
	i	1702	1832	1962	2062	1777	1907	2037	2137	1972	2102	2232	2332
	k	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
	n		702				777				972		
	o		233				258				323		
	m		95				120				185		
	l1		102				127				192		
	l2		105				105				105		
	r		80				80				80		
	q		105				105				105		
	p		160				185				250		
			588				663				858		
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190	
Displacement (dm ³)	195	220	240	260	196	221	241	261	199	224	244	264	
Weight (kg)		265				270				275			

9.12. CM2 I 800 with coarse change-over selector, overall dimensions


(A) Current take-off terminal


Model	CM2 I 800-72.5-252/B				CM2 I 800-72.5-252/C				CM2 I 800-72.5-252/D(DE)				
	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252	
U_m in kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252	
Dimensions (mm)	h	1702	1832	1982	2062	1777	1907	2037	2137	1972	2102	2232	2332
	l	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
	k		702				777				972		
	n		233				258				323		
	o		95				120				185		
	m		102				127				192		
	t1		105				105				105		
	t2		80				80				80		
	r		105				105				105		
	q		276.5				301.5				366.5		
	p		697				772				967		
	Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190
Displacement (dm ³)	196	221	241	261	196	221	241	261	199	224	244	264	
Weight (kg)		270				270				280			

Unit: mm

9.13. CM2 I 1200 / 1500 without change-over selector, overall dimensions



(A) Current take-off terminal

Model		CM2 I 1200/1600-72.5-252/B				CM2 I 1200/1600-72.5-252/C				CM2 I 1200/1500-72.5-252/D(DE)			
U _m in kV		72.5	128	170	252	72.5	128	170	252	72.5	128	170	252
Dimensions (mm)	h	1887	2017	2147	2247	1962	2092	2222	2322	2157	2287	2417	2517
	l	1000	1130	1260	1360	1000	1130	1280	1360	1000	1130	1260	1360
	k	887				962				1157			
	n	233				258				323			
	o	95				120				185			
	t1	105				105				105			
	t2	80				80				80			
m	102				127				192				
Oil filling (dm ³)		130	150	170	190	130	150	170	190	130	150	170	190
Displacement (dm ³)		194	219	239	259	194	219	239	269	195	221	241	261
Weight (kg)		260				260				270			

9.14. CM2 I 1200 / 1500 with reversing switch, overall dimensions



Model	CM2 I 1200/1500-72.5-252/B				CM2 I 1200/1500-72.5-252/C				CM2 I 1200/1500-72.5-252/D(DE)			
U _m In kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252
h	1887	2017	2147	2247	1962	2092	2222	2322	2157	2287	2417	2517
i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
k		887				962				1157		
n		233				258				323		
o		95				120				185		
l1		105				105				105		
l2		80				80				80		
m		102				127				192		
r		105				105				105		
q		160				185				250		
p		773				848				1043		
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190
Displacement (dm ³)	199	224	244	264	200	225	245	265	202	227	247	267
Weight (kg)		280				280				290		

Unit: mm

9.15. CM2 I 1200 / 1500 with coarse change-over selector, overall dimensions



(A) Current take-off terminal

Model	CM2 I 1200/1500-72.5-252/B				CM2 I 1200/1500-72.5-252/C				CM2 I 1200/1500-72.5-252/D (DE)			
U_m in kV	72.5	126	170	252	72.5	126	170	252	72.5	126	170	252
h	1887	2017	2147	2247	1962	2092	2222	2322	2157	2287	2417	2517
i	1000	1130	1260	1360	1000	1130	1260	1360	1000	1130	1260	1360
k	887				982				1157			
n	233				258				323			
o	95				120				185			
t1	105				105				105			
t2	80				80				80			
m	102				127				192			
r	105				105				105			
q	278.5				301.5				368.5			
p	882				957				1152			
Oil filling (dm ³)	130	150	170	190	130	150	170	190	130	150	170	190
Displacement (dm ³)	200	225	245	265	200	225	245	265	204	229	249	269
Weight (kg)	285				285				295			


9.16. CM2 OLTC mounted with tie-in resistor, overall dimensions


h—the OLTC height excluding tie-in resistor.
 Special design may depend on the requirement
















TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA




9.17. CM2 OLTC General layout Drawing (With insulated bottom)







1. The dimension 140 is that with insulation bottom.
2. With insulation bottom, the total height of OLTC will increase by 53mm.
3. Models with insulation bottom only for 10 pitch.


9.18. CM2 tap selector contacts arrangement


9.19. CM2 OLTC head flange for standard tank type, overall dimensions






I: Magnified figure


 R
Connection pipe flange

 S, Q (With groove)
Connection pipe flange


- E1: Bleeding for on-load tap changer
- E2: Bleeding for transformer oil tank
- R: Connection flange for protective relay
- S: Connection flange for oil suction pipe
- Q: Connection flange for oil return pipe

9.20. CM2 OLTC head flange with pressure relief valve, overall dimensions



1: Magnified figure


 S, Q (With groove)
Connection pipe flange


TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

- E1: Bleeding for on-load tap changer
- E2: Bleeding for transformer oil tank
- R: Connection flange for protective relay
- S: Connection flange for oil suction pipe
- Q: Connection flange for oil return pipe



**9.21. CM2 OLTC head flange with pressure relief valve,
overall dimensions(with raised seat)**



E1: Bleeding for on-load tap changer
 E2: Bleeding for transformer oil tank
 R: Connection flange for protective relay
 S: Connection flange for oil suction pipe
 Q: Connection flange for oil return pipe

[Handwritten signature]

9.22. Transformer connection flange for CM2 OLTC, overall dimensions





TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA


Unit: mm

[Handwritten signature]

[Handwritten signature]



9.23. CM2 OLTC head flange installation for bell-type, overall dimensions

9.24. Upper gear unit, arrangement and swiveling range





Drive shaft left output, with pressure relief valve, swiveling range

Drive shaft right output, with pressure relief valve, swiveling range




Drive shaft left output, with elevated holder for pressure relief valve, swiveling range

Drive shaft right output, with elevated holder for pressure relief valve, swiveling range




SR: Inspection window on the right
 SL: Inspection window on the left
 V: Tap selector driving side

Unit: mm


9.25-1. CM2 OLTC arrangement drawing-1


Item	Dimensions		
	H1>	H2>	H3>
Mln. mechanical size	535	515	840

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA



9.25-2. CM2 OLTC arrangement drawing-2

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

Item	Dimensions		
	H1>	H2>	H3>
Min. mechanical size	535	515	840

9.26. CM2 OLTC, general layout drawing


- | | |
|------------------------------------|--|
| A: Tap selector | G: Bevel gear unit |
| B: Diverter switch oil compartment | H: Vertical drive shaft |
| C: Pipe connections (R,S,Q,E2) | I: Intermediate bearing (applied when shaft > 2000mm only) |
| D: Tap changer head cover | J: Motor drive unit |
| E: Upper gear unit | V: Driving side of tap selector |
| F: Horizontal drive shaft | |




9.27. Bevel gear unit, overall & installation dimensions




TYPE CH2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

Unit: mm


**9.28. CM2 I 800 / 1200 / 1500 OLTC,
parallel connection plate of tap selector terminals, overall dimensions**



Connection plate



CM2I 800 contacts connection drawing




CM2I 1200/1500 contacts connection drawing




9.29. Protective relay, overall & installation dimensions

Type QJ4-25A protective relay



Type QJ4-25 protective relay




Model	D	D1	D2	D3	D4	d1	H1	H2	L1	L2	Note
QJ4-25A	25	35	65	85	115	14	215	153	208	200	1 pair of gas signal and 1 pair of trip signal, gas release device connected to main position
QJ4-25	25	35	65	85	115	14	215	153	208	200	1 pair of gas signal and 1 pair of trip signal

Unit: mm




HMO.154.5701

9.30. CM2(10070) operating position table and connection diagram



Operation position number	7
Different voltage number	7
Set position ●	4

Tap selector contact position	1	2	3	4	5	6	7
Display position	1	2	3	4	5	6	7


9.31. CM2(10090) operating position table and connection diagram


Operation position number	9
Different voltage number	9
Set position ●	5

Tap selector contact position	1	2	3	4	5	6	7	8	9
Display position	1	2	3	4	5	6	7	8	9

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

● Drawing is shown at the set position


9.32. CM2(10071W) operating position table and connection diagram


Please connect terminal 1 and "+", 4 and "+", 2 and 2, 3 and 3 in the same phase.

Operation position number	7
Different voltage number	7
Set position ●	4

Change-over selector location	← K+ → ← K- →						
Tap changer position	1	2	3	4	5	6	7
Tap selector contact position	1	2	3	K	2	3	4
Display position	1	2	3	4	5	6	7

9.33. CM2(10091W) operating position table and connection diagram



Please connect terminal 1 and "-", 5 and "+", 2 and 2, 3 and 3, 4 and 4 in the same phase.


Operation position number	9
Different voltage number	9
Set position ●	5

Change-over selector location	← K+ →				← K- →				
	Tap changer position	1	2	3	4	5	6	7	8
Tap selector contact position	1	2	3	4	K	2	3	4	5
Display position	1	2	3	4	5	6	7	8	9




TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

● Drawing is shown at the set position

9.34. CM2(10191W) operating position table and connection diagram


Operation position number	19
Different voltage number	19
Set position ●	10

Change-over selector location	K+									K-									
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
Tap selector contact position	1	2	3	4	5	6	7	8	9	K	1	2	3	4	5	6	7	8	9
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19

9.35. CM2(10193W) operating position table and connection diagram



Operation position number	19
Different voltage number	17
Set position •	9b

Change-over selector location	K+									K-									
	Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Tap selector contact position	1	2	3	4	5	6	7	8	9	K	1	2	3	4	5	6	7	8	9
Display position	1	2	3	4	5	6	7	8	9a	9b	9c	10	11	12	13	14	15	16	17

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

• Drawing is shown at the set position

9.36. CM2(10191G) operating position table and connection diagram




Operation position number	19
Different voltage number	19
Set position ●	10

Change-over selector location	0+									0-									
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
Tap selector contact position	1	2	3	4	5	6	7	8	9	K	1	2	3	4	5	6	7	8	9
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

● Drawing is shown at the set position





9.37. CM2(10193G) operating position table and connection diagram


Operation position number	19
Different voltage number	17
Set position •	9b

Change-over selector location	0+									0-									
	Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Tap selector contact position	1	2	3	4	5	6	7	8	9	K	1	2	3	4	5	6	7	8	9
Display position	1	2	3	4	5	6	7	8	9a	9b	9c	10	11	12	13	14	15	16	17

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

9.38. CM2(12110) operating position table and connection diagram



9.39. CM2(12111W) operating position table and connection diagram


Please connect 1 and "-", 6 and "+", 2 and 2, 3 and 3, 4 and 4, 5 and 5 in the same phase.

Operation position number	11
Different voltage number	11
Set position ●	6


Change-over selector location	K+					K-					
	Tap changer position	1	2	3	4	5	6	7	8	9	10
Tap selector contact position	1	2	3	4	5	K	2	3	4	5	6
Display position	1	2	3	4	5	6	7	8	9	10	11

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

9.40. CM2(12233W) operating position table and connection diagram


Operation position number	23
Different voltage number	21
Set position *	11b


Change-over selector location	K+											K-											
	Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	K	1	2	3	4	5	6	7	8	9	10	11
Display position	1	2	3	4	5	6	7	8	9	10	11a	11b	11c	12	13	14	15	16	17	18	19	20	21

9.41. CM2(12233G) operating position table and connection diagram


Operation position number	23
Different voltage number	21
Set position ●	11b

Change-over selector location	0 +											0 -											
Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	K	1	2	3	4	5	6	7	8	9	10	11
Display position	1	2	3	4	5	6	7	8	9	10	11a	11b	11c	12	13	14	15	16	17	18	19	20	21


TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

9.42. CM2(14130) operating position table and connection diagram


Operation position number	13
Different voltage number	13
Set position ●	7

Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	12	13
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13

9.43. CM2(14131W) operating position table and connection diagram




Please connect 1 and "7", 7 and "+", 2 and 2, 3 and 3, 4 and 4, 5 and 5, 6 and 6 in the same phase.

Operation position number	13
Different voltage number	13
Set position ●	7

Change-over selector location	K+						K-						
Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13
Tap selector contact position	1	2	3	4	5	6	K	2	3	4	5	6	7
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA


● Drawing is shown at the set position

9.44. CM2(14273W) operating position table and connection diagram


Operation position number	27
Different voltage number	25
Set position ●	13b

Change-over selector location	K+													K-													
	Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	12	13	K	1	2	3	4	5	6	7	8	9	10	11	12	13
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13a	13b	13c	14	15	16	17	18	19	20	21	22	23	24	25

9.45. CM2(14273G) operating position table and connection diagram




Operation position number	27
Different voltage number	25
Set position *	13b

Change-over selector location	0+													0-													
	Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	12	13	K	1	2	3	4	5	6	7	8	9	10	11	12	13
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13a	13b	13c	14	15	16	17	18	19	20	21	22	23	24	25

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

* Drawing is shown at the set position




9.46. CM2(16150) operating position table and connection diagram


Operation position number	15
Different voltage number	15
Set position ●	8

Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15

9.47. CM2(16151W) operating position table and connection diagram




Please connect 1 and "L", 8 and "+", 2 and 2, 3 and 3, 4 and 4, 5 and 5, 6 and 6, 7 and 7 in the same phase.

Operation position number	15
Different voltage number	15
Set position ●	8

Change-over selector location	K+							K-							
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Tap changer position	1	2	3	4	5	6	7	K	2	3	4	5	6	7	8
Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

9.48. CM2(16313W) operating position table and connection diagram




Operation position number	31
Different voltage number	29
Set position ●	15b

Change-over selector location	K+															K-															
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	K	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15a	15b	15c	16	17	18	19	20	21	22	23	24	25	26	27	28	29

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

● Drawing is shown at the set position


9.49. CM2(16313G) operating position table and connection diagram


Operation position number	31
Different voltage number	29
Set position ●	15b

Change-over selector location	0+																0-														
	Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	K	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15a	15b	15c	16	17	18	19	20	21	22	23	24	25	26	27	28	29


TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

● Drawing is shown at the set position

9.50. CM2(18170) operating position table and connection diagram


Operation position number	17
Different voltage number	17
Set position ●	9

Tap selector contact position	1	2	3	4	5	6	6	7	8	9	10	11	12	13	14	15	16	17
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	


9.51. CM2(18171W) operating position table and connection diagram


Please connect 1 and "9 and "+", 2 and 2, 3 and 3, 4 and 4, 5 and 5, 6 and 6, 7 and 7, 8 and 8 in the same phase.

Operation position number	17
Different voltage number	17
Set position ●	9

Change-over selector location	K+									K-							
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Tap selector contact position	1	2	3	4	5	6	7	8	K	2	3	4	5	6	7	8	9
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

9.52. CM2(18353W) operating position table and connection diagram



Operation position number	35
Different voltage number	33
Set position •	17b

Change-over selector location	K+																	K-																	
	Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34
Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	k	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17a	17b	17c	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

• Drawing is shown at the set position

9.53. CM2(18353G) operating position table and connection diagram



Operation position number	35
Different voltage number	33
Set position ●	17b

Change-over selector location	0+																	0-																	
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35
Tap changer position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	k	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Tap selector contact position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	k	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Display position	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17a	17b	17c	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33

TYPE CM2 VACUUM ON-LOAD TAP CHANGER TECHNICAL DATA

● Drawing is shown at the set position



SHANGHAI HUAMING POWER EQUIPMENT CO., LTD.

Address: 977 Tong Pu Road, Shanghai, P.R.China 200333

Tel: +86 21 5270 3965(direct)

+86 21 5270 8966 Ext.


8688/8123/8698/8158/8110/8658

Fax: +86 21 5270 2715

Web: www.huaming.com

E-mail: export@huaming.com

Printing: FEB.2010







ETRA 33
ENERGETSKI
TRANSFORMATORJI, d.o.o.

OIL TEMPERATURE INDICATOR - AKM


PNA-6.40.31

Revision: 1

Date: 1. 8. 2005



CONTACT DIAGRAM:



CHARACTERISTICS

1. TYPE: AKM 34 4 01 15 - 6.0
2. PROTECTION MODE: IP -65
3. SWITCHING ELEMENT: 4 CHANGE-OVER SWITCHES
4. BREAKING CAPACITY: 15A, 250V, 40-60Hz
5. INSULATION TEST: AC 2.0kV, 1min




ETRA 33
ENERGETSKI
TRANSFORMATORJI, d.o.o.

WINDING TEMPERATURE INDICATOR - AKM


PNA-6.40.41

Revision: 2

Date: 3. 4. 2006



CONTACT DIAGRAM:



CHARACTERISTICS:

1. TYPE: AKM 35 4 01 15 - 6.0
2. PROTECTION MODE: IP -65
3. SWITCHING ELEMENT: 4 CHANGE-OVER SWITCHES
4. BREAKING CAPACITY: 15 A, 250 V, 40-60 Hz
5. INSULATION TEST: AC 2.0 kV, 1min




KOLEKTOR
KOLEKTOR ETRA s.p.a.

OIL LEVEL INDICATORS type LA and LB

PNA-6.40.17

Revision: 3

Date: 20.03.2013




Oil level indicator type LA

Oil level indicator type LB

TECHNICAL SPECIFICATION

Standard specification	EN 50216-5
Indicator type	Level gauge with magnetic joint
Dial size	Ø140 mm, Ø220 mm or Ø340 mm
Min / Max level	Dial shows all red / Dial shows all white
Reference marks	-20°C, +20°C, +85°C, special marks available on request
Breaking capacity	3 A, 125/250 V AC (resistive) 0.5 A, 125 V DC (inductive load) 0.25 A, 250 V DC (inductive load)
Cable gland	M25x1,5 mm
Insulation test	2.5 kV AC, 50/60 Hz, 1 min
Degree of protection	IP 55
Ambient temperature	Between -25 °C and +60°C
Manufacturer	COMEM, Italy

Wiring Diagrams



Scheme X

1 contact on min. level
1 contact on max. level

Scheme W

2 contacts on min. level
2 contacts on max. level

Scheme Y

2 contacts on min. level

Scheme K

1 contact on min. level



KOLEKTOR
KOLEKTOR ETRA d.o.o.

DEHYDRATING BREATHERS COMEM type: DA, DB and 1MB

PNA-6.40.63

Revision: 3

Date: 11. 03. 2013




Fig. 1: Dehydrating breathers types DA and DB

Fig. 2: Dehydrating breather type 1MB

Code	Max. oil quantity (ton)	Silicagel		Dimensions (mm)									Weight (kg)	
		(dm ³)	(kg)	L	L1	D1	H	Ø	R	F	G	D	Type DA	Type DB
2	2	0,95	0,76	265	210	30	12	100	75	12	G 1"	140	3	2,7
3	6	2,75	2,2	360	310	44	14	130	100	14	G 1 1/2"	175	5,4	4,95
4	15	6,5	5,2	610	560	44	14	130	100	14	G 1 1/2"	175	9,35	8,75
5	30	13,3	10,6	675	625	57	15	140	110	14	G 2"	220	16,7	16,5
6	40	19	15,2	895	845	57	15	140	110	14	G 2"	220	22,5	22,2

Table 1: Dehydrating Breathers types DA and DB

Code	Max. oil quantity (ton)	Silicagel (dm ³)	Silicagel (kg)	Weight (kg)
1MB	1,4	0,47	0,38	1,15

Table 2: Dehydrating breather type 1MB

Description


Dehydrating breathers are used to absorb moisture from the air drawn into transformers due to thermal contraction of the oil and prevents its contamination by moisture. The breathers contain silicagel (silicon dioxide) in granular form, which is able to absorb about 35-40% of its own weight of water. When the silicagel is saturated with moisture, its colour changes. As the half of the quantity of the silicagel is saturated, it should be replaced by dry granules. The colour variations are shown on label on the dehydrator.

The upper and lower parts of the dehydrator consist of compact, corrosion-proof aluminium castings. The transparent tube containing silicagel is made of polycarbonate, resistant to oil, UV light and tropical as well as marine climates. For mechanical protection, the tube is protected by a stainless steel cylinder with openings allowing visual inspection of the silicagel. The closing system at the bottom prevents constant air contacts with the silicagel. This closing system can be hydraulic (DA and DB types) or mechanical (1MB type), and it allows air passage in both directions only when there is a different pressure inside and outside the transformer (300 Pa for inlet air and 500 Pa for outlet air).

PNA 6_40_63

Izdelač I. Jerman

Sheet 1/1






ETRA 33
ENERGETSKI
TRANSFORMATORJI, d.o.o.

CONTROL VALVES OF THE INTERNAL PRESURE OF TANKS COMEM



PNA-6.40.23

Revision: 4

Date: 26. 2. 2009



Tip	50T	80T	125T
A	14	16	16
B	4	4	5
C max	74	110	120
D	∅49	∅80	∅125
D1	∅165	∅200	∅278
D2	∅125	∅160	∅210
D3	∅106	∅143	∅190
D4	∅85	∅117	∅164
D5	∅99	∅131	∅182
D6	4x∅18	4x∅18	8x∅18
E	130	140	210
F max	16	32	62
G	∅62	∅100	∅155
I	∅175	∅210	∅288



IP 66

Breaking capacity:
voltage 230 V AC
current 2 A
 $\cos \varphi > 0,5$

voltage 24–220 V DC
current 2 A
breaking capacity:
100 mA L/R < 40 ms

Test voltage: 2 kV AC, 1 min




ETRA 33
ENERGETSKI
TRANSFORMATORJI, d.o.o.

BUCHOLZ RELAYS COMEM

PNA-6.40.52

Revision: 1



Date: 1. 8. 2005



CHARACTERISTICS:

1. PROTECTION MODE: IP-55
2. OIL VELOCITY: 100 cm/sec (operating of trip contact)
3. SWITCHING ELEMENT: 2 CONTACTS
4. CONTACT TYPE: A (normally open)
5. BREAKING CAPACITY: 2 A, 250 V, AC $\cos \phi$ 0.4±25%
: 2 A, 250 V, DC L/R=40 ms ±15%
6. INSULATION TEST: AC 2.0 kV, 1 min

TYPE	a	b	d	d1	d2	d4	mass [kg]
BR50	250	168	50	125	165	102	3.7
BR80	303	193	80	160	200	138	4.8



LumaSMART

**Fluoroptic-Based Winding Hot Spot Temperature
Sensor for Generation, Transmission and
Distribution Transformers**

LumaSMART is the fifth generation Fluoroptic®-based thermometry system from LumaSense. By providing direct and real-time winding hotspot measurements, utilities can:

- Implement Dynamic Loading
- Extend the Life of Transformers
- Reduce Costly Failures
- Maximize Safe Performance

Exceptional Reliability and Accuracy in Winding Hot Spots Temperature Monitoring

LumaSense Technologies' LumaSMART winding hot spot temperature system is the most advanced and reliable real-time monitoring solution available today. LumaSense is the leader in Fluoroptic® (FOT) Technology, with decades of proven expertise. The LumaSMART FOT hot spot monitoring systems provide accurate, real-time temperature readings for protection and control of your critical power transformer assets.


LumaSense's PFA teflon-jacketed Fluoroptic probes are considered the standard in the industry. Featuring five-layer protection in their fiber optic encapsulation for 99% installation success, they are specially designed to withstand harsh environments without deteriorating physically or affecting the accuracy of the temperature measurement.

LumaSense Technologies' LUXTRON brand is the world leader in fiber optic temperature measurement in transformers. With more than 30 years of fiber optic experi-

ence, LumaSense continues to lead the way in innovation of new, robust technology.

Measuring Hot Spot Winding Temperature
Transformers often take the brunt of an overload condition. Monitoring the transformer winding hot spot is critical to safeguard your transformer from damage and extend its usage. Transformer life is directly related to the life of the internal paper insulation. The insulating paper's life is directly affected by its exposure to high temperature. The highest temperature on the windings is the Winding Hot Spot, where the insulating paper will deteriorate first. Conventional methods simulate or calculate this temperature, but do not accurately measure it. The only true way of knowing the actual temperature is through real-time fiber optic measurement. Our reliable, accurate monitors quickly detect and respond to hot spot conditions, triggering alarms and relays to protect your most valuable assets.

Smart Grid Power Transformer Hot Spots Temperature Monitoring




The Multi-Channel Controller System Should Include:

- LumaSMART Multi-Channel Smart Controller
- Fluoroptic Probes
 - Quality Probes
 - DipTip Rugged Probes
- Extension Cables
 - Single Fiber Extension
 - Four-Fiber Extension
- Tank Wall Feedthrough Plate Assembly
 - Stainless Steel Bolted Plate
 - Individual Tank Wall Feedthroughs
- Optional Accessories
 - NEMA 4 Enclosure
 - WEIDMANN-Certified SmartSacers™
 - NEMA 12 Tank Wall Cover Box
 - Internal and External Plug Assemblies
 - LUXTRON 812 Handheld Unit



The LumaSMART Controller




LumaSense Technologies' LumaSMART controller is the newest innovation from the leader in FOT technology. Building on the proven performance of the ThermAsset2, this monitor provides all of the capabilities of its predecessor while adding smart grid capabilities, an innovative touch screen and extended channel and relay capabilities.

- Easily adaptable to user-specific needs with 4 to 16 channels and 0, 8 or 16 Form-C programmable relays
- $\pm 2^{\circ}\text{C}$ accuracy over the entire temperature range for the life of transformer with no calibration
- No drift, no calibration required
- Analog outputs and Modbus, DNP3, ASCII and IEC61850 communication capability standard
- RS-232C and RS-485, Ethernet and USB serial outputs
- Light source lasts the life of the transformer
- Interactive touch screen display for alarms, notifications and set-up
- Equipped with 2GB standard data storage for transformer lifetime memory storage
- On-board diagnostics troubleshooting guidance

Fluoroptic Probes

The measurement performance of LUXTRON probes exceeds common temperature sensors in environments with high voltage, radio frequency interference (RFI), electromagnetic interference (EMI) or corrosive and above boiling point liquids. Our robust probes are designed for ease of installation and have a greater than 99% installation success rate.




- Industry standard LUXTRON Quality Probes™ and DipTip Rugged Probes™
- Viton O-ring connector for protection against leaks
- PFA Teflon®-jacketed design with Kevlar® construction
- Immune to RF and EMI and Electrically Non-Conductive
- Most robust, well-built fiber optic probes on the market
- Insulated with five layers for superior protection
- DipTip Rugged Probes don't require double installations

- Dielectrically tested to ensure safe, accurate performance
- Chemically inert and compatible with many aggressive chemicals
- Intrinsically safe, stable and drift-free
- Available in various lengths (1m to 16m standard)

WEIDMANN-Certified SmartSpacers™

Our sensor tips can be supplied with WEIDMANN-certified SmartSpacers. All WEIDMANN-certified components including adhesives and assemblies meet strict manufacturing process controls and are shipped with a certificate of compliance outlining that the component has met the five-part WEIDMANN certification process. Available with LumaSense DipTip Rugged Probes™.



Extensions


LumaSense offers multiple fiber optic extensions options to connect the probes from the tank wall plate to the instrument.

Single Fiber Extension

- Hard Clad Silica fiber jacketed in PVC and Kevlar®
- Available in lengths of 5, 10, 15 or 20 meters or custom lengths by request up to 50 meters
- SMA connector includes Viton O-ring for protection against leaks


Four-Fiber Extension

- Four fiber cable subunits and a central Kevlar® strength member in one PVC outer jacket
- Each subunit features Hytrel® and Kevlar® over Hard Clad Silica fiber
- Available in lengths of 5, 10, 15 or 20 meters or custom lengths by request up to 50 meters
- Viton O-ring connectors for protection against leaks
- Available in low temperature construction also



Tank Wall Plate Assembly

LumaSense provides welded tank wall feedthrough plate assemblies. Each tank wall plate features our proprietary welded feedthroughs on a stainless steel plate, with a carbon steel backing ring and Viton O-ring for maximum protection against leaks.



Technical Data

Performance

Number of Channels	4 to 16 (in increments of 2)
Temperature Range	-30 to 230°C
Accuracy	±2°C over entire temperature range for life of transformer without calibration
Display Response Time	1 sec
Measurement Resolution	0.1°C
Precision	±0.5°C
Light Source Life Span	Life of the transformer
EMI/RFI Susceptibility	Complete immunity

Interface

Display	5.7-inch Interactive touch screen
Probe Signal Strength Readout	Accessible for all channels
Diagnostics	On-board self diagnostics and troubleshooting guide

Environmental Specifications

Operating Temperature	-30 to 70°C
Storage Temperature	-35 to 75°C

Communication

Analog Output	Choice of 4-20mA or 0-1mA
Serial Output	RS-232C and RS-485, Ethernet, USB
Relays	0, 8 or 16 Form-C programmable relays
System Status Relay	1 Form-C relay
Communications	Modbus ASCII, Modbus RTU, DNP3.0, ASCII and IEC61850 Standard
Probes	Accepts LUXTRON Rugged and Quality Probes
Data Storage	2 GB of data at 1 minute intervals on all channels, as well as error codes and relay statuses. Retains approximately 40 years of data.

Electrical


Input Power	90 to 264 VAC or 127 to 370 VDC, 47 to 63 Hz
Surge Protection	4000V (IEEE C37.90.1-2002)
Consumption	108 W (maximum)

Physical

Mounting	Rack, panel or wall mount available
----------	-------------------------------------

Innovative On-Board Software

The LumaSMART's innovative on-board software gives a color-coded visual display of all connected probes. Using the touch screen exclusively offered by LumaSense, you can customize channel labels, configure alarms and relays and download data logs. In addition, the diagnostic feature allows you to easily test your configured relay settings by simulating alarm conditions. Our software also allows for trending and data analysis of temperatures measured.



LumaSense Technologies

Americas and Australia
Sales & Service
Santa Clara, CA
Ph: +1 800 631 0176
Fax: +1 408 727 1677

info@lumasenseinc.com

LumaSense Technologies, Inc., reserves the right to change the information in this publication at any time.

Temperature and Gas Sensing Solutions

Europe, Middle East, Africa
Sales & Service
Frankfurt, Germany
Ph: +49 69 97373 0
Fax: +49 69 97373 167

India
Sales & Support Center
Mumbai, India
Ph: +91 22 67419203
Fax: +91 22 67419201



China
Sales & Support Center
Shanghai, China
Ph: +86 133 1182 7766
Fax: +86 21 5877 2383

www.lumasenseinc.com

©2012 LumaSense Technologies. All rights reserved.
LumaSMART Brochure Rev. 01/31/12

[Handwritten signature]

LUMASENSE®
TECHNOLOGIES



SmartDGA® Monitoring Solutions

Cost-effective and accurate gas detection solutions based on Non-Dispersive Infrared (NDIR) sensor technology to measure fault gases in transformers or load tap changers (LTC's)

- Identify potential faults prior to failures (reducing unplanned outages and associated costs)
- Reduce the number and frequency of LTC maintenance cycles, thereby increasing uptime and maximum efficiency of the LTC
- Proactively investigate premature aging or the cause of faults of a transformer

[Redacted text]


[Handwritten signature]

[Handwritten signature]

Protect critical assets through comprehensive analysis of transformer fault conditions with online SmartDGA® monitors

SmartDGA® Instruments


The SmartDGA® family of instruments is the industry's most cost effective Dissolved Gas Analysis (DGA) solution, designed to be the most flexible and to provide the best user experience available. Each model has been designed using state-of-the-art Non-Dispersive Infrared (NDIR) technology. The continuous online DGA values reported by the SmartDGA® instrument quickly identify potential fault conditions through monitoring of key gas levels and ratios.



- **SmartDGA Gauge™** is the industry's first dedicated online Load Tap Changer (LTC) condition monitor. The Gauge measures and records Methane, Acetylene, and Ethylene plus moisture to assess LTC health.
- **SmartDGA Guard™** provides a cost effective early warning monitoring system of potential transformer failures. The Guard measures and records Hydrogen, Acetylene, Carbon Dioxide, and Carbon Monoxide plus moisture to provide an early diagnostics tool.
- **SmartDGA Guide™** provides comprehensive online DGA results that enable diagnostic techniques. The Guide measures and reports nine (9) DGA gases plus moisture in an instrument that vastly reduces total cost of ownership of an on-line monitoring system.

SmartDGA EZHub™

The SmartDGA EZHub™ unit is the central intelligence for the SmartDGA® system. A fully configured unit is capable of handling the power and communication needs for the SmartDGA® system. The EZHub can support a Gauge instrument for the LTC and a Guard or Guide instrument for the transformer. All interface functions and interconnects are provided in the EZHub device as well as internal memory, and four (4) relays with bright LED indicators to indicate Caution, Warning, and Alarm gas level, rate, and ratio conditions. The fourth relay provides status information on the SmartDGA system itself.





Key Functional Features

- Each SmartDGA® package includes the instrument, mounting hardware, connection cable, the SmartDGA EZHub™ unit, and SmartDGA Viewer Software.
- Versatile mounting configurations – including single and dual valve mount. Inline mounting is available for LTC filter system or non-valve mounting for a transformer. The SmartDGA® instrument can be mounted in a vertical or horizontal position.
- Extremely cost effective – total cost of ownership is a fraction of the cost of other instruments and installation can be accomplished in just hours.
- No consumables, carrier gases, or scheduled calibration required.
- Sunlight visible indicators for Caution, Warning, and Alarm conditions. Has Status Relay notification and corrective action triggering to ensure optimal system operations.
- Packages available for LTC monitoring with specific interfaces for common LTC filter models. SmartDGA Gauge monitors and displays gases for Duval triangle 2 for LTC.
- Communications supported via all major protocols common in the electric power industry such as Modbus RTU, DNP 3.0, and IEC 61850 with the optional iCore.

LumaSMART iCore™ (Optional)

The LumaSmart iCore™ controller provides a local interactive touch screen display of DGA data collected from the SmartDGA EZHub™ using the DGA Viewer™ software. The DGA Viewer™ software allows for on-site viewing of DGA data collected from the SmartDGA® instruments. The software provides a local means to set and create operational levels for caution, warning and alarm conditions. Additionally, the LumaSmart iCore™ device provides communications to external systems using RS485 or Ethernet. Each LumaSmart iCore™ device enables connectivity to multiple EZHub™ units (up to a maximum of 4 using either the Ethernet or RS-485 connection).






40+ Years of Experience with NDIR

LumaSense is the industry leader in the use of Non-Dispersive Infrared (NDIR) technologies and has deployed thousands of systems in the field. With over 40 years of experience, LumaSense has redefined the way gases are measured.


Non-Dispersive Infrared (NDIR) quantifies known gases. Building upon the fundamental science behind how molecules interact with light, LumaSense Technologies' ANDROS® brand pioneered NDIR gas analysis

for automotive emissions and patient monitoring. NDIR is the heart of our suite of SmartDGA® products designed for the Energy industry to perform Dissolved Gas Analysis (DGA) of transformers and load tap changers (LTCs). With ANDROS® NDIR modules, the cost of gas measurement is greatly reduced because our modules can measure multiple gases and field calibration is not needed.




DGA Viewer™ software


The DGA Viewer™ software allows users to configure systems using various set-up tools and view data being captured by the SmartDGA® instrument.




Device Configuration
Customized gas detection levels of Caution, Warning, and Alarm values. Included are user-configurable settings for each gas Rate of Change detection levels. Ratio setpoint activation is also available.




Details Screen
Review Gas levels and PPM/day as well as Ratios in a single screen. The last and next measurement date and times are also visible.



DGA Dashboard
The DGA Viewer™ software displays all connected instruments with status as well as the last and next sampling times.



Duval Triangle
Visual diagnostic tool divided into fault zones based on the types of electrical and thermal faults as defined in Duval triangle type 1 and 2 for transformers and LTCs respectively.



Trends
The Trends screen displays all detected gases via a trend graph over a user-selectable period of time. Each gas can be individually displayed or all 9 gases can be displayed at once.



SmartDGA™ System Technical Data

Instrument Specifications

NDIR Gas Phase Sensor Accuracy	± 5% or ± LDL, whichever is greater
Reporting Rate	Every 24 hours - default, user selectable from approximately 3 hours to 7 days.
Measurement Range	Minimum value is the lower detectable limit after settling-in period after initial installation which may take up to 1 week, maximum value is the upper limit of accurate response
Moisture Accuracy	± 3 ppm or ± 2% RS
Oil Pressure	up to 45 psig (3 bar)
Enclosure Rating	IP 55
Sunlight visible indicators for condition codes	<ul style="list-style-type: none"> • Green - Normal • Yellow - Caution • Blue - Warning • Red - Alarm • Red/Blue - System Status Error • Green/Yellow - Loss of Communication
Note: Indicators normally flash on for 5 seconds, off for 15 seconds	

Environmental

	SmartDGA® Instrument	SmartDGA EZHub™	LumaSMART iCore™
Operating Temperature*	-50 to 55 °C	-50 to 55 °C	-40 to 70 °C
Storage Temperature	-50 to 70 °C	-50 to 70 °C	-40 to 75 °C
Storage Humidity (non-condensing)	1-99% RH	1-99% RH	1-99% RH
Dimensions (L x H x D)	16.4" x 8.6" dia.	10.3" x 5.7" x 6"	8.7" x 7.4" x 6.6"
Weight	18.74 lbs	6.61 lbs	11.02 lbs

Certifications and Standards (Instrument & SmartDGA EZHub™)

Emissions / Immunity	EN 61000-6-2 (2005) +C1 EN 61000-6-4 (2007) +A1 EN 61000-3-2 (2006) +A1 EN 61000-3-3 (2008)
Environmental / Vibration	ETSI EN 300 019-2-4
Surge Protection	4000V (IEEE C37.90.1-2002)

Standard Accessories (included in system order)

- Mounting Hardware - includes single valve, dual valve or off transformer installation kit
- Connection Cable - 10 m standard (additional lengths and cold weather options available)
- DGA Viewer™ software

LumaSense Technologies

Americas and Australia
Sales & Service
Santa Clara, CA
Ph: +1 800 631 0176
Fax: +1 408 727 1677

Europe, Middle East, Africa
Sales & Service
Frankfurt, Germany
Ph: +49 69 97373 0
Fax: +49 69 97373 167

India
Sales & Support Center
Mumbai, India
Ph: +91 22 67419203
Fax: +91 22 67419201

China
Sales & Support Center
Shanghai, China
Ph: +86 133 1182 7766
Fax: +86 21 5877 2383

info@lumasenseinc.com

LumaSense Technologies, Inc., reserves the right to change the information in this publication at any time.

SmartDGA® Instrument Gas Measurements (Min-Max)

Gas	Gauge	Guard	Guide
Acetylene (C ₂ H ₂)	0.5-50,000 ppm	0.5-10,000 ppm	0.5-10,000 ppm
Ethylene (C ₂ H ₄)	2-50,000 ppm		2-50,000 ppm
Carbon Monoxide (CO)		10-10,000 ppm	10-10,000 ppm
Moisture (RS)	1-99%	1-99%	1-99%
Hydrogen (H ₂)		5-10,000 ppm	5-10,000 ppm
Carbon Dioxide (CO ₂)		10-20,000 ppm	10-20,000 ppm
Methane (CH ₄)	2-50,000 ppm		2-50,000 ppm
Ethane (C ₂ H ₆)			2-20,000 ppm
Oxygen (O ₂)			500-50,000 ppm
Nitrogen (N ₂)			5,000-100,000 ppm

SmartDGA EZHub™ & LumaSMART iCore™ Specifications

Power Supplied to EZHub & iCore	90 ~ 264 VAC, 127 ~ 370 VDC, 47 ~ 63 Hz, 6.5 A max
Power Supplied to Instrument	48 VDC ~ 4.16 A max
Memory	Up to 40+ years worth of data storage available with optional iCore
Data Export (Available with EZHub and iCore/PC)	Export of results to date in a single file onto a USB memory stick. When using iCore/PC, user can select date range; when using EZHub port, all data is exported
Available Communications (Available with EZHub)	Proprietary communications via RS485 and Ethernet connections to DGA Viewer software
Optional Communications (Modbus available with PC, others available with iCore)	IEC61850, DNP3, and Modbus protocols for up to 3 EZHubs
Alarm Contacts	<p>EZHub 3 programmable relay outputs (Type C, NO/NC) for caution, warning, & alarm</p> <p>EZHub & iCore One (1) alarm relay output for system status (Type C, NO/NC)</p>
Relay Contact Ratings	Single phase alarm relays (8 A, 250 VAC; 5 A, 30 VDC)

Optional Accessories

- LumaSMART iCore™
- NEMA4x Enclosure (for the LumaSMART iCore™ controller and/or SmartDGA EZHub™ unit)

*For operating temperatures less than -20° C, the cold weather cable is required. For operating in environments where the temperature routinely exceeds 40° C, the high temperature accessory is recommended to prevent premature aging and reduction of component lifetime. Temperatures are based upon air temperatures for unit installation in shaded location.

Awakening Your 6th Sense

www.lumasenseinc.com
©2015 LumaSense Technologies. All rights reserved.
SmartDGA Brochure-EN - Rev. 01/20/2015



KOLEKTOR
KOLEKTOR ETRA d.o.o.

**INHIBITED
TRANSFORMER OIL
TYPE HYVOLT III**

PNA-3.50.24

Revision: 1

Date: 08. 03. 2012

TECHNICAL PROPERTIES

TEST DESCRIPTION	TEST METHOD	SPECIFICATIONS		MARKETING VALUES
		MIN	MAX	
Function				
Viscosity, mm ² /s at 40°C	ISO 3104		12.0	9.2
Viscosity, mm ² /s at -30°C	ISO 3104		1800	924
Pour Point, °C	ISO 3016		-40	-65
Water Content, mg/kg	IEC 60814		30	13
Breakdown Voltage, kV, Before treatment	IEC 60156	30		57
Breakdown Voltage, kV, After treatment	IEC 60156	70		73
Density at 20°C, g/ml	ISO 12185		0.895	0.875
DDF at 90°C	IEC 60247		0.005	0.001
Refining/Stability				
Appearance	ERTM-2	PASS		PASS
Acidity, mg KOH/g	IEC 62021-1		0.01	<0.01
Interfacial Tension, mN/m	ASTM D 971	40		48
Corrosive Sulfur	DIN 51353	Noncorrosive		Noncorrosive
Corrosive Sulfur	ASTM D 1275, B	Noncorrosive		Noncorrosive
Corrosive Sulfur	IEC 62535	Noncorrosive		Noncorrosive
DBDS	IEC 62697-1	Not detected		Not detected
Inhibitors, wt%	IEC 60666	0.08	0.40	0.37
Metal Passivator Additives	IEC 60666	Not detected		Not detected
Sulfur, wt%	IEC 14596		0.15	0.008
Furfural Content, mg/kg	IEC 61198		0.05	<0.05
Carbon Type Analysis, %	IR-Brandes			
Ca				9
Cn				44
Cp				47
Performance				
Oxidation Stability at 120°C, 500 hours	IEC 61125, C			
Total Acidity, mg KOH/g			0.30	0.01
Sludge, %			0.05	0.02
DDF at 90°C			0.050	0.013
Health, Safety and Environment				
Flash Point, PMCC, °C	ISO 2719	135		141
PCA Content, %	BS 2000 Part 346		3	<3
PCB Content	IEC 61619	Not detected		Not detected

PNA 3_50_24

Page 1/1

*Hyvolt III is a product of Ergon Refining, Inc.
This inhibited electrical insulating oil is produced from a severely hydrotreated naphthenic oil to meet the specification requirements defined in IEC 60296:2012, special applications.
As per IEC 60296:2012, this product contains no undeclared additives.*

②

②



ELEKTROINŠTITUT MILAN VIDMAR

Our sign: 1626-4/15

To whom it may concern,


Ljubljana, June 18th, 2015

Subject: Test supervision declaration

We Milan Vidmar Electric Power Research Institute, accredited in accordance
SIST EN ISO/IEC 17025:2005,
hereby declare,
that we supervised routine, type and special tests performed on the transformers
SN 78947,74273
and confirm that tests were performed according to IEC 60076.



Director:


Boris Žitnik, Ph. D. E. E.

Enclosures:

Transformer test report - 78947,74273
Lightning impulse test - 78947,74273
Heat run test - 78947,74273

INŠTITUT ZA ELEKTROGOSPODARSTVO IN ELEKTROINDUSTRIJO
1000 Ljubljana, Slovenija, Hajdrihova 2, p.p. 285, tel.: +386 1 474 3601, fax: +386 1 425 3326
Poslovni račun NLB d.d. Ljubljana 02924-0012833094, identifikacijska številka SI11781939


1/1



CS

CC

на бланка на ЕИМВ Електроинститут Милан Видмар

До всички заинтересовани

наш знак: 1626-4/15

Любляна, 18 юни 2015

относно: Декларация за супервизиране на изпитвания/тестове

Ние, изследователски електроинститут Милан Видмар, акредитирани в съответствие с акредитационен документ СИСТ ЕН ИСО/ИЕЦ 17025:2005 (IEC 17025:2005), с настоящото декларираме, че под наш контрол са извършени рутинни, типови и специални тестове на трансформатори със серийни номера: 78947 и 74273 и потвърждаваме, че тези тестове и изпитания са проведени в съответствие със стандарт ИЕЦ 60076 (IEC 60076).

Печат на Електроинститут Милан Видмар

Директор: /подписът не се чете/

Д-р. Борис Житник

Приложения:

Изпитвателен протокол на трансформатор - 78947, 74273

Изпитване с мълниев импулс - 78947, 74273

Изпитване на прегряване - 78947, 74273

ИНСТИТУТ ЗА ЕЛЕКТРОГОСПОДАРТСТВО ИН ЕЛЕКТРОИНДУСТИЮ

1000 Любляна, Словения, ул. Хайдрихова 2, п.п. 285, тел. +38614743601, факс: +38614253326

Бизнес профил НЛБ д.д. Любляна 02924-0012833094, Идентификационен номер: СИ11781939

Преводът на български език е извършен от Стефан Миячев

CC

CC

10

**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Naročnik: Purchaser:	Proizvajalec: Manufacturer:	Preizkušeno po: Tested in accordance with:	Leto izdelave: Year of manufacture:
Alstom Power Systems for TEŠ Slovenija	KOLEKTOR ETRA ENERGETSKI TRANSFORMATORJI d.o.o.	IEC 60076	2012

TEHNIČNI PODATKI TECHNICAL RATING			
Tip: Type:	Transformator: Transformer:	Regulacijsko stikalo: Tap-changer:	Komandna omarica reg. st.: Tap-changer motor drive unit:
	RT 40000-115,5	MR - V III 300Y	MR - ED100S
Tov. št.: Ser. No.:	78947	133 5902	133 5902
Št. načrta: Diagram No.:	3447		
Navilje; Winding:	VN - HV	VN _N - HV _N	NN - LV
Stopnja izolacije: Um [kV] Insulation level: LI / AC [kV]	123 550 / 230	123 550 / 230	12 75 / 28
Nazivna moč; Rated power: [kVA]	40.000		40.000
Nazivna napetost; Rated voltage: [V]	+ 8 x 1,25% 115.500 - 8 x 1,25%		11.000
Nazivni tok; Rated current: [A]	199,9		2.100
Frekvenca: Frequency:	Število faz: No. of phases:	Vezna skupina: Vector group:	Sistem hlajenja: Cooling method:
50 Hz	3	YNd5	ONAN / ONAF
Skupna masa [t]: Total weight [t]:	Masa olja [t]: Weight of oil [t]:		Tip izolacijskega olja: Type of isolation oil:
59,0	14,1		Shell D1ala S3 ZX-I

OPOMBE: ONAF - 40 MVA
NOTES: ONAN - 24 MVA**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

Štandrova ulica 10
10.1231 Ljubljana, Slovenija

I: 134/12

Preizkusom je prisostvoval:
The test was carried out in presence of:Mr. Gil Attuyer - Alstom
Mr. Benoit Le Mintier - Alstom
Mr. Sandi Dolšak - TEŠ
Mr. Miro Bugeza - ELEK
Mr. Mladen Igljič - EIMVELEKTROINŠTITUT MILAN VIDMAR
Hojkriževa 2, 1000 Ljubljana, SlovenijaMeritve opravil: Tested by: **Franc Stempelj**
Primoz Dimnik
Ljubljana: 2011-12-05Pregledal: Checked by:
Ljubljana:Odobril: Approve:
Ljubljana:

KOLEKTOR ETRA Energetski transformatorji d.o.o.

Štandrova 10, 1001 Ljubljana, p.p. 4959, Slovenija

tel. +386 1 6302 800, fax. +386 1 6302 830, http://www.kolektor-etra.si

SI 78947.doc / 27-07/12/2012

E: LM2050 / s: F.S. 30.07.97 - Verzija 0

1 / 21

**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA

TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**Tov. št.:
Ser. No.: **78947****SPISEK MERITEV IN PREIZKUSOV**
LIST OF MEASUREMENTS AND TESTS

1.0	Meritev prestavnega razmerja Measurement of voltage ratio	<input checked="" type="checkbox"/>
1.1	Meritev magnetilnih tokov pri 400 V, 50 Hz No-load current at 400 V, 50 Hz	<input checked="" type="checkbox"/>
2.0	Meritev ohmskih upornosti navitij Measurement of winding resistance	<input checked="" type="checkbox"/>
3.1	Meritev izgub in toka praznega teka Measurement of no-load loss and no-load current	<input checked="" type="checkbox"/>
3.2	Meritev izgub in napetosti kratkega stika Measurement of load loss and impedance voltage	<input checked="" type="checkbox"/>
4.1	Preizkus z napetostjo iz tujega vira Separate-source voltage withstand test	<input checked="" type="checkbox"/>
4.2	Preizkus z inducirano napetostjo (ACSD, ACLD) Induced AC withstand voltage test (ACSD, ACLD)	<input checked="" type="checkbox"/>
4.3	Meritev izolacijske upornosti Measurements of insulation resistance	<input checked="" type="checkbox"/>
4.4	Meritev prebojne trdnosti izolacijskega olja Measurements of dielectric strength of insulating oil	<input checked="" type="checkbox"/>
5.0	Preizkus regulacijskega stikala Tests on on-load tap-changer	<input checked="" type="checkbox"/>
7.0	Meritev izgub hladilnega sistema Measurement of power consumption of cooling system	<input checked="" type="checkbox"/>
11.0	Meritev kapacitivnosti in tg δ Measurements of capacity and dissipation factor tg δ	<input checked="" type="checkbox"/>
12.0	Meritev stresane induktivnosti Measurements of leakage inductance	<input checked="" type="checkbox"/>
13.0	Meritev nivoja hrupa Measurement of sound level	<input checked="" type="checkbox"/>
15.0	Spisek elementov na transformatorju List of elements on transformer	<input checked="" type="checkbox"/>
16.0	Preizkus komandne - signalne omarice Test of control - signal cubicle	<input checked="" type="checkbox"/>
17.0	Funkcionalni preizkus elementov na transformatorju Functional test of elements on transformer	<input checked="" type="checkbox"/>
19.0	Meritve na vgrajenih tokovnih transformatorjih Measurement on built-in current transformers	<input checked="" type="checkbox"/>
20.0	Frekvenčna karakteristika transformatorja Frequency response of transformer	<input checked="" type="checkbox"/>
21.0	Preizkus segrevanja Temperature-rise test	S 61/12 <input checked="" type="checkbox"/>
22.0	Preizkus z udarno napetostjo Impulse voltage test	UP 100/12 <input checked="" type="checkbox"/>

ELEKTROINŠTITUT MILAN VIDMAR
Hajdrihova 2, 1000 Ljubljana, Slovenija



KOLEKTOR
KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator: RT 40000-115,5
Transformer: RT 40000-115,5
Tov. št.: 78947
Ser. No.: 78947

1.0 MERITEV PRESTAVNEGA RAZMERJA IN VEZNE SKUPINE
MEASUREMENT OF VOLTAGE RATIO AND VECTOR GROUP - IEC 60076-1 (clause 6, 9, 10.3)

Vežna skupina: YNd5 VN - NN; HV - LV
Vector group: YNd5

Poz. stik.: Tap pos.:	Računska napetost: Calculated voltage:		Konstanta: Constant: $[U_2 / U_1 \times k]$	Izmerjeno odstopanje; Measured deviations:		
	U_1 [kV]	U_2 [kV]		1U - 2U [%]	1V - 2V [%]	1W - 2W [%]
1	127.050		149,961	+0,05	+0,05	+0,05
2	125.606		151,685	+0,08	+0,08	+0,08
3	124.163		153,449	+0,10	+0,10	+0,10
4	122.719		155,254	+0,11	+0,11	+0,11
5	121.275		157,102	+0,12	+0,12	+0,12
6	119.831		158,995	+0,13	+0,13	+0,13
7	118.388		160,934	+0,15	+0,15	+0,15
8	116.944		162,921	+0,16	+0,16	+0,16
9	115.500	11.000	164,957	+0,18	+0,18	+0,18
10	114.056		167,045	+0,22	+0,22	+0,22
11	112.613		169,187	+0,24	+0,24	+0,24
12	111.169		171,384	+0,25	+0,25	+0,25
13	109.725		173,639	+0,27	+0,27	+0,27
14	108.281		175,954	+0,30	+0,30	+0,30
15	106.838		178,332	+0,32	+0,32	+0,32
16	105.394		180,775	+0,33	+0,33	+0,33
17	103.950		183,286	+0,34	+0,34	+0,34

Vežna skupina: YNd5
Vector group: YNd5

Poz. stik.: Tap pos.:	Računska napetost: Calculated voltage:		Konstanta: Constant: $[U_2 / U_1 \times k]$	Izmerjeno odstopanje; Measured deviations:		
	U_1 [kV]	U_2 [kV]		[%]	[%]	[%]

Merilna oprema; Measuring equipment:
- merilnik prestavnega razmerja Iskra, tip MPRT, točnosti ± 0,05 %
- turns ratio meter Iskra, type MPRT, accuracy ± 0,05 %

1.1 MERITEV MAGNETILNIH TOKOV pri 3 x 400 V, 50 Hz
NO-LOAD CURRENT at 3 x 400 V, 50 Hz

Poz. stik.: Tap pos.:	Navitje: Winding:	Faza A - U [mA]	Faza B - V [mA]	Faza C - W [mA]
		Phase A - U [mA]	Phase B - V [mA]	Phase C - W [mA]
9	VN - HV	5,2	2,8	5,1
**	NN - LV	210	195	250

Merilna oprema; Measuring equipment:
- univerzalni instrument točnosti ± 0,5 %
- multimeter accuracy ± 0,5 %



KOLEKTOR
KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**

Tov. št.:
Ser. No.: **78947**

2.0 MERITEV OHMSKIH UPORNOSTI NAVITIJ
MEASUREMENT OF WINDING RESISTANCE

- IEC 60076-1 (clause 10.2)

Temperatura - Temperature ϑ : **21 °C**

Poz. stik.: Tap pos.:	VN navitje HV winding			I_{test} 20 A
	1U - 1V [Ω]	1V - 1W	1U - 1W	
1	0,853217	0,852210	0,853510	
2	0,842571	0,841853	0,842961	
3	0,833276	0,832281	0,833608	
4	0,823464	0,822569	0,823858	
5	0,813318	0,812245	0,813650	
6	0,803645	0,802634	0,804031	
7	0,793220	0,792295	0,793516	
8	0,783602	0,782749	0,784059	
9	0,770767	0,770970	0,771764	
10	0,783506	0,782524	0,783921	
11	0,793898	0,792825	0,794242	
12	0,803825	0,802936	0,804327	
13	0,813557	0,812386	0,813876	
14	0,823474	0,822455	0,823945	
15	0,833004	0,831854	0,833472	
16	0,843068	0,842064	0,843620	
17	0,853151	0,851980	0,853529	

Poz. stik.: Tap pos.:	NN navitje LV winding			I_{test} 20 A
	2U - 2V [Ω]	2V - 2W [Ω]	2U - 2W [Ω]	
--	0,007177	0,007197	0,007199	--

Poz. stik.: Tap pos.:	[Ω]	[Ω]	[Ω]	I_{test}
--				--

Merilna oprema: Measuring equipment:

- merilnik Ohmske upornosti Tellex, tip 2283, točnost $\pm 0,06\%$
- resistance meter Tellex, type 2283, accuracy $\pm 0,06\%$

ETRA

**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORTTransformator:
Transformer: **RT 40000-115,5**Tov. št.: **78947**
Ser. No.:**3.1 MERITEV IZGUB IN TOKA PRAZNEGA TEKA**
MEASUREMENT OF NO-LOAD LOSS AND NO-LOAD CURRENT - IEC 60076-1 (clause 9, 10.5)Napetost priključena; Voltage supply to: **NN1 / LV1 (tap pos. 9)** Frekvenca; Frequency: **50 Hz**

Napetost; Voltage:		$U_{m^{1,11}}$ [%]	90	100	110
$U_{m^{1,11}}$ [V]			9.900	11.000	12.100
U_{rms} [V]			9.867	10.934	11.943
Tok; Current:		$I_{rms A}$ [A]	1,082	1,651	3,517
$I_{rms B}$ [A]			1,148	1,606	3,313
$I_{rms C}$ [A]			1,576	2,221	4,297
I_o [A]			1,268	1,826	3,709
I_o [%]			0,060	0,087	0,177
Fazni kot; Phase angle:		$\cos \phi$ []	0,861831	0,704971	0,414801
Mer. izgube; Measur. loss: P_{Fe} [W]			18.682	24.366	31.803
Kor. izgube; Corrected loss: P_{Fe0} [W]			18.754	24.527	32.245

3.2 MERITEV IZGUB IN NAPETOSTI KRATKEGA STIKA
MEASUREMENT OF LOAD LOSS AND IMPEDANCE VOLTAGE - IEC 60076-1 (clause 9, 10.4)Temperatura; Temperature: **21 °C** Frekvenca; Frequency: **50 Hz**

Napajano - kratko skljnjeno:		HV-LV	HV-LV	HV-LV
Supply - short circuited:				
Pozicija stikala; Tap position:		1	9	17
Tok; Current: I_m [A]		178,27	199,06	202,08
Napetost; Voltage: U_m [V]		12.912	11.107	8.794
Izgube; Loss: P_m [W]		105.020	107.790	103.330
Preračun na nazivni tok navilja. - Calculated at winding nominal current.				
Moč; Power: S_n [kVA]		40.000	40.000	40.000
Tok; Current: I_n [A]		181,8	199,9	222,2
Napetost; Voltage: U_k [V]		13.165	11.156	9.668
Izgube; Loss: P_k [W]		109.179	108.748	124.883
Preračun na referenčno temperaturo 75 °C. - Calculated at reference temperature 75 °C.				
I^2R izgube; I^2R loss: P_R [W]		108.758	113.567	134.028
D. izg.; Stray loss: P_d [W]		15.993	12.357	11.728
Izgube; Loss: P_k [W]		124.751	125.924	145.756
Krat. nap.; Impedance voltage: U_k [%]		10,36	9,66	9,30
U_R [%]		0,31	0,31	0,36
U_x [%]		10,36	9,66	9,30

3.3 REZULTATI MERITEV IZGUB
RESULTS OF LOSS MEASUREMENTS - IEC 60076-1 (clause 9)

	Poz.; Tap:	S_n [kVA]	P_{Fe} [kW]	P_{x75} [kW]	P_{tot} [kW]	$P_{coll.s.}$ [kW]	I_o [%]	U_{k75} [%]
Garantirano: Guaranteed:	1	40.000						
	9	40.000	25,0 (+15%)	130,0(+16%)	155,0(+10%)		0,15 (+30%)	9,0 (±10%)
	17	40.000		150,0(+15%)				
Merjeno: Measured:	1	40.000		124,751	149,278			10,36
	9	40.000	24,527	125,924	150,451		0,087	9,66
	17	40.000		145,756	170,283			9,30

Merilna oprema; Measuring equipment:

- močnosni analizator Norma, tip D6000, točnost $\pm 0,05\%$; - power analyzer Norma, type D6000, accuracy $\pm 0,05\%$
- merilni napetostni pretvornik Tellex, točnost $\pm 0,1\%$; - measuring voltage transducer Tellex, accuracy $\pm 0,1\%$
- merilni tokovni transformator CdC, točnost $\pm 0,2\%$; - measuring current transformer CdC, accuracy $\pm 0,2\%$

ELEKTROINŠTITUT MIRAN VIDMAR
Hojdrihova 2, 1000 Ljubljana, Slovenija



KOLEKTOR
KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**

Tov. št.:
Ser. No.: **78947**

4.1 PREIZKUS Z IZMENIČNO NAPETOSTJO IZ TUJEGA VIRA
SEPARATE SOURCE AC WITHSTAND VOLTAGE TEST - IEC 60076-3 (clause 11)

Med; Between	U [kV _{peak} /√3]	f [Hz]	t [s]	C [pF]	I _c [A]
HV - LV + M	230	50	60		
LV - HV + M	28	50	60		

Merilna oprema; Measuring equipment:
- AC voltmeter Haefely, tip DMI 551, točnost ± 0.5 %
- AC voltmeter Haefely, type DMI 661, accuracy ± 0.5 %

OPOMBA; NOTE:
M - ozemljeni deli
M - ground

4.2 PREIZKUS Z INDUCIRANO NAPETOSTJO (ACSD, ACLD)
INDUCED OVERVOLTAGE WITHSTAND TEST (ACSD), ACLD) - IEC 60076-3 (clause 7.3, 12)

4.2.1 Transformator s polno izolacijo VN navitja (U_m ≤ 72,5 kV)
Transformer with uniformly insulated HV winding (U_m ≤ 72,5 kV) - IEC 60076-3 (clause 7.3, 12.1)

Položaj reg. stikala; Tap changer pos.:

Napajano navitje; Supply winding	U _n [kV] NN; LV	U _{test} [kV] NN; LV	U _{test} [kV] VN; HV	f [Hz]	t [s]

4.2.2 Transformator z znižano izolacijo VN navitja
Transformer with non-uniformly insulated HV winding - IEC 60076-3 (clause 7.3, 12.3)

Položaj reg. stikala; Tap changer pos.:

Napajano navitje; Supply winding	U _n [kV] NN; LV phase - phase	U _{test} [kV] NN; LV phase - phase	U _{test} [kV] VN; HV phase - earth	U _{test} [kV] N N - earth	f [Hz]	t [s]

k =

Merilna oprema; Measuring equipment:
- močnosni analizator Norma, tip D6000, točnost ± 0,05 %; - power analyzer Norma, type D6000, accuracy ± 0.05 %
- merilni napetostni pretvornik Teitex, točnost ± 0,1 %; - measuring voltage transducer Teitex, accuracy ± 0.1 %
- merilni tokovni transformator CdC, točnost ± 0,2 %; - measuring current transformer CdC, accuracy ± 0.2 %
- merilnik delnih praznjen Lemke, tip LDS-6; - partial discharge instrument Lemke, tip LDS-6

[Handwritten signature and stamp]

ENW
ELEKTROINŽINIR MIHAN VIDMAR
Hožurkova 2, 1000 Ljubljana, Slovenija



KOLEKTOR
KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator: **RT 40000-115,5** Tov. št.: **78947**
Transformer: Ser. No.:


4.2.3 MERITEV DELNIH PRAZNIJENJ - IEC 60076-3 (clause 12)
PARTIAL DISCHARGE MEASUREMENT - IEC 60270

Trifazno preizkušanje z meritvijo delnih praznjenj
Three-phase test with measurement of partial discharges

Položaj reg. stikala; Tap changer pos.: **9** Napajano navilje; Supply winding: **LV** Tip preizkusa; Test type: **ACSD**

U_m	123	[kV]	- najvišja nap. opreme na VN navilju; highest voltage for equipment on HV winding
LI/AC	550 / 230	[kV]	- stopnja izolacije VN navilja; insulation level HV winding
U_1 (HV)	$230 / \sqrt{3} = 133$	[kV]	- IEC 60076-3, tabela D.1; IEC 6076-3, table D.1
U_2 (HV)	$160 / \sqrt{3} = 92$	[kV]	- IEC 60076-3, tabela D.1; IEC 6076-3, table D.1
U_3 (HV)	$135 / \sqrt{3} = 78$	[kV]	- IEC 60076-3, (1,1 x $U_m / \sqrt{3}$)
f_{Um}	300	[Hz]	- napajalna frekvenca; supply frequency
Q_0 (calib.)	100	[pC]	- kalibracijska vrednost; calibration value
f_m	100 - 400	[kHz]	- merilna frekvenca; measuring frequency
Filter:	wide band		

Časovni interval; Time sequence	U_1 VN - HV [kV]	U_2 NN - LV [kV]	Priključki; Terminals						Dovoljeno Allowed [pC]
			A / U [pC]	B / V [pC]	C / W [pC]	[pC]	[pC]	[pC]	
Osnovne molnje; Background noise:	0	0	16	14	15				< 50
A ↓	135 / 78	13,0	17	45	23				< 100
			19	18	23				
B ↓	160 / 92	15,4	19	19	24				< 300
			23	25	25				
C	230 / 133	22,0	22	34	23				..
D ↓	160 / 92	15,4	25	21	19				< 300
			19	23	24				
E ↓	135 / 78	13,0	19	21	19				< 100
			23	25	20				
Osnovne molnje; Background noise:	0	0	15	14	14				< 50



Simetrični tri fazni prikljop. Merjenje na kapacitivnem skoz. Časovni intervali preizkusne napetosti.
Symmetrical three-phase connection. Circuit for measure. on capac. bushing. Time sequence for application of test voltage.

Merilna oprema; Measuring equipment:

- močnosilni analizator Norma, tip D6000, točnost ± 0,05 %; - power analyzer Norma, type D6000, accuracy ± 0,05 %
- merilni napetostni pretvornik Teltest TMS 581, točnost ± 0,10 %; - measuring voltage transducer Teltest TMS 581, accuracy ± 0,10 %
- merilni tokovni transformator Teltest TMS 582, točnost ± 0,11 %; - measuring current transformer Teltest TMS 582, accuracy ± 0,11 %
- merilnik delnih praznjenj Lemke, tip LDS-6; - partial discharge instrument Lemke, tip LDS-6

**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA

TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**Tov. št.:
Ser. No.: **78947**

4.3 MERITEV IZOLACIJSKE UPORNOSTI MEASUREMENTS OF INSULATION RESISTANCE		- IEC 60076-1 (clause 10.1.3)					
Med; Between	R _(30 s) [MΩ]	R _(60 s) [MΩ]	R _(180 s) [MΩ]	R _(600 s) [MΩ]	DAR _(R_{30s}/R_{300s})	U [kV _{DC}]	t [°C]
HV - LV + M		46.500			1,03	2,5	21
LV - HV + M		25.800			1,28	2,5	21
m. core - M		20.400			1,29	1,0	21
core clamp - M		18.300			1,23	1,0	21
Merilna oprema; Measuring equipment: - merilnik izolacijske upornosti Megger MIT 1020, točnosti ± 5 % - insulation resistance meter Megger MIT 1020, accuracy ± 5 %					OPOMBA; NOTE M - ozemljeni deli M - ground		

4.4 MERITEV PREBOJNE TRDNOSTI IZOLACIJSKEGA OLJA MEASUREMENTS OF DIELECTRIC STRENGTH OF INSULATING OIL		- IEC 156					
Tip izolacijskega olja: Type of insulation oil: Shell Diala S3 ZX-I		Razmak med iskriščem preskusne naprave je 2.5 mm. Distance between gaps of oil tester is 2.5 mm.					
Mesto odvzema: Test sample taken from:	1 [kV]	2 [kV]	3 [kV]	4 [kV]	5 [kV]	6 [kV]	M [kV]
middle of transformer tank	78,3	83,7	73,4	76,0	79,2	75,7	77,7
Merilna oprema; Measuring equipment: - merilna naprava Bauer, tip DTA-E 100; - measuring device Bauer, type DTA-E 100							

5.0 PREIZKUS REGULACIJSKEGA STIKALA TESTS ON ON-LOAD TAP-CHANGER		- IEC 60076-1 (clause 10.8)	
a.	8 kompletnih ciklov operacij z nevzbujenim transformatorjem 8 complete operating cycles with the transformer not energized	<input checked="" type="checkbox"/>	
b.	1 kompletan cikel operacij z nevzbujenim transformatorjem, pri 85% pomožni napajalni napetosti with the transformer un-energized, and with the auxiliary voltage reduced to 85% of its rated value, one complete cycle of operation	<input checked="" type="checkbox"/>	
c.	1 kompletan cikel operacij z vzbujenim transformatorjem v praznem teku pri nazivni frekvenci in nazivni napetosti 1 complete operating cycle with transformer at rated voltage and frequency, at no-load	<input checked="" type="checkbox"/>	
d.	10 delovanj regulacijskega stikala s ± 2 stopnjama regulacije z vsake strani glavnega odcepa, pri čim bližjem nazivnem toku transformatorja, z enim kratko vezanim navitjem 10 tap-change operations with ±2 steps on either side of the principal tapping with as far as possible the rated current of the transformer, with one winding short-circuited	<input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/> preizkus opravljen test O.K.			

ELEKTROINŠTITUT MILAN VIDMAR
Hofstühnerova 2, 1000 Ljubljana, Slovenija

	KOLEKTOR	MERILNI LIST TRANSFORMATORJA
	KOLEKTOR ETRA d.o.o.	TRANSFORMER TEST REPORT

Transformator: Transformer:	RT 40000-115,5	Tov. št.: Ser. No.:	78947
--------------------------------	-----------------------	------------------------	--------------


7.0 MERITEV IZGUB HLADILNEGA SISTEMA
MEASUREMENT OF POWER CONSUMPTION OF COOLING SYSTEM

Hladilni sistem ima: Cooling system includes:	4 ventilatorje; fans: / črpalke; oil pumps: / izmenjevalec; exchanger:	Klima - AVT 630 / /
--	--	---------------------------


	U [V]	I [A]	P [W]	f [Hz]		U [V]	I [A]	P [W]	f [Hz]
M1	3 x 400	1,07	117	50					
M2	3 x 400	1,08	121	50					
M3	3 x 400	1,08	121	50					
M4	3 x 400	1,04	119	50					

	U [V]	I [A]	P [W]	f [Hz]
Σ M1..M4	3 x 400	4,27	478	50

Merilna oprema; Measuring equipment:
 - širokopasovni močnostni analizator Norma, tip D6000, točnosti ± 0,05 %
 - wide band power analyzer Norma, type D6000, accuracy ± 0,05 %




 ELEKTROINŠTITUT MILAN VIDMAR
 Hojčičeva 7, 1000 Ljubljana, Slovenija



KOLEKTOR
KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**

Tov. št.:
Ser. No.: **78947**

11.0 MERITEV KAPACITIVNOSTI IN tg δ
MEASUREMENTS OF CAPACITY AND DISSIPATION FACTOR tg δ - IEC 60076-1 (clause 10.1.3)

	vezava connection	U [kV]	pos. (I - II)	N [Ω]	R ₃ [Ω]	R ₄ [kΩ]	C ₄ [μF]	C _x [pF]	tg δ [%]
1	HV - LV + M	10	II	∞	3,52	1/K	0,1801	9.044	0,180
2	LV - HV + M	10	II	∞	1,70	1/K	0,1901	18.726	0,190
3									
4									
5									
6									
7									
8									

1									
2									
3									
4									
5									
6									
7									
8									

Testni pogoji; Test condition:

C_N: **100,01 pF** t: **21 °C** p: **kPa**

Formule za izračun; Formulas for equation:

$C_x = C_N * R_4 / R_3$ [F] pos I → $tg\delta = R_4 * \omega * C_4 * 100$ [%] [C₄ → μF]
 pos II → $tg\delta = 0.01 * C_4 * 100$ [%] [C₄ → μF]

OPOMBA; NOTE
M - ozemljeni dell
M - ground

Merilna oprema; Measuring equipment:

- Schering most tip 2801, po vezavi 1a
- Schering Bridge type 2801, Arrangement 1a

12.0 MERITEV STRESANE INDUKTIVNOSTI
MEASUREMENTS OF LEAKAGE INDUCTANCE

	vezava connection	I [A]	pos. (I - II)	R ₂ [Ω]	R ₃ [Ω]	R _{3 ext} [Ω]	R ₄ [kΩ]	C ₄ [μF]	L _x [mH]	ΔL _x [%]
1	1U-1V (2U+2V+2W)	0,4	I	10.000	5,0	--	127,0	0,4839	24,20	0,373
2	1V-1W (2U+2V+2W)	0,4	I	10.000	5,0	--	133,5	0,4813	24,07	-0,166
3	1U-1W (2U+2V+2W)	0,4	I	10.000	5,0	--	132,2	0,4811	24,06	-0,207
4										
5										
6										
7										
8										
9										

Testni pogoji; Test condition:

poz. slikala; tap range: **9** (..) navitje kratko sklenjeno; winding short circuit

Formule za izračun; Formulas for equation:

$L_x = R_2 * R_3 * C_4$ [H] $\Delta L_x = ((L_{AN} * 100) / (L_{AN} + L_{BN} + L_{CN} / 3)) - 100$ [%]

Merilna oprema; Measuring equipment:

- Schering most tip 2801, po vezavi 2c
- Schering Bridge type 2801, Arrangement 2c

ERAR

[Handwritten signatures and scribbles]

10/21

**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA

TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**Tov. št.:
Ser. No.: **78947****13.1 MERITEV NIVOJA HRUPA - Metoda zvočnega tlaka**
MEASUREMENT OF SOUND LEVEL - Sound pressure method

- IEC 60076-10

pri nazivni napetosti, ONAN, razdalja **0,3 m**; at nominal voltage, ONAN, distance **0,3 m**Napajano:
Supply: **LV**Poz. stikala:
Tap range: **g**Frekvenca:
Frequency: **50 Hz**

	okol. amb.		transformator transformer					okol. amb.		transformator transformer			
	1/3		2/3					1/3		2/3			
	L_{pA1}	L_{pA2}	L_{pA1}	L_{pA2}	L_{pA1}	L_{pA2}		L_{pA1}	L_{pA2}	L_{pA1}	L_{pA2}	L_{pA1}	L_{pA2}
	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)		dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)
1		51,5		53,0	14			57,4		48,8		27	
2		50,4		53,2	15			60,6		52,7		28	
3		51,4		56,6	16			55,1		51,6		29	
4		57,2		55,0	17			51,9		52,1		30	
5		57,3		54,8	18			55,1		51,1		31	
6		58,5		55,8	19			53,5		49,9		32	
7		57,5		50,3	20							33	
8		54,1		52,8	21							34	
9		50,6		52,6	22							35	
10		53,6		60,4	23							36	
11		56,5		58,1	24							37	
12		51,3		55,0	25							38	
13		52,3		50,3	26							39	

Povprečna izmerjena kvadratna vrednost Quadratic mean sound level	L_{pAO}	55,0	dB(A)	Formule za izračun; Formulas for equation: $L_{pAO} = 10 \lg \left[\frac{1}{N} \sum_{i=1}^N 10^{0,1 L_{p,i}}$ $A = \alpha * S_v$ $K = 10 \log_{10} \left[1 + \frac{4}{A/S} \right]$ $L_{pA} = 10 \lg [10^{0,1 L_{pAO}} - 10^{0,1 L_{bgA}}] - K$ $L_{WA} = \bar{L}_{pA} + 10 * \log_{10} S$ $S = 1,25 * h * l_m \rightarrow 0,3m$ $S = (h + 2) * l_m \rightarrow 2m$ $S = (h + 1) * l_m \rightarrow 1m$
Povprečna izmerjena vrednost okolice Average level of background noise	L_{bgA}	30	dB(A)	
Srednji akustični dušilni koeficient Average acoustic absorption coefficient	α	0,35		
Skupna površina testnega prostora Total area of the surface of the test room	S_v	4650	m ²	
Popravek zaradi vpliva prostora (≤ 7 dB) Environmental correction (≤ 7 dB)	K	0,6	dB	
Popravek zaradi vpliva osnovnega hrupa Background correction		0,0	dB(A)	
Kor. A-utežna povp. raven zvočnega tlaka Corrected A-weighted sound pressure level	L_{pA}	54,4	dB(A)	
Garant. A-utežna povp. raven zvočnega tlaka Guaranteed A-weighted sound pressure level	L_{pA}	≤ 72	dB(A)	
Merilna razdalja Measurement distance	X	0,3	m	
Dolžina merilne linije Length of the prescribed contour	l_m	19	m	
Višina transformatorskega kotla Height of the transformer tank	h	2,7	m	
Ekvivalentna površina Area of the effective surface	S	64,1	m ²	
A-utežna raven zvočne moči A-weighted sound power level	L_{WA}	72,5	dB(A)	
Garant. A-utežna raven zvočne moči Guaranteed A-weighted sound power level	L_{WA}	--	dB(A)	

Merilne točke; Measuring points:	1,2,3, ... m. ločke; m. points D = 1m X = ONAN 0,3 m ONAF 2,0 m AN 1,0 m	Opomba; Note: Irafo: 6/48 kV
----------------------------------	--	---------------------------------

Merilna oprema; Measuring equipment:	- merilnik šuma B&K, tip 2250; kalibrator B&K, tip 4331, točnost $\pm 0,30$ dB - measuring instrument B&K, type 2250; calibrator B&K, type 4331, accuracy $\pm 0,30$ dB
--------------------------------------	--



KOLEKTOR
KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**

Tov. št.:
Ser. No.: **78947**

13.2 MERITEV NIVOJA HRUPA - Metoda zvočnega tlaka
MEASUREMENT OF SOUND LEVEL - Sound pressure method

- IEC 60076-10

pri nazivni napetosti, ONAF, razdalja 2 m; at nominal voltage, ONAF, distance 2 m

Napajano: LV1
Supply:


Poz. stikala: 9
Tap range:

Frekvenca: 50 Hz
Frequency:

	okol. amb.		transformator			okol. amb.		transformator			okol. amb.		transformator	
	1/3		2/3			1/3		2/3			1/3		2/3	
	L _{pA1} dB(A)	L _{pA2} dB(A)	L _{pA1} dB(A)	L _{pA2} dB(A)		L _{pA1} dB(A)	L _{pA2} dB(A)	L _{pA1} dB(A)	L _{pA2} dB(A)		L _{pA1} dB(A)	L _{pA2} dB(A)	L _{pA1} dB(A)	L _{pA2} dB(A)
1		60,7		61,4	14		62,4		63,6	27		62,6		61,4
2		60,8		61,7	15		62,0		63,8	28		62,3		61,2
3		61,8		61,7	16		62,0		62,6	29		61,2		60,1
4		61,3		62,7	17		62,3		63,3	30				
5		61,8		61,3	18		61,7		62,8	31				
6		62,3		62,1	19		61,3		62,2	32				
7		61,3		62,8	20		61,8		61,6	33				
8		62,1		63,4	21		61,8		62,7	34				
9		62,5		62,1	22		62,0		62,9	35				
10		61,5		61,7	23		62,3		63,2	36				
11		61,5		60,7	24		62,1		62,7	37				
12		61,4		62,3	25		61,4		62,1	38				
13		62,2		63,5	26		62,1		61,4	39				

Povprečna izmerjena kvadratna vrednost Quadratic mean sound level	L _{pAO}	62,1	dB(A)	Formule za izračun; Formulas for equation: $L_{pAO} = 10 \lg \left[\frac{1}{N} \sum_{i=1}^N 10^{0,1 L_{pAi}} \right]$ $A = \alpha * S_p$ $K = 10 \log_{10} \left[1 + \frac{4}{A/S} \right]$ $L_{pA} = 10 \lg \left[10^{0,1 L_{pAO}} - 10^{0,1 L_{pA1}} \right] - K$ $L_{WA} = \bar{L}_{pA} + 10 * \log_{10} S$ $S = 1,25 * h * l_m \rightarrow 0,3m$ $S = (h + 2) * l_m \rightarrow 2m$ $S = (h + 1) * l_m \rightarrow 1m$
Povprečna izmerjena vrednost okolice Average level of background noise	L _{bgA}	30	dB(A)	
Srednji akustični dušilni koeficient Average acoustic absorption coefficient	α	0,35		
Skupna površina testnega prostora Total area of the surface of the test room	S _v	4650	m ²	
Popravek zaradi vpliva prostora (≤ 7 dB) Environmental correction (≤ 7 dB)	K	1,3	dB	
Popravek zaradi vpliva osnovnega hrupa Background correction		0,0	dB(A)	
Kor. A-utežna povp. raven zvočnega tlaka Corrected A-weighted sound pressure level	L _{pA}	60,8	dB(A)	
Garant. A-utežna povp. raven zvočnega tlaka Guaranteed A-weighted sound pressure level	L _{pA}	≤ 72	dB(A)	
Merilna razdalja Measurement distance	X	2,0	m	
Dožljna merilne llnlje Length of the prescribed contour	l _m	29	m	
Višina transformatorskega kotla Height of the transformer tank	h	2,7	m	
Ekvivalentna površina Area of the effective surface	S	136,3	m ²	
A-utežna raven zvočne moči A-weighted sound power level	L _{WA}	82,2	dB(A)	
Garant. A-utežna raven zvočne moči Guaranteed A-weighted sound power level	L _{WA}	--	dB(A)	

Merilne točke; Measuring points:



1,2,3, .. m. točke; m. pozis
D = 1m
X = ONAF 0,3 m
ONAF 2,0 m
AN 1,0 m

Opomba; Note:
trafo: 6/48 kV

Merilna oprema; Measuring equipment:

- merilnik šuma B&K, tip 2250; kalibrator B&K, tip 4331, točnost ± 0,30 dB
- measuring instrument B&K, type 2250; calibrator B&K, type 4331, accuracy ± 0,30 dB

ELEKTROENERGETSKI INŠTITUT
Beyerskers 1, 1000 Ljubljana, Slovenija

	KOLEKTOR	MERILNI LIST TRANSFORMATORJA TRANSFORMER TEST REPORT	
	KOLEKTOR ETRA d.o.o.		
Transformator: Transformer:	RT 40000-115,5	Tov. št.: Ser. No.:	78947

15.0 SPISEK ELEMENTOV NA TRANSFORMATORJU
LIST OF ELEMENTS ON TRANSFORMER

		Oznaka Label	Tip Type	Tov. št. Ser. No.	Opombe Notes	
1	Skoznik Bushing	1N	ABB - GOB 650	25008003/02		
2	Skoznik Bushing	1U 1V 1W	ABB - GOB 650	25006003/04 25008003/03 25006003/01		
3	Komandna omarica Control cubicle	B00	Rittal - AE1016			
4	Plinski rele Gas relay	B01	Comem - BR 80	051587		
5	Zaščitni rele reg. stikala Protective relay O.L.T.C.	B02	MR - RS 2001			
6	Kazalo olja za transformator Oil level indicator for transformer	B03	Comem - LB22			
7	Kazalo olja za reg. stikalo Oil level indicator for O.L.T.C.	B04	Comem - LB22			
8	Termična slika - VN Winding temp. indicator - HV	B05	AB Kihlstrom - 35	140380-9	75/80/113/118 °C	H = 1,10 gH = 28 K R = 1,0 Ω
9	Kontaktni termometer Oil temperature indicator	B06	AB Kihlstrom - 34	354487-3	50/60/95/100 °C	
10	Uporovni termometer Resistance thermometer	B09	Elplast - Pt 100			
11	Uporovni termometer Resistance thermometer	B10	Elplast - Pt 100			
12	Varnostni ventil Pressure relief valve	B07	Comem - 126			
13	Zaščitni rele reg. stikala Protective relay O.L.T.C.	B08	Comem - 50T			
14	Tokovni transformator Current transformer	CT1	250/2A; 10 VA	122718001	Cl 3; Fs5	in 1V
15	Tokovni transformator Current transformer	CT11..13	250/1A; 30 VA	122719001 122719002 122719003	5P20	in 1U in 1V in 1W
16	Tokovni transformator Current transformer	CT14..16	250/1A; 30 VA	122719004 122719005 122719006	5P20	in 1U in 1V in 1W
17	Tokovni transformator Current transformer	CT17, 18	250/1A; 30 VA	122719007 122719008	5P20	in 1N
18	Tokovni transformator Current transformer	CT19..21	250/2A; 10 VA	122718002 122718003 122718004	Cl 3; Fs5	in 1U in 1V in 1W
19	Monitor plina in vlage v olju Fault gas and moisture in oil monitor		GE Power System - Hydran	1202418848		
20						

16.0 PREIZKUS KOMANDNE - SIGNALNE OMARICE
TEST OF CONTROL - SIGNAL CUBICLE

Elementi so preizkušeni na osnovi načrta (na vratih omarice).
The functional test has been performed according to the drawing (on cubicle door).
Preizkus ožičenja z izmenično napetostjo 2 kV v trajanju 60 sek.
Auxiliary wiring insulation test by 2 kV in duration 60 s

preizkus opravljen test O.K.

17.0 FUNKCIONALNI PREIZKUS ELEMENTOV NA TRANSF.
FUNCTIONAL TEST OF ELEMENTS ON TRANSFORMER

Elementi so preizkušeni na osnovi načrta (na vratih omarice).
The functional test has been performed according to the drawing (on cubicle door).

preizkus opravljen test O.K.

EIMW

TESTIRANJE

[Handwritten signature]

[Handwritten signature]

**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA

TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**Tov. št.:
Ser. No.: **78947****19.0 MERITVE NA VGRAJENIH TOKOVNIH TRANSFORMATORJIH**
MEASUREMENT ON BUILT-IN CURRENT TRANSFORMERS

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/2 A						
Moč; Power:	10 VA						
Klasa; Class:	3						
Fs	5						
Int. oznaka; Int. designation:	CT1						
Montiran v; Mounted in:	1V						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi; Measurements and tests:							
R (Ω):	0,429						
R _{ISO} (at 1000VDC) (M Ω):	56.200						
k:	125						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	-	-	7	18	24

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:							
Razmerje; Ratio:							
Moč; Power:							
Klasa; Class:							
Fs							
Int. oznaka; Int. designation:							
Montiran v; Mounted in:							
Sponke; Terminals:							
Meritve in preizkusi; Measurements and tests:							
R (Ω):							
R _{ISO} (at 1000VDC) (M Ω):							
k:							
Polariteta; Polarity:		mA	20	50	100	500	2000
		V	-				

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:							
Razmerje; Ratio:							
Moč; Power:							
Klasa; Class:							
Fs							
Int. oznaka; Int. designation:							
Montiran v; Mounted in:							
Sponke; Terminals:							
Meritve in preizkusi; Measurements and tests:							
R (Ω):							
R _{ISO} (at 1000VDC) (M Ω):							
k:							
Polariteta; Polarity:		mA	20	50	100	500	2000
		V	-				

Vse meritve in preizkusi so opravljene na sponkah v priključni omarici
All measurements and tests are carried out at terminals in the terminal cubicle.

Merilna oprema; Measuring equipment:

- močnosilni analizator Norma, tip D6000, točnost $\pm 0,05\%$; - power analyzer Norma, type D6000, accuracy $\pm 0,05\%$
- merilnik ohmske upornosti Raytech, tip Micro Junior 2, točnost $\pm 0,1\%$; - resistance meter Raytech, type Micro Junior 2, accuracy $\pm 0,1\%$
- merilnik prest. razmerja Haefely, tip VTR 2795, točnost $\pm 0,2\%$; - transformer turns ratio meter Haefely, type VTR 2795, accuracy $\pm 0,2\%$



KOLEKTOR
KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator; Transformer: **RT 40000-115,5** Tov. št.; Ser. No.: **78947**

19.0 MERITVE NA VGRAJENIH TOKOVNIH TRANSFORMATORJIH
MEASUREMENT ON BUILT-IN CURRENT TRANSFORMERS

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/1 A						
Moč; Power:	30 VA						
Klasa; Class:	5P20						
Fs							
Int. oznaka; Int. designation:	CT11						
Montiran v; Mounted in:	1U						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi: Measurements and tests:							
R [Ω]:	0,926						
R _{ISO} (at 1000VDC) [MΩ]:	40.100						
k:	250						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	18	51	94	145	200

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/1 A						
Moč; Power:	30 VA						
Klasa; Class:	5P20						
Fs							
Int. oznaka; Int. designation:	CT12						
Montiran v; Mounted in:	1V						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi: Measurements and tests:							
R [Ω]:	0,916						
R _{ISO} (at 1000VDC) [MΩ]:	35.200						
k:	250						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	18	51	94	145	200

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/1 A						
Moč; Power:	30 VA						
Klasa; Class:	5P20						
Fs							
Int. oznaka; Int. designation:	CT13						
Montiran v; Mounted in:	1W						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi: Measurements and tests:							
R [Ω]:	0,913						
R _{ISO} (at 1000VDC) [MΩ]:	36.600						
k:	250						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	18	51	94	145	200

Vse meritve in preizkusi so opravljene na sponkah v priključni omari
All measurements and tests are carried out at terminals in the terminal cubicle.

Merilna oprema; Measuring equipment:

- močnostni analizator Norma, tip D6000, točnost ± 0,05 %; - power analyzer Norma, type D6000, accuracy ± 0,05 %
- merilnik ohmske upornosti Raytech, tip Micro Junior 2, točnost ± 0,1 %; - resistance meter Raytech, type Micro Junior 2, accuracy ± 0,1 %
- merilnik prest. razmerja Heafely, tip TTR 2195, točnost ± 0,2 %; - transformer turns ratio meter Heafely, type TTR 2195, accuracy ± 0,2 %





KOLEKTOR
KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**

Tov. št.:
Ser. No.: **78947**

19.0 MERITVE NA VGRAJENIH TOKOVNIH TRANSFORMATORJIH
MEASUREMENT ON BUILT-IN CURRENT TRANSFORMERS

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/1 A						
Moč; Power:	10 VA						
Klasa; Class:	5P20						
Fs							
Int. oznaka; Int. designation:	CT14						
Montiran v; Mounted in:	1U						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi: Measurements and tests:							
R [Ω]:	0,928						
R _{iso} (at 1000VDC) [M Ω]:	27.900						
k:	250						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	18	51	94	145	200

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/1 A						
Moč; Power:	10 VA						
Klasa; Class:	5P20						
Fs							
Int. oznaka; Int. designation:	CT15						
Montiran v; Mounted in:	1V						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi: Measurements and tests:							
R [Ω]:	0,921						
R _{iso} (at 1000VDC) [M Ω]:	29.900						
k:	250						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	18	51	94	145	200

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/1 A						
Moč; Power:	10 VA						
Klasa; Class:	5P20						
Fs							
Int. oznaka; Int. designation:	CT16						
Montiran v; Mounted in:	1W						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi: Measurements and tests:							
R [Ω]:	0,910						
R _{iso} (at 1000VDC) [M Ω]:	30,100						
k:	250						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	18	51	94	145	200

Vse meritve in preizkusi so opravljene na sponkah v priključni omarici!
All measurements and tests are carried out at terminals in the terminal cubicle.

Merilna oprema; Measuring equipment:

- močnosilni analizator Norma, tip D6000, točnost $\pm 0,05\%$; - power analyzer Norma, type D6000, accuracy $\pm 0,05\%$
- merilnik ohmske upornosti Raytech, tip Micro Junior 2, točnost $\pm 0,1\%$; - resistance meter Raytech, type Micro Junior 2, accuracy $\pm 0,1\%$
- merilnik prest. razmerja Haefely, tip TTR 2795, točnost $\pm 0,2\%$; - transformer turns ratio meter Haefely, type TTR 2795, accuracy $\pm 0,2\%$

**KOLEKTOR**


KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA

TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**Tov. št.:
Ser. No.: **78947****19.0 MERITVE NA VGRAJENIH TOKOVNIH TRANSFORMATORJIH**
MEASUREMENT ON BUILT-IN CURRENT TRANSFORMERS**Podatki; Ratings:**


Tov. številka; Ser. No.: *see 15.0 - list of el. on transf.*
 Razmerje; Ratio: **250/1 A**
 Moč; Power: **30 VA**
 Klasa; Class: **5P20**
 Fs
 Int. oznaka; Int. designation: **CT17**
 Montiran v; Mounted in: **1N**
 Sponke; Terminals: **P1-P2 / S1-S2**
Meritve in preizkusi; Measurements and tests:
 R (Ω): **0,904**
 R_{ISO} (at 1000VDC) (M Ω): **34.400**
 k: **250**
 Polariteta; Polarity: **O.K.**

Magnetilna krivulja; Excitation curve: S1 - S2

mA	20	50	100	500	2000
V	18	51	94	145	200

Podatki; Ratings:

Tov. številka; Ser. No.: *see 15.0 - list of el. on transf.*
 Razmerje; Ratio: **250/1 A**
 Moč; Power: **30 VA**
 Klasa; Class: **5P20**
 Fs
 Int. oznaka; Int. designation: **CT18**
 Montiran v; Mounted in: **1N**
 Sponke; Terminals: **P1-P2 / S1-S2**
Meritve in preizkusi; Measurements and tests:
 R (Ω): **0,909**
 R_{ISO} (at 1000VDC) (M Ω): **37.500**
 k: **250**
 Polariteta; Polarity: **O.K.**

Magnetilna krivulja; Excitation curve: S1 - S2

mA	20	50	100	500	2000
V	18	51	94	145	200

Podatki; Ratings:

Tov. številka; Ser. No.:
 Razmerje; Ratio:
 Moč; Power:
 Klasa; Class:
 Fs
 Int. oznaka; Int. designation:
 Montiran v; Mounted in:
 Sponke; Terminals:
Meritve in preizkusi; Measurements and tests:
 R (Ω):
 R_{ISO} (at 1000VDC) (M Ω):
 k:
 Polariteta; Polarity:

Magnetilna krivulja; Excitation curve: S1 - S2

mA	20	50	100	500	2000
V	-				

Vse meritve in preizkusi so opravljeni na sponkah v priključni omarici
 All measurements and tests are carried out at terminals in the terminal cabinet.

Merilna oprema; Measuring equipment:

- močnostni analizator Norma, tip D6000, točnost ± 0,05 %; - power analyzer Norma, type D6000, accuracy ± 0,05 %
- merilnik ohmske upornosti Raytech, tip Micro Junior 2, točnost ± 0,1 %; - resistance meter Raytech, type Micro Junior 2, accuracy ± 0,1 %
- merilnik prest. razmerja Haefely, tip TTR 2795, točnost ± 0,2 %; - transformer turns ratio meter Haefely, type TTR 2795, accuracy ± 0,2 %



KOLEKTOR
KOLEKTOR ETRA d.o.o.

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**

Tov. št.:
Ser. No.: **78947**

19.0 MERITVE NA VGRAJENIH TOKOVNIH TRANSFORMATORJIH
MEASUREMENT ON BUILT-IN CURRENT TRANSFORMERS

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/2 A						
Moč; Power:	10 VA						
Klasa; Class:	3						
Fs	5						
Int. oznaka; Int. designation:	CT19						
Montiran v; Mounted in:	1U						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi; Measurements and tests:							
R [Ω]:	0,387						
R _{ISO} (at 1000VDC) [$M\Omega$]:	28.300						
k:	125						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	-	-	5	9	24

Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/2 A						
Moč; Power:	10 VA						
Klasa; Class:	3						
Fs	5						
Int. oznaka; Int. designation:	CT20						
Montiran v; Mounted in:	1V						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi; Measurements and tests:							
R [Ω]:	0,378						
R _{ISO} (at 1000VDC) [$M\Omega$]:	27.100						
k:	125						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	-	-	5	9	24


Podatki; Ratings:		Magnetilna krivulja; Excitation curve: S1 - S2					
Tov. številka; Ser. No.:	see 15.0 - list of el. on transf.						
Razmerje; Ratio:	250/2 A						
Moč; Power:	10 VA						
Klasa; Class:	3						
Fs	5						
Int. oznaka; Int. designation:	CT21						
Montiran v; Mounted in:	1W						
Sponke; Terminals:	P1-P2 / S1-S2						
Meritve in preizkusi; Measurements and tests:							
R [Ω]:	0,365						
R _{ISO} (at 1000VDC) [$M\Omega$]:	26.600						
k:	125						
Polariteta; Polarity:	O.K.	mA	20	50	100	500	2000
		V	-	-	5	9	24

Vse meritve in preizkusi so opravljeni na sponkah v priključni omarici
All measurements and tests are carried out at terminals in the terminal cubicle.

Merilna oprema; Measuring equipment:


- močnosilni analizator Norma, tip D6000, točnost $\pm 0,05\%$; - power analyzer Norma, type D6000, accuracy $\pm 0,05\%$
- merilnik ohmske upornosti Raytech, tip Micro Junior 2, točnost $\pm 0,1\%$; - resistance meter Raytech, type Micro Junior 2, accuracy $\pm 0,1\%$
- merilnik prest. razmerja Haefely, tip TTR 2795, točnost $\pm 0,2\%$; - transformer turns ratio meter Haefely, type TTR 2795, accuracy $\pm 0,2\%$

[Handwritten signature]


	KOLEKTOR KOLEKTOR ETRA d.o.o.	MERILNI LIST TRANSFORMATORJA TRANSFORMER TEST REPORT
	Transformator; Transformer: RT 40000-115,5	Tov. št.: Ser. No.: 78947

20.0 FREKVENČNA KARAKTERISTIKA TRANSFORMATORJA
FREQUENCY RESPONSE OF TRANSFORMER

20.1	Faza; Phase: 1U	Frekvenca; Frequency: 20 Hz - 2 MHz
Napajano; Supply: 1U - 1N	Pozicija stikala; Tap pos.: 1	Temperatura; Temperature: 21 °C
NN navitje; LV winding: odprto / open	TN navitje; TV winding: ...	



Before all measurements and tests!



Merilna oprema; Measuring equipment:
- frekvenčni analizator Tettec, tip FRA 5310;
- frequency analyzer Tettec, type FRA 5310

[Handwritten signature]

ELEKTROINŠTITUT AGLASIA VEMAR
Bojdnikova 2, 1000 Ljubljana, Slovenija

[Handwritten signature]

[Handwritten signature]



KOLEKTOR
KOLEKTOR ETRA d.o.o.


MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 40000-115,5**


Tov. št.:
Ser. No.: **78947**

20.0 FREKVENČNA KARAKTERISTIKA TRANSFORMATORJA
FREQUENCY RESPONSE OF TRANSFORMER

20.2 Faza; Phase: **1V** Frekvenca; Frequency: **20 Hz - 2 MHz**
Napajano; Supply: **1V - 1N** Pozicija stikala; Tap pos.: **1** Temperatura; Temperature: **21 °C**
NN navitje: **odprto / open** TN navitje: **---**
LV winding: **odprto / open** TV winding: **---**



Before all measurements and tests!



Merilna oprema; Measuring equipment:
- frekvenčni analizator Teltex, tip FRA 5310;
- frequency analyzer, Teltex, type FRA 5310

[Handwritten signature and stamp]

EMV

ELEKTROINŽNITUT AČLANA PAMAR
Hojkrtova 7, 1000 Ljubljana, Slovenija

	KOLEKTOR KOLEKTOR ETRA d.o.o.	MERILNI LIST TRANSFORMATORJA TRANSFORMER TEST REPORT
--	---	--


Transformator: Transformer:	RT 40000-115,5	Tov. št.: Ser. No.:	78947
--------------------------------	-----------------------	------------------------	--------------

20.0	FREKVENČNA KARAKTERISTIKA TRANSFORMATORJA FREQUENCY RESPONSE OF TRANSFORMER
-------------	--


20.3	Faza; Phase:	1W	Frekvenca; Frequency:	20 Hz - 2 MHz
------	--------------	-----------	-----------------------	----------------------

Napajano; Supply:	1W - 1N	Pozicija stikala; Tap pos.:	1	Temperatura; Temperature:	21 °C
-------------------	----------------	-----------------------------	----------	---------------------------	--------------

NN navitlje: LV winding:	odprto / open	TN navitlje: TV winding:	...
-----------------------------	----------------------	-----------------------------	------------



Before all measurements and tests!



Merilna oprema; Measuring equipment:
- frekvenčni analizator Tellex, tip FRA 5310;
- frequency analyzer Tellex, type FRA 5310



ELEKTROINŠTITUT MIROSLAV
HVALA
Hojskihova 7, 1000 Ljubljana

21.0 PREIZKUS SEGREVANJA; TEMPERATURE-RISE TEST

21.1 Tehnični podatki; Technical data:

Transformator tip: Transformer type:		RT 20000-110		Tovarniška št.: Serial No.:		74273		Št. načrta.: Draw. No.:		2966	
		VN-navitje HV-winding		NN-navitje LV-winding		Vezalna skupina: Connection symbol:		YNd5			
Nazivna moč: Rated power:		P_n [kVA]		20000		20000		Frekvenca: Frequency:		50 Hz	
Nazivna napetost: Rated voltage:		U_n [kV]		110		6,3		Število faz: No. of phases:		3	
Nazivni tok: Rated current:		I_n [A]		105,0		1832,9					
Hladilni medij: Dielectric type:		Nytro 10X		Tip hlajenja: Type of cooling:		ONAN / ONAF		Št. vent. / črpalk: No. fans / pumps:		2 / .	
Tip vent.: Fan type:		Shorman - SH 600-8		Tip črpalke: Pump type:		-		Tip hladilnika: Cooler type:		-6 x FG	

21.2 Predhodno merjeni podatki; Injection values:

Stopnja regulacijskega stikala pri segr.: Tap changer position at test:		19		ONAN		12 MVA	
Merjene izgube prostega teka Measured no load losses		P_0 [W]		12 149			
Merjene izgube kratkega stika pri 75 °C Measured load losses at 75 °C		P_k [W]		41 176			
Skupne izgube med preizkusom Injected total losses		P_{tot} [W]		53 325			
Nazivni tok VN navitja med preizkusom Injected current on HV winding		I_n [A]		78,7			
Nazivni tok NN navitja med preizkusom Injected current on LV winding		I_n [A]		1099,7			

21.3 Postopek preizkušanja; Test procedure:

Transformator se preizkuša po metodi kratkega stika.
The transformer is tested according to short-circuit method.

1 Transformator bremenimo s skupnimi izgubami (P_{tot}), dokler ne dosežemo temperaturne stabilizacije olja, kot jo predpisuje standard.
The transformer is loaded with total losses (P_{tot}) until a steady - state oil temp. rise is established according to standard.

2 Po temperaturni stabilizaciji olja, navitje napajamo z nazivnim tokom (I_n) približno 1 uro.
After a steady - state of oil rated current (I_n) is maintained constant for about 1 hour.

3 Po odklopu napajanja, posnamemo ohlajevalno krivuljo navitja in določimo srednjo nadtemperaturo navitja za vsako navitje posebej.
After shutdown, cooling curve is recorded and average winding temperature rise is determined for each winding separately.

Preizkus je opravljen po priporočilih standarda SIST EN 60076-2 in po internih navodilih LO-8201.
The test is performed according to Standard IEC 60076-2 and internal test procedure LO-8201.

ELEKTROINŠTITUT MILAN VIDMAR Hajdrihova 2, 1000 Ljubljana, Slovenija	Meritve opravil: Tested by: Franc Štampelj Ljubljana: 24. junij 2004
--	--


[Handwritten signature]

TEST REPORT


Impulse Analysing System by Heafely Test AG




Page: 8; Tr. No.: 78947; Terminal: 2V; Tap. pos.: --




No. 24 LI full Upk: -37.477 kV T1: 1.266 us T2: 53.104 us




No. 24 LI full Ipk max: -34.668 A Ipk min: 5.029 A




No. 25 LI full Upk: -76.129 kV T1: 1.255 us T2: 53.045 us




No. 25 LI full Ipk max: -71.975 A Ipk min: 12.793 A




No. 26 LI full Upk: -74.817 kV T1: 1.264 us T2: 53.139 us



No. 26 LI full Ipk max: -73.439 A Ipk min: 29.932 A



No. 27 LI full Upk: -75.178 kV T1: 1.266 us T2: 53.121 us



No. 27 LI full Ipk max: -69.555 A Ipk min: 9.814 A

[Handwritten signature]

FLEKTROINSTITUT MELAN
Hajdubova 7, 19000 Praha 2, C.R.

[Handwritten signature]

[Large handwritten signature]


[Handwritten signature]

TEST REPORT


Impulse Analysing System by Heafely Test AG




Page: 9; Tr. No.: 78947; Terminal: 2W; Tap. pos.: --




No. 28 LI full Upk: -37.392 kV T1: 1.272 us T2: 53.294 us




No. 28 LI full Ip k max: -35.166 A Ip k min: 5.273 A




No. 29 LI full Upk: -75.474 kV T1: 1.276 us T2: 62.611 us




No. 29 LI full Ip k max: -71.631 A Ip k min: 10.400 A




No. 30 LI full Upk: -74.827 kV T1: 1.274 us T2: 62.708 us



No. 30 LI full Ip k max: -71.240 A Ip k min: 25.536 A



No. 31 LI full Upk: -75.142 kV T1: 1.259 us T2: 62.877 us



No. 31 LI full Ip k max: -69.233 A Ip k min: 10.254 A

EMV

ELEKTROINSTITUT MEANV
Hofstraße 2, 1000 Ljag, 5




21.4 Rezultati segrevanja; Measured results:

Temperaturna stabilizacija olja s skupnimi izgubami - Steady - state of oil with total losses

	[K]	Izmerjeno Measured	Korekcija Corr.	Garant. Guaran.	
Maksimalna nadtemperatura olja Top oil temperature rise	[K]	45.7		60.0	$\Delta\theta_{ir} = \theta_{ir} - \theta_a$
Srednja nadtemperatura olja (P ₁₀₁) Average oil temperature rise (P ₁₀₁)	[K]	36.8		--	$\Delta\theta_{avr} = \Delta\theta_{ir} - ((\theta_{ir} - \theta_{br})/2)$

Temperaturna stabilizacija navitij z nazivnim tokom - Steady - state of windings with rated current

Srednja nadtemperatura olja (I _n) Average oil temperature rise (I _n)	[K]	35.6		--	$\Delta\theta_{avr2} = \Delta\theta_{ir2} - ((\theta_{ir2} - \theta_{br2})/2)$
Temp. razlika navitje-olja srednje (VN) Temp. difference winding to oil average (LV)	[K]	12.9			$\Delta\theta_{wor} = \Delta\theta_2 - \Delta\theta_{avr2}$
Srednja nadtemperatura navitja (VN) Average winding temperature rise (LV)	[K]	49.7		65.0	$\Delta\theta_{wr} = \Delta\theta_{wor} + \Delta\theta_{avr}$
Temp. razlika navitje-olja srednje (NN) Temp. difference winding to oil average (LV)	[K]	7.2			$\Delta\theta_{wor} = \Delta\theta_2 - \Delta\theta_{avr2}$
Srednja nadtemperatura navitja (NN) Average winding temperature rise (LV)	[K]	44.0		65.0	$\Delta\theta_{wr} = \Delta\theta_{wor} + \Delta\theta_{avr}$
Temp. razlika navitje-olja srednje Temp. difference winding to oil average	[K]				$\Delta\theta_{wor} = \Delta\theta_2 - \Delta\theta_{avr2}$
Srednja nadtemperatura navitja Average winding temperature rise	[K]				$\Delta\theta_{wr} = \Delta\theta_{wor} + \Delta\theta_{avr}$



[Handwritten signature]



ELEKTROINŽINIR MILAN VIDMAR
Hajdrihova 2, 1000 Ljubljana, Slovenija

[Handwritten signature]


[Handwritten signature]



ETRA 33
ENERGETSKI TRANSFORMATORJI d.d.
Ljubljana - SLOVENIJA

POROČILO - TEST REPORT
07 / 2004

21.4 Temperature curves oil - ambient; Temperature curves oil - ambient													
čas time	merilne točke; measuring point								rezultati; results				opombe; note
	1 žep	2 rad.-zg.	3 rad.-sp.	4 rad.-zg.	5 rad.-sp.	6 amb. 1	7 amb. 2	8 amb. 3	(6/7/8) ambient	(2,3-4,5) raz. rad.	hadtemp t rise	razlika df. t rise	
h	°C	°C	°C	°C	°C	°C	°C	°C	°C	°C	K	K	
0	36.0	48.4	29.2	34.4	28.5	26.1	26.2	25.8	26.0				##
	40.2	38.0	29.9	38.2	30.4	26.1	26.2	25.8	26.0	8.0			1.2 In
1	52.2	48.7	33.7	48.8	34.0	26.2	26.3	25.8	26.1	14.9	26.1		1.2 In
	61.7	57.6	39.7	57.5	39.2	26.2	26.3	25.8	26.1	18.1	35.6	9.5	1.2 In
2	69.7	65.3	45.7	65.2	44.4	26.2	26.4	25.9	26.2	20.2	43.5	7.9	1.2 In
	76.2	71.5	51.4	71.3	49.6	26.3	26.4	26.0	26.2	20.9	50.0	6.4	1.2 In
3	81.6	76.6	56.3	76.7	54.1	26.4	26.6	26.1	26.4	21.5	55.2	5.3	1.2 In
	82.9	77.9	58.2	77.6	55.0	26.7	26.8	26.4	26.6	21.2	56.3	1.0	Plot + fans
4	80.5	76.0	56.8	75.4	53.9	26.8	27.0	26.5	26.8	20.4	53.7	-2.5	Plot + fans
	78.4	74.0	55.5	73.5	52.4	26.9	27.3	26.7	27.0	19.8	51.4	-2.3	Plot + fans
5	75.5	71.6	54.0	71.2	51.1	27.0	27.4	26.8	27.1	18.9	48.4	-3.0	Plot + fans
	74.7	70.5	53.4	70.3	50.8	27.1	27.5	27.0	27.2	13.8	47.5	-0.9	Plot + fans
6	74.0	69.7	53.0	69.5	50.1	27.4	27.6	27.1	27.4	18.1	46.6	-0.9	Plot + fans
	73.6	69.2	52.7	68.8	49.6	27.5	27.7	27.2	27.5	17.9	46.1	-0.5	Plot + fans
7	73.2	68.8	52.3	68.5	49.6	27.6	27.7	27.2	27.5	17.7	45.7	-0.4	Plot + fans
	72.5	68.2	51.9	68.1	49.3	27.7	27.8	27.3	27.6	17.6	44.9	-0.8	In
8	71.9	67.6	51.4	67.6	48.9	27.7	28.0	27.4	27.7	17.5	44.2	-0.7	In
9													
10													
11													
12													



[Handwritten signature]

ETRA
ELEKTROINŠTITUT MIHAN VIDMAR
Hajdrihova 2, 1000 Ljubljana, Slovenija



ETRA 33
ENERGETSKI TRANSFORMATORJI d.d.
Ljubljana - SLOVENIJA

POROČILO - TEST REPORT



07 / 2004

21.5.1 Upornost merjena po končanem segrevanju (ONAN) Resistance measured after finished temp. rise (ONAN)

Št. No.	VN navitje; HV winding			NN navitje; LV winding		
	[s]	[Ω]	[K]	[s]	[Ω]	[K]
1	69.1	2.688489	47.85	70.5	0.006598	42.02
2	129.1	2.684153	47.41	130.5	0.006592	41.83
3	189.1	2.679868	46.85	190.5	0.006577	41.07
4	249.1	2.675954	46.40	250.5	0.006563	40.43
5	309.1	2.672501	46.07	310.5	0.006554	40.08
6	369.1	2.669042	45.60	370.5	0.006549	39.78
7	429.1	2.665759	45.23	430.5	0.006539	39.30
8	489.1	2.662669	44.87	490.5	0.006533	39.05
9	549.1	2.659756	44.53	550.5	0.006523	38.57
10	609.1	2.656843	44.20	610.5	0.006519	38.41
11	669.1	2.654300	43.90	670.5	0.006513	38.11
12	729.1	2.651478	43.58	730.5	0.006502	37.63
13	789.1	2.648833	43.27	790.5	0.006497	37.38
14	849.1	2.646375	42.99	850.6	0.006498	37.44
15	909.1	2.643917	42.77	910.5	0.006488	37.03
16	969.1	2.641732	42.45	970.5	0.006479	36.53
17	1029.1	2.639735	42.22	1030.6	0.006484	36.76
18	1089.1	2.637272	41.94	1090.5	0.006478	36.48
19	1149.2	2.635269	41.70	1150.6	0.006473	36.26
20	1209.1	2.633266	41.47	1210.5	0.006466	35.92

21.5.2 Ohlajevalna krivulja navitja (ONAN) Temperature curve of winding (ONAN)

	VN navitje HV winding	NN navitje LV winding		
$\theta_1 =$	26.9	26.9	[°C]	- temperatura navitja v hladnem stanju - cold winding resistance temperature
$R_1 =$	2.267 513	0.005 671	[Ω]	- hladna upornost navitja - cold winding resistance
$R_2 =$	2.453 355	0.006 014	[Ω]	- upornost navitja po izklopu - winding resistance at shut - down
$\Delta\theta_2 =$	48.4	42.7	[K]	- srednja nadtemperatura navitja - average winding temperature rise
$T_{au} =$	24.1	16.3	[min]	- termična časovna konstanta navitja - winding time constant
$g_r =$	12.2	9.5	[K]	- temperatura razlika navitje-olja - winding-oil temperature difference



07-04.doc / 3> 24.08.04

LM2101 / M> F.S. 11.09.97 - Verzija 4 (04.12.03)

ETRA
4/6

ELEKTROINŽENJER MIJAN VIDMAR
Hojčičeva 2, 1000 Ljubljana, Slovenija



21.6 Določitev temperature olja in navitja; Determination of the oil and winding temperature:

θ_a - Merjenje temperature okolice. Measurement of the ambient temperature.

Vrednost je povprečje 3 merilnih sond (2,3,4), lociranih 1 - 2 m od površine hladilnega sistema in na polovici višine hladilnega sistema. Pri WF hlajenjih merimo temperaturo hladilne vode na vstopu v hladilnik.

By means of 3 thermocouples (2,3,4), placed at 1 - 2m from the cooling surface, at half height of the cooling system. At WF cooling the temperature of water at entrance in cooler is measured.

θ_{or} - Merjenje maksimalne temperature olja. Top oil temperature measurement.

Vrednost je odčitana iz merilne sonde locirane v žepu na pokrovu transformatorja.

By means of thermocouple placed in pocket on the cover.

$\Delta\theta_{or}$ - Maksimalna nadtemperatura olja. Top oil temperature rise.

$$\Delta\theta_{or} = \theta_{or} - \theta_a$$

r - predstavlja veličine pri nazivni moči. Indicates rated quantity.

Če med preizkusom ni možno doseči skupnih izgub, se izvrši korekcija maksimalna nadtemperatura olja po naslednji enačbi:

$\Delta\theta_{or}$ nova korigirana nazivna vrednost (K)-new corrected rated value

$\Delta\theta_o$ - izmerjena vrednost (K) - measured value

X=1,0 za OF., all OD., način hlajenja - OF., or OD., cooling

X=0,9 za ON., način hlajenja - ON., cooling

X=0,8., distr. tr. pri $P_N \leq 2.5$ MVA - distr. tr. at $P_N \leq 2.5$ MVA

If the specified values of total losses have not been obtained during the test, the results shall be corrected according to the following relations:

$$\Delta\theta_{or} = \Delta\theta_o \left(\frac{\text{total_losses}}{\text{test_losses}} \right)^x$$

θ_{ir} θ_{br} - Merjenje temperature vstopnega in izstopnega olja hladilnega sistema.

Top and bottom oil cooler temperature measurement.

V primeru kadar gre za hladilni aparat sestavljen iz več radiatorjev ali hladilnikov se vrednosti merita z dvema termo sondama: θ_{br} (št. 5,6) in θ_{ir} (št. 7,8). Termosondi (št. 5,6) sta locirani na izhodu iz hladilnega sistema in merita temperaturo izstopnega olja iz hladilnega sistema θ_{br} . Termosondi (št. 7,8) sta locirani na vhodu v hladilni sistem in merita temperaturo vstopnega olja v hladilni sistem θ_{ir} .

If several batteries of cooling equipment are fitted, two thermocouples are used: θ_{br} (No 5,6) and θ_{ir} (No 7,8). The bottom oil temperature θ_{br} is determined by thermocouples (No 5,6) fitted in the return headers from coolers or radiators. The oil temperature θ_{ir} is determined by thermocouples (No 7,8) fitted in the inlet headers from coolers or radiators.

$\Delta\theta_{avr}$ - Srednja nadtemperatura olja: Average oil temperature rise.

$$\Delta\theta_{avr} = \theta_{or} - \left(\frac{\theta_{ir} - \theta_{br}}{2} \right) - \theta_a$$

Za distribucijske transformatorje moči $\leq 2,5$ MVA s hlajenjem OHAN, z zalovlim koškom, oziroma z neločljivim hladilnim aparatom se lahko srednja

nadtemperatura olja določi po enostavni relaciji: $\Delta\theta_{avr} = 0,8 \theta_{or}$.

For ONAN transformers up to 2,5 MVA, with plain or corrugated tanks or individual cooling tubes mounted directly on the tank, the average oil temperature rise above ambient air temperature may be taken 80% of the top oil temperature rise.

Po temperaturni stabilizaciji olja preizkus nadaljujemo tako, da tok znižamo na nazivno vrednost. To stanje vzdržujemo 1 uro in medtem merimo temperaturo olja in okolice.

Po pretečeni uri izmerimo ohmske upornosti navitij.

When the top oil temperature rise has been established, the test was immediately continued with the test current, reduced to rated current for the winding combination connected. This condition is maintained for 1 hour, with continuous observation of oil and cooling medium temperature. At the end of the hour, the resistances of the windings were measured.

$\Delta\theta_{wr}$ - Določitev srednje nadtemperature navitja. Determination of the average winding temperature rise.

Ohmska upornost se meri v trajanju 20 min po izklopu transformatorja. Vrednosti se avtomatično ekstrapolirajo na čas izklopa transformatorja $t = 0$, s pomočjo numeričnega računalniškega izračuna.

The winding resistance is measured in duration of 20 min. after transformer shutdown. With automatic extrapolation curve, values at the time of transformer shutdown $t = 0$ are defined by using a numerical method of extrapolation.

$$\theta_2 = \frac{R_2}{R_1} (235 + \theta_1) - 235$$


R_1 - ohmska upornost navitja pri θ_1 - winding resistance at θ_1

R_2 - ohmska upornost navitja pri θ_2 - winding resistance at θ_2

$\Delta\theta_{w0r}$ - Izračun temperaturne razlike navitje-olja srednje. Calculation of temperature difference winding to oil average.

$$\Delta\theta_{w0r} = \theta_2 - \theta_{avr2}$$

Kjer je θ_{avr2} srednja temperatura olja na koncu stabilizacije navitja z nazivnim tokom.



Where the θ_{or2} represents average temperature of oil at the end of rated current injection.

$$\theta_{wr2} = \theta_{or2} - \left(\frac{\theta_{lr2} - \theta_{br2}}{2} \right)$$

Če med preizkusom ni možno doseči nazivnega toka, se izvrši korekcija temperature razlike navitje-olja srednje po naslednji enačbi:
 If the specified values of rated current have not been obtained during the test, the results shall be corrected according to the following relations:

$$\Delta\theta_{wr} = \Delta\theta_{wr0} \left(\frac{\text{rated_current}}{\text{test_current}} \right)^y$$

$\Delta\theta_{wr}$ - nova korigirana vrednost (K) -- new corrected value (K)
 $\Delta\theta_{wr0}$ - izmerjena vrednost (K) -- measured value (K)
 $y = 2.0$ za OD., način hlajenja -- for OD., cooling
 $y = 1.6$ za ON., in OF način hlajenja -- for ON., and OF., cooling

$\Delta\theta_{wr}$ - Srednja nadtemperatura navitja. Average temperature of winding.

$$\Delta\theta_{wr} = \Delta\theta_{wr0} + \Delta\theta_{mr}$$

$\Delta\theta_{hr}$ - Nadtemperatura najtoplejše točke. Hot-spot temperature rise.

$$\Delta\theta_{hr} = \Delta\theta_{or} + H g_r$$

$H = 1,1$ distr. trans. ONAN $\leq 2,5$ MVA
 $H = 1,3$ trans. $> 2,5$ MVA

Kjer je g_r temperaturna razlika navitje-olja. Where the g_r represents winding to oil temperature difference.

$$g_r = \theta_2 - \theta_0$$

θ_2 - temperatura navitja v trenutku odklopa. The winding (extrapolated) temperature at instant of shutdown.

θ_0 - srednja ekstrapolirana temperatura olja v navitju. Average extrapolated temp. of the cooling oil in the windings.

21.7 Merilna oprema; Measuring equipment:

Merilna oprema; Measuring equipment:

- širokopasovni močnosni analizator Norma, tip D6000, točnosti ± 0.05 %
- wide band power analyzer Norma, type D6000, accuracy ± 0.05 %
- merilni tokovni in napetostni transformatorji CdC, točnosti ± 0.2 %
- measuring current and voltage transformer CdC, accuracy ± 0.2 %
- merilnik ohmske upornosti Teltex, tip 2283, točnosti ± 0.06 %
- resistance meter Teltex, type 2283, accuracy ± 0.06 %

ELEKTROINŽITUT ARIAN LEMBE
 Hojdrihova 2, 1000 Ljubljana, Slovenija

**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

POROČILO - TEST REPORT

61 / 2012

**21.0 PREIZKUS SEGREVANJA
TEMPERATURE-RISE TEST**

- IEC 60076-2

Tehnični podatki:

Technical data:

Transformator tip: Transformer type:	RT 40000-115,5	Tovarniška št.: Serial No.:	78947	Št. načrta: Draw. No.:	3447
Vezna skupina: Vector group:	YNd5	Število faz: No. of phases:	3	Frekvenca: Frequency:	50 Hz

Navitlje: Winding:	VN - HV	NN - LV			
Nazivna moč: Rated power:	[kVA] 40.000	40.000			
Nazivna napetost: Rated voltage:	[kV] 115,5	11			
Nazivni tok: Rated current:	[A] 199,9	2.100			
Hladilni medij: Dielectric type:	Shell Dials S3 ZX-I		Tip hlajenja: Type of cooling:	ONAN / ONAF	
Tip hladilnika: Cooler type:	12 x FG 1100x15		Št. vent. / črpalk: No. fans / pumps:	4 / --	
Tip vent. / Fan type:	Klima - AVS 630		Tip črpalke: Pump type:	--	

Predhodno merjeni podatki:

Injection values:

Stopnja regulacijskega stikala pri segr.: Tap changer position at test:	17	ONAF	
		40 MVA	
Merjene izgube praznega teka: Measured no load losses:	P_0	[W]	24.527
Merjene izgube kratkega stika pri 75 °C: Measured load losses at 75 °C:	P_k	[W]	145.756
Skupne izgube med preizkusom: Injected total losses:	P_{tot}	[W]	170.283
Tok VN navitja med preizkusom: Current on HV winding:	I_n	[A]	222,2
	I_n	[A]	
Tok NN2 navitja med preizkusom: Current on LV2 winding:	I_n	[A]	2.100

OPOMBE:

NOTE:

J. J. J.

ETRA

ELEKTROINSTITUT M...
Hodkova 7, 1000 Ljubljana

Meritve opravil:

Tested by: **Franc Stempelj
Primož Dimnik**

Ljubljana:

2012-12-07**KOLEKTOR ETRA Energetski transformatorji d.o.o.**

Štandrova 10, 1001 Ljubljana, p.p.: 4956, Slovenija

tel. ++386 1 5302 800, fax. ++386 1 5302 830, http://www.etra33.si

SI-61-12.dco/2-07/12/2012

E-IM2101 / s. P.S. 11.09.97 - Verzija 5 (16.08.04) 1231 Ljubljana - Gmufca, Slovenija

KOLEKTOR ETRA d.o.o.

Štandrova ulica 10

1 / 5



KOLEKTOR
KOLEKTOR ETRA d.o.o.

POROČILO - TEST REPORT

61 / 2012

Rezultati segrevanja - ONAF:

Measured results - ONAF:

Temperaturna stabilizacija olja s skupnimi izgubami - Steady - state of oil with total losses


			Izmerjeno Measured	Korekcija Corrected	Garant. Guaran.	
Maksimalna nadtemperatura olja: Top oil temperature rise:	$\Delta\theta_o$	[K]	47,9		$\leq 60,0$	$\Delta\theta_o = \theta_o - \theta_a$
Srednja nadtemperatura olja (P_{100}): Average oil temperature rise (P_{100}):	$\Delta\theta_{om}$	[K]	39,9		--	$\Delta\theta_{om} = \Delta\theta_o - ((\theta_o - \theta_b)/2)$

Temperaturna stabilizacija navitij z nazivnim tokom - Steady - state of windings with rated current

			Izmerjeno Measured	Korekcija Corrected	Garant. Guaran.	
Srednja nadtemperatura olja (I_n) (VN): Average oil temperature rise (I_n) (HV):	$\Delta\theta_{om'}$	[K]	39,0		--	$\Delta\theta_{om'} = \Delta\theta_o' - ((\theta_o' - \theta_b')/2)$
Temp. razlika nav.- olje srednje (VN): Average winding gradient (HV):	g	[K]	17,1		--	$g = \Delta\theta_w - \Delta\theta_{om'}$
Srednja nadtemperatura navitja (VN): Average winding temperature rise (HV):	$\Delta\theta_w$	[K]	57,0		$\leq 65,0$	$\Delta\theta_w = \Delta\theta_m + g$
Nadtemperatura najtoplejšje točke (VN): Hot-spot temperature rise (HV):	$\Delta\theta_h$	[K]	66,7		$\leq 78,0$	$\Delta\theta_h = \Delta\theta_o + (g * H)$
Faktor najtoplejšje točke (VN): Hot-spot faktor (HV):	H		1,10		--	računska vrednost (IEC 60076-2) calculated value (IEC 60076-2)

	$\Delta\theta_{om'}$	[K]			--	$\Delta\theta_{om'} = \Delta\theta_o' - ((\theta_o' - \theta_b')/2)$
	g	[K]			--	$g = \Delta\theta_w - \Delta\theta_{om'}$
	$\Delta\theta_w$	[K]			$\leq 65,0$	$\Delta\theta_w = \Delta\theta_m + g$
	$\Delta\theta_h$	[K]			$\leq 78,0$	$\Delta\theta_h = \Delta\theta_o + (g * H)$
	H				--	računska vrednost (IEC 60076-2) calculated value (IEC 60076-2)

Srednja nadtemperatura olja (I_n) (NN): Average oil temperature rise (I_n) (LV):	$\Delta\theta_{om'}$	[K]	39,0		--	$\Delta\theta_{om'} = \Delta\theta_o' - ((\theta_o' - \theta_b')/2)$
Temp. razlika nav.- olje srednje (NN): Average winding gradient (LV):	g	[K]	15,5		--	$g = \Delta\theta_w - \Delta\theta_{om'}$
Srednja nadtemperatura navitja (NN): Average winding temperature rise (LV):	$\Delta\theta_w$	[K]	55,4		$\leq 65,0$	$\Delta\theta_w = \Delta\theta_m + g$
Nadtemperatura najtoplejšje točke (NN): Hot-spot temperature rise (LV):	$\Delta\theta_h$	[K]	65,7		$\leq 78,0$	$\Delta\theta_h = \Delta\theta_o + (g * H)$
Faktor najtoplejšje točke (NN): Hot-spot faktor (LV):	H		1,15		--	računska vrednost (IEC 60076-2) calculated value (IEC 60076-2)



$\Delta\theta_o$ top-liquid temperature rise
 $\Delta\theta_{om}$ average-liquid temperature rise
 $\Delta\theta_b$ bottom-liquid temperature rise
 $\Delta\theta_w$ average-winding temperature rise at the instant of shutdown
 $\Delta\theta_h$ hot-spot winding temperature rise
 g average thermal gradient between winding and liquid
 H hot-spot factor



KOLEKTOR

KOLEKTOR ETRA d.o.o.


POROČILO - TEST REPORT

61 / 2012

Temperaturne krivulje olje - ambient

Temperature curves oil - ambient

čas Time h	merilne točke; measuring point								rezultati; results				opombe; note		
	1	2	3	4	5	6	7	8	(6/7)	(2,3-4,5)			infet value	Cooling method	Cooler system
	žep pocel t θ _o	rad.-zg r.-top θ _o	rad.-sp r.-bot θ _b	rad.-zg r.-top θ _o	rad.-sp r.-bot θ _b	amb_1 θ _a	amb_2 θ _a	amb_3 θ _a	amb θ _a	az. rad Δθ _{om}	radtemp Δθ _o	razlika Δ			
	°C	°C	°C	°C	°C	°C	°C	°C	°C	°C	K	K			
0:00	22,7	22,4	21,0	21,8	21,1	20,9	20,8	20,4	20,7				##		
0:30	30,6	27,5	21,0	26,8	21,1	20,9	20,9	20,5	20,8	6,0	9,8		Plot (170,3kW)	ONAF	closed
1:00	50,5	42,9	22,3	41,9	22,8	21,1	21,0	20,6	20,9	19,9	29,6	19,8	Plot (170,3kW)	ONAF	closed
1:30	65,3	55,3	24,3	53,9	25,3	21,4	21,4	20,9	21,2	29,8	44,1	14,5	Plot (170,3kW)	ONAF	closed
2:00	73,9	61,9	47,3	64,0	45,3	23,4	21,9	21,2	22,2	16,7	51,7	7,7	Plot (170,3kW)	ONAF	open
2:30	72,4	60,3	46,2	62,6	44,8	25,2	22,5	22,9	23,5	16,0	48,9	-2,9	Plot (170,3kW)	ONAF	open
3:00	72,1	60,1	46,1	62,4	44,7	25,5	22,4	23,4	23,8	15,9	48,3	-0,5	Plot (170,3kW)	ONAF	open
3:30	71,9	60,0	46,0	62,2	44,5	25,8	22,5	23,7	24,0	15,9	47,9	-0,4	Plot (170,3kW)	ONAF	open
4:00	71,9	60,0	46,0	62,3	44,5	26,1	22,6	24,2	24,3	15,9	47,6	-0,3	Plot (170,3kW)	ONAF	open
4:30	72,2	60,2	46,2	62,2	44,7	26,4	22,8	24,5	24,6	15,8	47,6	0,0	Plot (170,3kW)	ONAF	open
5:00	72,4	60,5	46,2	62,4	44,7	26,5	22,8	24,6	24,6	16,0	47,8	0,1	Plot (170,3kW)	ONAF	open
5:30	72,6	60,7	46,5	62,5	44,8	26,6	22,9	24,6	24,7	16,0	47,9	0,1	Plot (170,3kW)	ONAF	open
6:00	71,8	59,6	45,7	61,7	44,0	26,3	23,0	24,2	24,5	15,8	47,3	-0,6	In (222,2A)	ONAF	open
6:30	71,0	58,5	45,3	61,1	44,0	26,3	22,9	24,2	24,5	15,2	46,5	-0,8	In (222,2A)	ONAF	open
7:00															
7:30															
8:00															
8:30															
9:00															
9:30															
10:00															
10:30															
11:00															
11:30															
12:00															
12:30															
13:00															
13:30															
14:00															



**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

POROČILO - TEST REPORT

61 / 2012

Upornost merjena po končanem segrevanju - ONAF:

Resistance measured after finished temp. rise - ONAF:


Št. No.	VN navitje HV winding				NN navitje LV winding			
	t [s]	R ₂ [Ω]	ΔR ₂ [Ω]	Δθ _{wr} [K]	t [s]	R ₂ [Ω]	ΔR ₂ [Ω]	Δθ _{wr} [K]
0	0,0				0,0			
1	73,5	1,033821		54,63	77,3	0,008619		52,12
2	103,5	1,031535		53,94	107,0	0,008587		50,97
3	133,5	1,029497		53,32	137,3	0,008555		49,81
4	163,5	1,027388		52,68	167,3	0,008532		48,98
5	193,5	1,025409		52,08	197,3	0,008509		48,13
6	223,5	1,023609		51,56	227,3	0,008482		47,16
7	253,5	1,021774		50,97	257,3	0,008466		46,58
8	283,5	1,020110		50,47	287,3	0,008444		45,79
9	313,5	1,018537		49,99	317,3	0,008431		45,33
10	343,5	1,016988		49,52	347,3	0,008415		44,73
11	373,5	1,015444		49,05	377,6	0,008400		44,20
12	403,5	1,014050		48,63	407,3	0,008385		43,66
13	433,5	1,012632		48,20	437,2	0,008369		43,08
14	463,5	1,011308		47,79	467,2	0,008357		42,65
15	493,5	1,010060		47,42	497,2	0,008349		42,36
16	523,5	1,008832		47,04	527,2	0,008335		41,84
17	553,5	1,007634		46,68	557,2	0,008325		41,53
18	583,5	1,006436		46,31	587,2	0,008317		41,21
19	613,5	1,005328		45,98	617,2	0,008304		40,76
20	643,5	1,004270		45,66	647,5	0,008301		40,61
21	673,5	1,003192		45,33	677,2	0,008290		40,20
22	703,5	1,002235		45,04	707,2	0,008285		40,02
23	733,5	1,001232		44,73	737,2	0,008276		39,73
24	763,5	1,000215		44,42	767,5	0,008267		39,38
25	793,5	0,999287		44,18	797,5	0,008258		39,05
26	823,5	0,998370		43,90	827,1	0,008252		38,87
27	853,5	0,997528		43,64	857,1	0,008246		38,66
28	883,5	0,996655		43,38	887,5	0,008239		38,41
29	913,5	0,995798		43,12	917,5	0,008232		38,17
30	943,5	0,994951		42,86	947,1	0,008226		37,93
31	973,5	0,994179		42,62	977,1	0,008222		37,80
32	1003,5	0,993417		42,39	1007,1	0,008220		37,73
33	1033,5	0,992615		42,15	1037,4	0,008212		37,45
34	1063,5	0,991838		41,91	1067,4	0,008204		37,13
35	1093,5	0,991081		41,68	1097,1	0,008203		37,09
36	1123,5	0,990439		41,49	1127,0	0,008196		36,86
37	1153,5	0,989672		41,25	1157,4	0,008188		36,59
38	1183,5	0,988980		41,08	1187,7	0,008187		36,58
39								
40								

ELEKTROINŽENIR
Hojnikova 2, 1000 Lj.




Ohlajevalna krivulja navitja - ONAF:
Winding cooling curve - ONAF:

	VN HV	NN LV			
$\theta_1 =$	24,1	24,1			[°C] - Temperatura navitja v hladnem stanju - Cold winding temperature
$R_1 =$	0,852871	0,007168			[Ω] - Hladna upornost navitja - Cold winding resistance
	1U - 1V	2U - 2V			[] - Upornost merjena na sponkah - The resistance measured on the terminals
$R_2 =$	1,034242	0,008648			[Ω] - Upornost navitja po izklopu - Winding resistance at shut - down
$\Delta\theta_w =$	56,1	54,5			[K] - Srednja nadtemperatura navitja po izklopu - Average winding temperature rise at shut-down
$A_0 =$	36,0	34,8			[K] - Ocenjena srednja nadtemperatura olja - Estimated average oil temperature
$T_w =$	14,6	8,6			[min] - Ocenjena termična časovna konstanta navitja - Estimated winding time constant
$\Delta t =$	0,5	0,5			[min] - Časovni interval - Time interval



Ekstrapolacija ohlajevalne krivulje (VN navitje)
Extrapolation of the cooling down curve (HV winding)



Ekstrapolacija ohlajevalne krivulje (NN navitje)
Extrapolation of the cooling down curve (LV winding)



ELEKTROINŠTITUT MIHARJEV
Hojskova 2, 1000 Ljubljana, Slovenija


[Handwritten signature]

22.0 PREIZKUS Z UDARNO NAPETOSTJO; IMPULSE VOLTAGE TEST

Tehnični podatki; Technical data:

Transformator tip : Transformer type :	RT 20000-110	Tovarniška št. : Serial No. :	74273	Št. načrta : Draw. No. :	2966
Navilje; Winding:					
	VN - HV	NN - LV			
Nazivna moč; Nominal power:	[kVA] 20 000	20 000			
Nazivna napetost; Rated voltage:	[kV] 110	6.3			
Stopnja izolacije; Isolation level:	LI/AC 550/230	LI/AC 75/28			
Udarne napetost; Impulse test voltage:	[kV] 550	75			
Položaj stikala; Tap changer position:	1, 8, 19	-			
Vezna skupina; Vector group:	YNd5	Frekvenca; Frequency:	50 Hz	Število faz; No. of phases:	3
Oblika vala; Wave form:	[μs] 1.2/50	Temperatura; Temperature:	[°C] 24		
Zračni tlak; Air pressure:	[kPa]				

22.1 Osnovna vezava udarnega kroga; Typical impulse test circuit:



		za VN for HV	za NN for LV
polariteta; polarity		neg.	neg.
Ug	[kV]	1200 / 600	1200 / 200
Par. / ser.	[]	1 / 6	3 / 2
Cs stage	[μF]	1.0	3.0
Rf stage	[Ω]	12	12
Rl stage	[Ω]	1 x 75	2 x 75
Ro + Lk	[Ω, μH]	150 / -	150 / -
D	[kV]	1200	1200
k (D)		956	956
S	[Ω]	1.0	1.0 + 400
S - priključen; connected		1N	2U - 2V - 2W
polnilna nap.; charge volt.	[kV]	47.0 / 95.0	28.0 / 56.0
razmak iskr.; sphere gap dist.	[mm]	20.2 / 44.0	11.1 / 24.2

Meritve opravil:
Tested by:

Franz Stampelj

Ljubljana:

22. junij 2004


[Signature]

ELEKTROINŠTITUT MILAN VIDMAR
 Hojdrihova 2, 1000 Ljubljana, Slovenija



ETRA 33 Energetski transformatorji d.d.
 Štandrova 10, 1001 Ljubljana, p.p. 4986, Slovenija
 tel. ++386 1 5302 800, fax. ++386 1 6302 810, http://www.etra33.si


ETRA 33
ENERGETSKI
TRANSFORMATORJI
 Ljubljana, Štandrova 10




[Signature]

[Signature]


TEST REPORT		ETRA33 d.d.	
Ljubljana / Slovenija		Sheet no.: 2	
Impulse Voltage Test - Oscillograms		:	
Type: RT 20000-110		Serial No.: 74273	
Phase: 1U		Tap Changer Pos.: 1	




Vp [kV] T1 [µs] T2 [µs]
-273.7 1.1 47.4




Vp [kV] T1 [µs] T2 [µs]
-553.8 1.08 48.5




Ip [A]
-257.6




Ip [A]
-500.8




Vp [kV] T1 [µs] T2 [µs]
-545.9 1.08 48.5



Vp [kV] T1 [µs] T2 [µs]
-553.7 1.08 48.6




Ip [A]
-491.2




Ip [A]
-500.8

22 June 2004	Measured by:	Checked by:	Approved by:
--------------	--------------	-------------	--------------

Data Acquisition System by PASSONI & VILLA - MILAN - ITALY











ELEKTROINSTITUT MEHANA
Hajdrihova 7, 1000 Ljubljana, SLOVENIA



[Handwritten signature]

TEST REPORT		ETRA33 d.d.	
		Ljubljana / Slovenija	
Impulse Voltage Test - Oscillograms		Sheet no.: 3	
Type: RT 20000-110		Serial No.: 74273	
Phase: 1V		Tap Changer Pos.: 8	



22 June 2004	Measured by:	Checked by:	Approved by:
Data Acquisition System by PASSONI & VILLA - MILAN - ITALY			

[Handwritten signature]









ELEKTROINŠTITUT MILAN VENTURA
Hajdrihova 2, 1000 Ljubljana, SLO

[Handwritten signature]

[Large handwritten signature]

[Handwritten signature]

TEST REPORT		ETRA33 d.d.	
Ljubljana / Slovenija			
Impulse Voltage Test - Oscillograms	:	Sheet no.: 4	
Type: RT 20000-110	Serial No.: 74273		
:	Phase: 1W	Tap Changer Pos.: 19	















22 June 2004	Measured by:	Checked by:	Approved by:
Data Acquisition System by PASSONI & VILLA - MILAN - ITALY			

[Handwritten signature]

ELEKTROINŠTITUT
Hajdrihova 2, 1000 Ljubljana

[Handwritten signature]

TEST REPORT		ETRA33 d.d.	
		Ljubljana / Slovenija	
Impulse Voltage Test - Oscillograms		:	Sheet no.: 5
Type: RT 20000-110		Serial No.: 74273	
Phase: 2U		Tap Changer Pos.: --	



22 June 2004	Measured by:	Checked by:	Approved by:
Data Acquisition System by PASSONI & VILLA - MILAN - ITALY			

[Handwritten signature]









ELEKTROINSTITUT MILAN VIDMAR
Hožičeva 7, 1000 Ljubljana, Slovenija

[Handwritten signature]

[Large handwritten signature]

[Handwritten signature]

TEST REPORT		ETRA33 d.d.	
Impulse Voltage Test - Oscillograms		Ljubljana / Slovenija	
Type: RT 20000-110		Sheet no.: 6	
Phase: 2V		Serial No.: 74273	
Tap Changer Pos.: --			



22 June 2004	Measured by:	Checked by:	Approved by:
--------------	--------------	-------------	--------------

Data Acquisition System by PASSONI & VILLA - MILAN - ITALY











ELEKTRONSKI INSTITUT MEAN VEMAR
Hojdrihova 2, 1000 Ljubljana, Slovenija

[Handwritten signatures and scribbles]

[Handwritten signature]

TEST REPORT		ETRA33 d.d.	
Impulse Voltage Test - Oscillograms		Ljubljana / Slovenija	
Type: RT 20000-110		Sheet no.: 7	
Phase: 2W		Serial No.: 74273	
Tap Changer Pos.: --			



22 June 2004	Measured by:	Checked by:	Approved by:
Data Acquisition System by PASSONI & VILLA - MILAN - ITALY			



ELEKTROINSITUT MILAN VIDMAR
 Hojdničeva 2, 1000 Ljubljana, Slovenija

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

**KOLEKTOR**

KOLEKTOR ETRA d.o.o.

POROČILO - TEST REPORT

100 / 2012

**22.0 PREIZKUS Z UDARNO NAPETOSTJO
LIGHTING IMPULSE VOLTAGE TEST**

- IEC 60076-3 (clause 13)

Tehnični podatki:

Technical data:

Transformator tip: Transformer type:	RT 40000-115,5	Tovarniška št.: Serial No.:	78947	Št. načrta.: Draw. No.:	3447
Vezna skupina: Vector group:	YNd5	Število faz: No. of phases:	3	Frekvenca: Frequency:	50 Hz

Navitje; Winding:	VN - HV	VN _N - HV _N	NN - LV		
Stopnja izolacije: Um [kV] Insulation level: LI/AC [kV]	123	123	12		
Nazivna moč: Rated power: [kVA]	40.000		40.000		
Nazivna napetost: Rated voltage: [kV]	115,5		11		
Udarne nap. LI / LIC: Impulse test voltage LI / LIC: [kV]	550	550	75		
Priključki Terminals:	1U; 1V; 1W	1N	2U; 2V; 2W		
Položaj stikala: Tap changer position:	1; 9; 17	1			
Oblika vala: Wave shape:	1,2/50 μs	1,2/50 μs	1,2/50 μs		
Čas rezanja: Chopping time:	--	--	--		

Postopek preizkušanja:

Test procedure:

 - DA; YES - NE; NO

LI	<input checked="" type="checkbox"/>	En poln udar pri znižani (50%) preizkusni napetosti.	One reduced (50%) level full impulse.
LI	<input checked="" type="checkbox"/>	En poln udar pri polni preizkusni napetosti.	One full level full impulse.
LI + LIC	<input checked="" type="checkbox"/>	En odrezan udar pri znižani (50%) preizkusni napetosti.	One reduced (50%) level chopped impulse.
LI + LIC	<input checked="" type="checkbox"/>	Dva odrezana udara pri polni preizkusni napetosti.	Two full level chopped impulses.
LI	<input checked="" type="checkbox"/>	En poln udar pri znižani (50%) preizkusni napetosti.	One reduced (50%) level full impulse.
LI	<input checked="" type="checkbox"/>	Dva polna udara pri polni preizkusni napetosti.	Two full level full impulses.

OPOMBE:

NOTE:

ELEKTROINŠTITUT MIJAN VIDMAR
Hojdrihova 7, 1000 Ljubljana, Slovenija

Merilne opravil:

Tested by: **Franč Štampelj**
Primož Dimnik

Ljubljana: 2012-12-05

KOLEKTOR

KOLEKTOR ETRA d.o.o.

**KOLEKTOR ETRA Energetski transformatorji d.o.o.**

Štandrova 10, 1001 Ljubljana, p.p. 4956, Slovenija

tel. ++386 1 5302 800 fax. ++386 1 5302 830, http://www.etra33.si

10 1231 Ljubljana-Črnuče, Slovenija

1 / 9

100-12.doc / 05/12/2012

Lm2021 / S. F.S. 03.03.98 - Verzija 3 (01.07.08)

**KOLEKTOR**


KOLEKTOR ETRA d.o.o.

POROČILO - TEST REPORT

100 / 2012

Vezava udarnega generatorja:

Diagram of impulse generator:



	Za VN For HV	Za VN For HV	Za NN For LV		
Polariteta: Polarity:	negativ	negativ	negativ		
Število kaskad: No. of stage:	8s 1p	8s 1p	2s 4p		
Kapacitivnost: Capacitance:	[nF] 250	250	4000		
Serijska upornost: Series resistance:	[Ω] 6x20; 2x60	8x20	20; 20		
Paralelna kapacitivnost: Parallel capacitance:	[nF]		2,2		
Paralelna upornost: Parallel resistance:	[Ω] 6x68; 2x68/2	8x68	68/5		
Delilnik napetosti: Voltage divider:	2000	2000	2000		
Razmerje delilnika: Measured ratio:	[Ω] 1483	1483	281,6		
Merilni shunt: Shunt:	[Ω] 0,5	0,5	0,5		
Shunt priključen na: Shunt connected to:	LV	LV	HV		
Dodatni upor: Additional resistance:	[Ω]				
Območje (LI): Range (LI):	[kV] 550	550	75		
Območje (L _{te}): Range (L _{te}):	[kV] //	//	//		
Območje (LI): Range (LI):	[A] 200	1000	80		
Območje (L _{te}): Range (L _{te}):	[A] //	//	//		

Merilna oprema: Measuring equipment:

- Digitalni impulzni analizator Haefely HIAS 743-2 in GC 223
- Digital impulse analysing system Haefely HIAS 743-2 and GC 223


EMVELEKTROINŽENIRSKA
Hodnikova 2, 1000 Ljubljana, Slovenija

TEST REPORT


Impulse Analysing System by Haefely Test AG




Page: 3; Tr. No.: 78947; Terminal: 1U; Tap. pos.: 1




No. 1 U full Upk: -275.324 kV T1: 1.271 us T2: 56.200 us




No. 1 LI full Ipk max: -71.950 A Ipk min: 32.532 A




No. 2 U full Upk: -548.567 kV T1: 1.265 us T2: 56.249 us




No. 2 LI full Ipk max: -147.627 A Ipk min: 64.697 A




No. 3 U full Upk: -550.323 kV T1: 1.275 us T2: 56.281 us



No. 3 LI full Ipk max: -145.366 A Ipk min: 65.063 A



No. 4 U full Upk: -549.243 kV T1: 1.272 us T2: 56.346 us



No. 4 LI full Ipk max: -145.020 A Ipk min: 64.575 A

ETRA
ELEKTROBÜHNTUM
Hofdörferstr. 7, 1900 Lüneburg


[Handwritten signature]

TEST REPORT


Impulse Analysing System by Haeefely Test AG




Page: 4; Tr. No.: 78947; Terminal: 1V; Tap. pos.: 9




No. 5 LI full Upk: -275.646 kV T1: 1.272 us T2: 53.204 us




No. 5 LI full Ipk max: -82.397 A Ipk min: 32.593 A




No. 6 LI full Upk: -549.114 kV T1: 1.274 us T2: 53.509 us




No. 6 LI full Ipk max: -152.954 A Ipk min: 64.697 A




No. 7 LI full Upk: -549.939 kV T1: 1.270 us T2: 53.688 us



No. 7 LI full Ipk max: -157.637 A Ipk min: 64.941 A



No. 8 LI full Upk: -549.419 kV T1: 1.270 us T2: 53.563 us



No. 8 LI full Ipk max: -156.006 A Ipk min: 64.941 A

[Handwritten signature]

[Handwritten signature]

ETRA
ELEKTROINSTITUT MILAN VIDMAR
Bodajeva 2, 1000 Ljubljana, Slovenija


[Handwritten signature]

TEST REPORT


Impulse Analysing System by Hasfely Test AG




Page: 5; Tr. No.: 78947; Terminal: 1W; Tap. pos.: 17




No. 9 LI full Upk: -278.206 kV T1: 1.268 us T2: 49.199 us




No. 9 LI full Ipk max: -60.627 A Ipk min: 33.936 A




No. 10 LI full Upk: -548.483 kV T1: 1.272 us T2: 49.970 us




No. 10 LI full Ipk max: -151.245 A Ipk min: 68.406 A




No. 11 LI full Upk: -549.581 kV T1: 1.280 us T2: 49.383 us



No. 11 LI full Ipk max: -150.879 A Ipk min: 66.528 A



No. 12 LI full Upk: -550.318 kV T1: 1.281 us T2: 49.418 us



No. 12 LI full Ipk max: -154.663 A Ipk min: 68.359 A

ELEKTROINSTITUT MILAN VIDMAR
Hajdrihova 7, 1000 Ljubljana, Slov.


[Handwritten signature]

TEST REPORT


Impulse Analysing System by Haeferly Test AG




Page: 6; Tr. No.: 78947; Terminal: 1N; Tap. pos.: 1




No. 14 LI full Upk: -276.406 kV T1: 4.720 us T2: 41.630 us




No. 14 LI full Ipk max: -389.688 A Ipk min: 176.938 A




No. 15 LI full Upk: -548.798 kV T1: 4.725 us T2: 42.028 us




No. 15 LI full Ipk max: -773.350 A Ipk min: 355.605 A




No. 16 LI full Upk: -549.892 kV T1: 4.725 us T2: 41.933 us



No. 16 LI full Ipk max: -770.869 A Ipk min: 353.760 A



No. 17 LI full Upk: -550.383 kV T1: 4.699 us T2: 41.667 us



No. 17 LI full Ipk max: -772.119 A Ipk min: 351.914 A

[Handwritten signature]

[Handwritten signature]
[Handwritten signature]

ELECTROINSTITUT MILANO
Hofbrunnstr. 2, 1000 Ljubljana, Slovenia


[Handwritten signature]

TEST REPORT


Impulse Analysing System by Haeefly Test AG




Page: 7; Tr. No.: 78947; Terminal: 2U; Tap. pos.: --




No. 20 LI full Upk: -37.367 kV T1: 1.277 us T2: 53.155 us




No. 20 LI full Ipk max: -33.887 A Ipk min: 4.932 A




No. 21 LI full Upk: -75.013 kV T1: 1.268 us T2: 53.060 us




No. 21 LI full Ipk max: -66.650 A Ipk min: 9.473 A




No. 22 LI full Upk: -75.077 kV T1: 1.252 us T2: 53.162 us



No. 22 LI full Ipk max: -67.480 A Ipk min: 9.570 A



No. 23 LI full Upk: -74.977 kV T1: 1.272 us T2: 53.029 us



No. 23 LI full Ipk max: -68.553 A Ipk min: 9.570 A

ETRB

ELEKTROINŽINĚRSTVÍ MILAN VILÍMA
Hojkethova 7, 10000 Praha 2, ČR


[Handwritten scribble]

TEST REPORT


Impulse Analysing System by Haefely Test AG




Page: 8; Tr. No.: 78947; Terminal: 2V; Tap. pos.: --




No. 24 LI full Upk: -37.477 kV T1: 1.266 us T2: 53.104 us




No. 24 LI full Ipk max: -34.658 A Ipk min: 5.029 A




No. 25 LI full Upk: -75.129 kV T1: 1.255 us T2: 53.045 us




No. 25 LI full Ipk max: -71.875 A Ipk min: 12.793 A




No. 26 LI full Upk: -74.617 kV T1: 1.264 us T2: 53.139 us



No. 26 LI full Ipk max: -73.438 A Ipk min: 29.932 A



No. 27 LI full Upk: -76.178 kV T1: 1.268 us T2: 53.121 us



No. 27 LI full Ipk max: -68.555 A Ipk min: 9.814 A

ETRC
ELEKTROINSTITUT MEASUREMENT
Heldhofstr. 7, 1000 Ljubljana, Slovenia

[Handwritten signature]

[Handwritten signature]
ETRC


[Handwritten signature]

TEST REPORT


Impulse Analysing System by Haeftly Test AG




Page: 9; Tr. No.: 78947; Terminal: 2W; Tap. pos.: --




No. 28 LI full Upk: -37.392 kV T1: 1.272 us T2: 53.294 us




No. 28 LI full Ipk max: -35.156 A Ipk min: 5.273 A




No. 29 LI full Upk: -76.474 kV T1: 1.276 us T2: 52.611 us




No. 29 LI full Ipk max: -71.631 A Ipk min: 10.400 A




No. 30 LI full Upk: -74.827 kV T1: 1.274 us T2: 62.798 us



No. 30 LI full Ipk max: -71.240 A Ipk min: 25.586 A



No. 31 LI full Upk: -75.142 kV T1: 1.259 us T2: 52.877 us



No. 31 LI full Ipk max: -69.238 A Ipk min: 10.254 A

EA
ELEKTROINŽINERSTVU MEAN V.
Hojdňova 2, 1000 Praha 5

 ETRA 33 ENERGETSKI TRANSFORMATORJI d.d. Ljubljana - SLOVENIJA	MERILNI LIST TRANSFORMATORJA TRANSFORMER TEST REPORT	

Naročnik: Purchaser:	Proizvajalec: Manufacturer:	Preizkušeno po: Tested in accordance with:	Leto izdelave: Year of manufacture:
Termoelektrarna Trbovlje	ETRA 33 ENERGETSKI TRANSFORMATORJI d.d.	EN 60076	2004


TEHNIČNI PODATKI TECHNICAL RATING			
	Transformator: Transformer:	Regulacijsko stikalo: Tap-changer:	Komandna omarica reg. st.: Tap-changer motor drive unit:
Tip: Type:	RT 20000-110	MR - MS III 300Y	MR - ED 100S
Tov. št.: Ser. No.:	74273	589 264	589 264
Št. načrta: Diagram No.:	2966		
Navilje; Winding :		VN - HV	NN - LV
Stopnja izolacije; Um [kV]	123	12	
Insulation level: LI / AC [kV]	550 / 230	75 / 28	
Nazivna moč; Rated power: [kVA]	20 000	20 000	
Nazivna napetost; Rated voltage: [kV]	+ 7 x 1.82%		
	110 000	6 300	
	- 11 x 1.82%		
Nazivni tok; Rated current: [A]	105.0	1832.9	
Frekvenca: Frequency:	Število faz: No. of phases:	Vezna skupina: Vector group:	Sistem hlajenja: Cooling method:
50 Hz	3	YNd5	ONAN / ONAF
Skupna masa [t]: Total weight [t]:	Masa olja [t]: Weight of oil [t]:		Tip izolacijskega olja: Type of isolation oil:
42.0	10.5		Nynas Nytro 10X


OPOMBE:
NOTES: ONAN - 12 MVA
ONAF - 20 MVA

I: 39/04

Preizkusom je prisostvoval:
The test was carried out in presence of:




g. Jože AHAC - TE Trbovlje
g. Anton URANKAR - TE Trbovlje
g. Damjan DETELA - TE Trbovlje
g. Marko KNEZ - TE Trbovlje
g. Mladen IGLIČ - EIMV


 ELEKTROINŠTITUT MILAN VIDMAR
 Hajdrihova 2, 1000 Ljubljana, Slovenija



Meritve opravil:
Tested by:

Franc Štampelj
Bojan Košič
Ljubljana:
22. junij 2004

  CERTIFIKACIJSKI ISO 9001	ETRA 33 Energetski transformatorji d.o.o. Šlandrova 10, 1001 Ljubljana, p.p. 4956, Slovenija tel. ++386 61 161 21 31, fax. ++386 61 373 194, http://www.etra33.si	 ETRA 33 ENERGETSKI TRANSFORMATORJI d.o.o. Ljubljana, Šlandrova 10
---	---	---

LM 74273.doc / v. 29.06.04

LM2050 / S. S. 30.07.07 Verzija 0

5

ETRA	ETRA 33 ENERGETSKI TRANSFORMATORJI d.d. Ljubljana - SLOVENIJA	MERILNI LIST TRANSFORMATORJA TRANSFORMER TEST REPORT	
	Transformator: Transformer: RT 20000-110	Tov. št.: Ser. No.: 74273	

SPISEK MERITEV IN PREIZKUSOV LIST OF MEASUREMENTS AND TESTS

1.0	Meritev prestavnega razmerja Measurement of voltage ratio	<input checked="" type="checkbox"/>
1.1	Meritev magnetilnih tokov pri 400 V, 50 Hz No-load current at 400 V, 50 Hz	<input checked="" type="checkbox"/>
2.0	Meritev ohmskih upornosti navitij Measurement of winding resistance	<input checked="" type="checkbox"/>
3.1	Meritev izgub in toka praznega teka Measurement of no-load loss and no-load current	<input checked="" type="checkbox"/>
3.2	Meritev izgub in napetosti kratkega stika Measurement of load loss and impedance voltage	<input checked="" type="checkbox"/>
3.3	Rezultati meritev izgub Results of loss measurements	<input checked="" type="checkbox"/>
4.1	Preizkus z inducirano napetostjo Induced AC withstand voltage test	<input checked="" type="checkbox"/>
4.2	Meritev delnih praznjenj Partial discharge measurement	<input checked="" type="checkbox"/>
4.3	Preizkus z napetostjo iz tujega vira Separate-source voltage withstand test	<input checked="" type="checkbox"/>
4.4	Meritev izolacijske upornosti Measurements of insulation resistance	<input checked="" type="checkbox"/>
4.5	Meritev prebojne trdnosti izolacijskega olja Measurements of dielectric strength of insulating oil	<input checked="" type="checkbox"/>
5.0	Preizkus regulacijskega stikala Tests on on-load tap-changer	<input checked="" type="checkbox"/>
6.0	Meritev nične impedanče Measurement of zero-sequence impedance	<input checked="" type="checkbox"/>
7.0	Meritev izgub hladilnega sistema Measurements of loss of cooling system	<input checked="" type="checkbox"/>
11.0	Meritev kapacitivnosti in tg δ Measurements of capacity and dissipation factor tg δ	<input checked="" type="checkbox"/>
12.0	Meritev stresane induktivnosti Measurements of leakage inductance	<input checked="" type="checkbox"/>
13.0	Meritev nivoja hrupa Measurement of sound level	<input checked="" type="checkbox"/>
15.0	Spisek elementov na transformatorju List of elements on transformer	<input checked="" type="checkbox"/>
16.0	Funkcionalni preizkus komandne omarice Functional test of control cubicle	<input checked="" type="checkbox"/>
17.0	Funkcionalni preizkus elementov na transformatorju Functional test of elements on transformer	<input checked="" type="checkbox"/>
18.0	Meritev višjeharmonskih tokov praznega teka Measurements of the harmonics of the no-load current	<input checked="" type="checkbox"/>
19.0	Meritve na vgrajenih tokovnih transformatorjih Measurement on built-in current transformers	<input checked="" type="checkbox"/>
21.0	Preizkus segrevanja Temperature-rise test	<input checked="" type="checkbox"/>
22.0	Preizkus z udarno napetostjo Impulse voltage test	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	preizkus opravljen; test O.K.	



ETRA 33
ENERGETSKI TRANSFORMATORJI d.d.
Ljubljana - SLOVENIJA

MERILNI LIST TRANSFORMATORJA

TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 20000-110**

Tov. št.:
Ser. No.: **74273**

1.0 MERITEV PRESTAVNEGA RAZMERJA IN VEZNE SKUPINE

MEASUREMENT OF VOLTAGE RATIO AND VECTOR GROUP

- IEC 60076-1 (clause 10.3)

Vezna skupina:
Vector group: **YNd5**

Poz. stik.: Tap pos.:	Računska napetost: Calculated voltage:		Konstanta: Constant: [U ₂ /U ₁ xk]	Izmerjeno odstopanje: Measured deviations:		
	U ₁ [V]	U ₂ [V]		1U/2U [%]	1V/2V [%]	1W/2W [%]
1	124 014		87.996	-0.22	-0.22	-0.22
2	122 012		89.440	-0.22	-0.22	-0.22
3	120 010		90.931	-0.21	-0.21	-0.21
4	118 008		92.474	-0.20	-0.20	-0.20
5	116 006		94.069	-0.19	-0.19	-0.19
6	114 004		95.720	-0.18	-0.18	-0.18
7	112 002		97.430	-0.17	-0.17	-0.17
8	110 000	6 300	99.203	-0.16	-0.16	-0.16
9	107 998		101.041	-0.15	-0.15	-0.15
10	105 996		102.949	-0.15	-0.15	-0.15
11	103 994		104.931	-0.14	-0.14	-0.14
12	101 992		106.989	-0.12	-0.12	-0.12
13	99 990		109.131	-0.11	-0.11	-0.11
14	97 988		111.359	-0.09	-0.09	-0.09
15	95 986		113.681	-0.08	-0.08	-0.08
16	93 984		116.101	-0.07	-0.07	-0.07
17	91 982		118.627	-0.06	-0.06	-0.06
18	89 980		121.265	-0.05	-0.05	-0.05
19	87 978		124.023	-0.04	-0.04	-0.04

Merilna oprema; Measuring equipment:

- merilnik prestavnega razmerja Končar, tip MK1, točnosti ± 0.05 %
- turns ratio meter Končar, type MK1, accuracy ± 0.05 %

1.1 MERITEV MAGNETILNIH TOKOV pri 400 V, 50 Hz

NO-LOAD CURRENT at 400 V, 50 Hz

Poz. stik.: Tap pos.:	Navitje: Winding:	Faza A [mA] Phase A [mA]	Faza B [mA] Phase B [mA]	Faza C [mA] Phase C [mA]
8	VN - HV	2.9	2.2	3.2
--	NN - LV	190	200	290

Merilna oprema; Measuring equipment:

- univerzalni instrument točnosti ± 0.5 %
- multimeter accuracy ± 0.5 %

Transformator:
Transformer: **RT 20000-110**

Tov. št.:
Ser. No.: **74273**

2.0 MERITEV OHMSKIH UPORNOSTI NAVITIJ
MEASUREMENT OF WINDING RESISTANCE

- IEC 60076-1 (clause 10.2)

Temperatura - Temperature ϑ : **26 °C**

Poz. stik.: Tap pos.:	VN navitje HV winding		
	I_{test} 11 A		
	1U - 1V [Ω]	1V - 1W [Ω]	1U - 1W [Ω]
1	2.281231	2.283006	2.282383
2	2.227126	2.228447	2.228714
3	2.171806	2.173172	2.173461
4	2.117701	2.118964	2.118917
5	2.063420	2.064412	2.063564
6	2.008181	2.009795	2.008812
7	1.953620	1.955487	1.955141
8	1.898425	1.899892	1.900149
9	1.843557	1.845145	1.845787
10	1.785276	1.785839	1.786124
11	1.842761	1.845557	1.844888
12	1.898084	1.900802	1.899600
13	1.952378	1.955212	1.953927
14	2.007475	2.010348	2.008790
15	2.062250	2.065051	2.063727
16	2.116877	2.119731	2.118377
17	2.172332	2.175034	2.173504
18	2.226878	2.229644	2.228043
19	2.281897	2.284537	2.283017

Poz. stik.: Tap pos.:	NN navitje LV winding		
	I_{test} 11 A		
	2U - 2V [Ω]	2V - 2W [Ω]	2U - 2W [Ω]
	0.005654	0.005717	0.005722

Merilna oprema; Measuring equipment:

- merilnik ohmske upornosti Teltex, tip 2283, točnosti $\pm 0.06\%$
- resistance meter Teltex, type 2283, accuracy $\pm 0.06\%$



ETRA 33
ENERGETSKI TRANSFORMATORJI d.d.
Ljubljana - SLOVENIJA

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 20000-110**

Tov. št.:
Ser. No.: **74273**

3.1 MERITEV IZGUB IN TOKA PRAZNEGA TEKA					- IEC 60076-1 (clause 10.5)	
MEASUREMENT OF NO-LOAD LOSS AND NO-LOAD CURRENT						
Napetost priključena; Voltage supply to: NN		Frekvenca; Frequency: 50 Hz				
Napetost; Voltage:	$U_{m^{*1,11}}$ [%]	90	100	110		
	$U_{m^{*1,11}}$ [V]	5 670	6 300	6 930		
	U_{rms} [V]	5 666	6 302	6 950		
Tok; Current:	$I_{rms U}$ [A]	0.99	1.23	2.46		
	$I_{rms V}$ [A]	0.78	1.06	2.41		
	$I_{rms W}$ [A]	1.23	1.59	3.17		
	I_o [A]	1.001	1.297	2.684		
	I_o [%]	0.054	0.071	0.146		
	Mer. izgube; Measur. loss:	P_{Fe} [W]	9 292	12 096	16 550	
Kor. izgube; Corrected loss:	P_{Fec} [W]	9 337	12 149	16 659		

3.2 MERITEV IZGUB IN NAPETOSTI KRATKEGA STIKA					- IEC 60076-1 (clause 9)	
MEASUREMENT OF LOAD LOSS AND IMPEDANCE VOLTAGE						
Temperatura - Temperature: 24 °C		Frekvenca - Frequency: 50 Hz				
Napajano - kratko skljnjeno: Supply - short circuited:		VN - NN	VN - NN	VN - NN		
Pozicija stikala - Tap position:		1	8	19		
Tok - Current:	I_m [A]	90.41	102.87	131.14		
Napetost - Voltage:	U_m [V]	13 775	11 590	9 236		
Izgube - Loss:	P_{mCu} [W]	71 530	71 070	99 640		
Korekcija - Correction:	P [W]	-124	-161	-261		
Izgube - Loss:	P_{mCuC} [W]	71 406	70 909	99 379		
Preračun na nazivni tok navilja. - Calculated at winding nominal current.						
Moč - Power:	S_n [kVA]	20 000	20 000	20 000		
Tok - Current:	I_n [A]	93.1	105.0	131.2		
Napetost - Voltage:	U_k [V]	14 186	11 827	9 243		
Izgube - Loss:	P_k [W]	75 731	73 834	99 538		
Preračun na referenčno temperaturo 75 °C. - Calculated at reference temperature 75 °C.						
I^2R izgube - I^2R loss:	P_{d75} [W]	68 820	70 845	103 374		
Dod. izg. - Stray loss:	P_{d75} [W]	15 233	12 235	11 004		
Izgube - Loss:	P_{Cu75} [W]	84 054	83 080	114 378		
Kratk. nap.; Imp. voltage:	U_{k75} [%]	11.44	10.75	10.51		

3.3 REZULTATI MERITEV IZGUB							- IEC 60076-1 (clause 9)	
RESULTS OF LOSS MEASUREMENTS								
	Pos.	S_n [kVA]	P_{Fe} [kW]	P_{Cu75} [kW]	P_{Tot} [kW]	I_o [%]	U_{k75} [%]	
Garantirano: Guaranteed:	1	20 000						
	8	20 000	12.5 (+0%)	83.5 (+0%)	96.0 (+0%)	0.15 (+30%)	11.3 (+7.6%)	
	19	20 000						
Merjeno: Measured:	1	20 000		84.054	96.203		11.44	
	8	20 000	12.149	83.080	95.229	0.071	10.75	
	19	20 000		114.378	126.527		10.51	

Merilna oprema; Measuring equipment:
 - širokopasovni moč. analizator Norma, tip D6000, točnosti ± 0.05 %
 - wide band power analyzer Norma, type D6000, accuracy ± 0.05 %
 - merilni lok. in nap. transfor. CdC, točnosti ± 0.2 %; - measuring current and voltage transformer CdC, accuracy ± 0.2 %

ETRA	ETRA 33 ENERGETSKI TRANSFORMATORJI d.d. Ljubljana - SLOVENIJA	MERILNI LIST TRANSFORMATORJA TRANSFORMER TEST REPORT
	Transformator: Transformer: RT 20000-110	Tov. št.: Ser. No.: 74273

4.1 PREIZKUS Z INDUCIRANO NAPETOSTJO
INDUCED OVERVOLTAGE WITHSTAND TEST

Položaj reg. stikala; Tap changer pos.: 1 8

4.1.1	Transformator s polno izolacijo VN navitja Transformer with uniformly insulated HV winding	- IEC 60076-3 (clause 12.1 or 12.2)			
napajano navitje; supply winding	U_n [kV] NN;LV phase - phase	U_{test} [kV] NN;LV phase - phase	U_{test} [kV] VN;HV phase - phase	f [Hz]	t [s]
NN	6.3	12.6	220	300	20

4.1.2	Transformator z znižano izolacijo VN navitja Transformer with non-uniformly insulated HV winding	- IEC 60076-3 (clause 12.3)				
napajano; supply	U_n [kV] NN;LV phase - earth	U_{test} [kV] NN;LV phase - earth	U_{test} [kV] VN;HV phase - earth	U_{test} [kV] N N - earth	f [Hz]	t [s]

Merilna oprema; Measuring equipment:

- širokopasovni močnostni analizator Norma, tip D6000, točnosti ± 0.05 %
- wide band power analyzer Norma, type D6000, accuracy ± 0.05 %
- merilni tokovni in napetostni transformatorji CdC, točnosti ± 0.2 %
- measuring current and voltage transformer CdC, accuracy ± 0.2 %

4.3	PREIZKUS Z IZMENIČNO NAPETOSTJO IZ TUJEGA VIRA SEPARATE SOURCE AC WITHSTAND VOLTAGE TEST	- IEC 60076-3 (clause 11)	
med; between	U [kV _{peak} /V]	f [Hz]	t [s]
VN - NN + M	230	50	60
NN - VN + M	28	50	60

Merilna oprema; Measuring equipment:

- voltmeter temenske vrednosti Haefely, tip 51, točnosti ± 0.5 %
- AC peak voltmeter Haefely, type 51, accuracy ± 0.5 %

OPOMBA; NOTE:
M - ozemljeni del
M - ground


4.4	MERITEV IZOLACIJSKE UPORNOSTI MEASUREMENTS OF ISULATION RESISTANCE			
med; between	R_{ISO} (60 sek.) [MΩ]	R_d (R60 sek./R30 sek.)	U [kV _{DC}]	t [°C]
VN - NN (M)	18 000	1.19	2.5	26
VN - NN + M	11 800	1.10	2.5	26
NN - VN + M	7 200	1.28	2.5	26

Merilna oprema; Measuring equipment:

- merilnik izolacijske upornosti Norma ISO 5kV, točnosti ± 3 %
- insulation resistance meter Norma ISO 5kV, accuracy ± 3 %

OPOMBA; NOTE:
M - ozemljeni del
M - ground



 ETRA 33 ENERGETSKI TRANSFORMATORJI d.d. Ljubljana - SLOVENIJA	MERILNI LIST TRANSFORMATORJA TRANSFORMER TEST REPORT	
	Transformator: Transformer: RT 20000-110	Tov. št.: Ser. No.: 74273

4.2 MERITEV DELNIH PRAZNIJENJ
PARTIAL DISCHARGE MEASUREMENT

- IEC 60076-3 (clause 12.4)
 - IEC 60270


Položaj reg. stikala; Tap changer pos.:	8	Napajano navitje; Supply winding	NN	Tip preizkusa; Test type:	ACLD
LI/AC	550/230 [kV]	- stopnja izolacije VN nav.; insulation level HV wind.			
U _m (HV)	123 [kV _{r.m.s.}]	- najvišja nap. opreme; highest voltage for equipment			
U ₁ (HV)	123 [kV _{r.m.s.}]	- preizkusna napetost; test voltage (U ≤ 2 × U _{n ph})			
U ₂ (HV)	106 [kV _{r.m.s.}]	⇒ q _{max} ≤ 500 pCat ACLD, ≤ 300 pCat ACSD			
U ₃ (HV)	78 [kV _{r.m.s.}]	⇒ q _{max} ≤ 100 pC			
f _{um}	300 [Hz]	- napajalna frekvenca; supply frequency			
Q ₀ (calib.)	100 [pC]	- kalibracijska vrednost; calibration value			
f _m	100 - 400 [kHz]	- merilna frekvenca; measuring frequency			
Filter:	wide band				

$$U_1 = \frac{\sqrt{3} * U_n}{\sqrt{3}} \text{ (phase-to-earth)}$$

$$U_2 = 1.5 * \frac{U_m}{\sqrt{3}} \text{ (phase-to-earth)}$$

$$U_3 = 1.1 * \frac{U_n}{\sqrt{3}} \text{ (phase-to-earth)}$$

Časovni interval; Time sequence	U _{ph}		Prijključki; Terminals						OPOMBE NOTES
	VN - HV	NN - LV	A	B	C				
	[kV]	[kV]	[pC]	[pC]	[pC]	[pC]	[pC]	[pC]	
Osnovne moltnje; Background noise:	0	0	13	12	11				
A ↓ 1 min	78	7.73	20	21	12				
5 min			25	50	21				
B ↓ 1 min	106	10.51	29	228	64				
5 min			31	234	47				
C 20 sec	123	12.20	35	236	51				
D ↓	106	10.51	28	230	41				
			1 min	30	231	41			
			5 min	27	231	34			
			10 min	28	208	31			
			15 min	26	207	31			
			20 min	26	180	28			
E ↓	78	7.73	23	75	24				
			5 min	24	83	22			
			Osnovne moltnje; Background noise:	0	0	16	13	12	



Simetrični tri fazni priklp. Merjenje na kapacitivnem skoz. Časovni intervali preizkusne napetosti.
 Symmetrical three-phase connection. Circuit for measure. on conden. bushing. Time sequence for application of test voltage.

- Merilna oprema; Measuring equipment:**
- širokopasovni močnostni analizator Norma, tip D6000, točnosti ± 0.05 %
 - wide band power analyzer Norma, type D6000, accuracy ± 0.05 %
 - merilni tokovni in napetostni transformatorji CdC, točnosti ± 0.2 %
 - measuring current and voltage transformer CdC, accuracy ± 0.2 %
 - merilnik delnih praznjenj Lemke, tip LDS-6
 - partial discharge instrument Lemke, tip LDS-6



ETRA 33
ENERGETSKI TRANSFORMATORJI d.d.
Ljubljana - SLOVENIJA

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 20000-110**

Tov. št.:
Ser. No.: **74273**

4.5 MERITEV PREBOJNE TRDNOSTI IZOLACIJSKEGA OLJA
MEASUREMENTS OF DIELECTRIC STRENGTH OF ISULATING OIL

Tip izolacijskega olja :
Type of isolation oil: **Nynas Natro 10X**

mesto odvzema: test sample taken from:	1 [kV]	2 [kV]	3 [kV]	4 [kV]	5 [kV]	6 [kV]	M [kV/cm]	S
sredina transformatorskega kotla	54.7	61.3	56.5	57.8	60.5	58.7	232	2.5

Razmak med iskriščem preskusne naprave je 2.5 mm. Distance between gaps of oil tester is 2.5 mm.

Merilna oprema; Measuring equipment:

- merilna naprava Bauer, tip DTA 75
- measuring device Bauer, type DTA 75

5.0 PREIZKUS REGULACIJSKEGA STIKALA
TESTS ON ON-LOAD TAP-CHANGER

• IEC 60076-1 (clause 10.8)

1.	8 kompletnih ciklov operacij z nevzbujenim transformatorjem 8 complete operating cycles with the transformer not energized	<input checked="" type="checkbox"/>
2.	1 kompleten cikel operacij z vzbujenim transformatorjem v praznem teku pri nazivni frekvenci in nazivni napetosti 1 complete operating cycle with transformer at rated voltage and frequency, at no-load	<input checked="" type="checkbox"/>
3.	10 delovanj regulacijskega stikala s ± 2 stopnjama regulacije z vsake strani glavnega odcepa, pri čim bližjem nazivnem toku transformatorja, z enim kratko vezanim navitjem 10 tap-change operations with ±2 steps on either side of the principal tapping with as far as possible the rated current of the transformer, with one winding short-circuited	<input checked="" type="checkbox"/>

preizkus opravljen
test O.K.

6.0 MERITEV NIČNE IMPEDANCE
MEASUREMENT OF ZERO-SEQUENCE IMPEDANCE

• IEC 60076-1 (clause 10.7)

Temperatura - Temperature : **26 °C**

Frekvenca - Frequency : **50 Hz**

Napajano : Supply :	1U+1V+1W - 1N		
Pozicija stikala - Tap position:	8		
Tok - Current I	[A]	188.08	
Napetost - Voltage U	[V]	3 607	
Nazivni tok - Rated current I _n	[A]	105.0	
Nazivna napetost - Rated voltage U _n	[V]	63 507	
Impedanca - Impedance	Z ₀	[Ω]	57.53
	Z ₀	[%]	9.51

Merilna oprema; Measuring equipment:

- širokopasovni močnostni analizator Norma, tip D6000, točnosti ± 0.05 %
- wide band power analyzer Norma, type D6000, accuracy ± 0.05 %
- merilni tokovni in napetostni transformatorji CdC, točnosti ± 0.2 %
- measuring current and voltage transformer CdC, accuracy ± 0.2 %



ELEKTROINŠTITUT MILAN VIDMAR
Nojstrice 2, 1000 Ljubljana, Slovenija


 ETRA 33 ENERGETSKI TRANSFORMATORJI d.d. Ljubljana - SLOVENIJA	MERILNI LIST TRANSFORMATORJA TRANSFORMER TEST REPORT	
	Transformator: Transformer: RT 20000-110	Tov. št.: Ser. No.: 74273

7.0 MERITEV IZGUB HLADILNEGA SISTEMA
MEASUREMENTS OF LOSS OF COOLING SYSTEM

Hladilni sistem ima: Cooling system includes:	2 ventilatorja; fans: / črpalk; oil pumps: /	Schorman - SH 800-12 (0.41 kW, 400V, 1.1A)
--	---	--

	U [V]	I [A]	P [W]	f [Hz]
1. - ventilator; fan	3 x 400	1.30	376	50
2. - ventilator; fan	3 x 400	1.31	398	50
Σ	3 x 400	2.61	774	50

Merilna oprema; Measuring equipment:
 - širokopasovni močnostni analizator Norma, tip D6000, točnosti ± 0.05 %
 - wide band power analyzer; Norma, type D6000, accuracy ± 0.05 %




 ELEKTROINŠTITUT MILAN VIDMAR
 Hojdničeva 2, 1000 Ljubljana, Slovenija






ETRA 33
ENERGETSKI TRANSFORMATORJI d.d.
Ljubljana - SLOVENIJA

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 20000-110**

Tov. št.:
Ser. No.: **74273**

11.0 MERITEV KAPACITIVNOSTI IN $tg \delta$
MEASUREMENTS OF CAPACITY AND DISSIPATION FACTOR $tg \delta$

	vezava connection	U [kV]	pos. (I - II)	N [Ω]	R ₃ [Ω]	R ₄ [k Ω]	C ₄ [μ F]	C _x [pF]	tg δ [%]
1	VN - NN (M)	10	II	∞	6.34	1/K	0.1485	5 021	0.148
2									
3									
4									
5	VN - NN + M	10	II	∞	4.06	1/K	0.1735	7 840	0.173
6									
7									
8									
9	NN - M (VN)	10	II	∞	3.12	1/K	0.2615	10 203	0.261
10									
11									
12									
13	NN - VN + M	10	II	∞	2.09	1/K	0.2165	15 231	0.216
14									
15									
16									
17	VN - NN (M)	10	II	∞	6.34	1/K	0.1455	5 021	0.145
18									
19									
20									
21	VN - NN + M	10	II	∞	4.06	1/K	0.1755	7 840	0.175
22									
23									
24									
25	NN - M (VN)	10	II	∞	3.12	1/K	0.2566	10 203	0.256
26									
27									
28									
29	NN - VN + M	10	II	∞	2.09	1/K	0.2585	15 231	0.258
30									
31									
32									

Testni pogoji; Test condition:

C_N: 100.01 pF t: 26 / °C p: kPa

Merilna oprema; Measuring equipment:

- Schering most tip 2801 po vezavi 1a
- Schering Bridge type 2801 - Arrangement 1a

12.0 MERITEV STRESANE INDUKTIVNOSTI
MEASUREMENTS OF LEAKAGE INDUCTANCE

	vezava connection	I [A]	pos. (I - II)	R ₂ [Ω]	R ₃ [Ω]	R ₃ ext [Ω]	R ₄ [k Ω]	C ₄ [μ F]	L _x [mH]
1	1U - 1N (2U+2V+2W)	1.0	I	100 000	2.0	-	57.752	1.0073	201.46
2									
3	1V - 1N (2U+2V+2W)	1.0	I	100 000	2.0	-	60.507	0.9962	199.24
4									
5	1W - 1N (2U+2V+2W)	1.0	I	100 000	2.0	-	61.340	1.0104	202.08
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									

Testni pogoji; Test condition:

poz. stikala; tap range: 8 (..) navitje kratko sklenjeno; winding short circuit

Merilna oprema; Measuring equipment:

- Schering most tip 2801 po vezavi 2c
- Schering Bridge type 2801 - Arrangement 2c

10/17

Transformator: **RT 20000-110** Tov. št.: **74273**
 Transformer: Ser. No.:

13.0 MERITEV NIVOJA HRUPA - IEC 60076-10
MEASUREMENT OF SOUND LEVEL


ONAN ($U_n = 100\%$) razdalja 0.3 m
 ONAN ($U_n = 100\%$) distance 0.3 m

	okolica amb.			transformator transformer				frekvenčna analiza (1/1 oktave)				
	[dBA]	[dBA]	[dBA]	[dBA]	[dBA]	[dBA]		amb.	4	8	-	-
1	35	53.4	19				A					
2	35	51.3	20				C					
3	35	55.4	21				L					
4	35	59.1	22				31.5 Hz					
5	35	62.2	23				63 Hz					
6	35	60.4	24				125 Hz					
7	35	56.1	25				250 Hz					
8	35	56.5	26				500 Hz					
9	35	56.4	27				1 kHz					
10	35	53.1	28				2 kHz					
11	35	51.6	29				4 kHz					
12	35	52.4	30				8 kHz					
13	35	50.5	31									
14	35	56.2	32									
15	35	52.5	33									
16	35	52.7	34									
17			35									
18			36									

povprečna kvadratna vrednost 35 56.39
 quadratic mean sound level

		ONAN - 0.3 m	
Povprečna izmerjena kvadratna vrednost Quadratic mean sound level	[L _{p(A)}]	56.4	dBA
Popravek zaradi okolice Environmental correction	[K]	0	dBA
Korigirana izmerjena kvadratna vrednost Correction quadratic mean sound level	[L _{p(A)}]	56.4	dBA
Garantirana kvadratna vrednost Guaranteed quadratic mean sound level	[L _{p(A)}]		dBA
Dolžina merilne linije Length of the prescribed contour	[l _m]	16.5	m
Višina transformatorskega kotla Height of the transformer tank	[h]	2.6	m
Ekvivalentna površina Area of the effective surface	[S]	53.6	m ²
Nivo A moči zvočnega vira A-weighted sound power level	[L _{w(A)}]	73.7	dBA

Formule za izračun; Formulas for equation:
 $L_{p(A)} = 10 \log_{10} \left[\frac{1}{N} \sum_{i=1}^N 10^{0.1 L_{p(A),i}} \right] - K$
 $L_{p(A)} = \bar{L}_{p(A)} + 10 \cdot \log_{10} S$
 $S = 1.25 \times h \times l_m \rightarrow 0.3m$
 $S = (h+1) \times l_m \rightarrow 1m$ $S = (h+2) \times l_m \rightarrow 2m$

Merilne točke; Measuring points:

 1, 2, 3, ... m. točke; m. points
 D = 1m
 X = ONAN 0.3 m
 ONAF 2.0 m
 AN 1.0 m

Merilna oprema; Measuring equipment:
 - merilnik šuma B&K, tip 2236, tov. št. 1914395, na področju F SPL
 - kalibrator B&K, tip 4231, tov. št. 1914631, točnosti ± 0.20 dB
 - measuring instrument B&K, type 2236, ser. No. 1914395, on position F SPL
 - calibrator B&K, type 4231, ser. No. 1914631, accuracy ± 0.20 dB

(Handwritten signatures and marks)

Transformator:
Transformer: **RT 20000-110**

Tov. št.:
Ser. No.: **74273**

13.0 MERITEV NIVOJA HRUPA
MEASUREMENT OF SOUND LEVEL

- IEC 60076-10

ONAF ($U_n = 100\%$) razdalja 2 m
ONAF ($U_n = 100\%$) distance 2 m

	okolica amb.		transformator transformer			frekvenčna analiza (1/1 oktave)				
	[dBA]	[dBA]	[dBA]	[dBA]		amb.	4	8	-	-
1	38	60.8	19	38	61.3	A				
2	38	60.5	20	38	60.7	C				
3	38	57.8	21	38	61.0	L				
4	38	56.5	22	38	61.5	31.5 Hz				
5	38	56.4	23	38	61.9	63 Hz				
6	38	57.5	24	38	62.1	125 Hz				
7	38	56.6	25	38	61.8	250 Hz				
8	38	56.9	26	38	62.0	500 Hz				
9	38	55.7	27	38	61.1	1 kHz				
10	38	55.4	28			2 kHz				
11	38	56.1	29			4 kHz				
12	38	57.7	30			8 kHz				
13	38	59.5	31							
14	38	60.1	32							
15	38	61.7	33							
16	38	62.1	34							
17	38	60.6	35							
18	38	60.6	36							

povprečna kvadratna vrednost
quadratic mean sound level

38 60.01

ONAF - 2 m

Povprečna izmerjena kvadratna vrednost Quadratic mean sound level	[L _{p(A)}]	60.0	dBA
Popravek zaradi okolice Environmental correction	[K]	0	dBA
Korigirana izmerjena kvadratna vrednost Correction quadratic mean sound level	[L _{p(A)}]	60	dBA
Garantirana kvadratna vrednost Guaranteed quadratic mean sound level	[L _{p(A)}]	65	dBA
Dotžina merilne linije Length of the prescribed contour	[m]	28	m
Višina transformatorskega kotla Height of the transformer tank	[h]	2.6	m
Ekvivalentna površina Area of the effective surface	[S]	128.8	m ²
Nivo A moči zvočnega vira A-weighted sound power level	[L _{W(A)}]	81.1	dBA

Formule za izračun; Formulas for equation:


$$L_{p(A)} = 10 \log_{10} \left[\frac{1}{N} \sum_{i=1}^N 10^{0.1 L_{p_i(A)}} \right] - K$$

$$L_{p(A)} = \bar{L}_{p(A)} + 10 \cdot \log_{10} S$$

$$S = 1.25 \times h \times l_n \rightarrow 0.3m$$

$$S = (h+1) \times l_n \rightarrow 1m \quad S = (h+2) \times l_n \rightarrow 2m$$

Merilne točke; Measuring points:



Merilna oprema; Measuring equipment:

- merilnik šuma B&K, tip 2236, tov. št. 1914395, na področju F SPL
- kalibrator B&K, tip 4231, tov. št. 1914631, točnosti ± 0.20 dB
- measuring instrument B&K, type 2236, ser. No. 1914395, on position F SPL
- callibrator B&K, type 4231, ser. No. 1914631, accuracy ± 0.20 dB

ELEKTROINŠTITUT MILAN VIDMAR
Hojarijeva 7, 1000 Ljubljana, Slovenija

Transformator: **RT 20000-110** Tov. št.: **74273**
 Transformer: Ser. No.:

15.0 SPISEK ELEMENTOV NA TRANSFORMATORJU LIST OF ELEMENTS ON TRANSFORMER					
		Oznaka Label	Tip Type	Tov. št. Ser. No.	Opombe Notes
1	Skozničnik Bushing	faza A	ABB - GOB 550	296 587	
2	Skozničnik Bushing	faza B	ABB - GOB 550	296 586	
3	Skozničnik Bushing	faza C	ABB - GOB 550	296 588	
4	Skozničnik Bushing	faza N	ABB - GOB 550	296 589	
5	Komandna omarica Control cubicle	B00	Rittal - AE 1016		
6	Pilnski rele Gas relay	B01	Comem - BR 80	C02871	
7	Zaščitni rele reg. stikala Pressure relief valve O.L.T.C.	B02	MR - RS 2001		
8	Kazalo olja za transformator Oil level indicator for transformer	B03	Comem - LB 22		
9	Kazalo olja za reg. stikalo Oil level indicator for O.L.T.C.	B04	Comem - LA 22		
10	Termična slika Winding temperature indicator	B05	Kihlströms - AKM 35	34884-2	75/0/110/115°C 25 K/1.6 Ω
11	Kontaktni termometer Contact thermometer	B06	Kihlströms - AKM 34	364703-1	50/0/95/100°C
12	Varnostni ventil Pressure relief valve	B07	Comem - 125T		
13	Tokovni transformator Current transformer	B08	FTM - 150-2	04090848	Cl 3, 10VA v 1V
14					
15					
16					
17					
18					
19					
20					
21					

16.0 FUNKCIONALNI PREIZKUS KOMANDNE OMARICE
FUNCTIONAL TEST OF CONTROL CUBICLE

Delovanje omarice je preizkušeno na osnovi načrta (na vratih omarice).
 The functional test has been performed according to the drawing (on cubicle door).

preizkus opravljen test O.K.

17.0 FUNKCIONALNI PREIZKUS ELEMENTOV NA TRANSFOR.
FUNCTIONAL TEST OF ELEMENTS ON TRANSFORMER

Elementi so preizkušeni na osnovi načrta (na vratih omarice).
 The functional test has been performed according to the drawing (on cubicle door).

preizkus opravljen test O.K.

EIMV
 4
 ELEKTROINŠTITUT MILAN VIDMAR
 Hajdrihova 2, 1000 Ljubljana, Slovenija



ETRA 33
ENERGETSKI TRANSFORMATORJI d.d.
Ljubljana - SLOVENIJA

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 20000-110**

Tov. št.: **74273**
Ser. No.:

18.0 MERITEV VIŠJEHARMONSKIH TOKOV PRAZNEGA TEKA
MEASUREMENTS OF THE HARMONICS OF THE NO-LOAD CURRENT

Napajano naviljje; Supply winding: **NN / LV**

90 % Un

Vrednosti; Variables: **Napetost; Voltage**

Vrednosti; Variables: **Tok; Current**

Spectrum 0.19 f11 50.010 Hz average over 1 periods

order	U1 3.426E+01Vrms U1 [Vrms] P101[°]	U2 7.158E+01Vrms U2 [Vrms] P102[°]	U3 3.206E+01Vrms U3 [Vrms] P103[°]			
0	0.000	0.000	0.000			
1	100.000	0.00	100.000	0.00	100.000	0.00
2	0.020	...	0.032	...	0.003	...
3	1.450	177.20	1.459	171.11	1.509	-173.70
4	0.004	...	0.007	...	0.005	...
5	0.531	-6.54	0.515	-19.64	0.800	5.03
6	0.015	...	0.005	...	0.007	...
7	1.305	15.60	1.432	-70.19	1.422	4.42
8	0.006	...	0.007	...	0.008	...
9	0.047	...	0.072	...	0.075	...
10	0.003	...	0.004	...	0.002	...
11	0.036	...	0.044	...	0.045	...
12	0.002	...	0.000	...	0.001	...

Spectrum 0.19 f11 50.010 Hz average over 1 periods



order	I1 0.617E+01Arms I1 [Arms] P101[°]	I2 7.494E+01Arms I2 [Arms] P102[°]	I3 1.202E+01Arms I3 [Arms] P103[°]			
0	0.000	0.000	0.000			
1	100.000	0.00	100.000	0.00	100.000	0.00
2	1.606	-49.15	1.539	31.53	1.390	171.62
3	16.047	-177.15	18.181	-107.53	5.491	1.27
4	1.103	61.61	0.951	-179.22	0.857	78.12
5	12.838	-30.13	12.647	151.77	12.758	-167.30
6	0.852	-132.93	0.020	...	0.681	-02.74
7	2.969	14.26	2.967	139.52	1.049	123.96
8	0.302	...	0.271	...	0.247	...
9	1.057	-81.65	0.914	-178.51	0.370	-65.60
10	0.143	...	0.161	...	0.110	...
11	0.815	39.72	1.158	52.76	1.018	140.14
12	0.101	...	0.033	...	0.068	...

scroll with cursor keys or enter a number HOLD
functions: harmonics spectrum LOCKED
variable: bargraph blockout length average absolut

scroll with cursor keys or enter a number HOLD
functions: harmonics spectrum LOCKED
variable: bargraph blockout length average absolut

Grafikon; Graph: **Napetost; Voltage**

Grafikon; Graph: **Tok; Current**



scroll with cursor keys HOLD
functions: harmonics LOCKED
single triple U&IAP phase on y-scale zoom

scroll with cursor keys HOLD
functions: harmonics LOCKED
single triple U&IAP phase on y-scale zoom

Merilna oprema; Measuring equipment:

- širokopasovni močnostni analizator Norma, tip D6000, točnost ± 0.05 %
- wide band power analyzer Norma, type D6000, accuracy ± 0.05 %
- merilni tokovni in napetostni transformatorji CdC, točnosti ± 0.2 %
- measuring current and voltage transformer CdC, accuracy ± 0.2 %



ELEKTROINŽITRUT MILAN VIDMAR
Hožarhova 7, 1000 Ljubljana, Slovenija



ETRA 33
ENERGETSKI TRANSFORMATORJI d.d.
Ljubljana - SLOVENIJA

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 20000-110**

Tov. št.: **74273**
Ser. No.:

18.0 MERITEV VIŠJEHARMONSKIH TOKOV PRAZNEGA TEKA
MEASUREMENTS OF THE HARMONICS OF THE NO-LOAD CURRENT

Napajano navitje; Supply winding: **NN / LV**

100 % Un


Vrednosti; Variables: **Napetost; Voltage**

Spectrum 0.19 f11 50.010 Hz average over 1 periods						
order	U1 3.795E+3V(H01)		U2 3.500E+3V(H01)		U3 3.559E+3V(H01)	
	U [z(H01)]	φ[01] [°]	U [z(H01)]	φ[01] [°]	U [z(H01)]	φ[01] [°]
0	0.000		0.000		0.000	
1	100.000	0.00	100.000	0.00	100.000	0.00
2	0.014	---	0.011	---	0.023	---
3	1.491	-176.60	1.430	168.28	1.514	-175.79
4	0.003	---	0.016	---	0.013	---
5	0.723	-7.60	0.675	-23.69	0.833	2.69
6	0.023	---	0.005	---	0.020	---
7	1.255	-14.16	1.303	-20.45	1.255	3.53
8	0.008	---	0.011	---	0.015	---
9	0.040	---	0.098	---	0.075	---
10	0.004	---	0.008	---	0.005	---
11	0.078	---	0.094	---	0.115	---
12	0.008	---	0.001	---	0.008	---


Vrednosti; Variables: **Tok; Current**

Spectrum 0.19 f11 50.010 Hz average over 1 periods						
order	I1 1.122E+0A(H01)		I2 9.623E-1A(H01)		I3 1.492E+0A(H01)	
	I [z(H01)]	φ[01] [°]	I [z(H01)]	φ[01] [°]	I [z(H01)]	φ[01] [°]
0	0.000		0.000		0.000	
1	100.000	0.00	100.000	0.00	100.000	0.00
2	2.591	-69.99	2.259	9.76	2.017	159.64
3	23.038	143.38	22.376	-100.37	8.100	-43.01
4	1.662	9.79	1.562	117.54	1.370	33.07
5	26.465	-108.97	26.592	72.25	24.450	125.44
6	1.808	149.33	0.116	---	1.314	-147.33
7	7.140	27.70	6.270	-157.95	6.958	-87.53
8	0.652	-61.05	0.643	173.04	0.495	29.89
9	2.323	168.04	2.203	61.32	0.338	178.13
10	0.284	---	0.309	---	0.238	-76.05
11	2.863	-101.68	3.873	-103.00	3.053	33.22
12	0.310	168.60	0.054	---	0.243	118.41

Grafikon; Graph: **Napetost; Voltage**



Grafikon; Graph: **Tok; Current**



Merilna oprema; Measuring equipment:

- širokopasovni močnostni analizator Norma, tip D6000, točnost ± 0.05 %
- wide band power analyzer Norma, type D6000, accuracy ± 0.05 %
- merilni tokovni in napetostni transformatorji CdC, točnosti ± 0.2 %
- measuring current and voltage transformer CdC, accuracy ± 0.2 %

ELEKTROINŠTITUT MILAN VIDMAR
Hajdova 2, 1000 Ljubljana, Slovenija



ETRA 33
ENERGETSKI TRANSFORMATORJI d.d.
Ljubljana - SLOVENIJA

MERILNI LIST TRANSFORMATORJA
TRANSFORMER TEST REPORT

Transformator:
Transformer: **RT 20000-110**

Tov. št.:
Ser. No.: **74273**

18.0 MERITEV VIŠJEHARMONSKIH TOKOV PRAZNEGA TEKA
MEASUREMENTS OF THE HARMONICS OF THE NO-LOAD CURRENT

Napajano navitje; Supply winding: **NN / LV** **110 % Un**

Vrednosti; Variables: **Napetost; Voltage**

Vrednosti; Variables: **Tok; Current**

Spectrum 0.10 f11 50.003 Hz average over 1 periods						
U1	U2	U3	U1	U2	U3	
4.210E+3Vrms	3.886E+3Vrms	3.954E+3Vrms	U [Vrms]	Phi[°]	U [Vrms]	
U [Vrms]	Phi[°]	U [Vrms]	Phi[°]	U [Vrms]	Phi[°]	
0	0.000	0.000	0.000	0.000	0.000	
1	100.000	0.00	100.000	0.00	100.000	0.00
2	0.026	0.021	0.021	---	0.024	---
3	1.547	-171.62	1.480	180.37	1.511	-170.80
4	0.010	---	0.025	---	0.014	---
5	1.453	-5.26	1.447	25.60	1.780	9.03
6	0.027	---	0.043	---	0.030	---
7	0.832	-14.62	0.754	-42.42	0.523	-14.05
8	0.014	---	0.016	---	0.014	---
9	0.103	-100.63	0.214	97.62	0.044	---
10	0.011	---	0.012	---	0.011	---
11	0.313	7.61	0.353	-24.71	0.413	42.77
12	0.011	---	0.001	---	0.012	---



Spectrum 0.10 f11 50.003 Hz average over 1 periods						
I1	I2	I3	I1	I2	I3	
2.017E+0Ah	2.025E+0Ah	2.175E+0Ah	I [Arms]	Phi[°]	I [Arms]	
I [Arms]	Phi[°]	I [Arms]	Phi[°]	I [Arms]	Phi[°]	
0	0.000	0.000	0.000	0.000	0.000	
1	100.000	0.00	100.000	0.00	100.000	0.00
2	1.603	-117.59	1.601	-45.16	1.129	97.50
3	30.542	44.22	25.143	125.05	4.763	142.06
4	1.189	137.74	1.212	-9.07	0.886	-72.30
5	52.726	72.20	50.747	-49.81	47.070	-4.18
6	1.433	-52.27	0.044	---	1.029	38.89
7	26.332	193.61	24.222	-10.41	23.510	70.46
8	0.509	18.52	0.512	81.30	0.341	---
9	4.655	193.72	4.340	145.13	0.257	---
10	0.250	---	0.287	---	0.197	---
11	7.415	-138.41	8.330	-87.79	6.782	73.45
12	0.249	---	0.012	---	0.189	---

scroll with cursor keys or enter a number HOLD
FUNCTIONS: harmonics spectrum LOCKED
variable | bargraph | blockout | length | average | absolute

scroll with cursor keys or enter a number HOLD
FUNCTIONS: harmonics spectrum LOCKED
variable | bargraph | blockout | length | average | absolute

Grafikon; Graph: **Napetost; Voltage**

Grafikon; Graph: **Tok; Current**



scroll with cursor keys HOLD
FUNCTIONS: harmonics spectrum LOCKED
single | triple | U1&P | phase on | y-scale | zoom

scroll with cursor keys HOLD
FUNCTIONS: harmonics spectrum LOCKED
single | triple | U1&P | phase on | y-scale | zoom

Merilna oprema; Measuring equipment:

- širokopasovni močnostni analizator Norma, tip D6000, točnosti ± 0.05 %
- wide band power analyzer Norma, type D6000, accuracy ± 0.05 %
- merilni tokovni in napetostni transformatorji CdC, točnosti ± 0.2 %
- measuring current and voltage transformer CdC, accuracy ± 0.2 %



ELEKTROINSTITUT MILAN VIDMAR
Hofječeva 2, 1000 Ljubljana, Slovenija

ETRA	ETRA 33 ENERGETSKI TRANSFORMATORJI d.d. Ljubljana - SLOVENIJA	MERILNI LIST TRANSFORMATORJA TRANSFORMER TEST REPORT	
	Transformator: Transformer: RT 20000-110	Tov. št.: Ser. No.: 74273	

19.0 MERITVE NA VGRAJENIH TOKOVNIH TRANSFORMATORJIH
MEASUREMENT ON BUILT-IN CURRENT TRANSFORMERS

19.1	Podatki; Ratings:	Magnetilna krivulja; Excitation curve:														
	Tip; Type: AOS	<table border="1"><caption>Excitation Curve Data (Approximate)</caption><thead><tr><th>mA</th><th>y</th></tr></thead><tbody><tr><td>0</td><td>0</td></tr><tr><td>1000</td><td>18</td></tr><tr><td>2000</td><td>21</td></tr><tr><td>3000</td><td>22</td></tr><tr><td>4000</td><td>23</td></tr><tr><td>5000</td><td>24</td></tr></tbody></table>	mA	y	0	0	1000	18	2000	21	3000	22	4000	23	5000	24
mA	y															
0	0															
1000	18															
2000	21															
3000	22															
4000	23															
5000	24															
	Tov. številka; Ser. No.: 04090848															
	Proizvajalec; Manufacturer: F.T.M. Srl. Italy															
	Razmerje; Ratio: 150/2 A															
	Moč; Power: 10 VA															
	Klasa; Class: 3															
	Fs 5															
	Int. oznaka; Int. designation: B08															
	Sponke; Terminals: P1-P2 / 1S1-1S2															
	Montiran v; Mounted in: 1V															
	termična slika															
	Meritve in preizkusi; Measurements and tests:															
	R _{izolaci} : 0.329 Ω															
	Polariteta; Polarity: O.K.															

Vse meritve in preizkusi so opravljene na sponkah v komandni omarici!
All measurements and tests are carried out at terminals in the terminal cubicle.

EMW
ELEKTROINŠTITUT MILAN VIDMAR
Hajdrihova 2, 1000 Ljubljana, Slovenia

CC

CC

11
12
13



**SLOVENSKA
AKREDITACIJA**



LP-063

akreditacijska listina accreditation certificate

Elektroinštitut Milan Vidmar

Hajdrihova ulica 2, 1000 Ljubljana
Laboratorij OVENO, Laboratorij OOK, Laboratorij LVN

Organizacija je akreditirana pri Slovenski akreditaciji (SA), kot preskuševalni laboratorij. S to listino se priznava izpolnjevanje zahtev standarda

SIST EN ISO/IEC 17025:2005

za dejavnosti, ki so opisane v prilogi te listine, označeni z isto številko.

Datum podelitve akreditacije: 30. maj 2005

Akreditacija je veljavna, če akreditirani organ v celoti izpolnjuje zahteve za akreditacijo, kar SA ugotavlja s postopki nadzora. Veljavnost akreditacije je mogoče preveriti na spletni strani SA, www.sa.gov.si.

Slovenska akreditacija je podpisnica sporazumov o medsebojnem priznavanju akreditacij na področju kalibracijskih in preskuševalnih laboratorijev pri Evropskem združenju za akreditacijo (EA) in pri Mednarodnem združenju za akreditiranje laboratorijev (ILAC).

The above entity has been accredited by Slovenian Accreditation (SA) as a testing laboratory. This is to signify compliance with the requirements of the SIST EN ISO/IEC 17025:2005 for the approved scope of accreditation as described in the Annex hereto marked with the same number.

Initial accreditation date: 30 May 2005

This accreditation shall remain in force provided that the accredited body fully complies with the accreditation requirements, which is determined by SA through surveillance. Information on current accreditation status is available at the SA website, www.sa.gov.si.

Slovenian Accreditation (SA) is a signatory of the Multilateral Agreements of the European Co-operation for Accreditation (EA) and International Laboratory Accreditation Co-operation (ILAC) for calibration and testing.

Ljubljana, 24. september 2008

CC

CC

Handwritten scribbles or marks at the bottom left of the page.



**SLOVENSKA
AKREDITACIJA**

Reg. št. / Ref. No.: 3150-0138/10-0007

Datum izdaje / Issued on: 30. maj 2016

Zamenjuje izdajo z dne / Replaces Annex dated: 1. julij 2015

Veljavnost akreditacije je mogoče preveriti na spletni strani SA, www.slo-akreditacija.si.
Information on current accreditation status is available at the SA website, www.slo-akreditacija.si.

PRILOGA K AKREDITACIJSKI LISTINI **Annex to the accreditation certificate**

LP-063

1 AKREDITIRANI ORGAN / Accredited body

Elektroinštitut Milan Vidmar

Hajdrihova ulica 2, 1000 Ljubljana

Kopija priloge za objavo na spletnem mestu. / Copy of attachment for web publishing.

2 STANDARD

SIST EN ISO/IEC 17025:2005

3 OBSEG AKREDITACIJE / Scope of accreditation

V okviru te akreditacijske listine Slovenska akreditacija priznava akreditiranemu organu usposobljenost za opravljanje naslednjih dejavnosti: / SA hereby acknowledges the accredited body as being competent for performing the following activities:

3.1 Skrajšan opis obsega akreditacije / A short description of the scope

Področja preskušanja glede na vrsto preskušanja / Testing fields with reference to the type of test:

- neionizirajoča sevanja (elektromagnetno sevanje, elektromagnetna združljivost / non-ionising radiation (electromagnetic radiation, electromagnetic compatibility)
- akustika, hrup, vibracije (hrup) / acoustics, noise, vibrations (noise)
- vzorčenje / sampling
- kemija / chemistry
- fizikalno preskušanje / physical testing



**SLOVENSKA
AKREDITACIJA**

Priloga k akreditacijski listini
Annex to the Accreditation Certificate

Datum izdaje / *Issued on*

Zamenjuje izdajo z dne / *Replaces Annex dated*

Veljavnost akreditacije je mogoče preveriti na
Information on current accreditation status is available at

LP-063

30. maj 2016

1. julij 2015

www.slo-akreditacija.si

Področja preskušanja glede na vrsto preskušanca / *Testing fields with reference to the type of test item:*

- okolje in vzorci iz okolja (virji elektromagnetnih sevanj, okolje, virji emisij snovi, zrak) / *environment and samples from the environment (electromagnetic radiation sources, environment, sources of emissions of substances, air)*
- električni proizvodi in oprema (elektromehanske naprave) / *electrical products and equipment (electromechanical devices)*

Kopija priloge za objavo na spletnem mestu. / *Copy of attachment for web publishing.*



3.2 Podroben opis obsega akreditacija / Detailed scope of accreditation

3.2.1 Laboratorij OVENO, Hajdrihova ulica 2, 1000 Ljubljana

Tabela / Table 1

Tip obsega: fiksni / Type of scope: fixed Mesto izvajanja: na terenu / Site: fieldwork Področja preskušanja glede na vrsto preskušanja: nelonizirajoča sevanja (elektromagnetno sevanje) / Testing fields with reference to the type of test: non-ionising radiation (electromagnetic radiation) Področja preskušanja glede na vrsto preskušanja: Okolje in vzorci iz okolja (virji elektromagnetnih sevanj) / Testing fields with reference to the type of test item: environment and samples from the environment (electromagnetic radiation sources)				
Sl. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja; negotovost rezultata preskušanja (kjer je to pomembno) Range of testing; Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
1.	SIST ENV 50166-1:1995 razveljavljen withdrawn brez poglavja 4 without chapter 4	Izpostavljenost človeka elektromagnetnim poljem, Nizke frekvence (0 Hz do 10 kHz) Human exposure to electromagnetic fields Low frequency (0 Hz to 10 kHz)	5 Hz – 10 kHz	visokonapetostni daljnovodi, transformatorske postaje, elektrarne, transformatorji in električna oprema HV power lines, power substations, power plants, transformers and electric equipment
2.	IEEE Std 644-1987 brez točk 4.3, 6.3 without points 4.3, 6.3	Standardni postopki IEEE za meritev izmeničnih električnih in magnetnih polj energetskih vodov IEEE standard procedures for measurement of power frequency electric and magnetic fields from AC power lines	5 Hz – 30 kHz	visokonapetostni daljnovodi, transformatorske postaje, elektrarne, transformatorji in električna oprema HV power lines, power substations, power plants, transformers and electric equipment
3.	IEEE Std 644-1994 brez točk 4.3, 6.3 without points 4.3, 6.3	Standardni postopki IEEE za meritev izmeničnih električnih in magnetnih polj energetskih vodov IEEE standard procedures for measurement of power frequency electric and magnetic fields from AC power lines	5 Hz – 30 kHz	visokonapetostni daljnovodi, transformatorske postaje, elektrarne, transformatorji in električna oprema HV power lines, power substations, power plants, transformers and electric equipment



Tip obsega: fiksni / Type of scope: fixed Mesto izvajanja: na terenu / Site: fieldwork Področja preskušanja glede na vrsto preskušanja: nelonizirajoča sevanja (elektromagnetno sevanje) / Testing fields with reference to the type of test: non-ionising radiation (electromagnetic radiation) Področja preskušanja glede na vrsto preskušanca: Okolje in vzorci iz okolja (virji elektromagnetnih sevanj) / Testing fields with reference to the type of test item: environment and samples from the environment (electromagnetic radiation sources)				
St. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja; Negotovost rezultata preskušanja (kjer je to pomembno) Range of testing; Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
4.	SIST IEC 61786: 2005 brez točk 5.2, 6.2 without points 5.2, 6.2	Merjenje nizkofrekvenčnih elektromagnetnih polj z vidika izpostavljenosti ljudi – Posebne zahteve za instrumente in napolki za merjenje Measurement of low-frequency magnetic and electric fields with regard to exposure of human beings – Special requirements for instruments and guidance for measurements	frekvenčno območje: 15 Hz – 9 kHz frequency range: 15 Hz – 9 kHz	visokonapetostni daljnovodi, transformatorske postaje, elektrarne, transformatorji in električna oprema HV power lines, power substations, power plants, transformers, and electric equipment

Tabela / Table 2

Tip obsega: fiksni / Type of scope: fixed Mesto izvajanja: na terenu / Site: fieldwork Področja preskušanja glede na vrsto preskušanja: nelonizirajoča sevanja (elektromagnetna združljivost) / Testing fields with reference to the type of test: non-ionising radiation (electromagnetic compatibility) Področja preskušanja glede na vrsto preskušanca: električni proizvodi in oprema (elektromehanske naprave) / Testing fields with reference to the type of test item: electrical products and equipment (electromechanical devices)				
St. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja; Negotovost rezultata preskušanja (kjer je to pomembno) Range of testing; Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
5.	SIST EN 61000-4-4:2013 poglavje 7.4, samo asimetrične prenapetosti clause 7.4, asymmetrical overvoltages only modificirana modified	Elektromagnetna združljivost (EMC) - 4-4. del: Preskusne in merilne tehnike - Preskus odpornosti proti hitrim električnim prehodnim pojavom/razpoku (IEC 61000-4-4:2012) Electromagnetic compatibility (EMC) - Part 4-4: Testing and measurement techniques - Electrical fast transient/burst immunity test OPA.6.EMC Merjenje prehodnih prenapetosti Measurement of transient overvoltages	frekvenčno območje: (0 – 100) MHz napetostno območje: (0-2500) Veff frequency range: (0 – 100) MHz voltage range: (0-2500) Veff	sekundarna oprema v visokonapetostnih, srednjena-petostnih in nizkonape-tostnih transformatorstorskih postajah, elektrarnah secondary equipment in HV, MV and LV power substations, power plants



Tip obsega: fiksni / Type of scope: fixed
Mesto izvajanja: na terenu / Site: fieldwork
Področja preskušanja glede na vrsto preskušanja: neionizirajoča sevanja (elektromagnetna združljivost) / Testing fields with reference to the type of test: non-ionising radiation (electromagnetic compatibility)
Področja preskušanja glede na vrsto preskušanca: električni proizvodi in oprema (elektromehanske naprave) / Testing fields with reference to the type of test item: electrical products and equipment (electromechanical devices)

St. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja, negotovost rezultata preskušanja (kjer je to pomembno) Range of testing, Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
6.	SIST EN 50522:2011 paragraf L.2.2c), L.4 a, L.4 b paragraph L.2.2c), L.4 a, L.4 b	Ozemljitve močnostnih inštalacij, ki presegajo 1 kV izmenične napetosti Earthing of power installations exceeding 1 kV a.c.		razdelilne transformatorske postaje, razdelilne postaje, transformatorske postaje, elektrarne power stations, power substations, power plants
7.	SIST EN 50522:2011 paragraf L.2.2c) paragraph L.2.2c) modificirana modified	OPA.6.OZ Meritev ozemljitvene impedance z visokotokovno metodo Measurement of impedance to earth using heavy current injection method		razdelilne transformatorske postaje, razdelilne postaje, transformatorske postaje, elektrarne power stations, power substations, power plants

Kopija priloge za objavo na spletnem mestu. / Copy of attachment for web publishing.

Tabela / Table 3

Tip obsega: fiksni / Type of scope: fixed
Mesto izvajanja: na terenu / Site: fieldwork
Področja preskušanja glede na vrsto preskušanja: akustika, hrup, vibracije (hrup) / Testing fields with reference to the type of test: acoustics, noise, vibrations (noise)
Področja preskušanja glede na vrsto preskušanca: okolje in vzorci iz okolja (okolje) / Testing fields with reference to the type of test item: environment and samples from the environment (environment)

St. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja, negotovost rezultata preskušanja (kjer je to pomembno) Range of testing, Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
8.	SIST ISO 1996-2:2007	Akustika – Opis, merjenje in ocena hrupa v okolju – 2. del: Določanje ravni hrupa v okolju Acoustics- Description, measurement and assessment of environmental noise – Part 2: Determination of environmental noise levels <u>v povezavi s SIST ISO 1996-1:2006</u>	območje merjenja: (34 – 108) dBA frekvenčno območje: (20 – 20.000) Hz range of measurement: (34 – 108) dBA frequency range: (20 – 20.000) Hz	hrup v okolju environmental noise



Tip obsega: fiksni / Type of scope: fixed Mesto izvajanja: na terenu / Site: fieldwork Področja preskušanja glede na vrsto preskušanja: akustika, hrup, vibracije (hrup) / Testing fields with reference to the type of test: acoustics, noise, vibrations (noise) Področja preskušanja glede na vrsto preskušanca: okolje in vzorci iz okolja (okolje) / Testing fields with reference to the type of test item: environment and samples from the environment (environment)				
Sl. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja; Negotovost rezultata preskušanja (kjer je to pomembno) Range of testing; Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
9.	SIST ISO 9613-2:1997	Akustika – Slabljenje zvoka pri širjenju na prostem – Splošna metoda za računanje izračun na osnovi meritev izvedenih po standardu SIST ISO 1996-2 Acoustics – Attenuation of sound during propagation outdoors - General method of calculation The calculation on the basis of measurements carried out according to standard SIST ISO 1996-2	območje izračuna: (34 – 108) dBA frekvenčno območje: (100 – 8000) Hz range of measurement: (34 – 108) dBA frequency range: (100 – 8000) Hz	hrup v okolju environmental noise
10.	IEEE Std 656-1992	IEEE standard za merjenje akustičnega hrupa daljnovidov IEEE Standard for the Measurement of Audible Noise From Overhad Transmission Lines	Območje merjenja: (34 – 108) dBA Frekvenčno območje: (20 – 20.000) Hz range of measurement: (34 – 108) dBA frequency range: (20 – 20.000) Hz	hrup daljnovidov v okolju noise from overhad transmission lines

Kopija priloge za objavo na spletnem mestu / Copy of attachment for web publishing

3.2.2 Laboratorij OOK, Hajdrihova ulica 2, 1000 Ljubljana

Tabela / Table 4

Tip obsega: fiksni / Type of scope: fixed Mesto izvajanja: na terenu / Site: fieldwork Področja preskušanja glede na vrsto preskušanja: vzorčenje; kemija; fizikalno preskušanje / Testing fields with reference to the type of test: sampling; chemistry; physical testing Področja preskušanja glede na vrsto preskušanca: okolje in vzorci iz okolja (viri emisij snovi, zrak) / Testing fields with reference to the type of test item: environment and samples from the environment (sources of emissions of substances, air)				
Sl. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja; Negotovost rezultata preskušanja (kjer je to pomembno) Range of testing; Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
11.	SIST ISO 7935:1996	Emisije nepremičnih virov - Ugotavljanje masne koncentracije žvepovega dioksida - Delovne karakteristike avtomatskih merilnih metod Stationary source emissions - Determination of the mass concentration of sulfur dioxide - Performance characteristics of automated measuring methods	SO ₂ : (1 – 2000) mg/m ³	odpadni plini waste gases



**SLOVENSKA
AKREDITACIJA**

Priloga k akreditacijski listini
Annex to the Accreditation Certificate

LP-063

Datum izdaje / Issued on

30. maj 2016

Zamenjuje izdajo z dne / Replaces Annex dated

1. julij 2015

Veljavnost akreditacije je mogoče preveriti na
Information on current accreditation status is available at

www.slo-akreditacija.si

Tip obsega: fiksni / Type of scope: fixed Mesto izvajanja: na terenu / Site: fieldwork Področja preskušanja glede na vrsto preskušanja: vzorčenje; kemija; fizikalno preskušanje / Testing fields with reference to the type of test: sampling; chemistry; physical testing Področja preskušanja glede na vrsto preskušanca: okolje in vzorci iz okolja (virji emisij snovi); zrak / Testing fields with reference to the type of test item: environment and samples from the environment (sources of emissions of substances; air)				
Sl. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja; negotovost rezultata preskušanja (kjer je to pomembno) Range of testing; Uncertainty of the result of testing (where relevant)	Materiali, proizvodi Materials, products
12.	ASTM D 2156-94:2003	Standardna preskusna metoda za določanje dimnega števila v odpadnih plinih pri izgorevanju destiliranih goriv Standard Test Method for Smoke Density in Flue Gases from Burning Distillate Fuels	dimno število: 0 - 9	odpadni plini waste gases
13.	SIST ISO 10780:1996	Emisije nepremičnih virov: Meritev hitrosti in volumnskega pretoka plinskih tokov v odvodnikih Stationary source emissions - Measurement of velocity and volume flowrate of gas streams in ducts	v: (2 - 48) m/s	odpadni plini waste gases
14.	SIST EN 14385:2004 samo vzorčenje sampling of only	Emisije nepremičnih virov - Določevanje celotne emisije As, Cd, Cr, Co, Cu, Mn, Ni, Pb, Sb, Tl in V Stationary source emissions - Determination of the total emission of As, Cd, Cr, Co, Cu, Mn, Ni, Pb, Sb, Tl and V		odpadni plini waste gases
15.	SIST EN 13211:2002 samo vzorčenje sampling only; za objavo na Kopij za objavo na	Kakovost zraka - Emisije nepremičnih virov - Ročna metoda za določevanje celotnega živega srebra, mestu. Air quality - Stationary source emissions - Manual method of determination of the concentration of total mercury		odpadni plini waste gases
16.	SIST EN 15058:2006	Emisije nepremičnih virov - Določevanje masne koncentracije ogljikovega monoksida (CO) - Referenčna metoda: nedisperzivna infrardeča spektrometrija Stationary source emissions - Determination of the mass concentration of carbon monoxide (CO) - Reference method: Non-dispersive infrared spectrometry	CO: (0,5 - 1250) mg/m ³	odpadni plini waste gases
17.	SIST EN 14792:2006	Emisije nepremičnih virov - Določevanje masne koncentracije dušikovih oksidov (NO _x) - Referenčna metoda: kemiluminiscenca Stationary source emissions - Determination of mass concentration of nitrogen oxides (NO _x) - Reference method: Chemiluminescence	NO _x : (0,5 - 2000) mg/m ³	odpadni plini waste gases
18.	SIST EN 14789:2005	Emisije nepremičnih virov - Določevanje volumnske koncentracije kisika (O ₂) - Referenčna metoda: paramagnetizem Stationary source emissions - Determination of volume concentration of oxygen (O ₂) - Reference method - Paramagnetism	O ₂ : (0,1-25) % vol.	odpadni plini waste gases



Tip obsega: fiksni / Type of scope: fixed Mesto izvajanja: na terenu / Site: fieldwork Področja preskušanja glede na vrsto preskušanja: vzorčenje; kemija; fizikalno preskušanje / Testing fields with reference to the type of test: sampling; chemistry; physical testing Področja preskušanja glede na vrsto preskušanca: okolje in vzorci iz okolja (viri emisij snovi), zrak / Testing fields with reference to the type of test item: environment and samples from the environment (sources of emissions of substances, air)				
Sl. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja; negotovost rezultata preskušanja (kjer je to pomembno) Range of testing; Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
19.	SIST EN 12619:2013	Emisije nepremičnih virov - Določevanje masnih koncentracij celotnega organskega ogljika v plinasti fazi - Kontinuirana metoda plamenske ionizacijske detekcije Stationary source emissions - Determination of the mass concentration of total gaseous organic carbon - Continuous flame ionisation detector method	(0,1-- 200) mg/m ³	odpadni plini waste gases
20.	SIST EN ISO 16911-1:2014	Emisije nepremičnih virov - Ročno in avtomatsko določevanje hitrosti in volumskega pretoka v odvodnikih - 1. del: Ročna referenčna metoda Stationary source emissions - Manual and automatic determination of velocity and volume flow rate in ducts - Part 1: Manual reference method	v: (2 -- 30) m/s	odpadni plini waste gases
21.	SIST EN 14211:2012 brez poglavja 8 in 11.1 without chapter 8 and 11.1	Kakovost zunanje zraka - Standardna metoda za določanje koncentracije dušikovega dioksida in dušikovega monoksida s kemiluminiscenco Ambient air quality - Standard method for the measurement of the concentration of nitrogen dioxide and nitrogen monoxide by chemiluminescence	NO: (2-1200) µg/m ³ NO ₂ : (2-500) µg/m ³	zrak air
22.	SIST EN 14212:2012 brez poglavja 8 in 11.1 without chapter 8 and 11.1	Kakovost zunanje zraka - Standardna metoda za določanje koncentracije žveplovega dioksida z ultravijolično fluorescenco Ambient air quality - Standard method for the measurement of the concentration of sulphur dioxide by ultraviolet fluorescence	SO ₂ : (1-1000) µg/m ³	zrak air

Tabela / Table 5

Tip obsega: fiksen / Type of scope: fixed Mesto izvajanja: na terenu in v laboratoriju / Site: fieldwork and in the laboratory Področja preskušanja glede na vrsto preskušanja: vzorčenje; kemija; fizikalno preskušanje / Testing fields with reference to the type of test: sampling; chemistry; physical testing Področja preskušanja glede na vrsto preskušanca: okolje in vzorci iz okolja (virni emisiji snovi, zrak) / Testing fields with reference to the type of test item: environment and samples from the environment (sources of emissions of substances, air)				
St. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode In morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja, negotovost rezultata preskušanja (kjer je to pomembno) Range of testing; Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
23.	SIST ISO 9096:2003	Emisije nepremičnih virov - Ročno določanje masne koncentracije trdnih delcev Stationary source emissions - Manual determination of mass concentration of particulate matter	celotni prah: (20 - 475) mg/m ³	odpadni plini waste gases
24.	SIST EN 13284-1:2002	Emisije nepremičnih virov - Določevanje majhnih masnih koncentracij prahu - 1. del: Ročna gravimetrijska metoda Stationary source emissions - Determination of low range mass concentration of dust - Part 1: Manual gravimetric method	celotni prah: (0,5 - 50) mg/m ³	odpadni plini waste gases
25.	VDI 2066 Part 10:2004	Meritev emisij PM ₁₀ in PM _{2,5} na nepremičnih virih onesnaževanja z impaktorjem Messung der Emissionen von PM ₁₀ und PM _{2,5} an geführten Quellen nach dem Impaktionsverfahren	PM _{2,5} : (1 - 50) mg/m ³ PM ₁₀ : (2 - 50) mg/m ³	odpadni plini waste gases
26.	SIST EN 12341:2014	Zunanji zrak - Standardna gravimetrijska metoda za določevanje masne koncentracije frakcije ledbečih delcev PM ₁₀ ali PM _{2,5} Ambient air - Standard gravimetric measurement method for the determination of the PM ₁₀ or PM _{2,5} mass concentration of suspended particulate matter	> 2 µg/m ³	zrak air
27.	SIST EN ISO 1911:2011	Emisije nepremičnih virov - Določevanje masne koncentracije plinskih kloridov, izražene kot HCl - Standardna referenčna metoda - Analiza vzorca se izvaja po metodi B Stationary source emissions - Determination of mass concentration of gaseous chlorides expressed as HCl - Standard reference method - Sample analysis according to Method B	HCl: (1,5 - 5000) mg/m ³	odpadni plini waste gases
28.	SIST EN 14791:2005	Emisije nepremičnih virov - Določevanje masne koncentracije žveplovega dioksida - Referenčna metoda Stationary source emissions - Determination of mass concentration of sulphur dioxide - Reference method	SO ₂ : (20 - 500) mg/m ³	odpadni plini waste gases
29.	SIST ISO 15713:2009	Emisije nepremičnih virov - Vzorčenje in določevanje plinastega fluorida Stationary source emissions - Sampling and determination of gaseous fluoride content	HF: (0,5-200) mg/m ³	odpadni plini waste gases
30.	SIST EN 14790:2005	Emisije nepremičnih virov - Določevanje vodne pare v odvodnikih Stationary source emissions - Determination of the water vapour in ducts	vлага: (58-250) g/m ³	odpadni plini waste gases



**SLOVENSKA
AKREDITACIJA**

Priloga k akreditacijski listini
Annex to the Accreditation Certificate

Datum izdaje / Issued on

Zamenjuje izdajo z dne / Replaces Annex dated

Veljavnost akreditacije je mogoče preveriti na

Information on current accreditation status is available at

LP-063

30. maj 2016

1. julij 2015

www.slo-akreditacija.si

3.2.3 Laboratorij za visoke napetosti (LVN), Jamova 20, 1000 Ljubljana

Tabela / Table 6

Tip obsega: fiksni / Type of scope: fixed Mesto izvajanja: v laboratoriju / Site: in the laboratory Področja preskušanja glede na vrsto preskušanja: fizikalno preskušanje / Testing fields with reference to the type of test: physical testing Področja preskušanja glede na vrsto preskušanca: električni proizvodi in oprema (elektromehanske naprave) / Testing fields with reference to the type of test item: electrical products and equipment (electromechanical devices)				
St. No.	Oznaka standarda ali nestandardne preskusne metode Reference to standard or non-standard testing method	Naslov standarda ali nestandardne preskusne metode in morebitne navezave na druge standarde ali metode Title of standard or non-standard testing method and eventual relations to other standards or methods	Območje preskušanja Negotovost rezultata preskušanja (kjer je to pomembno) Range of testing; Uncertainty of the result of testing (where relevant)	Materiali; proizvodi Materials; products
31.	IEC 60060-1:2010 razen točke 4.5 except point 4.5	Visokonapetostni preizkusi električnih naprav High voltage tests.	Izmenična napetost: do 500 kV Enosmerna napetost: do 600 kV Udarna napetost: LI do 1800 kV SI do 1100 kV	visokonapetostne naprave high-voltage equipment
32.	IEC 61284:1997 točka 14 point 14	Meritev korone in radiointerferenčne napetosti (RIV) Corona and radio interference voltage (RIV) tests	do 500 kV	visokonapetostne naprave high-voltage equipment

Kopija priloge za objavo na spletnem mestu. / Copy of attachment for web publishing.

- Opombe / Notes:**
- V vseh točkah podrobnega obsega akreditacije, pri katerih v rubriki "Območje preskušanja; Negotovost rezultata preskušanja" ni navedenih podatkov, veljajo določila posameznih standardov oziroma nestandardnih preskusnih metod, ki se na to nanašajo.
In all columns of the scope of accreditation where the cells under "Range of measurement, testing; Uncertainty of the result of testing" are empty, the provisions of the relevant standards or non-standard testing methods should apply.
 - V točkah podrobnega obsega akreditacije, pri katerih sta v rubriki "Oznaka standarda" navedeni dve ali več oznak standardov, se sklic nanaša na v celoti identične standarde.
In those columns of the scope of accreditation where the cells under "Reference" specify two or more codes of standards, the complete citation to identical standards should apply.

Kopija priloge k akreditacijski listini za objavo na spletnem mestu.
Podpisani original priloge na vpogled na sedežu SA.
Copy of Annex to the accreditation certificate for web publishing.
Signed original of Annex available for consultation at the SA head office.

Direktor / Director
dr. Boštjan Godec

на бланка на СЛОВЕНСКА АКРЕДИТАЦИЯ

ЛП-063

СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ

ЕЛЕКТРОИНСТИТУТ МИЛАН ВИДМАР

ул. Хайдрихова 2, 1000 Любляна, Словения

Лаборатории ОВЕНО, Лаборатории ООК, Лаборатории ЛВН

Горната организация е акредитирана от Словенската Акредитация (СА), като изпитвателна лаборатория. Този документ удостоверява съответствие с изискванията на стандарта СИСТ ЕН ИСО/ИЕЦ 17025:2005 (SIST EN ISO/IEC 17025:2005) за одобрения обхват за акредитация, както е описано в анекса, отбелязан със същия номер.

Първоначална дата за акредитация: 30 май 2005г.

Тази акредитация остава в сила при условие, че акредитираната организация напълно отговаря и съответства с изискванията за акредитиране, които са определени от СА чрез наблюдение. Информация за настоящия статут на акредитиране може да бъде намерена на интернет страницата на СА: www.sa.gov.si.

Словенската Акредитация (СА) подписваща страна на многостранно споразумение за Европейско сътрудничество за Акредитация (ЕА) и Международно Сътрудничество за Акредитация на Лаборатории (МСАЛ) за калибриране и изпитване.

Любляна, 24 септември 2008г.

Преводът на български език е извършен от Стефан Минчев

(:

(

Реф. No.: 3150-0138/10-0007

Издаден на: 30 май 2016

Заменя Анекс издаден на: 1 юли 2015

Информация за настоящия акредитационен статус е налична на интернет страницата на СА: www.slo-akreditacija.si.

АНЕКС към Сертификат за Акредитация Номер ЛП-063/LP-063

1. Акредитирана организация:

ЕЛЕКТРОИНСТИТУТ МИЛАН ВИДМАР

ул. Хайдрихова 2, 1000 Любляна, Словения

2 СТАНДАРТ

СИСТ ЕН ИСО/ИЕЦ 17025:2005 (SIST EN ISO/IEC 17025:2005)

3 ОБХВАТ НА АКРЕДИТАЦИЯТА

СА с настоящото потвърждава, че акредитираната организация притежава компетентия/компетентност за извършването на следните дейности:

3.1 Кратко описание на обхвата

Тестване по отношение на вида на изпитването:

- не-йонизиращо лъчение (електромагнитна радиация, електромагнитна съвместимост)
- акустика, шум, вибрации (шум)
- вземане на проби
- химия
- физически тестове

Тестване във връзка с вида на изпитвания обект:

- околната среда и проби от околната среда (електромагнитни лъчения, околната среда, източници на емисии на вещества, въздух)
- електрически продукти и оборудване (електромеханични устройства)

3.2 Подробен обхват на акредитирането

3.2.1. ЛАБОРАТОРИИ ЛАВЕНО, ул. Хайдрихова 2, 1000 Любляна, Словения


Таблица 1

Тип на обхвата: <i>фиксиран</i> Място: <i>на обекта/на полето</i> Изпитване по отношение на типа на изпитване: <i>не-йонизиращо лъчение (електромагнитна радиация, електромагнитна съвместимост)</i> Тестване във връзка с вида на изпитвания обект: <i>околната среда и проби от околната среда (електромагнитни лъчения, околната среда, източници на емисии на вещества, въздух)</i>				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
1.	SIST ENV 50166-1:1995 изтеглен без глава 4	Излагане на човешкия организъм на въздействието на електромагнитни полета с ниска честота (0 Hz до 10 kHz)	5 Hz – 10 kHz	Силови линии Високо Напрежение (ВН), подстанции, централи, трансформатори и електрооборудване
2.	IEEE Std 644-1987 Без точки 4.3, 6.3	IEEE стандартни процедури за измерване на електрически и магнитни полета с промишлена честота от AC силови линии	5 Hz – 30 kHz	Силови линии Високо Напрежение (ВН), подстанции, централи, трансформатори и електрооборудване

Преводът на български език е извършен от Стефан Минцев

C:

C:






3.	IEEE Std 644-1994 Без точки 4.3, 6.3	IEEE стандартни процедури за измерване на електрически и магнитни полета с промишлена честота от AC силови линии	5 Hz – 30 kHz	Силови линии Високо Напрежение (ВН), подстанции, централи, трансформатори и електрооборудване
----	---	--	---------------	---


Тип на обхвата: фиксиран Място: на обекта/на полето Изпитване по отношение на типа на изпитване: не-йонизиращо лъчение (електромагнитна радиация, електромагнитна съвместимост) Тестване във връзка с вида на изпитвания обект: околната среда и проби от околната среда (електромагнитни лъчения, околната среда, източници на емисии на вещества, въздух)				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
4.	SIST IEC 61786: 2005 без точки 5.2, 6.2	Измерване на нискофреkwотни магнитни и електрически полета по отношение на излагането на човешкото тяло – Специални изисквания за измервателните прибори и ръководство за измервания	Честотен обхват: 15 Hz – 9 kHz	Силови линии, подстанции, централи, трансформатори и електрооборудване

Таблица 2

Тип на обхвата: фиксиран Място: на обекта/на полето Изпитване по отношение на типа на изпитване: не-йонизиращо лъчение (електромагнитна радиация, електромагнитна съвместимост) Тестване във връзка с вида на изпитвания обект: електрически продукти и оборудване (електромеханични устройства)				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
5.	SIST EN 61000-4-4:2013 клауза 7.4, асиметрични пренапрежения само променено	Електромагнитна съвместимост (EMC) - Част 4-4: Тестване и техники за измерване Електрически бърз преходен процес/тест за пробив Измерване на преходни пренапрежения	Честотен обхват: (0 – 100) MHz Обхват по напрежение: (0-2500) Veff	Силови подстанции и електрически централи с Високо Напрежение (ВН), Средно Напрежение (СрН) и Ниско Напрежение (НН)

Преводът на български език е извършен от Стефан Минчев



Тип на обхвата: фиксиран Място: на обекта/на полето Изпитване по отношение на типа на изпитване: не-йонизиращо лъчение (електромагнитна радиация, електромагнитна съвместимост) Тестване във връзка с вида на изпитвания обект: електрически продукти и оборудване (електромеханични устройства)				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
6.	SIST EN 50522:2011 параграф L.2.2c), L.4 a, L.4 b	Заземяване на силови инсталации над 1 kV a.c.		Силови станции, подстанции и електрически централи
7.	SIST EN 50522:2011 параграф L.2.2c) Променен	Измерване на импеданс към земя с използване на метод с голям инжектиран ток		Силови станции, подстанции и електрически централи

Таблица 3

Тип на обхвата: фиксиран Място: на обекта/на полето Изпитване по отношение на типа на изпитване: акустика, шум, вибрации (шум) Тестване във връзка с вида на изпитвания обект: околната среда и проби от околната среда (околната среда)				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
8.	SIST ISO 1996-2:2007	Акустика- Описание, измерване и оценка на шума в околната среда - Част 2: Определяне на нивата на шум в околната среда Съответствие с/във връзка с SIST ISO 1996-1:2006	Обхват на измерване: (34 – 108) dBA Честотен обхват: (20 – 20.000) Hz	Шум в околната среда

Тип на обхвата: фиксиран Място: на обекта/на полето Изпитване по отношение на типа на изпитване: акустика, шум, вибрации (шум) Тестване във връзка с вида на изпитвания обект: околната среда и проби от околната среда (околната среда)				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
9.	SIST ISO 9613-2:1997	Акустика - Затихване на звука по време на разпространението му на открито - Общ метод за изчисляване Изчисляването на базата на измерванията, извършени в съответствие със стандарт SIST ISO 1996-2	Обхват на измерванията: (34 – 108) dBA Честотен обхват: (100 – 8000) Hz	Шум в околната среда
10.	IEEE Std 656-1992	IEEE Стандарт за измерване на Звуков шум от преносни въздушни електропроводи	Обхват на измерванията: (34 – 108) dBA Честотен обхват: (20 – 20.000) Hz	Шум от преносни въздушни електропроводи

Преводът на български език е извършен от Стефан Минчев

(

(


3.2.1. ЛАБОРАТОРИИ ООК, ул. Хайдрихова 2, 1000 Любляна, Словения

Таблица 4

Тип на обхвата: <i>фиксиран</i> Място: <i>на обекта/на полето</i> Изпитване по отношение на типа на изпитване: <i>вземане на проби, химия, физически тестове</i> Тестване във връзка с вида на изпитвания обект: <i>околната среда и проби от околната среда (източници на емисии на вещества, въздух)</i>				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
11.	SIST ISO 7935:1996	Емисии от неподвижни източници - Определяне на масовата концентрация на серен диоксид - Работни характеристики на автоматизирани методи за измерване	SO ₂ : (1 – 2000) mg/m ³	Отпадни газове

Тип на обхвата: <i>фиксиран</i> Място: <i>на обекта/на полето</i> Изпитване по отношение на типа на изпитване: <i>вземане на проби, химия, физически тестове</i> Тестване във връзка с вида на изпитвания обект: <i>околната среда и проби от околната среда (източници на емисии на вещества, въздух)</i>				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
12.	ASTM D 2156-94:2003	Стандартен метод за изпитване <i>Smoke</i> Плътност в димните газове от изгарянето на дестилатни горива	Чувствителност за дим: 0 - 9	Отпадни газове
13.	SIST ISO 10780:1996	Неподвижни източници на емисии - измерване на скоростта на скорост и дебит на газовите потоци в проводите	v: (2 – 48) m/s	Отпадни газове
14.	SIST EN 14385:2004 Само проби	Емисии от неподвижни източници - Определяне на общото количество на емисиите на As, Cd, Cr, Co, Cu, Mn, Ni, Pb, Sb, Tl and V		Отпадни газове
15.	SIST EN 13211:2002 само проби	Качество на въздуха - Неподвижни източници на емисии - Mapua метод за определяне на концентрацията на общия живак		Отпадни газове
16.	SIST EN 15058:2006	Неподвижни източници на емисии - Определяне на концентрацията на масата на въглероден окис (CO) - Референтен метод: Не-дисперсионни инфрачервена спектрометрия	CO: (0,5 – 1250) mg/m ³	Отпадни газове

Преводът на български език е извършен от Стефан Минчев



17.	SIST EN 14792:2006	Неподвижни източници на емисии - Определяне на масова концентрация на азотни оксиди (NOx) - Референтен метод: хемилуминесценция	NOx: (0,5 – 2000) mg/m ³	Отпадни газове
18.	SIST EN 14789:2005	Неподвижни източници на емисии - Определяне на концентрация обем на кислород (O ₂) - Референтен метод - парамагнетизъм	O ₂ : (0,1-25) % vol.	Отпадни газове

Тип на обхвата: фиксиран Място: на обекта/на полето Изпитване по отношение на типа на изпитване: вземане на проби, химия, физически тестове Тестване във връзка с вида на изпитвания обект: околната среда и проби от околната среда (източници на емисии на вещества, въздух)				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
19.	SIST EN 12619:2013	Неподвижни източници на емисии - Определяне на концентрацията на масата на общия газообразен органичен въглерод - Непрекъснато пламък метод йонизационен детектор	(0,1– 200) mg/m ³	Отпадни газове
20.	SIST EN ISO 16911-1:2014	Стационарни източници на емисии - Ръчно и автоматично определяне на скоростта и дебит в канали - Част 1: Ръчно референтен метод	v: (2 – 30) m/s	Отпадни газове
21.	SIST EN 14211:2012 Без глава 8 и 11.1	Качество на атмосферния въздух - стандартен метод за измерване на концентрацията на азотен диоксид и азотен монооксид чрез хемилуминесценция	NO: (2-1200) µg/m ³ NO ₂ : (2-500) µg/m ³	въздух
22.	SIST EN 14212:2012 Без глава 8 и 11.1	Качество на атмосферния въздух - стандартен метод за измерване на концентрацията на серен диоксид от ултравиолетова флуоресценция	SO ₂ : (1-1000) µg/m ³	въздух

Преводът на български език е извършен от Стефан Минчев



Таблица 5

Тип на обхвата: фиксиран Място: на обекта/на полето и в лаборатория Изпитване по отношение на типа на изпитване: вземане на проби, химия, физически тестове Тестване във връзка с вида на изпитвания обект: околната среда и проби от околната среда (източници на емисии на вещества, въздух)				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
23.	SIST ISO 9096:2003	Неподвижни източници на емисии - Ръчно определяне на масова концентрация на частици	Съдържание на прах: (20 – 475) mg/m ³	Отпадни газове
24.	SIST EN 13284-1:2002	Неподвижни източници на емисии - Определяне на малък обхват масова концентрация на прах - Част 1: Ръчно гравиметричен метод	Съдържание на прах: (0,5 – 50) mg/m ³	Отпадни газове
25.	VDI 2066 Part 10:2004	Измерване на емисиите на ФПЧ10 и ФПЧ2,5 на източници	PM _{2,5} : (1 – 50) mg/m ³ PM ₁₀ : (2 – 50) mg/m ³	Отпадни газове
26.	SIST EN 12341:2014	Атмосферния въздух - стандартен метод за гравиметрично измерване за определяне на PM10 или ПЧ2,5 маса концентрация на суспендирани частици	$\tau > 2 \text{ } \mu\text{g}/\text{m}^3$	въздух
27.	SIST EN ISO 1911:2011	Неподвижни източници на емисии - Определяне на масова концентрация на газообразни хлориди, изразени като HCl - стандартен референтен метод - анализ на проба съгласно Метод В	HCl: (1,5 – 5000) mg/m ³	Отпадни газове
28.	SIST EN 14791:2005	Неподвижни източници на емисии - Определяне на масова концентрация на серен диоксид - Референтен метод	SO ₂ : (20 – 500) mg/m ³	Отпадни газове
29.	SIST ISO 15713:2009	Стационарни източници на емисии - вземане на проби и определяне на газообразни съдържание на флуор,	HF: (0,5-200) mg/m ³	Отпадни газове
30.	SIST EN 14790:2005	Емисии от неподвижни източници - Определяне на водната пара в каналите	влага: (58-250) g/m ³	Отпадни газове

Преводът на български език е извършен от Стефан Минчев

(

(

3.2.3. Лаборатория за високи напрежения (ЛВН), ул. Ямова 20, 1000 Любляна, Словения
Таблица 6

Тип на обхвата: фиксиран Място: в лаборатория Изпитване по отношение на типа на изпитване: физически тестове Тестване във връзка с вида на изпитвания обект: електрически продукти и оборудване (електромеханични устройства)				
Номер	Референция към стандарт или не-стандартен метод за изпитване	Заглавие на стандарт или нестандартен метод за изпитване и евентуални препратки към други стандарти или методи	Обхват на изпитването; Несигурност на резултата от изпитването (където е приложимо)	Материали; продукти
31.	IEC 60060-1:2010 Без точка 4.5	Изпитания с високо напрежение.	Синусоидално напрежение до 500 kV Постоянно напрежение до 600 kV Ударно напрежение: LI до 1800 kV SI до 1100 kV	Оборудване за високо напрежение
32.	IEC 61284:1997 точка 14	Изпитания за Корона и радиочестотно смущение (RIV)	до 500 kV	Оборудване за високо напрежение


Бележки:

- Във всички колони от обхвата на акредитацията, където клетките под "Обхват на тестване: неопределеност на резултат от изследване" са празни, следва да се прилагат разпоредбите на съответните стандарти или нестандартни методи за изпитване.
- В колоните на обхвата на акредитацията където клетките под "Референтен" определят два или повече кодове на стандарти, позоваването се отнася до напълно идентични стандарти.

Това е копие от приложението към сертификата за акредитация, предназначено за публикуване на сайта. Подписаният документ – оригинали са на разположение за проверка в централата на СА.

Директор
Д-р. Бостиан Годец

Преводът на български език е извършен от Стефан Минчев



Na podlagi poročila Št. P – 1338/11-520-1 izdaja

IZKAZ O ZRAKOTESNOSTI OBJEKTA

Objekt: **Kolektor ETRA – Zrakotesna hala**

Naslov: Šlandrova 10, 1231 Ljubljana

Neto prostornina: $V_e = 47138 \text{ m}^3$

Rezultati: Na podlagi meritev zrakotesnosti objekta znaša vrednost urne izmenjave zraka po standardu SIST EN 13829 – Metoda A (objekt v obratovalnem stanju)

$$n_{15} = 0,03 \text{ h}^{-1}$$


pri tlačni razliki $\Delta p = 15 \text{ Pa}$ glede na okolico in pri
standardnih pogojih zraka $T_0 = 20 \text{ }^\circ\text{C}$ in $p_0 = 1,01325 \text{ bar}$.

Datum preizkusa: 29.11.2011

V Ljubljani, dne 22.12.2011

Vodja Laboratorija za toplotno zaščito


Friderik Knez, univ. dipl. fiz.



Direktor Zavoda za gradbeništvo Slovenije

izr. prof. dr. Andraž Legat, univ. dipl. fiz.



ZAG Ljubljana

Slovenian National Building and Civil Engineering Institute

Dimičeva ulica 12, 1000 Ljubljana

<http://www.zag.si>, e-mail: info@zag.si

Based on the Report No. P-1338/11-520-1, we hereby grant

CERTIFICATE ON AIRTIGHTNESS OF BUILDING

Building: Kolektor ETRA – Airtight Hall
Location: Šlandrova 10, 12311 Ljubljana
Net volume: $V_e = 47138 \text{ m}^3$
Results: Based on the measurement of airtightness of the Building the value of hourly exchange of air according to the SIST EN 13829 Standard – A Method (Building in the state of operation) is

$$n_{15} = 0.013 \text{ h}^{-1}$$

at pressure difference $\Delta p = 15 \text{ Pa}$ in respect to the environment at standard condition of the air $T_0 = 20^\circ\text{C}$ and $p_0 = 1.01325 \text{ bars}$.

Date of test: 29 November 2011

In Ljubljana on 22 December 2011

Head of Laboratory for Thermal Protection

Friderik Knez, B.Sc. in Physics

(signed)

Director of Slovenian National Building and Civil Engineering Institute

Assoc. Prof. dr. Andraž Legat, B.Sc. in Physics

(signed)

Official round seal:

Slovenian National Building and Civil Engineering Institute

Ljubljana



Podpisana Marjeta Sekirnik, prof. z odločbo Ministrstva za pravosodje Republike Slovenije šte. 756-93/93, z dne 13. junija 1994 imenovana za stalnega sodnega tolmača za angleški jezik izjavljam, da se ta prevod povsem ujema z izvirnikom v slovenskem jeziku.

I, the undersigned Marjeta Sekirnik, BA, certified permanent court interpreter for English language, appointed under the Decree No.756-93/93, issued on 13 June 1994 by the Minister of Justice of the Republic of Slovenia, hereby declare and certify that this is a true translation of the original document written in Slovene attached hereinbefore.

Ljubljana, April 14, 2017

M. Sekirnik

C

C

[Handwritten mark]




[Handwritten mark]

[Handwritten signature]

(

(



ЗАГ Любляна

Словенски Национален Сграден и
Строително инженерингов Институт

Димичева Улица 12, 1000 Любляна

<http://www.zag.si>, e-mail: info@zag.si

Въз основа на Доклад № P-1338/11-520-1, с настоящото ние гарантираме

СЕРТИФИКАТ ЗА ХЕРМЕТИЧНОСТ НА СГРАДАТА

Сграда: Колектор ЕТРА – Херметична сграда

Локация: Сландрова 10, 12311 Любляна

Общ обем: $V_e = 47138 \text{ m}^3$

Резултат: на основание на измерване на херметичността на сградата
стойността на часовата подмяна на въздуха съгласно стандарт SIST
EN 13829 – А Метод (сграда в състояние на експлоатация) е

$n_{15} = 0.013 \text{ h}^{-1}$

при разлика в налягането $\Delta p = 15 \text{ Pa}$ по отношение на околната среда, при
стандартни условия на въздуха $T_0=20^\circ\text{C}$ и $p_0=1.01325 \text{ бара}$.

Дата на теста: 29 Ноември 2011

В Любляна на 22 Декември 2011

Ръководител на Лабораторията по
термична защита

Фредерик Кнез
(Подписано)

Директор Словенски Национален
Сграден и Строително инженерингов
Институт

Проф. Др. Андраз Легат
(Подписано)

Официален кръгъл печат:

Словенски Национален Сграден и Строително инженерингов Институт

Любляна

Превод на български език: Деян Маринов




(

(

**POROČILO O OPRAVLJENIH MERITVAH TEMPERATURE IN
RELATIVNE VLAŽNOSTI NOTRANJEGA ZRAKA ZA PROSTOR
»KONČNA MONTAŽA«**

Objekt: Proizvodni obrat Kolektor Etra d.o.o., Šlandrova ulica 10, Ljubljana

Delovni nalog: DN 2005457

Čas izvajanja meritev: Začetek 10.2.2015 ob 8:00, zaključek 11.2.2015 ob 8:00

Merilna oprema: Registratorji temperature in relativne vlažnosti zraka, tip Tinytag Ultra 2, TGU-4500 (oznake registratorjev: 609969, TT1*, 609964, TT2**)

Kalibracija opreme: Preizkušeno pri Laboratoriju za metrologijo in kakovost, Fakulteta za elektrotehniko, Univerza v Ljubljani
* oznaka certifikata LMK01151090, z dne 27.1.2015, in LMK0115H094, z dne 30.1.2015
** oznaka certifikata LMK01151091, z dne 27.1.2015, in LMK0115H095, z dne 30.1.2015

Protokol meritev: Meritve so potekale skladno s postopki opisanimi v standardu SIST EN ISO 7726:2002

Izmerjene vrednosti:

Merilno mesto	Temperatura	Relativna vlažnost
Končna montaža h=1,8m	25,0°C	9,8%
Končna montaža h=5,2m	25,0°C	8,7%

VODJA CENTRA ZA BIVALNO OKOLJE,
GRADBENO FIZIKO IN ENERGIJO

dr. Marjana ŠIJANEC-ZAVRL, univ.dipl.inž.grad.

TEHNIČNI DIREKTOR

dr. Blaž DOLINŠEK, univ.dipl.inž.grad.

GRADBENI INŠTITUT¹
ZRMK d.o.o.
Ljubljana, Dlmčeva 12

VARNO S ORIGINALI



C

C

ZRMK INSTITUTE

Building and Civil Engineering Institute

REPORT ON COMPLETED MEASUREMENTS OF TEMPERATURE AND RELATIVE HUMIDITY OF INDOOR AIR IN THE »FINAL ASSEMBLY« HALL

Building: Kolektor Etra d.o.o. Production Plant
Šlandrova ulica 10, Ljubljana
DN 2005457

Order: Beginning on 10 February 2015 at 8:00; conclusion on 11 February 2015 at 8:00

Time of performed measurement: Temperature registrars and relative humidity of air, Type Tinytag Ultra 2, TGU-5400 (registrars designation: 609969, TT1*, 609964, TT2**

Measuring equipment: Tested in the Laboratory for Metrology and Quality, Faculty of Electrical Engineering
*- Certificate LMK0115I090 dated 27 January 2015 and LMK0115H094 dated 30 January 2015
**- Certificate LMK0115I091 dated 27 January 2015 and LMK0115H095 dated 30 January 2015

Calibration equipment: Measurements were performed according to the procedures in compliance with the described standard SIST EN ISO 7726:2002

Measurement protocol:

Measured values:

Location	Temperature	Relative humidity
Final Assembly h= 1.8 m	25.0 °C	9.8%
Final Assembly h= 5.2 m	25.0 °C	8.7%

Manager of Living Environment Centre,
Civil Engineering Physics and Energy

(signed)

Dr. Marjan SIJANEC ZAVRL, B.Sc. in Civil Eng.


Manager of Technical Department

(signed)

Dr. Blaž DOLINŠEK, B.Sc. in Civil Eng.

Rectangular seal:

Building and Civil Engineering Institute



C

C

Podpisana Marjeta Sekirnik, prof. z odločbo Ministrstva za pravosodje Republike Slovenije števil. 756-93/93, z dne 13. junija 1994 imenovana za stalnega sodnega tolmača za angleški jezik izjavljam, da se ta prevod povsem ujema z izvirnikom v slovenskem jeziku.

I, the undersigned Marjeta Sekirnik, BA, certified permanent court interpreter for English language, appointed under the Decree No.756-93/93, issued on 13 June 1994 by the Minister of Justice of the Republic of Slovenia, hereby declare and certify that this is a true translation of the original document written in Slovene attached hereinbefore.

Ljubljana, April 14, 2017



Marjeta Sekirnik

(

(

[Handwritten flourish]



[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

C

C

ЗРМК Институт

Сграден и Строително инженерингов Институт

ПРОТОКОЛ ЗА ЗАВЪРШЕНИ ИЗМЕРВАНИЯ НА ТЕМПЕРАТУРАТА И ОТНОСИТЕЛНАТА
ВЛАЖНОСТ НА ВЪЗДУХА В ЗАЛА „ФИНАЛНО СГЛОБЯВАНЕ“

Сграда: Колектор ЕТРА д.о.о. Фабрика
Сландрова улица 10, Любляна
Поръчка: DN2005457
Време за изпълнение на измерванията: Започване на 10 Февруари 2015 в 8:00;
Завършване на 11 Февруари 2015 в 8:00
Измервателно оборудване: Регистратори на температура и
относителна влажност на въздуха, Тип
Tinytag Ultra 2, TGU-5400 (обозначение на
регистраторите: 609969 TT1*, 609964 TT2**)
Калибрационно оборудване: Тествано в Лабораторията за метрология и
качество, Факултет по Електроинженеринг
*- сертификат LMK01151090 от 27 Януари
2015 и LMK0115H094 от 30 Януари 2015
**- сертификат LMK01151091 от 27 Януари
2015 и LMK0115H095 от 30 Януари 2015
Протокол от измервания Измерванията бяха изпълнени в
съответствие с процедурите по описания
стандарт SIST EN ISO 7726: 2002

Измерени величини

Локация	Температура	Относителна влажност
Финално сглобяване h = 1.8m	25°C	9.8%
Финално сглобяване h = 5.2m	25°C	8.7%


Мениджър Център за жилищна околна среда Мениджър Техническа Дирекция
Строителен инженеринг Физика и
Енергия


Др. Мариян Суанец Заврл
(Подписано)

Др. Блаз Долинсек
(Подписано)

Официален кръгъл печат:

Словенски Национален Сграден и Строително инженерингов Институт

Превод на български език: Деян Маринов






institut za varstvo okolja
in varstvo okolja Maribor pu

IVD Maribor p.o.
Valvasorjeva ulica 73
SI 2000 Maribor
T: +386 (0)2 421 66 10
F: +386 (0)2 421 60 60
E: info@ivd.si
ivd@ivd.si

Contractor:
IVD MARIBOR p.o.
Valvasorjeva 73
2000 MARIBOR

Requested by
KOLEKTOR ETRA d.o.o.
Šlandrova 10
1231 Ljubljana-Črnuče

REPORT ON AIR DUST PARTICLES TEST RESULTS

Building: Production Plant of Kolektor Etra d.o.o., Šlandrova 10, Ljubljana

Order No.: CEVO-409/2015

Date of test measurement: 20 October 2015

Measuring equipment: Laser measuring equipment for counting of particles - GRIMM 1.108 product

Method of measurement: In compliance with the EN ISO 14644-1 Standard

Purpose: The purpose of this measurement test is to establish the quantity of present particles in the working area and the purity class in the working area - Assembly HALL 1 and Assembly Hall 2 and compliance with the EN ISO 14644-1 Standard.

Measuring Station	Measured number of particles		
	(0.5 $\mu\text{m}/\text{m}^3$)	(0.1 $\mu\text{m}/\text{m}^3$)	(0.5 $\mu\text{m}/\text{m}^3$)
HALL 1 - normal conditions of operation	16,124	3,325	30
HALL 2 - normal conditions of operation	19,065	2,050	17
HALL 2 - dry conditions of operation	20,050	5,568	31
Marginal value as per ISO 14644-1 for Class 8	3,520,000	832,000	29,300
Marginal value as per ISO 14644-1 for Class 7	352,000	83,200	2,930

Conclusion: Based on the performed measurements, we estimate, that production halls used for the assembly of magnetic circle, production of coiling, assembly of coiling, active part and final assembly, do comply with the purity criteria CLASS 8 and CLASS 7 in line with the SIST EN ISO 14664-1:2000 Standard, which applies to the operation phase.

Maribor, 23 October 2015



Zoran Belić, B.Sc. in Mech.
Head of Technical Department



(

(

ЛОГО ИВД Марибор

Изпълнител:

ИВД Марибор п. о.
Валвасориева 73
2000 МариборЗаявител
Колектор ЕТРА д.о.о.
Сландрова 10
1231 Любляна**ДОКЛАД ЗА ТЕСТВАНЕ ЗА НАЛИЧИЕ НА ПРАХОВИ ЧАСТИЦИ ВЪВ ВЪЗДУХА**

Сграда: Производствен завод Колектор ЕТРА д.о.о., Сландрова 10, Любляна
Поръчка №: CEVO-409/2015
Дата на измерване: 20 Октомври 2015
Измервателно оборудване: Лазерно измервателно оборудване за преброяване на частици GRIMM 1.108 продукт съгласно Стандарт EN ISO 14644-1
Метод на измерване: съгласно Стандарт EN ISO 14644-1
Цел: Целта на измерването е да бъде определено наличното количество частици в работната площ и класа на чистота на работната площ – Зала за сглобяване 1 и Зала за сглобяване 2 и съответствието със Стандарт EN ISO 14644-1

Измервателна станция	Измерено количество частици		
	(0.5 µm/m ³)	(0.1 µm/m ³)	(0.5 µm/m ³)
Зала 1 – нормални условия на работа	16,124	3,325	30
Зала 2 – нормални условия на работа	19,065	2,050	17
Зала 2 – сухи условия на работа	20,050	5,568	31
Гранични стойности съгласно ISO 14644-1 за Клас 8	3,520,000	832,000	29,300
Гранични стойности съгласно ISO 14644-1 за Клас 7	352,000	83,200	2,930


Заключение На база извършените изревания ние преценяваме, че производствените зали използвани за сглобяване на магнитните кръгове, производство на намотки, сглобяване на намотки и активна част и финално сглобяване отговарят на критериите за чистота КЛАС 8 и КЛАС 7 във връзка със Стандарт SIST ISO 14664-1:2000, които отговаря за работни фази.

Марибор, 23 октомври 2015

Зоран Белич

Ръководител Техническа дирекция

(Подписано)

Превод на български език: Деян Маринов

(

(



ДЕКЛАРАЦИЯ
за отсъствие на полихлорирани бифинили (PCB) в изоляционното масло

Долуподписаните

Екехарт Бернхард Нойрайтер, притежаващ лична карта (удостоверение за продължително пребиваване) №1801, издадена от МВР – гр. София, валидно до 18.07.2017г. адрес гр. София, бул. Христофор Колумб № 9, ет.3,

в качеството ми на Управител на АББ България ЕООД

и

Стефан Василев Минчев, притежаващ лична карта №641790843, издадена на 11.01.2011 от МВР – гр. София, адрес: гр. София, бул. Христофор Колумб № 9, ет.3,

в качеството ми на Управител на АББ България ЕООД,

участник в процедура за възлагане на обществена поръчка с предмет: „Доставка, демонтаж и монтаж на трифазни маслонапълнени понижавачи силови трансформатори 110kV/Средно напрежение (СрН) и цялото необходимо помощно оборудване“, реф. № PPD 17-001”,

ДЕКЛАРИРАМЕ, ЧЕ:


В предложените от нас трифазни маслонапълнени понижавачи силови трансформатори 110kV/Средно напрежение (СрН) се използва изоляционно масло, което не съдържа полихлорирани бифинили (PCB).

Приложение:

Заверено становище от производителя Ергон Рефайнинг Инк.

Дата: 19.04.2017

Декларатор:


Екехарт Нойрайтер
Управител
АББ България ЕООД



Стефан Минчев
Управител
АББ България ЕООД

ABB Bulgaria EOOD
Main Office
9, Hristofor Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com

UIC: 831133152
VAT Nr.: BG 831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13INGB91451000027317 (BGN)
IBAN: BG60INGB91451400027311 (EUR)
BIC: INGBBGSF



03.2017

(

(


Ergon Refining, Inc.

An ISO 9001 and 14001 Certified Company

July 23, 2014

Dear Valued Customer:

Reference: PCBs, chlorinated and halogenated compounds

This letter is generated in response to your recent inquiry concerning the polychlorinated biphenyl (PCB); polychlorinated terphenyl (PCT) and monomethyl-tetrachloro-diphenyl methane (PCBT) contents as well as the chlorinated and halogenated compounds contents of the Ergon naphthenic base, process and insulating oils.

PCBs are synthetically produced compounds added to oils to improve stability and/or flame retardation. Polychlorinated terphenyls (PCTs) and monomethyl-tetrachloro-diphenyl methanes (PCBTs) are addressed in EU Directive n. 96/59/EC of 16 September 1996 and included in the definition of PCBs. Ergon Refining oils are processed from naturally occurring raw materials with no additives or recycled oils that might introduce PCB contamination. Products are routinely tested to verify they are PCB-free.


In addition to being PCB-free, Ergon naphthenic base, process and insulating oils do not contain other chlorine or chlorinated compounds. They contain no halogen or organohalogen derivative products. These chemicals are not utilized in the manufacturing process, nor are they naturally occurring in the products produced.

Please give me a call if you have additional questions. I can be reached at 601-630-8314.

Best Regards,



Jennifer D. Hall
Manager, Product Services and Development



C

C

Лого ЕРГОН Рафиниране

23 Юли 2014

Уважаеми Клиенти:

Референция: РСВ, хлорирани и халогенирани съединения

Това писмо се е в отговор на Ваше запитване във връзка с полихлориден бифенол (РСВ); полихлорирани терфенили (РСТ) и монометил-тетрахлор-дифенил метан (РСВТ) съдържание както и за съдържание на хлорирани и халогенирани съединения в Ергон нафтеноса основа, процес и изолиране на масла.

РСВ са синтетично произведени съединения добавяни към маслото за подобряване стабилността и/или забавянето при изгаряне. Полихлорирани терфенили (РСТ) и монометил-тетрахлор-дифенил метан (РСВТ) са посочени в Евро Директива п. 96/59/ЕС от 16 Септември 1996 и включени в дефиницията за РСВ. Маслата на Ергон Рафиниране са от преработката на природни суровинни материали без добавки или рециклиране на масла което може да доведе до замърсяване с РСВ. Продуктите са рутинно тествани за да се потвърди тяхната РСВ – чистота.

В допълнение за РСВ-чистота, Ергон нафтеноса основа, процес и изолиране на масла не съдържат хлорин или други хлоринови съединения. Те съдържат нехалогенни или производни на органохалогенни продукти. Тези химикали не се използват в производствения процес, нито се срещат естествено в произвежданите продукти.

Моля обадете се ако имате други въпроси. Може да ме намерите на 601-630-8314.

С най-добри пожелания,


Дженифър Д. Халл

Маниджър, Продукти услуги и Развитие

Превод на български език: Деян Маринов

C

C



Приложение 3 - Декларация за конфиденциалност и
извършен оглед на обекта




ABB Bulgaria EOOD
Main Office
9, Hristofor Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com


UIC: 831133152
VAT Nr.: BG831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13INGB91451000027317 (BGN)
IBAN: BG60INGB91451400027311 (EUR)
BIC: INGBBGSF



03.2017





**ABB**

ДЕКЛАРАЦИЯ

за конфиденциалност и извършен оглед на обект по предмета на поръчката

Долуподписаните Екехарт Нойрайтер и Стефан Минчев в качеството ни на представляващи АББ България ЕООД, участник в процедура за възлагане на обществена поръчка с реф. № PPD 17-001 и предмет:

Доставка, демонтаж и монтаж на трифазни маслонапълнени понижавачи силови трансформатори 110kV/Средно напрежение (СрН) и цялото необходимо помощно оборудване,

ДЕКЛАРИРАМЕ, ЧЕ:

1/ Представител на участника, когото представлявам е извършил оглед на обект: п/ст Студентски град и съм запознат със съществуващото положение.


2/ Няма да разпространявам поверителна информация, във връзка с извършения оглед на обекта на Възложителя, като ми е известно, че за поверителна се счита всяка информация, относно пропускателния режим в обекта, организацията на работната сила и работния процес, наличното оборудване и техническите схеми на функционирането му, системите за защита и сигурност в обекта и всичко, което е свързано с наличното оборудване, съоръжения и тяхното функциониране в съответния обект.

3/ Прилагам документ за извършен оглед, съставен на място в подстанцията.

Приложение: Документ за извършен оглед, съставен на място в подстанцията

Дата: 19.04.2017

Участник:


Екехарт Нойрайтер
Управител
АББ България ЕООД



Стефан Минчев
Управител
АББ България ЕООД

ABB Bulgaria EOOD
Main Office
9, Hristofor Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com

UIC: 831133152
VAT Nr.: BG 831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13INGB91451000027317 (BGN)
IBAN: BG60INGB91451400027311 (EUR)
BIC: INGBBGSF



03.2017

(

(



ДЕКЛАРАЦИЯ

за извършен оглед на ПС „Буденски пръд“ 110/Ср.Н

Долуподписаният/ната/

Свещан Василев Митчел

.....
в качеството ми на представляващ АБВ България ЕООД
.....
кандидат за участие в процедура за възлагане на обществена поръчка с предмет: „Доставка, демонтаж и монтаж на трифазни маслонапълнени понижавачи силови трансформатори 110kV/Средно напрежение (СрН) и цялото необходимо помощно оборудване“ и реф. № PPD 17-001

ДЕКЛАРИРАМ:

Извърших оглед на обекта, предмет на обществената поръчка и се запознах със съществуващото положение, включително с действащите електрически съоръжения и спецификата на ПС „Буденски пръд“ 110/Ср.Н.

Дата 11.04.2018 г.

Декларатор:

/име, подпис и печат/

Свещан Василев Митчел

Служител на Възложителя допуснал до оглед кандидата:

Никола Янев - р-л ЕО Н.Я.
име и фамилия длъжност подпис

(

(




Приложение 4 - Копие на сертификат по стандарт БДС
EN ISO 9001 на производителя на предлагания
трансформатор

ABB Bulgaria EOOD
Main Office
9, Hristofor Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com


UIC: 831133152
VAT Nr.: BG 831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13ING891451000027317 (BGN)
IBAN: BG60ING891451400027311 (EUR)
BIC: INGBBG5F



03.2017



BUREAU VERITAS
Certification



Certificate

Awarded to

KOLEKTOR ETRA d.o.o.

ŠLANDROVA ULICA 10, 1231 LJUBLJANA – ČRNUČE, SLOVENIA

Bureau Veritas Certification Holding SAS – UK Branch certify that the Management System of the above organization has been audited and found to be in accordance with the requirements of the management system standard detailed below

STANDARD

ISO 9001:2008

SCOPE OF CERTIFICATION

DESIGN, PRODUCTION, INSTALLATION AND DECOMMISSION OF POWER AND SPECIAL TRANSFORMERS AND REACTORS

Certification cycle start date: **31/10/2014**

Subject to the continued satisfactory operation of the organisation's Management System, this certificate expires on: **31/10/2017**

Original certification date: **30/06/1997**

Certificate number: **SL21076Q**

Version number: **01** Revision date: **06/10/2015**

B. Mahan

Signed on behalf of BV/CH SAS UK Branch

Certification body address: 66 Prevet Street, London, E1 8JG, United Kingdom
Local office: Lindartova cesta 49a, 1000 Ljubljana, Slovenia


Further clarifications regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organization.

To check this certificate validity please call + 386 1 47 57 670.

Page 1 of 1




008



C

C

На бланка на Бюро Веритас Сертифициране



СЕРТИФИКАТ

Присъден на

КОЛЕКСТОР ЕТРА д.о.о.
улица „Сландрова“ № 10, 1231 Любляна – Чрунче, Словения

БЮРО ВЕРИТАС СЕРТИФИКАЦИОНЕН ХОЛДИНГ САС – клон Великобритания удостоверява, че СИСТЕМА ЗА УПРАВЛЕНИЕ на горната организация е одитирана и е установено, че тя е в съответствие с изискванията на стандартите на системата, описани подробно в:

Стандарт
ISO 9001:2008
обхват

Проектиране, производство, монтаж и демонтаж на силови и специални трансформатори и реактори.

Сертификационен цикъл с начална дата: **31.10.2014**

Подложен на непрекъсната задоволителна експлоатация на Системата за управление, този сертификат е валиден до: **31.10.2017.**

Дата на първоначално одобрение: **30.06.1997.**

Сертификат номер: **SL21076Q**

Версия **01**, Дата на ревизия: **06.10.2015**

Подписано от името на Бюро Веритас Сертификационен Холдинг САС клон Великобритания
/подписът не се чете/



Адрес на сертификационното тяло: ул. Прескот №66, гр. Лондон, Е1 8ХГ, Великобритания
Адрес на местен офис: Любартова цеста 49а, 1000 Любляна, Словения

Други подробности относно обхвата на този сертификат и приложимостта на изискванията на системата за управление могат да бъдат получени при връзка с организацията.


За проверка на този сертификат моля, обадете се на телефон: **+38614757670**

Страница 1 от 1.

Преводът на български език е извършен от Стефан Минчев





**ABB**

Приложение 5 - Декларация за срока на валидност на
офертата

ABB Bulgaria EOOD
Main Office
9, Hristofor Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com

UIC: 831133152
VAT Nr.: BG 831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13INGB91451000027317 (BGN)
IBAN: BG60INGB91451400027311 (EUR)
BIC: INGBBGSF




03.2017



(

(



ДЕКЛАРАЦИЯ
за срока на валидност на офертата

Долуподписаните

Екехарт Бернхард Нойрайтер, притежаващ лична карта (удостоверение за продължително пребиваване) №1801, издадена от МВР – гр. София, валидно до 18.07.2017г. адрес гр. София, бул. Христофор Колумб № 9, ет.3,

в качеството ми на Управител на АББ България ЕООД

и

Стефан Василев Минчев, притежаващ лична карта №641790843, издадена на 11.01.2011 от МВР – гр. София, адрес: гр. София, бул. Христофор Колумб № 9, ет.3,

в качеството ми на Управител на АББ България ЕООД,

участник в процедура за възлагане на обществена поръчка с предмет: „Доставка, демонтаж и монтаж на трифазни маслонапълнени понижавачи силови трансформатори 110kV/СрН и цялото необходимо помощно оборудване“, реф. № PPD 17-001”,


Обособена позиция 5 /ОП 5/ - Доставка, демонтаж и монтаж на трифазен маслонапълнен понижавач силов трансформатор 110kV/СрН за подстанция /ПС/ „Студентски град“, както и доставка на цялото необходимо помощно оборудване

ДЕКЛАРИРАМЕ, ЧЕ:

С подаване на настоящата оферта, направените от нас предложения и поети ангажменти са валидни за срока, посочен в обявлението, считано от крайния срок за подаване на офертите.

Дата: 19.04.2017

Декларатор:


Екехарт Нойрайтер
Управител
АББ България ЕООД



Стефан Минчев
Управител
АББ България ЕООД

ABB Bulgaria EOOD
Main Office
9, Hristofor Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com


UIC: 831133152
VAT Nr.: BG 831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13INGB91451000027317 (BGN)
IBAN: BG60INGB91451400027311 (EUR)
BIC: INGBBGSF



03.2017

C

C

**ABB**

Приложение 6 - Декларация за приемане на условията в
проекта на договор

ABB Bulgaria EOOD
Main Office
9, Hristofof Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com


UIC: 831133152
VAT Nr.: BG 831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13INGB91451000027317 (BGN)
IBAN: BG60INGB91451400027311 (EUR)
BIC: INGBBGSF



03.2017

C.

C.



ДЕКЛАРАЦИЯ

за приемане на условията в проекта на договор


Долуподписаните Екехарт Нойрайтер и Стефан Минчев в качеството ни на представляващи АББ България ЕООД участник в обществена поръчка с предмет: „Доставка, демонтаж и монтаж на трифазни маслонапълнени понижавачи силови трансформатори 110kV/Средно напрежение (СрН) и цялото необходимо помощно оборудване“, реф.№ PPD 17-001, обособена позиция № Обособена позиция 5 /ОП 5/ - Доставка, демонтаж и монтаж на трифазен маслонапълнен понижавач силов трансформатор 110kV/СрН за подстанция /ПС/ „Студентски град“, както и доставка на цялото необходимо помощно оборудване

ДЕКЛАРИРАМЕ, ЧЕ:


Приемаме условията в проекта на договор, приложен в документацията за участие.

Дата: 19.04.2017

Декларатор:



Екехарт Нойрайтер
Управител
АББ България ЕООД



Стефан Минчев
Управител
АББ България ЕООД

ABB Bulgaria EOOD
Main Office
9, Hristofor Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com

UIC: 831133152
VAT Nr.: BG 831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13INGB91451000027317 (BGN)
IBAN: BG60INGB91451400027311 (EUR)
BIC: INGBBGSF



03.2017

C.

(3)