

TEST REPORT

NO. 1213.1607.6.950

Tyco Electronics Raychem GmbH Flinsinger Feld 1 85521 Ottobrunn GERMANY		CLIENT
Tyco Electronics Raychem GmbH		MANUFACTURER
Screened separable cable connector for single-core cables with extruded plastic insulation		TEST OBJECT
RSES-52xx-R		TYPE:
12 test samples		SERIAL NO.
Rated voltage	U_p/U 12.7/22 kV	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Maximum value between two phase conductors	U_m 24 kV	
Rated current	250 A	
Rated cross-section range	50 mm ²	
CENELEC Harmonization Document HD 629.1 S2: 2006-02 DIN VDE 0278-629.1 (VDE 0278 Teil 629-1): 2002-06 IEC 61442: 2005-04 DIN VDE 0278-442 (VDE 0278 Teil 442): 2006-01		NORMATIVE DOCUMENT
Test sequences D1, D2 and D3 as well as Special tests Nos. 17 to 21		RANGE OF TESTS PERFORMED
22 May 2007 to 20 December 2007		DATE OF TEST
See Sub-clauses 4.7, 5.7, 6.7 and 7.7		TEST RESULT

Pannicke

PROF. DR. J. PANNICKE
Managing director
Berlin, 1 April 2008


D. Jegust

D. JEGUST
Test engineer in charge




Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DAkT) e.V. in the fields of hv. apparatus and switchgear, power cables and power cable accessories, hv. apparatus and switchgear, installation equipment and switching and control equipment

BMPTD G
OPMTHALIA



Contents	Sheet
1. Participants in the test.....	4
2. Test performed.....	4
3. Identity of the test object.....	6
3.1 Technical data and characteristics.....	6
3.2 Identity documents.....	6
4. Tests of test sequence D1.....	7
4.1 Test laboratory.....	7
4.2 Normative document.....	7
4.3 Required test parameters.....	8
4.4 Test arrangement.....	10
4.5 Test and measuring circuits.....	12
4.6 Test results.....	17
4.7 Assessment of the results of test sequence D1.....	26
5. Tests of test sequence D2.....	28
5.1 Test laboratory.....	28
5.2 Normative document.....	28
5.3 Required test parameters.....	28
5.4 Test arrangement.....	29
5.5 Test and measuring circuits.....	30
5.6 Test results.....	32
5.7 Assessment of the tests of test sequence D2.....	37
6. Tests of test sequence D3.....	38
6.1 Test laboratory.....	38
6.2 Normative document.....	38
6.3 Required test parameters.....	38
6.4 Test arrangement.....	39
6.5 Test and measuring circuits.....	40
6.6 Test results.....	41
6.7 Assessment of the results of test sequence D3.....	42

БҮРҮНД
ОПШИМАЛА



TEST REPORT NO. 1213.1607.6.950

SHEET 3

7.	Special tests (tests Nos. 17 to 21)	43
7.1	Test laboratory	43
7.2	Normative documents	43
7.3	Required test parameters	43
7.4	Test arrangement	44
7.5	Test and measuring circuits	45
7.6	Test results	49
7.7	Assessment of special tests	52
8.	Photos	53
9.	Oscillograms	56
10.	Drawings	60
11.	Identification of test cable	66

This test document consists of 66 sheets.

Distribution

Copy No. 1 In English:

Copy No. 1
Tyco Electronics Raychem GmbH

The test results relate only to the object tested
This document is confidential its transfer to third parties as well as its reproduction in extracts require the consent of the client

ВЫПУСК
ОРИГИНАЛ



1. Participants in the test

Mr. Jegust IPH test engineer in charge
 Mr. Moritz IPH test engineer (short-circuit tests and screen fault current initiation test)
 Mr. Schad Tyco Electronics Raychem GmbH (partially present)

2. Test performed

All tests of the test sequences D1, D2 as well as special tests Nos. 17 to 21 in the following order:

Test sequence	Test	Type of test
D1	1	DC voltage dry withstand test
	2	AC voltage dry withstand test
	3	Partial discharge test at ambient temperature
	4	Impulse voltage test at elevated temperature
	5	Electrical heat cycling test ¹⁾ in air
	6	Electrical heat cycling test ¹⁾ in water
	7	Disconnection/connection
	8	Partial discharge test at elevated and ambient temperatures
	9	Impulse voltage test at ambient temperature
	10	AC voltage dry withstand test

Test sequence	Test	Type of test
D2	1	DC voltage dry withstand test
	2	AC voltage dry withstand test
	3	Thermal short-circuit test of the conductor
	4	Dynamic short-circuit test of the conductor
	5	Disconnection/connection
	6	Impulse voltage test at ambient temperature
	7	AC voltage test



ВАРНО С
 ОРНИНА

Test performed (continued)

Test sequence	Test	Type of test
D3	14	Operating eye test
	15	Partial discharge test at ambient temperature

Special tests	17	Screen resistance measurement
	18	Leakage current measurement ²⁾
	19	Screen fault current initiation test ³⁾
	20	Operating force test
	21	Test of capacitive test point performance ⁴⁾

The thermal short-circuit test of the screen does not apply because the test object is equipped neither with a connection to the metal screen nor with an adapter for the metal screen of the cable.

Special tests Nos. 17 to 19 and 21 have been carried out on separate test objects.

Note to the tests:

CENELEC Harmonization Document HD 629.1 S2: 2006-02 and IEC 61442: 2005-04 use different terms with regard to the types of test. Below you find the terms of the normative document of the test procedure:

- 1) Heating cycles voltage test
- 2) Screen leakage current measurement
- 3) Screen fault current initiation test
- 4) Test of capacitive test point performance

ВАРНА С
ОРГАНИЗАЦИЯ



3. Identity of the test object

3.1 Technical data and characteristics

The technical data and characteristics of the test object are defined by the following parameters and specified by the client

Test object: Screened separable cable connector for single-core cables with extruded plastic insulation
 Type: RSES-52xx-R
 Manufacturer: Tyco Electronics Raychem GmbH
 Serial No.: 12 test samples
 Year of manufacture: 2006

Rated characteristics: Rated voltage U_0/U 12.7/22 kV
 Maximum value between two phase conductors U_m 24 kV
 Rated current 250 A
 Rated cross-section range of the conductor 50 mm²

Design: Type of cable connection Screened separable elbow connector, with capacitive test point

Cable Screened single-core cable with extruded plastic insulation,


Cable marking N2XS(F)2Y 1x50 RM/16 mm² 12/20 kV
 Designation of manufacturer NEXANS
 Material of conductor Cu
 Material of screen Cu

3.2 Identity documents

The manufacturer confirms that the test object has been manufactured in compliance with the drawings given in this document. IPH did not verify this compliance in detail. The identity of the test object is fixed by the following drawings and data submitted by the client:

Name of drawing	Drawing No.	Date of drawing	Author	Notes
Installations Instruction Type RSES	EPP-0472	2/00	Tyco Electronics	Sheets 60 to 65

Entry of test objects at IPH: 28 March 2007



TEST REPORT NO. 1213.1607.6.950

SHEET 7

4. Tests of test sequence D1

4.1 Test laboratory

High-voltage test laboratory, high-voltage hall 2

4.2 Normative document

CENELEC Harmonization Document HD 629.1 S2; 2006-02
DIN VDE 0278-629.1 (VDE 0278 Teil 629-1); 2002-06
IEC 61442; 2005-04
DIN VDE 0278-442 (VDE 0278 Teil 442); 2006-01


ВАРНО С
ОРИГИНАЛА



4.3 Required test parameters

Test No.	Type of test	Required test parameters
1	DC voltage dry withstand test	Test voltage $6 \times U_0$: 76 kV Duration of test: 15 min Polarity: Negative
2	AC voltage dry withstand test	Test voltage $4.5 \times U_0$: 57 kV Test frequency: 50 Hz Duration of test: 5 min
3	Partial discharge test at ambient temperature	Prestress voltage $2.25 \times U_0$: 29 kV Measuring voltage $2.00^{(1)} \times U_0$: 25 kV Prestress duration: 1 min Measuring time: 1 min
4	Impulse voltage test at elevated temperature	Front time: 1.2 μ s Virtual time to half value: 50 μ s Test voltage: 125 kV Number of impulses: 10 impulses Polarity: pos./neg. Conductor temperature: 95 - 100 °C ²⁾
5	Electrical heat cycling test in air	<ul style="list-style-type: none"> • Continuous AC voltage Test voltage $2.5 \times U_0$: 32 kV Test frequency: 50 Hz Duration of test: 21 day • Thermal cycles Number of cycles: 63 Cycle (8 h): 5 hours of heating + 3 hours of cooling Conductor temperature during the last 2 hours of heating cycle: 95 - 100 °C ²⁾
6	Electrical heat cycling test in water	See test No. 5, additionally Height of water: 1 m
7	Disconnection/connection	Number of complete operations: 5
8	Partial discharge test at ambient temperature and elevated temperature	See test No. 3, except Conductor temperature: 9 _U resp. 95-100 °C ²⁾
9	Impulse voltage test at ambient temperature	See test No. 4, except Conductor temperature: 9 _U Duration of test: 15 min

ВЫПУСК
ОПТИМИЗАЦИЯ



Required test parameters (continued)

Test No.	Type of test	Required test parameters	
10	AC voltage dry withstand test	Test voltage $2.5 \times U_0$:	32 kV
		Test frequency:	50 Hz
		Duration of test:	15 min

Notes to the table of required test parameters:

- 1) CENELEC Harmonization Document HD 629.1 S2: 2006-2, Table 7, requires the partial discharge to be measured at a measuring voltage of $1.73 \times U_0$ or $2.00 \times U_0$ respectively. The measurement was done at $2 \times U_0$, because the standard of the cable used for the test requires a test voltage $> 1.73 \times U_0$.
- 2) Acc to EN 61442: 2005-04, Clause 9, the heating current to be applied in this test depends on the set conductor temperature. HD 620 specifies that this shall be 5 K to 10 K above the maximum permissible cable conductor temperature of 90 °C for XLPE-insulated cables. In the given case this requirement resulted in a heating current, which exceeded the current carrying capacity respectively the rated current of the bushing. The resulting higher thermal load of the bushing was accepted and was agreed with the client before the test was started.



**ВЪВЕДЕН
ОРИГИНАЛ**

4.4 Test arrangement

The client arranged each of the four cable connectors under test (test objects) on a test line. Every two of the test objects were connected by a coupling unit of DJ250-2 type (manufacturer: Cooper). The test objects were mounted on cable lines of approx. 3 m length and of N2XS(F)2Y-1x50 RM/16 mm²-12/20 kV type. To apply the test voltage, each of the test lines had additionally been equipped with one auxiliary sealing end of EPKT 24C1XI type (manufacturer Tyco Electronics Raychem). All test voltages were applied to the core against the cable screen, which was connected to the test earth.

The tests did not start earlier than 24 hours after the installation of the accessories on the cable lines.

4.4.1 DC voltage test (test 1)

Test arrangement to IEC 61442: 2005-04, Clause 5

4.4.2 AC voltage test (test 2)

Test arrangement to IEC 61442: 2005-04, Clause 4

4.4.3 Partial discharge test at ambient temperature (test 3)

Test arrangement to IEC 61442: 2005-4, Clause 7, with the following simplifications:

Due to the short cable lengths, neither double impulse diagram nor terminating impedance or reflexion suppressor were used. The PD calibrator was connected in parallel to the test object only at the detector-remote end.

4.4.4 Impulse voltage test at elevated temperature (test 4)

Test arrangement to IEC 61442: 2005-04, Clause 6

The conductors of the four test objects were connected in series. To obtain the necessary elevated (conductor) temperature, the conductor of the single-core cable was heated with single-phase AC on the basis of the induction principle by leading the conductor loop through a heating transformer. The supply voltage of the heating circuit was automatically controlled. So, the elevated conductor temperature remained constant ± 2 K during the last 2 hours of the 5-hour heating cycle.

4.4.5 Electrical heat cycling test in air (test 5)

Test arrangement to IEC 61442: 2005-04, Clauses 4 and 9

For the test arrangement of the heating circuit see Sub-clause 4.4.4. The ambient temperature was kept to $20 \text{ }^\circ\text{C} \pm 5 \text{ K}$. The thermal cycling was implemented by a test cycle control facility.



ВНЕШНЕЕ
ОПРЕДЕЛЕНИЕ

Test arrangement (continued)

4.4.6 Electrical heat cycling test in water (test 6)

In addition to the test arrangement to Sub-clause 4.4.5, the test objects were arranged in a water-filled tank (water bath). The water-level was 1 m above the upper edge of the test objects (see Figure 1).




Figure 1: Test of the connectors in water bath

4.4.7 Disconnection/connection (test 7)

None

4.4.8 Partial discharge test at elevated and ambient temperatures (test 8)

See Sub-clause 4.4.3

For the test at elevated temperature see also Sub-clause 4.4.4,

4.4.9 Impulse voltage test at ambient temperature (test 9)

See Sub-clause 4.4.4, but without additional conductor heating

4.4.10 AC voltage test (test 10)

See Sub-clause 4.4.2



ВЕРНО
ОПРЕДЕЛЕНА

4.5 Test and measuring circuits

4.5.1 DC voltage test (test 1)

Technical data of test circuit

DC voltage source


Test transformer: Rated voltage 100 kV
 Rated power 8 kVA
 Rated frequency 50 Hz

Rectifier: Rated voltage 135 kV
 Rated current 15 mA

Smoothing capacitor: Capacitance 10 nF

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	Ohmic divider with MU11 (TuRD) peak voltmeter	Ratio 560



- E Supply
- PTr Test transformer with variable transformer connected in series
- GI Rectifier
- C_G Smoothing capacitor
- 1 Measuring point
- PO Test object

Figure 2: Test and measuring circuit for the DC voltage test



**ВЯНО С
ОРИГИНАЛА**

Test and measuring circuits (continued)

4.5.2 AC voltage test (tests 2 and 10)


Technical data of test circuit

Single-phase AC voltage source

Test transformer:	Rated voltage	125 kV
	Rated power	100 kVA
	Rated frequency	50 Hz
	Damping resistance	0.67 kΩ

Technical data of measuring circuit


Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	Capacitive divider with MU11 (TuRD) peak voltmeter	Ratio 864



- E Supply
- PTr Test transformer with variable transformer connected in series
- R_D Damping resistance
- 1 Measuring point
- PO Test object

Figure 3: Test and measuring circuit for the AC voltage test

**ВРЛО С
ОРИГИНАЛ**



Test and measuring circuits (continued)


4.5.3 Partial discharge test at elevated and ambient temperatures (tests 3 and 8)

Technical data of test circuit

Test transformer:	Rated voltage	125 KV
	Rated power	100 KVA
	Rated frequency	50 Hz
	Damping resistance	0.67 KOhm

Technical data of measuring circuit


Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	- Capacitive divider with MU11 peak voltmeter (TuRD)	Ratio 864
2	Partial discharges	- Coupling capacitor of WMCF type (TuRD) - Coupling four pole of COPL542A type - PD measuring station of MPD540 type - USB Interface 502 - PD calibrator of CAL542 type (mtronix)	$C_k = 1 \text{ nF}$ Band width = 300 MHz Center frequency 400 kHz Output 10 pC



- E Supply
- PTr Test transformer with variable transformer connected in series
- Z_s Blocking impedance
- C_k Coupling capacitor
- Z_m Coupling four pole (measuring impedance)
- C-T. Capacitive divider
- HE Auxiliary sealing end
- 1, 2 Measuring points
- PO Test object

Figure 4: Test and measuring circuit for the partial discharge test
(schematic without heating circuit, for the heating circuit see Figure 6, Sheet 1)

BRAND
OPTIMATA



Test and measuring circuits (continued)


4.5.4 Impulse voltage test at elevated and ambient temperatures (tests 4 and 9)

Technical data of test circuit

Impulse circuit:	Number of stages	$n =$	2
	Impulse capacitance	$C_S =$	70 nF
	Loading capacitance	$C_B =$	1.5 nF
	Damping resistance	$R_D =$	122 Ω
	Discharge resistance	$R_E =$	1100 Ω


Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
i	Test voltage	R divider of SMR 10/770 type (made by TuRD) with digital measuring instrument of DMI 551 type (made by Haefely) and TDS 220 digital oscilloscope (made by Tektronix)	Ratio 466.9



- Gl Rectifier
- C_S Impulse capacitance
- ZFS Spark gap
- R_E Discharge resistance
- R_D Damping resistance
- C_B Loading capacitance
- PO Test object
- 1 Measuring point

Figure 5: Test and measuring circuit for the Impulse voltage test (without heating circuit, this see Figure 6, but connection of impulse generator instead of single-phase AC voltage source)



Test and measuring circuits (continued)

4.5.5 Electrical heat cycling in air and in water, resp. (tests 5 and 6)

Technical data of test circuit

Single-phase continuous AC voltage source


Test transformer: Rated voltage 125 kV
Rated power 100 kVA
Rated frequency 50 Hz

Heating circuit

Heating transformers: Rated primary voltage 380 V
Rated power 57 kVA
Max. secondary current 1000 A
Rated frequency 50 Hz

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	Capacitive divider with MU11 peak voltmeter (TuRD)	Ratio 864
2	Heating current	LH 2040 prong-type ammeter	2000-A (AC) measuring range
3	Temperature	CoCo thermocouples in connection with Almeno temperature measuring system of 2290-3 type (made by Ahlborn)	—




- Str Variable transformer
- Ht Heating transformer
- 1 - 3 Measuring points
- Ptr Test transformer with variable transformer connected in series

Figure 6: Test and measuring circuit for the electrical heat cycling tests in air and in water, resp.

4.5.6 Disconnection/connection (test 7)

None



4.6 Test results

4.6.1 DC voltage test (test 1)

Polarity: Negative

Duration of test after having reached full voltage: 15 min

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
1	Conductor	Screen	-76	No disruptive discharge
2	Conductor	Screen		No disruptive discharge
3	Conductor	Screen		No disruptive discharge
4	Conductor	Screen		No disruptive discharge

Notes:

Two test lines were tested together, they were connected by a coupling unit.

КЭПНД С
ОПРЕДЕЛЕНИЯ



TEST REPORT NO. 1213.1607.6.950

SHEET 18

Test results (continued)


4.6.2 AC voltage test (test 2)

Duration of test after having reached full voltage: 5 min
 Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
1	Conductor	Screen	57	No disruptive discharge
2	Conductor	Screen		No disruptive discharge
3	Conductor	Screen		No disruptive discharge
4	Conductor	Screen		No disruptive discharge

Notes:

Two test lines were tested together, they were connected by a coupling unit.



Test results (continued)


4.6.3 Partial discharge test at ambient temperature (test 3)

Test frequency: 50 Hz

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Calibration of the test circuit by calibrator output 10 pC


Measured PD values

Test arrangement			Prestress voltage	Measuring voltage	Measured PD value
			(1 min)	(1 min)	
No. of test object	Voltage applied to	Earthed	kV	kV	pC
1	Conductor	Screen	29	25	<1 ¹⁾
2	Conductor	Screen			
3	Conductor	Screen	29	25	<1 ¹⁾
4	Conductor	Screen			

Notes:

Two test lines were tested together, they were connected by a coupling unit

¹⁾ Basic disturbance level at same value




Test results (continued)

4.6.4 Impulse voltage test at elevated temperature (test 4)

Full wave: Front time $T_1 = 1.84 \mu s$
 Virtual time to half value $T_2 = 50 \mu s$

Test temperature: Ambient temperature $18 \text{ }^\circ\text{C}$
 Conductor temperature $95\text{--}100 \text{ }^\circ\text{C}$

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	Number of impulses/disruptive discharges
1	Conductor	Screen	+125 ¹⁾ -125 ¹⁾	10/0 ¹⁾ 10/0 ¹⁾
2	Conductor	Screen		
3	Conductor	Screen		
4	Conductor	Screen		



Notes:

¹⁾ All four test lines were connected to form one closed conductor loop for heating the latter. Therefore, all test lines were simultaneously tested. Providing separate test results for each of the test lines is not possible.



БЪЛГАРИЯ
 ОФИС
 ПР. 1213.1607.6.950

Test results (continued)


4.6.5 Electrical heat cycling test in air (test 5)

Duration of test: 21 days
 Test frequency: 50 Hz
 Test temperature: Ambient temperature 25 °C
 Conductor temperature 95..100 °C
 Number of load cycles: 63

Test arrangement			Continuous AC withstand voltage	Heating current	Result
No. of test object	Voltage applied to	Earthed			
1	Conductor	Screen	32 ¹⁾	341 ^{1,2)}	No disruptive discharge
2	Conductor	Screen			No disruptive discharge
3	Conductor	Screen			No disruptive discharge
4	Conductor	Screen			No disruptive discharge

Notes:

- ¹⁾ All four test lines were connected to form one closed conductor loop for heating the latter. Therefore, all test lines were simultaneously tested. Providing separate test results for each of the test lines is not possible.
- ²⁾ The heating current was regulated in such a way that a constant conductor temperature was obtained after approx. 3 hours of heating. This was kept constant ± 2 K for the remaining 2 hours of the 5-hour heating period.




Test results (continued)

4.6.8 Partial discharge test at elevated and ambient temperatures (test 8)

Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C and elevated, resp. 95..100 °C
 Calibration of the test circuit by calibrator Output 10 pC

Measured PD values

Test arrangement			Prestress voltage (1 min)	Measuring voltage (1 min)	Measured PD value	
						
No. of test object	Voltage applied to	Earthed	kV	kV	pC	
Measured PD values at elevated temperature						
1	Conductor	Screen	29	25	< 5 ¹⁾	
2	Conductor	Screen				
3	Conductor	Screen				
4	Conductor	Screen				
Measured PD values at ambient temperature						
1	Conductor	Screen	29	25	< 1.0 ¹⁾	
2	Conductor	Screen				
3	Conductor	Screen				< 1.0 ^{1), 2), 3)}
4	Conductor	Screen				< 1.0 ^{1), 2), 3)}

Notes:

- ¹⁾ Two of the respective test lines were connected to form one closed conductor loop for heating the latter. Thus, two test lines were simultaneously tested. Providing separate test results for each of the test lines is not possible.
- ²⁾ Basic disturbance level at same value
- ³⁾ The test lines were separated for the PD measurement.




ВАРИАНТ
 ОПИТНАКА

Test results (continued)

4.6.9 Impulse voltage test at ambient temperature (test 9)


Full wave: Front time $T_1 = 1.27 \mu s$
 Virtual time to half value $T_2 = 53.0 \mu s$

Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	Number of impulses/disruptive discharges
1	Conductor	Screen	+125 -125	10/0 10/0
2	Conductor	Screen		
3	Conductor	Screen		
4	Conductor	Screen		

Notes:

All test lines were tested simultaneously.




TEST REPORT NO. 1213.1607.6950

SHEET 25

Test results (continued)

4.6.10 AC voltage test (test 10)

Duration of test after having reached full voltage: 15 min
 Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	
1	Conductor	Screen	32	No disruptive discharge
2	Conductor	Screen		
3	Conductor	Screen		
4	Conductor	Screen		

Notes:

All test lines were tested simultaneously.

ВЫПОЛНЕНО
ОПЕРАЦИЯ



4.7 Assessment of the results of test sequence D1

- Test 1

In the DC voltage test at -76 kV/15 min, no disruptive discharge occurred on any of the four test objects.

- Test 2

In the 50-Hz AC voltage test at 57 kV/5 min, no disruptive discharge occurred on any of the four test objects.

- Test 3

In the partial discharge test at ambient temperature and at 50-Hz AC voltage of 25 kV, none of the four test objects exceeded the permissible maximum partial discharge value of 10 pC. The partial discharge value measured was not higher than 1.0 pC.

- Test 4

In the impulse voltage test at elevated temperature with 10 test impulses of 125-kV lightning impulse voltage 1.2/50 of each polarity, no disruptive discharge occurred on any of the four test objects.

- Test 5

All of the four test objects were subjected to 63 electrical heat cycles in air. In the simultaneous 50-Hz continuous AC voltage test at 32 kV, no disruptive discharge occurred on any of the four test objects.

- Test 6

All of the four test objects were subjected to 63 electrical heat cycles in water. No disruptive discharge occurred on any of the four test objects, when they were tested simultaneously in water and by 50-Hz continuous AC voltage of 32 kV.

- Test 7

After 5 complete operations of disconnection and connection, no visible damage was found on the contact.

- Test 8

In the partial discharge test at elevated and ambient temperatures at 50-Hz AC voltage of 25 kV, none of the four test objects exceeded the permissible maximum partial discharge value of 10 pC. The partial discharge value measured was not higher than 5 pC.

ВЕРНО
ПРОТОВАЛ



TEST REPORT NO. 1213.1607.6.950

SHEET 27

Assessment of the results of test sequence D1 (continued)

• Test 9

In the impulse voltage test at ambient temperature with 10 test impulses of 125-kV lightning impulse voltage 1.2/50 of each polarity, no disruptive discharge occurred on any of the four test objects.

• Test 10

In the 50-Hz AC voltage test at 32 kV/15 min, no disruptive discharge occurred on any of the four test objects.

All of the four test objects meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2 2006-2.

The tests of test sequence D1 have been PASSED.



5. Tests of test sequence D2

5.1 Test laboratory


High-voltage test laboratory, high-voltage hall 2 and
High-power test laboratory, high-current bay

5.2 Normative document

CENELEC Harmonization Document HD 629.1 S2: 2006-02
DIN VDE 0278-629.1 (VDE 0278 Teil 629-1); 2002-06
IEC 61442: 2005-04
DIN VDE 0278-442 (VDE 0278 Teil 442); 2006-01

5.3 Required test parameters

Test No.	Type of test	Required test parameters	
1	DC voltage test	Test voltage $6 \times U_0$: Duration of test: Polarity:	76 kV 15 min Negative
2	AC voltage test	Test voltage $4.5 \times U_0$: Test frequency: Duration of test:	57 kV 50 Hz 5 min
3	Thermal short-circuit test of the conductor	Short-circuit-conductor final temperature: Number of short-circuits:	250 °C 2
5	Disconnection/connection	Number of complete operations:	5
6	Impulse voltage test at ambient temperature	Front time: Virtual time to half value: Test voltage: Number of impulses: Polarity: Conductor temperature:	1.2 μ s 50 μ s 125 kV 10 impulses pos/neg. ϑ_u
7	AC voltage test	Test voltage $2.5 \times U_0$: Test frequency: Duration of test:	32 kV 50 Hz 15 min



ВЪВЕДЕНА С ОПИШВАЩА

5.4 Test arrangement

Each of the three connectors under test was arranged on a test line by the client. The connectors were completed by bushings or terminations. The test objects were mounted on cable lines of approx. 3-m length and of N2XS(F)2Y-1x50 RM/16 mm²-12/20 kV type. To apply the test voltage, each of the test lines had additionally been equipped with one auxiliary sealing end of EPKT type (made by Tyco Electronics Raychem).

All test voltages were applied to the core against the cable screen, which was connected to the test earth. The tests did not start earlier than 24 hours after the installation of the accessories on the cable lines.

5.4.1 DC voltage test (test 1)

Test arrangement to IEC 61442: 2005-04, Clause 5

5.4.2 AC voltage test (test 2)

Test arrangement to IEC 61442: 2005-04, Clause 4

5.4.3 Thermal short-circuit test of the conductor (test 3)

Test arrangement to IEC 61442: 2005-04, Clause 11

The three test objects were arranged on an assembly plate on equal level with phase centres distances of 110 mm. Additionally the cables were fixed by cable clamps at a distance of 350 mm from the axis of the cable connector centre. For the test, a short-circuit bridge of 30 mm x 10 mm was connected at the three bushings, and the auxiliary sealing end sides of the three test lines were connected three-pole to the short-circuit current source.

5.4.4 Disconnection/connection (test 5)

None

5.4.5 Impulse voltage test at ambient temperature (test 6)

Test arrangement to IEC 61442: 2005-04, Clause 6

5.4.6 AC voltage test (test 7)

See Sub-clause 5.4.2



5.5 Test and measuring circuits

5.5.1 DC voltage test (test 1)

See Sub-clause 4.5.1

5.5.2 AC voltage test (test 2)

See Sub-clause 4.5.2

5.5.3 Thermal short-circuit test of the conductor (test 3)

See following sheet

5.5.4 Disconnection/connection (test 5)

None

5.5.5 Impulse voltage test at ambient temperature (test 6)

See Sub-clause 4.5.4

5.5.6 AC voltage test (test 7)

See Sub-clause 4.5.2

**ВЕРНО С
ОРИГИНАЛА**




Test and measuring circuits (continued)

Thermal short-circuit test (test 3)

Technical data of test circuits

Test requirement	Short-circuit tests	
Test No.	207 2835 and 207 2837	
Number of phases (Test circuit)	3	
Number of poles/phases (Test object)	3	
Power frequency Hz	50	
Power factor $\cos \varphi$	0,015	
Earthing conditions	Generator / grid	Not earthed
	Short-circuit transformer	Earthed
	Short-circuit point	Not earthed



E	Power supply (grid)	TO	Test object
SI	Master breaker	I	Current measurement
Dr	Making switch	U	Voltage measurement
L	Current-limiting reactor	1 - 3	Measuring points
Tr	Short-circuit transformer		

Figure 7: Test and measuring circuit for the thermal short-circuit test of the conductor

Technical data of measuring circuits

Measuring point	Symbol	Measured quantity	Measuring sensor/device
1	I L1	Current of conductor L1	Rogowski measuring device
2	I L2	Current of conductor L2	Rogowski measuring device
3	I L3	Current of conductor L3	Rogowski measuring device

Recording Instrument: BE 256 transient recorder system



ВЪВЕД С
ОПРЕДЕЛЕНА

5.6 Test results

5.6.1 DC voltage test (test 1)

Polarity: Negative

Duration of test after having reached full voltage: 15 min

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
5	Conductor	Screen	-76	No disruptive discharge
6	Conductor	Screen	-76	No disruptive discharge
7	Conductor	Screen	-76	No disruptive discharge

Notes: -




**ВАЖНО С
ОРИГИНАЛОМ**

Test results (continued)

5.6.2 AC voltage test (test 2)

Duration of test after having reached full voltage: 5 min
 Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
5	Conductor	Screen	57	No disruptive discharge
6	Conductor	Screen	57	No disruptive discharge
7	Conductor	Screen	57	No disruptive discharge

Notes: -



**ВАЖНО С
ОПРЕДЕЛЕНИЕМ**

Test results (continued)

5.6.3 Thermal short-circuit test of the conductor (test 3)

Condition of test object before test:	Prestressed by previous tests
Connection of the test object:	By 50-mm ² cable
Short-circuit point:	At the bushings
Ambient temperature:	16 °C

Test parameters:

Test No.		207 2835	207 2837
Test voltage	V	455	455
Peak short-circuit current	kA	L1	12.8
		L2	13.5
		L3	14.8
Symmetrical short-circuit current	kA	L1	8.93
		L2	8.86
		L3	9.32
	Average	9.04	9.01
Duration of short-circuit	ms	1011	1011
Joule Integral 10 ⁶	A ² s	L1	80.8
		L2	79.9
		L3	88.2
Symmetrical short-circuit current 1 s	kA	9.09	9.06
Notes		-	2_Kt
Evaluation		OK	OK

Notes:

OK: The test object is able to carry the short-circuit current.

Condition of test object after test:

The test objects did not show any externally visible changes or damage.



**ВНЕШНЕ
ОПРЕДЕЛЕНИЕ**


Test results (continued)

5.6.4 Disconnection/connection (test 5)

Each of the three test objects was disconnected and connected altogether five times as specified by the manufacturer's assembly instructions. No visible damage was found on the contact.

5.6.5 Impulse voltage test at ambient temperature (test 6)

Full wave:	Front time	$T_1 = 1.27 \mu s$
	Virtual time to half value	$T_2 = 53 \mu s$
Test temperature:	Ambient temperature	20 °C
	Conductor temperature	20 °C

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	Numbers of Impulses/disruptive discharges
5	Conductor	Screen		
6	Conductor	Screen	+125 -125	10/0 10/0
7	Conductor	Screen		

Notes:

All test lines were tested simultaneously.



ВЪВЕДЕН
ОПРАВКА

TEST REPORT NO. 1213.1607.6.950

SHEET 36

Test results (continued)

5.6.6 AC voltage test (test 7)

Duration of test after having reached full voltage: 15 min

Test frequency: 50 Hz

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
5	Conductor	Screen	32	No disruptive discharge
6	Conductor	Screen		
7	Conductor	Screen		

Notes:

All test lines were tested simultaneously.



ВЪЗЛОЖИ
ОПРЕДЕЛЕНИЕ

5.7 Assessment of the tests of test sequence D2

• Test 1

In the DC voltage test at -76 kV/15 min, no disruptive discharge occurred on any of the three test objects.

• Test 2

In the 50-Hz AC voltage test at 57 kV/5 min, no disruptive discharge occurred on any of the three test objects.

• Test 3

In the thermal short-circuit test of the conductor with a thermally equivalent current of 9.1 kA/1 s, no visible damage was detected on any of the three test objects.

• Test 5

After 5 complete operations of disconnection and connection, no visible damage was found on the contact.

• Test 6

In the impulse voltage test at ambient temperature with 10 test impulses of 125-kV lightning impulse voltage 1.2/50 of each polarity, no disruptive discharge occurred on any of the three test objects.

• Test 7

In the 50-Hz AC voltage test at 32 kV/15 min, no disruptive discharge occurred on any of the three test objects.

All of the three test objects meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2 2006-2.

The tests of test sequence D2 have been PASSED



6. Tests of test sequence D3

6.1 Test laboratory

High-voltage test laboratory, high-voltage hall 2

6.2 Normative document

CENELEC Harmonization Document HD 629.1 S2: 2006-02
 DIN VDE 0278-629.1 (VDE 0278 Teil 629-1): 2002-06
 IEC 61442: 2005-04
 DIN VDE 0278-442 (VDE 0278 Teil 442): 2006-01

6.3 Required test parameters

Test No.	Type of test	Required test parameters
14	Operating eye test	Axial force 1300 N, 1 min Torque 14 Nm Duration of test: 1 min
15	Partial discharge test at ambient temperature	Prestress voltage $2.25 \times U_0$: 29 kV Measuring voltage $2.00^{1)} \times U_0$: 25 kV Prestress duration: 1 min Measuring time: 1 min

Notes to the table of required test parameters:

- 1) CENELEC Harmonization Document HD 629.1 S2: 2006-2, Table 7, requires the partial discharge to be measured at a measuring voltage of $1.73 \times U_0$ or $2.00 \times U_0$ respectively. The measurement was done at $2 \times U_0$ because the standard of the cable used for the test requires a test voltage $> 1.73 \times U_0$

**ВЯЖО С
ОРИГИНАЛА**



6.4 Test arrangement

The client arranged each of the cable connectors under test (test object) on a test line. The test objects were mounted on cable lines of approx. 1 m length and of N2XS(F)2Y-1x50 RM/16 mm²-12/20 kV type. To apply the test voltage, each of the test line had additionally been equipped with one auxiliary sealing end of EPKT type (manufacturer Tyco Electronics Raychem). All test voltages were applied to the core against the cable screen, which was connected to the test earth.

The tests did not start earlier than 24 hours after the installation of the accessories on the cable lines.

6.4.1 Operating eye test

Test arrangement to IEC 61442: 2005-04, Clause 19

6.4.2 Partial discharge test at ambient temperature

Test arrangement to IEC 61442: 2005-4, Clause 7, with the following simplifications:

Due to the short cable lengths, neither double impulse diagram nor terminating impedance or reflexion suppressor were used. The PD calibrator was connected in parallel to the test object only at the detector-remote end.



6.5 Test and measuring circuits

6.5.1 Operating eye test

None


6.5.2 Partial discharge test at ambient temperature

Technical data of test circuit

Test transformer:	Rated voltage	125 kV
	Rated power	100 kVA
	Rated frequency	50 Hz
	Damping resistance	0.67 kOhm

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	- Capacitive divider with MU11 peak voltmeter (TuRD)	Ratio 864
2	Partial discharges	- Coupling capacitor of WMCF type (TuRD) - Coupling four pole of COPL542A type - PD measuring station of MPD540 type - USB Interface 502 - PD calibrator of CAL542 type (mtronix)	$C_k = 1 \text{ nF}$ Band width = 300 MHz Center frequency 400 kHz Output 10 pC



- E Supply
- PTr Test transformer with variable transformer connected in series
- Z_s Blocking Impedance
- C_k Coupling capacitor
- Z_m Coupling four pole (measuring Impedance)
- C-T. Capacitive divider
- HE Auxillary sealing end
- 1, 2 Measuring points
- PO Test object

Figure 8: Test and measuring circuit for the partial discharge test



ВАЖНО С
ОРИГИНАЛ

6.6 Test results

6.6.1 Operating eye test

The connector releases at an axial force of 23 N, but is capable of tightening again.


6.6.2 Partial discharge test at ambient temperature

Test frequency: 50 Hz

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Calibration of the test circuit by calibrator output 10 pC

Measured PD values

Test arrangement			Prestress voltage	Measuring voltage	Measured PD value
			(1 min)	(1 min)	
No. of test object	Voltage applied to	Earthed	kV	kV	pC
1	Conductor	Screen	29	25	(1 ¹⁾

Notes:

¹⁾ Basic disturbance level at same value



ВАЖНО С
ОРИГИНАЛА

TEST REPORT NO. 1213.1607.6.950

SHEET 42

6.7 Assessment of the results of test sequence D3

• Test 1

No visible damage was found after the operating eye test.

• Test 2

In the partial discharge test at ambient temperature and at 50-Hz AC voltage of 25 kV, none of the test object exceeded the permissible maximum partial discharge value of 10 pC. The partial discharge value measured was not higher than 1.0 pC.

All of the test object meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2 2006-2.

The tests of the test sequence D3 have been PASSED



**ВЯЖО С
ОРИГИНАЛ**

7. Special tests (tests Nos. 17 to 21)

7.1 Test laboratory

Low-voltage test laboratory, test room 7 (test No. 17)
 High-voltage test laboratory, high-voltage hall 2 (tests Nos. 18, 20 and 21))
 High-power test laboratory, test bay 3 (test No. 19)

7.2 Normative documents

CENELEC Harmonization Document HD 629.1 S2: 2006-02
 DIN VDE 0278-629.1 (VDE 0278 Teil 629-1): 2002-06
 IEC 61442: 2005-04
 DIN VDE 0278-442 (VDE 0278 Teil 442): 2006-01

7.3 Required test parameters

Test No.	Type of test	Required test parameters
17	Screen resistance measurement	Temperature during exposure to heat: (120±2) °C Duration of thermal ageing: 168 h
18	Leakage current measurement	Test voltage U_m : 24 kV
19	Screen fault current initiation test	<ul style="list-style-type: none"> • Solidly earthed system Test voltage: 12.7 kV¹⁾ Test current: 10 kA Duration of current flow: 0.2 s Number of tests: 2 • Unearthed or Impedance-earthed system Test voltage: 12.7 kV¹⁾ Test current: Minimum 10 A Test procedure: Start C-1 s O-2 min C-2 min O-2 min C 1 min O end
20	Operating force test	F < 900 N
21	Capacitive test point performance	-

Note:

1) Test parameter complies with normative document. If lower values are applied the test will become more severe.



**ВАЖНО С
ОРИГИНАЛА**

7.4 Test arrangement

7.4.1 Screen resistance measurement (test No. 17)

Test arrangement to IEC 61442: 2005-04, Clause 15

Only one single connector body was used for the measurement. For the definite and reproducible measurement of the resistance on the screen two rings made of bare copper wire and of approx. 1-mm width were fixed to the screen. They served as fixed electrodes for the resistance measurement.

7.4.2 Leakage current measurement (test No. 18)

Test arrangement to IEC 61442: 2005-04, Clause 16

The client installed one test object on a short length of cable, which was equipped with an auxiliary sealing end on its other end, and completed it with a bushing. Subsequently, a square metal foil of 25 cm² was fitted to the outer conductive layer of the test object in the region of the bushing. When the AC test voltage was applied to the test object, the leakage current from metal foil to earth was measured.

7.4.3 Screen fault current initiation test (test No. 19)

Test arrangement to IEC 61442: 2005-04, Clause 17

A bushing was centrally arranged in a metal plate of 600 x 600 x 5, which was vertically fixed to a test rack. Each of the test objects, installed on a short length of cable by the client, was fixed to the bushing and the screen was earthed in accordance with the manufacturer's instructions. The other end of each length of cable was equipped with an auxiliary sealing end. For the test with solidly earthed system, a threaded rod of 10 mm Ø was arranged in the region of the transition from the conductor to the cable lug in the body of the connector under test so that a connection was established from the cable lug through a drilled hole to the inner and outer conducting layers of the connector body. For the test with unearthed or impedance earthed systems, a drilled hole was used instead of the rod. It had a copper wire of 0.2 mm Ø for bridging the insulation between the inner and outer screens and for initiating the arc. In both cases, neither the rod nor the wire protruded beyond the outer conducting layer of the connector body.

7.4.4 Operating force test of the cable connector (test No. 20)


Test arrangement to IEC 61442: 2005-04, Clause 18

One connector was assembled according to the client's instructions and was mounted on a bushing using a gliding agent provided by the client.

7.4.5 Capacitive test point performance (test No. 21)

Test arrangement to IEC 61442: 2005-04, Clause 20

One connector was installed on a short length of cable by the client and the screen was earthed in accordance with the manufacturer's instructions. The test object was equipped with a mating bushing.




7.5 Test and measuring circuits

7.5.1 Screen resistance measurement (test No. 17)

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Resistance	Digital hand multimeter of 137 type (KETHLEY)	Measuring range R - 2 kΩ



- 1 Measuring point
- PO Test object

Figure 9: Measuring circuit for resistance measurement on the screen



Test and measuring circuits (continued)

7.5.2 Leakage current measurement (test No. 18)


Technical data of test circuit

Single-phase AC voltage source

Test transformer:	Rated voltage	125 kV
	Rated power	100 kVA
	Rated frequency	50 Hz
	Damping resistance	0.67 kΩ

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	Capacitive divider with MU11 (TuRD) peak voltmeter	Ratio 864
2	Test current	Digital hand multimeter of 137 type (KEITHLEY)	MB 0.2 mA AC



- E Supply
- Ptr Test transformer with variable transformer connected in series
- R_d Damping resistance
- R Resistance
- 1, 2 Measuring points
- PO Test object

Figure 10: Test and measuring circuit for the leakage current measurement

ВАРНО С
ОРИГИНАЛ




Test and measuring circuits (continued)

7.5.3 Screen fault current initiation test (test No. 19)

Technical data of test circuit

Test requirement	Screen fault current test	
Test No.	107 4008 and 107 6207	
Number of phases	(Test circuit)	2
Number of poles/phases	(Test object)	1
Power frequency	Hz	50
Power factor $\cos \varphi$		< 0.15
Connection of short-circuit transformers		I/I
Short-circuit power		120 MVA
Earthing conditions	Grid	Not earthed
	Short-circuit transformer	Earthed




- E Power supply (grid)
- Si Master breaker
- Dr Making switch
- L1, L2 Current limiting reactors
- Tr Short-circuit transformer
- 1, 2 Measuring points
- I Current measurement
- U Voltage measurement
- TO Test object

Figure 11: Test and measuring circuit for the screen fault current initiation test

Technical data of measuring circuits

Test No.	Measuring point	Symbol	Measured quantity	Measuring sensor/device
107 4008 and 107 6207	1	I	Short-circuit current	Current transformer
	2	U	Test voltage	RC divider

Recording Instrument:
BE 256 transient recorder




7.5.4 Capacitive test point performance (test No. 21)

Capacitance measurement by differential bridge

The capacitance C_x to be measured was connected to a capacitance measuring bridge together with the well-known capacitance C_n .

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Capacitance	C-tan δ measuring bridge of VFM type (made by MWB)	Measuring range x 100 pF
2	Test voltage	Capacitive divider with MU11 (made by TuRD) peak voltmeter	



- G Sine-wave generator
- C_x Capacitance to be determined
- L, S Cable conductor or cable screen
- KP Capacitive test point
- C_n Comparison capacitance
- 1, 2 Measuring points

Figure 12: Test and measuring circuit for determining the capacitive test point performance

БЯРНО С
ОРИГИНАЛ



7.6 Test results

7.6.1 Screen resistance measurement (test No. 17)

Test temperature: Ambient temperature 20 °C
 Temperature during exposure to heat 120 °C
 Time of exposure to heat 168 h

Test arrangement		Resistance	Result
No. of test object	Condition of test object	Ω	
8	Before exposure to heat	216	OK
8	After exposure to heat	300	OK


OK: The resistance measured before and after the exposure to heat was significantly below the maximum permissible value of 5000 Ω.

7.6.2 Leakage current measurement (test No. 18)

Test temperature: Ambient temperature 20 °C

Test arrangement			Test voltage	Leakage current	Result
No. of test object	Voltage applied to	Earthed	kV	μA	
9	Conductor	Screen	24		

OK: The leakage current was below the maximum permissible value of 0.5 mA



TEST REPORT NO. 1213.1607.6.950

SHEET 50

Test results (continued)

7.6.3 Screen fault current initiation test (test No. 19)

Test requirement: Screen fault current test for impedance-earthed systems

Type of test object: RSES-5225-R 250 A

Ambient temperature: 19 °C

Test No.	107 ...	4007	4008		
Test object	No.	-	11		
Cycle		-	C _{1s} - O _{2min} - C _{2min} - O _{2min} - C _{1min} - O		
Test voltage	kV	12.8	12.8	12.8	12.8
Test current	A	15.5	15.5	15.5	15.5
Time of test	s	0.2	1	120	60
Notes		1)	2)	2)	2)
Evaluation		-	OK	OK	OK

Notes:

- 1) Current setting
 - 2) The test object is capable of properly carrying the fault current.
- OK: During the making cycle the arc was ignited or re-ignited, respectively.
During the making time, the current flow was present.
A fault in the insulation is reliably detectable.

Test requirement: Screen fault current test for solidly earthed systems


Type of test object: RSES-5225-R 250 A

Ambient temperature: 19 °C

Test No.	107	6207
Test object	No.	9
Test voltage	kV	12.8
Test current	kA	10.9
Time of test	s	200
Notes		1)
Evaluation		n. OK

Notes:

- 1) The connector got loosened from bushing and cable. The bushing got broken.
- n. OK: For the case of a disruptive discharge the screen of the connector is able to carry a fault current which is sufficient to trip the protection device, but another operation is no more possible.



Test results (continued)

7.6.4 Operating force test (test No. 20)


Cold conditioning for 12 h at -20 °C, withdrawal force = 524 N

7.6.5 Capacitive test point performance (test No. 21)

Test temperature:


Ambient temperature

23 °C

Test arrangement			Capacitance of test point KP		Notes
					
No. of test object	Voltage applied to	Earthed	Towards cable screen C_{te}	Towards cable conductor C_{tc}	
			pF	pF	
12	L (conductor)	Screen connection of the connector body	-	9.5	OK
12	S (screen)	Conductor	11.8	-	OK

Notes:

OK: The ratio of C_{te} to C_{tc} was 11.8 pF:9.5 pF \approx 1.24, and thus \leq 1.2 as specified by the normative document



ВАШЕ С
ОПТИМАЛНА

7.7 Assessment of special tests

• Test 17

The resistance measured before and after the exposure to heat at 120 °C/168 h was 300 and 216 Ω, resp. This was significantly below the maximum permissible value of 5000 Ω.

• Test 18

The leakage current measured at an applied AC test voltage of 24 kV fell below the maximum permissible value of 0.5 mA with a measured value of 5 μA.

• Test 19

- Solidly earthed systems

For the case of a disruptive discharge the screen of the connector is able to carry a fault current which is sufficient to trip the protection device. The fault was reliably initiated within 3 s. The screen is able to discharge an arc to earth. The current is sufficient to operate the circuit protection, but the cable terminal gets completely destroyed so that another making of the short-circuit was no more possible.

- Unearthed or Impedance-earthed systems

During the making cycle the arc was ignited or re-ignited, respectively. During the making time, the current flow was present. A fault in the insulation is reliably detectable. During the making cycle, the arc was ignited resp. re-ignited at 12.1 kV. During the making time, the current flow was present at 12.1 kV. A fault in the insulation is reliably detectable.

• Test 20

The withdrawal force was determined to be 524 N. Thus it is below the maximum permissible value of 900 N.

• Test 21

The ratio of C_{ie} to C_{ic} was determined to be 1.24, which is ≤ 12 as specified by the normative document.

The test objects meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2: 2006-2, except Test No. 19.



8. Photos




Figure 13: View of one test object




Figure 14: Arrangement for the electrical heat cycling test in air for test sequence D1

ВЪРНО С
ОРИГИНАЛ





Figure 15: View of the test objects for the test sequence D2 (mounted on bushings)




Figure 16: Test object after the screen fault current initiation test (solidly earthed systems)







Figure 17: Test object No. 11 after the screen fault current initiation test (unearthed or impedance-earthed systems)




9. Oscillograms



Test-No. 1074008



БЯРНО С
ОРЪЖИЯТА




Test-No. 1076207



БҮРГЭС
ОПРЕДЕЛ




Test-No. 2072835



2072835



Test-No. 2072837



БҮРТАС
ЭРҮҮГЭЭГ
БҮЛЭГ





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

**Списък на проведените изпитвания на щепселна кабелна глава, Г-образна/адаптор/
тип RSES**

1. Изпитване издръжливост с постоянно напрежение;
2. Изпитване издръжливост с променливо напрежение;
3. Изпитване частичен разряд при околна температура;
4. Изпитване импулсно напрежение при околна температура;
5. Изпитване циклично електрическо нагряване във въздух;
6. Изпитване циклично електрическо нагряване във вода;
7. Изпитване комутация/включване/изключване;
8. Изпитване частичен разряд при околна температура;

13.01.2016г.

Подпис и печат:



Немска Служба по Акредитация
Предоставено съгласно

с подписано многостранно споразумение на EA, ILAC и IAF за взаимно одобрение

АКРЕДИТАЦИЯ

С настоящото Немска служба за акредитация потвърждава, че лабораторията за изпитване

FGH Инженеринг и Изпитвания
Халенвег 40, 68219 Манхайм

притежава правомощия съгласно ISO/IEC 17025:2005 да провежда изпитвания в областта на
съоръжения и уреди за високо напрежение и техните компоненти,
силови кабели и комплекти за силови кабели

Свидетелството за акредитация важи във връзка с решение от 11.01.2012 с акредитационен № D-PL-12110-01 и е
валидно до 10.01.2017г. Състои се от този лист, обратната страна на този лист и приложения общо 22 страници.

Регистрационен номер на свидетелството: D-PL-12110-01

Франкфурт на Майн, 11.01.2012

дипл. инж. Ралф Егнер





Deutsche Akkreditierungsstelle GmbH German Accreditation Body

Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1 subsection 1 AkkStelleGBV

Signatory to the Multilateral Agreements of EA, ILAC and IAF for Mutual Recognition

Accreditation



The Deutsche Akkreditierungsstelle GmbH (German Accreditation Body) attests that the testing laboratory

FGH Engineering & Test GmbH
Hallenweg 40, 68219 Mannheim

is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out tests in the following fields:

High voltage devices and systems and their components
Power cable and power cable sets

The accreditation certificate shall only apply in connection with the notice of accreditation of 11.01.2012 with the accreditation number D-PL-12110-01 and is valid until 10.01.2017. It comprises the cover sheet, the reverse side of the cover sheet and the following annex with a total of 22 pages.

Registration number of the certificate: D-PL-12110-01

Frankfurt am Main, 11.01.2012

On behalf of Dipl.-Ing. (FH) Ralf Egnor
Head of Division 2

This document is a translation. The definitive version is the original German accreditation certificate.

See notes overleaf.



Немска Служба по Акредитация
Предоставено съгласно

с подписано многостранно споразумение на EA, ILAC и IAF за взаимно одобрение

АКРЕДИТАЦИЯ

С настоящото Немска служба за акредитация потвърждава, че лабораторията за изпитване

Институт „Изпитвания на електрическа високо технологична техника“
Ландсбергер Алее 378А, 12681 Берлин


притежава правомощия съгласно ISO/IEC 17025:2005 да провежда изпитвания в областта на
съоръжения и уреди за високо напрежение и техните компоненти,
кабели и проводници
индустриално оборудване ниско напрежение

Свидетелството за акредитация важи във връзка с решение от 31.08.2012 с акредитационен № D-PL-12107-01 и е валидно до 24.01.2017г. Състои се от този лист, обратната страна на този лист и приложения общо 30 страници.

Регистрационен номер на свидетелството: D-PL-12107-01-01

Франкфурт на Майн, 31.08.2012

дипл. инж. Ралф Егнер



Deutsche Akkreditierungsstelle GmbH

Bellehene gemäß § 8 Absatz 1 AkkStelleG i.V.m. § 1 Absatz 1 AkkStelleGBV
Unterzeichnerin der Multilateralen Abkommen
von EA, ILAC und IAF zur gegenseitigen Anerkennung

Akkreditierung



Die Deutsche Akkreditierungsstelle GmbH bestätigt hiermit, dass das Prüflaboratorium

Institut "Prüffeld für elektrische Hochleistungstechnik" GmbH
Landsberger Allee 378A, 12681 Berlin

die Kompetenz nach DIN EN ISO/IEC 17025:2005 besitzt, Prüfungen in folgenden Bereichen
durchzuführen:


Hochspannungsgeräte, -anlagen und deren Komponenten
Kabel und Leitungen
Industrielle Niederspannungsgeräte

Die Akkreditierungsurkunde gilt nur in Verbindung mit dem Bescheid vom 31.08.2012 mit der
Akkreditierungsnummer D-PL-12107-01 und ist gültig bis 24.01.2017. Sie besteht aus diesem Deckblatt,
der Rückseite des Deckblatts und der folgenden Anlage mit insgesamt 30 Seiten.

Registrierungsnummer der Urkunde: D-PL-12107-01-01

Frankfurt am Main, 31.08.2012

Siehe Einnachweise auf der Rückseite


Im Auftrag Dipl.-Ing. (FH) Ralf Egner
Leiter Abteilung 2

**ВАРНО С
ОПИТНАТА**





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният Иван Вълков Костов, в качеството си на управител на Кимтех България ООД, гр. Бургас, жк. Братя Миладинови, бл. 57, вх. 4А официален дистрибутор на изделията на Tyco Electronics Raychem декларирам, на собствена отговорност, че продуктите:


- 1/ Щепселна кабелна глава права 20kV, 250A, 50мм² тип RSSS 5225-P
- 2/ Щепселна кабелна глава права, 20kV, 250A, 95мм² тип RSSS 5229-P

произведени в Отобрун, Германия, за които се отнася тази декларация, са произведени в условията на въведената и поддържаната от производителя система за производствен контрол и в съответствие със следните стандарти CENELEC HD 629 (VDE 0278-629), и съответствието е оценено съгласно Наредбата за съществените изисквания и оценяване на съответствието на строителните продукти. Декларацията се издава въз основа на протоколи от проведени изпитания № PPR 2528, издаден от Лаборатория за изпитвания Берлин.

13.01.2016г.
гр. Бургас

Подпис и печат
/И. Костов-управител/







Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
тусо Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният Иван Вълков Костов, в качеството си на управител на Кимтех България ООД, гр. Бургас, жк. Братя Миладинови, бл. 57, вх. 4А официален дистрибутор на изделията на Тусо Electronics Raychem декларирам, на собствена отговорност, че продуктите:

- 1/ Щепселна кабелна глава Г-образна, 20kV, 250A, 50мм2 тип RSES 5225-P
- 2/ Щепселна кабелна глава Г-образна, 20kV, 250A, 95мм2 тип RSES 5229-P

произведени в Отобрун, Германия, за които се отнася тази декларация, са произведени в условията на въведената и поддържаната от производителя система за производствен контрол и в съответствие със следните стандарти CENELEC HD 629 (VDE 0278-629), и съответствието е оценено съгласно Наредбата за съществените изисквания и оценяване на съответствието на строителните продукти. Декларацията се издава въз основа на протоколи от проведени изпитания № PPR 2527, издаден от Лаборатория за изпитвания Берлин.

13.01.2016г.
гр. Бургас

Подпис и печат:
/И. Костов, управител/





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
~~Тусо~~ Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният Иван Вълков Костов, в качеството си на управител на Кимтех България ООД, гр. Бургас, жк. Братя Миладинови, бл. 57, вх. 4А официален дистрибутор на изделията на Tusco Electronics Raychem декларирам, на собствена отговорност, че продуктите:

- 1/ Щепселна кабелна глава за проходни изводи тип „С“ 20kV, 95-185мм² тип RICS 5133
- 1/ Щепселна кабелна глава за проходни изводи тип „С“ 20kV, 95-185мм² тип RICS 5137

произведени в Отобрун, Германия, за които се отнася тази декларация, са произведени в условията на въведената и поддържаната от производителя система за производствен контрол и в съответствие със следните стандарти CENELEC HD 629.1 S21 (2006-02), (VDE 0278-629), и съответствието е оценено съгласно Наредбата за съществените изисквания и оценяване на съответствието на строителните продукти. Декларацията се издава въз основа на сертификат от типово одобрение № E-13892 издаден от Дет Норске Веритас съгласно одобрени протоколи от проведени типови изпитания № PPR 866, PPR 1106 издадени от Лаборатория за изпитвания Тайко Електроникс Райхем и Лаборатория за изпитвания Мюнхен.

13.01.2016г.
гр. Бургас

Подпис и печат





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
тусо Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният Иван Вълков Костов, в качеството си на управител на Кимтех България ООД, гр. Бургас, жк. Братя Миладинови, бл. 57, вх. 4А официален дистрибутор на изделията на Тусо Electronics Raychem декларирам, на собствена отговорност, че продуктите:

1/ Кабелна глава, 20 kV, закрит монтаж, термосвиваема 70-240mm² тип POLT 24D/1X1


произведени в Отобрун, Германия, за които се отнася тази декларация, са произведени в условията на въведената и поддържаната от производителя система за производствен контрол и в съответствие със следните стандарти CENELEC HD 629 (VDE 0278-629), IEC 60502-4 и съответствието е оценено съгласно Наредбата за съществените изисквания и оценяване на съответствието на строителните продукти. Декларацията се издава въз основа на протокол от проведени изпитания № PPR 1410, издаден от Лаборатория за изпитвания Манхайм.

13.01.2016г.
гр. Бургас

Подпис и печат
/И. Костов - Управител/



E L E C T R I C A L
P R O D U C T S D I V I S I O N



Инструкция за монтаж
EPP 0580 9/95

Екраниран прав адаптор
250А, за едножилни
пластмасови кабели
12 до 24 kV без броня
(с тръба за маркиране на
фазите)

Тип RSSS



Raychem

ВЪРХО С
ОПРИМАН


Препоръки за безопасност

Важно е да се спазват съответните правила за безопасност при работа с оборудване високо напрежение. За точна информация относно безопасността моля свържете се с официалният представител.

Преди монтажа

Проверете, че комплекта е предназначен за кабела. Проверете етикета на комплекта и заглавието на Инструкцията за монтаж. Възможно е, компонентите или стъпки на работа да са променени, в сравнение с тези от предходния път, в който сте монтирали този продукт. Внимателно прочетете и следвайте стъпките в Инструкцията за монтаж.

Информацията, съдържаща се в тези инструкции за монтаж е предназначена да опише правилния метод на монтаж на този продукт. Въпреки това, Rauchem няма контрол върху полевите условия, които влияят върху монтажа на продукта. Това е отговорност на потребителя, да се определи пригодността на метода на монтаж в полеви условия на потребителя. Задълженията на Rauchem са само тези, които са посочени в стандартните условия за продажба на Rauchem за този продукт и в никакъв случай Rauchem няма да е отговорен за каквито и да било други случайни, непреки или последващи вреди, произтичащи от употребата или злоупотребата с продуктите.



Подготовка на кабела




Почистете и обезмаслете края на външната обвивка на дължина от 1 метър с разтворител.


A. Кабел с екран от телове

Позициониране на кабела.
Маркирайте външната обвивка на 200 mm под края на втулката. Отрежете кабела 420 mm над маркировката и премахнете външната обвивка до този размер

Увийте един слой уплътнителна лента (червена) с малко припокриване и леко разтягане около края на външната обвивка 60 mm. Огънете екрана от телове обратно върху външната обвивка. Избягвайте пресичане на отделните телове. Фиксирайте теловите с лента.


Отрежете жилото в съответствие с чертежа. Премахнете екрана съгласно чертежа. Повърхността на изолацията не трябва да има следи от полупроводим материал. Забележка: не наранявайте изолацията, почистете от неравности






B2

2323/10



B3

2400/2



B4

1/1

В. Кабел с екран от ленти
 Отрежете жилото съгласно чертежа. Премахнете външната обвивка на разстояние от 190 mm. Премахнете екрана от метални ленти до 20 mm от отреза на външната обвивка. Премахнете олюпроводимия екрана на жилото до 50 mm от отреза на външната обвивка. Повърхността на изолацията не трябва да има следи от полупроводим материал. Забележка: не наранявайте изолацията, почистете от неравности

Увийте един слой уплътнителна лента (червена) с малко припокриване и леко разтягане около края на външната обвивка 60 mm.


Фиксирайте заземителното въже към металния екран, така че приблизително 300 mm да остане свободният край. Оформете 30 mm преграда срещу влага като започнете 10 mm под мастик лентата. Фиксирайте заземителното въже с лента.

Изпълнение на адаптора

Отрежете изолацията както е показано на чертежа. Монтирайте конектора с инструмент за кербоване за алуминий в съответствие с размера показан на съединителя. Почистете и обезмасл. изол. на жилото и съединителя. Забележка: Използвайте само кербовъчни накрайници с мин. ширина на раб. повърхност 7 mm.


Проверете позицията на фазите и поставете съответно маркираната тръба върху кабела.

Нанесете силиконова смазка до края на изолацията на разстояние от около 50mm.




5

2325/3




6


2321/4




7



Напъхайте тялото на адаптора върху подготовеният кабел. Уверете се, че щифта е захванал тялото. Не трябва да е възможно да се измъкне обратно ако това е направено правилно. Точката за изпитване на адаптора трябва да е достъпна за измерване.
Note: Не пипайте изолацията.



Увийте уплътнителна лента /червена/ между края на външната изолация и адаптора с дължина 25мм.
 Сложете достатъчно уплътнителна лента, за да се постигне плавен преход от външната обвивка към адаптора.








A. Екран от телове
 Поставете 3 екраниращи телове и ги промушете през отвора на адаптора. Още не ги увивайте заедно.

В. Екран от ленти
 Вземете края на телта и я промушете през отвора адаптора. Още не я увивайте.

Започнете от долния край на предно положената лента и увивайте на горе уплътнителна лента /червена/ около кабела и адаптора на разстояние 120 mm.


Позиционирайте тръбата така, че частта увита с лента да е напълно покрита и свийте с горелка като започнете от долу нагоре по посока на адаптора.






A. Екран от телове

Увийте екраниращите телове заедно около дупката на адаптора. Подсигурете телове с плетенка към изолацията. Увийте екраниращите телове заедно във формата на заземително въже.



B. Екран от ленти

Увийте телове заедно около дупката на адаптора. Подсигурете заземителното въже към изолацията с плетенка.





14
Нанесете силиконова смазка във прохода и във вътрешната повърхност


на свързания адаптор.

Изпълнение на връзката

Пъхнете адаптора в прохода.




Разположете планките около тялото над точката за изпитване. Уверете се, че планките се припокриват, както е показано така, че да се получи равна повърхност.



Пъхнете скобите през дупките на планките и ги закачете към прохода затегнете болтовете здраво на ръка. Монтажът е готов.

ВАЖНО С ОПТИКАТА
 Х-БЪЛГАРИЯ
 КИМТЕХ
 БУРГАС



Инструкция за монтаж
ERP-0470-2/00

Екраниран адаптор
250А за едножилен
пластмасов кабел 12
до 24 kV без броня
(с тръба за маркиране на
фазите)

Тип RSES

Tyco Electronics Raychem GmbH
Energy Division
Finsinger Feld 1
85521 Ottobrunn
Munich, Germany
Tel. ++49-89-6089-9
Fax ++49-89-6096345

ВАРНА
ОРБИМА




Препоръки за безопасност

Важно е да се спазват съответните правила за безопасност при работа с оборудване високо напрежение. За точна информация относно безопасността моля свържете се с официалния представител.

Преди монтажа

Проверете, че комплекта е предназначен за кабела. Проверете етикета на комплекта и заглавието на Инструкцията за монтаж. Възможно е компонентите или стъпките на работа да са променени, в сравнение с тези от предходния път, в който сте монтирали този продукт. Внимателно прочетете и следвайте стъпките в Инструкцията за монтаж.






Подготовка на кабела


Почистете и обезмаслете края на външната обвивка на дължина от 1 метър с разтворител.

A. Кабел с екран от телове
Позициониране на кабела.
Маркирайте външната обвивка на 200мм под края на втулката, отрежете кабелна на 420мм над маркировката и премахнете външната обвивка до този размер.

Увийте един слой уплътнителна лента (червена) с малко припокриване и леко разтягане около края на външната обвивка 60 мм. Огънете екрана от телове обратно върху външната обвивка. Избягвайте пресичане на отделните телове. Фиксирайте теловите с лента.

Отрежете жилото в съответствие с чертежа. Премахнете екрана съгласно чертежа. Повърхността на изолацията не трябва да има следи от полупроводим материал. Забележка: не наранявайте изолацията почистете от неравности.






B2

2323_08

В. Кабел с екран от ленти
Отрежете жилото съгласно чертежа. Премахнете външната обвивка на Разстояние от 190 mm. Премахнете полупроводимия екран на жилото до 50 mm от отреза на външната обвивка. Повърхността на изолацията не трябва да има следи от полупроводим материал. Забележка: не наранявайте изолацията, почистете от неравности.

Отрежете изолацията както е показано на чертежа. Монтирайте кабелна обувка на проводника, така че отвора на кабелната обувка и втулката да са на една линия. Монтирайте кабелната обувка с инструмент за кербоване за алуминий в съответствие с размера показан на обувката. Забележка: използвайте само кербовъчни крайници с дължина на на раб. повърхност 7 мм.




B3

2400_01

Увийте един слой уплътнителна лента /Червена/ с малко припокриване и лека разтягане околочрая на на външната обвивка 60mm.

Почистете и обезмаслете изолацията на жилата и обувката. Проверете позицията на фазите и поставете съответно маркираната тръба върху фазите.




B4

2401_01


Фиксирайте заземителното въже, така, че приблизително 300mm да остане свободния край. Оформете 30mm преграда срещу влага като започнете 10mm по д мастик лентата. Фиксирайте заземителното въже с лента.

Нанесете силиконова смазка до края на изолацията на разстояние от около 50mm.




5

2325_01




6

2321_03




7


50



Напъхайте тялото на адаптора върху подготвения кабел. Предният край на адаптора трябва да сочи към втулката. Отвора на кабелната обвивка и втулката трябва да са на една линия.
Забележка: не пипайте изолацията




Вкрайте свързващия щифт в адаптора и я закрепете с шестограмен ключ. Завъртете докато ключът се деформира.




Увийте уплътнителна лента /червена/ между края на външната изолация и адаптора с дължина 25мм. Сложете достатъчно уплътнителна лента, за да се постигне плавен преход от външната обвивка към адаптора.

А. Екран от телове
Поставете 3 екраниращи телове и ги промушете през отвора на адаптора. Още не ги увивайте заедно




2332_01

В. Екран от ленти
Вземете края на телта и я промушете през отвора на адаптора. Още не я увивайте.




2332_02

Започнете от долния край на предходно сложената лента и увивайте нагоре уплътнителна лента /червена/ около кабела и адаптора на разстояние 120мм




2357_01



13

2333_04


Позиционирайте така тръбата, че частта увита с лента да е напълно покрита и свийте с горелка като започнете от долу на горе по посока на адаптора.



A14

2333_06

А. Екран от телове
Увийте телове заедно около дупката на адаптора. Подсигурете телове с плетенка към изолацията. Увийте екраниращите телове във формата на заземително въже.



B14


2333_05

В. Екран от ленти
Увийте телове заедно около дупката на адаптора. Подсигурете заземителното въже към изолацията с плетенка.

Нанесете силиконова смазка във прохода и във вътрешната повърхност на свързания адаптор.


Закачете скобите в прохода. Пъхнете адаптора в прохода.

Центрирайте скобата към адаптора и я закрепете. Монтажът е готов.




15

2328_01




16

2335_04b



17



Инструкция за монтаж
ERP-0271-BG-12/94
Изолирани
T-адаптори за
напрежение до 24 kV
и 630 A за втулки с
резба по DIN 47636

Тип: RICS



Raychem

ВЪРНА С
ОРИГИНАЛА

Информацията, съдържаща се в настоящата инструкция е предназначена да опише точния метод за инсталиране на този продукт. Поради това, че Rauchem няма възможност да контролира полевите или други условия на монтаж, монтажът трябва да прилага собствения си опит, когато инсталира този продукт.

Rauchem не поема отговорност в случаи на повреди, възникнали в следствие на неправилно използване на продукта.

Внимание!

Адапторът и главата не са екранирани!

При подадено напрежение повърхността на изолацията ще бъде също под напрежение, затова не трябва да се докосва!


Спазвайте правилата за работа с високоволтови съоръжения.

Забележка:

Минимално разстояние между адапторите: 25 mm

между адаптор и земя: 25 mm

Профил на втулката: Описаните адаптори да се използват само при размери на втулките отговарящи на тези от схеми A1 или A2.



Общи инструкции

Използвайте кабелни обувки с подходящ отвор.

Отстранете окиса от плоската част на обувката.

След пресоване отстранете острите ръбчета.

Използвайте обувки с подходящ химичен състав, ако е нужно - калайдисани или биметални.

Оставете главата да изстине преди да монтирате адаптора.


Монтаж на главата

Монтирайте главата според приложената от Rauchem инструкция.


Стрехичките, доставени с главата не са нужни при адаптора RICS.

Главата съдържа херметизиращ лепилен слой върху обувката, който трябва да е на разстояние най-малко 50 mm от центъра на отвора на обувката.


Ако в комплекта на адаптора има заклиняваща тръба, свийте я върху главата по размерите от схема В.



С Разположение на детайлите в готов Т-адаптор




Монтаж на Т-адаптора




Намажете обилно със силиконова паста края на главата на около 80 mm. Намажете с проводимата паста повърхността на вложката, късия край на адаптора и плоската част на обувката.

0157


Пъхнете главата в тялото на адаптора. Дългият край на адаптора да сочи втулката.




Отворът на кабелната обувка да е на една линия с този на металната вложка на адаптора.




Отстранете щифта, останал във втулката. Завийте щифта на адаптора във втулката и го затегнете добре.






5
Намажете със силикон втулката и вътрешната повърхност на адаптора.



6
Напъхайте адаптора върху втулката. Вкарайте шайбата и гайката. Затегнете голямата гайка с усилие, показано долу.

Втулка	Резба	Сила Nm	
		min	max
A1	M16	50	70
A1	M16/M12	35	40
A2	M12	35	40




7
Поставете връвчицата в отвора на адаптора, както е показано на схемата.

Намажете обилно със силикон коничната повърхност на запушалката на адаптора и вътрешната му повърхност.

Завийте запушалката в адаптора. Завиването става с голямо усилие. Монтажът е завършен при усещане на голямо съпротивление. Не пренатягайте! Издърпайте връвчицата, за да освободите въздушно налягане в адаптора.


Схемата показва завършения адаптор.

Отстранете всички отпадъци в съответствие с санитарните норми.




8
Raychem е запазена марка на Raychem Corporation

Raychem




9
Raychem България
ВРЗЕТ ИНЖЕНЕРИНГ
Бургас
жк Братя Миладинови
бл.57 вх.4А ап.3
тел.факс 0035 956 37102
тел. 0035 956 34198




10

ВЪНШНА
ОРИЕНТАЦИЯ



Стр. 4/4

Raychem



Инструкция за монтаж
ESD-3824-BG-4/05

Кабелни глави за кабели
с пластмасова изолация
без броня, за напрежение
до 42 kV

Тип: POLT

Raychem – България
Бургас 8000
ЕРЗЕТ ИНЖЕНЕРИНГ
жк. "Братя Милединови"
Бл. 57, вх. 4А, ет. 1
Тел./факс-0035 956 34198
Тел./факс-0035 956 37102
GSM -0035 988 639903

Tyco Electronics Raychem GmbH
Energietechnik
Finsinger Feld 1
85521 Ottobrunn
Telefon: ++49-89-6089-0
Telefax: ++49-89-6096345



Преди работа

Убедете се, че комплекта, който използвате съответства на кабела.
Сверете етикета на комплекта със заглавието на инструкцията.
Внимателно прочетете инструкцията и следвайте стриктно стъпките на монтажа, защото е възможно да е настъпила промяна в компонентите или последователността на операциите след последния монтаж, който сте извършвали.

Общи положения

Препоръчва се използването на пропан-бутан.

Регулирайте горелката така, че да преобладава мекият, жълт пламък.

Избягвайте островърхия, син пламък.

Дръжте горелката наклонена в посоката на свиване така, че да подгрива студените части на тръбата.

Движете пламъка непрекъснато, за да избягвате прегаряне и нагърчване на тръбата.

Почистете с разтворител всички части, които ще контактуват с термотопимото лепило.

Спазвайте инструкциите за работа със съответния разтворител.

При рязане на тръбите използвайте остър нож и избягвайте образуването на ръбчета и неравности.


Свиването на всяка тръба извършвайте, както е посочено в инструкцията.

Убедете се, че тръбата се е свила добре по окръжността на кабела, преди да продължите свиването надлъжно.

Тръбата трябва да се свие гладко, без нагърчвания и профилът на вътрешните елементи да личи добре.

Информацията, съдържаща се в тази инструкция е предназначена да опише точния метод на монтаж на това изделие. Поради това, че Tyco Electronics няма възможност да контролира полевите или други условия на монтаж, монтьорът трябва да прилага собствения си опит, когато инсталира този продукт. Tyco Electronics не носи отговорност в случаи на повреда, възникнала в следствие на неправилен монтаж.
Raychem е запазена марка на Tyco Electronics.

ВАЖНО С
ОРИГИНАЛ




Подготовка на кабела


А. Кабел с екран от телове

Таблица 1

Тип POLT-	L	L
	закрито [mm]	открито [mm]
12	240	240
17,5	240	280
24	280	380
36	380	440
42	440	500



Отстранете обвивката по размера L (Таблица 1).
Почистете края на обвивката на 100 mm.
Навийте червената херметизираща лента върху края на обвивката.






Огънете телове към обвивката и ги положете без кръстосване върху червената лента.
Превържете ги с бандаж от тел на 60 mm от края на обвивката.
Оплетете телове в заземително жило.

Отстранете полупроводимия екран до 40 mm от обвивката. Повърхността на изолацията да е абсолютно чиста от проводими частици. Загладете неравностите. **Забележка:** Не наранявайте изолацията!

Отрежете изолацията по размера K от схемата.
а. Пресови обувки
Размерът K да не надвишава 110 mm.
Монтирайте обувката.
б. Винтови обувки
Монтирайте обувката. Натягвайте двата болта равномерно до откъсване на главите им.

Около края на полупроводимия екран навийте лента така, че да покриете 20 mm от екрана и 10 mm от изолацията.
Разпъвайте лентата до около половината от първоначалната и ширина, като се стремите да получите тънък и фин ръб върху изолацията.




Подготовка на кабела


В. Кабел с екран от ленти

Таблица 2

Тип POLT-	L	
	закрито [mm]	открито [mm]
12	250	250
17.5	250	290
24	290	390
36	390	450
42	450	510



Отстранете обвивката по размера L (Таблица 2).
Отстранете металния екран до 20 mm обвивката.
Почистете обвивката на 100 mm.
Навийте червената херметизираща лента върху края на обвивката.



Фиксирайте заземителното въже към металния екран чрез запояване или друг приет метод.
Водната бариера да легне върху червената лента.
С тел фиксирайте заземителното жило към обвивката непосредствено под червената лента.





Отстранете полупроводимия екран до 60 mm от обвивката.
Повърхността на изоляцията да е абсолютно чиста от проводими частици. Загладете неравностите.
Забележка: Не наранявайте изоляцията!

Отрежете изоляцията по размера K от схемата.


а. Пресови обувки
Размерът K да не надвишава 110 mm.

Монтирайте обувката.
б. Винтови обувки
Монтирайте обувката. Натягвайте двата болта равномерно до откъсване на главите им.

Около края на полупроводимия екран навийте лента така, че да покриете 20 mm от екрана и 10 mm от изоляцията.
Разпъвайте лентата до около половината от първоначалната и ширина, като се стремите да получите тънък и фин ръб върху изоляцията.




Изработване на главата




Уплътняване на кабелната обувка:
Използвайте червена лента и херметизирайте допълнително кабелната обувка при следните напрежение/сечение.

12kV:	10 - 25mm ²
17,5kV:	16 - 25mm ²
24 kV:	25 mm ²
36kV:	35 - 50 mm ²
42kV:	35 - 50 mm ²



Подгрейте кабелната обувка и напъхайте тръбата до бандажа от тел.






Започнете свиването на тръбата върху края на полупроводимия екран. Продължете свиването към кабелната обувка и накрая - към кабела.
Цифрите на схемата показват последователността на свиване.


Кабелната глава за монтаж на закрито е готова

Забележка: След монтаж на главата върху шината е желателно главата да се нагрее допълнително до изтичането на зелена маса от вътрешността.
Оставете я да изстине, преди да я подложите на механически стрес.


За монтаж на открито:

Свийте стрехичките по размерите от таблицата на Стр.6.
Започнете свиването от най-долната стрехичка.







Брой стрехички на жило		
kV	закрито	открито
12	0	1
17.5	0	3
24	0	3
36	0	4
42	0	4



Минимален радиус на огъване и отстояния




Min. отстояния	Max. Напрежение в kV				
	12	17,5	24	36	42
a Въздушни	По местните спецификации				
b Ф/Ф и Ф/земля в mm	16	20	25	35	45
d Между стрехичките в mm	10	15	20	25	35
r (min. Радиус на огъване) = 15 x D					

Молим, отстранете всички отпадъци в съответствие с екологичните и санитарни норми




**ВАРНО С
ОРИГИНАЛ**



- Modular size for 10x38, 14x51 and 22x58mm fuses
- Finger safe - IP20 IEC degree of protection against accidental contact with live parts and with sealable cover for operators' safety
- Version with status indicator to quickly determine if the fuse is still operative or needs to be replaced
- UL and CSA certified versions.

	Sec. - PAGE
Fuse holders	
AC fuse holders.....	12 - 2
DC fuse holders for photovoltaic applications.....	12 - 3
Fuses for photovoltaic applications	12 - 3
Accessories	12 - 3
Dimensions	12 - 4
Wiring diagrams	12 - 4
Technical characteristics	12 - 5


moduLo



ВАРНО С
ДИСТРИБУЦИЯ

Lovato
electric


CIRCUIT PROTECTION AND ISOLATION



Page 12:2

AC FUSE HOLDERS


- Version without indicator: 1P, 1P+N, 2P, 3P, 3P+N
- Version with indicator: 1P
- For fuses 10x38, 14x51 and 22x68mm IEC class gG or aM.
- Rated current: 32A, 50A, 125A
- Rated voltage: 690VAC.



Page 12:2

AC FUSE HOLDERS CLASS CC FOR NORTH AMERICAN MARKET

- Version without indicator: 1P, 2P, 3P
- Version with indicator: 1P
- For 10x38mm UL/CSA class CC fuses
- Rated current: 30A
- Rated voltage: 600VAC.



Page 12:3

DC FUSE HOLDERS FOR PHOTOVOLTAIC APPLICATIONS


- Version without indicator: 1P, 2P
- Version with indicator: 1P, 2P
- For 10x38mm IEC class gPV fuses
- Rated current: 32A
- Rated voltage: 1000VDC
- IEC utilisation category: DC20B.



Page 12:3

DC FUSES FOR PHOTOVOLTAIC APPLICATIONS

- 10x38mm, IEC class gPV
- Rated current: 20A
- Rated voltage: 1000VDC.






**BANKO
OPTIKA**

Fuse holders AC fuse holders



Fuse holders UL Recognized and CSA certified



Order code	Pole arrangement	Status indicator	DIN size	Qty. per pkg.	Wt. (kg)
------------	------------------	------------------	----------	---------------	----------

For 10x38mm fuses.
32A rated current at 690VAC.

FB01 A 1P	1P	—	1	12	0.066
FB01 A 1PL	1P	YES	1	12	0.065
FB01 A 1N0	1P+N	—	1	12	0.062
FB01 A 1N	1P+N	—	2	6	0.134
FB01 A 2P	2P	—	2	6	0.132
FB01 A 3P	3P	—	3	4	0.188
FB01 A 3N	3P+N	—	4	3	0.260

For 14x61mm fuses.
50A rated current at 690VAC.

FB02 A 1P	1P	—	1	12	0.113
FB02 A 1PL	1P	YES	1	12	0.114
FB02 A 1N	1P+N	—	2	6	0.237
FB02 A 2P	2P	—	2	6	0.224
FB02 A 3P	3P	—	3	4	0.335
FB02 A 3N	3P+N	—	4	3	0.460

For 22x68mm fuses.
125A rated current at 690VAC.

FB03 A 1P	1P	—	1	12	0.167
FB03 A 1PL	1P	YES	1	12	0.167
FB03 A 1N	1P+N	—	2	6	0.364
FB03 A 2P	2P	—	2	6	0.334
FB03 A 3P	3P	—	3	4	0.500
FB03 A 3N	3P+N	—	4	3	0.720

⊖ Not certified.

Operational characteristics

- IEC rated voltage U_e: 690VAC
- 690VAC (FB01 A 1M excluded)
- 400VAC (FB01 A 1M only)
- IEC rated current I_e:
 - FB01 A: 32A
 - FB02 A: 50A
 - FB03 A: 125A
- IEC utilisation category:
 - FB01 A: AC22B 500V, AC21B 690V (except FB03 A 1M: AC22B 400V)
 - FB02 A: AC22B 500V, AC21B 690V
 - FB03 A: AC21B 690V
- Suitable for IEC fuse class: gg and aM
- IEC degree of protection: IP20

Certifications and compliance

Certifications obtained:


Type	UL Recognized USA (File E343395)	CSA certified (File 252040 class 6225)	UL Recognized USA and Canada (File E343395)
FB01 A 1P	●	●	●
FB01 A 1PL	●	●	●
FB01 A 1N	●	●	●
FB02 A	●	●	●
FB03 A	●	●	●

● Certification obtained

UL Recognized: Products having this type of marking are intended for use as components of complete workshop-assembled equipment.

Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3, UL 4248-1, UL 4248-4, CSA C22.2 n°4248.1, CSA C22.2 n°4248.4

Fuse holders



Order code	Pole arrangement	Status indicator	DIN size	Qty. per pkg.	Wt. (kg)
------------	------------------	------------------	----------	---------------	----------

For 10x38mm fuses.
32A rated current at 690VAC.

FB01 B 1P	1P	—	1	12	0.062
FB01 B 1PL	1P	YES	1	12	0.064
FB01 B 1N	1P+N	—	2	6	0.127
FB01 B 2P	2P	—	2	6	0.128
FB01 B 3P	3P	—	3	4	0.185
FB01 B 3N	3P+N	—	4	3	0.247


Operational characteristics

- IEC rated voltage U_e: 690VAC
- IEC rated current I_e: 32A
- IEC utilisation category: AC22B 500V, AC21B 690V
- Suitable for IEC fuse class: gg and aM
- IEC degree of protection: IP20

Reference standards

Compliant with standards: IEC/EN 60947-1, IEC/EN 60947-3, IEC/EN 60269-1, IEC/EN 60269-2

Fuse holders UL Listed and CSA certified for class CC fuses for North American market



Order code	Pole arrangement	Status indicator	DIN size	Qty. per pkg.	Wt. (kg)
------------	------------------	------------------	----------	---------------	----------

For 10x38mm fuses.
30A rated current at 600VAC.

FB01 C 1P	1P	—	1	12	0.070
FB01 C 1PL	1P	YES	1	12	0.072
FB01 C 2P	2P	—	2	6	0.140
FB01 C 3P	3P	—	3	4	0.210

NOTE: UL Listed and CSA certified as "Fuseholders, Cartridge Fuse" for use with Class CC fuses. Interrupting rating 200,000 Amps rms symmetrical. Voltage rating 600V. Current rating 30A.

Operational characteristics

- IEC rated voltage U_e: 600VAC
- IEC rated current I_e: 30A
- IEC utilisation category: AC22B 500V, AC21B 690V
- Suitable for UL/CSA fuse class: CC
- IEC degree of protection: IP20

Certifications and compliance

Certifications obtained: UL Listed (File E343395) and CSA certified (File 252040 class 6225)

Compliant with standards: IEC/EN 60269-1, IEC/EN 60947-1, IEC/EN 60947-3, UL 4248-1, UL 4248-4, CSA C22.2 n°4248.1, CSA C22.2 n°4248.4




Fuse holders

DC fuse holders for photovoltaic applications.

Accessories

Fuse holders for photovoltaic applications



FB01 D... FB01 D 1PL



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt. [kg]
			n°	n°	

For 10x38mm fuses.
32A rated current at 1000VDC.

FB01 D 1P	1P	—	1	12	0.064
FB01 D 1PL	1P	YES	1	12	0.065
FB01 D 2P	2P	—	2	6	0.127
FB01 D 2PL	2P	YES	2	6	0.130

Operational characteristics
IEC rated voltage U_e: 1000VDC
IEC rated current I_e: 32A
IEC utilisation category: DC20B 1000VDC
Suitable for IEC fuse class: gPV
IEC degree of protection: IP20

Reference standards
Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3

Fuses for photovoltaic applications



FE01 D...



Order code	Rated current I _n [A]	Qty per pkg	Wt. [kg]
		n°	

For 10x38mm fuses.
30kA breaking capacity at 1000VDC.

FE01 D 00200	2	10	0.008
FE01 D 00400	4	10	0.008
FE01 D 00600	6	10	0.008
FE01 D 00800	8	10	0.008
FE01 D 01000	10	10	0.008
FE01 D 01200	12	10	0.008
FE01 D 01600	16	10	0.008
FE01 D 02000	20	10	0.008

Operational characteristics
IEC rated voltage U_e: 1000VDC
IEC rated current I_e: 2-20A
IEC fuse class: gPV

Reference standards
Compliant with standards: IEC/EN 60269-6

Accessories



FBX 00 FBX 01 FBX 02



Order code	Description	Qty per pkg	Wt. [kg]
		n°	


FBX 000	Coupling clip for 10x38, 14x51 and 22x58mm sizes	100	0.003
FBX 010	Coupling pin for 10x38mm size	100	0.005
FBX 02	Coupling pin for 14x51 and 22x58mm sizes	100	0.008

For FB01 A... and FB01 B... types.

FBX 05	Three-phase connection busbar, for 57 modules in total, 1m/3.3ft long	10	0.465
FBX 07	One-pole terminal for 25mm ² max conductor	25	0.010
FBX 08	One-pole terminal for 50mm ² max conductor	25	0.020
FBX 13	End cap for FBX05 busbar	50	0.001

⊕ Not suitable for FB01 B1N, FB01 B2P, FB01 B3P and FB01 B3N types.

General and operational characteristics
THREE-PHASE BUSBAR:
Central point of power supply: 130A max
Side point of power supply: 80A max
Pitch: 18mm/0.7in
Busbar section: 10mm²
Number of modules/poles: 57
For paralleling connection
Length (standard supplied): 1m/3.3ft which can be cut in shorter sections



FBX 05




FBX 07 FBX 08



FBX 13

Fuse holder assembly in multiple pole configuration



⊕ Not suitable for FB01 B1N, FB01 B2P, FB01 B3P and FB01 B3N types.

BAPPO C. S.p.A. - Via... - 1213


Fuse holders

Dimensions [mm (in)]




FUSE HOLDERS


FB01 A... FB01 B... FB01 C... FB01 D...



FB02 A...




FB03 A...




12

FUSES

FE01 D 0...



Wiring diagrams



ВАРТО С
ОПШНА



Fuse holders


Technical characteristics

TYPE	FB01 A...	FB01 B...	FB02 A...	FB03 A...	FB01 C...	FB01 D...
Range	AC				Class CC (AC)	DC
IEC maximum rated current I _n	32A		50A	125A	30A	32A
IEC maximum rated voltage I _n	690VAC; 400VAC Ⓢ	690VAC			600VAC	1000VDC
IEC utilisation category	AC22B 500V; AC21B 690V; AC22B 400V Ⓢ			AC21B 690V	AC22B 500V; AC21B 690V	DC20B 1000VDC
Maximum power dissipation	3W		5W	9.5W	3W	4W
Derating factor of current I _n for different ambient temperatures	20°C	1				
	30°C	0.95				
	40°C	0.9				
	50°C	0.8				
	60°C	0.7				
	70°C	0.5				
Derating factor of current I _n for side-by-side fuse holders - n° poles	1-4	1				
	5-6	0.8				
	7-9	0.7				
	≥10	0.6				
Voltage for status indicator	120...690VAC		230...690VAC		120...600VAC	350...1000VDC
CONNECTIONS						
Maximum tightening torque	2.5Nm; 2Hm Ⓢ / 22lbin		3Nm / 26lbin	4Nm / 35lbin	2.5Nm / 22lbin	
Maximum conductor cross section	flexible/stranded	1x16mm ² ; 1-16mm ² Ⓢ / 8AWG	1x25mm ² / 6AWG	1x35mm ² / 2AWG	1x16mm ² / 8AWG	1x16mm ² / 6AWG
	rigid/solid	1x25mm ² ; 1-10mm ² Ⓢ / 8AWG	1x35mm ² / 8AWG	1x50mm ² / 1AWG	1x25mm ² / 10AWG	1x25mm ² / 4AWG
AMBIENT CONDITIONS						
Operating temperature	-20...+70°C					
Storage temperature	-40...+80°C					
Maximum altitude	3,000m					
Operation position	Any					
Fixing	On 35mm DIN rail (IEC/EN 60715)					
Ⓢ Values valid only for FB01 A 1M type.						

TECHNICAL CHARACTERISTICS FOR FE01 D... FUSES

TYPE	Rated current [A]	Power consumption at 0.7 I _n [W]	Power consumption at I _n [W]	Prearcing I ² t [A ² s]	Total I ² t at 1000VDC [A ² s]
FE01 D 00200	2	0.62	1.54	1.78	6.5
FE01 D 00400	4	0.73	1.84	3	11
FE01 D 00600	6	0.96	2.4	8.5	32
FE01 D 00800	8	1.02	2.55	25	93
FE01 D 01000	10	1.03	2.58	11	52
FE01 D 01200	12	1.04	2.6	25	116
FE01 D 01600	16	1.08	2.7	33	152
FE01 D 02000	20	1.16	2.9	85	390

TIME-CURRENT CHARACTERISTICS FOR FE01 D... FUSES



ВЕРИМО
СЕРТИФИКАТ





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

Описание на типа

за клемен блок с 3 еднополюсни предпазител разединители с цилиндрични
стояеми предпазител

Наименованието на клемния блок е ИК7ТКЗР

Клемния блок е съставен от 7бр. разединяеми клеми тип URTK/S и комплектован с допълнителни аксесоари към тях, 3 броя еднополюсни предпазител разединители тип FB01B и 3 броя цилиндрични стояеми предпазител 10x38 4A, съгласно изискванията на ЧЕЗ България.

Разединяемите клеми URTK/S и техните аксесоари са произведени от Phoenix Contact GmbH и са със страна на произход Германия.


Предпазител разединителите са произведени от Lovato Electric и са със страна на произход Италия

Клемите, аксесоарите им, предпазител разединителите и стояемите предпазител се произвеждат в клемен блок съгласно изискванията на ЧЕЗ България.

Подпис и печат



ВАЖНО С
ОРИГИНАЛ



СВЕТЛОС
ОПТИКА

ВИВ Изоматик ООД
1600 София, ул. "Пирин" №40А
Тел. 02 958 63 40, 958 63 44, 958 31 11, факс 958 22 70

ОБЕКТИВ/измервателен Клеморед ЧЕЗ

ЧЕРТИ	Лист №01 1/ 1	СЪГЛАСУВАЛИ:
едвак ПТ	МОДАСИ -	
		ВЪЗЛОЖИТЕЛ/
		ЦЕНТРАЛ/
		Р-1 фирма Инж. Вл. Дасаров



LOVATO ELECTRIC S.P.A.
 Via Don E. Mazza, 12
 24020 Gorle (BG) Italy
 Tel: +39 035 4282111
 Fax (National) +39 0354282200
 Fax (International) +39 0354282400
 E-mail: info@LovatoElectric.com
 VAT ID No. IT 0192130016477

Questa dichiarazione è conforme alla Norma Europea EN45014 "Criteri generali del fornitore". Le basi per tali criteri sono documenti internazionali ed in particolare la Guida ISO/IEC 22 "Information on manufacture's declaration of conformity with standards or other technical specifications"

This declaration of conformity is in compliance with the European Standard EN 45014 "General criteria for supplier's declaration of conformity". The basis for the criteria has been found in international documentation, particularly in: ISO/IEC Guide 22 "Information on manufacture's declaration of conformity with standards or other technical specifications"

DICHIARAZIONE DI CONFORMITÀ
DECLARATION OF CONFORMITY

Noi (denominazione del fornitore) **LOVATO ELECTRIC S.p.A.**
 We (supplier's name)

(indirizzo) **Via Don E. Mazza, 12 - 24020 Gorle - Bergamo - ITALY**
 (address)

dichiariamo sotto la nostra esclusiva responsabilità che i prodotti
 declare under our sole responsibility that the products

Portafusibili **FB..**
 Fuseholders

(nome, tipo o modello, lotto o numero di serie, possibilmente l'origine e la quantità)
 (name, type or model, batch or serial number, possibility sources and number of items)

sono conformi alle seguenti direttive
 are in conformity with the following directives

Direttiva Bassa Tensione nr.2006/95/CE
 Low Voltage Directive no.2006/95/EC

Direttiva Compatibilità Elettromagnetica nr.2004/108/CE
 Electromagnetic Compatibility Directive no.2004/108/EC

Questo è documentato dalla conformità alle norme
 This is documented by the conformity with the following standards

EN 60269-1

(Titolo e/o numero e data di pubblicazione della norma o di altri documenti normativi)
 (Title and for number and date of issue of the standard or other normative documents)

Revisione:
 Revision

Gorle, 04/03/2011
 (luogo e data)
 (place and data of issue)

Perani

Ing. D. Perani Product Manager

(Nome e firma della persona autorizzata)
 (Name and signature of authorized person)

**BAPPO C
 OPTIMIZIA**



DEVICE UNDER TEST..... Fuse holder *FB01B* types

MANUFACTURER..... Lovato Electric S.p.A.

TYPE OF TEST..... Temperature rise test on FB01B fuse holders

DATE OF DEVICE RECEIPT..... 27/04/2011

START / END TESTING 29/04/2011 – 13/05/2011

SAMPLES STORING..... Eliminated / returned to customer Storage :

INDEX.....	1. PURPOSE OF TESTING.....	2
	2. TEST SAMPLES.....	2
	3. TEST METHOD.....	2
	4. TEST PROCEDURES.....	2
	5. TEST RESULTS	3
	6. TEST EQUIPMENT	5
	7. REMARKS & ANALYS.....	5
	8. ANNEX.....	6

ISSUE 16/05/2011

COMPILED STAFF LPR

APPROVED RESP. LPR

The test results are related only to the exemplary tested and listed under the "test samples".

OPERA
C



1. PURPOSE OF TESTING

Requested test (according to the customer specification):
Temperature rise at 690V – 32A on FB01B fuse holders

Test purpose:
"Verify the good function of FB01B fuse holders."

Test target:
Pass the test.

2. TEST SAMPLES

- N. 1 FB01B1P fuse holder - 32A (10 x 38 mm), batch production number ...¹
- N. 1 FB01B2P fuse holder - 32A (10 x 38 mm), batch production number ...¹
- N. 1 FB01B3P fuse holder - 32A (10 X 38 mm), batch production number ...¹

3. TEST METHOD

IEC 60947-3 (2008-08) Ed. 3.0 + IEC 60947-1 Ed. 5.1 (2011-03)
Temperature rise (§ 8.3.3.1)

4. TEST PROCEDURES

Temperature rise..... Test instruction LPR 051-1, rev. 4, dated 11/10/2010.

¹ not available
¹ not available
¹ not available

The test results are related only to the exemplary tested and listed under the test samples.



КНИИ
ЭЛЕКТРОТЕХНИЧЕСКОГО
СЕКТОРА

5. TEST RESULTS

5.1 TEMPERATURE RISE

5.1.1 WITH LEGRAND FUSE 32 A gG 400 V

Sample under test.....N. 1 FB01B1P - 32A
N. 1 FB01B2P - 32A
N. 1 FB01B3P - 32A

Test conditions

Ambient temperature.....21 °C
Relative humidity.....46 %
Installation.....In vertical way, on DIN RAIL 35mm

Data sheet fusible used:

- SupplerLegrand
- Codecod. 133 32

Test parameters

Wiring of the main circuit

- cables section / length6,0 mm² / 1,0 m
- screws tightening nominal torque2,0 + 2,5 N.m
- screws applied tightening torque2,0 N.m

Supply of the main circuit

- rated current.....I_{th} = 25 - 32 A
- test current.....I = 32 A
- supply frequency.....50 Hz

Test results

See next page.

The test results are related only to the exemplary tested and listed under the test sample



Stamp: BIP 110516-2

Temperature rise main circuit

	[K]			Standard limit EN60947-1 tab. 2
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Terminal T1	43	54	57	65
Terminal T1	39	51	52	65
Terminal T2	-	55	61	65
Terminal T2	-	49	58	65
Terminal T3	-	-	57	65
Terminal T3	-	-	50	65
Note:	Silver plated-brass terminal			

Temperature rise for accessible parts

	[K]			Standard limit EN60947-1 tab. 3
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Line side	14	24	29	40
Load side	10	19	21	40
Left side	24	30	32	40
Right side	22	30	31	40
On front	18	24	29	40
Lever	9	16	17	40




BSPHO C
OPHITHA


The test results are related only to the exemplary tested and listed under the "test sample"

8. ANNEX

Picture 1: Temperature rise – test setup



Picture 1a: Temperature rise – test setup



The test results are related only to the exemplary tested and listed under the "test sample"

B.P.O.C
OPINATA



Picture 2: Catalogue Legrand fuses

legrand

Fusibili cilindrici


Informazioni tecniche, curva e quote (p. 120)

Tipo "aM"		
Risponderà alla norma IEC EN 60269-1		
Approvazione Bureau Veritas		
Ingresso (A)	Ingresso (kA)	Isola (kA)
8,5 x 31,5 mm		
1	250	6
2		
4		
6		
10		
8,5 x 31,5 mm		
1	300	30
2		
4		
6		
8		
10		
12		
16		
18		
20		
10,3 x 38 mm		
0,25	500	100
0,50		
1		
2		
4		
6		
8		
10		
12		
16		
20		
25		
14 x 51 mm		
2	600	100
4		
6		
10		
16		
20		
25		
32		
40		
60		
22 x 58 mm		
10	600	100
16		
20		
25		
32		
40		
50		
63		
80		
100		
125		
Neutri		
8,5 x 31,5		
10,3 x 38		
14 x 51		
22 x 58		

(1) Tipo g

(1) Tipo con innalzato

The test results are related only to the exemplary tested and listed under the "test samples"





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
~~ЦСС~~ Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

Списък на проведените изпитвания на клемен блок с клеми за медни проводници
от проходен тип 1P, 3P и 3P+N

1. Изпитване покачване на температура.

13.01.2016г.

Подпис и печат



CERTIFICATE

KEMA No. 97-4907/10

Issued to:

Applicant:

Phoenix Contact GmbH & Co.

Flachmarktstrasse 3-28

BLOMBERG, Germany

Manufacturer/Importer:

Phoenix Contact GmbH & Co.

Flachmarktstrasse 3-28

BLOMBERG, Germany

Product: terminal blocks

Trade name: PHOENIX CONTACT

Types/models: URTK/S-BEN BU, URTK/S-BEN, URTK/S, URTK/SP,
USLKG 10, USLKG 6N

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standards EN 60947-7-1:1991, EN 60947-7-2:1995
- an inspection of the production location according to CCA Group Operational Document CCA 204
- a certification agreement with the number 900469

KEMA hereby grants the right to use the KEMA certification mark



The KEMA KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA KEUR certification agreement and under the conditions of the KEMA KEUR certification agreement.

This certificate is issued on August 6, 1999

G.M. Boschloo
Certification Manager

Integral publication of this certificate is allowed



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

product : terminal blocks
 trade name : PHOENIX CONTACT
 types : URTK/S-BEN BU, URTK/S-BEN, URTK/S,
 URTK/SP, USLKG 10, USLKG 6N
 material : thermoplastic material
 mounting : top hat rail 35 mm (EN 50022) and G-profile
 rail 32 mm (EN 50035)

Additional information

Markings

Trademark, type designation, rated connection capacity and rated insulation voltage are indented in the insulation material.

Product data – type USLKG 6N

rated connection capacity : 6 mm²
 connectable conductors : one conductor
 0,2 - 10 mm² solid
 0,2 - 6 mm² flexible without ferrule
 0,25 - 6 mm² flexible with ferrule
 two conductors
 0,2 - 2,5 mm² solid
 0,2 - 2,5 mm² flexible without ferrule
 0,25 - 1,5 mm² flexible with ferrule
 description : protective conductor terminal block with 2
 screw-type clamping units, 1-pole

Product data – type URTK/S

rated voltage : 400 V
 rated connection capacity : 6 mm²
 connectable conductors : one conductor
 0,5 - 10 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 10 mm² flexible with ferrule
 two conductors
 0,5 - 2,5 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 4 mm² flexible with ferrule
 rated impulse withstand voltage : 6 kV
 description : disconnect terminal block with 2 screw-type
 clamping units, 1-pole

N.V. KEMA
 Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
 P.O. Box 9035, 6800 ET ARNHEM, The Netherlands
 Telephone +31 26 3562850, Telefax +31 26 3514922

BTPI/C
 OPHEM



Product data – type USLKG 10

rated connection capacity : 6 mm²
connectable conductors : one conductor
0,5 - 10 mm² solid
0,5 - 6 mm² flexible without ferrule
0,5 - 6 mm² flexible with ferrule
two conductors
0,5 - 2,5 mm² solid
0,5 - 2,5 mm² flexible without ferrule
0,5 - 2,5 mm² flexible with ferrule
description : protective conductor terminal block with 2
screw-type clamping units, 1-pole

Product data – type URTK/S-BEN

rated voltage : 500 V
rated connection capacity : 6 mm²
connectable conductors : one conductor
0,5 - 10 mm² solid
0,5 - 6 mm² flexible without ferrule
0,5 - 10 mm² flexible with ferrule
two conductors
0,5 - 2,5 mm² solid
0,5 - 6 mm² flexible without ferrule
0,5 - 4 mm² flexible with ferrule
rated impulse withstand voltage : 6 kV
description : disconnect terminal block with 2 screw-type
clamping units, 1-pole

Product data – type URTK/S-BEN BU

rated voltage : 500 V
rated connection capacity : 6 mm²
connectable conductors : one conductor
0,5 - 10 mm² solid
0,5 - 6 mm² flexible without ferrule
0,5 - 10 mm² flexible with ferrule
two conductors
0,5 - 2,5 mm² solid
0,5 - 6 mm² flexible without ferrule
0,5 - 4 mm² flexible with ferrule
rated impulse withstand voltage : 6 kV
description : disconnect terminal block with 2 screw-type
clamping units, 1-pole

N.V. KEMA

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9035, 6800 ET ARNHEM, The Netherlands
Telephone +31 26 3562860, Telefax +31 26 3514922

ВНИОС
ОПТИКА



Product data – type URTK/SP

rated voltage : 500 V
rated connection capacity : 6 mm²
connectable conductors : one conductor
0,5 - 10 mm² solid
0,5 - 6 mm² flexible without ferrule
0,5 - 6 mm² flexible with ferrule
two conductors
0,5 - 2,5 mm² solid
0,5 - 4 mm² flexible without ferrule
0,5 - 2,5 mm² flexible with ferrule
rated impulse withstand voltage : 6 kV
description : disconnect terminal block with 2 screw-type
clamping units, 1-pole

TESTS**Test requirements**

EN 60947-7-1:1991 + C:1997-06 + A11:1997
EN 60947-7-2:1995 + C:1996-01

Test results

The test results are laid down in KEMA test file 97.4117.13.

Conclusion

The examination proved that all test requirements were met.

Tested by : H.L. Schendstok

Checked by : L.J.W. van Megen

FACTORY-LOCATION(S)

Phoenix Contact GmbH & Co.
Flachmarktstrasse 8-28, BLOMBERG, Germany

N.V. KEMA
Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9036, 6800 ET ARNHEM, The Netherlands
Telephone +31 26 3582850, Telefax +31 26 3514922



ВАРИО С
ОПТИКА

Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: **30-03-2010** to **01-03-2014**

Replaces annex dated: **30-06-2009**

Premises: **n.a.**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
LF 0 0	DC/LF Quantities			
LF 1 0	DC Voltage			
	Standard cells		3 μ V	
	Up to 1 mV		0,4 μ V	
	1 mV to 10 mV		$3 \cdot 10^{-4} \cdot U$	
	10 mV to 100 mV		$3 \cdot 10^{-5} \cdot U$	
	100 mV to 10 V		$5 \cdot 10^{-6} \cdot U$	
	10 V to 100 V		$1 \cdot 10^{-5} \cdot U$	
	100 V to 1100 V		$2 \cdot 10^{-5} \cdot U$	
	Zener Reference Standards			
	1 V and 1,018 V		3 μ V	
	10 V		20 μ V	
	High Voltage			Measuring
	1 kV to 6 kV		$2 \cdot 10^{-3} \cdot U$	
LF 2 0	DC Current			
	10 μ A to 3 A		$2 \cdot 10^{-5} \cdot I$	
	3 A to 10 A		$2,5 \cdot 10^{-5} \cdot I$	
	10 A to 20 A		$6 \cdot 10^{-5} \cdot I$	

This annex has been approved by:



J.G. van der Poel
Chief Executive


Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: **30-03-2010** to **01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
	20 A to 100 A		$1 \cdot 10^{-4} \cdot I$	
LF 3 1	AC Voltage			
	60 mV to 1000 V	40 Hz to 20 kHz	$2 \cdot 10^{-4} \cdot U$	
	60 mV to 1000 V	20 kHz to 50 kHz	$3 \cdot 10^{-4} \cdot U$	
	60 mV to 220 V	20 kHz to 50 kHz 50 kHz to 100 kHz	$4 \cdot 10^{-4} \cdot U$	
	220 V to 1000 V	50 kHz to 100 kHz	$4 \cdot 10^{-4} \cdot U$	
	220 V to 1000 V	50 kHz to 100 kHz	$2 \cdot 10^{-3} \cdot U$	
	High Voltage			Measuring
	1 kV tot 6 kV	50 Hz	$2 \cdot 10^{-3} \cdot U$	
LF 3 2	AC Voltage Ratio (instrument transformers)			
	Primary: (10-600)V Secondary: (0,1-240)V	50 Hz and 60 Hz	$3 \cdot 10^{-5} \cdot U_{UH}/U_m$ and 90 μ rad	
LF 3 3	AC Current			
	0,1 mA to 300 mA	40 Hz to 5 kHz	$3 \cdot 10^{-4} \cdot I$	
	300 mA to 20 A	40 Hz to 1 kHz	$3 \cdot 10^{-4} \cdot I$	
	20 A to 50 A	40 Hz to 1 kHz	$6 \cdot 10^{-4} \cdot I$	
LF 4 2	AC Current Ratio			ambient temp. (23 \pm 2) °C
	(instrument transformers)	50 Hz and 60 Hz	$3 \cdot 10^{-5} \cdot I_{UH}/I_m$ and 90 μ rad	Measuring



OPDRACHT
OPDRACHT
Page 2 of 7


Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: **30-03-2010** to **01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
	Primary: 5 A to 6000 A Secondary: 1A or 5A			
LF 4 3	High Current 10 A to 6000 A	50 Hz, 60 Hz	$3 \cdot 10^{-4} \cdot I$	
LF 5 0	Power and Energy			10 mV to 1100 V, 10 μ A to 100 A
	Power			
	0,1 μ W to 1 μ W		$1 \cdot 10^{-4} \cdot P$	
	1 μ W to 1 kW		$5 \cdot 10^{-5} \cdot P$	
	1 kW tot 10 kW 10 kW tot 110 kW 3 W to 57,6 kW	50 Hz and 60 Hz	$1 \cdot 10^{-4} \cdot P$ $2 \cdot 10^{-4} \cdot P$ $\frac{3 \cdot 10^{-4}}{\cos \varphi} \cdot P$	on site to be performed at ambient temperature; voltage and current as mentioned above
	3 W to 2,9 MW	50 Hz and 60 Hz	$\frac{2 \cdot 10^{-4}}{\cos \varphi} \cdot P$	measuring 20 V to 1100 V 100 mA to 6000A $\cos \varphi = 0$ to 1
	Reactive Power (P_r) 6 var to 1,8 Mvar	50 Hz and 60 Hz	$\frac{5 \cdot 10^{-4}}{\sin \varphi} \cdot P_r$	60 V to 300 V 100 mA to 6000 A
	Electrical (reactive-) energy			see (reactive-) power and time
LF 5 1	Power Factor $\cos \varphi : 0$ to 1	40 Hz to 100 Hz	$\frac{2 \cdot 10^{-3}}{\cos \varphi} \cdot PF$	




Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: **30-03-2010** to **01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
LF 6	Impedance (DC/LF)			
LF 6 2	DC Resistance			Non-decadic values
	20 $\mu\Omega$ to 50 $\mu\Omega$		$3 \cdot 10^{-4} \cdot R$	
	50 $\mu\Omega$ to 100 $\mu\Omega$		$1 \cdot 10^{-4} \cdot R$	
	100 $\mu\Omega$ to 20 $k\Omega$		$1,2 \cdot 10^{-5} \cdot R$	
	1 $m\Omega$ to 10 $m\Omega$		$6,5 \cdot 10^{-6} \cdot R$	
	10 $m\Omega$ to 1000 $m\Omega$		$7 \cdot 10^{-6} \cdot R$	
	1 Ω to 10 $k\Omega$		$5 \cdot 10^{-6} \cdot R$	
	10 $k\Omega$ to 1 $M\Omega$		$1 \cdot 10^{-5} \cdot R$	
	1 $M\Omega$ to 10 $M\Omega$		$1,2 \cdot 10^{-5} \cdot R$	
	10 $M\Omega$ to 100 $M\Omega$		$3 \cdot 10^{-5} \cdot R$	
	100 $\mu\Omega$ to 10 $k\Omega$		$6 \cdot 10^{-6} \cdot R$	Decadic Values
LF 6 4	Capacitance			
	LF Capacitance			accuracy depends on dissipation factor at 1 kHz
	10 pF to 100 pF	100 Hz, 1 kHz, 10 kHz	$1 \cdot 10^{-3} \cdot C$	
	1 μF	50 Hz, 200 Hz, 1 kHz	$1 \cdot 10^{-3} \cdot C$	
LF 6 7	Inductance			
	1 mH to 10 mH	1 kHz, (400-1692)Hz	$1 \cdot 10^{-3} \cdot L$	
	100 mH	100 Hz, 1 kHz, 1,592 kHz	$1 \cdot 10^{-3} \cdot L$	
	1 H	100 Hz, 200 Hz, 400 Hz and 1 kHz	$1 \cdot 10^{-3} \cdot L$	
RF 0 0	RF Quantities			
RF 3 0	RF Power			
	- 9 dBm to +30 dBm	0,1 MHz to 4200 MHz	0,5 dB	Measuring: 50 ohm coaxial VSWR
	+30 dBm to +57 dBm	0,1 MHz to 500 MHz	0,6 dB	
	-60 dBm to -10 dBm	10 MHz to 10000 MHz	0,5 dB	



Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem


This annex is valid from: **30-03-2010** to **01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
	-80 dBm to -10 dBm	0,1 MHz to 2700 MHz	1,1 dB	source < 2 Generating: (0,09 - 3200) MHz
RF 5 0	Rise time (10% to 90%) 1 ns to 1 ms		$2 \cdot 10^{-2} \cdot \tau + 200$ ps	10 mV/div to 1 kV/div
TF 0 0	TIME and FREQUENCY			
TF2 1	Frequency	1 Hz to 1,2 GHz	$5 \cdot 10^{-10} \cdot f$	
TF 2 2	Time interval	1 μ s to ∞	$5 \cdot 10^{-10} \cdot f + 100$ ns	
TF 3 2	Hammonic Distortion			(1)
	< 0,1 %	20 Hz to 2,5 kHz	$3 \cdot 10^{-4}$	
	0,1 % to 1 %	20 Hz to 2,5 kHz	$1 \cdot 10^{-3}$	
	1 % to 10 %	20 Hz to 2,5 kHz	$3 \cdot 10^{-3}$	
	10 % to 30 %	20 Hz to 2,5 kHz	$1 \cdot 10^{-2}$	
	30 % to 100 %	20 Hz to 2,5 kHz	$3 \cdot 10^{-2}$	

Part II, Mechanical quantities and Temperature

Measured quantity, Instrument, Gauge	Range	Best measurement capabilities ($k=2$)	Remarks
PV 1 0	Pressure		(2)
	Relative Pressure		medium: air
	(-10 to 10) kPa	$3 \cdot 10^{-4} \cdot p_0 + 4$ Pa	medium: nitrogen
	(-98 to 100) kPa	$3 \cdot 10^{-4} \cdot p_0 + 5$ Pa	medium: nitrogen
	100 kPa to 10 MPa	$3 \cdot 10^{-4} \cdot p_0$	medium: oil
	(10 to 70) MPa	$3 \cdot 10^{-4} \cdot p_0$	




Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: **30-03-2010 to 01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
	Absolute Pressure	(80 to 110) kPa	$3 \cdot 10^{-4} \cdot p$	medium: air
		(2 to 200) kPa	$3 \cdot 10^{-4} \cdot p + 5 \text{ Pa}$	medium: nitrogen
		200 kPa to 10 MPa	$3 \cdot 10^{-4} \cdot p$	medium: nitrogen
		(10 to 70) MPa	$3 \cdot 10^{-4} \cdot p$	medium: oil
TE 00	TEMPERATURE, HUMIDITY AND THERMOPHYSICAL PROPERTIES			
TE 10	Resistance thermometers	-50 °C to 20 °C	0,02 K	
		20 °C to 50 °C	0,05 K	
		50 °C to 300 °C	0,05 K	
		300 °C to 550 °C	0,16 K	
		550 °C to 650 °C	0,50 K	
TE 30	Thermocouples	-50 °C to 20 °C	0,16 K	Including C.J. references
		20 °C to 50 °C	0,16 K	
		50 °C to 300 °C	0,16 K	
		300 °C to 550 °C	0,21 K	
		550 °C to 650 °C	0,6 K	
		650 °C to 1000 °C	1,6 K	
TE 40	Liquid-in-glass thermometers	-50 °C to 50 °C	0,02 K	
		20 °C to 50 °C	0,04 K	
		50 °C to 300 °C	0,02 K	
	Differential Temperature	-50 °C to 200 °C	0,05 K	$t_{\min} = -50 \text{ °C}$ $t_{\max} = 200 \text{ °C}$
TE 41	Self indicating thermometers			



Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: **30-03-2010 to 01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
	Dry Block Calibrators	-20 °C to 650 °C	$(8 \cdot 10^{-4} \cdot t_{90} + 0,06)$ K	
	Writing thermometers	15 °C to 50 °C	0,5 K	including C.J. references resolution 1 digit
	Digital thermometers	-50 °C to 20 °C	0,02 K	
		20 °C to 50 °C	0,05 K	
		50 °C to 300 °C	0,05 K	
		300 °C to 550 °C	0,16 K	
		550 °C to 630 °C	0,50 K	
		630 °C to 1000 °C	1,5 K	

Remarks:

The ambient temperature during calibration is, unless specified otherwise, for:

- LF measurements @ $(23 \pm 1)^\circ\text{C}$
- TF measurements @ $(23 \pm 1)^\circ\text{C}$
- Pressure measurements @ $(23 \pm 2)^\circ\text{C}$
- Temperature measurements @ $(23 \pm 2)^\circ\text{C}$

(1) The stated best measurement capabilities are based on the fundamental frequency of the input signal. If desired the distortion can be specified as a rang number of the harmonics.

(2) $p_e = p - p_{amb}$; p_e is the relative pressure, p_{amb} is the local air pressure, p is the absolute pressure.

The best measurement capability is the highest achievable accuracy for a given measuring value or measuring range, expressed as the total positive and negative measurement uncertainty.

The uncertainty is calculated according to EA-4/02 "Expression of the Uncertainty of Measurement in Calibration".

Calibrations are performed inside the laboratory, unless specified otherwise.

