


Test results (continued)

4.6.8 Partial discharge test at elevated and ambient temperatures (test 8)


Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C and elevated, resp. 95..100 °C
 Calibration of the test circuit by calibrator Output 10 pC

Measured PD values

Test arrangement			Prestress voltage (1 min)	Measuring voltage (1 min)	Measured PD value
No. of test object	Voltage applied to	Earthed	kV	kV	pC
					
Measured PD values at elevated temperature					
1	Conductor	Screen	29	25	< 5 ¹⁾
2	Conductor	Screen	29	25	< 5 ¹⁾
3	Conductor	Screen	29	25	< 2 ¹⁾
4	Conductor	Screen	29	25	< 2 ¹⁾
Measured PD values at ambient temperature					
1	Conductor	Screen	29	25	< 1.0 ¹⁾
2	Conductor	Screen	29	25	< 1.0 ^{1), 2), 3)}
3	Conductor	Screen	29	25	< 1.0 ^{1), 2), 3)}
4	Conductor	Screen	29	25	< 1.0 ^{1), 2), 3)}

Notes:

- ¹⁾ Two of the respective test lines were connected to form one closed conductor loop for heating the latter. Thus, two test lines were simultaneously tested. Providing separate test results for each of the test lines is not possible.
- ²⁾ Basic disturbance level at same value
- ³⁾ The test lines were separated for the PD measurement




01.01.2010
 12.01.2010
 13.01.2010
 14.01.2010
 15.01.2010
 16.01.2010
 17.01.2010
 18.01.2010
 19.01.2010
 20.01.2010
 21.01.2010
 22.01.2010
 23.01.2010
 24.01.2010
 25.01.2010
 26.01.2010
 27.01.2010
 28.01.2010
 29.01.2010
 30.01.2010
 31.01.2010

Test results (continued)

4.6.9 Impulse voltage test at ambient temperature (test 9)

Full wave: Front time $T_1 = 1.27 \mu s$
Virtual time to half value $T_2 = 53.0 \mu s$

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	Number of impulses/disruptive discharges
1	Conductor	Screen		
2	Conductor	Screen	+125	10/0
3	Conductor	Screen	-125	10/0
4	Conductor	Screen		

Notes:

All test lines were tested simultaneously.



BRUNNEN
BERLIN

Test results (continued)

4.6.10 AC voltage test (test 10)

Duration of test after having reached full voltage: 15 min

Test frequency: 50 Hz

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
1	Conductor	Screen	32	No disruptive discharge
2	Conductor	Screen		
3	Conductor	Screen		
4	Conductor	Screen		

Notes:

All test lines were tested simultaneously.

BRUNNEN
OPPELWALD
3 04/15/10



4.7 Assessment of the results of test sequence D1

• Test 1

In the DC voltage test at -76 kV/15 min, no disruptive discharge occurred on any of the four test objects.

• Test 2

In the 50-Hz AC voltage test at 57 kV/5 min, no disruptive discharge occurred on any of the four test objects.

• Test 3

In the partial discharge test at ambient temperature and at 50-Hz AC voltage of 25 kV, none of the four test objects exceeded the permissible maximum partial discharge value of 10 pC. The partial discharge value measured was not higher than 1.0 pC.

• Test 4

In the impulse voltage test at elevated temperature with 10 test impulses of 125-kV lightning impulse voltage 1.2/50 of each polarity, no disruptive discharge occurred on any of the four test objects.

• Test 5

All of the four test objects were subjected to 63 electrical heat cycles in air. In the simultaneous 50-Hz continuous AC voltage test at 32 kV, no disruptive discharge occurred on any of the four test objects.

• Test 6

All of the four test objects were subjected to 63 electrical heat cycles in water. No disruptive discharge occurred on any of the four test objects, when they were tested simultaneously in water and by 50-Hz continuous AC voltage of 32 kV.

• Test 7

After 5 complete operations of disconnection and connection, no visible damage was found on the contact

• Test 8

In the partial discharge test at elevated and ambient temperatures at 50-Hz AC voltage of 25 kV, none of the four test objects exceeded the permissible maximum partial discharge value of 10 pC. The partial discharge value measured was not higher than 5 pC.

IPB
GmbH
Prüfung
Bericht



TEST REPORT NO. 1213.1607.6950

SHEET 27

Assessment of the results of test sequence D1 (continued)

• Test 9

In the impulse voltage test at ambient temperature with 10 test impulses of 125-kV lightning impulse voltage 1.2/50 of each polarity, no disruptive discharge occurred on any of the four test objects.

• Test 10

In the 50-Hz AC voltage test at 32 kV/15 min, no disruptive discharge occurred on any of the four test objects.

All of the four test objects meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2 2006-2.

The tests of test sequence D1 have been PASSED.



ОТВЕДЕНО
ОТ ПРОВЕРКИ

5. Tests of test sequence D2

5.1 Test laboratory


High-voltage test laboratory, high-voltage hall 2 and
High-power test laboratory, high-current bay

5.2 Normative document

CENELEC Harmonization Document HD 629.1 S2: 2006-02
DIN VDE 0278-629.1 (VDE 0278 Teil 629-1): 2002-06
IEC 61442: 2005-04
DIN VDE 0278-442 (VDE 0278 Teil 442): 2006-01

5.3 Required test parameters

Test No.	Type of test	Required test parameters	
1	DC voltage test	Test voltage $6 \times U_0$: Duration of test: Polarity:	76 kV 15 min Negative
2	AC voltage test	Test voltage $4.5 \times U_0$: Test frequency: Duration of test:	57 kV 50 Hz 5 min
3	Thermal short-circuit test of the conductor	Short-circuit-conductor final temperature: Number of short-circuits:	250 °C 2
5	Disconnection/connection	Number of complete operations:	5
6	Impulse voltage test at ambient temperature	Front time: Virtual time to half value: Test voltage: Number of impulses: Polarity: Conductor temperature:	1.2 μ s 50 μ s 125 kV 10 impulses pos./neg. ϑ_0
7	AC voltage test	Test voltage $2.5 \times U_0$: Test frequency: Duration of test:	32 kV 50 Hz 15 min



1213.1607.6.950
 01.01.2007

5.5 Test and measuring circuits

5.5.1 DC voltage test (test 1)

See Sub-clause 4.5.1

5.5.2 AC voltage test (test 2)

See Sub-clause 4.5.2

5.5.3 Thermal short-circuit test of the conductor (test 3)

See following sheet

5.5.4 Disconnection/connection (test 5)

None

5.5.5 Impulse voltage test at ambient temperature (test 6)

See Sub-clause 4.5.4

5.5.6 AC voltage test (test 7)

See Sub-clause 4.5.2




2010.08.10
KAMTEX

Test and measuring circuits (continued)

Thermal short-circuit test (test 3)

Technical data of test circuits

Test requirement		Short-circuit tests
Test No.		207 2835 and 207 2837
Number of phases	(Test circuit)	3
Number of poles/phases	(Test object)	3
Power frequency	Hz	50
Power factor $\cos \varphi$		0.015
Earthing conditions	Generator / grid	Not earthed
	Short-circuit transformer	Earthed
	Short-circuit point	Not earthed




- | | | | |
|----|---------------------------|-------|---------------------|
| E | Power supply (grid) | TO | Test object |
| SI | Master breaker | I | Current measurement |
| Dr | Making switch | U | Voltage measurement |
| L | Current-limiting reactor | 1 - 3 | Measuring points |
| Tr | Short-circuit transformer | | |

Figure 7: Test and measuring circuit for the thermal short-circuit test of the conductor

Technical data of measuring circuits

Measuring point	Symbol	Measured quantity	Measuring sensor/device
1	i_{L1}	Current of conductor L1	Rogowski measuring device
2	i_{L2}	Current of conductor L2	Rogowski measuring device
3	i_{L3}	Current of conductor L3	Rogowski measuring device
Recording instrument: BE 256 transient recorder system			



БУДИМО
 ОФИЦИЈА


5.6 Test results

5.6.1 DC voltage test (test 1)


Polarity: Negative

Duration of test after having reached full voltage: 15 min

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	
5	Conductor	Screen	-76	No disruptive discharge
6	Conductor	Screen	-76	No disruptive discharge
7	Conductor	Screen	-76	No disruptive discharge

Notes: -



2013.1607.6.950
2013.1607.6.950

Test results (continued)

5.6.2 AC voltage test (test 2)

Duration of test after having reached full voltage: 5 min

Test frequency: 50 Hz

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
5	Conductor	Screen	57	No disruptive discharge
6	Conductor	Screen	57	No disruptive discharge
7	Conductor	Screen	57	No disruptive discharge

Notes: -



СЭРЖАА
БИЛГЭЭНИЙН
ТӨВ

Test results (continued)

5.6.3 Thermal short-circuit test of the conductor (test 3)

Condition of test object before test:	Prestressed by previous tests
Connection of the test object:	By 50-mm ² cable
Short-circuit point:	At the bushings
Ambient temperature:	16 °C

Test parameters:

Test No.		207 2835	207 2837	
Test voltage	V	455	455	
Peak short-circuit current	kA	L1	12.8	13.4
		L2	13.5	14.0
		L3	14.8	15.6
Symmetrical short-circuit current	kA	L1	8.93	9.02
		L2	8.86	8.91
		L3	9.32	9.09
	Average	9.04	9.01	
Duration of short-circuit	ms	1011	1011	
Joule Integral 10 ⁶	A ² s	L1	80.8	82.3
		L2	79.9	80.3
		L3	88.2	84.0
Symmetrical short-circuit current 1 s	kA	9.09	9.06	
Notes		-	2..Kt	
Evaluation		OK	OK	

Notes:

OK: The test object is able to carry the short-circuit current

Condition of test object after test:

The test objects did not show any externally visible changes or damage.



BRUNO
OPPENHEIM

TEST REPORT NO. 1213.1607.6950

SHEET 36

Test results (continued)

5.6.6 AC voltage test (test 7)

Duration of test after having reached full voltage: 15 min

Test frequency: 50 Hz

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
5	Conductor	Screen	32	No disruptive discharge
6	Conductor	Screen		
7	Conductor	Screen		

Notes:

All test lines were tested simultaneously.



[Handwritten signature]

**ВСТРОЕНО
ОПРЕДЕЛЕНА**

5.7 Assessment of the tests of test sequence D2

• Test 1

In the DC voltage test at -76 kV/15 min, no disruptive discharge occurred on any of the three test objects.

• Test 2

In the 50-Hz AC voltage test at 57 kV/5 min, no disruptive discharge occurred on any of the three test objects.

• Test 3

In the thermal short-circuit test of the conductor with a thermally equivalent current of 9.1 kA/1 s, no visible damage was detected on any of the three test objects.

• Test 5

After 5 complete operations of disconnection and connection, no visible damage was found on the contact.

• Test 6

In the impulse voltage test at ambient temperature with 10 test impulses of 125-kV lightning impulse voltage 1.2/50 of each polarity, no disruptive discharge occurred on any of the three test objects.

• Test 7

In the 50-Hz AC voltage test at 32 kV/15 min, no disruptive discharge occurred on any of the three test objects.

All of the three test objects meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2 2006-2.

The tests of test sequence D2 have been PASSED



IPB
BERLIN
OPFERSTRASSE 11
10585 BERLIN

6. Tests of test sequence D3

6.1 Test laboratory

High-voltage test laboratory, high-voltage hall 2

6.2 Normative document

CENELEC Harmonization Document HD 629.1 S2: 2006-02
 DIN VDE 0278-629.1 (VDE 0278 Teil 629-1): 2002-06
 IEC 61442: 2005-04
 DIN VDE 0278-442 (VDE 0278 Teil 442): 2006-01

6.3 Required test parameters

Test No.	Type of test	Required test parameters
14	Operating eye test	Axial force 1300 N, 1 min Torque 14 Nm Duration of test: 1 min
15	Partial discharge test at ambient temperature	Prestress voltage $2.25 \times U_0$: 29 kV Measuring voltage $2.00^{1)} \times U_0$: 25 kV Prestress duration: 1 min Measuring time: 1 min

Notes to the table of required test parameters:

- 1) CENELEC Harmonization Document HD 629.1 S2: 2006-2, Table 7, requires the partial discharge to be measured at a measuring voltage of $1.73 \times U_0$ or $2.00 \times U_0$ respectively. The measurement was done at $2 \times U_0$ because the standard of the cable used for the test requires a test voltage $> 1.73 \times U_0$.



PATENT
 OFFICE
 BERLIN

6.4 Test arrangement

The client arranged each of the cable connectors under test (test object) on a test line. The test objects were mounted on cable lines of approx. 1 m length and of N2XS(F)2Y-1x50 RM/16 mm²-12/20 kV type. To apply the test voltage, each of the test line had additionally been equipped with one auxiliary sealing end of EPKT type (manufacturer Tyco Electronics Raychem). All test voltages were applied to the core against the cable screen, which was connected to the test earth.

The tests did not start earlier than 24 hours after the installation of the accessories on the cable lines.

6.4.1 Operating eye test

Test arrangement to IEC 61442: 2005-04, Clause 19

6.4.2 Partial discharge test at ambient temperature

Test arrangement to IEC 61442: 2005-4, Clause 7, with the following simplifications:

Due to the short cable lengths, neither double impulse diagram nor terminating impedance or reflexion suppressor were used. The PD callibrator was connected in parallel to the test object only at the detector-remote end.



BRUNO C
OPREKATA

6.6 Test results

6.6.1 Operating eye test


The connector releases at an axial force of 23 N, but is capable of tightening again.

6.6.2 Partial discharge test at ambient temperature

Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C

Calibration of the test circuit by callibrator output 10 pC

Measured PD values

Test arrangement			Prestress voltage	Measuring voltage	Measured PD value
			(1 min)	(1 min)	
No. of test object	Voltage applied to	Earthed	kV	kV	pC
1	Conductor	Screen	29	25	(1 ¹⁾

Notes:

¹⁾ Basic disturbance level at same value



БРПНО
 ОПИНА

6.7 Assessment of the results of test sequence D3

• Test 1


No visible damage was found after the operating eye test.

• Test 2

In the partial discharge test at ambient temperature and at 50-Hz AC voltage of 25 kV, none of the test object exceeded the permissible maximum partial discharge value of 10 pC. The partial discharge value measured was not higher than 1.0 pC.

All of the test object meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2 2006-2.

The tests of the test sequence D3 have been PASSED



IPB
BERLIN

7. Special tests (tests Nos. 17 to 21)

7.1 Test laboratory

Low-voltage test laboratory, test room 7 (test No. 17)
 High-voltage test laboratory, high-voltage hall 2 (tests Nos. 18, 20 and 21))
 High-power test laboratory, test bay 3 (test No. 19)

7.2 Normative documents

CENELEC Harmonization Document HD 629.1 S2: 2006-02
 DIN VDE 0278-629.1 (VDE 0278 Teil 629-1): 2002-06
 IEC 61442: 2005-04
 DIN VDE 0278-442 (VDE 0278 Teil 442): 2006-01

7.3 Required test parameters

Test No.	Type of test	Required test parameters
17	Screen resistance measurement	Temperature during exposure to heat: (120±2) °C Duration of thermal ageing: 168 h
18	Leakage current measurement	Test voltage U_m : 24 kV
19	Screen fault current initiation test	<ul style="list-style-type: none"> • Solidly earthed system Test voltage: 12.7 kV¹⁾ Test current: 10 kA Duration of current flow: 0.2 s Number of tests: 2 • Unearthed or Impedance-earthed system Test voltage: 12.7 kV¹⁾ Test current: Minimum 10 A Test procedure: Start C-1 s O-2 min C-2 min O-2 min C 1 min O end
20	Operating force test	$F < 900$ N
21	Capacitive test point performance	-

Note:

- 1) Test parameter complies with normative document. If lower values are applied the test will become more severe.

BIPAC
 OPTIMAT



7.4 Test arrangement

7.4.1 Screen resistance measurement (test No. 17)

Test arrangement to IEC 61442: 2005-04, Clause 15

Only one single connector body was used for the measurement. For the definite and reproducible measurement of the resistance on the screen two rings made of bare copper wire and of approx. 1-mm width were fixed to the screen. They served as fixed electrodes for the resistance measurement.

7.4.2 Leakage current measurement (test No. 18)

Test arrangement to IEC 61442: 2005-04, Clause 16

The client installed one test object on a short length of cable, which was equipped with an auxiliary sealing end on its other end, and completed it with a bushing. Subsequently, a square metal foil of 25 cm² was fitted to the outer conductive layer of the test object in the region of the bushing. When the AC test voltage was applied to the test object, the leakage current from metal foil to earth was measured.

7.4.3 Screen fault current initiation test (test No. 19)

Test arrangement to IEC 61442: 2005-04, Clause 17

A bushing was centrally arranged in a metal plate of 600 x 600 x 5, which was vertically fixed to a test rack. Each of the test objects, installed on a short length of cable by the client, was fixed to the bushing and the screen was earthed in accordance with the manufacturer's instructions. The other end of each length of cable was equipped with an auxiliary sealing end. For the test with solidly earthed system, a threaded rod of 10 mm Ø was arranged in the region of the transition from the conductor to the cable lug in the body of the connector under test so that a connection was established from the cable lug through a drilled hole to the inner and outer conducting layers of the connector body. For the test with unearthed or impedance earthed systems, a drilled hole was used instead of the rod. It had a copper wire of 0.2 mm Ø for bridging the insulation between the inner and outer screens and for initiating the arc. In both cases, neither the rod nor the wire protruded beyond the outer conducting layer of the connector body.

7.4.4 Operating force test of the cable connector (test No. 20)


Test arrangement to IEC 61442: 2005-04, Clause 18

One connector was assembled according to the client's instructions and was mounted on a bushing using a gliding agent provided by the client.

7.4.5 Capacitive test point performance (test No. 21)

Test arrangement to IEC 61442: 2005-04, Clause 20

One connector was installed on a short length of cable by the client and the screen was earthed in accordance with the manufacturer's instructions. The test object was equipped with a mating bushing.




БЫЛЛО С
ОПРЕДЕЛЕНА

7.5 Test and measuring circuits

7.5.1 Screen resistance measurement (test No. 17)


Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Resistance	Digital hand multimeter of 137 type (KEITHLEY)	Measuring range R - 2 kΩ



1 Measuring point
PO Test object

Figure 9: Measuring circuit for resistance measurement on the screen



IPB
PRÜFFELD
FÜR ELEKTRISCHE
HOCHLEISTUNGSTECHNIK
GMBH

Test and measuring circuits (continued)

7.5.2 Leakage current measurement (test No. 18)


Technical data of test circuit

Single-phase AC voltage source

Test transformer:	Rated voltage	125 kV
	Rated power	100 kVA
	Rated frequency	50 Hz
	Damping resistance	0.67 kΩ

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	Capacitive divider with MU11 (TuRD) peak voltmeter	Ratio 864
2	Test current	Digital hand multimeter of 137 type (KEITHLEY)	MB 0.2 mA AC



- E Supply
- PTr Test transformer with variable transformer connected in series
- R_0 Damping resistance
- R Resistance
- 1, 2 Measuring points
- PO Test object

Figure 10: Test and measuring circuit for the leakage current measurement

ВЫПОЛНО
ОПРЕДЕЛЕНА




Test and measuring circuits (continued)

7.5.3 Screen fault current initiation test (test No. 19)

Technical data of test circuit

Test requirement		Screen fault current test
Test No.		107 4008 and 107 6207
Number of phases	(Test circuit)	2
Number of poles/phases	(Test object)	1
Power frequency	Hz	50
Power factor $\cos \varphi$		< 0.15
Connection of short-circuit transformers		I/I
Short-circuit power		120 MVA
Earthing conditions	Grid	Not earthed
	Short-circuit transformer	Earthed




- E Power supply (grid)
- SI Master breaker
- Dr Making switch
- L1, L2 Current limiting reactors
- Tr Short-circuit transformer
- 1, 2 Measuring points
- I Current measurement
- U Voltage measurement
- TO Test object

Figure 11: Test and measuring circuit for the screen fault current initiation test

Technical data of measuring circuits

Test No.	Measuring point	Symbol	Measured quantity	Measuring sensor/device
107 4008 and 107 6207	1	i	Short-circuit current	Current transformer
	2	u	Test voltage	RC divider
Recording Instrument: BE 256 transient recorder				



107 4008
 107 6207


7.5.4 Capacitive test point performance (test No. 21)

Capacitance measurement by differential bridge

The capacitance C_x to be measured was connected to a capacitance measuring bridge together with the well-known capacitance C_n .

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Capacitance	C-tan δ measuring bridge of VFM type (made by MWB)	Measuring range x 100 pF
2	Test voltage	Capacitive divider with MU11 (made by TuRD) peak voltmeter	



- G Sine-wave generator
- C_x Capacitance to be determined
- L, S Cable conductor or cable screen
- KP Capacitive test point
- C_n Comparison capacitance
- 1, 2 Measuring points

Figure 12: Test and measuring circuit for determining the capacitive test point performance



1213.1607.6.950
 01.11.2013

TEST REPORT NO. 1213.1607.6.950

SHEET 50

Test results (continued)

7.6.3 Screen fault current initiation test (test No. 19)

Test requirement: Screen fault current test for Impedance-earthed systems
 Type of test object: RSES-5225-R 250 A
 Ambient temperature: 19 °C

Test No.	107 ...	4007	4008		
Test object	No.	-	11		
Cycle		-	C _{1s} - O _{2min} - C _{2min} - O _{2min} - C _{1min} - O		
Test voltage	kV	12.8	12.8	12.8	12.8
Test current	A	15.5	15.5	15.5	15.5
Time of test	s	0.2	1	120	60
Notes		1)	2)	2)	2)
Evaluation		-	OK	OK	OK

Notes:


- 1) Current setting
 - 2) The test object is capable of properly carrying the fault current
- OK: During the making cycle the arc was ignited or re-ignited, respectively.
 During the making time, the current flow was present.
 A fault in the insulation is reliably detectable.

Test requirement: Screen fault current test for solidly earthed systems
 Type of test object: RSES-5225-R 250 A
 Ambient temperature: 19 °C

Test No.	107	6207
Test object	No.	9
Test voltage	kV	12.8
Test current	kA	10.9
Time of test	s	200
Notes		1)
Evaluation		n. OK

Notes:

- 1) The connector got loosened from bushing and cable. The bushing got broken.
- n. OK: For the case of a disruptive discharge the screen of the connector is able to carry the fault current which is sufficient to trip the protection device, but another operation is not possible.



БРПНО С
 ОПИТАНА

Test results (continued)

7.6.4 Operating force test (test No. 20)


Cold conditioning for 12 h at -20 °C, withdrawal force = 524 N

7.6.5 Capacitive test point performance (test No. 21)

Test temperature:

Ambient temperature

23 °C

Test arrangement			Capacitance of test point KP		Notes
					
No. of test object	Voltage applied to	Earthed	Towards cable screen C_{te}	Towards cable conductor C_{tc}	
			pF	pF	
12	L (conductor)	Screen connection of the connector body	-	9.5	OK
12	S (screen)	Conductor	11.8	-	OK

Notes:

OK: The ratio of C_{te} to C_{tc} was 11.8 pF:9.5 pF ≈ 1.24 , and thus ≤ 12 as specified by the normative document



BRUNNEN
 OPAPRINT

7.7 Assessment of special tests

- Test 17

The resistance measured before and after the exposure to heat at 120 °C/168 h was 300 and 216 Ω, resp. This was significantly below the maximum permissible value of 5000 Ω.

- Test 18

The leakage current measured at an applied AC test voltage of 24 kV fell below the maximum permissible value of 0.5 mA with a measured value of 5 μA.

- Test 19

- Solidly earthed systems

For the case of a disruptive discharge the screen of the connector is able to carry a fault current which is sufficient to trip the protection device. The fault was reliably initiated within 3 s. The screen is able to discharge an arc to earth. The current is sufficient to operate the circuit protection, but the cable terminal gets completely destroyed so that another making of the short-circuit was no more possible.

- Unearthed or impedance-earthed systems

During the making cycle the arc was ignited or re-ignited, respectively. During the making time, the current flow was present. A fault in the insulation is reliably detectable. During the making cycle, the arc was ignited resp. re-ignited at 12.1 kV. During the making time, the current flow was present at 12.1 kV. A fault in the insulation is reliably detectable.

- Test 20

The withdrawal force was determined to be 524 N. Thus it is below the maximum permissible value of 900 N.

- Test 21

The ratio of C_{te} to C_{tc} was determined to be 1.24, which is ≤ 12 as specified by the normative document.

The test objects meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2: 2006-2, except Test No. 19.



DEPTO C
DEPTO A

8. Photos




Figure 13: View of one test object




Figure 14: Arrangement for the electrical heat cycling test in air for test sequence



BRUNNEN
OPHTHALMIA
CORNEA




Figure 15: View of the test objects for the test sequence D2 (mounted on bushings)




Figure 16: Test object after the screen fault current initiation test (solidly earthed systems)



BYPHOC
CPATHANA






Figure 17: Test object No. 11 after the screen fault current initiation test
(unearthed or Impedance-earthed systems)



ВЕРНО
ОПРАВДА



9. Oscillograms

Test-No. 1074008



РИПО С
ОПТИМА


Test-No. 1076207



BRAND 3 01150





Test-No. 2072835



EXPL 0 C
KMWEX

Test-No. 2072837





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
Lucsa Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

**Списък на проведените изпитвания на щепселна кабелна глава, Г-образна/адаптор/
тип RSES**

1. Изпитване издръжливост с постоянно напрежение;
2. Изпитване издръжливост с променливо напрежение;
3. Изпитване частичен разряд при околна температура;
4. Изпитване импулсно напрежение при околна температура;
5. Изпитване циклично електрическо нагряване във въздух;
6. Изпитване циклично електрическо нагряване във вода;
7. Изпитване комутация/включване/изключване;
8. Изпитване частичен разряд при околна температура;

13.01.2016г.

Подпис и печат:



Немска Служба по Акредитация
Предоставено съгласно

с подписано многостранно споразумение на EA, ILAC и IAF за взаимно одобрение

АКРЕДИТАЦИЯ

С настоящото Немска служба за акредитация потвърждава, че лабораторията за изпитване

FGH Инженеринг и Изпитвания
Халенвег 40, 68219 Манхайм

притежава правомощия съгласно ISO/IEC 17025:2005 да провежда изпитвания в областта на
съоръжения и уреди за високо напрежение и техните компоненти,
силови кабели и комплекти за силови кабели

Свидетелството за акредитация важи във връзка с решение от 11.01.2012 с акредитационен № D-PL-12110-01 и е
валидно до 10.01.2017г. Състои се от този лист, обратната страна на този лист и приложения общо 22 страници.

Регистрационен номер на свидетелството: D-PL-12110-01

Франкфурт на Майн, 11.01.2012

дипл. инж. Ралф Егнер





Deutsche Akkreditierungsstelle GmbH German Accreditation Body

Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1 subsection 1 AkkStelleGBV
Signatory to the Multilateral Agreements of
EA, ILAC and IAF for Mutual Recognition

Accreditation



The Deutsche Akkreditierungsstelle GmbH (German Accreditation Body) attests that the testing laboratory

FGH Engineering & Test GmbH
Hallenweg 40, 68219 Mannheim

Is competent under the terms of DIN EN ISO/IEC 17028:2005 to carry out tests in the following fields:

High voltage devices and systems and their components
Power cable and power cable sets

The accreditation certificate shall only apply in connection with the notice of accreditation of 11.01.2012 with the accreditation number D-PL-12110-01 and is valid until 10.01.2017. It comprises the cover sheet, the reverse side of the cover sheet and the following annex with a total of 22 pages.


Registration number of the certificate: D-PL-12110-01

Frankfurt am Main, 11.01.2012

On behalf of Dipl.-Ing. (FH) Ralf Egner
Head of Division 2

This document is a translation. The definitive version is the original German accreditation certificate.

See notes overleaf.



Немска Служба по Акредитация
Предоставено съгласно

с подписано многостранно споразумение на EA, ILAC и IAF за взаимно одобрение

АКРЕДИТАЦИЯ

С настоящото Немска служба за акредитация потвърждава, че лабораторията за изпитване

Институт „Изпитвания на електрическа високо технологична техника“
Ландсбергер Алее 378А, 12681 Берлин

притежава правомощия съгласно ISO/IEC 17025:2005 да провежда изпитвания в областта на
съоръжения и уреди за високо напрежение и техните компоненти,
кабели и проводници
индустриално оборудване ниско напрежение

Свидетелството за акредитация важи във връзка с решение от 31.08.2012 с акредитационен № D-PL-12107-01 и е
валидно до 24.01.2017г. Състои се от този лист, обратната страна на този лист и приложения общо 30 страници.

Регистрационен номер на свидетелството: D-PL-12107-01-01

Франкфурт на Майн, 31.08.2012

дипл. инж. Ралф Егнер





Deutsche Akkreditierungsstelle GmbH

Befähigte gemäß § 8 Absatz 1 AkkStelleG i.V.m. § 1 Absatz 1 AkkStelleGBV
Unterzeichnerin der Multilateralen Abkommen
von EA, ILAC und IAF zur gegenseitigen Anerkennung

Akkreditierung



Die Deutsche Akkreditierungsstelle GmbH bestätigt hiermit, dass das Prüflaboratorium

Institut "Prüffeld für elektrische Hochleistungstechnik" GmbH
Landsberger Allee 378A, 12681 Berlin

die Kompetenz nach DIN EN ISO/IEC 17025:2005 besitzt, Prüfungen in folgenden Bereichen durchzuführen:

Hochspannungsgeräte, -anlagen und deren Komponenten
Kabel und Leitungen
Industrielle Niederspannungsgeräte


Die Akkreditierungsurkunde gilt nur in Verbindung mit dem Bescheid vom 31.08.2012 mit der Akkreditierungsnummer D-PL-12107-01 und ist gültig bis 24.01.2017. Sie besteht aus diesem Deckblatt, der Rückseite des Deckblatts und der folgenden Anlage mit insgesamt 30 Seiten.

Registrierungsnummer der Urkunde: D-PL-12107-01-01

Frankfurt am Main, 31.08.2012

Siehe Hinweise auf der Rückseite

Im Auftrag Dipl.-Ing. (FH) Ralf Eder
Leiter Abteilung 2



R. Eder
31.08.2012
D-PL-12107-01-01



Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
TYCO Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният Иван Вълков Костов, в качеството си на управител на Кимтех България ООД, гр. Бургас, жк. Братя Миладинови, бл. 57, вх. 4А официален дистрибутор на изделията на Tyco Electronics Raychem декларирам, на собствена отговорност, че продуктите:

- 1/ Щепселна кабелна глава права 20kV, 250A, 50mm² тип RSSS 5225-P
- 2/ Щепселна кабелна глава права, 20kV, 250A, 95mm² тип RSSS 5229-P

произведени в Отобрун, Германия, за които се отнася тази декларация, са произведени в условията на въведената и поддържаната от производителя система за производствен контрол и в съответствие със следните стандарти CENELEC HD 629 (VDE 0278-629), и съответствието е оценено съгласно Наредбата за съществените изисквания и оценяване на съответствието на строителните продукти. Декларацията се издава въз основа на протоколи от проведени изпитания № PPR 2528, издаден от Лаборатория за изпитвания Берлин.

13.01.2016г.
гр. Бургас

Подпис и печат
/И. Костов-Управител/





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tuco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТВИЕ

Долуподписаният Иван Вълков Костов, в качеството си на управител на Кимтех България ООД, гр. Бургас, жк. Братя Миладинови, бл. 57, вх. 4А официален дистрибутор на изделията на Tусо Electronics Raychem декларирам, на собствена отговорност, че продуктите:

- 1/ Щепселна кабелна глава Г-образна, 20кV, 250А, 50мм² тип RSES 5225-P
- 2/ Щепселна кабелна глава Г-образна, 20кV, 250А, 95мм² тип RSES 5229-P

произведени в Отобрун, Германия, за които се отнася тази декларация, са произведени в условията на въведената и поддържаната от производителя система за производствен контрол и в съответствие със следните стандарти CENELEC HD 629 (VDE 0278-629), съответствието е оценено съгласно Наредбата за съществените изисквания и оценяване на съответствието на строителните продукти. Декларацията се издава въз основа на протоколи от проведени изпитания № PPR 2527, издаден от Лаборатория за изпитвания Берлин.

13.01.2016г.
гр. Бургас

Подпис и печат
/И. Костов-Управител/





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
тусо Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web:www.kimtech.bg
e-mail: office@kimtech.bg

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният Иван Вълков Костов, в качеството си на управител на Кимтех България ООД, гр. Бургас, жк. Братя Миладинови, бл. 57, вх. 4А официален дистрибутор на изделията на Tusо Electronics Raychem декларирам, на собствена отговорност, че продуктите:

- 1/ Щепселна кабелна глава за проходни изводи тип „С“ 20kV, 95-185мм² тип RICS 5133
- 1/ Щепселна кабелна глава за проходни изводи тип „С“ 20kV, 95-185мм² тип RICS 5137

произведени в Отобрун, Германия, за които се отнася тази декларация, са произведени в условията на въведената и поддържаната от производителя система за производствен контрол и в съответствие със следните стандарти CENELEC HD 629.1 S21 (2006-02), (VDE 0278-629), и съответствието е оценено съгласно Наредбата за съществените изисквания и оценяване на съответствието на строителните продукти. Декларацията се издава въз основа на сертификат от типово одобрение № E-13892 издаден от Дет Норске Веритас съгласно одобрени протоколи от проведени типови изпитания № PPR 866, PPR 1106 издадени от Лаборатория за изпитвания Тайко Електроникс Райхем и Лаборатория за изпитвания Мюнхен.

13.01.2016г.
гр. Бургас

Подпис и печат





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
Тусо Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният Иван Вълков Костов, в качеството си на управител на Кимтех България ООД, гр. Бургас, жк. Братя Миладинови, бл. 57, вх. 4А официален дистрибутор на изделията на Тусо Electronics Raychem декларирам, на собствена отговорност, че продуктите:

1/ Кабелна глава, 20 kV, закрит монтаж, термосвиваема 70-240mm² тип POLT 24D/1X1


произведени в Отобрун, Германия, за които се отнася тази декларация, са произведени в условията на въведената и поддържаната от производителя система за производствен контрол и в съответствие със следните стандарти CENELEC HD 629 (VDE 0278-629), IEC 60502-4 и съответствието е оценено съгласно Наредбата за съществените изисквания и оценяване на съответствието на строителните продукти. Декларацията се издава въз основа на протокол от проведени изпитания № PPR 1410, издаден от Лаборатория за изпитвания Манхайм.

13.01.2016г.
гр. Бургас

Подпис и печат
/И. Костов /управител/



ELECTRICAL
PRODUCTS DIVISION



Инструкция за монтаж
EPP 0580 9/95

Екраниран прав адаптор
250А, за едножилни
пластмасови кабели
12 до 24 kV без броня
(с тръба за маркиране на
фазите)

Тип RSSS

Raychem



ВЪВЕДЕНА
ОПРЕДЕЛЕНА


Препоръки за безопасност

Важно е да се спазват съответните правила за безопасност при работа с оборудване високо напрежение. За точна информация относно безопасността моля свържете се с официалният представител.

Преди монтажа

Проверете, че комплекта е предназначен за кабела. Проверете етикета на комплекта и заглавието на Инструкцията за монтаж. Възможно е, компонентите или стъпки на работа да са променени, в сравнение с тези от предходния път, в който сте монтирали този продукт. Внимателно прочетете и следвайте стъпките в Инструкцията за монтаж.

Информацията, съдържаща се в тези инструкции за монтаж е предназначена да опише правилния метод на монтаж на този продукт. Въпреки това, Raychem няма контрол върху полевите условия, които влияят върху монтажа на продукта. Това е отговорност на потребителя, да се определи пригодността на метода на монтаж в полеве условия на потребителя. Задълженията на Raychem са само тези, които са посочени в стандартните условия за продажба на Raychem за този продукт и в никакъв случай Raychem няма да е отговорен за каквито и да било други случайни, непреки или последващи вреди, произтичащи от употребата или злоупотребата с продуктите.



Подготовка на кабела




Почистете и обезмаслете края на външната обвивка на дължина от 1 метър с разтворител.




A. Кабел с екран от телове

Позициониране на кабела.
Маркирайте външната обвивка на 200 mm под края на втулката.
Отрежете кабела 420 mm над маркировката и премахнете външната обвивка до този размер

Увийте един слой уплътнителна лента (червена) с малко припокриване и леко разтягане около края на външната обвивка 60 mm. Огънете екрана от телове обратно върху външната обвивка. Избягвайте пресичане на отделните телове. Фиксирайте телове с лента.

Отрежете жилото в съответствие с чертежа. Премахнете екрана съгласно чертежа. Повърхността на изолацията не трябва да има следи от полупроводим материал. Забележка: не наранявайте изолацията, почистете от неравности





В. Кабел с екран от ленти
 Премахнете жилото съгласно чертежа. Премахнете външната обвивка на разстояние от 190 mm. Премахнете екрана от метални ленти до 20 mm от отреза на външната обвивка. Премахнете олюпроводимия екран на жилото до 50 mm от отреза на външната обвивка. Повърхността на изолацията не трябва да има следи от полупроводим материал. Забележка: не наранявайте изолацията, почистете от неравности

Увийте един слой уплътнителна лента (червена) с малко припокриване и леко разтягане около края на външната обвивка 60 mm.




Фиксирайте заземителното въже към металния екран, така че приблизително 300 mm да остане свободният край. Оформете 30 mm преграда срещу влага като започнете 10 mm под мастик лентата. Фиксирайте заземителното въже с лента.


Изпълнение на адаптора

Отрежете изолацията както е показано на чертежа. Монтирайте конектора с инструмент за кербоване за алуминий в съответствие с размера показан на съединителя. Почистете и обезмасл. изол. на жилото и съединителя. Забележка: Използвайте само кербовъчни накрайници с мин. ширина на раб. повърхност 7 mm.

Проверете позицията на фазите и поставете съответно маркираната тръба върху кабела.


Нанесете силиконова смазка до края на изолацията на разстояние от около 50mm.






8

Напъхайте тялото на адаптора върху подготовеният кабел. Уверете се, че щифта е захванал тялото. Не трябва да е възможно да се измъкне обратно ако това е направено правилно. Точката за изпитване на адаптора трябва да е достъпна за измерване.
Note: Не пипайте изолацията.



9

Увийте уплътнителна лента /червена/ между края на външната изолация и адаптора с дължина 25мм. Сложете достатъчно уплътнителна лента, за да се постигне плавен преход от външната обвивка към адаптора.






A10


А. Екран от телове
 Поставете 3 екраниращи телове и ги промушете през отвора на адаптора. Още не ги увивайте заедно.

В. Екран от ленти
 Вземете края на телта и я промушете през отвора адаптора. Още не я увивайте.

Запichnete от долния край на предно положената лента и увивайте на горе уплътнителна лента /червена/ около кабела и адаптора на разстояние 120 mm.

Позиционирайте тръбата така, че частта увита с лента да е напълно покрита и свийте с горелка като запichnete от долу нагоре по посока на адаптора.





Инструкция за монтаж
ERP-0470-2/00

Екраниран адаптор
250А за едножилен
пластмасов кабел 12
до 24 kV без броня
(с тръба за маркиране на
фазите)

Тип RSES

Tyco Electronics Raychem GmbH
Energy Division
Finsinger Feld 1
85521 Ottobrunn
Munich, Germany
Tel. ++49-89-6089-0
Fax ++49-89-6096345




ВЪВЕДЕНИЕ
ОПРЕДЕЛЕНИЕ
СЪДЪЖАНИЕ

Препоръки за безопасност

Важно е да се спазват съответните правила за безопасност при работа с оборудване високо напрежение. За точна информация относно безопасността моля свържете се с официалния представител.

Преди монтажа

Проверете, че комплекта е предназначен за кабела. Проверете етикета на комплекта и заглавието на Инструкцията за монтаж. Възможно е компонентите или стъпките на работа да са променени, в сравнение с тези от предходния път, в който сте монтирали този продукт. Внимателно прочетете и следвайте стъпките в Инструкцията за монтаж.






Подготовка на кабела


Почистете и обезмаслете края на външната обвивка на дължина от 1 метър с разтворител.

A. Кабел с екран от телове
 Позициониране на кабела.
 Маркирайте външната обвивка на 200мм под края на втулката, отрежете кабелна на 420мм над маркировката и премахнете външната обвивка до този размер.


Увийте един слой уплътнителна лента (червена) с малко припокриване и леко разтягане около края на външната обвивка 60 мм. Огънете екрана от телове обратно върху външната обвивка. Избягвайте пресичане на отделните телове. Фиксирайте телове с лента.

Отрежете жилото в съответствие с чертежа. Премахнете екрана съгласно чертежа. Повърхността на изолацията не трябва да има следи от полупроводим материал.
 Забележка: не наранявайте изолацията почистете от неравности.






B2 **В. Кабел с екран от ленти**
 Отрежете жилото съгласно чертежа. Премахнете външната обвивка на Разстояние от 190 mm. Премахнете полупроводимия екран на жилото до 50 mm от отреза на външната обвивка. Повърхността на изолацията не трябва да има следи от полупроводим материал. **Забележка:** не наранявайте изолацията, почистете от неравности.



B3 Увийте един слой уплътнителна лента L4 червена/ с малко припокриване и лека разтягане около края на на външната обвивка 60mm.








B4 Фиксирайте заземителното въже, така, че приблизително 300mm да остане свободния край. Оформете 30mm преграда срещу влага като започнете 10mm по д мастик лентата. Фиксирайте заземителното въже с лента.

Отрежете изолацията както е показано на чертежа. Монтирайте кабелна обувка на проводника, така че отвора на кабелната обувка и втулката да са на една линия. Монтирайте кабелната обувка с инструмент за кербоване за алуминий в съответствие с размера показан на обувката. **Забележка:** използвайте само кербовъчни крайници с дължина на на раб. повърхност 7 mm.


Почистете и обезмаслете изолацията на жилата и обувката. Проверете позицията на фазите и поставете съответно маркираната тръба върху фазите.

Нанесете силиконова смазка до края на изолацията на разстояние от около 50mm.






Напъхайте тялото на адаптора върху подготвения кабел. Предният край на адаптора трябва да сочи към втулката. Отвора на кабелната обувка и втулката трябва да са на една линия.
Забележка: не пипайте изолацията.




Вкрайте свърващия щифт в адаптора и я закрепете с шестограмен ключ. Завъртете докато ключът се деформира.




Увийте уплътнителна лента /червена/ между края на външната изолация и адаптора с дължина 25мм. Сложете достатъчно уплътнителна лента, за да се постигне плавен преход от външната обвивка към адаптора.



A. Екран от телове
Поставете 3 екраниращи телове и ги промушете през отвора на адаптора. Още не ги увивайте заедно




B. Екран от ленти
Вземете края на телта и я промушете през отвора на адаптора. Още не я увивайте.




Започнете от долния край на предходно сложената лента и увивайте нагоре уплътнителна лента /червена/ около кабела и адаптора на разстояние 120мм






13
2333_04

Позиционирайте така тръбата, че частта увита с лента да е напълно пририта и свийте с горелка като започнете от долу на горе по посока на адаптора.



A14
2333_06

А. Екран от телове
Увийте телове заедно около дупката на адаптора. Подсигурете телове с плетенка към изолацията. Увийте екраниращите телове във формата на заземително въже.




B14
2333_05

В. Екран от ленти
Увийте телове заедно около дупката на адаптора. Подсигурете заземителното въже към изолацията с плетенка.


Нанесете силиконова смазка във прохода и във вътрешната повърхност на свързания адаптор.

Закачете скобите в прохода. Пъхнете адаптора в прохода.


Центрирайте скобата към адаптора и я закрепете. Монтажът е готов.




15
2328_01




16
2335_04b



17
2335_04c





Инструкция за монтаж
ERP-0271-BG-12/94
Изолирани
Т-адаптори за
напрежение до 24 kV
и 630 A за втулки с
резба по DIN 47636

Тип: RICS

Raychem



Информацията, съдържаща се в настоящата инструкция е предназначена да опише точния метод за инсталиране на този продукт. Поради това, че Rauchet няма възможност да контролира полевите или други условия на монтаж, монтьорът трябва да прилага собствения си опит, когато инсталира този продукт.

Rauchet не поема отговорност в случаи на повреди, възникнали в следствие на неправилно използване на продукта.

Внимание!

Адапторът и главата не са екранирани!

При подадено напрежение повърхността на изолацията ще бъде също под напрежение, затова не трябва да се докосва!

Спазвайте правилата за работа с високоволтови съоръжения.


Забележка:

Минимално разстояние между адапторите: 25 mm

между адаптор и земя: 25 mm


Профил на втулката: Описаните адаптори да се използват само при размери на втулките отговарящи на тези от схеми A1 или A2.

A1



2507/8

A2



2507/9

Общи инструкции

Използвайте кабелни обувки с подходящ отвор.

Отстранете окиса от плоската част на обувката.

След пресоване отстранете острите ръбчета.

Използвайте обувки с подходящ химичен състав, ако е нужно - калайдисани или биметални.

Оставете главата да изстине преди да монтирате адаптора.


Монтаж на главата

Монтирайте главата според приложената от Rauchet инструкция.

Стрехичките, доставени с главата не са нужни при адаптора RICS.

Главата съдържа херметизиращ лепилен слой върху обувката, който трябва да е на разстояние най-малко 50 mm от центъра на отвора на обувката.


Ако в комплекта на адаптора има заклиняваща гръбна, свийте я върху главата по размерите от схема В.




Размери в mm



С Разположение на детайлите в готов Т-адаптор




Монтаж на Т-адаптора




Намажете обилно със силиконова паста края на главата на около 80 mm. Намажете с проводимата паста повърхността на вложката, късия край на адаптора и плоската част на обувката.

0167


Пъхнете главата в тялото на адаптора. Дългият край на адаптора да сочи втулката.




Отворът на кабелната обувка да е на една линия с този на металната вложка на адаптора.




Отстранете щифта, останал във втулката. Завийте щифта на адаптора във втулката и го затегнете добре.






5
Намажете със силикон втулката и вътрешната повърхност на адаптора.



6
Напъхайте адаптора върху втулката. Вкарайте шайбата и гайката. Затегнете голямата гайка с усилие, показано долу.

Втулка	Резба	Сила Nm	
		min	max
A1	M16	50	70
A1	M16/M12	35	40
A2	M12	35	40




7
Поставете връвчицата в отвора на адаптора, както е показано на схемата.

Намажете обилно със силикон коничната повърхност на запушалката на адаптора и вътрешната му повърхност.

Завийте запушалката в адаптора. Завиването става с голямо усилие. Монтажът е завършен при усещане на голямо съпротивление. Не пренатягайте! Издърпайте връвчицата, за да освободите въздушното налягане в адаптора.


Схемата показва завършения адаптор.

Отстранете всички отпадъци в съответствие със санитарните норми.





8
Raychem е запазена марка на Raychem Corporation

Raychem




9
Raychem България
ЕРЗЕТ ИНЖЕНЕРИНГ
Бургас
жк Братя Миладинови
бл.57 вх.4А ап.3
тел.факс 0035 956 37102
тел. 0035 956 34198



Стр. 4/4
ОПРЕДЕЛЕНИЕ

Raychem



**Инструкция за монтаж
ESD-3824-BG-4/05**

**Кабелни глави за кабели
с пластмасова изолация
без броня, за напрежение
до 42 kV**

Тип: POLT

Raychem – България
Бургас 8000
ЕРЗЕТ ИНЖЕНЕРИНГ
жк. "Братя Миладинови"
Бл.57, вх.4А, от.1
Тел./факс-0035 956 34198
Тел./факс-0035 956 37102
GSM -0035 988 639903

Tyco Electronics Raychem GmbH
Energietechnik
Finsinger Feld 1
85521 Ottobrunn
Telefon: ++49-89-6089-0
Telefax: ++49-89-6096345



ОТКАЗАНО
БЪЛГАРИЯ

Преди работа

Убедете се, че комплекта, който използвате съответства на кабела.
Сверете етикета на комплекта със заглавието на инструкцията.
Внимателно прочетете инструкцията и следвайте стриктно стъпките на монтажа, защото в възможно да е настъпила промяна в компонентите или последователността на операциите след последния монтаж, който сте извършвали.

Общи положения

Препоръчва се използването на пропан-бутан.

Регулирайте горелката така, че да преобладава мекият, жълт пламък.

Избягвайте островърхия, син пламък.

Дръжте горелката наклонена в посоката на свиване така, че да подгръва студените части на тръбата.

Движете пламъка непрекъснато, за да избягвате прегаряне и нагърчване на тръбата.

Почистете с разтворител всички части, които ще контактуват с термотопимото лепило.

Спазвайте инструкциите за работа със съответния разтворител.


При рязане на тръбите използвайте остър нож и избягвайте образуването на ръбчета и неравности.

Свиването на всяка тръба извършвайте, както е посочено в инструкцията.

Убедете се, че тръбата се е свила добре по окръжността на кабела, преди да продължите свиването надлъжно.

Тръбата трябва да се свие гладко, без нагърчвания и профилът на вътрешните елементи да личи добре.

Информацията, съдържаща се в тази инструкция е предназначена да опише точния метод на монтаж на това изделие. Поради това, че Tyco Electronics няма възможност да контролира полевите или други условия на монтаж, монтажът трябва да прилага собствения си опит, когато инсталира този продукт. Tyco Electronics не носи отговорност в случаи на повреда, възникнала в следствие на неправилен монтаж.
Raychem е запазена марка на Tyco Electronics.




СЕРВИСНО
ОТДЕЛЕНИЕ

Подготовка на кабела


А. Кабел с екран от телове

Таблица 1

Тип POLT-	L	
	закрито [mm]	открито [mm]
12	240	240
17.5	240	280
24	280	380
36	380	440
42	440	500



Отстранете обвивката по размера L (Таблица 1).
Почистете края на обвивката на 100 mm.
Навийте червената херметизираща лента върху края на обвивката.






Огънете теловите към обвивката и ги положете без кръстосване върху червената лента.
Превържете ги с бандаж от тел на 60 mm от края на обвивката.
Оплетете теловите в заземително жило.

Отстранете полупроводимия екран до 40 mm от обвивката. Повърхността на изоляцията да е абсолютно чиста от проводими частици. Загладете неравностите. **Забележка:** Не наранявайте изоляцията!

Отрежете изоляцията по размера K от схемата.
а. Пресови обувки
Размерът K да не надвишава 110 mm.
Монтирайте обувката.
б. Винтови обувки
Монтирайте обувката. Натягайте двата болта равномерно до откъсване на главите им.

Около края на полупроводимия екран навийте лента така, че да покриете 20 mm от екрана и 10 mm от изоляцията.
Разпъвайте лентата до около половината от първоначалната и ширина, като се стремите да получите тънък и фин ръб върху изоляцията.




Подготовка на кабела


В. Кабел с екран от ленти

Таблица 2

Тип POLT-	L	
	закрито [mm]	открито [mm]
12	250	250
17.5	250	290
24	290	390
36	390	450
42	450	510



Отстранете обвивката по размера L (Таблица 2).
Отстранете металния екран до 20 mm обвивката.
Почистете обвивката на 100 mm.
Навийте червената херметизираща лента върху края на обвивката.



Фиксирайте заземителното въже към металния екран чрез запояване или друг приет метод. Водната бариера да легне върху червената лента.
С тел фиксирайте заземителното жило към обвивката непосредствено под червената лента.

Отстранете полупроводимия екран до 60 mm от обвивката. Повърхността на изолацията да е абсолютно чиста от проводими частици. Загладете неравностите. Забележка: Не наранявайте изолацията!

Отрежете изолацията по размера K от схемата.




а. Пресови обувки
Размерът K да не надвишава 110 mm.

Монтирайте обувката.


б. Винтови обувки

Монтирайте обувката. Натягвайте двата болта равномерно до откъсване на главите им.

Около края на полупроводимия екран навийте лента така, че да покриете 20 mm от екрана и 10 mm от изолацията.
Разпъвайте лентата до около половината от първоначалната и ширина, като се стремите да получите тънък и фин ръб върху изолацията.




Изработване на главата




Уплътняване на кабелната обувка:
Използвайте червена ланта и херметизирайте допълнително кабелната обувка при следните напрежение/сечение.

12kV:	10 - 25mm ²
17,6kV:	16 - 25mm ²
24 kV:	25 mm ²
36kV:	35 - 50 mm ²
42kV:	35 - 50 mm ²



Подгрейте кабелната обувка и напъхайте тръбата до бандажа от тел.






Започнете свиването на тръбата върху края на полупроводимия екран. Продължете свиването към кабелната обувка и накрая - към кабела.
Цифрите на схемата показват последователността на свиване.


Кабелната глава за монтаж на закрито е готова

Забележка: След монтаж на главата върху шината е желателно главата да се нагрее допълнително до изтичането на зелена маса от вътрешността.
Оставете я да изстине, преди да я подложите на механически стрес.


За монтаж на открито:

Свийте стрехичките по размерите от таблицата на Стр.6.
Започнете свиването от най-долната стрехичка.







Брой стрехички на жило		
kV	закрито	открито
12	0	1
17.5	0	3
24	0	3
36	0	4
42	0	4





Минимален радиус на огъване и отстояния



Min. отстояния	Max. Напрежение в kV				
	12	17,5	24	36	42
a Въздушни	По местните спесификации				
b Ф/Ф и Ф/земя в mm	15	20	25	35	45
d Между стрехичките в mm	10	15	20	25	35
r (min. Радиус на огъване) = 15 x D					

Молим, отстранете всички отпадъци в съответствие с екологичните и санитарни норми





Page 12-2

AC FUSE HOLDERS


- Version without indicator: 1P, 1P+N, 2P, 3P, 3P+N
- Version with indicator: 1P
- For fuses 10x38, 14x51 and 22x58mm IEC class gG or aM.
- Rated current: 32A, 50A, 125A
- Rated voltage: 690VAC.



Page 12-2

AC FUSE HOLDERS CLASS CC FOR NORTH AMERICAN MARKET

- Version without indicator: 1P, 2P, 3P
- Version with indicator: 1P
- For 10x38mm UL/CSA class CC fuses
- Rated current: 30A
- Rated voltage: 600VAC.



Page 12-3

DC FUSE HOLDERS FOR PHOTOVOLTAIC APPLICATIONS

- Version without indicator: 1P, 2P
- Version with indicator: 1P, 2P
- For 10x38mm IEC class gPV fuses
- Rated current: 32A
- Rated voltage: 1000VDC
- IEC utilisation category: DC20B.




Page 12-3

DC FUSES FOR PHOTOVOLTAIC APPLICATIONS

- 10x38mm, IEC class gPV
- Rated current: 20A
- Rated voltage: 1000VDC.

БЪЛГАРСКО
СТАНДАРТИЗАЦИОННО
ОБЩЕСТВО





- Modular size for 10x38, 14x51 and 22x58mm fuses
- Finger safe - IP20 IEC degree of protection against accidental contact with live parts and with sealable cover for operators' safety
- Version with status indicator to quickly determine if the fuse is still operative or needs to be replaced
- UL and CSA certified versions.

	SEC. - PAGE
Fuse holders	
AC fuse holders.....	12 - 2
DC fuse holders for photovoltaic applications.....	12 - 3
Fuses for photovoltaic applications	12 - 3
Accessories	12 - 3
Dimensions	12 - 4
Wiring diagrams	12 - 4
Technical characteristics	12 - 5

modulo



БУРФАГ
 БЪЛГАРИЯ
 КИМТЕХ


Lovato
electric

CIRCUIT PROTECTION AND ISOLATION

Fuse holders AC fuse holders



Fuse holders UL Recognized and CSA certified



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt. [kg]
			n°	n°	[kg]

For 10x38mm fuses.
32A rated current at 690VAC.

FB01 A 1P	1P	—	1	12	0.066
FB01 A 1PL	1P	YES	1	12	0.065
FB01 A 1N	1P+N	—	1	12	0.062
FB01 A 1N	1P+N	—	2	6	0.134
FB01 A 2P	2P	—	2	6	0.132
FB01 A 3P	3P	—	3	4	0.188
FB01 A 3N	3P+N	—	4	3	0.260

For 14x51mm fuses.
60A rated current at 690VAC.

FB02 A 1P	1P	—	1	12	0.113
FB02 A 1PL	1P	YES	1	12	0.114
FB02 A 1N	1P+N	—	2	6	0.237
FB02 A 2P	2P	—	2	6	0.224
FB02 A 3P	3P	—	3	4	0.335
FB02 A 3N	3P+N	—	4	3	0.460

For 22x58mm fuses.
125A rated current at 690VAC.

FB03 A 1P	1P	—	1	12	0.167
FB03 A 1PL	1P	YES	1	12	0.167
FB03 A 1N	1P+N	—	2	6	0.354
FB03 A 2P	2P	—	2	6	0.334
FB03 A 3P	3P	—	3	4	0.500
FB03 A 3N	3P+N	—	4	3	0.720

⊖ Not certified.

Operational characteristics

- IEC rated voltage U_n :
 - 690VAC (FB01 A 1M excluded)
 - 400VAC (FB01 A 1M only)
- IEC rated current I_n :
 - FB01 A: 32A
 - FB02 A: 60A
 - FB03 A: 125A
- IEC utilisation category:
 - FB01 A: AC22B 500V, AC21B 690V (except FB01 A 1M: AC22B 400V)
 - FB02 A: AC22B 500V, AC21B 690V
 - FB03 A: AC21B 690V
- Suitable for IEC fuse classes gG and gM
- IEC degree of protection: IP20

Certifications and compliance

Certifications obtained:


Type	UL Recognized for USA (File E343395)	CSA certified (File 252040 class 6225)	UL Recognized for USA and Canada (File E343395)
FB01 A 1P, FB01 A 1PL, FB01 A 1N	●	●	●
FB02 A	●	●	●
FB03 A	●	●	●

● Certification obtained

UL Recognized Products having this type of marking are intended for use as components of complete workshop assembled equipment.

Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3, UL 4248-1, UL 4248-4, CSA C22.2 n° 4248-1, CSA C22.2 n° 4248-4

Fuse holders



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt. [kg]
			n°	n°	[kg]

For 10x38mm fuses.
32A rated current at 690VAC.

FB01 B 1P	1P	—	1	12	0.062
FB01 B 1PL	1P	YES	1	12	0.064
FB01 B 1N	1P+N	—	2	6	0.127
FB01 B 2P	2P	—	2	6	0.128
FB01 B 3P	3P	—	3	4	0.185
FB01 B 3N	3P+N	—	4	3	0.247


Operational characteristics

- IEC rated voltage U_n : 690VAC
- IEC rated current I_n : 32A
- IEC utilisation category: AC22B 600V, AC21B 690V
- Suitable for IEC fuse class: gG and gM
- IEC degree of protection: IP20

Reference standards

Compliant with Standards: IEC/EN 60947-1, IEC/EN 60947-3, IEC/EN 60269-1, IEC/EN 60269-2

Fuse holders UL Listed and CSA certified for class CC fuses for North American market



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt. [kg]
			n°	n°	[kg]

For 10x38mm fuses.
30A rated current at 600VAC.

FB01 C 1P	1P	—	1	12	0.070
FB01 C 1PL	1P	YES	1	12	0.072
FB01 C 2P	2P	—	2	6	0.140
FB01 C 3P	3P	—	3	4	0.210

NOTE: UL Listed and CSA certified as "Fuseholders, Cartridge Fuse" for use with Class CC fuses. Interrupting rating 200,000 Amps rms symmetrical. Voltage rating 600V. Current rating 30A.

Operational characteristics

- IEC rated voltage U_n : 600VAC
- IEC rated current I_n : 30A
- IEC utilisation category: AC22B 600V, AC21B 600V
- Suitable for UL/CSA fuse class: CC
- IEC degree of protection: IP20

Certifications and compliance

Certifications obtained: UL Listed (File E343395) and CSA certified (File 252040 class 6225)

Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3, UL 4248-1, UL 4248-4, CSA C22.2 n° 4248-1, CSA C22.2 n° 4248-4


Fuse holders

DC fuse holders for photovoltaic applications.

Accessories



Fuse holders for photovoltaic applications



FB01 D...

FB01 D 1PL

Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt [kg]
			n°	n°	[kg]
For 10x38mm fuses. 32A rated current at 1000VDC.					
FB01 D 1P	1P	—	1	12	0.064
FB01 D 1PL	1P	YES	1	12	0.065
FB01 D 2P	2P	—	2	6	0.127
FB01 D 2PL	2P	YES	2	6	0.130

Operational characteristics
 IEC rated voltage U_n : 1000VDC
 IEC rated current I_n : 32A
 IEC utilization category: DC20B 1000VDC
 Suitable for IEC fuse class: gPV
 IEC degree of protection: IP20

Reference standards
 Compliant with standards: IEC/EN 60269-1,
 IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3

Fuses for photovoltaic applications



FE01 D...

Order code	Rated current I_n [A]	Qty per pkg	Wt [kg]
For 10x38mm fuses. 30kA breaking capacity at 1000VDC.			
FE01 D 00200	2	10	0.008
FE01 D 00400	4	10	0.008
FE01 D 00600	6	10	0.008
FE01 D 00800	8	10	0.008
FE01 D 01000	10	10	0.008
FE01 D 01200	12	10	0.008
FE01 D 01600	16	10	0.008
FE01 D 02000	20	10	0.008

Operational characteristics
 IEC rated voltage U_n : 1000VDC
 IEC rated current I_n : 2-20A
 IEC fuse class: gPV


Reference standards
 Compliant with standards: IEC/EN 60269-6

Accessories



FBX 00

FBX 01
FBX 02



FBX 05



FBX 07

FBX 08



FBX 11


Order code	Description	Qty per pkg	Wt [kg]
	[A]	n°	[kg]
FBX 00	Coupling clip for 10x38, 14x51 and 22x58mm sizes	100	0.003
FBX 01	Coupling pin for 10x38mm size	100	0.005
FBX 02	Coupling pin for 14x51 and 22x58mm sizes	100	0.008
For FB01 A... and FB01 B... types.			
FBX 05	Three-phase connection busbar, for 57 modules in total, 1m/3.3ft long	10	0.465
FBX 07	One-pole terminal for 25mm ² max conductor	25	0.010
FBX 08	One-pole terminal for 50mm ² max conductor	25	0.020
FBX 11	End cap for FBX05 busbar	50	0.001

⊘ Not suitable for FB01 B1N, FB01 B2P, FB01 B3P and FB01 B3N types.



General and operational characteristics
THREE-PHASE BUSBAR
 Central point of power supply: 130A max
 Side point of power supply: 80A max
 Pitch: 18mm/0.7in
 Busbar section: 10mm²
 Number of modules/poles: 57
 For paralleling connection
 Length (standard supplied): 1m/3.3ft which can be cut in shorter sections

12

Fuse holder assembly in multiple pole configuration



⊘ Not suitable for FB01 B1N, FB01 B2P, FB01 B3P and FB01 B3N types.




Fuse holders

Dimensions [mm (in)]




FUSE HOLDERS


FB01 A... FB01 B... FB01 C... FB01 D...



FB02 A...




FB03 A...




12

FUSES

FE01 D 0...



Wiring diagrams



Fuse holders

Technical characteristics




TYPE	FB01 A...	FB01 B...	FB02 A...	FB03 A...	FB01 C...	FB01 D...
Range	AC				Class CC (AC)	DC
IEC maximum rated current In	32A		50A	125A	30A	32A
IEC maximum rated voltage Un	690VAC; 400VAC ◊	690VAC			600VAC	1000VDC
IEC utilisation category	AC22B 500V; AC21B 690V; AC22B 400V ◊			AC21B 690V	AC22B 500V; AC21B 690V	DC20B 1000VDC
Maximum power dissipation	3W		5W	9.5W	3W	4W
Derating factor of current In for different ambient temperatures	20°C	1				
	30°C	0.95				
	40°C	0.9				
	50°C	0.8				
	60°C	0.7				
	70°C	0.6				
Derating factor of current In for side-by-side fuse holders - n° poles	1-4	1				
	5-6	0.8				
	7-9	0.7				
	≥10	0.6				
Voltage for status indicator	120...690VAC		230...690VAC		120...600VAC	350...1000VDC
CONNECTIONS						
Maximum tightening torque	2.5Nm; 2Nm ◊ / 22lbin		3Nm / 26lbin	4Nm / 35lbin	2.5Nm / 22lbin	
Maximum conductor cross section	flexible/stranded	1x16mm ² ; 1-16mm ² ◊ / 8AWG	1x25mm ² / 8AWG	1x35mm ² / 2AWG	1x16mm ² / 8AWG	1x16mm ² / 6AWG
	rigid/solid	1x25mm ² ; 1-10mm ² ◊ / 8AWG	1x35mm ² / 8AWG	1x60mm ² / 1AWG	1x25mm ² / 10AWG	1x25mm ² / 4AWG
AMBIENT CONDITIONS						
Operating temperature	-20...+70°C					
Storage temperature	-40...+80°C					
Maximum altitude	3,000m					
Operation position	Any					
Fixing	On 35mm DIN rail (IEC/EN 60716)					

◊ Values valid only for FB01 A 1M type.

TECHNICAL CHARACTERISTICS FOR FE01 D... FUSES

TYPE	Rated current [A]	Power consumption at 0.7 In [W]	Power consumption at In [W]	Prearcing I ² t [A ² s]	Total I ² t at 1000VDC [A ² s]
FE01 D 00200	2	0.82	1.54	1.78	6.6
FE01 D 00400	4	0.73	1.84	3	11
FE01 D 00600	6	0.98	2.4	8.5	32
FE01 D 00800	8	1.02	2.55	25	93
FE01 D 01000	10	1.03	2.58	11	52
FE01 D 01200	12	1.04	2.6	25	116
FE01 D 01600	16	1.08	2.7	33	162
FE01 D 02000	20	1.16	2.9	85	390

TIME-CURRENT CHARACTERISTICS FOR FE01 D... FUSES



REVISIONS

1

2

3

4

5

6

7

8

9

10



Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web:www.kimtech.bg
e-mail: office@kimtech.bg

Описание на типа

за клемен блок с 3 еднополюсни предпазител разединители с цилиндрични
стояеми предпазител

Наименованието на клемния блок е ИК7ТК3Р


Клемния блок е съставен от 7бр. разединяеми клеми тип URTK/S и комплектован с допълнителни аксесоари към тях, 3 броя еднополюсни предпазител разединители тип FB01B и 3 броя цилиндрични стояеми предпазител 10x38 4А, съгласно изискванията на ЧЕЗ България.


Разединяемите клеми URTK/S и техните аксесоари са произведени от Phoenix Contact GmbH и са със страна на произход Германия.

Предпазител разединителите са произведени от Lovato Electric и са със страна на произход Италия

Клемите, аксесоарите им, предпазител разединителите и стояемите предпазител се произвеждат в клемен блок съгласно изискванията на ЧЕЗ България.

Подпис и печат






ОБЪЕКТ
ПРОЕКТА



ВИВ ИЗОМСТИК 001
 1680 София, ул. "Пирин" №10/А
 Тел. 02 938 63 40, 938 63 44, 958 91 11, факс 938 22 70

ОБЕКТ/Измервателен материал ЧЕЗ

ИСТИ		ЛИСТ №1 V 1		СЪГЛАСУВАЛИ:	
ФАЗИС ПЛ	ПОДСЕЛ -	ВЪЗ/ДЪЖИТЕЛИ			
		ЧЕРТАЩИ			
		Р-П	Фирма инж. Д.Л. Лазаров		



LOVATO ELECTRIC S.P.A.

Via Don E. Mazza, 12
24020 Gorle (BG) Italy
Tel: +39 035 4282111
Fax (National) +39 0354282200
Fax (International) +39 0354282400
E-mail: info@LovatoElectric.com
VAT ID No. IT 0192130016477

Questa dichiarazione è conforme alla Norma Europea EN45014 "Criteri generali del fornitore". Le basi per tali criteri sono documenti internazionali ed in particolare la Guida ISO/IEC 22 "Information on manufacture's declaration of conformity with standards or other technical specifications"

This declaration of conformity is in compliance with the European Standard EN 45014 "General criteria for supplier's declaration of conformity".

The basis for the criteria has been found in international documentation, particularly in: ISO/IEC Guide 22 "Information on manufacture's declaration of conformity with standards or other technical specifications"

Revisione:
Revision

Gorle, 04/03/2011
(luogo e data)
(place and data of issue)

DICHIARAZIONE DI CONFORMITA' DECLARATION OF CONFORMITY

Noi (denominazione del fornitore) **LOVATO ELECTRIC S.p.A.**
We (supplier's name)

(Indirizzo) **Via Don E. Mazza, 12 - 24020 Gorle - Bergamo - ITALY**
(address)

dichiariamo sotto la nostra esclusiva responsabilità che i prodotti
declare under our sole responsibility that the products

Portafusibili **FB..**
Fuseholders

(nome, tipo o modello, lotto o numero di serie, possibilmente l'origine e la quantità)
(name, type or model, batch or serial number, possibility sources and number of items)

sono conformi alle seguenti direttive
are in conformity with the following directives

Direttiva Bassa Tensione nr.2006/95/CE
Low Voltage Directive no.2006/95/EC

Direttiva Compatibilità Elettromagnetica nr.2004/108/CE
Electromagnetic Compatibility Directive no.2004/108/EC


Questo è documentato dalla conformità alle norme
This is documented by the conformity with the following standards

EN 60269-1

(Titolo e/o numero e data di pubblicazione della norma o di altri documenti normativi)
(Title and for number and date of issue of the standard or other normative documents)

Ing. D. Perani Product Manager

(Nome e firma della persona autorizzata)
(Name and signature of authorized person)



LOVATO ELECTRIC S.p.A.

DEVICE UNDER TEST Fuse holder *FB01B* types
MANUFACTURER..... Lovato Electric S.p.A.


TYPE OF TEST..... Temperature rise test on FB01B fuse holders

DATE OF DEVICE RECEIPT..... 27/04/2011
START / END TESTING 29/04/2011 – 13/05/2011

SAMPLES STORING..... Eliminated / returned to customer Storage :

INDEX.....	1. PURPOSE OF TESTING.....	2
	2. TEST SAMPLES.....	2
	3. TEST METHOD.....	2
	4. TEST PROCEDURES.....	2
	5. TEST RESULTS	3
	6. TEST EQUIPMENT	5
	7. REMARKS & ANALYS.....	5
	8. ANNEX.....	8

ISSUE 16/05/2011
COMPILED STAFF LPR
APPROVED RESP. LPR



The test results are related only to the exemplary tested and listed under the "test samples".

1. PURPOSE OF TESTING

Requested test (according to the customer specification):
Temperature rise at 690V – 32A on FB01B fuse holders

Test purpose:
"Verify the good function of FB01B fuse holders."

Test target:
Pass the test.

2. TEST SAMPLES

- N. 1 FB01B1P fuse holder - 32A (10 x 38 mm), batch production number ...¹
- N. 1 FB01B2P fuse holder - 32A (10 x 38 mm), batch production number ...¹
- N. 1 FB01B3P fuse holder - 32A (10 X 38 mm), batch production number ...¹

3. TEST METHOD

IEC 60947-3 (2008-08) Ed. 3.0 + IEC 60947-1 Ed. 5.1 (2011-03)
Temperature rise (§ 8.3.3.1)

4. TEST PROCEDURES

Temperature rise..... Test Instruction LPR 051-1, rev. 4, dated 11/10/2010.

¹ not available
¹ not available
¹ not available



КИМТЕХ
БЪЛГАРИЯ
БОРГАС

The test results are related only to the exemplary tested and listed under the "test samples".

6. TEST RESULTS

6.1 TEMPERATURE RISE

6.1.1 WITH LEGRAND FUSE 32 A gG 400 V

Sample under test.....N. 1 FB01B1P - 32A
N. 1 FB01B2P - 32A
N. 1 FB01B3P - 32A

Test conditions

Ambient temperature.....21 °C
Relative humidity.....46 %
Installation.....In vertical way, on DIN RAIL 35mm

Data sheet fusible used:

- SupplierLegrand
- Codecod. 133 32

Test parameters

Wiring of the main circuit


- cables section / length6,0 mm² / 1,0 m
- screws tightening nominal torque2,0 + 2,5 N.m
- screws applied tightening torque2,0 N.m

Supply of the main circuit

- rated current.....I_{th} = 25 - 32 A
- test current.....I = 32 A
- supply frequency.....50 Hz

Test results

See next page.



The test results are related only to the exemplary tested and listed under the "test samples".

Temperature rise main circuit

	[K]			Standard limit EN60947-1 tab. 2
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Terminal L1	43	54	57	65
Terminal T1	39	51	52	65
Terminal L2	-	55	61	65
Terminal T2	-	49	58	65
Terminal L3	-	-	57	65
Terminal T3	-	-	50	65
Note	Silver plated-brass terminal			

Temperature rise for accessible parts

	[K]			Standard limit EN60947-1 tab. 3
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Line side	14	24	29	40
Load side	10	19	21	40
Left side	24	30	32	40
Right side	22	30	31	40
On front	18	24	29	40
Lever	9	16	17	40




 ДИМИТЪР
 СТОЯНОВ

The test results are related only to the exemplary tested and listed under the "test samples".

6. TEST EQUIPMENT AND INSTRUMENTS

6.1. TEST EQUIPMENT

Description	Used for	Full scale	Code
Current supply station	Power supply main circuit	20V – 50A	LPRA 065

6.2. MEASURING INSTRUMENTS

Description	Used to measure	Full scale	Code	Calibration expiration date
Thermohygrometer	Ambient temperature	-5 + 50 °C	LPR 165	27/10/2011
Thermohygrometer	Relative humidity	10 + 90%	LPR 165	27/10/2011
Thermometric Instrument	Temperature rise	-30 + +200 °C	LPR 201	10/01/2012
Thermocouple T type	Temperature rise	-30 + +200 °C	LPR 201	10/01/2012
Thermocouple T type	Temperature rise	-30 + +200 °C	LPR 201.13	10/01/2012
Current transformer	Main circuit current	1.004/50 A	LPR 155	11/05/2014
Digital multimeter	Main circuit current	10 A	LPR 55	11/05/2012
Digital multimeter	Drop voltage	mV - Autom.	LPR 125	11/05/2012
Dynamometric screw driver	Main terminal screw tightening	6,0 Nm	LPR 231	07/01/2012

7. REMARKS & ANALYS


Temperature rise test 690V – 32A: test passed





The test results are related only to the exemplary tested and listed under the "test samples".

8. ANNEX

Picture 1: Temperature rise – test setup




Picture 1a: Temperature rise – test setup



ИЗПИТНО
ОПРЕДЕЛЕНИЕ

The test results are related only to the exemplary tested and listed under the "test samples".

Picture 2: Catalogue Legrand fuses



Informazioni tecnica, come a quote (p. 122)

Fusibili cilindrici			Tipo "eM"		
Interruttore (A)	Interruttore (A)	Interruttore (A)	Interruttore (A)	Interruttore (A)	Interruttore (A)
8,5 x 23 mm Rispondenti alla norma IEC EN 60269-1 Approvazione Bureau Veritas			8,5 x 31,5 mm Rispondenti alla norma IEC EN 60269-1 Approvazione Bureau Veritas		
10	012107	2	10	012001	1
10	012107	4	10	012002	2
10	012107	6	10	012003	4
10	012107	10	10	012004	6
10	012107	10	10	012005	10
10	012107	10	10	012006	10
10	012107	10	10	012007	10
10	012107	10	10	012008	10
10	012107	10	10	012009	10
10	012107	10	10	012010	10
10	012107	10	10	012011	10
10	012107	10	10	012012	10
10	012107	10	10	012013	10
10	012107	10	10	012014	10
10	012107	10	10	012015	10
10	012107	10	10	012016	10
10	012107	10	10	012017	10
10	012107	10	10	012018	10
10	012107	10	10	012019	10
10	012107	10	10	012020	10
10	012107	10	10	012021	10
10	012107	10	10	012022	10
10	012107	10	10	012023	10
10	012107	10	10	012024	10
10	012107	10	10	012025	10
10	012107	10	10	012026	10
10	012107	10	10	012027	10
10	012107	10	10	012028	10
10	012107	10	10	012029	10
10	012107	10	10	012030	10
10	012107	10	10	012031	10
10	012107	10	10	012032	10
10	012107	10	10	012033	10
10	012107	10	10	012034	10
10	012107	10	10	012035	10
10	012107	10	10	012036	10
10	012107	10	10	012037	10
10	012107	10	10	012038	10
10	012107	10	10	012039	10
10	012107	10	10	012040	10
10	012107	10	10	012041	10
10	012107	10	10	012042	10
10	012107	10	10	012043	10
10	012107	10	10	012044	10
10	012107	10	10	012045	10
10	012107	10	10	012046	10
10	012107	10	10	012047	10
10	012107	10	10	012048	10
10	012107	10	10	012049	10
10	012107	10	10	012050	10
10	012107	10	10	012051	10
10	012107	10	10	012052	10
10	012107	10	10	012053	10
10	012107	10	10	012054	10
10	012107	10	10	012055	10
10	012107	10	10	012056	10
10	012107	10	10	012057	10
10	012107	10	10	012058	10
10	012107	10	10	012059	10
10	012107	10	10	012060	10
10	012107	10	10	012061	10
10	012107	10	10	012062	10
10	012107	10	10	012063	10
10	012107	10	10	012064	10
10	012107	10	10	012065	10
10	012107	10	10	012066	10
10	012107	10	10	012067	10
10	012107	10	10	012068	10
10	012107	10	10	012069	10
10	012107	10	10	012070	10
10	012107	10	10	012071	10
10	012107	10	10	012072	10
10	012107	10	10	012073	10
10	012107	10	10	012074	10
10	012107	10	10	012075	10
10	012107	10	10	012076	10
10	012107	10	10	012077	10
10	012107	10	10	012078	10
10	012107	10	10	012079	10
10	012107	10	10	012080	10
10	012107	10	10	012081	10
10	012107	10	10	012082	10
10	012107	10	10	012083	10
10	012107	10	10	012084	10
10	012107	10	10	012085	10
10	012107	10	10	012086	10
10	012107	10	10	012087	10
10	012107	10	10	012088	10
10	012107	10	10	012089	10
10	012107	10	10	012090	10
10	012107	10	10	012091	10
10	012107	10	10	012092	10
10	012107	10	10	012093	10
10	012107	10	10	012094	10
10	012107	10	10	012095	10
10	012107	10	10	012096	10
10	012107	10	10	012097	10
10	012107	10	10	012098	10
10	012107	10	10	012099	10
10	012107	10	10	012100	10
10	012107	10	10	012101	10
10	012107	10	10	012102	10
10	012107	10	10	012103	10
10	012107	10	10	012104	10
10	012107	10	10	012105	10
10	012107	10	10	012106	10
10	012107	10	10	012107	10
10	012107	10	10	012108	10
10	012107	10	10	012109	10
10	012107	10	10	012110	10
10	012107	10	10	012111	10
10	012107	10	10	012112	10
10	012107	10	10	012113	10
10	012107	10	10	012114	10
10	012107	10	10	012115	10
10	012107	10	10	012116	10
10	012107	10	10	012117	10
10	012107	10	10	012118	10
10	012107	10	10	012119	10
10	012107	10	10	012120	10
10	012107	10	10	012121	10
10	012107	10	10	012122	10
10	012107	10	10	012123	10
10	012107	10	10	012124	10
10	012107	10	10	012125	10
10	012107	10	10	012126	10
10	012107	10	10	012127	10
10	012107	10	10	012128	10
10	012107	10	10	012129	10
10	012107	10	10	012130	10
10	012107	10	10	012131	10
10	012107	10	10	012132	10
10	012107	10	10	012133	10
10	012107	10	10	012134	10
10	012107	10	10	012135	10
10	012107	10	10	012136	10
10	012107	10	10	012137	10
10	012107	10	10	012138	10
10	012107	10	10	012139	10
10	012107	10	10	012140	10
10	012107	10	10	012141	10
10	012107	10	10	012142	10
10	012107	10	10	012143	10
10	012107	10	10	012144	10
10	012107	10	10	012145	10
10	012107	10	10	012146	10
10	012107	10	10	012147	10
10	012107	10	10	012148	10
10	012107	10	10	012149	10
10	012107	10	10	012150	10
10	012107	10	10	012151	10
10	012107	10	10	012152	10
10	012107	10	10	012153	10
10	012107	10	10	012154	10
10	012107	10	10	012155	10
10	012107	10	10	012156	10
10	012107	10	10	012157	10
10	012107	10	10	012158	10
10	012107	10	10	012159	10
10	012107	10	10	012160	10
10	012107	10	10	012161	10
10	012107	10	10	012162	10
10	012107	10	10	012163	10
10	012107	10	10	012164	10
10	012107	10	10	012165	10
10	012107	10	10	012166	10
10	012107	10	10	012167	10
10	012107	10	10	012168	10
10	012107	10	10	012169	10
10	012107	10	10	012170	10
10	012107	10	10	012171	10
10	012107	10	10	012172	10
10	012107	10	10	012173	10
10	012107	10	10	012174	10
10	012107	10	10	012175	10
10	012107	10	10	012176	10
10	012107	10	10	012177	10
10	012107	10	10	012178	10
10	012107	10	10	012179	10
10	012107	10	10	012180	10
10	012107	10	10	012181	10
10	012107	10	10	012182	10
10	012107	10	10	012183	10
10	012107	10	10	012184	10
10	012107	10	10	012185	10
10	012107	10			

CERTIFICATE

KEMA No. 97/007/3

Phoenix Contact GmbH & Co.
Flachsmarktstrasse 8-28
BLOMBERG, Germany

Manufacturer
Phoenix Contact GmbH & Co.
Flachsmarktstrasse 8-28
BLOMBERG, Germany

Product : Terminal blocks

Trade name : PHOENIX CONTACT
Types/models : URTK/S-BEN BU, URTK/S-BEN, URTK/S, URTK/SP,
USLKG 10, USLKG 6N

The product and any details about variations specified in the Annex to this certificate and the documents thereto referred to.

KEMA hereby declares that the above mentioned product has been certified on the basis of:

- a type test according to the standards EN 60947-7-1:1991, EN 60947-7-2:1995
- an inspection of the production location according to CCA Group Operational Requirement CCA 204
- a certificate of approval with the number 900469

KEMA hereby grants the right to use the KEMA certification mark



The KEMA KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA KEUR certification agreement and under the conditions of the KEMA KEUR certification agreement.


This certificate is issued on August 6, 1999.

C.M. Boshuizen
Certification Manager

Integral publication of this certificate is allowed.

N.V. KEMA
Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9035, 6800 ET Arnhem, The Netherlands
Telephone +31 26 3 56 28 50, Telefax +31 26 3 61 49 22

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



07/99

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

product : terminal blocks
 trade name : PHOENIX CONTACT
 types : URTK/S-BEN BU, URTK/S-BEN, URTK/S,
 URTK/SP, USLKG 10, USLKG 6N
 material : thermoplastic material
 mounting : top hat rail 35 mm (EN 50022) and G-profile
 rail 32 mm (EN 50035)

Additional Information

Markings

Trademark, type designation, rated connection capacity and rated insulation voltage are indented in the insulation material.

Product data – type USLKG 6N

rated connection capacity : 6 mm²
 connectable conductors : one conductor
 0,2 - 10 mm² solid
 0,2 - 6 mm² flexible without ferrule
 0,25 - 6 mm² flexible with ferrule
 two conductors
 0,2 - 2,5 mm² solid
 0,2 - 2,5 mm² flexible without ferrule
 0,25 - 1,5 mm² flexible with ferrule
 description : protective conductor terminal block with 2
 screw-type clamping units, 1-pole

Product data – type URTK/S

rated voltage : 400 V
 rated connection capacity : 6 mm²
 connectable conductors : one conductor
 0,5 - 10 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 10 mm² flexible with ferrule
 two conductors
 0,5 - 2,5 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 4 mm² flexible with ferrule
 rated impulse withstand voltage : 6 kV
 description : disconnect terminal block with 2 screw-type
 clamping units, 1-pole

N.V. KEMA

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
 P.O. Box 9036, 6800 ET ARNHEM, The Netherlands
 Telephone +31 26 3562860, Telefax +31 26 3514922



Product data – type URTK/SP

rated voltage : 500 V
rated connection capacity : 6 mm²
connectable conductors : one conductor
0,5 - 10 mm² solid
0,5 - 6 mm² flexible without ferrule
0,5 - 6 mm² flexible with ferrule
two conductors
0,5 - 2,5 mm² solid
0,5 - 4 mm² flexible without ferrule
0,5 - 2,5 mm² flexible with ferrule
rated impulse withstand voltage : 6 kV
description : disconnect terminal block with 2 screw-type
clamping units, 1-pole

TESTS**Test requirements**

EN 60947-7-1:1991 + C:1997-06 + A11:1997
EN 60947-7-2:1995 + C:1996-01

Test results

The test results are laid down in KEMA test file 97.4117.13.

Conclusion

The examination proved that all test requirements were met.

Tested by : H.L. Schendatok 

Checked by : L.J.W. van Meegen 

FACTORY-LOCATION(S)

Phoenix Contact GmbH & Co.
Flachsmarktstrasse 8-28, BLOMBERG, Germany

N.V. KEMA
Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9036, 6800 ET ARNHEM, The Netherlands
Telephone +31 26 3562850, Telefax +31 26 3514922



КИМТЕХ
БЪЛГАРИЯ



Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

Списък на проведените изпитвания на клемен блок с клеми за медни проводници
от проходен тип 1P, 3P и 3P+N

1. Изпитване покачване на температура.

13.01.2016г.

Подпис и печат



Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: **30-03-2010** to **01-03-2014**

Replaces annex dated: **30-06-2009**

Premises: **n.a.**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
LF 0 0	DC/LF Quantities			
LF 1 0	DC Voltage			
	Standard cells		3 μ V	
	Up to 1 mV		0,4 μ V	
	1 mV to 10 mV		$3 \cdot 10^{-4} \cdot U$	
	10 mV to 100 mV		$3 \cdot 10^{-5} \cdot U$	
	100 mV to 10 V		$5 \cdot 10^{-6} \cdot U$	
	10 V to 100 V		$1 \cdot 10^{-5} \cdot U$	
	100 V to 1100 V		$2 \cdot 10^{-5} \cdot U$	
	Zener Reference Standards			
	1 V and 1,018 V		3 μ V	
	10 V		20 μ V	
	High Voltage			Measuring
	1 kV to 6 kV		$2 \cdot 10^{-3} \cdot U$	
LF 2 0	DC Current			
	10 μ A to 3 A		$2 \cdot 10^{-5} \cdot I$	
	3 A to 10 A		$2,5 \cdot 10^{-5} \cdot I$	
	10 A to 20 A		$6 \cdot 10^{-5} \cdot I$	



This annex has been approved by:

Ir. J.C. van der Poel
Chief Executive


Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: 30-03-2010 to 01-03-2014

Replaces annex dated: 30-06-2009

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
	20 A to 100 A		$1 \cdot 10^{-4} \cdot I$	
LF 3 1	AC Voltage			
	60 mV to 1000 V	40 Hz to 20 kHz	$2 \cdot 10^{-4} \cdot U$	
	60 mV to 1000 V	20 kHz to 50 kHz	$3 \cdot 10^{-4} \cdot U$	
	60 mV to 220 V	20 kHz to 50 kHz 50 kHz to 100 kHz	$4 \cdot 10^{-4} \cdot U$	
	220 V to 1000 V	50 kHz to 100 kHz	$4 \cdot 10^{-4} \cdot U$	
	220 V to 1000 V	50 kHz to 100 kHz	$2 \cdot 10^{-3} \cdot U$	
	High Voltage			Measuring
	1 kV tot 6 kV	50 Hz	$2 \cdot 10^{-3} \cdot U$	
LF 3 2	AC Voltage Ratio (instrument transformers)			
	Primary: (10-600)V Secondary: (0,1-240)V	50 Hz and 60 Hz	$3 \cdot 10^{-5} \cdot U_{out}/U_{in}$ and 90 μ rad	
LF 3 3	AC Current			
	0,1 mA to 300 mA	40 Hz to 5 kHz	$3 \cdot 10^{-4} \cdot I$	
	300 mA to 20 A	40 Hz to 1 kHz	$3 \cdot 10^{-4} \cdot I$	
	20 A to 50 A	40 Hz to 1 kHz	$6 \cdot 10^{-4} \cdot I$	
LF 4 2	AC Current Ratio (instrument transformers)			
		50 Hz and 60 Hz	$3 \cdot 10^{-5} \cdot I_{out}/I_{in}$ and 90 μ rad	



2010-03-30
 2014-03-01
 2009-06-30

Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: 30-03-2010 to 01-03-2014

Replaces annex dated: 30-06-2009

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
	Primary: 5 A to 6000 A Secondary: 1A or 5A			
LF 4 3	High Current 10 A to 6000 A	50 Hz, 60 Hz	$3 \cdot 10^{-4} \cdot I$	
LF 5 0	Power and Energy Power 0,1 μ W to 1 μ W 1 μ W to 1 kW 1 kW tot 10 kW 10 kW tot 110 kW 3 W to 57,6 kW 3 W to 2,9 MW	50 Hz and 60 Hz 50 Hz and 60 Hz	$1 \cdot 10^{-4} \cdot P$ $5 \cdot 10^{-5} \cdot P$ $1 \cdot 10^{-4} \cdot P$ $2 \cdot 10^{-4} \cdot P$ $\frac{3 \cdot 10^{-4}}{\cos \varphi} \cdot P$ $\frac{2 \cdot 10^{-4}}{\cos \varphi} \cdot P$	10 mV to 1100 V, 10 μ A to 100 A on site to be performed at ambient temperature; voltage and current as mentioned above measuring 20 V to 1100 V 100 mA to 6000A $\cos \varphi = 0$ to 1
	Reactive Power (P_r) 6 var to 1,8 Mvar Electrical (reactive-) energy	50 Hz and 60 Hz	$\frac{5 \cdot 10^{-4}}{\sin \varphi} \cdot P_r$	60 V to 300 V 100 mA to 6000 A see (reactive-) power and time
LF 5 1	Power Factor $\cos \varphi$: 0 to 1	40 Hz to 100 Hz	$\frac{2 \cdot 10^{-3}}{\cos \varphi} \cdot PF$	



ВЪВЕДЕНА
ОПРАВИЛКА

Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: 30-03-2010 to 01-03-2014

Replaces annex dated: 30-06-2009

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
LF 6	Impedance (DC/LF)			
LF 6.2	DC Resistance			Non-decadic values
	20 $\mu\Omega$ to 50 $\mu\Omega$		$3 \cdot 10^{-4} \cdot R$	
	50 $\mu\Omega$ to 100 $\mu\Omega$		$1 \cdot 10^{-4} \cdot R$	
	100 $\mu\Omega$ to 20 k Ω		$1,2 \cdot 10^{-5} \cdot R$	
	1 m Ω to 10 m Ω		$6,5 \cdot 10^{-6} \cdot R$	
	10 m Ω to 1000 m Ω		$7 \cdot 10^{-6} \cdot R$	
	1 Ω to 10 k Ω		$5 \cdot 10^{-6} \cdot R$	
	10 k Ω to 1 M Ω		$1 \cdot 10^{-5} \cdot R$	
	1 M Ω to 10 M Ω		$1,2 \cdot 10^{-5} \cdot R$	
	10 M Ω to 100 M Ω		$3 \cdot 10^{-5} \cdot R$	
	100 $\mu\Omega$ to 10 k Ω		$6 \cdot 10^{-8} \cdot R$	Decadic Values
LF 6.4	Capacitance			
	LF Capacitance			accuracy depends on dissipation factor at 1 kHz
	10 pF to 100 pF	100 Hz, 1 kHz, 10 kHz	$1 \cdot 10^{-3} \cdot C$	
	1 μF	50 Hz, 200 Hz, 1 kHz	$1 \cdot 10^{-3} \cdot C$	
LF 6.7	Inductance			
	1 mH to 10 mH	1 kHz, (400-1692)Hz	$1 \cdot 10^{-3} \cdot L$	
	100 mH	100 Hz, 1 kHz, 1,592 kHz	$1 \cdot 10^{-3} \cdot L$	
	1 H	100 Hz, 200 Hz, 400 Hz and 1 kHz	$1 \cdot 10^{-3} \cdot L$	
RF 0.0	RF Quantities			
RF 3.0	RF Power			
	-9 dBm to +30 dBm	0,1 MHz to 4200 MHz	0,5 dB	Measuring 50 ohm coaxial VSWR
	+30 dBm to +57 dBm	0,1 MHz to 500 MHz	0,6 dB	
	-60 dBm to -10 dBm	10 MHz to 10000 MHz	0,5 dB	



Measuring 50 ohm coaxial VSWR

Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: **30-03-2010 to 01-03-2014**

Replaces annex dated: **30-06-2009**

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
	-80 dBm to -10 dBm	0,1 MHz to 2700 MHz	1,1 dB	source < 2 Generating: (0,09 - 3200) MHz
RF 5 0	Rise time (10% to 90%) 1 ns to 1 ms		$2 \cdot 10^{-2} \cdot \tau + 200$ ps	10 mV/div to 1 kV/div
TF 0 0	TIME and FREQUENCY			
TF2 1	Frequency	1 Hz to 1,2 GHz	$5 \cdot 10^{-10} \cdot f$	
TF 2 2	Time Interval	1 μ s to ∞	$5 \cdot 10^{-10} \cdot t + 100$ ns	
TF 3 2	Harmonic Distortion			(1)
	< 0,1 %	20 Hz to 2,5 kHz	$3 \cdot 10^{-4}$	
	0,1 % to 1 %	20 Hz to 2,5 kHz	$1 \cdot 10^{-3}$	
	1 % to 10 %	20 Hz to 2,5 kHz	$3 \cdot 10^{-3}$	
	10 % to 30 %	20 Hz to 2,5 kHz	$1 \cdot 10^{-2}$	
	30 % to 100 %	20 Hz to 2,5 kHz	$3 \cdot 10^{-2}$	

Part II, Mechanical quantities and Temperature

Measured quantity, Instrument, Gauge	Range	Best measurement capabilities ($k=2$)	Remarks
PV 1 0 Pressure Relative Pressure	(-10 to 10) kPa (-98 to 100) kPa 100 kPa to 10 MPa (10 to 70) MPa	$3 \cdot 10^{-4} \cdot p_0 + 4$ Pa $3 \cdot 10^{-4} \cdot p_0 + 5$ Pa $3 \cdot 10^{-4} \cdot p_0$ $3 \cdot 10^{-4} \cdot p_0$	(2) medium: air medium: nitrogen medium: nitrogen medium: oil



Annex to ISO/IEC 17025 declaration of accreditation
for registration number: K 006

of **KEMA Nederland B.V.**
Calibration & Metering
Arnhem

This annex is valid from: 30-03-2010 to 01-03-2014

Replaces annex dated: 30-06-2009

HCS code	Measured quantity, Range	Frequency	Best measurement capabilities ($k=2$)	Remarks
	Dry Block Calibrators	-20 °C to 650 °C	$(8 \cdot 10^{-4} \cdot t_{90} + 0,06)$ K	
	Writing thermometers	15 °C to 50 °C	0,5 K	including C.J. references resolution 1 digit
	Digital thermometers	-50 °C to 20 °C	0,02 K	
		20 °C to 50 °C	0,05 K	
		50 °C to 300 °C	0,05 K	
		300 °C to 550 °C	0,16 K	
		550 °C to 630 °C	0,50 K	
		630 °C to 1000 °C	1,5 K	

Remarks:

The ambient temperature during calibration is, unless specified otherwise, for:

- LF measurements @ $(23 \pm 1)^\circ\text{C}$
- TF measurements @ $(23 \pm 1)^\circ\text{C}$
- Pressure measurements @ $(23 \pm 2)^\circ\text{C}$
- Temperature measurements @ $(23 \pm 2)^\circ\text{C}$

- (1) The stated best measurement capabilities are based on the fundamental frequency of the input signal. If desired the distortion can be specified as a range number of the harmonics.
- (2) $p_r = p - p_{amb}$; p_r is the relative pressure, p_{amb} is the local air pressure, p is the absolute pressure.

The best measurement capability is the highest achievable accuracy for a given measuring value or measuring range, expressed as the total positive and negative measurement uncertainty.

The uncertainty is calculated according to EA-4/02 "Expression of the Uncertainty of Measurement in Calibration".

Calibrations are performed inside the laboratory, unless specified otherwise.

KEMA
 NEDERLAND
 CALIBRATION



C

Cylindrical fuse-links	158
Fuse disconnectors for cylindrical fuse-links for AC and DC systems	160
Technical data	400



LOW VOLTAGE CYLINDRICAL FUSES



POWER NEEDS CONTROL

Cylindrical fuse-links

Cylindrical fuse-link CH

rated current: 1-100 A
 rated voltage: 60, 690 V


Application: Cylindrical fuse-links are used as the most secure protection of electrical installations, control, and signal circuits against overloads and short circuit currents. Their dimensions comply with IEC 60269-1 and IEC 60269-2-1. They are used mainly in industrial areas, since their dimensions allow voltages of up to 690 V. The most common sizes are the following four: 8x32, 10x38, 14x51 and 22x58.



CH10	rated current / rated voltage	code No. 06	code No. 01	weight (g)	packaging (pcs)
	1A/400V	002610000	002611000	4	10/740
	2A/400V	002610001	002611001		
	4A/400V	002610003	002611003		
	6A/400V	002610005	002611005		
	8A/400V	002610006	002611006		
	10A/400V	002610007	002611007		
	12A/400V	002610008	002611008		
	16A/400V	002610009	002611009		
	20A/400V	002610011	002611011		
	25A/400V	002610013	002611013		



CH100	rated current / rated voltage	code No. 06	code No. 01	weight (g)	packaging (pcs)
	0.5A/500V	002620017	002621017	7,5	10/500
	1A/500V	002620000	002621000		
	2A/500V	002620001	002621001		
	4A/500V	002620003	002621003		
	6A/500V	002620005	002621005		
	8A/500V	002620006	002621006		
	10A/500V	002620007	002621007		
	12A/500V	002620008	002621008		
	16A/500V	002620009	002621009		
	20A/500V (100V a.U.)	002620011	002621011		
	25A/500V (100V a.U.)	002620013	002621013		
	32A/500V	002620015	002621015		




Cylindrical fuse-links

rated current (A)	code No. 06	NEW!		code No. 08	code No. 09	weight (g)	packing (100)
		code No. 06 with stroke 010	code No. 07				
2A, 690V	002630001	006711015*	002631001	006711018*		18,6	10/200
4A, 690V	002630003	006711005*	002631003	006711030*			
6A, 690V	002630005	006711016*	002631005	006711031*			
8A, 690V	002630006	006711017*	002631006	006711032*			
10A, 690V	002630007	006711018*	002631007	006711033*			
12A, 690V	002630008	006711006*	002631008	006711034*			
16A, 690V	002630009	006711001*	002631009	006711035*			
20A, 690V	002630011	006711002*	002631011	006711036*			
25A, 690V	002630013	006711003*	002631013	006711037*			
32A, 690V	002630015	006711019*	002631015**	006711038*			
40A, 690V	002630017	006711004*	002631017	006711039*			
60A, 690V	002630019	006711020**	002631019**	006711040*			

*500V
**400V




rated current (A)	code No. 06	NEW!		code No. 08	code No. 09	weight (g)	packing (100)
		code No. 06 with stroke 010	code No. 07				
4A, 690V		006711008				51	10/480
6A, 690V		006711009					
8A, 690V		006711021					
10A, 690V		006711010					
12A, 690V		006711022					
16A, 690V	002640009	006711023	002641009	006711045			
20A, 690V	002640011	006711024	002641011	006711046			
25A, 690V	002640013	006711025	002641013	006711047			
32A, 690V	002640015	006711011	002641015	006711048			
40A, 690V	002640017	006711026	002641017	006711049			
50A, 690V	002640019	006711027	002641019	006711050			
63A, 690V	002640021	006711012	002641021	006711051			
80A, 690V	002640023	006711013	002641023	006711052			
100A, 690V	002640025	006711014	002641025	006711053			




Fuse disconnectors for cylindrical fuse-links

Advantages of fuse disconnectors PCF


→ 1 pole + N in one module






→ Double connection clamps



→ New method of mounting on the DIN rail and simple replacement




→ LED indicator version




→ Extraction of entire fuse-link when changing

→ Chamber for spare fuse-link



→ Sealing possibility



Fuse disconnectors (one or more fuse-links)

Fuse disconnecter PCF 8

Rated current max. 20 A Rated operating voltage 400 V Rated frequency AC 220

1-pole		code no.	indicator	weight (g)	part no. (P3)
U _N (V)	I _N (A)				
400	20	002530001	-	58	12/108
		002530011	LED		
		*002531001	-		
		*002531011	LED		

NEW!

*Connection clamp on the right side "French version"



1-pole		code no.	indicator	weight (g)	part no. (P3)
U _N (V)	I _N (A)				
400	20	002530002	-	70	12/108
		002530012	LED		
		*002531002	-		
		*002531012	LED		


NEW!

*Connection clamp on the right side, N pole on the left "French version"

2-pole		code no.	indicator	weight (g)	part no. (P3)
U _N (V)	I _N (A)				
400	20	002530003	-	120	6/54
		002530013	LED		
		*002531003	-		
		*002531013	LED		

NEW!


*Connection clamp on the right side "French version"



3-pole		code no.	indicator	weight (g)	part no. (P3)
U _N (V)	I _N (A)				
400	20	002530004	-	180	4/36
		002530014	LED		
		*002531004	-		
		*002531014	LED		

NEW!

*Connection clamp on the right side "French version"



3-pole + N		code no.	indicator	weight (g)	part no. (P3)
U _N (V)	I _N (A)				
400	20	002530005	-	195	4/36
		002530015	LED		
		*002531005	-		
		*002531015	LED		

NEW!


*Connection clamp on the right side, N pole on the left "French version"

Handwritten signature or initials.



Fuse disconnector PCF 10


Rated current max. 32 A Rated operational voltage 690 V a.c. Rated short-circuit capacity AC22B



Type	U _N (V)	I _N (A)	code No.	Indicator	width (g)	packing (pcs)
690	32		002550001	-	58	12/108
			002550011	LED		
			*002551001	-	58	12/108
			*002551011	LED		

*Connection clamp on the right side *French version*


NEW!



Type - N	U _N (V)	I _N (A)	code No.	Indicator	width (g)	packing (pcs)
690/690	32		002550002	-	70	12/108
			002550012	LED		
			*002551002	-	70	12/108
			*002551012	LED		

*Connection clamp on the right side, N pole on the left *French version*

NEW!



Type	U _N (V)	I _N (A)	code No.	Indicator	width (g)	packing (pcs)
690	32		002550003	-	120	6/54
			002550013	LED		
			*002551003	-	120	6/54
			*002551013	LED		

*Connection clamp on the right side *French version*

NEW!

Type	U _N (V)	I _N (A)	code No.	Indicator	width (g)	packing (pcs)
690	32		002550004	-	180	4/36
			002550014	LED		
			*002551004	-	180	4/36
			*002551014	LED		

*Connection clamp on the right side *French version*

NEW!

Type - N	U _N (V)	I _N (A)	code No.	Indicator	width (g)	packing (pcs)
690	32		002550005	-	195	4/36
			002550015	LED		
			*002551005	-	195	4/36
			*002551015	LED		

*Connection clamp on the right side, N pole on the left *French version*

NEW!



Fuse disconnectors for cylindrical fuse-links




Fuse disconnector PCF CC

Rated current max. 30 A	Rated operating voltage 600 V	Protection class AC22B
----------------------------	----------------------------------	---------------------------

1-pole		code no.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
600	30	002550101	-	58	12/108
		002550111	LED		

2-pole		code no.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
600	30	002550103	-	120	6/54
		002550113	LED		

3-pole		code no.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
600	30	002550104	-	180	4/36
		002550114	LED		



Accessories

Fuse disconnector PS PCF						
U _N (V)	I _N (A)	code no. PCF	code no. PCF10	weight (g)	packaging (pcs)	contacts
230	30	002559001	002559001	35	1/10	1xb 1xa/b



General information about fuse disconnecter VLC

The main characteristics of ETI fuse disconnectors are:

- ☒ Compliance with IEC 60947-1, IEC 60947-3, UL 512 and UL 486 E.
- ☒ Plastic parts are made of material resistant to high temperatures.
- ☒ All contact surfaces are silver plated.
- ☒ Mounting on standard DIN 35 mm rail (DIN EN 60715). The sizes 14x51 and 22x58 can be also fixed with screws on a flat base.
- ☒ For all sizes a version with electronic indicator is available. There are two technical types of indicator:
 - a) I (LED) with built-in LED diode which blinks after the fuse-link operates. The internal circuit resistance is 2 MΩ, thus the total dissipation is minimal. The indicator is capable of operating in conditions of open circuit with minimum capacitance between connection cables. Operating voltage range spans from 50 V to 690 V a.c. and d.c.
 - b) I (NEON) with neon lamp which is constantly lit after the fuse-link operates. The internal circuit resistance is 570 kΩ, thus it is necessary for the circuit to be closed in order for the indicator to function. The operational voltage range is 100 V to 750 V a.c.
- ☒ Modular design—it is possible to assemble multi pole versions on customer's site for VLC8, VLC 10, VLC 14 and VLC 22.

Fuse disconnecter VLC 8

max. 20 A 400 V AC22



U ₀ /U _e (V)	I _n (A)	model	indicator	weight (g)	packing (pcs)
200	20	002521000	-	65	12/108
		002521100	I-LED		
		002521200	I-NEON		

1-pole+N		U ₀ /U _e (V)	I _n (A)	model	indicator	weight (g)	packing (pcs)
200	20	20	20	002522000	-	128	6/54
				002522100	I-LED		
				002522200	I-NEON		
				002522001	-		
				002522101	I-LED		
002522201	I-NEON	128	6/54				


*N-pole on left "French version"

**ВЯРНО С
ОРИГИНАЛА**




Fuse disconnectors for cylindrical fuse holders

2-pole		code No.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
400	20	002523000	-	124	6/54
		002523100	L-LED		
		002523200	I-NEON		



3-pole		code No.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
400	20	002524000	-	187	4/36
		002524100	L-LED		
		002524700	I-NEON		



3-pole		code No.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
400	20	002525000	-	270	3/27
		002525100	L-LED		
		002525200	I-NEON		
		002525001	-	270	3/27
		002525101	L-LED		
		002525201	I-NEON		


NEW!

*N pole on left "French version"

Fuse disconnector VLC 10

max 32 A 690 V AC228

1-pole		code No.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
690	32	002541000	-	65	12/108
		002541100	L-LED		
		002541200	I-NEON		



3-pole		code No.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
400/690	32	002542000	-	128	6/54
		002542100	L-LED		
		002542200	I-NEON		
		002542001	-	128	6/54
		002542101	L-LED		
		002542201	I-NEON		

NEW!


*N pole on left "French version"

**ВЯРНО С
ОРИГИНАЛА**




ETI

Fuse disconnectors for cylindrical fuse-links



2 poles	U _N (V)	I _N (A)	code No.	indicator	width (mm)	packing (pcs)
600	30	32	002543000	-	124	6/54
			002543100	L-LED		
			002543200	I-NEON		




3 poles	U _N (V)	I _N (A)	code No.	indicator	width (mm)	packing (pcs)
600	30	32	002544000	-	187	4/36
			002544100	L-LED		
			002544200	I-NEON		

3 poles + N	U _N (V)	I _N (A)	code No.	indicator	width (mm)	packing (pcs)
600	30	32	002545000	-	270	3/27
			002545100	L-LED		
			002545200	I-NEON		
			002545001	-		
			002545101	L-LED		
002545201	I-NEON	270	3/27	NEW!		

*N pole on left "French version"

Fuse disconnecter VLC CC

Rated current MAX 30 A	Rated voltage 600 V	Overcurrent category AC22B
---------------------------	------------------------	-------------------------------




1 pole	U _N (V)	I _N (A)	code No.	indicator	width (mm)	packing (pcs)
600	30	32	002541300	-	65	12/108

2 poles	U _N (V)	I _N (A)	code No.	indicator	width (mm)	packing (pcs)
600	30	32	002543300	-	124	6/54

3 poles	U _N (V)	I _N (A)	code No.	indicator	width (mm)	packing (pcs)
600	30	32	002544300	-	187	4/36

ВЯРНО С
ОРИГИНАЛА



Fuse disconnectors for cylindrical fuse links

Varovalčni ločilnik VLC 14


Rated current max. 30 A Rated operating voltage 690 V Terminal category AC22B

1 pole	U/V	I/A	code No.	indicator	weight (g)	packaging (pcs)
690	50	30	002561000	-	100	12/96
			002561100	L-LED		


1 pole N	U/V	I/A	code No.	indicator	weight (g)	packaging (pcs)
690	50	30	002562000	-	222	6/48
			002562100	L-LED		
			*002562001	-		
			*002562101	L-LED		

*N pole on left "French version"


NEW!



2 poles	U/V	I/A	code No.	indicator	weight (g)	packaging (pcs)
690	50	30	002563000	-	201	6/48
			002563100	L-LED		



3 poles	U/V	I/A	code No.	indicator	weight (g)	packaging (pcs)
690	50	30	002564000	-	308	4/32
			002564100	L-LED		



3 pole N	U/V	I/A	code No.	indicator	weight (g)	packaging (pcs)
690	50	30	002565000	-	437	3/24
			002565100	L-LED		
			*002565001	-		
			*002565101	L-LED		

*N pole on left "French version"

NEW!


Fuse disconnecter VLC 22

Rated current max. 100 A Rated operating voltage 690 V Terminal category AC21B

1 pole	U/V	I/A	code No.	indicator	weight (g)	packaging (pcs)
690	100	100	002571000	-	160	3/105
			002571100	L-LED		

**ВЯРНО С
ОРИГИНАЛА**






1 pole + N		code No.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
690	100	002572000	-	355	2/48
		002572100	L-LED		
		002572001	-	355	2/48
		002572101	L-LED		


*N pole on left *French version*

NEW!



2 poles		code No.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
690	100	002573000	-	310	2/48
		002573100	L-LED		

3 poles		code No.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
690	100	002574000	-	480	1/35
		002574100	L-LED		



4 pole + N		code No.	indicator	weight (g)	packaging (pcs)
U _N (V)	I _N (A)				
690	100	002575000	-	680	1/24
		002575100	L-LED		
		002575001	-	680	1/24
		002575101	L-LED		

*N pole on left *French version*

NEW!


Accessories



Auxiliary switch PS VLC		code No. VLC1	code No. VLC2	weight (g)	packaging (pcs)	contacts
U _N (V)	I _N (A)					
230	6	002569001	002579001	50	1/10	1xmake 1xbreak


Auxiliary switch PS VLC is intended to be mounted with disconnectors VLC 14 and VLC 22 for all versions (1p, 2p, 2p+N, 3p, 3p+N). The width of apparatus is 9mm, other dimensions comply with VLC 14 and VLC 22 series switches. Auxiliary switch PS VLC signals the operation of CH14 or CH22 fuse-links only in the case a fuse-link is mounted with striking pin - see IEC 60 269-2-1 Figure 1a (III).

BRAND NEW




Cylindrical fuse-link

Technical data	
Rated Voltage	400 V a.c., 500 V a.c., 690 V a.c.
Rated current	CH 8 1-25 A/400 V
	CH 10 0,5-16 A/500 V, 20-32 A/400 V
	CH 14 2-25 A/690 V, 32-50 A/500 V
	CH 22 16-40 A/690 V (50 A/690 V aM), 50-100 A/500 V
Rated frequency	50 Hz
Rated breaking capacity	CH 8 50 kA
	CH 10 100 kA
	CH 14 2-25 A/80 kA, 32-50 A/120 kA
	CH 22 16-40 A/80 kA (50 A/80 kA aM), 50-100 A/120 kA
Characteristics	gG, aM
Body material	ceramic
Material of contact parts	CuZn28, gal Ag



Series	Length (mm)	End cap length (mm)	End cap diameter (mm)	Body diameter (mm)	Weight (g)
8x37	31,5±0,5	6,7	8,5±0,1	4	1±0,5
10x38	38,0±0,6	10,5	10,3±0,1	6	1,5±0,5
14x51	51,0±0,6	13,8	14,3±0,1	7,5	2,1
22x58	58,0±0,1	16,2	22,2±0,1	11	2,1





Series	Length (mm)	End cap length (mm)	End cap diameter (mm)	Body diameter (mm)	Weight (g)
14x51	51,0	13,8	14,3	7,5	2,1
22x58	58,0	16,2	22,2	11	2,1

With striker pin


**ВЯРНО С
ОРИГИНАЛА**




Technical data - C




**ВЯРНО С
ОРИГИНАЛА**





Melting energy characteristics Pt CH8




Time current characteristics It, gG CH10




Technical data - C




ВЪРХО С
ОРИГИНАЛ



Time current characteristics I_t, gG CH14



Cut-off current characteristics CH14




**ВЯРНО С
ОРИГИНАЛА**




Technical data - C


Melting energy characteristics Pt CH14




Time current characteristics I_t, gG CH22




**ВЯРНО С
ОРИГИНАЛА**



Cut-off current characteristics CH22



Melting energy characteristics P1 CH22




ВЯРНО С
ОПРЕДЕЛЕНА




Technical data - C

Time current characteristics I/t, aM CH10, 14, 22



Time current characteristics I/t, aM CH10, 14, 22




**ВЯРНО С
ОРИГИНАЛА**



Fuse disconnectors for cylindrical fuse-links


Technical data							
Model	V1C0	PCF	V1C10	V1C10	V1C20	V1C20	V1C20
Number of poles	1p, 1p+N, 2p, 3p, 3p+N		1p, 2p, 3p		1p, 1p+N, 2p, 3p, 3p+N		
Type of current	a.c.						
Utilization category	AC-22B						AC1-B
Rated Operational Voltage Ue (V)	400	400	400/690 1p+N	400/690 1p+N	600	690	690
Rated frequency (Hz)	50		60		50		
Rated impulse withstand voltage Uimp (kV)	8	4	8	4	8	6	8
Rated operational current (A)	20	20	32	32	30	50	125
Rated short-circuit withstand Icw (kA)	240	240	390	390	160	600	1500
Rated conditional short-circuit current (kA)	50	100	200	200	100	100	100
Cage clamp (max mm)	25	10	25	10	25	35	50
Maximal power dissipation (W)	2,5	2,5	3	3	3	5	9,5
Test reports	UL	Int.	CCA/CB, UL UL/CSA	CCA/CB, UL	Int., UL	CCA/CB, UL CSA	CCA/CB

Fuse disconnecter PCF




Fuse disconnecter PCF 8, PCF 10	
Type	Dimension
B	8
1p	17,3
1p+N	17,3
2p	35,6
3p	37,1
3p+N	51,4

Auxiliary switch PS PCF




ВАРНО С
ОРИГИНАЛА



Technical parameter	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3
rated current (A)	25	30	50	50	125	32	20	25		
rated voltage (V)	1000	600	690	1000	690	400/690 1P+N	1000	900		
type of current	d.c.	a.c.	a.c.	d.c.	a.c.	a.c.	d.c.	d.c.		
max power dissipation of the fuse-link (W)	3	3	5	5	9,5	3	3	3		
AC22-B acc. IEC 60947-3	AC22-B	AC22-B	AC22-B	AC22-B	AC21-B	AC22-B	AC22-B	AC22-B		
DC20-B acc. IEC 60947-3	DC20-B	DC20-B	DC20-B	DC20-B		DC20-B	DC20-B	DC20-B		
rated conditional short-circuit current (kA)	25	200	100	50	100	100/200	25	25		
rated short-time withstand current (A)	300	360	600	600	1500	390	240	300		
operating cycles (mech)	2000	1700	1700	2000	1400	1700	2000	2000		
operating cycles (electr.)	0	2000	300	0	200	300	0	0		
operating ambient temperature (°C)	-5...+40	-5...+40	-5...+40	-5...+40	-5...+40	-5...+40	-5...+40	-5...+40		
cross section (mm ²)	1,5...2,5	1,5...2,5	1,5...3,5	1,5...3,5	4...5,0	0,5...1,0	0,5...1,0	0,5...1,0		
torque (Nm)	2,5	2,5	3	3	3	1,2	1,2	1,2		
rated insulation voltage (V)	1000	600	690	1000	390	690	1000	900		
rated imp. withstand voltage (kV)	8	8	8	8	8	4	4	4		
overvoltage category	Overvoltage category III (according to Table H.1 in IEC 60947-1 and according to IEC 60099-1)									
	CCA/CB		CCA/CB	CCA/CB	CCA/CB	CCA/CB	CCA/CB	CCA/CB	Int.	Int.
	UL		UL	UL	UL	UL	UL	UL	UL	Int.

**ВЯРНО
ОРИГИНАЛ**

Version with signal detector LED indicator	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3	IEC 60947-3
UL max. voltage a.c. (V)	50/690		50/690	50/690	50/690	50/690	50/690	50/900
UL max. voltage d.c. (V)	50/1.000		50/1.000	50/1.000	50/1.000	50/1.000	50/1.000	50/900





ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Производител: ETI Elektroelement d.d.
Адрес: ETI Elektroelement d.d.
Obrezija 5
1411 Izlake
Slovenia

Продукт: Основа-расединител за цилиндрични стопяеми предпазители VLS
Размер: VLS10 1р, 1р+N, 2р, 3р, 3р+N
32A/690V a.c.

Продуктите отговарят на следните Европейски директиви:

Директива: 2006/95/EC
Директива на Европейския парламент и на Съвета на 12 Декември 2006 за хармонизиране на законите на държавите членки отнасящи се до електро оборудване, проектирано за употреба в определени граници на напрежение.

Хармонизирани
Стандарти: EN 60947-1:2007, EN 60947-3:1999/A2:2005, EN 60947-3:2008,

Описаните продукти са произведени съгласно изискванията на съответните стандарти и с това изпълняват изискванията на Европейската директива.

Стандарти: IEC 60947-1 Ed.5.0:2007, IEC 60947-3 Ed.3:2008

Протоколи от изпитания: CB/ССА/No. 2.03.00938.1.0/VLS10/CB/ССА
Маркировка CE: На продукта; на опаковката

Място и дата: София, 01 юни 2013

Представяващ производителя Александър Маркович



ВЯРНО С
ОРИГИНАЛА



Accredited by BMMVA, No. BMMVA-92.714/0532-I/12/2006 as test- and inspection body
and according to BGBl. II, No. 244/2006 as certification body for personnel

arsenal research
Ein Unternehmen der Austrian Research Centers

Test Report

Project Designation

TYPE TEST AT FUSE-SWITCH-DISCONNECTORS FOR CYLINDRICAL FUSE-LINKS TYPE VLC 10

Client

ETI Elektroelement d.d.
1411 Izlake, Obrežlja 5
SLOVENIA

Order form / No. 09/2008 / ---


Project Number 2.03.00938.1.0/VLC10 Test Engineer Ing. J. Alnetter

Date of issue	26.01.2009
Total number of issues / No.	1 / 1
Number of pages	5
Annex	CB/CCA - Test Report No. 2.03.00938.1.0/VLC10/CB/CCA (30 pages)

The results relate exclusively to the terms tested.

This report may only be reproduced or published in full, without omissions, alterations or additions.

The reproduction or publishing of extracts from this report requires the written approval of the research center.



Test Item

Identification:

Low-voltage fuse-switch-disconnectors for cylindrical fuse-links type VLC 10

Manufacturer: ETI Elektroelement d.d.
Trademark: ETI
Number of poles: 1p, 1p+N, 2p, 3p, 3p+N
Rated operational voltage(s): 400V up to 690V
Rated operational current(s): 10A up to 32A
Rated frequency: 50Hz

Technical data and description:

See page 4

Testing location, Period of testing

Testing location:

Österreichisches Forschungs- und Prüfzentrum Arsenal Ges.m.b.H.
Business Unit Monitoring, Energy and Drive Technologies – Power Service Center
Gleifinggasse 2
1210 Wien
AUSTRIA

Period of testing:

10 ... 12/2008

Test(s)

Test(s) performed:

Type test

Test standard(s):

IEC 60947-1:2007 (5th Edition) and IEC 60947-3:2008 (3rd Edition)
EN 60947-1:2007 and EN 60947-3:1998+A1:2001+A2:2005


Test procedure(s):

CB Scheme and CCA Scheme

Result

The low-voltage fuse-switch-disconnectors for cylindrical fuse-links type VLC 10 have passed the type test successfully.


Test Engineer



Ing. J. Alnetter



Project Engineer,
technical responsibility




Ing. K. Farthofer




ВЯРНО С
ОРИГИНАЛА

Testing laboratory




ACCREDITED
according to
EN ISO/IEC 17025
No. BMWA-92.714/0532-V12/2006



CERTIFICATED
according to
ISO 9001
Reg. No. 12769-03




RECOGNIZED
CB TESTING LABORATORY
under the responsibility of OVE
as the National Certification Body



PSC – POWER SERVICE CENTER:



Control station for tests up to 15kA



Control station for tests above 15kA



Technical data and description

Test Item	Low-voltage fuse-switch-disconnectors for use with cylindrical fuse-links
Trademark	ETI
Model/Type reference	VLC 10
Manufacturer	ETI Elektroelement d.d.
Place of manufacture	1411 Izlake, Obrezlja 5
Method of operation	Dependent manual operation
Switching positions	ON / OFF
Number of poles	1p, 1p+N, 2p, 3p, 3p+N
Nature of supply	AC
Utilization category	AC-22B at 690V/32A
Rated operational voltage	p to 69000V up t
Rated operational current	p to 32A10A up t
Rated frequency	50Hz
Conventional free air thermal current	10A up to 32A (max. 3W)
Rated insulation voltage	690V
Rated impulse withstand voltage	8kV
Rated short-time withstand current	300A / 1s
Rated conditional short-circuit current	100kA at 400V (with 32A fuse-links)
Kind of protective device	Cylindrical fuse-link CH 10 (10 x 38)
Degree of protection	IP 20



Measuring equipment

Measured quantity	Device	Manufacturer	Code
Voltage (tests up to 15kA)	Voltage divider 1:2000 Difference amplifier AM 502 Signal memory recorder TRA 800	ÖFPZ Arsenal Tektronix W&W	- AM 502/1...3 TRA800
Current (tests up to 15kA)	LIn. current transformer LGSSO Burden 1Ω Signal memory recorder TRA 800	Ritz ÖFPZ Arsenal W&W	WLIN5000/1...3 - TRA800
Current (tests at reduced voltage)	Current transformer GE 4451 Current transformer AET110 True-RMS amperemeter Kl. 0,5 Digital multimeter Fluke 185	Goerz Siemens Norma Fluke	W1800/1...3 W14000/1...3 A0,5/1...3 FLUKE185/1, 2
Transient recovery voltage	Adjustment equipment for TRV Oscilloscope G 801.1	ÖFPZ Arsenal Tektronix	- G801.1
Dielectric properties	High-voltage test equipment 90-1F with measuring equipment Impulse tester 35 Impulse voltmeter 64M Oscilloscope 8410	Elabo Haefely Haefely Le Croy	HSG5KV G304 G502 G803
Leakage current	High-voltage test equipment 90-1F Digital multimeter Fluke 185 Digital multimeter Fluke 185	Elabo Fluke Fluke	HSG5KV FLUKE185/1 FLUKE185/2
Time	Signal memory recorder TRA 800 Stopwatch	W&W Junghans	TRA800 938-2
Temperature	24-channel recorder Polycomp SK30 Temperature meter TESTO 901	H & B Testoterm	SK 30 TESTO
Abnormal heat and fire	Glow-wire test device with measuring equipment	ÖFPZ Arsenal	-
Mechanical strength of terminals	Test equipment	ÖFPZ Arsenal	-
Insertability of unprepared conductors	Gauges	ÖFPZ Arsenal	-
Strength of actuator mechanism	Test equipment	Schatz	-
Degree of protection	Test probe	PTL	-
Clearances, creepage distances	Digital slide gauge CD-20D	Mitutoyo	SCHUB





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

**Списък на проведените изпитвания на Триполюсни и еднополюсни стопяем
цилиндричен предпазител-прекъсвач-разединители, размер 10x38 mm**

1. Изпитване напрежение до 15kV;
2. Изпитване ток до 15kV;
3. Изпитване ток при редуцирано напрежение;
4. Възстановяване на предходно напрежение;
5. Диелектрични свойства;
6. Ток на утечка;
7. Време;
8. Температура
9. Анормално нагряване и пламък;
10. Механична якост;
11. Нестабилност на неподготвени проводници;
12. Якост на задвижващия механизъм;
13. Степен на защита;
14. Отстояния, утечки;

13.01.2016г.

Подпис и печат





TRANSLATION AGENCY

Превод от английски език

50 Hristo Smirnenski Blvd.
1164, Sofia, Bulgaria

T +359 2 9804090
F +359 2 9817160
office@greg-bg.com
www.greg-bg.com

Фирмена бланка на Akkreditierung Austria

Националният акредитиращ орган

Akkreditierung Austria

потвърждава акредитацията на

Лаборатория за изпитване

AIT Austrian Institute of Technology GmbH
ул. Донау-Сити 1, А-1220 Виена
Идентификационен номер: 0001

Акредитацията е въз основа на:
ÖVE/ÖNORM EN ISO/IEC 17025:2007
Начална дата на акредитация: 01.12.1993 г.

Информация относно обхвата на акредитацията и Akkreditierung Austria
<http://www.bmvfw.gv.at/akkreditierung>

Тази акредитация е предоставена със сертификат, който потвърждава че Органът за оценка за съответствието - включително обектите, посочени в сертификата – отговаря на изискванията на ÖVE/ÖNORM EN ISO/IEC 17025:2007. Това потвърждение за акредитация може да бъде възпроизведено само в пълна форма.


12.08.2014 г.
Дата

(подпис не се чете)
Допл. инж. д-р. Норман Брунер
Ръководител на Акредитация Австрия

Кръгъл фирмен печат

Долуподписаният, Жасмин Кръстев Кръстев, удостоверявам верността на извършения от мен превод от английски език на български език на приложения документ: Удостоверение за акредитация с дата 12.08.2014 г. Преводът се състои от 1 стр.

Подпис: 
Жасмин Кръстев Кръстев



Жасмин Кръстев Кръстев



Die Nationale Akkreditierungsstelle / *The National Accreditation Body*

AKKREDITIERUNG AUSTRIA

bestätigt die Akkreditierung der / *confirms the accreditation of*

Prüfstelle / *Testing Laboratory*

AIT Austrian Institute of Technology GmbH

Donau-City-Straße 1, A-1220 Wien

Identifikationsnummer / *ID-number* **0001**

Akkreditierungsgrundlage / *Accreditation basis*:

ÖVE/ÖNORM EN ISO/IEC 17025:2007

Datum der Erstakkreditierung / *Initial date of accreditation*: **01.12.1993**

Informationen zum Akkreditierungsumfang und zu Akkreditierung Austria /
Information about the accreditation scope and Akkreditierung Austria


<http://www.bmwf.gv.at/akkreditierung>

Die Akkreditierung wurde mittels Bescheid erteilt und damit bestätigt, dass die Konformitätsbewertungsstelle - einschließlich der im Bescheid genannten Standorte - die Anforderungen der ÖVE/ÖNORM EN ISO/IEC 17025:2007 erfüllt. Diese Bestätigung der Akkreditierung darf nur unverändert weiterverbreitet werden.

The accreditation was granted by a decree which confirms, that the Conformity Assessment Body - including the sites mentioned in the decree - fulfills the requirements of ÖVE/ÖNORM EN ISO/IEC 17025:2007. This confirmation of accreditation may not be reproduced other than in full.

Dipl.-Ing. Dr. Norman Brunner
 Leiter Akkreditierung Austria / *Head Akkreditierung Austria*

12.08.2014
 Datum / *Date*






IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity		P
Type SL2-3x/3A: AC-22B at 500V/630A (Test1: L1 and L2 closed, L3 operated; Test2: L1 operated, L2 closed, L3 open)			
	- utilization category	AC-22B	
	- rated operational voltage U_e (V)	500	
	- rated operational current I_e (A)	630	
Conditions for make operation, AC-23A and AC-23B only:			N/A
	- test voltage, $U = 1,05 U_e$(V):	L1: - L2: - L3: -	
	- test current, $I =$ $10 \times I_e$ (A):	L1: - L2: - L3: -	
	- power factor	L1: - L2: - L3: -	
Conditions for break operation, AC-23A and AC-23B only:			N/A
	- test voltage, $U = 1,05 U_e$(V):	L1: - L2: - L3: -	
	- test current, $I =$ $8 \times I_e$ (A):	L1: - L2: - L3: -	
	- power factor	L1: - L2: - L3: -	
Conditions for make/break operations, other than AC-23A and AC-23B:			P
	- test voltage, $U = 1,05 U_e$(V):	L1: 527 L2: 528 L3: 526	
	- test current, $I =$ $3 \times I_e$ (A):	L1: 1903 L2: 1910 L3: 1898	
	- power factor / time constant	L1: 0,62 L2: 0,62 L3: 0,62	
	Number of make/break or make and break operations	5	P
	- recovery voltage duration ≥ 50 ms (ms).....	260	P
	- current duration (ms)	290	
	- time interval between operations (s)	30	P
Characteristic of transient recovery voltage for AC-22 and AC-23 only:			P
	- oscillatory frequency (kHz)	62,68	
	- measured oscillatory frequency (kHz)	L1: 62,7 L2: 62,7 L3: 62,7	


ВАЖНО С
ОРИГИНАЛА



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	- factor γ	L1: 1,1 L2: 1,1 L3: 1,1	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		P
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...:	1380	
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage $1,1 U_e$ (V)	760	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- power loss (W)	45 max.	
	- rated breaking capacity (kA)	100	
	Conductor cross-section (mm ²)	1 x 240 (fuse-links) 2 x 185 (solid-links)	
	Test current I_e (A)	400 (fuse-links) 630 (solid-links)	



IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 61 (fuse-links) ≤ 70 (solid-links)	80	P
	Manual operating means: non-metallic	≤ 5 (fuse-links) ≤ 7 (solid-links)	35	P
	Parts intended to be touched but not hand-held: non-metallic	≤ 31 (fuse-links) ≤ 25 (solid-links)	50	P
	Parts which need not be touched during normal operation: non-metallic	≤ 39 (fuse-links) ≤ 36 (solid-links)	60	P
8.3.3.7	Strength of actuator mechanism			P
8.2.5	Verification of the strength of actuator mechanism and position indicating device			P
	- actuator type (fig.)	1e		
8.2.5.2.1	Dependent and independent manual operation			P
	- actuating force for opening (N)	141		
	- test force with blocked main contacts (N)	400		
	- used method to keep the contact closed	Brazing		
	During and after the test, open position not indicated	No open position		P
	Equipment with locking mean, no locking in the open position while test force is applied	No locking mechanism		N/A
8.2.5.2.2	Dependent power operation			N/A
	- main contacts fixed together in the closed position	-		N/A
	- used method to keep the contact closed	-		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times)	-		N/A
	During and after the test, open position not indicated	-		N/A
	Equipment show no damage impairing its normal operation	-		N/A
	Equipment with locking mean, no locking in the open position while test force is applied	-		N/A



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position	-	N/A
	- used method to keep the contact closed	-	N/A
	- stored energy of the power operator released (3 times).....	-	N/A
	During and after the test, open position not indicated	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N/A

**ВАРНО С
ОРИГИНАЛА**



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity		P
Type SL2-3x3/3A: AC-22B at 500V/630A			
	- utilization category	AC-22B	
	- rated operational voltage U_e (V)	500	
	- rated operational current I_e (A)	630	
	Conditions for make operation, AC-23A and AC-23B only:		N/A
	- test voltage, $U = 1,05 U_e$(V):	L1: - L2: - L3: -	
	- test current, $I =$ $10 \times I_e$ (A):	L1: - L2: - L3: -	
	- power factor	L1: - L2: - L3: -	
	Conditions for break operation, AC-23A and AC-23B only:		N/A
	- test voltage, $U = 1,05 U_e$(V):	L1: - L2: - L3: -	
	- test current, $I =$ $8 \times I_e$ (A):	L1: - L2: - L3: -	
	- power factor	L1: - L2: - L3: -	
	Conditions for make/break operations, other than AC-23A and AC-23B:		P
	- test voltage, $U = 1,05 U_e$(V):	L1: 527 L2: 528 L3: 526	
	- test current, $I =$ $3 \times I_e$ (A):	L1: 1903 L2: 1910 L3: 1898	
	- power factor / time constant	L1: 0,62 L2: 0,62 L3: 0,62	
	Number of make/break or make and break operations	5	P
	- recovery voltage duration ≥ 50 ms (ms).....	Permanent	P
	- current duration (ms)	290	
	- time interval between operations (s)	30	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only:		P
	- oscillatory frequency (kHz)	62,68	
	- measured oscillatory frequency (kHz)	L1: 62,7 L2: 62,7 L3: 62,7	P


**ВАЖНО С
ОРИГИНАЛ**



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	- factor γ	L1: 1,1 L2: 1,1 L3: 1,1	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		P
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...:	1380	
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage $1,1 U_e$ (V)	760	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- power loss (W)	45 max.	
	- rated breaking capacity (kA)	100	
	Conductor cross-section (mm ²)	1 x 240 (fuse-links) 2 x 185 (solid-links)	
	Test current I_e (A)	400 (fuse-links) 630 (solid-links)	



IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 62 (fuse-links) ≤ 69 (solid-links)	80	P
	Manual operating means: non-metallic	≤ 5 (fuse-links) ≤ 7 (solid-links)	35	P
	Parts intended to be touched but not hand-held: non-metallic	≤ 31 (fuse-links) ≤ 26 (solid-links)	50	P
	Parts which need not be touched during normal operation: non-metallic	≤ 39 (fuse-links) ≤ 35 (solid-links)	60	P
8.3.3.7	Strength of actuator mechanism			P
8.2.5	Verification of the strength of actuator mechanism and position indicating device			P
	- actuator type (fig.)	1e		
8.2.5.2.1	Dependent and independent manual operation			P
	- actuating force for opening (N)	178		
	- test force with blocked main contacts (N)	400		
	- used method to keep the contact closed	Brazing		
	During and after the test, open position not indicated	No open position		P
	Equipment with locking mean, no locking in the open position while test force is applied.....	No locking mechanism		N/A
8.2.5.2.2	Dependent power operation			N/A
	- main contacts fixed together in the closed position	-		N/A
	- used method to keep the contact closed	-		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times)	-		N/A
	During and after the test, open position not indicated	-		N/A
	Equipment show no damage impairing its normal operation.....	-		N/A
	Equipment with locking mean, no locking in the open position while test force is applied.....	-		N/A



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position	-	N/A
	- used method to keep the contact closed	-	N/A
	- stored energy of the power operator released (3 times).....	-	N/A
	During and after the test, open position not indicated	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N/A

**ВЯНО С
ОРИГИНАЛА**



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity		P
Type SL2-3x/3A: AC-21B at 690V/630A (Test1: L1 and L2 closed, L3 operated; Test2: L1 operated, L2 closed, L3 open)			
	- utilization category	AC-21B	
	- rated operational voltage U_e (V)	690	
	- rated operational current I_e (A)	630	
Conditions for make operation, AC-23A and AC-23B only:			N/A
	- test voltage, $U = 1,05 U_e$(V):	L1: - L2: - L3: -	
	- test current, $I =$ $10 \times I_e$ (A):	L1: - L2: - L3: -	
	- power factor	L1: - L2: - L3: -	
Conditions for break operation, AC-23A and AC-23B only:			N/A
	- test voltage, $U = 1,05 U_e$(V):	L1: - L2: - L3: -	
	- test current, $I =$ $8 \times I_e$ (A):	L1: - L2: - L3: -	
	- power factor	L1: - L2: - L3: -	
Conditions for make/break operations, other than AC-23A and AC-23B:			P
	- test voltage, $U = 1,05 U_e$(V):	L1: 729 L2: 730 L3: 728	
	- test current, $I =$ $1,5 \times I_e$ (A):	L1: 955 L2: 960 L3: 951	
	- power factor / time constant	L1: 0,95 L2: 0,94 L3: 0,95	
	Number of make/break or make and break operations	5	P
	- recovery voltage duration ≥ 50 ms (ms).....	340	P
	- current duration (ms)	280	
	- time interval between operations (s).....	30	P
Characteristic of transient recovery voltage for AC-22 and AC-23 only:			N/A
	- oscillatory frequency (kHz)	-	
	- measured oscillatory frequency (kHz)	L1: - L2: - L3: -	

**ВЯРНО С
ОРИГИНАЛА**



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	- factor γ	L1: - L2: - L3: -	N/A
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		P
	test voltage $2 U_e$ with a minimum of 1000V~ (V)	1380	
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage $1,1 U_e$ (V)	760	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- power loss (W)	45 max.	
	- rated breaking capacity (kA)	100	
	Conductor cross-section (mm ²)	1 x 240 (fuse-links) 2 x 185 (solid-links)	
	Test current I_e (A)	400 (fuse-links) 630 (solid-links)	

**ВЯРНО С
ОРИГИНАЛА**



IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 61 (fuse-links) ≤ 66 (solid-links)	80	P
	Manual operating means: non-metallic	≤ 5 (fuse-links) ≤ 6 (solid-links)	35	P
	Parts intended to be touched but not hand-held: non-metallic	≤ 30 (fuse-links) ≤ 26 (solid-links)	50	P
	Parts which need not be touched during normal operation: non-metallic	≤ 37 (fuse-links) ≤ 33 (solid-links)	60	P
8.3.3.7	Strength of actuator mechanism			P
8.2.5	Verification of the strength of actuator mechanism and position indicating device			P
	- actuator type (fig.)	1e		
8.2.5.2.1	Dependent and independent manual operation			P
	- actuating force for opening (N)	141		
	- test force with blocked main contacts (N)	400		
	- used method to keep the contact closed	Brazing		
	During and after the test, open position not indicated	No open position		P
	Equipment with locking mean, no locking in the open position while test force is applied.....	No locking mechanism		N/A
8.2.5.2.2	Dependent power operation			N/A
	- main contacts fixed together in the closed position	-		N/A
	- used method to keep the contact closed	-		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times)	-		N/A
	During and after the test, open position not indicated	-		N/A
	Equipment show no damage impairing its normal operation.....	-		N/A
	Equipment with locking mean, no locking in the open position while test force is applied.....	-		N/A

ВЪРНО С
ОРИГИНАЛА



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position	-	N/A
	- used method to keep the contact closed	-	N/A
	- stored energy of the power operator released (3 times).....	-	N/A
	During and after the test, open position not indicated	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N/A

**ВЯРНО С
ОРИГИНАЛА**




IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity		P
Type SL2-3x3/3A: AC-21B at 690V/630A			
	- utilization category	AC-21B	
	- rated operational voltage U_e (V)	690	
	- rated operational current I_e (A)	630	
	Conditions for make operation, AC-23A and AC-23B only:		N/A
	- test voltage, $U = 1,05 U_e$(V):	L1: - L2: - L3: -	
	- test current, $I =$ $10 \times I_e$ (A):	L1: - L2: - L3: -	
	- power factor	L1: - L2: - L3: -	
	Conditions for break operation, AC-23A and AC-23B only:		N/A
	- test voltage, $U = 1,05 U_e$(V):	L1: - L2: - L3: -	
	- test current, $I =$ $8 \times I_e$ (A):	L1: - L2: - L3: -	
	- power factor	L1: - L2: - L3: -	
	Conditions for make/break operations, other than AC-23A and AC-23B:		P
	- test voltage, $U = 1,05 U_e$(V):	L1: 729 L2: 730 L3: 728	
	- test current, $I =$ $1,5 \times I_e$ (A):	L1: 955 L2: 960 L3: 951	
	- power factor / time constant	L1: 0,95 L2: 0,94 L3: 0,95	
	Number of make/break or make and break operations	5	P
	- recovery voltage duration ≥ 50 ms (ms).....	Permanent	P
	- current duration (ms)	280	
	- time interval between operations (s).....	30	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only:		N/A
	- oscillatory frequency (kHz)	-	
	- measured oscillatory frequency (kHz)	L1: - L2: - L3: -	


ВЪРНО С
 ОРГИНАЛА



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	- factor γ	L1: - L2: - L3: -	N/A
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		P
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...:	1380	
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage $1,1 U_e$ (V)	760	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- power loss (W)	45 max.	
	- rated breaking capacity (kA)	100	
	Conductor cross-section (mm ²)	1 x 240 (fuse-links) 2 x 185 (solid-links)	
	Test current I_e (A)	400 (fuse-links) 630 (solid-links)	



IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 62 (fuse-links) ≤ 66 (solid-links)	80	P
	Manual operating means: non-metallic	≤ 5 (fuse-links) ≤ 6 (solid-links)	35	P
	Parts intended to be touched but not hand-held: non-metallic	≤ 30 (fuse-links) ≤ 28 (solid-links)	50	P
	Parts which need not be touched during normal operation: non-metallic	≤ 38 (fuse-links) ≤ 36 (solid-links)	60	P
8.3.3.7	Strength of actuator mechanism			P
8.2.5	Verification of the strength of actuator mechanism and position indicating device			P
	- actuator type (fig.)	1e		
8.2.5.2.1	Dependent and independent manual operation			P
	- actuating force for opening (N)	178		
	- test force with blocked main contacts (N)	400		
	- used method to keep the contact closed	Brazing		
	During and after the test, open position not indicated	No open position		P
	Equipment with locking mean, no locking in the open position while test force is applied	No locking mechanism		N/A
8.2.5.2.2	Dependent power operation			N/A
	- main contacts fixed together in the closed position	-		N/A
	- used method to keep the contact closed	-		N/A
	- 110% of the rated supply voltage applied to the equipment (3 times)	-		N/A
	During and after the test, open position not indicated	-		N/A
	Equipment show no damage impairing its normal operation	-		N/A
	Equipment with locking mean, no locking in the open position while test force is applied	-		N/A




ВЪРНО С
ОРИГИНАЛА

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position	-	N/A
	- used method to keep the contact closed	-	N/A
	- stored energy of the power operator released (3 times).....	-	N/A
	During and after the test, open position not indicated	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N/A



**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY		P
8.3.4.1	Operational performance test		P
	Type SL2-3x/3A: AC-23B at 400V/400A (Test1: L1 and L2 closed, L3 operated; Test2: L1 operated, L2 closed, L3 open)		
	- utilization category	AC-23B	
	- rated operational voltage (V)	400	
	- rated operational current (A)	400	
	Test conditions for electrical operation cycles:		P
	- test voltage (V)	L1: 403 L2: 402 L3: 403	
	- test current (A)	L1: 409 L2: 413 L3: 407	
	- power factor / time-constant	L1: 0,65 L2: 0,65 L3: 0,65	
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current)	With	
	Second test sequence (with/without current)	Without	
	- time interval between first and second test sequence	No time interval	
	- recovery voltage duration at operations with current ≥ 50 ms (ms).....	260	P
	- current duration (ms)	280	
	- time interval between operations (s)	60	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P



**ВАЖНО С
ОРИГИНАЛОМ**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.4.2	Dielectric verification			P
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...:	1380		
	No breakdown or flashover			P
8.3.4.3	Leakage current			P
	test voltage $1,1 U_e$ (V)	760		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1		P
8.3.4.4	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			
	- manufacturer's name, trademark or Identification mark	Jean Müller		
	- manufacturer's model or type reference	M2gG400/69		
	- rated voltage (V)	690		
	- rated current (A)	400		
	- power loss (W)	45 max.		
	- rated breaking capacity (kA)	100		
	Conductor cross-section (mm ²)	1 x 240		
	Test current I_e (A)	400		
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 67	80	P
	Manual operating means: non-metallic	5	35	P
	Parts Intended to be touched but not hand-held: non-metallic	35	50	P
	Parts which need not be touched during normal operation: non-metallic	44	60	P



**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1	Operational performance test		P
	Type SL2-3X3/3A: AC-23B at 400V/400A		
	- utilization category	AC-22B	
	- rated operational voltage (V)	400	
	- rated operational current (A)	400	
	Test conditions for electrical operation cycles:		P
	- test voltage (V)	L1: 403 L2: 402 L3: 403	
	- test current (A)	L1: 409 L2: 413 L3: 407	
	- power factor / time-constant	L1: 0,65 L2: 0,65 L3: 0,65	
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current)	With	
	Second test sequence (with/without current)	Without	
	- time interval between first and second test sequence	No time interval	
	- recovery voltage duration at operations with current ≥ 50 ms (ms)	Permanent	P
	- current duration (ms)	380	
	- time interval between operations (s)	30	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P




**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.4.2	Dielectric verification			P
	test voltage 2 Ue with a minimum of 1000V~ (V) ...:	1380		
	No breakdown or flashover			P
8.3.4.3	Leakage current			P
	test voltage 1,1 Ue (V)	760		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1		P
8.3.4.4	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			
	- manufacturer's name, trademark or identification mark	Jean Müller		
	- manufacturer's model or type reference	M2gG400/69		
	- rated voltage (V)	690		
	- rated current (A)	400		
	- power loss (W)	45 max.		
	- rated breaking capacity (kA)	100		
	Conductor cross-section (mm ²)	1 x 240		
	Test current Ie (A)	400		
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 66	80	P
	Manual operating means: non-metallic	5	35	P
	Parts intended to be touched but not hand-held: non-metallic	34	50	P
	Parts which need not be touched during normal operation: non-metallic	43	60	P



**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1	Operational performance test		P
	Type SL2-3X/3A: AC-22B at 500V/630A (Test1: L1 and L2 closed, L3 operated; Test2: L1 operated, L2 closed, L3 open)		
	- utilization category	AC-22B	
	- rated operational voltage (V)	500	
	- rated operational current (A)	630	
	Test conditions for electrical operation cycles:		P
	- test voltage (V)	L1: 509 L2: 510 L3: 509	
	- test current (A)	L1: 637 L2: 641 L3: 632	
	- power factor / time-constant	L1: 0,80 L2: 0,80 L3: 0,80	
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current)	With	
	Second test sequence (with/without current)	Without	
	- time interval between first and second test sequence	No time interval	
	- recovery voltage duration at operations with current ≥ 50 ms (ms)	260	P
	- current duration (ms)	280	
	- time interval between operations (s)	60	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		
	- equipment is able to carry its rated current after normal closing operation		




**ВЫПОЛНЕНО
ОПРЕДЕЛЕНА**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.4.2	Dielectric verification			P
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...:	1380		
	No breakdown or flashover			P
8.3.4.3	Leakage current			P
	test voltage $1,1 U_e$ (V)	760		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1		P
8.3.4.4	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			
	- manufacturer's name, trademark or identification mark	Jean Müller		
	- manufacturer's model or type reference	M2gG400/69		
	- rated voltage (V)	690		
	- rated current (A)	400		
	- power loss (W)	45 max.		
	- rated breaking capacity (kA)	100		
	Conductor cross-section (mm ²)	1 x 240 (fuse-links) 2 x 185 (solid-links)		
	Test current I_e (A)	400 (fuse-links) 630 (solid-links)		
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 66 (fuse-links) ≤ 73 (solid-links)	80	P
	Manual operating means: non-metallic	≤ 6 (fuse-links) ≤ 7 (solid-links)	35	P
	Parts Intended to be touched but not hand-held: non-metallic	≤ 34 (fuse-links) ≤ 31 (solid-links)	50	P
	Parts which need not be touched during normal operation: non-metallic	≤ 43 (fuse-links) ≤ 40 (solid-links)		P




**ВАРНО С
ОРИГИНАЛ**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1	Operational performance test		P
	Type SL2-3X3/3A: AC-22B at 500V/630A		
	- utilization category	AC-22B	—
	- rated operational voltage (V)	500	—
	- rated operational current (A)	630	—
	Test conditions for electrical operation cycles:		P
	- test voltage (V)	L1: 509 L2: 510 L3: 509	—
	- test current (A)	L1: 637 L2: 641 L3: 632	—
	- power factor / time constant	L1: 0,80 L2: 0,80 L3: 0,80	—
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current)	With	—
	Second test sequence (with/without current)	Without	—
	- time interval between first and second test sequence	No time Interval	—
	- recovery voltage duration at operations with current ≥ 50 ms (ms).....	Permanent	P
	- current duration (ms)	280	—
	- time interval between operations (s)	60	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P



**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.4.2	Dielectric verification			P
	test voltage $2 U_e$ with a minimum of 1000V~ (V)	1380		
	No breakdown or flashover			P
8.3.4.3	Leakage current			P
	test voltage $1,1 U_e$ (V)	760		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1		P
8.3.4.4	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			
	- manufacturer's name, trademark or identification mark	Jean Müller		
	- manufacturer's model or type reference	M2gG400/69		
	- rated voltage (V)	690		
	- rated current (A)	400		
	- power loss (W)	45 max.		
	- rated breaking capacity (kA)	100		
	Conductor cross-section (mm ²)	1 x 240 (fuse-links) 2 x 185 (solid-links)		
	Test current I_e (A)	400 (fuse-links) 630 (solid-links)		
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 66 (fuse-links) ≤ 72 (solid-links)	80	P
	Manual operating means: non-metallic	≤ 6 (fuse-links) ≤ 7 (solid-links)	35	P
	Parts intended to be touched but not hand-held: non-metallic	≤ 34 (fuse-links) ≤ 32 (solid-links)	50	P
	Parts which need not be touched during normal operation: non-metallic	≤ 45 (fuse-links) ≤ 41 (solid-links)		P




**ВЪРНО С
ОРИГИНАЛА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1	Operational performance test		P
	Type SL2-3X/3A: AC-21B at 690V/630A (Test1: L1 and L2 closed, L3 operated; Test2: L1 operated, L2 closed, L3 open)		
	- utilization category	AC-21B	
	- rated operational voltage (V)	690	
	- rated operational current (A)	690	
	Test conditions for electrical operation cycles:		P
	- test voltage (V)	L1: 694 L2: 694 L3: 695	
	- test current (A)	L1: 640 L2: 643 L3: 634	
	- power factor / time-constant	L1: 0,96 L2: 0,95 L3: 0,95	
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current)	With	
	Second test sequence (with/without current)	Without	
	- time interval between first and second test sequence	No time interval	
	- recovery voltage duration at operations with current ≥ 50 ms (ms).....	270	P
	- current duration (ms)	280	
	- time interval between operations (s)	60	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P




**БЮРО С
ОРНИНАТА**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.4.2	Dielectric verification			P
	test voltage $2 U_e$ with a minimum of 1000V~ (V)	1380		
	No breakdown or flashover			P
8.3.4.3	Leakage current			P
	test voltage $1,1 U_e$ (V)	760		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1		P
8.3.4.4	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			
	- manufacturer's name, trademark or identification mark	Jean Müller		
	- manufacturer's model or type reference	M2gG400/69		
	- rated voltage (V)	690		
	- rated current (A)	400		
	- power loss (W)	45 max.		
	- rated breaking capacity (kA)	100		
	Conductor cross-section (mm ²)	1 x 240 (fuse-links) 2 x 185 (solid-links)		
	Test current I_e (A)	400 (fuse-links) 630 (solid-links)		
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 67 (fuse-links) ≤ 73 (solid-links)	80	P
	Manual operating means: non-metallic	≤ 7 (fuse-links) ≤ 7 (solid-links)	35	P
	Parts intended to be touched but not hand-held: non-metallic	≤ 33 (fuse-links) ≤ 32 (solid-links)	50	P
	Parts which need not be touched during normal operation: non-metallic	≤ 46 (fuse-links) ≤ 42 (solid-links)	60	P




**БYPHO C
OPIIИHАJA**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1	Operational performance test		P
	Type SL2-3X/3A: AC-21B at 690V/630A		
	- utilization category	AC-21B	—
	- rated operational voltage (V)	690	—
	- rated operational current (A)	690	—
	Test conditions for electrical operation cycles:		P
	- test voltage (V)	L1: 694 L2: 694 L3: 695	—
	- test current (A)	L1: 640 L2: 643 L3: 634	—
	- power factor / time-constant	L1: 0,96 L2: 0,95 L3: 0,95	—
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current)	With	—
	Second test sequence (with/without current)	Without	—
	- time interval between first and second test sequence	No time interval	—
	- recovery voltage duration at operations with current ≥ 50 ms (ms).....	Permanent	P
	- current duration (ms)	280	—
	- time interval between operations (s)	60	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P



**ВЯРНО С
ОПИСАНИЕ**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.4.2	Dielectric verification			P
	test voltage 2 Ue with a minimum of 1000V~ (V)	1380		—
	No breakdown or flashover			P
8.3.4.3	Leakage current			P
	test voltage 1,1 Ue (V)	760		—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1		P
8.3.4.4	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			
	- manufacturer's name, trademark or identification mark	Jean Müller		
	- manufacturer's model or type reference	M2gG400/69		
	- rated voltage (V)	690		
	- rated current (A)	400		
	- power loss (W)	45 max.		
	- rated breaking capacity (kA)	100		
	Conductor cross-section (mm ²)	1 x 240 (fuse-links) 2 x 185 (solid-links)		
	Test current Ie (A)	400 (fuse-links) 630 (solid-links)		
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 67 (fuse-links) ≤ 74 (solid-links)	80	P
	Manual operating means: non-metallic	≤ 5 (fuse-links) ≤ 7 (solid-links)	35	P
	Parts intended to be touched but not hand-held: non-metallic	≤ 30 (fuse-links) ≤ 34 (solid-links)	50	P
	Parts which need not be touched during normal operation: non-metallic	≤ 38 (fuse-links) ≤ 41 (solid-links)		P




**ВЯРНО С
ОПРЕДЕЛЕНА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5	TEST SEQUENCE III: SHORT-CIRCUIT PERFORMANCE CAPABILITY		P
8.3.5.1	Short-time withstand current test		P
	Type SL2-3x/3A		
	Rated short-time withstand current I_{cw} (A) ($\geq 12 I_e$ max.)	10000 / 1s	P
	- test voltage (V)	L1: 695 L2: 695 L3: 694	—
	- r.m.s. test current (A)	L1: 10470 L2: 10790 L3: 10200	—
	- peak test current (A)	L1: 15240 L2: 17100 L3: 18280	—
	- power factor / time constant	L1: 0,46 L2: 0,46 L3: 0,46	—
	- factor n	1,79	—
	Test duration (ms)	1010	—
8.3.5.1.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.5.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P



**ВЕРНО
ОПРЕДЕЛЕНА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.2	Short-circuit making capacity		N/A
	Rated short-circuit making capacity I_{cm} (A)	-	N/A
	- test voltage ($1,05 \times U_e$)(V):	L1: - L2: - L3: -	
	- r.m.s. test current (A)(A):	L1: - L2: - L3: -	
	- maximum peak test current (factor n)	-	N/A
	- power factor / time constant	L1: - L2: - L3: -	N/A
	Current duration (s)	-	
	Time Interval between the cycles	-	
8.3.5.2.5	Behaviour of the equipment during the test		N/A
	Test performed without:		
	- endanger to the operator		N/A
	- cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.5.2.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A




**ВЯРНО С
ОПРИМНАТА**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.5.3	Dielectric verification			P
	test voltage $2 U_e$ with a minimum of 1000V~ (V):	1380		—
	No flashover or breakdown			P
8.3.5.4	Leakage current			P
	test voltage $1,1 U_e$ (V)	760		—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1		P
8.3.5.5	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			—
	- manufacturer's name, trademark or identification mark	Jean Müller		—
	- manufacturer's model or type reference	M2gG400/69		—
	- rated voltage (V)	690		—
	- rated current (A)	400		—
	- power loss (W)	45 max.		—
	- rated breaking capacity (kA)	100		—
	Conductor cross-section (mm ²)	1 x 240		—
	Test current I_e (A)	400		—
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	N/A
	Terminals	≤ 61	80	N/A
	Manual operating means: non-metallic	5	35	N/A
	Parts Intended to be touched but not hand-held: non-metallic	30	50	N/A
	Parts which need not be touched during normal operation: non-metallic	37	60	N/A



↓
ВРПНО С
ОПРЕДНА

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.1	Short-time withstand current test		P
	Type SL2-3x3/3A		
	Rated short-time withstand current I_{cw} (A) ($\geq 12 I_e$ max.)	15000 / 1s	P
	- test voltage (V)	L1: 695 L2: 695 L3: 694	
	- r.m.s. test current (A)	L1: 15130 L2: 15180 L3: 15090	
	- peak test current (A)	L1: 24150 L2: 29100 L3: 30590	
	- power factor / time constant	L1: 0,27 L2: 0,27 L3: 0,27	
	- factor n	2,02	
	Test duration (ms)	1010	
8.3.5.1.5	Behaviour of the equipment during the test		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.5.1.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P



**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.2	Short-circuit making capacity		N/A
	Rated short-circuit making capacity I_{cm} (A)	-	N/A
	- test voltage ($1,05 \times U_e$)(V):	L1: - L2: - L3: -	-
	- r.m.s. test current (A)(A):	L1: - L2: - L3: -	-
	- maximum peak test current (factor n)	-	N/A
	- power factor / time constant	L1: - L2: - L3: -	N/A
	Current duration (s)	-	-
	Time interval between the cycles	-	-
8.3.5.2.5	Behaviour of the equipment during the test		N/A
	Test performed without:		-
	- endanger to the operator		N/A
	- cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.5.2.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A



**ВЫПОЛНЕНО
ОПЛАЧЕНО**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.5.3	Dielectric verification			P
	test voltage $2 U_e$ with a minimum of 1000V~ (V):	1380		
	No flashover or breakdown			P
8.3.5.4	Leakage current			P
	test voltage $1,1 U_e$ (V)	760		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-	N/A	
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P	
8.3.5.5	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			
	- manufacturer's name, trademark or identification mark	Jean Müller		
	- manufacturer's model or type reference	M2gG400/69		
	- rated voltage (V)	690		
	- rated current (A)	400		
	- power loss (W)	45 max.		
	- rated breaking capacity (kA)	100		
	Conductor cross-section (mm ²)	1 x 240		
	Test current I_e (A)	400		
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	N/A
	Terminals	≤ 60	80	N/A
	Manual operating means: non-metallic	5	35	N/A
	Parts intended to be touched but not hand-held: non-metallic	30	50	N/A
	Parts which need not be touched during normal operation: non-metallic	37	60	N/A



**ВРНО С
ОРИГИНАЛ**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT		P
	Conditional short-circuit current test		P
	Type SL2-3x/3A: 120kA at 500V/400A (L1 open, L2 closed, L3 operated)		
	Protective device details:		P
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gL400	
	- rated voltage (V)	500	
	- rated current (A)	400	
	- rated breaking capacity (kA)	120	
8.3.6.2	Conditional short-circuit current test values		P
	- test voltage (1,05 U ₀) (V)	L1: 528 L2: 530 L3: 527	
	- test current (A)	L1: 120940 L2: 121300 L3: 120630	
	- rated frequency (Hz)	50	
	- power factor	0,17	
	- time constant (ms)	-	
	- factor n	2,22	
	Fuse protected short-circuit withstand (equipment in closed position)		P
	- max. let-through current (A)	L1: 27500 L2: 18400 L3: 31540	
	- Joule integral I ² dt (A ² s)	L1: 1085400 L2: 411000 L3: 1489500	
	Fuse protected short-circuit making (equipment closing on to short-circuit)		P
	- mean velocity of 15 manually under no-load conditions operations (m/s)	0,98	
	- point at which the measurement is made	Handle of the actuator	
	- test speed during the fuse protected short-circuit making (m/s)	1,1	
	- max. let-through current (A)	L1: - L2: 36500 L3: 36500	
	- Joule Integral I ² dt (A ² s)	L1: - L2: 1556000 L3: 1556000	




БРФО С
 ОПИНАТА

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...	1380	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage $1,1 U_e$ (V)	760	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark	Jean Müller	—
	- manufacturer's model or type reference	M2gG400/69	—
	- rated voltage (V)	690	—
	- rated current (A)	400	—
	- power loss (W)	45 max.	—
	- rated breaking capacity (kA)	100	—
	Conductor cross-section (mm ²)	1 x 240	—
	Test current I_e (A)	400	—



IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 61	80	P
	Manual operating means: non-metallic	5	35	P
	Parts intended to be touched but not hand-held: non-metallic	31	50	P
	Parts which need not be touched during normal operation: non-metallic	38	60	P




**ВЯЧЭС
ОПІТНАНА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditional short-circuit current test		P
	Type SL2-3x3/3A: 120kA at 500V/400A		
	Protective device details:		P
	- manufacturer's name, trademark or identification mark	Jean Müller	—
	- manufacturer's model or type reference	M2gL400	—
	- rated voltage (V)	500	—
	- rated current (A)	400	—
	- rated breaking capacity (kA)	120	—
8.3.6.2	Conditional short-circuit current test values		P
	- test voltage (1,05 U _e) (V)	L1: 528 L2: 530 L3: 527	—
	- test current (A)	L1: 120940 L2: 121300 L3: 120630	—
	- rated frequency (Hz)	50	—
	- power factor	0,17	—
	- time constant (ms)	-	—
	- factor n	2,22	—
	Fuse protected short-circuit withstand (equipment in closed position)		P
	- max. let-through current (A)	L1: 44120 L2: 44990 L3: 4980	—
	- Joule integral I ² dt (A ² s)	L1: 1085400 L2: 1273500 L3: 80010	—
	Fuse protected short-circuit making (equipment closing on to short-circuit)		P
	- mean velocity of 15 manually under no-load conditions operations (m/s)	0,98	—
	- point at which the measurement is made	Handle of the actuator	—
	- test speed during the fuse protected short-circuit making (m/s)	1,1	—
	- max. let-through current (A)	L1: 30120 L2: 35470 L3: 29860	—
	- Joule Integral I ² dt (A ² s)	L1: 1178000 L2: 1269990 L3: 1154200	—




**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...:	1380	
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage $1,1 U_e$ (V)	760	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- power loss (W)	45 max.	
	- rated breaking capacity (kA)	100	
	Conductor cross-section (mm ²)	1 x 240	
	Test current I_e (A)	400	




BUREAU OF STANDARDS AND METROLOGY
STATE OF QATAR

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 62	80	P
	Manual operating means: non-metallic	5	35	P
	Parts intended to be touched but not hand-held: non-metallic	31	50	P
	Parts which need not be touched during normal operation: non-metallic	38	60	P



**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	Conditional short-circuit current test		P
	Type SL2-3x/3A: 80kA at 690V/400A (L1 open, L2 closed, L3 operated)		
	Protective device details:		P
	- manufacturer's name, trademark or identification mark	Jean Müller	—
	- manufacturer's model or type reference	M2gG400/69	—
	- rated voltage (V)	690	—
	- rated current (A)	400	—
	- rated breaking capacity (kA)	100	—
8.3.6.2	Conditional short-circuit current test values		P
	- test voltage (1,05 Ue) (V)	L1: 726 L2: 727 L3: 726	—
	- test current (A)	L1: 80790 L2: 81130 L3: 80350	—
	- rated frequency (Hz)	50	—
	- power factor	0,17	—
	- time constant (ms)	-	—
	- factor n	2,21	—
	Fuse protected short-circuit withstand (equipment in closed position)		P
	- max. let-through current (A)	L1: 31520 L2: 5650 L3: 36110	—
	- Joule Integral I ² dt (A ² s)	L1: 882000 L2: 125000 L3: 1110200	—
	Fuse protected short-circuit making (equipment closing on to short-circuit)		P
	- mean velocity of 15 manually under no-load conditions operations (m/s)	0,98	—
	- point at which the measurement is made	Handle of the actuator	—
	- test speed during the fuse protected short-circuit making (m/s)	1,1	—
	- max. let-through current (A)	L1: - L2: 35700 L3: 35700	—
	- Joule Integral I ² dt (A ² s)	L1: - L2: 1288000 L3: 1288000	—




**ВЯРНО С
ОПРИМАНА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...:	1380	
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage $1,1 U_e$ (V)	760	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- power loss (W)	45 max.	
	- rated breaking capacity (kA)	100	
	Conductor cross-section (mm ²)	1 x 240	
	Test current I_e (A)	400	




**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 62	80	P
	Manual operating means: non-metallic	5	35	P
	Parts Intended to be touched but not hand-held: non-metallic	32	50	P
	Parts which need not be touched during normal operation: non-metallic	38	60	P



**ВЫХОД
ОПРАВДАНА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	Conditional short-circuit current test		P
	Type SL2-3x3/3A: 80kA at 690V/400A		
	Protective device details:		P
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- rated breaking capacity (kA)	100	
8.3.6.2	Conditional short-circuit current test values		P
	- test voltage (1,05 U _e) (V)	L1: 726 L2: 727 L3: 726	
	- test current (A)	L1: 80790 L2: 81130 L3: 80350	
	- rated frequency (Hz)	50	
	- power factor	0,17	
	- time constant (ms)	-	
	- factor n	2,21	
	Fuse protected short-circuit withstand (equipment in closed position)		P
	- max. let-through current (A)	L1: 25950 L2: 35200 L3: 15400	
	- Joule Integral I ² dt (A ² s)	L1: 982560 L2: 1195200 L3: 365000	
	Fuse protected short-circuit making (equipment closing on to short-circuit)		P
	- mean velocity of 15 manually under no-load conditions operations (m/s)	0,98	
	- point at which the measurement is made	Handle of the actuator	
	- test speed during the fuse protected short-circuit making (m/s)	1,1	
	- max. let-through current (A)	L1: 35120 L2: 34590 L3: 7100	
	- Joule Integral I ² dt (A ² s)	L1: 1168000 L2: 1008500 L3: 100020	



**ВЯРНО С
ОПРЕДЕЛЕНА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...:	1380	
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage $1,1 U_e$ (V)	760	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- power loss (W)	45 max.	
	- rated breaking capacity (kA)	100	
	Conductor cross-section (mm ²)	1 x 240	
	Test current I_e (A)	400	




BRILO C
OPREDELJENJE

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 62	75	P
	Manual operating means: non-metallic	6	35	P
	Parts Intended to be touched but not hand-held: non-metallic	32	50	P
	Parts which need not be touched during normal operation: non-metallic	39	60	P




**ВРХО С
ОПІТНАЛА**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY		P
8.3.7.1	Overload test		P
	Type SL2-3x/3A		
	ambient temperature 10-40 °C	22	
	test enclosure W x H x D (mm x mm x mm)	-	
	material of enclosure	-	
	test current 1,6 x I _{lth} or 1,6 x I _{th} (A)	640	
	cable/busbar cross-section (mm ²)/(mm x mm).....	1 x 240 / 30 x 10	
	cable/busbar length (mm)/(mm).....	2000 / 600	
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- power loss (W)	45 max.	
	- rated breaking capacity (kA)	100	
	Time duration of the overload test (s)	770	
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed	Opened and closed	P
	Required opening force not greater than the test force of 8.2.5.2 and table 8		P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage 2 U _e with a minimum of 1000V~ (V) ...	1380	
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage 1,1 U _e (V)	760	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P



БУРНО С
 ОПИШНАТА

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.7.4	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			—
	- manufacturer's name, trademark or identification mark	Jean Müller		—
	- manufacturer's model or type reference	M2gG400/69		—
	- rated voltage (V)	690		—
	- rated current (A)	400		—
	- power loss (W)	45 max.		—
	- rated breaking capacity (kA)	100		—
	Fuse link(s) aged during the overload test are replaced by new fuse-link(s)	Yes		P
	Conductor cross-section (mm ²)	1 x 240		—
	Test current I _e (A)	400		—
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 62	75	P
	Manual operating means: non-metallic	6	35	P
	Parts intended to be touched but not hand-held: non-metallic	32	50	P
	Parts which need not be touched during normal operation: non-metallic	38	60	P




ВЯЧНО С
ОРИГИНАЛ

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7.1	Overload test		P
	Type SL2-3x3/3A		
	ambient temperature 10-40 °C	22	
	test enclosure W x H x D (mm x mm x mm)	-	
	material of enclosure	-	
	test current 1,6 x Ithe or 1,6 x Ith (A)	640	
	cable/busbar cross-section (mm ²)/(mm x mm).....	1 x 240 / 30 x 10	
	cable/busbar length (mm)/(mm).....	2000 / 600	
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M2gG400/69	
	- rated voltage (V)	690	
	- rated current (A)	400	
	- power loss (W)	45 max.	
	- rated breaking capacity (kA)	100	
	Time duration of the overload test (s)	802	
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed	Opened and closed	P
	Required opening force not greater than the test force of 8.2.5.2 and table 8		P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage 2 Ue with a minimum of 1000V~ (V) ...	1380	
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage 1,1 Ue (V)	760	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole	-	N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA)	< 1	P




**ВЪРНО С
ОРИГИНАЛА**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.7.4	Temperature-rise verification			P
	Fuse-link details (fuse-combination units only):			—
	- manufacturer's name, trademark or identification mark	Jean Müller		—
	- manufacturer's model or type reference	M2gG400/69		—
	- rated voltage (V)	690		—
	- rated current (A)	400		—
	- power loss (W)	45 max.		—
	- rated breaking capacity (kA)	100		—
	Fuse link(s) aged during the overload test are replaced by new fuse-link(s)	Yes		P
	Conductor cross-section (mm ²)	1 x 240		—
	Test current I _e (A)	400		—
	Temperature-rise dT of part:	dT (K) measured	dT (K) required	P
	Terminals	≤ 62	75	P
	Manual operating means: non-metallic	5	35	P
	Parts intended to be touched but not hand-held: non-metallic	32	50	P
	Parts which need not be touched during normal operation: non-metallic	38	60	P




**ԵՊՓՈՑ
ՕՐԻՆՏԱՆ**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.4	ELECTROMAGNETIC COMPATIBILITY TESTS		P
8.4.1	Immunity		P
8.4.1.1	Equipment not incorporating electronic circuits: no tests necessary		P
8.4.1.2	Equipment incorporating electronic circuits:		N/A
	Equipment utilizing circuits in which all components are passive are not required to be tested		N/A
	All other equipment, requirements according to 7.3.3.2 and limits according table 6 apply		N/A
	Performed tests.....:	-	N/A
	No unintentional separation or closing of contacts has occurred during these tests	-	N/A
8.4.2	Emission		P
8.4.2.1	Equipment not incorporating electronic circuits: no tests necessary		P
8.4.2.2	Equipment incorporating electronic circuits:		N/A
	Equipment utilizing circuits in which all components are passive are not required to be tested		N/A
	All other equipment, requirements according to 7.3.3.2 and limits according table 7 apply		N/A
	Performed tests.....:	-	N/A




**BAHAGIAN
OPERASI**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
Annex A (normative)			N/A
A	Equipment for direct switching of a single motor		N/A
A.1	Additional rated duties	-	N/A
A.1.1	- Intermittent periodic duty		N/A
	- Intermittent duty		N/A
A.1.1.1	Classes of Intermittent duty	-	N/A
	-class 1: up to 1 operating cycle per hour		N/A
	-class 3: up to 3 operating cycle per hour		N/A
	-class 12: up to 12 operating cycles per hour		N/A
	-class 30: up to 30 operating cycles per hour		N/A
	-class 120: up to 120 operating cycles per hour		N/A
A.1.2	Temporary duty	-	N/A
A.5	Mechanical durability:		N/A
	Equipment mounted according to manufacturer's instruction		N/A
	Preferred number of no-load operating cycles expressed in millions.....	-	N/A
	0,001 – 0,003 – 0,01 – 0,03 – 0,1 – 0,3 – 1		N/A
	If no mechanical endurance is stated by the manufacturer, a minimum mechanical endurance according to the class of Intermittent duty shall be tested.		N/A
	Number of no-load operating cycles performed.....	-	N/A
A.6	Electrical durability:		N/A
	- test according to manufacturer's instruction		N/A
A.7	Verification of making and breaking capacities:		N/A
	- utilization category	-	
	- rated operational voltage U_e (V)	-	
	- rated operational current I_e (A)	-	
	Conditions for make/break operations or make operations:		
	- test voltage, $U = 1,05 U_e$	L1: - L2: - L3: -	
	- test current, $I =$ x I_e (A):	L1: - L2: - L3: -	
	- power factor	L1: - L2: - L3: -	




ВЯРХО С
ОПМІННАЯ

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditions for make/break operations:		N/A
	- test voltage, $U = 1,05 U_e$(V):	L1: - L2: - L3: -	
	- test current, $I =$ $\times I_e$ (A):	L1: - L2: - L3: -	
	- power factor / time constant	L1: - L2: - L3: -	
	Number of make/break or make and break operations	-	N/A
	- recovery voltage duration ≥ 50 ms (ms)		N/A
	- current duration (ms)	-	
	- time interval between operations (s)	-	N/A
	Characteristic of transient recovery voltage if necessary:		N/A
	- oscillatory frequency (kHz)	-	
	- measured oscillatory frequency (kHz)	L1: - L2: - L3: -	N/A
	- factor γ	L1: - L2: - L3: -	N/A
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		N/A
	Test performed without:		
	- endanger to the operator		N/A
	- cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A
8.3.3.4	Dielectric verification		N/A
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...:	-	
	No flashover or breakdown		N/A




**ВРНО С
ОРИГИНАЛ**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.5	Leakage current		N/A
	test voltage $1,1 U_e$ (V)	-	
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole	-	N/A
	Leakage current (other utilization categories): ≤ 2 mA/pole (mA)	-	N/A
8.3.3.6	Temperature-rise verification		N/A
	- conductor cross-section (mm ²)	-	
	- test current I_e (A)	-	
	Measured temperature-rise	-	N/A
A.8	Operational performance test:		N/A
	- utilization category	-	
	- rated operational voltage (V)	-	
	- rated operational current (A)	-	
	Test conditions for electrical operation cycles:		N/A
	- test voltage (V)	L1: - L2: - L3: -	
	- test current (A)	L1: - L2: - L3: -	
	- power factor / time constant	L1: - L2: - L3: -	
	Number of cycles with current	-	N/A
	Number of cycles without current	-	N/A
	First test sequence (with/without current)	-	
	Second test sequence (with/without current)	-	
	- time interval between first and second test sequence	-	
	- recovery voltage duration at operations with current ≥ 50 ms (ms)	-	N/A
	- current duration (ms)	-	
	- time interval between operations (s)	-	N/A
8.3.4.1.5	Behaviour of the equipment during the operational performance test		N/A
	Test performed without:		
	- endanger to the operator		N/A
	- cause damage to adjacent equipment		N/A
	No permanent arcing		N/A




ВЯНО С
ОПРИМАНЕ

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A
8.3.4.2	Dielectric verification		N/A
	test voltage $2 U_e$ with a minimum of 1000V~ (V) ...: -		
	No breakdown or flashover		N/A
8.3.4.3	Leakage current		N/A
	test voltage $1,1 U_e$ (V): -		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole: -		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole (mA): -		N/A
8.3.4.4	Temperature-rise verification		N/A
	- conductor cross-section (mm^2): -		
	- test current I_e (A): -		
	Measured temperature-rise: -		N/A
A.9	Special tests:	-	N/A



**ВЯРНО С
ОРИГИНАЛ**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
Annex C (normative)			P
C	Single pole operated three pole switches		P
C.1	Three pole operated switches of fundamentally the same design, already successfully tested are deemed to satisfy the requirements of individually operated three pole devices.		P
C.2	Additional-tests to be performed on single pole operated three pole switches		P
	Test "8.3.3.3 Making and breaking capacities" according to test sequence I with following modifications		P
	L1 and L2 are closed, L3 is subjected to the required make-break operation cycle.....	see pages 16 to 19 see pages 24 to 27 see pages 32 to 35	P
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle.....	see pages 16 to 19 see pages 24 to 27 see pages 32 to 35	P
	Test performed in a three phase circuit		P
	Test "8.3.4.1 Operational performance" according to test sequence II with following modifications		P
	L1 and L2 are closed, L3 is subjected to the required make-break operation cycle.....	see pages 40 to 41 see pages 44 to 45 see pages 48 to 49	P
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle.....	see pages 40 to 41 see pages 44 to 45 see pages 48 to 49	P
	Test performed in a three phase circuit		P
	Test "8.3.6.2 Fuse protected short circuit test" according to test sequence IV with following modifications		P
	For the making test L1 shall be open and L2 closed, L3 is subjected to the required make operation cycle	see pages 58 to 60 see pages 64 to 66	P
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle.....	-	N/A
	Test performed in a three phase circuit		P
C.5	Instruction for use		P
	The product literature includes following statement.....		P
	These devices are intended for power distribution systems where switching and/or isolating of an individual phase may be necessary and shall not be used for the switching of the primary circuit of three-phase equipment.		P



**БЯРНО С
ОПРАТНАНА**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark	Verdict	
8.3.3.1	TABLE 1: Temperature-rise at SL2-3x/3A with fuse-links 400A		P	
Temperature rise dT of part:		dT (K) measured	dT (K) required	
Terminals	Incoming (tin plated copper)	L1	42	65
		L2	42	
		L3	43	
	Outgoing (tin plated copper)	L1	47	65
		L2	48	
		L3	58	
Manual operating means: non-metallic		6	25	
Parts intended to be touched but not hand-held: non-metallic		27	40	
Parts which need not be touched during normal operation: non-metallic		35	50	
Supplementary Information: Ambient temperature: 22°C				


8.3.3.1	TABLE 2: Temperature-rise at SL2-3x3/3A with fuse-links 400A		P	
Temperature rise dT of part:		dT (K) measured	dT (K) required	
Terminals	Incoming (tin plated copper)	L1	40	65
		L2	42	
		L3	43	
	Outgoing (tin plated copper)	L1	48	65
		L2	48	
		L3	60	
Manual operating means: non-metallic		6	25	
Parts intended to be touched but not hand-held: non-metallic		27	40	
Parts which need not be touched during normal operation: non-metallic		34	50	
Supplementary Information: Ambient temperature: 22°C				



БЪЛГАРИЯ
ОПШИННА

IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.3.1	TABLE 3: Temperature-rise at SL2-3x/3A with solid-links 630A			P
Temperature rise dT of part:			dT (K) measured	dT (K) required
Terminals	Incoming (tin plated copper)	L1	45	65
		L2	45	
		L3	46	
	Outgoing (tin plated copper)	L1	54	65
		L2	55	
		L3	64	
Manual operating means: non-metallic			4	25
Parts intended to be touched but not hand-held: non-metallic			23	40
Parts which need not be touched during normal operation: non-metallic			31	50
Supplementary Information: Ambient temperature: 22°C				

8.3.3.1	TABLE 4: Temperature-rise at SL2-3x3/3A with solid-links 630A			P
Temperature rise dT of part:			dT (K) measured	dT (K) required
Terminals	Incoming (tin plated copper)	L1	45	65
		L2	46	
		L3	45	
	Outgoing (tin plated copper)	L1	56	65
		L2	55	
		L3	63	
Manual operating means: non-metallic			4	25
Parts intended to be touched but not hand-held: non-metallic			24	40
Parts which need not be touched during normal operation: non-metallic			30	50
Supplementary Information: Ambient temperature: 22°C				



**ВЯРНО С
ОРИГИНАЛА**

IEC 60947-3				
Clause	Requirement + Test	Result - Remark	Verdict	
8.3.3.1	TABLE 5: Temperature-rise at SL2-3x/KM2G-F with fuse-links 400A		P	
Temperature rise dT of part:		dT (K) measured	dT (K) required	
Terminals	Incoming (tin plated copper)	L1	40	65
		L2	42	
		L3	41	
	Outgoing (tin plated copper)	L1	48	65
		L2	48	
		L3	57	
Manual operating means: non-metallic		6	25	
Parts intended to be touched but not hand-held: non-metallic		25	40	
Parts which need not be touched during normal operation: non-metallic		34	50	
Supplementary Information: Ambient temperature: 22°C				

8.3.3.1	TABLE 6: Temperature-rise at SL2-3x3/KM2G-F with fuse-links 400A		P	
Temperature rise dT of part:		dT (K) measured	dT (K) required	
Terminals	Incoming (tin plated copper)	L1	40	65
		L2	43	
		L3	42	
	Outgoing (tin plated copper)	L1	48	65
		L2	50	
		L3	56	
Manual operating means: non-metallic		6	25	
Parts intended to be touched but not hand-held: non-metallic		26	40	
Parts which need not be touched during normal operation: non-metallic		35	50	
Supplementary Information: Ambient temperature: 22°C				

ОПНО С
СРЕДНАТА



IEC 60947-3				
Clause	Requirement + Test	Result - Remark		Verdict
8.3.3.1	TABLE 7: Temperature-rise at SL2-3x/KM2G with fuse-links 400A			P
Temperature rise dT of part:			dT (K) measured	dT (K) required
Terminals	Incoming (tin plated copper)	L1	41	65
		L2	43	
		L3	41	
	Outgoing (tin plated copper)	L1	49	65
		L2	51	
		L3	57	
Manual operating means: non-metallic			6	25
Parts intended to be touched but not hand-held: non-metallic			25	40
Parts which need not be touched during normal operation: non-metallic			36	50
Supplementary Information: Ambient temperature: 22°C				

8.3.3.1	TABLE 8: Temperature-rise at SL2-3x3/KM2G with fuse-links 400A			P
Temperature rise dT of part:			dT (K) measured	dT (K) required
Terminals	Incoming (tin plated copper)	L1	42	65
		L2	43	
		L3	41	
	Outgoing (tin plated copper)	L1	50	65
		L2	52	
		L3	58	
Manual operating means: non-metallic			6	25
Parts intended to be touched but not hand-held: non-metallic			25	40
Parts which need not be touched during normal operation: non-metallic			37	50
Supplementary Information: Ambient temperature: 22°C				


БРФО С
ОПМНАЈА



List of test equipment used:

Measured quantity	Device	Manufacturer	Code
Voltage (tests up to 15kA)	Voltage divider 1:2000 Difference amplifier AM 502 Signal memory recorder TRA 800	AIT Tektronix W&W	- AM 502/1...3 TRA800
Current (tests up to 15kA)	Lin. current transformer LGSSO Burden 1Ω Signal memory recorder TRA 800	Ritz AIT W&W	WLIN5000/1...3 - TRA800
Voltage (tests above 15kA)	3-channel Insulating measuring amplifier Signal memory recorder Nicolet	Rohrer W&W	Arcus 930-1 2580-P
Current (tests above 15kA)	Lin. current transformer LGSSO Burden 0,7mΩ Signal memory recorder Nicolet	Ritz AIT W&W	WLIN6000.HVF/1...3 - 2580-P
Current (tests at reduced voltage)	Current transformer GE 4461 Current transformer AET110 True-RMS amperemeter KI, 0,5 Digital multimeter Fluke 185	Goerz Siemens Norma Fluke	WI600/1...3 WI4000/1...3 A0,5/1 /4 FLUKE185/2
Transient recovery voltage	Adjustment equipment for TRV Oscilloscope G 801.1	AIT Tektronix	- G801.1
Dielectric properties	High-voltage test equipment 90-1F with measuring equipment Impulse tester 35 Impulse voltmeter SV642 Oscilloscope 9430	Elabo Haefely Haefely Le Croy	HSG5KV G304 G503 G805
Leakage current	High-voltage test equipment 90-1F Digital multimeter Fluke 187 Digital multimeter Fluke 185	Elabo Fluke Fluke	HSG5KV G922 FLUKE185/2
Time	Signal memory recorders TA 800 Stopwatch	W&W Quantum	TRA800 938-3
Temperature	Data Acquisition/Data Logger Switch Unit 34970A Temperature meter TESTO 901	Agilent Testoterm	942 TESTO
Abnormal heat and fire	Glow-wire test device with measuring equipment	Friberg	Glow
Mechanical strength of terminals	Test equipment	AIT	MSD
Insertability of unprepared conductors	Gauges	AIT	Gauge 1...16
Strength of actuator mechanism	Test equipment	Sauter GmbH	FH1K
Degree of protection	Test probe	PTL	PTL 1...3
Clearances, creepage distances	Digital slide gauge CD-20D	Mitutoyo	SCH







Accredited by BMWA, No. BMWA-92.714/0532-V12/2008 as test- and inspection body and according to BGBl. II, No. 244/2005 as certification body for personnel

arsenal research

Ein Unternehmen der Austrian Research Centers.

Test Report

Project Designation

**TYPE TEST
AT A LOW-VOLTAGE
FUSE-SWITCH-DISCONNECTOR
TYPE
SL2G-3x and SL2G-3x3**

Client

Jean Müller GmbH
H.J.-Müller Straße 7
D-65343 Eltville, Germany

Order form / No.

01/2009 / --

Project Number

2.03.00954.1.0 /SL2G

Test Engineer

Ing.J.Ainetter

Date of issue	08.04.2009
Total number of Issues / No.	1 / 1
Number of pages	5
Annex	CB/CCA - Test Report No. 2.03.00954.1.0 /SL2G/CB/CCA (45 pages)

The results relate exclusively to the terms tested.

This report may only be reproduced or published in full, without omissions, alterations or additions.

The reproduction or publishing of extracts from this report requires the written approval of the research center.



**ВЕРНО С
ОРИГИНАЛ**

Test item

Identification:

Low-voltage fuse-switch-disconnector type SL2G-3x and SL2G-3x3

Manufacturer:	Jean Müller GmbH
Trademark:	Jean Müller
Number of poles:	3-pole
Rated operational voltage(s):	AC 400V, AC 500V, AC 690V
Rated operational current(s):	400A
Rated frequency:	50Hz

Technical data and description:

See page 4

Testing location, Period of testing

Testing location:

Österreichisches Forschungs- und Prüfzentrum Arsenal Ges.m.b.H.
Business Unit Electric Energy Systems
Power Service Center
Gleifinggasse 2
1210 Vienna
AUSTRIA

Period of testing:

01 ...03/2009

Test(s)

Test(s) performed:

Type test

Test standard(s):

IEC 60947-1:2007 (5th Edition) and IEC 60947-3:2008 (3rd Edition)
EN 60947-1:2004 and EN 60947-3:1999+A1:2001+A2:2005


Test procedure(s):

CB Scheme and CCA Scheme


Result

The low-voltage fuse-switch-disconnectors type SL2G-3x and SL2G-3x3 have passed the type test successfully.


Test Engineer




Ing. J. Ainetter




Project Engineer,
technical responsibility





Ing. K. Farthofer




Testing laboratory




ACCREDITED according to
EN ISO/IEC 17025
No. BMWA-92.714/0532-V/12/2006




CERTIFICATED according to
ISO 9001
Reg. No. 12789-03




RECOGNIZED
CB TESTING LABORATORY
under the responsibility of OVE
as the National Certification Body



POWER SERVICE CENTER:



Control station for tests up to 15kA



Control station for tests above 15kA



**ВРФО С
ОПИШНА**

Technical data and description


Test Item	Low-voltage fuse-switch-disconnector
Trademark	Jean Müller
Model/Type reference	SL2G-3x and SL2G-3x3
Manufacturer	Jean Müller GmbH
Place of manufacture	H.J.-Müller Straße7, D-65343 Eltville, Germany
Method of operation	Dependent manual operation
Switching positions	ON / OFF
Number of poles	3-pole
Nature of supply	AC
Utilization category	AC-22B
Rated operational voltage	400V, 500V, 690V
Rated operational current	400A
Rated frequency	50Hz
conventional free air thermal current Ith	400A
Rated insulation voltage	1000V
Rated impulse withstand voltage	12kV
Rated conditional short-circuit current	80kA
Degree of protection	IP30
Kind of protective device	Fuse-link NH2

**ВРНО С
ОПШТАНА**



Measuring equipment

Measured quantity	Device	Manufacturer	Code
Voltage (tests up to 15kA)	Voltage divider 1:2000 Difference amplifier AM 502 Signal memory recorder TRA 800	ÖFPZ Arsenal Tektronix W&W	- AM 502/1...3 TRA800
Current (tests up to 15kA)	Lin. current transformer LGSSO Burden 1Ω Signal memory recorder TRA 800	Ritz ÖFPZ Arsenal W&W	WLIN5000/1...3 - TRA800
Voltage (tests above 15kA)	3-channel insulating measuring amplifier Signal memory recorder SMR II	Rohrer W&W	T908D SMRII64/1
Current (tests above 15kA)	Lin. current transformer LGSSO Burden 0,7mΩ Signal memory recorder SMR II	Ritz ÖFPZ Arsenal W&W	WLIN6000.HVF/1...3 - SMRII64/1
Current (tests at reduced voltage)	Current transformer GE 4461 Current transformer AETt10 True-RMS amperemeter KI. 0,5 Digital multimeter Fluke 185	Goerz Siemens Norma Fluke	WI600/1...3 WI4000/1...3 A0,5/1...3 FLUKE185/1, 2
Transient recovery voltage	Adjustment equipment for TRV Oscilloscope G 801.1	ÖFPZ Arsenal Tektronix	- G801.1
Dielectric properties	High-voltage test equipment 90-1F with measuring equipment Impulse tester 35 Impulse voltmeter 64M Oscilloscope 9410	Elabo Haefely Haefely Le Croy	HSG5KV G304 G502 G803
Leakage current	High-voltage test equipment 90-1F Digital multimeter Fluke 185 Digital multimeter Fluke 185	Elabo Fluke Fluke	HSG5KV FLUKE185/1 FLUKE185/2
Time	Signal memory recorder TRA 800 Stopwatch	W&W Junghans	TRA800, SMRII64/1 938-2
Temperature	24-channel recorder Polycomp SK30 Temperature meter TESTO 901	H & B Testoterm	SK 30 TESTO
Abnormal heat and fire	Glow-wire test device with measuring equipment	Friborg	-
Mechanical strength of terminals	Test equipment	ÖFPZ Arsenal	-
Insertability of unprepared conductors	Gauges	ÖFPZ Arsenal	-
Strength of actuator mechanism	Test equipment	Schatz	-
Degree of protection	Test probe	PTL	-
Clearances, creepage distances	Digital slide gauge CD-20D	Mitutoyo	SCHUB




**BRPHO C
OPUKHANA**



Test Report issued under the responsibility of



TEST REPORT IEC / EN 60947-3 Low-voltage switchgear and controlgear Part 3: Switches, disconnectors, switch-disconnectors and fuse combination units	
Report Reference No.	2.03.00954.1.0 /SL2G/CB/GCA
Date of Issue.....	08.04.2009
Total number of pages.....	45
CB / CCA Testing Laboratory.....	ÖFPZ Arsenal Ges.m.b.H.
Address	A-1210 Wien, Gleifinggasse 2
Applicant's name.....	Jean Müller GmbH
Address	H.J.-Müller Strasse 7, D-65343 Eltville, Germany
Test specification:	
Standard	<input checked="" type="checkbox"/> IEC 60947-3:1999 (Second Edition) + A1:2001 + A2:2005 in conjunction with IEC 60947-1:2004 (Fourth Edition)
	<input checked="" type="checkbox"/> EN 60947-3:1999 + A1:2001 + A2:2005 in conjunction with EN 60947-1:2004
Test procedure.....	CB / CCA
Non-standard test method.....	N/A
Test Report Form No.....	IECEN60947_3B
Test Report Form(s) Originator	OVE
Master TRF.....	Dated 2006-08
Copyright © 2006 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo shall be removed.	
This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
This report is not valid as a CCA Test Report unless signed by an approved CCA Testing Laboratory and appended to a CCA Test Certificate issued by an NCB in accordance with CCA.	
Test item description.....	Fuse-switch-disconnector
Trade-Mark	JEAN MÜLLER
Manufacturer	Jean Müller GmbH H.J.-Müller Strasse 7, D-65343 Eltville, Germany
Model/Type reference.....	SL2G-3x and SL2G-3x3
Ratings.....	AC-22B; 690V; 400A; 3-pole



**ВЯРНО С
ОРИГИНАЛА**


Summary of testing:	
Tests performed (name of test and test clause): A type test was performed according to <ul style="list-style-type: none"> ▪ IEC 60947-1:2007 (5th Edition) ▪ IEC 60947-3:2008 (3rd Edition) and <ul style="list-style-type: none"> ▪ EN 60947-1:2004 ▪ EN 60947-3:1999+A1:2001+A2:2005. The fuse-switch-disconnectors type <ul style="list-style-type: none"> ▪ SL2G-3x and SL2G-3x3 have passed the type test successfully.	Testing location: ÖFPZ Arsenal Ges.m.b.H. Business Unit Electric Energy Systems Power Service Center Gleifinggasse 2 1210 Wien AUSTRIA The ÖFPZ Arsenal Ges.m.b.H. is a recognized CB Testing Laboratory under the responsibility of OVE as the National Certification Body.
Summary of compliance with National Differences: ---	
Copy of marking plate:	
<p>SL2G-3x:</p>	
<p>SL2G-3x3:</p>	





**ВЯРНО С
ОПРИМНАТА**

Picture(s) of the test item:

SL2G-3x3: Fuse-switch-disconnector, 3-poles, Independent switching pole after pole




SL2G-3x3: Fuse-switch-disconnector, 3-poles, switching 3-poles together, with locking device in close and open position



ВАРНО С
ОРИГИНАЛ

Test item particulars:	
- method of mounting.....	: Dependent manual operation
- switching positions	: I / O
- number of poles.....	: 3
- kind of current.....	: AC
- number of positions of the main contacts	: 2
Rated and limiting values, main circuit:	
- rated operational voltage U_e (V)	: 400, 500, 690
- rated insulation voltage U_i (V).....	: 1000
- rated impulse withstand voltage U_{imp} (kV).....	: 12
- rated operational current I_e with solid-links (A).....	: 400
- conventional free air thermal current I_{th} with fuse-links (A).....	: 400
- rated uninterrupted current I_u with fuse-links (A).....	: 400
- rated frequency (Hz)	: 50 to 60
- utilization category.....	: AC-22B
Short-circuit characteristic:	
- rated short-time withstand current I_{cw} (A)	: -
- rated short-time making capacity I_{cm} (A)	: -
- rated conditional short-circuit current (kA)	: 80
Rated and limiting values, auxiliary circuit(s):	
- rated operational voltage (V).....	: -
- rated frequency (Hz)	: -
- number of circuits.....	: -
- number and kind of contact elements	: -
Co-ordination of short-circuit protective devices:	
- kind of protective device.....	: NH-fuse 400A gG (size 02)
Possible test case verdicts:	
- test case does not apply to the test object.....	: N (Not applicable)
- test object does meet the requirement.....	: P (Pass)
- test object does not meet the requirement.....	: F (Fail)
Testing:	
Date of receipt of test item.....	: 01/2009
Date (s) of performance of tests.....	: 01 ... 3/2009



**БЯРНО С
ОРГАНІЗАЦІЯ**

General remarks:

The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the issuing testing laboratory.

"(See Enclosure #)" refers to additional information appended to the report.
"(See appended table)" refers to a table appended to the report.


Note: EN Group Differences together with National Differences and Special National Conditions, if any, are stated in the Appendix to the main body of this TRF.

Throughout this report a comma is used as the decimal separator.

The making and breaking and the short-circuit tests are carried out with a metallic screen placed at:
-right side 130mm
-left side 120mm
-upper side 160mm


General product information:

**Low-voltage fuse-switch-disconnector
size 2
for use with NH fuse-links
type
SL2G-3x and SL2G-3x3**



**ВЫПОЛНЕНО
ОПТИМАЛЬНО**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
5.2	MARKING		P
	Marking on equipment itself or on nameplate or nameplates attached to the equipment and legible from the front after mounting		P
	- Indication of the open and closed position	Visible open and closed position	P
	- suitability for isolation	Yes	P
	- disconnectors AC-20 and DC-20 only: marked "Do not operate under load"		N
	Marking on equipment not needed to be visible after mounting:		P
	- manufacturer's name or trademark	JEAN MÜLLER	P
	- type designation or serial number	SL2G-3x SL2G-3x3	P
	- rated operational current	400A	P
	- rated operational voltage	400V, 500V, 690V	P
	- utilization category	AC-22B	P
	- rated frequency	50-60Hz	P
	- manufacturer's claim for compliance with IEC/EN 60947-3	EN 60947-3	P
	- degree of protection	IP30	P
	Marking on fuse-combination units:		P
	- fuse type	NH fuse-link size 2	P
	- maximum rated current	400A	P
	- power loss of the fuse-link	45W	P
	Identification of terminals:		P
	- line terminals		P
	- load terminals		P
	- neutral pole terminal		N
	- protective earth terminal		N
	Data in the manufacturer's published information:		P
	- rated insulation voltage	1000V	P
	- rated impulse withstand voltage for equipment suitable for isolation or when determined	12kV	P
	- pollution degree, if different from 3	3	P
	- rated duty	Uninterrupted duty	P
	- rated short-time withstand current and duration	-	N
	- rated short-circuit making capacity	-	N
	- rated conditional short-circuit current	80kA	P



IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
7.1	CONSTRUCTION		P
7.1.1	Materials		P
7.1.1.1	Resistance to abnormal heat and fire		P
	Glow-wire test according to IEC 60695-2-10 and IEC 60695-2-11		P
	Parts made of insulating material necessary to retain current-carrying parts in position: test temperature 960 °C		P
	No visible flame and no sustained glowing.....: No visible flame		P
	Flames and glowing extinguish within 30 s: -		N
	No ignition of the tissue paper		P
	Parts of insulating material not necessary to retain current-carrying parts in position, even though in contact with them: test temperature 650 °C		P
	No visible flame and no sustained glowing.....: No visible flame		P
	Flames and glowing extinguish within 30 s: -		N
	No ignition of the tissue paper		P
7.1.2	Current-carrying parts and their connection		P
7.1.3	Clearances		P
	Rated impulse withstand voltage (kV): 8		—
	Minimum clearances (mm): 8		—
	Measured clearances (mm).....: > 8		P
	Creepage distances		P
	Pollution degree: 3		—
	Comparative tracking index (V): 600		—
	Material group: I		—
	Rated insulation voltage UI (V): 1000		—
	Minimum creepage distances (mm).....: 14		—
	Measured creepage distances (mm): > 14		P
7.1.4	Actuator		—
7.1.4.1	Insulation		—
	Actuator insulated from live parts for		—
	- rated insulation voltage	UI = 1000V	P
	- rated impulse withstand voltage	Uimp = 12kV	P
	Actuator made of metal	No	—
	- connected to a protective conductor or provided with an additional insulation		N




BŞİPHO C
DİREKTÖRLÜĞÜ

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Actuator made of or covered by insulating material:	Thermoplastic material	—
	- internal metal parts, which might become accessible in the event of an insulation failure, are also insulated from live parts for the rated insulation voltage		P
7.1.4.2	Direction of movement		P
	The direction of operation for actuators shall where applicable conform to IEC 60447		P
	There is no doubt of the "I" and "O" position and the direction of operation		P
7.1.5 of Part 1	Indication of contact position		P
7.1.5.1	Indicating means		P
7.1.5.2	Indication by the actuator	Yes	P
7.1.6	Additional safety requirements for equipment suitable for isolation		P
7.1.6.1	Additional constructional requirements for equipment suitable for isolation ($U_e > 50$ V):		P
	- marking according to 5.2.1b		P
	- indication of the position of the contacts		P
	- construction of the actuating mechanism		P
	- minimum clearances across open contacts (see Table 13, Part 1) (mm): 14		—
	- measured clearances (mm).....: > 14		P
	- test U_{imp} across gap (kV): 18,5		P
7.1.6.2	Supplementary requirements for equipment with provision for electrical interlocking with contactors or circuit-breakers:		N
	Auxiliary switch is rated according to IEC 60947-5-1 (unless the equipment is rated AC-23)		N
	Time interval between opening of the contacts of the auxiliary contact and the contacts of the main poles: ≥ 20 ms.....: -		—
	Measured time interval (ms): -		N
	During the closing operation the contacts of the auxiliary switch closes after or simultaneously with the contacts of the main poles		N




**БАРФОС
ОПРЕДЕЛЕНА**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
7.1.6.3	Supplementary requirements for equipment provided with means for padlocking the open position:		N
	The locking means is so designed that it cannot be removed with the appropriate padlock(s) installed		N
	Test force F applied to the actuator in an attempt to operate to the closed position (N).....: -		—
	Rated impulse withstand voltage (kV): -		—
	Test Uimp on open main contacts at test force (kV).....: -		N
7.1.7 of Part 1	Terminals		P
7.1.7.1	All parts of terminals which maintain contact and carry current are of metal having adequate mechanical strength	See 8.2.4 below	P
	Terminal connections are such that necessary contact pressure is maintained	See 8.2.4 below	P
	Terminals are so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	See 8.2.4 below	P
	Terminals do not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage is not reduced below the rated value	See 8.2.4 below	P
8.2.4	Mechanical properties of terminals		P
	Mechanical strength of terminals		P
	Maximum cross-sectional area of conductor.....: 240mm ²		—
	Diameter of thread (mm).....: M12		—
	Torque (Nm).....: 40Nm x 11% = 44Nm		—
	5 times on 2 separate clamping units		P
	Testing for damage to and accidental loosening of conductor (flexion test)		N
	Type of terminals tested.....: -		—
	Conductor of the smallest cross-sectional area (mm ²).....: -		—
	Number of conductors of the smallest cross section.....: -		—
	Diameter of bushing hole (mm): -		—




БЪЛГАРИЯ
ОПШТИНА
СЪПХОС

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Height between equipment and platen (mm).....:	-	—
	Mass at the conductor(s) (kg).....:	-	—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		—
	Pull-out test		N
	Force (N), applied for 1 min.....:	-	—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		—
	Conductor of the largest cross-sectional area (mm ²).....:	-	—
	Number of conductors of the largest cross section.....:	-	—
	Diameter of bushing hole (mm).....:	-	—
	Height between equipment and platen (mm).....:	-	—
	Mass at the conductor(s) (kg).....:	-	—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		—
	Pull-out test		N
	Force (N), applied for 1 min.....:	-	—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		N
	Conductor of the largest and smallest cross-sectional area (mm ²).....:	-	—
	Number of conductor of the smallest cross section, number of conductor of the largest cross section .. :	-	—
	Diameter of bushing hole (mm).....:	-	—
	Height between equipment and platen (mm).....:	-	—
	Mass at the conductor(s) (kg).....:	-	—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		N
	Pull-out test		N
	Force (N), applied for 1 min.....:	-	—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		N



**BAPIO C
PUNJANA**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
7.1.7.2	Connection capacity		P
	Type of conductors	Cable lugs for busbars	--
	Minimum cross-sectional area of conductor		--
	Maximum cross-sectional area of conductor		--
	Number of conductors simultaneously connectable to the terminal.....		--
7.1.7.3	Connection		P
	Terminals for connection to external conductors are readily accessible during installation		P
	Clamping screws and nuts do not serve to fix any other component		P
7.1.7.4	Terminal identification and marking		P
	Terminal intended exclusively for the neutral conductor		N
	Protective earth terminal		N
	Other terminals		P
7.1.8	Additional requirements for equipment provided with a neutral pole		N
	Equipment provided with a pole intended for the connection of neutral, this pole shall be clearly marked by the letter "N"		N
	The switched neutral pole does not break before and does not make after the other poles except		N
	- a pole having the appropriate short-circuit breaking and making capacity is used as neutral pole, all poles may operate together		N
	Conventional thermal current of neutral pole		N
7.1.9	Provisions for protective earthing		N
7.1.9.1	The exposed conductive parts are electrically interconnected and connected to a protective earth terminal		N
7.1.9.2	Protective earth terminal is readily accessible		N
	Protective earth terminal is suitably protected against corrosion		N
	Electrical continuity between exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	Protective earth terminal has no other functions		N
7.1.9.3	Protective earth terminal marking and identification		N




IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
7.1.10	Enclosure for equipment		N
7.1.10.1	Design		N
	When the enclosure is opened, all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space is provided inside the enclosure		N
	The fixed parts of a metal enclosure are electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances a removable metal part of the enclosure is insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure are firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
	If the enclosure is used for mounting push-buttons, it is not possible to remove the buttons from the outside of the enclosure		N
7.1.10.2	Insulation		N
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining is securely fixed to the enclosure		N
7.1.11	Degree of protection of enclosed equipment		P
	Degree of protection: IP30		P

БРРНО С
ОПШНАА




IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS		P
8.3.3.1	Temperature-rise		P
	ambient temperature 10-40°C	25	—
	test enclosure W x H x D (mm x mm x mm)	-	—
	material of enclosure.....	-	—
	Main circuits, test conditions:		P
	- conventional thermal current I _{th} (A)	400A	—
	- conventional enclosed thermal current I _{the} (A).....	-	—
	- cable/busbar cross-section (mm ²)/(mmxmm)	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	Fuse-link details (fuse-combination units only):		P
	- manufacturer's name, trademark or identification mark.....	Dummy	—
	- manufacturer's model or type reference.....	-	—
	- rated voltage (V)	-	—
	- rated current (A).....	400A	—
	- power loss (W).....	45W	—
	- rated breaking capacity (kA).....	-	—
	Temperature-rise of phase poles	See appended table 1	P
	Temperature-rise of neutral pole (if applicable)		N
	Temperature-rise of accessible parts	See appended table 1	P
	Auxiliary circuits, test conditions:		N
	- rated operation current (A)	-	—
	- cable cross-section (mm ²)	-	—
	Temperature-rise of terminals		N
	Temperature-rise of accessible parts		N



IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.2	Test of dielectric properties		P
	Rated impulse withstand voltage (kV)	12	—
	- test Uimp main circuits (kV).....	14,8	P
	- test Uimp auxiliary circuits (kV)	-	N
	- test Uimp on open main contacts (equipment suitable for isolation) (kV).....	18,5	P
	Power-frequency withstand voltage (V).....	1000	—
	- main circuits, test voltage for 5 sec. (V).....	2200	P
	- control and auxiliary circuits, test voltage for 5 sec. (V)	-	N
	Devices, which have been disconnected for the power-frequency withstand voltage test	-	N
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V).....	760	P
	Measured leakage current (mA)	< 0,2	P

БРПНО С
 ОПИТНАТА



IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity		P
	SL2G-3x3		
	- utilization category	AC-22B	—
	- rated operational voltage U_e (V).....	690	—
	- rated operational current I_e (A) or power (kW)....	400	—
	Conditions for make operations, AC-23A and AC-23B only:		N
	- test voltage, $U = 1,05 U_e$ (V)	L1: - L2: - L3: -	—
	- test current, $I = \dots \times I_e$ (A)	L1: - L2: - L3: -	—
	- power factor	L1: - L2: - L3: -	—
	Conditions for break operations, AC-23A and AC-23B only:		N
	- test voltage, $U = 1,05 U_e$ (V)	L1: - L2: - L3: -	—
	- test current, $I = \dots \times I_e$ (A)	L1: - L2: - L3: -	—
	- power factor	L1: - L2: - L3: -	—
	Conditions for make/break operations, other than AC-23A and AC-23B:		P
	- test voltage, $U = 1,05 U_e$ (V)	L1: 742 L2: 746 L3: 742	—
	- test current, $I = 3 \times I_e$ (A)	L1: 1231 L2: 1221 L3: 1225	—
	- power factor/time constant	L1: 0,65 L2: 0,65 L3: 0,65	—
	Number of make/break or make and break operations	5	P
	- recovery voltage duration (≥ 50 ms).....	Permanent	P
	- current duration (ms)	500	—
	- time interval between operations (s).....	30	P



IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Characteristic of transient recovery voltage for AC-22 and AC-23 only:		P
	- oscillatory frequency (kHz)	44,2	—
	- measured oscillatory frequency (kHz).....	L1: 48,1 L2: 48,1 L3: 47,9	P
	- factor γ	L1: 1,1 L2: 1,1 L3: 1,1	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles or poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		P
	test voltage; $2 \cdot U_e$ with a minimum of 1000V~ (V)...	1380	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 U_e) (V).....	759 (tested with 800V)	—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): $\leq 0,5$ mA / pole (mA)	-	N
	Leakage current (other utilization categories): $\leq 2,0$ mA / pole (mA)	< 2	P
8.3.3.6	Temperature-rise verification		P
	- conductor cross-section (mm ²) / (mmxmm).....	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	- test current I_e (A).....	400A	—
	Temperature rise of main circuit terminals ≤ 80 K (K).....	60	P




БІЛЛО С
ОПІВНІА

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		P
	- actuator type (fig.).....	One-hand operated (1e)	—
8.2.5.2.1	Dependent and independent manual operation		P
	- actuating force for opening (N).....	154	—
	- test force with blocked main contacts (N).....	400	—
	- used method to keep the contact closed.....	Welding	—
	During and after the test, open position not indicated.....	No open position	P
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N
8.2.5.2.2	Dependent power operation		N
	- main contacts fixed together in the closed position.....	-	N
	- used method to keep the contact closed.....	-	N
	- 110% of the rated supply voltage applied to the equipment (3 times).....	-	N
	During and after the test, open position not indicated.....	-	N
	Equipment show no damage impairing its normal operation.....	-	N
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N
8.2.5.2.3	Independent power operation		N
	- main contacts fixed together in the closed position.....	-	N
	- used method to keep the contact closed.....	-	N
	- stored energy of the power operator released (3 times).....	-	N
	During and after the test, open position not indicated.....	-	N
	Equipment show no damage impairing its normal operation.....	-	N
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N



IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity		P
	SL2G-3x		
	- utilization category	AC-22B	—
	- rated operational voltage U_e (V).....	690	—
	- rated operational current I_e (A) or power (kW)....	400	—
	Conditions for make operations, AC-23A and AC-23B only:		N
	- test voltage, $U = 1,05 U_e$ (V)	L1: - L2: - L3: -	—
	- test current, $I = \dots \times I_e$ (A)	L1: - L2: - L3: -	—
	- power factor	L1: - L2: - L3: -	—
	Conditions for break operations, AC-23A and AC-23B only:		N
	- test voltage, $U = 1,05 U_e$ (V)	L1: - L2: - L3: -	—
	- test current, $I = \dots \times I_e$ (A)	L1: - L2: - L3: -	—
	- power factor	L1: - L2: - L3: -	—
	Conditions for make/break operations, other than AC-23A and AC-23B:		P
	- test voltage, $U = 1,05 U_e$ (V)	L1: 741 L2: 747 L3: 742	—
	- test current, $I = 3 \times I_e$ (A)	L1: 1235 L2: 1228 L3: 1219	—
	- power factor/time constant	L1: 0,66 L2: 0,65 L3: 0,65	—
	Number of make/break or make and break operations	5 operations (L1 closed, L2 closed, L3 operated) 5 operations (L1 operated, L2 closed, L3 open)	P
	- recovery voltage duration (≥ 50 ms)	Permanent	P
	- current duration (ms)	500	
	- time interval between operations (s).....	30	

CCA
 2009
 2009



IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Characteristic of transient recovery voltage for AC-22 and AC-23 only:		P
	- oscillatory frequency (kHz)	44,2	—
	- measured oscillatory frequency (kHz)	L1: 48,1 L2: 48,1 L3: 48,1	P
	- factor γ	L1: 1,1 L2: 1,1 L3: 1,1	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles or poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ (V)....	1380	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 U_e) (V)	769 (tested with 800V)	—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): $\leq 0,5$ mA / pole (mA)	-	N
	Leakage current (other utilization categories): $\leq 2,0$ mA / pole (mA)	< 2	P
8.3.3.6	Temperature-rise verification		P
	- conductor cross-section (mm ²) / (mmxmm)	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	- test current I_e (A)	400A	—
	Temperature rise of main circuit terminals ≤ 80 K (K)	58	P

БЯРНОЕ
ОПИСКАНИЕ




IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		P
	- actuator type (fig.).....	One-hand operated (1e)	—
8.2.5.2.1	Dependent and independent manual operation		P
	- actuating force for opening (N).....	130	—
	- test force with blocked main contacts (N).....	390	—
	- used method to keep the contact closed.....	Welding	—
	During and after the test, open position not indicated.....	No open position	P
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N
8.2.5.2.2	Dependent power operation		N
	- main contacts fixed together in the closed position.....	-	N
	- used method to keep the contact closed.....	-	N
	- 110% of the rated supply voltage applied to the equipment (3 times).....	-	N
	During and after the test, open position not indicated.....	-	N
	Equipment show no damage impairing its normal operation.....	-	N
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N
8.2.5.2.3	Independent power operation		N
	- main contacts fixed together in the closed position.....	-	N
	- used method to keep the contact closed.....	-	N
	- stored energy of the power operator released (3 times).....	-	N
	During and after the test, open position not indicated.....	-	N
	Equipment show no damage impairing its normal operation.....	-	N
	Equipment with locking mean, no locking in the open position while test force is applied.....	-	N



ВІДНОС
ОПТИМАЛ

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY Type SL2G-3x3		P
8.3.4.1	Operational performance test		P
	- utilization category	AC-22B	—
	- rated operational voltage U_B (V).....	690	—
	- rated operational current I_B (A) or power (kW)....	400	—
	Test conditions for electrical operation cycles:		P
	- test voltage (V).....	L1: 701 L2: 698 L3: 695	—
	- test current (A).....	L1: 402 L2: 403 L3: 401	—
	- power factor/time constant	L1: 0,79 L2: 0,78 L3: 0,79	—
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current).....	With	—
	Second test sequence (with/without current).....	Without	—
	- time interval between first and second test sequence	No time interval	—
	- recovery voltage duration (≥ 50 ms).....	Permanent	P
	- current duration (ms)	320	—
	- time interval between operations (s).....	60	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles or poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after the operational performance test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P




ВАРНО С
ОРИГИНАЛ

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.4.2	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ (V)... :	1380	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 U_e) (V).....:	759	—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): $\leq 0,5$ mA / pole (mA)	-	N
	Leakage current (other utilization categories): $\leq 2,0$ mA / pole (mA)	< 2	P
8.3.4.4	Temperature-rise verification		P
	- conductor cross-section (mm ²) / (mmxmm).....:	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	- test current I_e (A).....:	400A	—
	Temperature rise of main circuit terminals ≤ 80 K (K).....:	< 57	P



ВЕРНО
ОПТИМАЛ

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY Type SL2G-3x		P
8.3.4.1	Operational performance test		P
	- utilization category	AC-22B	—
	- rated operational voltage U_e (V).....	690	—
	- rated operational current I_e (A) or power (kW)....	400	—
	Test conditions for electrical operation cycles:		P
	- test voltage (V).....	L1: 702 L2: 699 L3: 696	—
	- test current (A).....	L1: 401 L2: 402 L3: 401	—
	- power factor/time-constant	L1: 0,79 L2: 0,78 L3: 0,79	—
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current).....	With	—
	Second test sequence (with/without current).....	Without	—
	- time interval between first and second test sequence	No time interval	—
	- recovery voltage duration (≥ 50 ms).....	Permanent	P
	- current duration (ms).....	320	—
	- time interval between operations (s).....	60	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles or poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after the operational performance test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P



СПИСОК
ОРИГИНАЛ

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.4.2	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ (V)...	1380	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 U_e) (V).....	759	—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): $\leq 0,5$ mA / pole (mA)	-	N
	Leakage current (other utilization categories): $\leq 2,0$ mA / pole (mA)	< 2	P
8.3.4.4	Temperature-rise verification		P
	- conductor cross-section (mm ²) / (mmxmm).....	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	- test current I_e (A).....	400A	—
	Temperature rise of main circuit terminals ≤ 80 K (K).....	< 57	P



БЭРНО С
ОПШМАНА

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.5	TEST SEQUENCE III: SHORT-CIRCUIT PERFORMANCE CAPABILITY		N
8.3.5.1	Short-time withstand current test		N
	Rated short-time withstand current low (A)	-	N
	test voltage (V).....	L1: - L2: - L3: -	-
	r.m.s. test current (A)	L1: - L2: - L3: -	-
	peak test current (A)	L1: - L2: - L3: -	-
	power factor/time constant.....	L1: - L2: - L3: -	-
	factor <i>n</i>	-	N
	test duration (ms).....	-	N
8.3.5.1.5	Behaviour of the equipment during the test		N
	Test performed without:		-
	- endanger to the operator		N
	- cause damage to adjacent equipment		N
	No permanent arcing		N
	No flash over between poles or poles and frame		N
	No melting of the fuse in the detection circuit		N
8.3.5.1.6	Conditions of the equipment after the test		N
	Immediately after the test equipment must work satisfactorily		N
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N
	- equipment is able to carry its rated current after normal closing operation		N



**ВАЖНО С
ОПРИМАНЕ**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.5.2	Short-circuit making capacity		N
	Rated short-circuit making capacity I_{cm} (A).....:	-	N
	test voltage (1,05 U_e) (V).....:	L1:- L2:- L3:-	-
	r.m.s. test current (A).....:	L1:- L2:- L3:-	-
	peak test current (A).....:	L1:- L2:- L3:-	-
	power factor/time constant.....:	L1:- L2:- L3:-	N
	factor n:	-	N
	current duration (ms).....:	-	N
	Time interval between the cycles (min).....:	-	N
	Number of making cycles.....:	-	N
8.3.5.2.5	Behaviour of the equipment during the test		N
	Test performed without:		-
	- endanger to the operator		N
	- cause damage to adjacent equipment		N
	No permanent arcing		N
	No flash over between poles or poles and frame		N
	No melting of the fuse in the detection circuit		N
8.3.5.2.6	Conditions of the equipment after the test		N
	Immediately after the test equipment must work satisfactorily		N
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N
	- equipment is able to carry its rated current after normal closing operation		N



**ВЪРНА С
ОРИГИНАЛ**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.5.3	Dielectric verification		N
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ (V).....: -		—
	No flashover or breakdown		N
8.3.5.4	Leakage current		N
	test voltage ($1,1 U_e$) (V).....: -		—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): $\leq 0,5$ mA / pole (mA): -		N
	Leakage current (other utilization categories): $\leq 2,0$ mA / pole (mA): -		N
8.3.5.5	Temperature-rise verification		N
	- conductor cross-section (mm^2) / (mmxmm).....: -		—
	- test current I_e (A).....: -		—
	Temperature rise of main circuit terminals ≤ 80 K (K).....: -		N



ВРИПОС
ОПРЕДЕЛЕНА

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT Type SL2G-3x3, tested at 690V/80k		P
	Conditional short-circuit current test		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark.....	Jean Müller	—
	- manufacturer's model or type reference.....	M2gL400/69	—
	- rated voltage (V).....	690	—
	- rated current (A).....	400	—
	- rated breaking capacity (kA).....	80	—
8.3.6.2	Test conditions for conditional short-circuit current test		P
	test voltage (1,05 Ue) (V).....	L1: 729 L2: 732 L3: 733	—
	test current (A).....	L1: 81390 L2: 81500 L3: 81900	—
	rated frequency (Hz).....	50	—
	power factor.....	0,20	P
	time constant (ms).....	-	N
	factor n	2,24	P
a)	Fuse protected short-circuit withstand:		P
	- max. let-through current (A).....	L1: 11000 L2: 33800 L3: 32200	—
	- Joule Integral I^2dt (A ² s).....	L1: 151000 L2: 1080000 L3: 724000	—
b)	Fuse protected short-circuit withstand:		P
	- mean velocity of 15 manually under no-load conditions operations (m/s).....	0,97	—
	- point at which the measurement is made.....	Maximum distance of actuator	—
	- test speed during short-circuit making (m/s).....	1,0	—
	- max. let-through current (A).....	L1: 32100 L2: 11000 L3: 29000	—
	- Joule Integral I^2dt (A ² s).....	L1: 1100000 L2: 830000 L3: 810000	—




ВЕРНО
ОПРЕДЕЛЕНА

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles or poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after the test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ (V)... :	1380	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 U_e) (V)..... :	759 (tested with 800V)	—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): $\leq 0,5$ mA / pole (mA)..... :	-	N
	Leakage current (other utilization categories): $\leq 2,0$ mA / pole (mA)..... :	< 2	P
8.3.6.5	Temperature-rise verification		P
	- conductor cross-section (mm ²) / (mmxmm)..... :	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	- test current I_e (A)..... :	400A	—
	Temperature rise of main circuit terminals ≤ 80 K (K)..... :	61K	P



**ВЯНО С
ОРИГИНАЛ**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT Type SL2G-3x, tested at 690V/80k		P
	Conditional short-circuit current test		P
	Protective device details:		P
	- manufacturer's name, trademark or identification mark.....: Jean Müller		—
	- manufacturer's model or type reference.....: M2gL400/69		—
	- rated voltage (V).....: 690		—
	- rated current (A).....: 400		—
	- rated breaking capacity (kA).....: 100		—
8.3.6.2	Test conditions for conditional short-circuit current test		P
	test voltage (1,05 U _e) (V).....: L1: 727 L2: 730 L3: 730		—
	test current (A).....: L1: 82000 L2: 82200 L3: 83400		—
	rated frequency (Hz).....: 50		—
	power factor.....: 0,20		P
	time constant (ms).....: -		N
	factor <i>n</i>: 2,24		P
a)	Fuse protected short-circuit withstand:		P
	- max. let-through current (A).....: L1: 20200 L2: 42200 L3: 43400		—
	- Joule Integral I ² dt (A ² s).....: L1: 55600 L2: 1000000 L3: 769000		—
b)	Fuse protected short-circuit withstand:		P
	- mean velocity of 15 manually under no-load conditions operations (m/s).....: 0,97		—
	- point at which the measurement is made.....: Maximum distance of actuator		—
	- test speed during short-circuit making (m/s).....: 1,0		—
	- max. let-through current (A).....: L1: - L2: 37000 L3: 37000		—
	- Joule Integral I ² dt (A ² s).....: L1: - L2: 890000 L3: 890000		—



ПРОЦ
ОПРЕДЕЛЕНА

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during the test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles or poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after the test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 8		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ (V).....	1380	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage ($1,1 U_e$) (V).....	759 (tested with 800V)	—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): $\leq 0,5$ mA / pole (mA)	-	N
	Leakage current (other utilization categories): $\leq 2,0$ mA / pole (mA)	< 2	P
8.3.6.5	Temperature-rise verification		P
	- conductor cross-section (mm^2) / (mmxmm).....	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	- test current I_e (A)	400A	—
	Temperature rise of main circuit terminals ≤ 80 K (K)	60K	P



ВАРЛОС
ОРИГИНАЛ

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY Type SL2G-3x3, tested with 400A fuse-links		P
8.3.7.1	Overload test		P
	ambient temperature 10-40 °C	25	—
	test enclosure W x H x D (mm x mm x mm)	-	—
	material of enclosure.....	-	—
	test current 1,6 x I _{th} or 1,6 x I _{th} (A)	640	—
	- cable/busbar cross-section (mm ²)/(mm x mm)	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark.....	Jean Müller	—
	- manufacturer's model or type reference.....	M02gG400/69	—
	- rated voltage (V)	690	—
	- rated current (A).....	400	—
	- power loss (W).....	34	—
	- rated breaking capacity (kA).....	100	—
	- time duration of the overload test (s)	2290	P
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed	Opening and closing operation	P
	Required opening force not greater than the test force of 8.2.5.2 and table 8		P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage: 2*U _e with a minimum of 1000V~ (V)....	1380	—
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage (1,1 U _e) (V).....	759	—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): ≤ 0,5 mA / pole (mA)	-	N
	Leakage current (other utilization categories): ≤ 2,0 mA / pole (mA)	< 2	P
8.3.7.4	Temperature-rise verification		P
	Fuse links aged during the overload test are replaced by new fuse-links		P



ВАЖНО С
ОПРЕДЕЛЕНИЕ

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	- conductor cross-section (mm ²) / (mmxmm).....:	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	- test current I _e (A).....:	400A	—
	Temperature rise of main circuit terminals ≤ 80 K (K).....:	67K	P



**ВАЖНО С
ОРИГИНАЛ**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY Type SL2G-3x		P
8.3.7.1	Overload test		P
	ambient temperature 10-40 °C	25	—
	test enclosure W x H x D (mm x mm x mm)	-	—
	material of enclosure	-	—
	test current 1,6 x I _{th} or 1,6 x I _{th} (A)	640	—
	- cable/busbar cross-section (mm ²)/(mmxmm)	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark	Jean Müller	—
	- manufacturer's model or type reference	M02gG400/69	—
	- rated voltage (V)	690	—
	- rated current (A)	400	—
	- power loss (W)	34	—
	- rated breaking capacity (kA)	100	—
	- time duration of the overload test (s)	2300	P
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed	Opening and closing operation	P
	Required opening force not greater than the test force of 8.2.5.2 and table 8		P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage: 2*U _e with a minimum of 1000V~ (V) ...	1380	—
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage (1,1 U _e) (V)	759	—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): ≤ 0,5 mA / pole (mA)	-	N
	Leakage current (other utilization categories): ≤ 2,0 mA / pole (mA)	< 2	P
8.3.7.4	Temperature-rise verification		P
	Fuse links aged during the overload test are replaced by new fuse-links		P



ВЪПРОС
ОРИГИНАЛ

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	- conductor cross-section (mm ²) / (mmxmm).....:	Supply: copper bar 30x10mm Load: 240mm ² , 2m length	—
	- test current I _e (A).....:	400A	—
	Temperature rise of main circuit terminals ≤ 80 K (K).....:	67K	P



**ВЯРНО С
ОРИГИНАЛ**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.4	ELECTROMAGNETIC COMPATIBILITY TESTS		
8.4.1	Immunity		N
8.4.1.1	Equipment not incorporating electronic circuits: no tests necessary		N
8.4.1.2	Equipment incorporating electronic circuits:		N
	Equipment utilizing circuits in which all components are passive are not required to be tested		N
	All other equipment, requirements according to 7.3.2.2 and limits according table 6 apply		N
	Performed tests.....	-	N
	No unintentional separation or closing of contacts has occurred during these tests.....	-	N
8.4.2	Emission		N
8.4.2.1	Equipment not incorporating electronic circuits: no tests necessary		N
8.4.2.2	Equipment incorporating electronic circuits:		N
	Equipment utilizing circuits in which all components are passive are not required to be tested		N
	All other equipment, requirements according to 7.3.3.2 and limits according table 7 apply		N
	Performed tests.....	-	N
	No unintentional separation or closing of contacts has occurred during these tests.....	-	N



**ВЯНО С
ОРИГИНАЛ**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
Annex A (normative)			N
A	Equipment for direct switching of a single motor		N
A.1	Additional rated duties:		—
A.1.1	Intermittent periodic duty.....: -		N
	Intermittent duty: -		N
A.1.1.1	Classes of intermittent duty: -		N
	- class 1: up to 1 operating cycle per hour		N
	- class 3: up to 3 operating cycles per hour		N
	- class 12: up to 12 operating cycles per hour		N
	- class 30: up to 30 operating cycles per hour		N
	- class 120: up to 120 operating cycles per hour		N
A.1.2	Temporary duty.....: -		N
A.5	Mechanical durability:		N
	Equipment mounted according to manufacturer's Instruction		N
	Preferred number of no-load operating cycles expressed in millions (0,001 – 0,003 – 0,01 – 0,03 – 0,1 – 0,3 - 1).....: -		N
	Number of no-load operating cycles performed ...: -		N
	If no mechanical endurance is stated by the manufacturer, a minimum mechanical endurance according to the class of intermittent duty shall be tested (corresponding to 8000 h of operation).		N
A.6	Electrical durability:		N
	Test according to manufacturer's instruction		N
	Number of operating cycles performed: -		N



**ВЪРНО С
ОРИГИНАЛА**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
A.7	Verification of making and breaking capacities:		N
	- utilization category	-	—
	- rated operational voltage U_e (V)	-	—
	- rated operational current I_e (A) or power (kW)	-	—
	Conditions for make/break operations or make operations:		N
	- test voltage, $U = 1,05 U_e$ (V)	L1: - L2: - L3: -	—
	- test current, $I = \dots \times I_e$ (A)	L1: - L2: - L3: -	—
	- power factor	L1: - L2: - L3: -	—
	Conditions for make/break operations:		N
	- test voltage, $U = 1,05 U_e$ (V)	L1: - L2: - L3: -	—
	- test current, $I = \dots \times I_e$ (A)	L1: - L2: - L3: -	—
	- power factor/ time constant	L1: - L2: - L3: -	—
	Number of make/break or make and break operations	-	N
	- recovery voltage duration (≥ 50 ms)		N
	- current duration (ms)	-	—
	- time interval between operations (s)	-	N
	Characteristic of transient recovery voltage if necessary:		N
	- oscillatory frequency (kHz)	-	—
	- measured oscillatory frequency (kHz)	L1: - L2: - L3: -	N
	- factor γ	L1: - L2: - L3: -	N



IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		N
	Test performed without:		—
	- endanger to the operator		N
	- cause damage to adjacent equipment		N
	No permanent arcing		N
	No flash over between poles or poles and frame		N
	No melting of the fuse in the detection circuit		N
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		N
	Immediately after the test equipment must work satisfactorily		N
	- required opening force not greater than the test force of 8.2.6.2 and table 8		N
	- equipment is able to carry its rated current after normal closing operation		N
8.3.3.4	Dielectric verification		N
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~	-	—
	No flashover or breakdown		N
8.3.3.5	Leakage current		N
	test voltage (1,1 U_e) (V).....	-	—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): $\leq 0,5$ mA / pole (mA)	-	N
	Leakage current (other utilization categories): $\leq 2,0$ mA / pole (mA)	-	N
8.3.3.6	Temperature-rise verification		N
	- conductor cross-section (mm ²) / (mmxmm).....	-	—
	- test current I_e (A)	-	—
	Temperature rise of main circuit terminals ≤ 80 K (K).....	-	N
	Supplementary Information:		N



IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
A.8	Operational performance test:		N
	- utilization category	-	—
	- rated operational voltage U_e (V).....	-	—
	- rated operational current I_e (A) or power (kW)....	-	—
	Test conditions for electrical operation cycles:		N
	- test voltage (V).....	L1: - L2: - L3: -	—
	- test current (A).....	L1: - L2: - L3: -	—
	- power factor/time constant	L1: - L2: - L3: -	—
	Number of cycles with current	-	N
	Number of cycles without current	-	N
	First test sequence (with/without current).....	-	—
	Second test sequence (with/without current).....	-	—
	- time interval between first and second test sequence	-	—
	- recovery voltage duration (≥ 50 ms)		N
	- current duration (ms)	-	—
	- time interval between operations (s).....	-	N
8.3.4.1.5	Behaviour of the equipment during the operational performance test		N
	Test performed without:		—
	- endanger to the operator		N
	- cause damage to adjacent equipment		N
	No permanent arcing		N
	No flash over between poles or poles and frame		N
	No melting of the fuse in the detection circuit		N
8.3.4.1.6	Condition of the equipment after the operational performance test		N
	Immediately after the test equipment must work satisfactorily		N
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N
	- equipment is able to carry its rated current after normal closing operation		N

ВРНО С
ОРИГИНАЛ



IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.4.2	Dielectric verification		N
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~.....: -		—
	No breakdown or flashover		N
8.3.4.3	Leakage current		N
	test voltage (1,1 U_e) (V).....: -		—
	Leakage current (utilization categories AC-20A/B, and DC-20A/B): $\leq 0,5$ mA / pole (mA).....: -		N
	Leakage current (other utilization categories): $\leq 2,0$ mA / pole (mA).....: -		N
8.3.4.4	Temperature-rise verification		N
	- conductor cross-section (mm ²) / (mmxmm).....: -		—
	- test current I_e (A).....: -		—
	Temperature rise of main circuit terminals ≤ 80 K (K).....: -		N
	Supplementary information:		N
A.9	Special tests:		N
	- performed tests.....: -		N



**ВЪРНО С
ОРИГИНАЛА**

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
Annex C (normative)			N
C	Single pole operated three pole switches		N
C.1	Three pole operated switches of fundamentally the same design, already successfully tested are deemed to satisfy the requirements of individually operated three pole devices.		N
C.2	Additional-tests to be performed on single pole operated three pole switches		N
	Test "8.3.3.3 Making and breaking capacities" according to test sequence I with following modifications		N
	L1 and L2 are closed, L3 is subjected to the required make-break operation cycle		N
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle		N
	Test performed in a three phase circuit		N
	Test "8.3.4.1 Operational performance" according to test sequence II with following modifications		N
	L1 and L2 are closed, L3 is subjected to the required make-break operation cycle		N
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle		N
	Test performed in a three phase circuit		N
	Test "8.3.6.2 Fuse protected short circuit test" according to test sequence IV with following modifications		N
	For the making test L1 shall be open and L2 closed, L3 is subjected to the required make operation cycle		N
	Test performed in a three phase circuit		N
C.5	Instructions for use		N
	The product literature includes following statement:		N
	These devices are intended for power distribution systems where switching and/or isolating of an individual phase may be necessary and shall not be used for the switching of the primary circuit of three-phase equipment.		N

ВАРНО С
 ПАТЕНТНА



Table 1:

Temperature rise measurements (with dummy 45 W)			
Sequence F, type SL2G-3x, new			
Temperature rise dT of part:	Phase	Measured dT (K)	Required dT (K)
Cable terminals	L1	50,7	≤ 70
	L2	50,7	
	L3	50,7	
Busbar terminals	L1	50,7	
	L2	50,7	
	L3	50,7	
Actuator	---	6	≤ 25
Parts Intended to be touched but not hand-held:			
Metallic	---	---	≤ 30
Non-metallic	---	25	≤ 40
Parts which need not be touched during normal operation:			
Metallic	---	---	≤ 40
Non-metallic	---	34	≤ 50

ВЪРНО С
ВЪЗВРАЩАНА



Remarks

**ВЯНО С
ОРГИНАЛ**

TRF No. IECEN60947_3B





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web:www.kimtech.bg
e-mail: office@kimtech.bg

Списък на проведените изпитвания на Вертикален предпазител-разединител НН 400 А, с триполюсно управление

1. Изпитване устойчивост на стареене;
2. Краткотрайно изпитване на ток;
3. Изпитване ток на късо съединение;
4. Изпитване претоварване;
5. Изпитване електромагнитна съвместимост;

13.01.2016г.

Подпис и печат



NOTIFICATION OF TEST RESULTS

Product fuse-switch-disconnectors

Tested by request of Jean Müller GmbH, Friedrichstrasse 21,
D-65343 Eltville am Rhein, Germany

Manufactured at (name and place) Jean Müller GmbH, Friedrichstrasse 21,
D-65343 Eltville am Rhein, Germany

Rating and principal characteristics Ui 1000V, Ith 722 A/1000 A

Pre-licence factory inspection carried out by VDE

Trade mark (if any) JEAN MÜLLER

Model/Type Ref. SL 3-3x/1000 and SL 3-3x3/1000

Additional information (if any) _____

A sample of product has been tested and found to be in conformity with the current HD/BN and equivalent national standard, (number and edition) BN 60947-3:1999

as shown in the Test Report (ref.No.) 2001980.54 (36 pages)

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body.


N. V. KBMA

Arnhem

Date: December 6, 2000

Internal ref: HLS/Sco

Signature:


B.T.M. Holtus

N. V. KEMA
Utrechtseweg 310, 6812 AR Arnhem
P.O. Box 9035, 6800 ET Arnhem
The Netherlands
Telephone +31 26 3 56 28 50
Telefax +31 26 3 51 49 22


EXPIRED
CERTIFICATE

TEST REPORT EN 60 947-3

Low-voltage switchgear and controlgear Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

Report

Reference No.: 2001980.54
 Tested by (+ signature): *H.L. Schandstok*
 Approved by (+ signature): *L.J.W. van Megen*
 Date of issue: 2000-11-30
 Contents: 36 pages



This report is based on a blank test report that was prepared by KEMA using information obtained from the TRF originator (see below).

Testing laboratory

Name: KEMA Registered Quality B.V.
 Address: Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
 Testing location: as above *and*
: *Holec Laagspanning B.V., Hengelo, The Netherlands*
All tests were observed by compiler

Client

Name: *Jean Müller GmbH*
 Address: *Friedrichstrasse 21*
: *D-65343 ELTVILLE am Rhein, Germany*

Test specification

Standard: EN 60 947-3:99
 Test procedure: CCA-scheme
 Procedure deviation: N.A.
 Non-standard test method: N.A.


Test Report Form/blank test report

Test Report Form No.: 60947-3B/98-09
 TRF originator: KEMA
 Master TRF: dated 98-05

Copyright reserved to the bodies participating in the Committee of Certification Bodies (CCB) and/or the bodies participating in the CENELEC Certification Agreement (CCA).

Test item

Description: *fuse-switch-disconnector*
 Trademark: *Jean Müller*
 Model and/or type reference: *SL 3-3x/1000 and SL 3-3x3/1000*
 Manufacturer: *Jean Müller GmbH, Eltville am Rhein, Germany*



BY THE C
 OF THE KEMA

Rating(s): *UI 1000 V, Ith 722 A / 1000 A*

Particulars: test item vs. test requirements

- method of operation: *dependent manual operation*
- switching positions: *2 (on and off)*
- number of poles: *3-poles*
- kind of current: *AC*
- number of phases: *3*
- rated frequency (Hz): *60 Hz*
- number of positions of the main contacts: *2 (on and off)*

Rated and limiting values, main circuit

- rated operational voltage U_e (V): *400 V, 500 V and 690 V*
- rated insulation voltage U_i (V): *1000 V*
- rated impulse withstand voltage U_{imp} (kV): *12 kV*
- conventional free air thermal current I_{th} (A): *fuse: 722 A*
disconnect knife: 1000 A
- conventional enclosed thermal current I_{the} (A): -
- rated operational current I_e (A): *fuse: 722 A*
disconnect knife: 1000 A
- rated uninterrupted current I_u (A): *fuse: 722 A*
disconnect knife: 1000 A
- utilization category: *with disconnect knife:*
AC-21B 630 A 690 V
AC-22B 1000 A 400 V
AC-22B 800 A 500 V

with fuse:
AC-21B 630 A 690 V
AC-22B 722 A 400 V
AC-22B 630 A 500 V


Short-circuit characteristic

- rated short-time withstand current I_{cw} (kA): -
- rated short-time making capacity I_{cm} (kA): -
- rated conditional short-circuit current: *50 kA at 400 V*

Rated and limiting values, auxillary circuits: *N*

- rated operational voltage (V): -
- rated frequency (Hz): -

TRF No.: 60947-3B




60947-3B
 KEMA

- number of circuits	:	
- number and kind of contact elements	:	
Co-ordination of short-circuit protective devices	:	
- kind of protective device	:	<i>fuse-link, M3gTr722 NH3 500 kVA (722 A)</i>
Test case verdicts		
Test case does not apply to the test object	:	N(.A.)
Test item does meet the requirement	:	P(ass)
Test item does not meet the requirement	:	F(ail)
.....	:	

Testing	
Date of receipt of test item	: <i>2000-02-24</i>
Date(s) of performance of test	: <i>2000-03 and 2000-05</i>
.....	:

TRF No.: 60947-3B



originator: KEMA

EXHIBIT C
OPERAATIE

General remarks

This test report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item tested.

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

The making and breaking tests and short-circuit tests were carried out with a metallic screen placed at 165 mm at the top and 150 mm from the side of the fuse-switch-disconnector, with the cable terminals at the top.

The fuse-switch-disconnector type SL 3-3x/1000 were tested as follows:

Test sequence I and II: tests were done on phase L2, the load circuit was connected to phase L2, phases L1 and L3 were connected to the supply.

Test sequence IV: tests were done with a 3-phase supply, in the 'O-test' the load circuit was connected to all phases, in the 'CO-test' the load circuit was connected to L1 and L2.

TRF No.: 60947-3B




7-8-2001 originator: KEMA

KEMA
2001980.54

EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	- rated short-time withstand current and duration		N
	- rated short-circuit making capacity		N
	- rated conditional short-circuit current	50 kA	P

7.1	CONSTRUCTION		
7.1.2	Current-carrying parts and their connection	<i>no contact pressure through insulation material</i>	P
7.1.3	Clearances		
	Rated impulse withstand voltage	(see test sequence I)	P
	Creepage distances		
	Pollution degree	3	—
	Comparative tracking index (VT)	600 V, 450 V, 375 V	—
	Material group	I, II, IIIa	—
	Rated insulation voltage Ui (V)	1000 V	—
	Minimum creepage distances (mm)	16 mm	—
	Measured creepage distances (mm)	> 16 mm	P
	In case Uimp is not indicated		N
7.1.4	Actuator		
7.1.4.1	Insulation		
7.1.4.2	Direction of movement	(IEC 447)	P
7.1.5	Indication of contact position		
7.1.5.1.	Indicating means	<i>by actuator</i>	P
7.1.5.2	Indication by the actuator	<i>all main contacts are visible in the open position</i>	P
7.1.6	Additional safety requirements for equipment suitable for isolation		
7.1.6.1	Additional constructional requirements for equipment suitable for isolation (Ue > 50 V):		
	- marking according to 5.2b		P
	- indication of the position of the contacts	<i>all main contacts are visible in the open position</i>	P
	- construction of the actuating mechanism		P
	- minimum clearances across open contacts (see Table XIII, Part 1) (mm)	14 mm	
	- measured clearances (mm)	> 14 mm	P
	- test Uimp across gap (kV)	18,5 kV	P

TRF No.: 60947-3B




TRF originator: KEMA

 2001980.54
 01/11/2001

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
7.1.6.2	Supplementary requirements for equipment with provision for electrical interlocking with contactors or circuit-breakers:		N
	auxiliary switch shall be rated according to IEC 60 947-5-1		
	minimum time interval between opening of the contacts of the auxiliary contact and the contacts of the main poles (ms)		-
	measured time interval (ms)		-
	During the closing operation the contacts of the auxiliary switch shall close after or simultaneously with the contacts of the main poles		
7.1.6.3	Supplementary requirements for equipment provided with means for padlocking the open position:		N
	the locking means shall be designed in such a way that it cannot be removed with the appropriate padlock(s) installed		
	test force F applied to the actuator in an attempt to operate to the closed position (N)		-
	rated impulse withstand voltage (kV)		-
	test Uimp on open main contacts at the test force		
7.1.7	Terminals		
7.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals		P
	Mechanical strength of terminals		
	maximum cross-sectional area of conductor (mm ²)	(cable lugs or busbars)	
	diameter of thread (mm)	M12	
	torque (Nm)	40 Nm x 110% = 44 Nm	

TRF No.: 60947-3B



TRF originator: KEMA

 2001980.54
 01/11/2001

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	5 times on 2 separate clamping units		P
	Testing for damage to and accidental loosening of conductor (flexion test)		N
	conductor of the smallest cross-sectional area (mm ²)		-
	number of conductor of the smallest cross section		-
	diameter of bushing hole (mm)		-
	height between the equipment and the platen		-
	mass at the conductor(s) (kg)		-
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	Pull-out test		N
	force (N)		-
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	conductor of the largest cross-sectional area (mm ²)		-
	number of conductor of the largest cross section		-
	diameter of bushing hole (mm)		-
	height between the equipment and the platen		-
	mass at the conductor(s) (kg)		-
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	Pull-out test		N
	force (N)		-
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	conductor of the largest and smallest cross-sectional area (mm ²)		-
	number of conductor of the smallest cross section, number of conductor of the largest cross section		-
	diameter of bushing hole (mm)		-
	height between the equipment and the platen		-
	mass at the conductor(s) (kg)		-

TRF No.: 60947-3B



KEMA
KEMA

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	Pull-out test		N
	force (N)		-
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		N
7.1.7.2	Connection capacity		
	type of conductors: <i>(cable lugs or busbars)</i>		-
	minimum cross-sectional area of conductor (mm ²)		-
	maximum cross-sectional area of conductor (mm ²)		-
	number of conductors simultaneously connectable to the terminal		-
7.1.7.3	Connection		
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
7.1.7.4	Terminal identification and marking		
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals	L1, L2, L3	P
7.1.8	Additional requirements for equipment provided with a neutral pole		N
	Marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
7.1.9	Provisions for protective earthing		N
7.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
7.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N


TRF No.: 60947-3B



KEMA
 CERTIFICATE
 NO. 2001980.54

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N
7.1.9.3	Protective earth terminal marking and identification		N
7.1.10	Enclosure for equipment		N
7.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
	If the enclosure is used for mounting push-buttons, it shall not be possible to remove the buttons from the outside of the enclosure		N
7.1.10.2	Insulation		N
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
7.1.11	Degree of protection of enclosed equipment		N

TRF No.: 60947-3B


 2001980.54
 KEMA

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Degree of protection	IP	<i>N</i>

8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS		
8.3.3.1	Temperature-rise		
	ambient temperature 10-40 °C	23 °C	-
	test enclosure W x H x D (mm x mm x mm)	-	-
	material of enclosure	-	-
	Main circuits, test conditions:		
	- conventional thermal current I _{th} (A)	722 A with fuse-links 1000 A with disconnect knives	-
	- conventional enclosed thermal current I _{the} (A) :		-
	- cable/busbar cross-section (mm ²) / (mm)	fuse-links: 50 x 10 mm busbar and 2 x 240 mm ² cable disconnect knives: 60 x 10 mm horizontal busbar and 2 x 60 x 5 mm outgoing terminals	-
	Fuse-link details (fuse-combination units only):		
	- manufacturer's name, trademark or identification mark	Jean Müller	
	- manufacturer's model or type reference	M3gTr722 NH3	
	- rated current (A)	500 kVA (722 A)	
	- power loss (W)	51 W	
	- rated breaking capacity (kA)	100 kA	
	Temperature-rise	(see appended table)	<i>P</i>
	Auxiliary circuits: temperature rise of connecting terminals (K)		<i>N</i>
	idem, requirement (K)	≤	
	rated operation current (A)		
	cross-section (mm ²)		
8.3.3.2	Test of dielectric properties, impulse withstand voltage (U _{imp} indicated):		
	- rated impulse withstand voltage (kV)	12 kV	-
	- test U _{imp} main circuits (kV)	14,8 kV	<i>P</i>

TRF No.: 60947-3B



KEMA
 KONINKLIJK NEDERLANDS INSTITUUT VOOR DE TECHNISCHE WETENSCHAPPEN

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	- test Uimp auxiliary circuits (kV)		N
	- test Uimp on open main contacts (equipment suitable for isolating) (kV)	18,5 kV	P
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		N
	- rated insulation voltage (V)		-
	- main circuits, test voltage for 1 min (V)		
	- control and auxiliary circuits, test voltage for 1 min (V)		

8.3.3.3	Making and breaking capacity	<i>fuse-switch-disconnector type</i> <i>SL 3-3x3/1000</i>	
	utilization category	AC-22B	-
	rated operational voltage Ue (V)	400 V	-
	rated operational current Ie (A) or power (kW) ..	1000 A	-
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: 421 V L2: 421 V L3: 420 V	-
	- test current I/Ie = (A)	L1: 3800 A L2: 3830 A L3: 3860 A	
	- power factor/time constant	L1: 0,64 L2: 0,64 L3: 0,64	
	Conditions, break operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: L2: L3:	
	- test current I/Ie = (A)	L1: L2: L3:	
	- power factor	L1: L2: L3:	
	transient recovery voltage (V)	L1: 421 V L2: 421 V L3: 420 V	
	current duration (ms)	440 ms	
	time interval between operations	180 s	


TRF No.: 60947-3B



TRF Originator: KEMA

 ORIGINAL
 OF THE
 KEMA

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Number of make/break or make and break operations	5 x make/break	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		
	oscillatory frequency (kHz)	86,3 kHz	-
	Measured oscillatory frequency (kHz)	L1: 87,1 kHz L2: 87,1 kHz L3: 87,1 kHz	P
	Factor y	L1: 1,11 L2: 1,11 L3: 1,11	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No flashover or breakdown		P
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	$< 5 \mu A$	P
	test voltage (1,1 Ue) (V)	440 V	-
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 38 K - 60 K disconnect knives: 52 K - 80 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 50 x 10 mm busbar and 2 x 240 mm ² cable disconnect knives: 60 x 10 mm busbar and 4 x 150 mm ² cable	-
	test current Ie (A)	fuse-links: 722 A disconnect knives 1000 A	-
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and Ue > 50 V only)		
	actuator type (fig.)	one-hand operated (a)	-




01010 9
 01010 9
 01010 9

EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	actuating force for opening (N)	215 N	-
	test force with blocked main contacts (N)	400 N	-
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P

8.3.3.3	Making and breaking capacity	<i>fuse-switch-disconnector type</i> SL 3-3x/1000	
	utilization category	AC-22B	-
	rated operational voltage Ue (V)	400 V	-
	rated operational current Ie (A) or power (kW) ..	1000 A	-
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: L2: 426 V L3:	-
	- test current I/Ie = (A)	L1: L2: 3768 A L3:	-
	- power factor/time constant	L1: L2: 0,64 L3:	-
	Conditions, break operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: L2: L3:	-
	- test current I/Ie = (A)	L1: L2: L3:	-
	- power factor	L1: L2: L3:	-
	transient recovery voltage (V)	L1: L2: 426 V L3:	-
	current duration (ms)	600 ms	-
	time interval between operations	180 s	-
	Number of make/break or make and break operations	5 x make/break	P

TRF No.: 60947-3B




TRF originator: KEM

EXPLO C
 OPERATIONAL

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		
	oscillatory frequency (kHz)	85,9 kHz	-
	Measured oscillatory frequency (kHz)	L1: L2: 89,6 kHz L3:	P
	Factor Y	L1: L2: 1,11 L3:	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No flashover or breakdown		P
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,6$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	4,0 μ A - 8,3 μ A	P
	test voltage (1,1 Ue) (V)	440 V, tested with 800 V	-
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	<i>fuse-links: 49 K - 72 K</i> <i>disconnect knives: 51 K - 74 K</i>	P
	conductor cross-sectional area (mm ²)	<i>fuse-links: 50 x 10 mm busbar and 2 x 240 mm² cable</i> <i>disconnect knives: 60 x 10 mm horizontal busbar and 2 x 60 x 5 mm outgoing terminals</i>	
	test current Ie (A)	<i>fuse-links: 722 A</i> <i>disconnect knives 1000 A</i>	
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and Ue > 50 V only)		
	actuator type (fig.)	one-hand operated (e)	
	actuating force for opening (N)	181 N	

TRF No.: 60947-3B



KEMA

2001980.64

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	test force with blocked main contacts (N)	400 N	-
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P

8.3.3.3	Making and breaking capacity	<i>fuse-switch-disconnector type</i> SL 3-3x3/1000	
	utilization category	AC-21B	-
	rated operational voltage Ue (V)	690 V	-
	rated operational current Ie (A) or power (kW) ..	630 A	-
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: 747 V L2: 747 V L3: 747 V	-
	- test current I/Ie = (A)	L1: 974 A L2: 986 A L3: 985 A	-
	- power factor/time constant	L1: 0,95 L2: 0,95 L3: 0,95	-
	Conditions, break operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: L2: L3:	-
	- test current I/Ie = (A)	L1: L2: L3:	-
	- power factor	L1: L2: L3:	-
	transient recovery voltage (V)	L1: 741 V L2: 747 V L3: 748 V	-
	current duration (ms)	460 ms	-
	time interval between operations	60 s	-
	Number of make/break or make and break operations	5 x make/break	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		

TRF No.: 60947-3B



KEMETRIK
 BERKAS
 02/07/2001


EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	oscillatory frequency (kHz)	kHz	—
	Measured oscillatory frequency (kHz)	L1: L2: L3:	N
	Factor γ	L1: L2: L3:	N
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage (2 U_i) for 1 min (V)	2000 V	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	4,6 μ A – 8,2 μ A	P
	test voltage (1,1 U_e) (V)	759 V, tested with 800 V	—
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 57 K – 74 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 40 x 10 mm busbar and 2 x 185 mm ² cable	—
	test current I_e (A)	fuse-links: 630 A	—
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and $U_e > 50$ V only)		
	actuator type (fig.)	one-hand operated (e)	—
	actuating force for opening (N)	215 N	—
	test force with blocked main contacts (N)	400 N	—
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P



2001980.54
 OPTIMA

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity	<i>fuse-switch-disconnector type</i> <i>SL 3-3x/1000</i>	
	utilization category	AC-21B	-
	rated operational voltage U_e (V)	690 V	-
	rated operational current I_e (A) or power (kW) ..	630 A	-
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		
	- test voltage $U/U_e = 1,05$ (V)	L1: L2: 747 V L3:	-
	- test current $I/I_e =$ (A)	L1: L2: 991 A L3:	-
	- power factor/time constant	L1: L2: 0,94 L3:	-
	Conditions, break operation AC-23A and AC-23B only:		
	- test voltage $U/U_e = 1,05$ (V)	L1: L2: L3:	-
	- test current $I/I_e =$ (A)	L1: L2: L3:	-
	- power factor	L1: L2: L3:	-
	transient recovery voltage (V)	L1: L2: 744 V L3:	-
	current duration (ms)	360 ms	-
	time interval between operations	60 s	-
	Number of make/break or make and break operations	5 x make/break	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		
	oscillatory frequency (kHz)	kHz	-
	Measured oscillatory frequency (kHz)	L1: L2: L3:	N
	Factor γ	L1: L2: L3:	N

TRF No.: 60947-3B


 KEMETRIK
 KEMETRIK

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	4,4 µA – 8,1 µA	P
	test voltage (1,1 Ue) (V)	759 V, tested with 800 V	—
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 58 K – 73 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 40 x 10 mm busbar and 2 x 185 mm ² cable	—
	test current Ie (A)	fuse-links: 630 A	—
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and Ue > 50 V only)		
	actuator type (fig.)	one-hand operated (e)	—
	actuating force for opening (N)	181 N	—
	test force with blocked main contacts (N)	400 N	—
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P
8.3.3.3	Making and breaking capacity	fuse-switch-disconnector type SL 3-3x3/1000	
	utilization category	AC-22B	—
	rated operational voltage Ue (V)	500 V	—
	rated operational current Ie (A) or power (kW) ..	800 A	—
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		

TRF No.: 60947-3B



2001980.54
 06/04/2001

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	- test voltage $U/U_e = 1,05$ (V)	L1: 528 V L2: 532 V L3: 533 V	-
	- test current $I/I_e =$ (A)	L1: 2466 A L2: 2456 A L3: 2410 A	-
	- power factor/time constant	L1: 0,65 L2: 0,65 L3: 0,65	-
Conditions, break operation AC-23A and AC-23B only:			
	- test voltage $U/U_e = 1,05$ (V)	L1: L2: L3:	-
	- test current $I/I_e =$ (A)	L1: L2: L3:	-
	- power factor	L1: L2: L3:	-
	transient recovery voltage (V)	L1: 528 V L2: 532 V L3: 533 V	-
	current duration (ms)	360 ms	-
	time interval between operations	60 s	-
	Number of make/break or make and break operations	5 x make/break	P
Characteristic of transient recovery voltage for AC-22 and AC-23 only			
	oscillatory frequency (kHz)	65,75 kHz	-
	Measured oscillatory frequency (kHz)	L1: 66,7 kHz L2: 67,6 kHz L3: 65,8 kHz	P
	Factor γ	L1: 1,12 L2: 1,11 L3: 1,11	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage ($2 U_i$) for 1 min (V)	2000 V	-
	No flashover or breakdown		P



KEMA
 01/11/2001

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	3,9 μ A - 8,4 μ A	P
	test voltage (1,1 Ue) (V)	550 V, tested with 800 V	-
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 61 K - 78 K disconnect knives: 48 K - 61 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 40 x 10 mm busbar and 2 x 185 mm ² cable disconnect knives: 50 x 10 mm busbar and 2 x 240 mm ² cable	-
	test current Ie (A)	fuse-links: 630 A disconnect knives 800 A	-
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and Ue > 50 V only)		
	actuator type (fig.)	one-hand operated (e)	-
	actuating force for opening (N)	215 N	-
	test force with blocked main contacts (N)	400 N	-
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position Indicator does not show OFF-position after capture of test force at blocked main contacts		P
8.3.3.3	Making and breaking capacity	fuse-switch-disconnector type SL 3-3x/1000	
	utilization category	AC-22B	-
	rated operational voltage Ue (V)	500 V	-
	rated operational current Ie (A) or power (kW) ..	800 A	-
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		


TRF No.: 60947-3B



TRF originator: KEMA

2001980.54
 09/11/2001

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	- test voltage $U/U_e = 1,05$ (V)	L1: L2: 528 V L3:	-
	- test current $I/I_e =$ (A)	L1: L2: 2414 A L3:	-
	- power factor/time constant	L1: L2: 0,66 L3:	-
Conditions, break operation AC-23A and AC-23B only:			
	- test voltage $U/U_e = 1,05$ (V)	L1: L2: L3:	-
	- test current $I/I_e =$ (A)	L1: L2: L3:	-
	- power factor	L1: L2: L3:	-
	transient recovery voltage (V)	L1: L2: 532 V L3:	-
	current duration (ms)	480 ms	-
	time interval between operations	60 s	-
	Number of make/break or make and break operations	5 x make/break	P
Characteristic of transient recovery voltage for AC-22 and AC-23 only			
	oscillatory frequency (kHz)	65,75 kHz	-
	Measured oscillatory frequency (kHz)	L1: L2: 66,7 kHz L3:	P
	Factor γ	L1: L2: 1,12 L3:	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		-
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No flashover or breakdown		P



BUKIT BATU
 07100

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	4,7 μ A - 8,3 μ A	P
	test voltage (1,1 Ue) (V)	550 V, tested with 800 V	-
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 55 K - 73 K disconnect knives: 52 K - 60 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 40 x 10 mm busbar and 2 x 185 mm ² cable disconnect knives: 50 x 10 mm busbar and 2 x 240 mm ² cable	-
	test current Ie (A)	fuse-links: 630 A disconnect knives 800 A	-
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and Ue > 50 V only)		
	actuator type (fig.)	one-hand operated (e)	-
	actuating force for opening (N)	181 N	-
	test force with blocked main contacts (N)	400 N	-
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P

8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY <i>fuse-switch-disconnector type SL3-3x/1000</i>		
8.3.4.1	Operational performance test		
	utilization category	AC-22B	-
	rated operational voltage (V)	400 V	-
	rated operational current (A)	1000 A	-
	Test conditions electrical operation cycles:		



ORIGINAL
REPLOC

EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	test voltage (V)	L1: - L2: 413 V L3: -	-
	test current (A)	L1: - L2: 1003 A L3: -	-
	power factor/time constant	L1: - L2: 0,81 L3: -	-
	Number of cycles with current	100	P
	Number of cycles without current	500	P
	First test sequence (with/without current)	with current	-
	Second test sequence (with/without current)	without current	-
	time interval between first and second test sequence	1 hour	-
8.3.4.2	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No breakdown or flashover		P
8.3.4.3	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		N
	Leakage current (other utilization categories) ≤ 2 mA	5,7 µA – 7,1 µA	P
	test voltage (1,1 Ue) (V)	440 V, tested with 800 V	-
8.3.4.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 59 K – 71 K disconnect knives: 47 K – 57 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 50 x 10 mm busbar and 2 x 240 mm ² cable disconnect knives: 60 x 10 mm horizontal busbar and 2 x 60 x 5 mm outgoing terminals	-
	test current Ie (A)	fuse-links: 722 A disconnect knives: 1000 A	-



2001980.54
 KEMA
 Kwaliteitsinstituut voor de elektriciteits-, gas- en waterleidingtechniek

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY <i>fuse-switch-disconnector type SL3-3x/1000</i>		
8.3.4.1	Operational performance test		
	utilization category	AC-22B	-
	rated operational voltage (V)	500 V	-
	rated operational current (A)	800 A	-
	Test conditions electrical operation cycles:		
	test voltage (V)	L1: - L2: 510 V L3: -	-
	test current (A)	L1: - L2: 814 A L3: -	-
	power factor/time constant	L1: - L2: 0,80 L3: -	-
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current)	with current	-
	Second test sequence (with/without current) ...	without current	-
	time interval between first and second test sequence	1 hour	-
8.3.4.2	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No breakdown or flashover		P
8.3.4.3	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		N
	Leakage current (other utilization categories) ≤ 2 mA	4,8 μA - 7,3 μA	P
	test voltage (1,1 Ue) (V)	550 V, tested with 800 V	-
8.3.4.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	<i>fuse-links: 56 K - 72 K</i> <i>disconnect knives: 45 K - 60 K</i>	P




2001980.54
 KEMA

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	conductor cross-sectional area (mm ²)	<i>fuse-links: 40 x 10 mm busbar and 2 x 185 mm² cable</i> <i>disconnect knives: 50 x 10 mm busbar and 2 x 240 mm² cable</i>	-
	test current I _e (A)	<i>fuse-links: 630 A</i> <i>disconnect knives: 800 A</i>	-

8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY <i>fuse-switch-disconnector type SL3-3x/1000</i>		
8.3.4.1	Operational performance test		
	utilization category	<i>AC-21B</i>	-
	rated operational voltage (V)	<i>690 V</i>	-
	rated operational current (A)	<i>630 A</i>	-
	Test conditions electrical operation cycles:		
	test voltage (V)	L1: - L2: <i>689 V</i> L3: -	-
	test current (A)	L1: - L2: <i>632 A</i> L3: -	-
	power factor/time constant	L1: - L2: <i>0,95</i> L3: -	-
	Number of cycles with current	<i>200</i>	P
	Number of cycles without current	<i>800</i>	P
	First test sequence (with/without current)	<i>with current</i>	-
	Second test sequence (with/without current) ...	<i>without current</i>	-
	time interval between first and second test sequence	<i>1 hour</i>	-
8.3.4.2	Dielectric verification		
	test voltage (2 U _i) for 1 min (V)	<i>2000 V</i>	-
	No breakdown or flashover		P
8.3.4.3	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		N

TRF No.: 60947-3B



KEMA

DEPT. C
 SURVEILLANCE

EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	Leakage current (other utilization categories) ≤ 2 mA	5,6 μ A – 7,8 μ A	P
	test voltage (1,1 Ue) (V)	759 V, tested with 800 V	–
8.3.4.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	<i>fuse-links: 55 K – 76 K</i>	P
	conductor cross-sectional area (mm ²)	<i>fuse-links: 40 x 10 mm busbar and 2 x 185 mm² cable</i>	–
	test current Ie (A)	<i>fuse-links: 630 A</i>	–


8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY <i>fuse-switch-disconnector type SL3-3x3/1000 only without current</i>		
8.3.4.1	Operational performance test		
	utilization category	AC-22B	–
	rated operational voltage (V)	400 V	–
	rated operational current (A)	1000 A	–
	Test conditions electrical operation cycles:		
	test voltage (V)	L1: - L2: - L3: -	–
	test current (A)	L1: - L2: - L3: -	–
	power factor/time constant	L1: - L2: - L3: -	–
	Number of cycles with current		P
	Number of cycles without current	500 + 100	P
	First test sequence (with/without current)	<i>without current</i>	–
	Second test sequence (with/without current) ...		–
	time interval between first and second test sequence		–
8.3.4.2	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	–
	No breakdown or flashover		P
8.3.4.3	Leakage current		



DE WETENSCHAPPELIJKE
OPDRACHTGEVER

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA	4,8 μ A - 7,3 μ A	P
	test voltage (1,1 Ue) (V)	440 V, tested with 800 V	-
8.3.4.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	<i>fuse-links: 51 K - 68 K</i> <i>disconnect knives: 51 K - 74 K</i>	P
	conductor cross-sectional area (mm ²)	<i>fuse-links: 50 x 10 mm busbar and 2 x 240 mm² cable</i> <i>disconnect knives: 60 x 10 mm horizontal busbar and 2 x 60 x 5 mm outgoing terminals</i>	-
	test current Ie (A)	<i>fuse-links: 722 A</i> <i>disconnect knives: 1000 A</i>	-

8.3.5	TEST SEQUENCE III: SHORT-CIRCUIT PERFORMANCE CAPABILITY		N
8.3.5.1	Short-time withstand current test		
	Rated short-time withstand current Icw (A)		
	test voltage (V)	L1: L2: L3:	
	r.m.s. test current (A)	L1: L2: L3:	
	peak test current (A)	L1: L2: L3:	
	power factor/time constant	L1: L2: L3:	
	test duration (s)		
	Equivalent with		
8.3.5.1.5	Behaviour of the equipment during the test		



KEMA
 B.V.
 KEMA GROUP

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	- manufacturer's name, trademark or identification mark	Jean Müller	-
	- manufacturer's model or type reference	M3gTr722 NH3	-
	- rated voltage (V)	400 V	-
	- rated current (A)	500 kVA (722 A)	-
	- rated breaking capacity (kA)	100 kA	-
8.3.6.2	Fuse protected short-circuit withstand		
	test voltage (1,05 Ue) (V)	L1: 420 V L2: 420 V L3: 420 V	-
	test current (kA)	L1: 50,4 kA L2: 51,8 kA L3: 50,0 kA	-
	rated frequency (Hz)	50 Hz	-
	power factor	0,22	-
	Fuse protected short-circuit withstand		
	- max. let-through current (kA)	L1: 40,4 kA L2: 48,8 kA L3: 40,4 kA	-
	- Joule integral I ² dt (A ² s)	L1: 3690 kA ² s L2: 3970 kA ² s L3: 3710 kA ² s	-
	Fuse protected short-circuit making		
	- mean velocity of 15 manually under no-load conditions operations (m/s)	1,77 m/s	-
	- point at which the measurement is made		-
	- test speed during the fuse protected short-circuit making (m/s)	0,65 m/s	-
	- max. let-through current (kA)	L1: 42,7 kA L2: 42,7 kA L3: 5,50 kA	-
	- Joule integral I ² dt (A ² s)	L1: 3390 kA ² s L2: 3240 kA ² s L3: 88,2 kA ² s	-
8.3.6.2.5	Behaviour of the equipment during the test		P
8.3.6.2.6	Conditions of the equipment after the test		P
8.3.6.3	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No flashover or breakdown		P



BRAND C
OPMERKING

EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
8.3.6.4	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		
	Leakage current (other utilization categories) $\leq 2,0$ mA	4,2 μ A – 9,3 μ A	P
	test voltage (1,1 Ue) (V)	440 V, tested with 800 V	–
8.3.6.5	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	50 K – 69 K	P
	cross-sectional area (mm ²)	50 x 10 mm busbar and 2 x 240 mm ² cable	–
	test current Ie (A)	fuse-links: 722 A	–
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT <i>fuse-switch-disconnector type SL 3-3x/1000</i>		
	Protective device details:		
	- manufacturer's name, trademark or identification mark	Jean Müller	–
	- manufacturer's model or type reference	M3gTr722 NH3	–
	- rated voltage (V)	400 V	–
	- rated current (A)	722 A	–
	- rated breaking capacity (kA)	100 kA	–
8.3.6.2	Fuse protected short-circuit withstand		
	test voltage (1,05 Ue) (V)	L1: 420 V L2: 420 V L3: 420 V	–
	test current (kA)	L1: 50,4 kA L2: 51,8 kA L3: 50,0 kA	–
	rated frequency (Hz)	50 Hz	–
	power factor	0,22	–
	Fuse protected short-circuit withstand		
	- max. let-through current (kA)	L1: 38,1 kA L2: 50,2 kA L3: 38,1 kA	–
	- Joule integral I ² dt (A ² s)	L1: 3840 kA ² s L2: 4160 kA ² s L3: 3300 kA ² s	–



EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Fuse protected short-circuit making		
	- mean velocity of 15 manually under no-load conditions operations (m/s)	1,15 m/s	-
	- point at which the measurement is made		-
	- test speed during the fuse protected short-circuit making (m/s)	0,65 m/s	-
	- max. let-through current (kA)	L1: 39,7 kA L2: 39,7 kA L3:	-
	- Joule integral I ² dt (A ² s)	L1: 2960 kA ² s L2: 2960 kA ² s L3:	-
8.3.6.2.5	Behaviour of the equipment during the test		P
8.3.6.2.6	Conditions of the equipment after the test		P
8.3.6.3	Dielectric verification		
	test voltage (2 U _i) for 1 min (V)	2000 V	-
	No flashover or breakdown		P
8.3.6.4	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		
	Leakage current (other utilization categories) ≤ 2,0 mA	4,0 μA - 8,7 μA	P
	test voltage (1,1 U _e) (V)	440 V, tested with 800 V	
8.3.6.5	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	51 K - 74 K	P
	cross-sectional area (mm ²)	50 x 10 mm busbar and 2 x 240 mm ² cable	
	test current I _e (A)	fuse-links: 722 A	

8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY		
8.3.7.1	Overload test		
	ambient temperature 10-40 °C	23 °C	
	test enclosure W x H x D (mm x mm x mm)	-	
	material of enclosure		
	test current 1,6 I _{the} or 1,6 I _{th} (A)	1155 A	



EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	cable/busbar cross-section (mm ²) / (mm)	<i>busbar 50 x 10 mm</i> <i>cable 2 x 240 mm²</i>	–
	Fuse-link details:		
	- manufacturer's name, trademark or identification mark	<i>Jean Müller</i>	–
	- rated current (A)	<i>500kVA (722 A)</i>	–
	- power loss (W)	<i>51 W</i>	–
	- rated breaking capacity (kA)	<i>100 kA</i>	–
	- time duration of the overload test (s)	<i>1860 s</i>	–
	Within 3 min after the fuse(s) has(have) operated (or 1 h), the equipment shall be operated once, i.e. opened and closed		<i>P</i>
	The equipment shall not have undergo any impairment hindering such operation		<i>P</i>
8.3.7.2	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	<i>2000 V</i>	–
	No flashover or breakdown		<i>P</i>
8.3.7.3	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		
	Leakage current (other utilization categories) ≤ 2 mA)	<i>5,9 μA – 7,4 μA</i>	<i>P</i>
	test voltage (1,1 Ue) (V)	<i>440 V, tested with 800 V</i>	–
8.3.7.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K (K)	<i>53 K – 70 K</i>	<i>P</i>
	cross-sectional area (mm ²)	<i>50 x 10 mm busbar and</i> <i>2 x 240 mm² cable</i>	
	test current Ie (A)	<i>fuse-links: 722 A</i>	



EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	TABLE: temperature rise measurements <i>with fuse-links</i>		
	temperature rise, dT of part:	phase	dT (K)
	<i>terminal to horizontal busbar system (line terminal)</i>	L1	48
		L2	53
		L3	62
	<i>terminal to cable(s) (load terminal)</i>	L1	66
		L2	66
		L3	58
	<i>internal busbar near insulation material</i>	L1	122
	<i>actuator</i>		3
			25

TABLE: temperature rise measurements <i>with contact knives</i>			
temperature rise dT of part:	phase	dT (K)	required dT (K)
<i>terminal to horizontal busbar system (line terminal)</i>	L1	53	70
	L2	49	70
	L3	47	70
<i>terminal to cable(s) (load terminal)</i>	L1	62	70
	L2	64	70
	L3	61	70



ESPINO C
OPINIANO

Remarks


Additional test:

- Parts of insulation material necessary to retain current carrying parts were subjected to a glow-wire test according EN 60947-1, at 960 °C for the other insulation materials 650 °C. These tests withstood the requirements.

description:

Type SL 3-3x/1000 : fuse-switch-disconnector, 3-poles, switching pole after pole

Type SL 3-3x3/1000 : fuse-switch-disconnector, 3-poles, switching 3-poles



TRF original for KEMA
KEMA
SYRIS
EGSE

СПИСЪК

на типовите изпитвания, проведени от независима изпитвателна лаборатория,
за предлаганите вертикални разединители, както следва:

Марка: Jean Muller
Продукт: вертикален предпазител-разединители
Серия: SL3

5.2 Маркировка

7.1 Конструкция

8.3.3 Основни характеристики

8.3.3.1 Повишаване на температурата

8.3.3.2 Диелектрични свойства

8.3.3.3 Работна и гранична изключвателна възможност при късо съединение

8.3.3.4 Проверка на диелектричните свойства

8.3.3.5 Ток на утечка

8.3.3.6 Проверка при повишаване на температурата

8.3.3.7 Експлоатационна възможност на задвижващия механизъм

8.3.4 Работни характеристики

8.3.4.1 Изпитване на експлоатационната възможност

8.3.4.2 Проверка на диелектричните свойства на прекъсвач-разединителя

8.3.4.3 Ток на утечка

8.3.4.4 Проверка при повишаване на температурата

8.3.5 Характеристики при късо съединение

8.3.5.1 Издържан импулсен ток

8.3.5.2 Работна изключвателна възможност при късо съединение

8.3.5.3 Проверка на диелектричните свойства

8.3.5.4 Ток на утечка

8.3.5.5 Проверка при повишаване на температурата

8.3.6 Условен ток на късо съединение

8.3.6.2 Издържан ток на късо съединение със стопяем предпазител

8.3.6.3 Проверка на диелектричните свойства

8.3.6.4 Ток на утечка

8.3.6.5 Проверка при повишаване на температурата

8.3.7 Характеристики при претоварване

8.3.7.1 Изпитване на претоварване

8.3.7.2 Проверка на диелектричните свойства

8.3.7.3 Ток на утечка

8.3.7.4 Проверка при повишаване на температурата

ВЕРНО
СЪСТАВИ



Немска Служба по Акредитация
Предоставено съгласно

с подписано многостранно споразумение на EA, ILAC и IAF за взаимно одобрение

АКРЕДИТАЦИЯ

С настоящото Немска служба за акредитация потвърждава, че лабораторията за изпитване
RWE Eurotest

ул. Унтерще-Вилмс № 52, 44143 Дортмунд

притежава правомощия съгласно ISO/IEC 17025:2005 да провежда изпитвания в областта на
съоръжения и уреди за високо напрежение, компактни разпределителни уредби ниско
напрежение, кабели, кабелна арматура за силнотокowi кабели, пресови и винтови
съединители, изолационни продукти, електромагнитна съвместимост, заземителни
съоръжения

Свидетелството за акредитация важи във връзка с решение от 18.10.2011 с акредитационен № D-PL-15207-01 и е
валидно до 17.10.2016г. Състои се от този лист и приложения общо 6 страници.

Регистрационен номер на свидетелството: D-PL-15207-01-01

Франкфурт на Майн, 18.10.2011

дипл. инж. Ралф Егнер





Deutsche Akkreditierungsstelle GmbH

Bellehene gemäß § 8 Absatz 1 AkkStelleG i.V.m. § 1 Absatz 1 AkkStelleGBV
Unterzeichnerin der Multilateralen Abkommen
von EA, ILAC und IAF zur gegenseitigen Anerkennung

Akkreditierung



Die Deutsche Akkreditierungsstelle GmbH bestätigt hiermit, dass das Prüflaboratorium

RWE Eurotest GmbH
Unterste-Wilms-Str. 52, 44143 Dortmund

die Kompetenz nach DIN EN ISO/IEC 17025:2005 besitzt, Prüfungen in folgenden Bereichen durchzuführen:

Hochspannungsgeräte und -anlagen, Niederspannungs-Schaltgeräte-Kombinationen,
Kabel, Starkstromkabel-Garnituren, Press- und Schraubverbinder,
Isolierstoffe (Isolieröle), EMV, Erdungsanlagen,
sowie von PSA bei Lichtbögenwirkung

Die Akkreditierungsurkunde gilt nur in Verbindung mit dem Bescheid vom 18.10.2011 mit der Akkreditierungsnummer D-PL-15207-01 und ist gültig bis 17.10.2016. Sie besteht aus diesem Deckblatt, der Rückseite des Deckblatts und der folgenden Anlage mit insgesamt 6 Seiten.

Registrierungsnummer der Urkunde: D-PL-15207-01-01

Frankfurt am Main, 18.10.2011

Siehe Hinweise auf der Rückseite

Dipl.-Ing. (FH) Bolf Eger
Leiter Abteilung 2



ВЕРНО
СЕРТИФИКАТ



TRANSLATION AGENCY

Превод от английски език

50 Hristo Smirnenski Blvd.
1164, Sofia, Bulgaria

T +359 2 9804090
F +359 2 9817160
office@greg-bg.com
www.greg-bg.com

Фирмена бланка на Akkreditierung Austria

Националният акредитиращ орган

Akkreditierung Austria

потвърждава акредитацията на

Лаборатория за изпитване

AIT Austrian Institute of Technology GmbH

ул. Донау-Сити 1, A-1220 Виена

Идентификационен номер: 0001

Акредитацията е въз основа на:

ÖVE/ÖNORM EN ISO/IEC 17025:2007

Начална дата на акредитация: 01.12.1993 г.

Информация относно обхвата на акредитацията и Akkreditierung Austria

<http://www.bmvw.gv.at/akkreditierung>

Тази акредитация е предоставена със сертификат, който потвърждава че Органът за оценка за съответствието - включително обектите, посочени в сертификата - отговаря на изискванията на ÖVE/ÖNORM EN ISO/IEC 17025:2007. Това потвърждение за акредитация може да бъде възпроизведено само в пълна форма.

12.08.2014 г.

Дата

(подпис не се чете)

Допл. инж. д-р. Норман Брунер

Ръководител на Акредитация Австрия

Кръгъл фирмен печат

Долуподписаният, Жасмин Кръстев Кръстев, удостоверявам верността на извършения от Агенция ГРЕГ превод от английски език на български език на приложения документ: Удостоверение за акредитация с дата 12.08.2014 г. Преводът се състои от 1 стр.

Подпис:

Жасмин Кръстев Кръстев



ОБЩО С
СЪПЪТОВА



Die Nationale Akkreditierungsstelle / *The National Accreditation Body*

AKKREDITIERUNG AUSTRIA

bestätigt die Akkreditierung der / *confirms the accreditation of*

Prüfstelle / *Testing Laboratory*

AIT Austrian Institute of Technology GmbH

Donau-City-Straße 1, A-1220 Wien

Identifikationsnummer / *ID-number*: **0001**

Akkreditierungsgrundlage / *Accreditation basis*:

ÖVE/ÖNORM EN ISO/IEC 17025:2007

Datum der Erstakkreditierung / *Initial date of accreditation*: **01.12.1993**

Informationen zum Akkreditierungsumfang und zu Akkreditierung Austria /
Information about the accreditation scope and Akkreditierung Austria

<http://www.bmwfw.gv.at/akkreditierung>

Die Akkreditierung wurde mittels Bescheid erteilt und damit bestätigt, dass die Konformitätsbewertungsstelle - einschließlich der im Bescheid genannten Standorte - die Anforderungen der ÖVE/ÖNORM EN ISO/IEC 17025:2007 erfüllt. Diese Bestätigung der Akkreditierung darf nur unverändert weiterverbreitet werden.

The accreditation was granted by a decree which confirms, that the Conformity Assessment Body - including the sites mentioned in the decree - fulfills the requirements of ÖVE/ÖNORM EN ISO/IEC 17025:2007. This confirmation of accreditation may not be reproduced other than in full.

12.08.2014
Datum / *Date*

Dipl.-Ing. Dr. Norman Brunner
Leiter Akkreditierung Austria / *Head Akkreditierung Austria*



БВРС С
ОПНМММ

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

Location where activities are performed under accreditation

Head Office

Meander 1051
6825 MJ
Arnhem
The Netherlands

No.	Material or product	Type of activity	Reference number	Remarks
A. Electrical Safety Tests				
1a	Cables and cords (CABL)	Type test of cables and cords according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	HD 21 HD 22 HD 603 HD 604 HD 605 EN 13501, EN 50143; EN 50214; EN 50267; EN 50525; EN 50288; EN 50399; EN 50618 NEN/EN 50200 NEN/EN/IEC 60228 NEN-EN 50525 NEN/EN 50266 NEN/EN 50362 NEN/EN /IEC 61034 IEC 60092; IEC 60227 *; IEC 60245 *; IEC 60331; IEC 60332; IEC 60502-1; IEC 60502-2; IEC 60754; IEC 60800; IEC 60840; IEC 62067	* see note 3

This annex has been approved by:

Ir. J. C. van der Poel
Chief Executive



DEKRA CERTIFICATION B.V.
 Opleidingstraat 1
 6825 MJ Arnhem

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
1a	Cables and cords (CABL)	Type test of cables and cords according to the tests in the standard, among others:	DEKRA K 42; DEKRA K 102 DEKRA K 145; DEKRA K 146 DEKRA K 151; DEKRA K 152 DEKRA K 156; DEKRA K 157 DEKRA K 158; DEKRA K 160 DEKRA K 161; DEKRA K 162 DEKRA K 163; DEKRA K 164 DEKRA K 165; DEKRA K 167 DEKRA K 168; DEKRA K 169 DEKRA K 170; DEKRA K 171 DEKRA K 175; DEKRA K 176 DEKRA K 177; DEKRA K 178 DEKRA K 179	* see note 3
		- electrical safety tests	BS 6004; BS 6007; BS 4553; BS 5467; BS 6231; BS 6346; BS 6387; BS 6500; BS 6622; BS 6724; BS 6883; BS 7211; BS 7629; BS 7835; BS 7846; BS 7889; BS 8491;	
		- mechanical tests	BS EN 50288-7 BS EN 50525	
		- environmental tests	DIN VDE0815; DIN VDE0250	
		Test methods for non-metallic materials	IEC 60811-201; IEC 60811-202 IEC 60811-203; IEC 60811-401 IEC 60811-402; IEC 60811-403 IEC 60811-404; IEC 60811-405 IEC 60811-406; IEC 60811-408 IEC 60811-409; IEC 60811-411 IEC 60811-412; IEC 60811-501 IEC 60811-502; IEC 60811-503 IEC 60811-504; IEC 60811-505 IEC 60811-506; IEC 60811-507 IEC 60811-508; IEC 60811-509 IEC 60811-510; IEC 60811-511 IEC 60811-605; IEC 60811-606 IEC 60811-607	
		Electrical test methods for low voltage energy cables	NEN-EN 50395	
		Non electrical test methods for low voltage energy cables	NEN-EN 50396	

VERVOLGDE BLAD
 VAN DE TECHNISCHE
 OORSCHRIJVING



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
1b	Conduits	Type test of conduits according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	NEN/EN/IEC 61386 DEKRA K24 EN 50086	
1c	Installation systems Cable trays Cable ladders	Type test of cable trays and cable ladders, according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	KEMA 55 NEN/EN 50085 NEN/IEC/EN 61537 BS EN 61537	
1d	Boxes and enclosures for electrical installations	Type test of boxes and enclosures for electrical installations, according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	NEN/EN/IEC 60670	
2a	Switches for appliances and automatic controls for electrical household appliances (CONT)	Type test of switches according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests.	IEC/EN 60730*, 61095* IEC/EN 60691, 60934, 61058*, 60529 IEC 60265, 62271-1, 62271-100, 62271-101, 62271-102, 62271-105, 62271-110, 62271-200, 62271-201, 62271-202, 62271-203, EN 50152-1 IEEE Std C37.09, C37.081, 37.60, C37.013, C37.34, ANSI C37.41, C37.73, C37.20.2, C37.122 ANSI/IEEE C37.21 ANSI C37.54, C37.55, C37.20.2, C37.72	* see note 3

RECEIVED
03-04-2015



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
3	Household and similar equipment (HOUS)	Type test of household equipment according to the tests in the standard, among others:	IEC/EN 60335* IEC/EN 61770 IEC/EN 62233 EN 50366 IEC/EN 60204 IEC/EN 60730-1/2-8/2-9 IEC/EN 61558-1/2-3/2-6/2-5/2-6/2-16 IEC/EN 62061 EN/ISO 13849-1	* see note 3
		- electrical safety tests		
		- mechanical tests		
		- environmental tests		
		Low power measurements	IEC/EN 62301	
4	Installation accessories and connection devices (INST)	Type test of installation accessories and connection devices according to the tests in the standard, among others:	IEC/EN 60309*, 60320*, 60669*, 60670*, 60799*, 60884*, 60998*, 61058*, 61242*, 61534*, 61984*, 62208*; IEC/EN 60335-2-76, 60974, 61316, 61386, 62094 EN 50075, 50066, 50146, 50250, 50393 NEN 1251, IEC 60884*, 61238, 62080 BS 1363-1, BS 1363-2, BS 1363-3, BS 1363-4 SS 145 BS 546 BS 4573 BS 5733 NEN 1020 NF C61-314 DIN VDE 0620-1 DIN VDE 0620-2-1 CEI 23-50 NBN C 61-112-1 NEK IEC 60884-1 NEK 502 ÖVE/ÖNORM E 8684-1 ÖVE/ÖNORM E 8620-2(-3,-4, -5) SFS 5610 SS 428 08 34 DS 60884-2-D1 SEV 1011 UNE 20315-1-1; UNE 20315-1-2 IEC/EN 61535 EN 50428 required with 60669	* see note 3
		- electrical safety tests		
		- mechanical tests		
		- environmental tests		

VERBODEN TOEGANG
 03-03-2018




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
5	Luminalres (LITE)	Type test of luminalres according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60155*, 60238*, 60400*, 60570*, 60598*, 60838*, 60921*, 60968*, 60969*, 61347*, 62471* IEC/EN 60929, 61184, 62031, 62035, 60923, 60925, 60927, 61047, 62384, 62560, 61195, 62493	* see note 3
6	Measurement, control and laboratory equipment (MEAS)	Type test of measurement-, control- and laboratory equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 61010* IEC/EN 60044 IEC/EN 61243 IEEE Std C57.13	* see note 3
7	Electrical equipment for medical use (MED)	Type test of electrical equipment for medical use according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60601* IEC/EN/ISO 80601 HD 395	* see note 3
8	Miscellaneous equipment (MISC)	Type test of miscellaneous equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60825*	* see note 3



VERBODEN TOEGANG
 03-11-2014

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
9	IT and office equipment (OFF)	Type test of IT and office equipment according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 60950* IEC/EN 62040* IEC/EN 60825 IEC 62368 EN 41003	* see note 3
10	Low voltage, high power switching equipment (POW)	Type test of low voltage, high power switching equipment according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 60439*, 61439, IEC/EN 60947* IEC/EN 60282, 62208 EN 50178, IEC 60470, 60549, 60644, EN 60282-1 IEEE Std C37.41, C37.60 ANSI C37.44 IEC 61921	* see note 3
11	Installation protective equipment (PROT)	Type test of Installation protective equipment according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 60127*, 60269*, 60529*, 60898*, 61008*, 61009*, 61643*, 60755, 62019 IEC 60099, 60137, 60168, 60383, 60507, 60660, 61109, 60815 HD 630, 639, 60269 IEEE Std 62.11 ANSI C29 CAN/CSA C411.1	* see note 3
12	Safety transformers and similar equipment (SAFE)	Type test of safety transformers and similar equipment according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 80044*, IEC/EN 61558* IEC/EN 62040, IEC/EN 60076, IEC/EN 60353 EN 50091, EN 50464-1 HD 538.1 IEEE Std. C57.12.90, C57.21 NEMA 107 CISPR 16	* see note 3

DEKRA CERTIFICATION B.V.
 03-11-2014



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
13	Electric tools (TOOL)	Type test of electric tools according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60745* IEC/EN 61029* IEC/EN 60335* (Gardening) IEC/EN 62233, IEC/EN 60204 EN 50144 EN 50260-2-7 EN 792 EN/ISO 1114 IEC/EN 62081 EN/ISO 13849-1	* see note 3
14	Electronics, entertainment equipment (TRON)	Type test according to the tests as mentioned in the standard, except the following tests which are subcontracted: 60065, cl. 20.1.3 Pre-conditioning of printed circuit boards 60065, cl. 12.1.2 Vibration-sine	IEC / EN 60065* IEC / EN 60491 IEC 62368	* see note 3
15	Products within the scope of the EMC Directive 2004/108/EC (EMC)	Type test according to the tests as mentioned in the standard	CISPR11; CISPR12; CISPR13; CISPR14-*; CISPR15; CISPR16-*-*; CISPR20; CISPR22; CISPR24; CISPR25; IEC60601-*-*; IEC60945; IEC60947-*-*; IEC61000-*-*; IEC61008-1; IEC61009-1; IEC61131-2; IEC61204-3; IEC61326-*; IEC61543; IEC61547; IEC61800-*; IEC62040-2; IEC62052-*; IEC62053-*; IEC62054-*;	* see note 3

B. Electromagnetic Compatibility (EMC): Automotive tests

1	Vehicles, Motorcycles, Motorboats and Spark-ignited engine-driven devices	Radiated emission 30 to 1000 MHz OATS	European Directives 2004/104/EC, 97/24/EC European regulation ECE-R10.04 EN 55012, CISPR 12	
2	Vehicles, Motorcycles, Motorboats and Spark-ignited engine-driven devices	Radiated Immunity up to 30 V/m 20 to 2000 MHz OATS	European Directive 2004/104, 97/24/EC European regulation ECE-R10.04	

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018


Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
3	Electrical/ electronic sub-assembly	Pulse emission for ESA's along supply lines 12V and 24V	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 7637-1 ISO 7637-2	
4		Conducted emission for ESA's (V-method, LISN) 150 kHz to 108 MHz	European Directive 2004/104/EC European regulation ECE-R10.04 CISPR25	
5		Radiated emission for ESA's Anechoic Chamber method 30 to 1000 MHz	European Directive 2004/104/EC European regulation ECE-R10.04 CISPR25	
6		Radiated Immunity for ESA's Anechoic Chamber method and GTEM method 20 to 2000 MHz up to 30V/m	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 11452-1, ISO 11452-2, ISO 11452-3	
7		Electrical/ electronic sub-assembly	Bulk Current Injection for ESA's 20 to 400 MHz up to 100 mA	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 11452-1, ISO 11452-4
8		Pulse immunity for ESA's along supply lines 12V and 24V	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 7637-1 ISO 7637-2	

C. Electromagnetic Compatibility (EMC): EMF tests

1	Electrical and electronic equipment	EMF measurements: 0-400 kHz	EN 62233 EN 62493	
---	--	--------------------------------	----------------------	--

DECLARATION OF ACCREDITATION
L 022



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**


No.	Material or product	Type of activity	Reference number	Remarks
D. Electromagnetic Compatibility (EMC): Emission tests				
1	Electrical and electronic equipment	Conducted emission 9 kHz to 30 MHz	EN 55011, CISPR 11 EN 55013, CISPR 13 EN 55014-1, CISPR 14-1 EN 55015, CISPR 15 EN 55022, CISPR 22	
2		Radiated Emission Electric (EM) Field 30 MHz to 18 GHz	EN 55011, CISPR 11 EN 55014-1, CISPR 14-1 EN 55022, CISPR 22	
3		Disturbance power 30 MHz to 300 MHz	EN 55014-1, CISPR 14-1	
4		Click disturbances 150 kHz to 30 MHz	EN 55011, CISPR 11 EN 55014-1, CISPR 14-1	
5		Radiated Emission Magnetic Field 9 kHz to 30 MHz	EN 55011, CISPR 11 EN 55015, CISPR 15	
6		Harmonic current emissions 0 Hz to 2 kHz up to 16 A per phase	IEC / EN 61000-3-2	
7		Pulse magnetic field immunity up to 1000 A/m	IEC/EN 61000-4-9	
8		Limitation of voltage fluctuations and flicker up to 16 A per phase	IEC / EN 61000-3-3	

E. Electromagnetic Compatibility (EMC): FCC tests (USA legislation)

1	Radio-Frequency Devices Industrial, Scientific and Medical Equipment	Emission 9 kHz to 3 GHz	47 CFR FCC Part 15, Part 18 ANSI C63.4 FCC MP-5	
---	---	----------------------------	---	--

F. Electromagnetic Compatibility (EMC): Immunity test

1	Electric and electronic equipment	Electrostatic discharge immunity up to 30 kV	IEC/EN 61000-4-2	
2		Radiated EM field immunity up to 2,5 GHz up to 30 V/m	IEC/EN 61000-4-3	
3		EFT Burst Immunity up to 4 kV	IEC/EN 61000-4-4	



DEKRA CERTIFICATION B.V.
 01-03-2018

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
4	Electric and electronic equipment	Surge Immunity up to 10 kV	IEC/EN 61000-4-5	
5		Immunity to conducted RF disturbances up to 230 MHz, up to 30 Vrms	IEC/EN 61000-4-6	
6		Power frequency magnetic field Immunity up to 100 A/m	IEC/EN 61000-4-8	
7		Voltage dips and interruptions Single phase equipment up to 16 A	IEC/EN 61000-4-11	
8		Ring wave immunity test	IEC/EN 61000-4-12	


G. Electromagnetic Compatibility (EMC): MISC

1	Railway applications - Electromagnetic compatibility	Electromagnetic compatibility testing according the listed product standards	EN 50121-1 to -5	
2	Road traffic signal systems	Electromagnetic compatibility testing according the listed product standard	EN 50293	

H. Photometric Tests

(all tests are in accordance with the reference method)

1	Headlamps low and high beams and front fog lamps	All tests as mentioned in the ECE Regulations stated under Test method Photometry Colorimetry Heat tests Plastic tests	ECE Regulations Nos. 1, 5, 8, 19, 20, 31, 56, 57, 72, 76, 82, 98, 112, 113 and 123; European Directives 76/761, 76/762 and 97/24	Note 1
2	Signalling lamps	All tests as mentioned in the ECE Regulations stated under Test method Photometry Colorimetry Heat test	ECE Regulations Nos. 6, 7, 23, 38, 50, 77, 87 and 91 and European Directives 76/757, 76/759, 76/758, 77/538, 77/539, 77/540 and 97/24 ECE Regulation 38 (rear fog lamps only)	
3	Devices for the illumination of rear registration plates	All tests as mentioned in the ECE Regulations stated under Test method Luminance	ECE Regulations Nos. 4 and 50 European Directives 76/760 and 97/24	



DEKRA CERTIFICATION B.V.
 DEKRA


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
4	Retro-reflective devices	All tests as mentioned in the ECE Regulations stated under Test method Retro-reflection Colorimetry Water resistance test Corrosion Fuel and oil resistance Heat test UV resistance	ECE Regulations Nos. 3, 27, 69, 70, 88 and 104 European Directive 76/757	Note 2
5	Light Sources	All tests as mentioned in the ECE Regulations stated under Test method Geometry Photometry Colorimetry Optical quality Mechanical tests	ECE Regulations Nos. 37, 99 IEC 60809 IEC 60810 IEC 60983 IEC 60061	
6	Special warning lamps (beacons and flash lights)	All tests as mentioned in the ECE Regulations stated under Test method Photometry Colorimetry Water resistance test	ECE Regulation No. 65	
7	Cornering Lamps	All tests as mentioned in the ECE Regulation stated under Test method Photometry Colorimetry	ECE Regulation No.119	



DEKRA
 0 011110

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
I. Lighting testing: EPA ENERGY STAR Program				
1	Non-directional Fluorescent Luminalres	Specifications for Performance of Self-Ballasted Compact Fluorescent Lamps, Source Run-up Time (ms)	ANSI C78.5:2003	
		Method of Measurement of Fluorescent Lamp Ballasts, Power Factor, Operating Frequency	ANSI C82.2:2002	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electric and Photometric Measurements of Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-9:2009	
		Life Testing of Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-40:2010	
		Life Testing of Compact Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-65:2010	
		Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-66:2011	

DEKRA
 CERTIFICATION B.V.
 01-03-2018



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certificatlon B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
2	Directional Fluorescent Luminaires	Specifications for Performance of Self-Ballasted Compact Fluorescent Lamps, Source Run-up Time (ms)	ANSI C78.5:2003	
		Method of Measurement of Fluorescent Lamp Ballasts, Power Factor, Operating Frequency	ANSI C82.2:2002	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electric and Photometric Measurements of Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-9:2009	
		Life Testing of Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-40:2010	
		Life Testing of Compact Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-65:2010	
		Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-66:2011	
		Photometric Testing of Outdoor Fluorescent Luminaires, Efficacy, Light Output, Zonal Lumen Distribution	IES LM-10:2013	
Approved Method for Photometric Testing of Indoor Fluorescent Luminaires, Efficacy, Light Output, Zonal Lumen Distribution	IES LM-41:2013			
3	Luminaires CSD - Fluorescent Ballasts	Method of Measurement of Fluorescent Lamp Ballasts, Power Factor, Operating Frequency	ANSI C82.2:2002	

RECEIVED
03/14/15



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
4	Luminaire CSD - Fluorescent Lamps	Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electric and Photometric Measurements of Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-9:2009	
		Life Testing of Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-40:2010	
		Life Testing of Compact Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-65:2010	
		Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-66:2011	
5	Non-Directional HID Luminaires	High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		Ballasts for High Intensity Discharge (HID) Lamps - Methods of Measurement, Power Factor, Lamp Current Crest Factor	ANSI C82.6:2005	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Life Testing of High Intensity Discharge (HID) Lamps, Light Source Life, Lumen Maintenance	IES LM-47:2012	
		Electrical and Photometric Measurements of High Intensity Discharge Lamps, Efficacy, Light Output, CCT, CRI	IES LM-51:2013	

RECEIVED
3 02 2015



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
6	Directional HID Luminaires	High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		Ballasts for High Intensity Discharge (HID) Lamps - Methods of Measurement, Power Factor, Lamp Current Crest Factor	ANSI C82.6:2005	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Life Testing of High Intensity Discharge (HID) Lamps, Light Source Life, Lumen Maintenance	IES LM-47:2012	
		Electrical and Photometric Measurements of High Intensity Discharge Lamps, Efficacy, Light Output, CCT, CRI	IES LM-51:2013	
		Photometric Testing of Roadway Luminaires Using Incandescent Filament and High Intensity Discharge (HID) Lamps, Efficacy, Output, Zonal Lumen Distribution	IES LM-31:2013	
		Photometric Testing of Indoor Luminaires Using High Intensity Discharge or Incandescent Filament Lamps, Efficacy, Light Output, Zonal Lumen Distribution	IES LM-46:2004	
7	Luminaires CSD - HID Ballasts	High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		Ballasts for High Intensity Discharge (HID) Lamps - Methods of Measurement, Power Factor, Lamp Current Crest Factor	ANSI C82.6:2005	

WETZELBOND
O OALMBA



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
8	Luminaires CSD - HID Lamps	Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Life Testing of High Intensity Discharge (HID) Lamps, Light Source Life, Lumen Maintenance	IES LM-47:2012	
		Electrical and Photometric Measurements of High Intensity Discharge Lamps, Efficacy, Light Output, CCT, CRI	IES LM-51:2013	
9	Non-directional Solid State Luminaires and Subcomponents	Electrical and Photometric Measurements of Solid-State Lighting Products (section 10 not required for non-directional or subcomponents), Efficacy, Output, Lumen Maintenance, CCT, CRI, Color Maintenance	IES LM-79:2008	
		Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, Power Factor	ANSI C82.77:2002	
		Method of Measuring and Specifying Color Rendering of Light Sources, CRI	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Characterization of LED Light Engines and LED Lamps for Electrical and Photometric Properties as a Function of Temperature, Efficacy, Light Output, Lumen Maintenance, CCT, CRI, Color Maintenance, Light Source Life	IES LM-82:2012	
10	Directional Solid State Luminaires	Electrical and Photometric Measurements of Solid-State Lighting Products (Goniophotometer), Zonal Lumen Distribution, Color Angular Uniformity, Luminaire Photometry	IES LM-79:2008 sections 10 and 12	
		Guide to Spectroradiometric Measurements, Color Angular Uniformity	IES LM-58:2013	

WITTELIJKE
OORDELENING



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
10	Directional Solid State Luminaires	Method of Measuring and Specifying Color Rendering of Light Sources, CRI	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electrical and Photometric Measurements of Solid-State Lighting Products, Efficacy, Light Output, Lumen Maintenance, CCT, CRI, Color Maintenance	IES LM-79:2008	
11	Lumen Maintenance of LED Packages, Arrays, and Modules	Method for Measuring Lumen Maintenance of LED Light Sources, Light Source Life, Lumen Maintenance	IES LM-80:2008	
12	Non-Directional Outdoor Halogen Luminaires	Approved Method for Life Testing of Filament Lamps, Light Source Life Requirements	IES LM-49:2001, IES LM-49:2011	
13	Directional Outdoor Halogen Luminaires	Approved Method for Life Testing of Filament Lamps, Light Source Life Requirements	IES LM-49:2001	
		Photometric Testing of Outdoor Fluorescent Luminaires, Zonal Lumen Distribution	IES LM-10:1996	
		Photometric Testing of Roadway Luminaires Using Incandescent Filament and High Intensity Discharge (HID) Lamps, Zonal Lumen Distribution	IES LM-31:1991	
		Photometric Testing of Indoor Fluorescent Luminaires, Zonal Lumen Distribution	IES LM-41:1998	
		Photometric Testing of Indoor Luminaires Using High Intensity Discharge or Incandescent Filament Lamps, Zonal Lumen Distribution	IES LM-46:2004	
		Electrical and Photometric Measurements of Solid-State Lighting Products, Zonal Lumen Distribution	IES LM-79:2008 Section 10	

DEKRA CERTIFICATION B.V.
 DEKRA CERTIFICATION B.V.



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
14	CFL Directional Lamps	Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Center beam Intensity, Lumen Maintenance, Lifetime, CCT, CRI	IES LM-66:2011	
		Life Testing of Compact Fluorescent Lamps, Lumen Maintenance, Lifetime, Rapid Cycle Stress Test	IES LM-65:2010	
		IEEE Recommended Practice on Characterization of surges In Low Voltage (1000V and Less) AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Fluorescent Lamp Ballasts, Method of Measurement of Power Factor (included supplements)	ANSI C82.2:2002	
		Specifications for the Chromaticity of Fluorescent lamps, CCT	ANSI C78.376-2001	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Tool for Calculating Minimum Center beam Intensity, Minimum Center Beam Intensity – PAR and MR Lamps	Energy Star Online CBCP Tool	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, ET/LOR	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Light Output Ratio	
ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time			

WETZEL
C O O P E R A T I E



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certificatlon B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
14	CFL Directional Lamps	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	
15	CFL Omnidirectional and Decorative Lamps	Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Center beam Intensity, Lumen Maintenance, Lifetime, CCT, CRI	IES LM-66:2011	
		Life Testing of Compact Fluorescent Lamps, Lumen Maintenance, Lifetime, Rapid Cycle Stress Test	IES LM-65:2010	
		IEEE Recommended Practice on Characterization of surges in Low Voltage AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Specifications for the Chromaticity of Fluorescent lamps, CCT	ANSI C78.376-2001	
		Method of Measurement of Fluorescent Lamp Ballasts, Power Factor	ANSI C82.2:2002	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	
ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time			

WITTELIJNEN
30/04/2015



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022


of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
16	LED Directional Lamps	Electrical and Photometric Measurements of Solid-State Lighting Products, Efficacy, Output, Center Beam Intensity, Luminous Intensity Distribution, Lumen Maintenance, Lifetime, CCT, CRI, Color Maintenance, Color Angular Uniformity	IES LM-79:2008	
		Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, Power Factor	ANSI C82.77:2002 Sections 6 and 7	
		IEEE Recommended Practice on Characterization of surges In Low Voltage AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Chromaticity of Solid State Lighting Products, CCT	ANSI C78.377-2011	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Tool for Calculating Minimum Center beam Intensity, Minimum Center Beam Intensity – PAR and MR Lamps	Energy Star Online CBCP Tool	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, ETLOR	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Light Output Ratio	

WETTERLEINING
D. G. H. A. B. O.



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
16	LED Directional Lamps	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	
17	LED Omnidirectional and Decorative Lamps	Electrical and Photometric Measurements of Solid-State Lighting Products, Efficacy, Output, Center Beam Intensity, Luminous Intensity Distribution, Lumen Maintenance, Lifetime, CCT, CRI, Color Maintenance, Color Angular Uniformity	IES LM-79:2008	
		Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, Power Factor	ANSI C82.77:2002 Sections 6 and 7	
		IEEE Recommended Practice on Characterization of surges in Low Voltage AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	



WUTWUWUWU
3 01010


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
I. Additional Standards related to Energy Star				
1	Reflector type lamps	Photometric Testing	IES LM-35:2002	
2	Floodlights Using Incandescent Filament of Discharge Lamps	Electrical and photometric measurements	IES LM-45:2009	
3	Fluorescent Lamps	Electrical measurements	ANSI C78.375:1997 ANSI C78.375:2014	
4	Fluorescent Lamps	Chromaticity of Fluorescent Lamps	ANSI C78.376-2001	
5	Fluorescent Lamps	Chromaticity of Solid State Lighting Products	ANSI C78.377-2011	
6	Mercury Lamps	Measuring Characteristics	ANSI C78.386:1989	
7	Metal-Halide Lamps	Measuring Characteristics	ANSI C78.387:1987	
8	High Pressure Sodium Lamps	Measuring Characteristics	ANSI C78.388:1990	
9	High-Frequency Fluorescent Lamp Ballast	Measurement of a High-Frequency Fluorescent Lamp Ballast	ANSI C82.11-2002	
10	Light sources	The measurement of luminous flux	CIE 84:1989	
11	Luminaires	The Photometry and goniophotometry of luminaires	CIE121:1996	
12	All LED Products	Measurements of LEDs	CIE127:1997 CIE127:2007	
13	All products	Transient protection	ANSI/IEEE C62.41.1 ANSI/IEEE C62.41.2	
14	Decorative Light Strings	Weathering Test	ASTM G154-06 ASTM G154-12a	
15	Decorative Light Strings	ENERGY STAR Test Method for Decorative Light Strings	ENERGY STAR Test Method for Decorative Light Strings	
16	All products	ENERGY STAR Program requirements Product Specification for Lamps Version 1.0: Final Test Methods and Recommended Practices	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Final Test Methods and Recommended Practices	



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

Note 1: Weather-beaten tests of synthetic lenses is subcontracted

Note 2: Salt-nebula test is subcontracted

Note 3: See current list of sub set of standards on the IECEE CBTL website



DEKRA
CERTIFICATION B.V.



TRANSLATION AGENCY

Превод от английски език

50 Hristo Smirnenki Blvd.
1164, Sofia, Bulgaria

T +359 2 9804090
F +359 2 9817160
office@greg-bg.com
www.greg-bg.com

Декларация за съответствие

Ние: **ЕТИ Електроелемент АД**
Ул. Обрезия 5
1411 Излаке
СЛОВЕНИЯ

декларираме на наша отговорност, че стоката(ите)

Модел/Тип

NV лентов тип товарни прекъсвачи разединители със стоплени предназначители SL

за които се отнася тази декларация, са в съответствие с разпоредбите на следната директива(и) на ЕС:

2006/95/ЕС Директива за ниско напрежение
2004/108/ЕС Директива за ЕМС

и отговарят на следния стандарт(и):

EN 60947-3

Комутиционни апарати за ниско напрежение - Част 3: Товарни прекъсвачи, разединители, товарни прекъсвач-разединители и апарати, комбинирани със стопляеми предназначители

Година на СЕ маркировка

2000

Място и дата:

Излаке, 01.11.2008 г.

Подпис на представителя на производителя (*не се четат*)


Стане Верлич, Продуктов мениджър

Печат: Електроелемент АД

Долуподписаният, Жасмин Кръстев Кръстев, удостоверявам верността на извършения от мен превод от английски език на български език на приложения документ: Декларация за съответствие с дата 01.11.2008 г. Преводът се състои от 1 стр.

Подпис:

Жасмин Кръстев Кръстев



ОРИГИНАЛ



DECLARATION OF CONFORMITY

We: **ETI Elektroelement d.d.**
Obrezija 5
1411 Izlake
SLOVENIA

declare under our sole responsibility that the product(s)

Model/Type:

NV-Strip type fuse-switch disconnectors SL...

to which this declaration relates are in conformity with the provisions of the following EC Directive(s)

2006/95/EC **Low Voltage Directive**
2004/108/EC **EMC Directive**

and comply with the following standard(s):

EN 60947-3
Low-voltage switchgear and controlgear -- Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

Year of CE marking:

2000

Place and date:

Izlake, 1.11.2008

Manufacturer representative signature:
Stane Verlič, Product manager


ELEKTROELEMENT d.d.

IZLAKE

16

ETI

**ВЪПРОС
ОРГАНИЗАЦИЯ**



KEMA



CERTIFICATE

KEMA No.: 2075805.02

Issued to:

Applicant:

Jean Müller GmbH
H.J. Müller Straße 7
65343, ELTVILLE, Germany

Manufacturer/Licensee:

Jean Müller GmbH
H.J. Müller Straße 7
65343, ELTVILLE, Germany

Product : fuse-switch disconnectors

Trade names : JEAN MÜLLER

Types/models : SL2G-3x, SL2G-3x3

The product and any acceptable variation thereof is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:


- a type test according to the standard EN 60947-3:1999
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900416

KEMA hereby grants the right to use the KEMA-KEUR certification mark.



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: December 12, 2005


H.M. Versleegen
Certification Manager

© Integral publication of this certificate is allowed

KEMA Quality B.V.
Uitschloeyweg 319, 6827 AR Arnhem, The Netherlands
P.O. Box 5405, 65221 Delft, The Netherlands
Telephone +31 26 2 56 23 00, Telefax +31 26 2 52 5
Website: www.kema.com

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



ВІСНІВ
ОПІКИНА



KABEL

VIVIZOMATIK
ELECTRICAL DISTRIBUTION LTD. SOFIA

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долноподписаният Владимир Лазаров,

Управител на фирма "ВиВ Изоматик" ООД, София, ул.Пирин 40А

В качеството си на търговски представители на JEAN MULLER GMBH


Декларираме, че продуктът:

Марка:	JEAN MULLER
Продукт:	Предпазител-разединител 400А, 630А.
Серия:	SL2-3X3, SL3-3X3

За който се отнася тази декларация, при условие, че е инсталиран, обслужван и използван за приложения, за които е предназначен, е в съответствие със следните стандарти, технически одобрения или други нормативни актове:

IEC/EN 60947-1
IEC/EN 60947-3

София, 14.08.2012


Владимир Лазаров, управител
ВиВ Изоматик ООД



KABEL

WISOLMOT
MANUFACTURING & EXPORTING

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долноподписаният Владимир Лазаров,

Управител на фирма "ВиВ Изоматик" ООД, София, ул.Пирин 40А

В качеството си на търговски представители на JEAN MULLER GMBH

Декларираме, че продуктът:

Марка:	JEAN MULLER
Продукт:	Разединител 1000А
Серия:	SLT3-3S

За който се отнася тази декларация, при условие, че е инсталиран, обслужван и използван за приложения, за които е предназначен, е в съответствие със следните стандарти, технически одобрения или други нормативни актове:

IEC/EN 60947-1
IEC/EN 60947-3

София, 14.08.2012

Владимир Лазаров, управител
ВиВ Изоматик ООД



ВЪВЕДЕНИЕ
ОД 14.08.2012

EG-Konformitätserklärung EC Conformity Declaration

Dok.-Nr. L_98_01
Doc. No.

Hersteller, Anschrift Manufacturer, Address	Jean Müller GmbH Elektrotechnische Fabrik H.J.-Müller-Straße 7, D-65343 Ellville am Rhein
Produktbezeichnung Product designation	NH-Sicherungslastschaltleisten Baureihe SL, für Schalttafelbau und Schalttafelbau inklusive Zubehör. LV HRC Strip type fuse switch disconnectors, series SL and accessories, for panel board building. DIN-Size 00 (160A): SL00-3x3/100/; SL00-3x(3); SL00-3x/400A DIN-Size 1 to 3 (250A/400A/630A): SL123-3x(3) DIN-Size 3: SL3-3x(3)/1000A (NH-Trennleiste) (LV HRC Busbar disconnect strip 1-and 3 pole switchable) DIN-Size 3: SL3-3x2/1.250A or 1.600A DIN-Size 3: SL3-3x(3)/910A DIN-Size 3; SL3-3X6/2.000A DIN-Size 3: SLT3-3SRSL/3x(3)/50 (NH-Stromschienen-Trennleiste) (busbar disconnect strip)

Jahr der Anbringung der CE-Kennzeichnung : 1998
Affixing of the CE marking

Das bezeichnete Produkt stimmt mit den Vorschriften folgender EG-Richtlinie/n überein:
The designated product conforms to the provisions of the following European directives

2006/95/EG

Richtlinie des Rates vom 12. Dezember 2006 zur Angleichung der Rechtsvorschriften der Mitgliedsstaaten be-
treffen elektrische Betriebsmittel zur Verwendung innerhalb bestimmter Spannungsgrenzen.

*Directive of the European Parliament and of the Council of 12. December 2006 on the harmonisation of the laws of Member States relating to
electrical equipment designed for use within certain voltage limits.*

**Die Übereinstimmung des bezeichneten Produktes mit den Vorschriften der oben genannten Richtli-
nie/n wird nachgewiesen durch die Einhaltung folgender Normen:**

The conformity of the designated product with the provisions of the above mentioned Directives is proved by full compliance with the follow-
ing standards

Europäische Normen Harmonized European standards	EN 60947-3
IEC-Standards IEC standards	
Nationale Normen National standards	VDE 0660 Teil 107

Aussteller / Issuer	G / QM
Ort, Datum / Place, Date	Ellville, den 16. Jan. 2008

Rechtsverb. Unterschriften
Legally binding signature




Dr. B. Müller



I.V. A. Göttert

*Diese Erklärung bescheinigt die Übereinstimmung mit den genannten Richtlinien, beinhaltet jedoch keine Zusicherung von Eigenschaften.
Mitgelieferte Sicherheitshinweise sind zu beachten.
This declaration certifies compliance with the indicated directives but implies no warranty of properties. The safety instructions of the ac-
companying product documentation shall be observed.*





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tuco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ


Долуподписаният Иван Вълков Костов, в качеството си на управител на Кимтех България ООД, гр. Бургас, жк. Братя Миладинови, бл. 57, вх. 4А официален дистрибутор на изделията на Tусо Electronics Raychem декларирам, на собствена отговорност, че продуктите:

- 1/ Вертикален предпазител – разединител НН 400А, с триполюсно управление
- 2/ Вертикален предпазител – разединител НН 1000А, с триполюсно управление

отговаря на изискванията на техническата спецификация и на стандарта EN 60947.

13.01.2016г.
гр. Бургас


Подпис и печат



Low Voltage Products

COMPACT NS630b to 1600 A


User manual



a brand of
Schneider
Electric



Merlin Gerin



ВЪПРОС
АНВЕРЖЕНО
ОТВЕТА


User manual for circuit breakers
COMPACT NS630b to 1600 A

Discovering Compact	2
Manually operated Compact with a toggle	4
Components	4
Opening, closing, reset	5
Testing the device	6
Locking the toggle	7
Manually operated Compact with a rotary handle	8
Components	8
Opening, closing, reset	9
Testing the device	10
Locking the rotary handle	11
Remote operated Compact	14
Components	14
Opening, closing, reset	15
Locking the controls	18
Compact chassis	20
Components	20
Matching a device with its chassis	21
Racking	22
Racking	23
Locking in the "disconnected" position	24
Locking the switchboard door	26
Locking the device when the door is open	27
Locking the safety shutters	28
Electrical auxiliaries	30
Electrical diagrams	30
Operation	32
Electrical characteristics of contacts and control auxiliaries	33
Start-up	36
Start-up operations	36
What to do when the circuit breaker trips?	37
Compact operating conditions	38



КИМТЕХ-БАРНАУЛ
КИМТЕХ
СУПРАС
ПОО

Discovering Compact



Rating plate

0250 10A

Comp NS
NS6300-3N
 UI 750 V Uimp 8 kV
 Ue 220/240 V Icu 50 (kA) 50
 (V) 380/400 (kA) 50
 440 ~ 30
 500/525 ~ 40
 660/690 ~ 30
 Ics = 75% Icu
 Icw 25kA / 0.5s cat B
 IEC 60947-2
 AS UNZ GEL R3
 GTE VSC R23A


- Rated current (x 100 A)
- Performance level
- Suitability for Isolation
- Type of device: circuit breaker or switch-disconnector
- UI - rated insulation level
- Uimp - impulse withstand voltage
- Icu - ultimate breaking capacity
- Ue - rated operational voltage
- Ics - rated service breaking capacity
- Icw - rated short-time withstand current
- Standards



КРИОС
 ОТЕПЛАМ

Manually operated
Compact with a toggle


Components



[Handwritten signature]



ВЕРИТЕЛИ
ОПРЕДЕЛЕНИЕ

Opening, closing, reset



Local opening and closing

■ OFF: breaker open, ON: breaker closed.




Remote opening

Use either:
 ■ an MX opening release
 ■ an MN undervoltage release
 ■ a delayed MN undervoltage release.

When connected to the control panel, these releases may be used to remotely open the device.


MX, MN

Delay unit




Resetting the device following a trip

■ the device trips.




■ reset the device, then close it again.




КИМТЕКС
 БУЛГАРИЯ

Manually operated
Compact with a toggle


Testing the device





■ close the device.




■ press the "Press to trip" button.





■ push the toggle down to reset the device, then back up close it again.






Locking the toggle



Locking the toggle in the OFF position using one to three padlocks (shackle diameter 5 to 8 mm)




Locking the toggle in the ON or OFF position using one to three padlocks (shackle diameter 5 to 8 mm)



Manually operated
Compact with a rotary
handle


Components

000224



Opening, closing, reset


ET11454




Local opening and closing

■ OFF: breaker open, ON: breaker closed.

ET11454



ET11454



Remote opening


Use either:

- an MX opening release
- an MN undervoltage release
- a delayed MN undervoltage release.

When connected to the control panel, these releases may be used to remotely open the device.


MX, MN

ET11454



Delay unit


ET11454



Resetting the device following a trip


■ the device trips.

ET11454




■ reset the device, then close it again.

ET11454




*Manually operated
Compact with a rotary
handle*


Testing the device





■ close the device.




■ press the "Press to trip" button.



■ turn the handle to reset the device, then back to close it again.




Locking the rotary handle




Locking the direct or extended rotary handle in all positions using one to three padlocks (shackle diameter 5 to 8 mm)


■ In the standard configuration, the device may be locked in the OFF position.




■ remove the ring as indicated below to enable locking in both the ON and OFF positions.



■ lock the handle.



■ the controls are locked.




Note:
the rotary handle can be equipped for locking by both padlocks and keylocks.



ПРОС
СЪМЪНЛИ


Manually operated
Compact with a rotary
handle

Locking the rotary handle




Locking the direct rotary handle in all positions using a
keylock


lock.



the controls are locked.





unlock.



Two types of keylocks are available

RONIS


PROFALUX




КИМТЕХ
БЪЛГАРИЯ

Door locking when the device is in the ON position, using the extended rotary handle


■ In the standard configuration, the door cannot be opened when the rotary handle is set to the ON position.



■ It is possible, however, to defeat the door lock.




■ The door-lock function may be permanently disabled by removing the lock.




Handwritten text: "KAMTEX-SHIFARIS" and "BYPLA - HOD" written vertically.

Remote operated Compact Components




Front




КВАРТЕХ
ОПТИКА

Opening, closing, reset




Local opening and closing


Device open (OFF),
discharged





Device closed (ON),
discharged



Device open (OFF),
charged




Device closed (ON),
charged



KIMTEX-BELENIS CO. SYRAC. DG.

Remote operated Compact Opening, closing, reset



Remote opening



Use either:

- an MX opening release
- an MN undervoltage release
- a delayed MN undervoltage release
- a motor mechanism.




When connected to the control panel, these releases may be used to remotely open the device.

MX, MN

Delay unit







Motor mechanism




Remotely close

Motor mechanism




KAMTEX-8h ПАРК
EУРТАГ - 800





Manually recharge the device following a trip




the device trips.



reset the device, then recharge it.



Remote operated Compact **Locking the controls** Disabling local or remote closing






Locking the device using one to three padlocks
(shackle diameter 5 to 8 mm)

■ lock.


Open the device.

Pull out the tab.

Install the padlock(s).





■ the controls are locked.



■ unlock.


■ push in the tab.



Note:
Padlocks and keylocks may be used together.




ВЪВЕДЕНА
ВЪВЕДЕНА
ВЪВЕДЕНА




Padlocks and keylocks may be used together.
Locking using padlocks is identical to the system on the previous page.

Locking the device using a keylock and/or one to three padlocks (shackle diameter 5 to 8 mm)


■ keylocking.
Open the device.




Turn the key.




Remove the key.




■ the controls are locked.




■ unlock.
Insert the key.



Turn the key.




Push in the tab.




Two types of keylocks are available

RONIS



PROFALUX




Matching a device with its chassis





To set up a mismatch-prevention combination for the device and the chassis, see the mismatch-prevention installation manual.

The mismatch protection ensures that a device is installed only in a chassis with compatible characteristics.

The possible combinations are listed below.

050404



			
ABC	45	BCD	15
ABD	35	BCE	14
ABE	34	BC	145
AB	345	BDE	13
ACD	25	BD	135
ACE	24	BE	134
AC	245	CDE	12
ADE	23	CD	125
AD	235	CE	124
AE	234	DE	123





For complete information on Compact handling and mounting, see the Installation manual(s).

Before mounting Compact NS, make sure it matches the chassis.

Removing the rails

Press the release tabs and pull the rails out.



To put the rails back in, press the release tabs and push the rails in.



Inserting the device





Open the circuit breaker (In any case, it opens automatically during connection).

Position the circuit breaker on the rails. Check that it rests on all four supports.



If you cannot insert the device in the chassis, check that the mismatch protection on the chassis corresponds to that on the device.

Push the device into the chassis, taking care not to push on the control unit.



Locking in the "disconnected" position

Using one to three padlocks


Combination of locking systems.
It is possible to lock the device on the chassis in the "disconnected" position using:

- one to three padlocks
- one or two keylocks
- a combination of both.

Locking


Use padlocks with a maximum shackle diameter of 5 to 8 millimetres.

Device in "disconnected" position. Pull out the tab.




Insert the shackle (max. diameter 5 to 8 mm) of the padlock(s).

The crank cannot be inserted.




Unlocking


Remove the padlock(s). Release the tab.



The crank can be inserted.



Note:
Padlocks and keylocks may be used together.
If specified when ordering the chassis, this locking function may be adapted to operate in all positions ("connected", "test" and "disconnected"), instead of in "disconnected" position alone.




Using one or two keylocks

Locking



Device in 'disconnected' position.

Turn the key(s).



Remove the key(s).

The crank cannot be inserted.





Unlocking

Insert the key(s).

Turn the key(s).

The crank can be inserted.







Three types of keylocks are available.


RONIS

PROFALUX

CASTELL



The locking device is installed on the left or right-hand side of the chassis.
 ■ when the device is in "connected" or "test" position, the latch is lowered and the door is locked.
 ■ when the device is in "disconnected" position, the latch is raised and the door is unlocked.






Disabling door opening

Close the door.

Turn the crank until the device is in "test" or "connected" position.




The door is locked.




Enabling door opening

Turn the crank until the device is in "disconnected" position.


The door is unlocked.





Locking the device when the door is open



When the door is open, the crank cannot be inserted.




When the door is closed, the crank can be inserted.




Locking the safety shutters

Four locking possibilities inside the chassis using one or two padlocks (maximum shackle diameter 5 to 8 mm) for each shutter


Top and bottom shutters not locked.





Top shutter not locked.
Bottom shutter locked.



Top shutter locked.
Bottom shutter not locked.



Top and bottom shutters locked.







Handwritten signature or initials, possibly 'S', written vertically.

The diagram is shown with circuits de-energised, all devices open, connected and charged and relays in normal position.

Power **Control unit**



Remote operation



Control unit


Com	UC1	UC2	UC3	M6C
E5 E6	Z5 M1	M2 M3	F2+	C3
E3 E4	Z3 Z4	T3 T4	VN	C2
E1 E2	Z1 Z2	T1 T2	F1-	C1

Remote operation


CAF2 / CAF1	SD
D2 / C12	A1 A2
D1 / C11	B4 A1

A	P	Control unit	Remote operation
		Com: E1-E6 communication	SDE: Fault-trip indication contact (supplied as standard)
		UC1: Z1-Z5 zone selective interlocking; Z1 = ZSI = ZSI OUT SOURCE Z2 = ZSI OUT; Z3 = ZSI IN SOURCE Z4 = ZSI IN ST (short time) Z5 = ZSI IN GF (ground fault) M1 = Vigi module Input (Micrologic 7)	SD: Trip-indication contact (supplied as standard)
		UC2: T1, T2, T3, T4 = external neutral; M2, M3 = Vigi module Input (Micrologic 7)	MN: Undervoltage release or MX: Shunt release (standard or communicating)
		UC3: F2+, F1- external 24 V DC power supply VN external voltage connector (must be connected to neutral with circuit breaker 3P)	
		M6C: 6 programmable contacts (must be connected to external relay M6C) ext. 24 V DC power supply required	


A: Digital ammeter
P: A + power meter + programmable protection



Indication contacts



Chassis contacts



Indication contacts

CAF1/CAF2	SDE	SD	CAO2	CAO1	OF3	OF2	OF1
541 634	84	94	644	514	34	24	14
542 532	82	92	522	612	32	22	12
542 531	81	91	521	511	31	21	11

Chassis contacts

CD2	CD1	CE3	CE2	CE1	CT1
824	814	334	324	314	914
822	812	332	322	312	912
821	811	331	321	311	911

Indication contacts

OF3 / OF2 / OF1: ON/OFF indication contacts

Chassis contacts

CD2: Disconnected- CE3: Connected- CT1: Test-position
 CD1 position contacts CE2 position contacts


- Key:**
- Withdrawable device only
 - SDE1, OF1, OF2, OF3, OF4 supplied as standard
 - Interconnected connections (only one wire per connection point)



КИМТЕХ-БЪЛГАРИЯ
 БУРТАС


The ON/OFF indication contacts signal the status of the device main contacts.

Device



The carriage switches indicate the "connected", "test" and "disconnected" positions.

Chassis



КРАЙ
 ЗА
 СЛУЖБАТА

Electrical characteristics of contacts and control auxiliaries

Device indication contacts							
designation	type	standard, minimum current 100 mA 24 V low level, minimum current 2 mA 15 V			24 V low level, minimum current 2 mA 15 V		
OF ON/OFF contact	3 changeover contacts breaking capacity (AC 12 / DC 12 as per 947-5-1)	V AC	240/380	6 A (rms)	V AC	24/48	5 A (rms)
			480	6 A (rms)		240	5 A (rms)
		V DC	690	6 A (rms)	V DC	380	5 A (rms)
			24/48	2.5 A		24/48	5 / 2.5 A
			125	0.5 A		125	0.5 A
			250	0.3 A		250	0.3 A
SD fault indication	1 changeover contact breaking capacity (AC 12 / DC 12 as per 947-5-1)	V AC	240/380	6 A (rms)	V AC	24/48	5 A (rms)
			480	6 A (rms)		240	5 A (rms)
		V DC	690	6 A (rms)	V DC	380	5 A (rms)
			24/48	2.5 A		24/48	5 / 2.5 A
			125	0.5 A		125	0.6 A
			250	0.3 A		250	0.3 A
SDE fault-trip indication for device with motor mechanism	1 changeover contact breaking capacity (AC 12 / DC 12 as per 947-5-1)	V AC	240/380	6 A (rms)	V AC	24/48	5 A (rms)
			480	6 A (rms)		240	5 A (rms)
		V DC	690	6 A (rms)	V DC	380	5 A (rms)
			24/48	2.5 A		24/48	5 / 2.5 A
			125	0.5 A		125	0.5 A
			250	0.3 A		250	0.3 A
CAO early-break switch for device with rotary handle	2 changeover contacts breaking capacity (AC 12 / DC 12 as per 947-5-1)	V AC	240/380	6 A (rms)	V AC	24/48	5 A (rms)
			480	6 A (rms)		240	5 A (rms)
		V DC	690	6 A (rms)	V DC	380	5 A (rms)
			24/48	2.5 A		24/48	5 / 2.5 A
			125	0.5 A		125	0.6 A
			250	0.3 A		250	0.3 A
CAF early-make switch for device with rotary handle	2 changeover contacts breaking capacity (AC 12 / DC 12 as per 947-5-1)	V AC	240/380	6 A (rms)	V AC	24/48	5 A (rms)
			480	6 A (rms)		240	5 A (rms)
		V DC	690	6 A (rms)	V DC	380	5 A (rms)
			24/48	2.5 A		24/48	5 / 2.5 A
			125	0.5 A		125	0.5 A
			250	0.3 A		250	0.3 A

Device control auxiliaries				
designation	power supply	threshold	consumption	response time
MX opening release	V AC: 50/60 Hz: 24/48 - 100/130 - 200/250 - 277 - 380/480 V DC: 12 - 24/30 - 48/60 - 100/130 - 200/250	0.7 to 1.1 Un	pick-up: 200 VA or W (80 ms) hold: 4.5 VA or W	device at Un: 50 ms ± 10
MN undervoltage release	V AC: 50/60 Hz: 24/48 - 100/130 - 200/250 - 380/480 V DC: 24/30 - 48/60 - 100/130 - 200/250	open: 0.35 to 0.7 Un close: 0.85 Un	pick-up: 200 VA or W (80 ms) hold: 4.5 VA or W	device at Un: 40 ms ± 10
Delay unit for undervoltage release	V AC: 50/60 Hz V DC not adjustable: 100/130 - 200/250 V DC adjustable: 48/60 - 100/130 - 200/250 - 380/480	open: 0.35 to 0.7 Un close: 0.85 Un	200 VA	device at Un: not adjustable: 0.25 s adjustable: 0.5 - 0.9 - 1.5 - 3 s

Motor mechanism				
designation	power supply	threshold	consumption and motor overcurrent	recharge time and operating rate
Motor mechanism	V AC: 50/60 Hz: 48/60 - 100/130 - 200/240 - 277 - 400/440 - 480 V DC: 24/30 - 48/60 - 100/125 - 200/250	0.85 to 1.1 Un	consumption: 180 VA or W overcurrent: 2 to 3 In for 0.1 s	3 seconds max. 3 cycles per minute

Connected, test and disconnected position carriage switches							
designation	type	standard, minimum current 100 mA 24 V low level, minimum current 2 mA 15 V					
CE, CT, CD	3 changeover contacts breaking capacity (AC 12 / DC 12 as per 947-5-1)	V AC	240	8 A (rms)	V AC	24/48	5 A (rms)
			380	8 A (rms)		240	5 A (rms)
		V DC	480	8 A (rms)	V DC	380	5 A (rms)
			690	6 A (rms)		24/48	2.5 A
			24/48	2.5 A		125	0.8 A
			250	0.3 A		250	0.3 A



Electrical characteristics of contacts and control auxiliaries

Wiring of control auxiliaries


Under pick-up conditions, the level of consumption is approximately 150 to 200 VA. Consequently, for low supply voltages (12, 24, 48 V), cables must not exceed a maximum length determined by the supply voltage and the cross-section of the cables.

Indicative values for maximum cable lengths (in meters)

		12V		24V		48V	
		2.5 mm ²	1.5 mm ²	2.5 mm ²	1.5 mm ²	2.5 mm ²	1.5 mm ²
MN	100% source voltage	—	—	68	36	280	165
	85% source voltage	—	—	16	10	75	45
MX-XP	100% source voltage	21	12	115	70	650	330
	85% source voltage	10	6	75	44	350	210


Note:

The indicated length is that for each of the two supply wires.



C_i

C



Start-up operations Procedure

These operations must be carried out before using a device for the first time.

A general check of the device takes only a few minutes and avoids any risk of mistakes due to errors or negligence.

A general check must be carried out:

- prior to initial use
- following an extended period during which the device is not used.

A check must be carried out with the entire switchboard de-energised. In switchboards with compartments, only those compartments that may be accessed by the operators must be de-energised.

Electrical tests

Insulation and dielectric-withstand tests must be carried out immediately after delivery of the switchboard. These tests are precisely defined by international standards and must be directed and carried out by a qualified expert.

Prior to running the tests, it is absolutely necessary to:

- disconnect all the electrical auxiliaries of the device (MCH, MX, MN)
- remove the long-time rating plug on the 7.0 A control units.

Removal of the rating plug disconnects the voltage measurement input.

Switchboard inspection

Check that the devices are installed in a clean environment, free of any installation scrap or items (tools, electrical wires, broken parts or shreds, metal objects, etc.).

Conformity with the installation diagram

Check that the devices conform with the installation diagram:

- breaking capacities indicated on the rating plates
- identification of the control unit (type, rating)
- presence of any optional functions (motor mechanism)
- protection settings (long time, short time, instantaneous, ground fault)
- identification of the protected circuit marked on the front of each device.

Condition of connections and auxiliaries

Check device mounting in the switchboard and the tightness of power connections. Check that all auxiliaries and accessories are correctly installed:

- electrical auxiliaries
- terminal blocks
- connections of auxiliary circuits.

Operation

Check the mechanical operation of the devices:

- opening of contacts
- closing of contacts.

Check on the control unit

Check the control unit of each circuit breaker using the respective user manuals.



What to do when the circuit breaker trips?

Note the fault

Faults are signalled locally and remotely by the indicators and auxiliary contacts installed on devices (depending on each configuration). See page 32 in this manual and the user manual of the control unit for information on the fault indications available with your circuit breaker.

Identify the cause of tripping

A circuit must never be reclosed (locally or remotely) before the cause of the fault has been identified and cleared.


Depending on the type of fault and the criticality of the loads, a number of precautionary measures must be taken, in particular the insulation and dielectric tests on a part of or the entire installation. These checks and tests must be directed and carried out by qualified personnel.

Inspect the circuit breaker following a short-circuit


- check the tightness of connections (see the device installation manual)
- check the disconnecting-contact clusters.

Reset the circuit breaker

The circuit breaker can be reset locally or remotely. See pages 5, 9 and 16 in this manual for information on how the device can be reset.




Compact operating conditions



Ambient temperature

Compact devices can operate under the following temperature conditions:

- the electrical and mechanical characteristics are stipulated for an ambient temperature of -5°C to $+70^{\circ}\text{C}$
- circuit-breaker closing is guaranteed down to -35°C
- Compact (without the control unit) can be stored in an ambient temperature of -40°C to $+85^{\circ}\text{C}$
- the control unit can be stored in an ambient temperature of -25°C to $+85^{\circ}\text{C}$.




Extreme atmospheric conditions

Compact devices have successfully passed the tests defined by the following standards for extreme atmospheric conditions:

- IEC 68-2-1: dry cold at -55°C
- IEC 68-2-2: dry heat at $+85^{\circ}\text{C}$
- IEC 68-2-30: damp heat (temperature $+55^{\circ}\text{C}$, relative humidity 95%)
- IEC 68-2-52 level 2: salt mist.

Compact devices can operate in the industrial environments defined by standard IEC 947 (pollution degree up to 3).

It is nonetheless advised to check that the devices are installed in suitably cooled switchboards without excessive dust.




Vibrations


Compact devices resist electromagnetic or mechanical vibrations.

Tests are carried out in compliance with standard IEC 68-2-6 for the levels required by merchant-marine inspection organisations (Veritas, Lloyd's, etc.):

- 2 to 13.2 Hz: amplitude $\pm 1\text{ mm}$
- 13.2 to 100 Hz: constant acceleration 0.7 g.

Excessive vibration may cause tripping, breaks in connections or damage to mechanical parts.





Electromagnetic disturbances

Compact devices are protected against:

- overvoltages caused by devices that generate electromagnetic disturbances
- overvoltages caused by an atmospheric disturbance or by a distribution-system outage (e.g. failure of a lighting system)
- devices emitting radio waves (radios, walkie-talkies, radar, etc.)
- electrostatic discharges produced by users.

Compact devices have successfully passed the electromagnetic-compatibility tests (EMC) defined by the following International standards:

- IEC 947-2, appendix F
- IEC 947-2, appendix B (trip units with earth-leakage function).

The above tests guarantee that:

- no nuisance tripping occurs
- tripping times are respected.


Cleaning


non-metallic parts:

never use solvent, soap or any other cleaning product. Clean with a dry cloth only

metal parts:

clean with a dry cloth whenever possible. If solvent, soap or any other cleaning product must be used, make sure that it does not come into contact with non-metallic parts.





**General Specification for Molded Case
Circuit Breakers from 630 to 1600 A**

Protective device for low voltage electrical installation



**БЪЛГОС
ОРИЕНТА**

Table of contents:

1 General	3
2 Compliance with Standards	3
3 Circuit breaker design.....	4
3.1 Safety.....	4
3.2 Breaking capacity, Current limitation, discrimination, durability.....	4
3.3 Auxiliaries and accessories.....	4
3.3.1 Remote operation.....	5
4 Protections requirements	5
4.1 General	5
4.2 Trip unit protection functions.....	5
4.2.1 Basic protection (LI) with or without energy measurement.....	5
4.2.2 Selective protection (LSI) with or without energy measurement.....	5
4.2.3 Selective protection & Ground fault or Earth leakage protection (LSIG) with or without energy measurement.....	6
4.2.4 Advanced protection trip unit.....	6
4.3 Trip unit measurement function	6
5 Operating & Maintenance	6
5.1 Operating assistance function.....	6
5.2 Maintenance indicators.....	6
5.3 Commissioning and operating tool.....	7
5.4 Alarms (Advanced protection trip units).....	7
6 Communication	7
7 Environment	7



БЪРГО С
ОПРЕДЕЛЕНА

1 General

The present specification applies to molded case circuit breakers (MCCB) from 630A to 1600A for AC (50/60Hz) low voltage electrical installation from 220V to 690V.

- MCCB shall be equipped with a trip unit that offers the appropriate level of protection performance to fit to the application. All trip units could be proposed with versions that provide measurement, and communication functions.
- MCCB shall be available in fixed or withdrawable versions as well as in 3-pole and 4-pole versions. For withdrawable versions, a safety trip shall provide advanced opening to prevent connection and disconnection of a closed circuit breaker
- Fixed and manual MCCBs shall be designed for both vertical, horizontal or flat mounting, without any adverse effect on electrical performance.
- For a MCCB rating frame given, MCCBs dimensions shall be the same whatever the ultimate breaking capacity.
- MCCB shall have a rated operational voltage (U_e) of 690 V, a rated insulation voltage (U_i) of 800V (AC 50/60 Hz) and a rated impulse voltage (U_{imp}) of 8kV.

2 Compliance with Standards

Reference	Title	Scope
EN /IEC 60947-1 & 2	Low-voltage Switchgear and controlgear Part 2 : Circuit Breaker	Characteristics of circuit-breakers; - operation and behaviour in normal service; - operation and behaviour in case of overload and operation and behaviour in case of short-circuit, including co-ordination in service (discrimination and back-up protection); - dielectric properties;
IEC 60947-2, annex B	Circuit Breaker incorporating residual current protection	
IEC 60947-2, annex F	Additional tests for circuit-breakers with electronic over-current protection	Electronic trip unit (rms current measurement, EMC)
IEC 60664-1	Insulation coordination for equipment within low-voltage systems - Part 1: Principles, requirements and tests	Category IV for a rated insulation voltage up to 690 V, class II insulation between the front and internal power circuits
IEC 61000-4-1	Electromagnetic compatibility (EMC) Testing and measurement techniques	EMC Immunity
IEC 61557-12	Combined performance measuring and monitoring devices for electrical parameters	Accuracy class
IEC 60068-2	Environmental testing	Climatic withstand

Versions complying with UL 489 shall also be available.



ВЪПРОС
ОПРАВКА

3 Circuit breaker design

3.1 Safety

For maximum safety,


- The power contacts shall be insulated in an enclosure made of a thermosetting material from other functions such as the operating mechanism, the case, the trip unit and auxiliaries
- The molded case circuit breakers shall provide double insulation of the front face to allow on-site installation of auxiliaries without de-energising the installation. All electrical auxiliaries and accessories such as voltage releases, (shunt or undervoltage type) and auxiliary contacts shall be designed for easy on-site installation.
- The operating mechanism of the molded case circuit breakers shall be of the fast make and fast break type. Tripping on a fault shall be mechanically independent of the operating handle. The operating mechanism shall be designed to operate all poles of the circuit breaker simultaneously for making, breaking and tripping.
- If required, the circuit breaker shall be equipped with a rotary handle.
- The operating mechanism shall be designed in such a way that the position of the operating handle of the circuit breaker indicates the real position of the main contacts, even if the circuit breaker is equipped with a rotary handle.
- In order to ensure suitability for isolation complying with IEC 60947-2 § 7-27: The operating mechanism shall be designed such that the handle can only be in OFF position (O) if the power contacts are all actually separated, in OFF position, the handle shall indicate the isolation position.
- MCCBs shall be able to receive a device for locking in the "isolated" position, with up to 3 padlocks, Ø8 maximum or keylock (for rotary handle).
- MCCBs shall be designed to prevent access to live parts when the cover is removed
- MCCBs shall be equipped with a "push to trip" button in front to test operation and the opening of the poles.
- MCCB rating, "push to trip" button, performances and contact position indication must be clearly visible and accessible from the front, through the front panel or the door of the switchboard.
- In electronic trip units, protection functions shall be electronically managed independently of measurement and communication function by a dedicated ASIC.

3.2 Breaking capacity, Current limitation, discrimination, durability

- The molded case circuit breakers (except for current-limiting circuit breakers) shall belong to category B as defined in IEC60947-1. Certificates attesting to compliance with these rules shall be established taking into account the following performance levels for the test sequences: service breaking capacity (Ics) equal to at least 50% of the rated ultimate breaking capacity (Icu) and a rated short-time withstand current (Icw) of 25 kA / 0.5 s (except for current-limiting circuit breakers)
- If required current limiting circuit breakers shall be available.
- The rated ultimate breaking capacity (Icu) of each molded case circuit breaker shall be equal to at least the value of the short-circuit current (Isc) at the point of installation on the electric circuit, unless the upstream circuit breaker makes it possible to ensure coordination (as defined in Appendix A of IEC 60947-2); in this case, the coordination between the two circuit breakers shall be confirmed by manufacturer.
- MCCB's manufacturer shall provide selectivity and coordination tables with other devices such as other MCCBs, ACB, switches and contactors.

3.3 Auxiliaries and accessories

- The operating mechanism shall be of the stored-energy type only
- The addition of a motor mechanism or a rotary handle shall in no way affect circuit breaker characteristics:
 - o Only three stable tripping mechanism positions (ON, OFF and TRIPPED) shall be possible with the motor mechanism,
 - o Suitability for isolation shall be provided by positive contact indication (ON and OFF) in front of the motor mechanism module
- MCCBs shall be designed to enable safe on-site installation of auxiliaries such as voltage releases (shunt and undervoltage releases) and indication switches as follows:
 - o same field installable auxiliary contacts for signalling different functions, as: open/ closed position, fault signal, electrical fault (including electrical leakage) signal, all auxiliaries shall be common for the entire range,
 - o they shall be separated from power circuits,
 - o all electrical auxiliaries shall be of the snap-in type and fitted with terminal blocks,
 - o Auxiliary function and terminals shall be permanently engraved on the case of the circuit breaker and the auxiliary itself,
- The trip units shall not increase overall circuit breaker dimensions



БЪЛГАРИЯ
ОПШТИНА
СВЕТЛИЦА

3.3.1 Remote operation

- Coils:
 - o Manually operated circuit breaker could be equipped with one shunt opening release or one undervoltage opening release.
 - o Electrically operated circuit breaker could be equipped with one shunt opening release or one undervoltage opening release in addition to opening and closing order.
 - o Coils shall be designed for continuous-duty.
 - o Voltage release auxiliary power supply:
 - AC: 24 48 100/130 200/250 277 380/480 VAC
 - DC 12 24/30 48/60 100/130 200/250 VDC
 - o Opening time with shunt opening release 50ms +/- 10ms
 - o Electrical closing time 60ms +/- 10ms
- Electric motor for spring charge
 - o Motor auxiliary power supply:
 - AC: 24 48 100/130 200/250 277 380/415 VAC
 - DC 12 24/30 48/60 100/130 200/250 VDC
 - o Charging time: ≤ 4 sec
 - o Operating frequency ≤ 3 cycle / min.
- Electrically operated MCCB shall be equipped with anti pumping function: If opening and closing orders occur simultaneously, the circuit breaker shall remain in the open position.

4 Protections requirements

4.1 General

- The high-current molded case circuit breakers shall be available in 3-pole or 4-pole (neutral protection) versions. On 4-pole circuit breakers, a 3-position switch shall be provided to set neutral protection to any of the following levels: unprotected neutral (4P3D), half-protected neutral (4P3D+N/2) or fully protected neutral (4P4D).
- The trip units shall not augment overall circuit breaker dimensions
- Trip unit shall be easily interchangeable and easily secured to the MCCB without removing the breaker from the panel
- All electronic components shall withstand temperatures up to 105 °C.
- Electronic and thermal-magnetic trip units shall be adjustable and it shall be possible to fit lead seals to prevent unauthorised access to the settings
- Protection settings shall apply to all circuit breaker poles
- It shall be possible to adjust protections with a knob without any power supply or when the main is off
- Electronic trip unit shall be fitted with thermal memory
- It shall be possible to equip MCCBs with an auxiliary contact signaling an electrical fault operated by the trip unit.
- The following monitoring functions shall be integral parts of electronic trip units:
 - o 1 LED for load indication lighted above 105 % of Ir
 - o a test connector shall be installed for checks on electronic and tripping mechanism operation using an external device.

4.2 Trip unit protection functions

4.2.1 Basic protection (LI) with or without energy measurement

These trip units shall offer

- Long time protection
 - Adjustable Ir threshold settings from 40% to 100 % of the trip unit rating
 - Adjustable tr time delay
- Instantaneous protection
 - Adjustable Isd threshold settings from 1.5xIr to 10xIr

4.2.2 Selective protection (LSI) with or without energy measurement

These trip units shall offer

- Long time protection
 - Adjustable Ir threshold settings from 40% to 100 % of the trip unit rating
 - Adjustable tr time delay
- Short time protection



ВЪРНО С
ОРИГИНАЛ

- Adjustable Isd threshold settings from 1.5xIr to 10xIr
- Adjustable tsd time delay
- Instantaneous protection
 - Adjustable Ii threshold settings from 2xIn to 15xIn with an OFF position

4.2.3 Selective protection & Ground fault or Earth leakage protection (LSIG) with or without energy measurement

These trip units shall offer

- Long time protection
 - Adjustable Ir threshold settings from 40% to 100 % of the trip unit rating
 - Adjustable tr time delay
- Short time protection
 - Adjustable Isd threshold settings from 1.5xIr to 10xIr
 - Adjustable tsd time delay
- Instantaneous protection
 - Adjustable Ii threshold settings from 2xIn to 15xIn with an OFF position
- Ground fault protection (GF) Or Earth leakage protection (Vigi)
 - Adjustable Ig threshold settings Adjustable I_{tn} threshold settings
 - Adjustable tg time delay Adjustable t_{tn} time delay

4.2.4 Advanced protection trip unit

In addition to the previous protection functions trip units with Under/Over Voltage, Under/Over Frequency and Reverse Power protection could be proposed.

4.3 Trip unit measurement function

If required by the application, the trip unit shall offer measurement (including energy) without additional module whatever the protection type (LL, LSI, LSIG). Available measurements shall be:

- Currents
- Demand Current, Maxim Demand Current
- Voltage, active power, reactive power, power factor,
- Demand Power, Maxim Demand Power
- Energy
- Accuracies of the entire measurement system, including the sensors: shall be
 - Current: 1,5%
 - Voltage: 0.5 %
 - Power and energy: 2%
- Rogowski current transformers shall be used to ensure accurate measurements from low current up to high currents
- For safety reason, protection functions shall be electronically managed independently of measurement function by a dedicated ASIC.
- The measurements shall be displayed on the breaker itself and on a remote system via Modbus communication. In addition to these solutions it shall be possible to connect a remote display.

5 Operating & Maintenance


5.1 Operating assistance function

- Electronic trip units with measurement and communication capability shall offer operating assistance function:
 - o trips history (Fault type, date and time)
 - o Pre-alarm
 - o Trip and pre-alarm could activate relay output(s)
- Theses functions and indicators shall be available on the display, by communication or setting PC tool.

5.2 Maintenance indicators

Electronic trip units with measurement and communication capability shall offer maintenance indicators:

- Operation and trip counters,
- Operating hours counter,
- Load profile
- Theses functions and indicators shall be available by communication or setting PC tool.



ВЪВЕДЕН
ОФИЦИАЛНО

5.3 Commissioning and operating tool

- A test connector shall be installed for checks on electronic and tripping mechanism operation using an external dedicated tool
- A software tool available for all electronic trip unit shall be provided:
 - To visualize and configure trip unit parameters
 - To create and save setting files
 - To display tripping curve
 - To set time and date
 - To display tripping and alarms histories

5.4 Alarms (Advanced protection trip units)

- User shall be able to activate alarms based on measurement (I, U, F, Q, Idemand, Pdemand,)
- Alarms shall be time stamped
- Alarms could activate up to 6 relay output(s)
- These functions and indicators shall be available by display and/or communication and/or setting PC tool.

6 Communication



ACB shall be equipped easily with MODBUS communication.

- Whatever the trip unit is:
the following information shall be accessible:
 - Open / Close position / fault-trip indication (SDE) / Ready to close/ Position in the Chassis (Withdrawable version).
 the following commands shall be possible
 - open / close.
- When trip units with measurement functions are used the following information shall be accessible:
 - instantaneous and demand values, maximeters/minimeters, energy, Current demand and power demand.
 - timestamp trip and alarm histories and event table.
 - Maintenance indicators.


7 Environment

- Production site organisation shall be non polluting and certified to comply with ISO 9002 and ISO 14001 standards.
- MCCBs shall be designed according to Eco-design complying with ISO 14062 Especially MCCB's materials shall be of halogen free type
- MCCB shall be designed for easy disassembly and recycling at end of life, and complies with environmental directives RoHS and WEEE.
- The manufacturer shall provide product environmental profile of the MCCB
- The manufacturer shall provide instructions on the removal, dismantling and processing of circuit-breaker materials at the end of service life.





**ВЪРНО С
ОПРЕДЕЛЕНИЕ**



**ВЪРНО С
ОРИЖИНАЛ**



TRANSLATION AGENCY

Превод от английски език

50 Hristo Smirnenki Blvd.
1164, Sofia, Bulgaria

T +359 2 9804090
F +359 2 9817160
office@greg-bg.com
www.greg-bg.com

Фирмена бланка на ASEFA

Сертификат за съответствие № 147-05BT

Издаден на: ШНАЙДЕР ЕЛЕКТРИК ИНДЪСТРИС САС
бул. „Франклин Рузвелт“ № 89
92500 РУЕЛ МАЛМЕЗОН
ФРАНЦИЯ

за апарата: неподвижен триполосен или четириполосен прекъсвач за ниско напрежение
референция: Compact NS 630b H, 800 H, 1000 H, 1250 H, 1600 H, с електронен
изключвател, (MICROLOGIC 2.0, 5.0, 6.0, 7.0, типове A, P и H)

производител: ШНАЙДЕР ЕЛЕКТРИК СА
търговска марка: МЕРЛИН ГЕРИН

съгласно стандарт(и):
IEC 60947-2 (2003-04) ed. 3, раздел II, ал. 8.3.4 и раздел III, ал. 8.3.5

Номинални характеристики:

Работен ток (I_e) : 630 A до 1600 A
Работно напрежение (U_e) : 220 V променлив ток до 690 V пром. ток
Честота : 50 Hz - 60 Hz
Напрежение по изолацията (U_i) : 800 V

Издържано от изолацията импулсно напрежение (U_{imp}): 8 kV

Експлоатационни и пределни мощности при изключване на прекъсвача:

U_e (V)	I_{cu} (kA)	$I_{cs75\%}$ (kA) за $I_n=630$ a / 1250 A	$I_{cs50\%}$ (kA) за $I_n = 1600$ A
220/240, 380/415	70	52.5	35
440	65	48.75	32.5
500/525	50	37.5	25
660/690	42	31.5	21


Категория на използване : B
Еталонна температура : 40° C
Приспособление за изолация : да
Експлоатация : непрекъсната

Свързан документ(и):
Протокол(и) от изпитване: F01.04.19, F01.04.20

GREG Agency Ltd.
50 "Hristo Smirnenki" Blvd.
1164 Sofia, Bulgaria
T +359 2 9804090, F +359 2 9817160
office@greg-bg.com

www.greg-bg.com

Агенция ГРЕГ ООД
бул. "Христо Смирненски" 50,
1164-София, България
Т +359 2 9804090, Ф +359 2 9817160
office@greg-bg.com



Настоящият сертификат се отнася само за пробата, предоставена за типовото изпитване.


Фонтене-о-Роз,
Дата: 22.12.2005 г.

Председател на ASEFA: подпис (*не се чете*)
М. Бренон

Настоящият сертификат за съответствие се размножава само във вид на пълно копие по факс. Сертификат за съответствие ВТ вариант С.

Долуподписаният, Жасмин Кръстев Кръстев, удостоверявам верността на извършения от мен превод от английски език на български език на приложения документ: Сертификат за съответствие с дата 22.12.2005 г. Преводът се състои от 2 стр.

Подпис: 
Жасмин Кръстев Кръстев





Certificat de conformité / certificate of conformity n° 147-05BT

dé livré à / issued to : SCHNEIDER ELECTRIC INDUSTRIES SAS
89 boulevard Franklin Roosevelt
92500 RUEIL MALMAISON
FRANCE.

pour le matériel / for the apparatus : Disjoncteur basse tension tri-polaire ou tétra-polaire, fixe / Low-voltage fixed three- or four-pole circuit-breaker

référé nce / reference : Compact NS 630b H, 800 H, 1000 H, 1250 H, 1600 H, avec déclencheur électronique / with electronic trip unit, (MICROLOGIC 2.0, 5.0, 6.0, 7.0, types A, P et/and H).

constructeur / manufacturer : SCHNEIDER ELECTRIC SA
marque commerciale / trademark : MERLIN GERIN

selon le(s) référen tiel(s) / according to standard(s) :

GEI/IEC 60947-2 (2003-04) éd.3, séquen ce II, § 8.3.4 et/and séquen ce III, § 8.3.5

caractéristiques assignées / rated characteristics :

Courant d'emploi / Operational current, (Ie) : 630 A *à* up to 1600 A
Tension d'emploi / Operational voltage, (Ue) : 220 Vac *à* up to 690 Vac
Fréquence / Frequency : 50 Hz - 60 Hz
Tension d'isolement / Insulation voltage, (Ui) : 800 V
Tension de tenue aux chocs / Impulse withstand voltage, (Uimp) : 8 kV

Pouvoirs de coupure de service et ultime en court-circuit / Service and ultimate short-circuit breaking capacities.

U _e (V)	I _{cu} (kA)	I _{cs} (kA)	
		pour / for I _n =630 à / 1250 A	pour / for I _n =1600 A
220/240, 380/415	70	52.5	35
440	65	48.75	32.5
500/525	50	37.5	25
660/690	42	31.5	21

Catégorie d'utilisation / Utilization category : B
Température de référence / Reference temperature : 40°C
Appareil apte au sectionnement / Device suitable for isolation : oui / yes
Service / Duty : ininterrompu / uninterrupted

document(s) pris en compte (s) / relevant document(s) :

Rapport (s) d'essai / Test report (s) : F01.04.19, F01.04.20

Ce certificat ne s'applique qu'à l'échantillon soumis à l'essai de type / This certificate applies only to the sample submitted to the type test.

Fontenay-aux-Roses,
Le / on : 2005-12-22

Le Président de l'ASEFA / The chairman of ASEFA,

M. BRENDON

La reproduction de ce certificat de conformité n'est autorisée que sous la forme de fac-similé photographique intégral / This certificate of conformity shall only be reproduced in the form of a complete photographic facsimile.
Certificat de conformité BT version C / Certificate of conformity BT version C

33, av du général Leclerc
92260 Fontenay-aux-roses - France
tél. 01 40 95 63 34
fax 01 40 95 88 18
e-mail : asefa@lcie.fr

Accréditation
n° 5-0037
Portée
communiquée
sur demande

ВАРНО С
ОПРИМАНА

Test platform accredited
Under the Nr F01 by :



File nr : 31042

RECORD OF PROVING TEST n° : F01.04.20

Issued to : SCHNEIDER ELECTRIC INDUSTRIES SAS
89, boulevard Franklin Roosevelt
F-92500 RUEIL-MALMAISON FRANCE

Apparatus tested : Low-voltage circuit-breaker

reference : Compact NS 630b-H, 1600 H
with trip unit MICROLOGIC 5.0A

manufacturer : SCHNEIDER ELECTRIC SA
Trademark : MERLIN GERIN

Purpose of the test : Test at the rated ultimate (Icu) short-circuit breaking capacity according to the IEC 60947-2, ed.3 (04/2003) seq. III, SB 3.5

Rated characteristics :

Operational Voltage	220V to 690V
Rated current	630A to 1600A
Rated ultimate short circuit breaking capacity	220-240V / 70kA 380-415V / 70kA 440V / 65kA 500-525V / 50kA 660-690V / 42kA

Date or period of test : November 18th 2004 to January 14th 2005

This record of proving test comprises : 68 page(s) + 30 appendice(s)

The results obtained during tests entered in this record of proving test justify the rated characteristics assigned by the Manufacturer as stated above.

Date of issue : August 19th 2005


The technical responsible :

Name : E. FERNANDEZ

Signature :

*This document results from tests carried out on a sample. It does not prejudice the compliance of the whole manufactured products with the tested specimen.
This record of proving test shall only be reproduced in the complete form.
COFRAC accreditation is an attestation of the laboratory technical competence within the field of test covered by the accreditation*

Test performed by : VOLTA LABORATORY - SCHNEIDER ELECTRIC
2 rue Volta 38050 GRENOBLE Cedex 09



ВЕРНО С
ОПРАВДАНА

Description and characterization of the test object

Characteristics

Type of circuit-breaker: Compact NS 630bH , 1600 H

Number of poles 4
 Kind of current a.c.
 Number of phases 3
 Rated frequency 50/60 Hz
 Utilization category B
 Reference temperature 40 °C
 Suitability for isolation yes

Rated and limiting values: (according to test volume)


Main circuit:

Rated impulse withstand voltage U_{imp} 8 kV
 Rated insulation voltage U_i 800 V
 Conventional thermal current I_{th} / I_{the} 630A to 1600A
 Rated current I_n 630A to 1600A
 Rated current in the neutral pole 630A to 1600A

Short-circuit characteristics:

U_e/V	I_{cm}/kA	I_{cu}/kA	$I_{cs75\%}/kA$ For $I_n=630$ to $1250A$	$I_{cs50\%}/kA$ For $I_n=1600A$	I_{cw}/kA	I_{IT}/kA
220/240	154	70	52.5	35	19,2	./.
380/415	154	70	52.5	35	19,2	./.
440	143	65	48.75	32,5	19,2	./.
500/525	105	50	37.5	25	19,2	./.
660/690	88.2	42	31.5	21		

Test laboratory: F01- GRENOBLE
 ASEFA recognised PLATFORM



IEC/EN 60947-2
 Ed. 2.1 form 2

Date August 19th 2005

**ВАТНО
 ОПИШНА**

Control circuits:

Electrical control circuits:

Kind of current	a.c. or d.c.
Rated frequency	50/60Hz
Rated control circuit voltage U_c	MN:24 to 480Vac , 24 to 250Vdc MX:24 to 480Vac , 12 to 250Vdc
Rated control supply voltage U_s	./ V
Rated impulse withstand voltage U_{imp}	8 kV
Rated insulation voltage U_i	690 V

Air-supply control circuits:

Rated supply pressure	./ kPa
Limits of pressure	./ kPa
Required volume for each closing operation	./ m ³
Required volume for each opening operation	./ m ³

Auxiliary circuits:

Rated operational voltage U_o	240 to 690Vac and 24 to 250Vdc
Rated impulse withstand voltage U_{imp}	8 kV
Rated insulation voltage U_i	690 V
Rated frequency	50/60 Hz
Rated operational current I_o	according models
Number of circuits	according models
Number and kind of contact elements	OF/SDE/SD/MN/MX/

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM



Date August 19th 2005

**ВЪНШНО
ОПРЕДЕЛЕНИЕ**

Releases:

- Shunt release:

- Rated control circuit voltage U_c MX:24 to 480Vac , 12 to 250Vdc
- Kind of current a.c. or d.c.
- Rated frequency if a.c. 50/60 Hz

- Undervoltage or no-voltage release

- Rated control circuit voltage U_c MN:24 to 480Vac, 24 to 250Vdc
- Kind of current a.c. or d.c.
- Rated frequency if a.c. 50/60 Hz

- Over-current release:

- Short-circuit release

- Instantaneous release yes
- definite time-delay release yes

- Rated current I_n 630 to 1600 A
- Kind of current a.c.
- Rated frequency if a.c. 50/60 Hz
- Current setting (or range of settings) Isd:1.5 to 10xI_n
- Time setting (or range of settings) Ii=2 to 15 I_n
Tsd : 0.1 to 0.4s, on, off

- Overload release (IEC 60947-1; 2.4.30):

- instantaneous release No
- definite time-delay release No
- Inverse time-delay release No
- dependent on ambient air temperature No
- independent of ambient air temperature Yes

- Reference temperature 40°C
- Rated current I_n 630 to 1600A
- Kind of current a.c.
- Rated frequency if a.c. 50/60 Hz
- Current setting (or range of settings) 0.4 to 1 I_n
- Time setting (or range of settings) tr: 0.5 to 24 s



TRF IEC/EN 60947-2
Ed. 2.1 form 4

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

**ВАРНО С
ОПТИМАЛ**

ASEFA

Test report No.: F01.04.20

Page 5 / 68

Type test according to: IEC 60947-2
Test sequence III

Type: NS 630bH to 1600H

TEST SEQUENCE III


Rated ultimate short-circuit breaking capacity

Test sequence III comprises the following tests:

		Page(s)
Sample 31042.05		
8.3.5.1	Verification of overload releases	8
8.3.5.2	Rated ultimate short-circuit breaking capacity Additional sequence of short-circuit operations on four-pole circuit-breakers (if applicable)	9-11
8.3.5.3	Verification of dielectric withstand Verification of leakage current (if applicable)	12 13
8.3.5.4	Verification of overload releases	14
Sample 31042.06		
8.3.5.1	Verification of overload releases	15
8.3.5.2	Rated ultimate short-circuit breaking capacity Additional sequence of short-circuit operations on four-pole circuit-breakers (if applicable)	16-18
8.3.5.3	Verification of dielectric withstand Verification of leakage current (if applicable)	19 20
8.3.5.4	Verification of overload releases	21
Sample 31042.07		
8.3.5.1	Verification of overload releases	22
8.3.5.2	Rated ultimate short-circuit breaking capacity Additional sequence of short-circuit operations on four-pole circuit-breakers (if applicable)	23-25
8.3.5.3	Verification of dielectric withstand Verification of leakage current (if applicable)	26 27
8.3.5.4	Verification of overload releases	28
Sample 31042.08		
8.3.5.1	Verification of overload releases	29
8.3.5.2	Rated ultimate short-circuit breaking capacity Additional sequence of short-circuit operations on four-pole circuit-breakers (if applicable)	30-32
8.3.5.3	Verification of dielectric withstand Verification of leakage current (if applicable)	33 34
8.3.5.4	Verification of overload releases	35

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005



ВРНО С
ОПТИКА

ASEFA	Test report No.: F01.04.20 Page 6 / 68
Type test according to: IEC 60947-2 Test sequence III	Type: NT 06-12 H2

Test sequence III comprises the following tests:

		Page(s)
Sample 31042.09		
8.3.5.1	Verification of overload releases	36
8.3.5.2	Rated ultimate short-circuit breaking capacity Additional sequence of short-circuit operations on four-pole circuit-breakers (if applicable)	37-39
8.3.5.3	Verification of dielectric withstand	40
	Verification of leakage current (if applicable)	41
8.3.5.4	Verification of overload releases	42
Sample 31042.10		
8.3.5.1	Verification of overload releases	43
8.3.5.2	Rated ultimate short-circuit breaking capacity Additional sequence of short-circuit operations on four-pole circuit-breakers (if applicable)	44-46
8.3.5.3	Verification of dielectric withstand	47
	Verification of leakage current (if applicable)	48
8.3.5.4	Verification of overload releases	49
Sample 31042.11		
8.3.5.1	Verification of overload releases	50
8.3.5.2	Rated ultimate short-circuit breaking capacity Additional sequence of short-circuit operations on four-pole circuit-breakers (if applicable)	51-53
8.3.5.3	Verification of dielectric withstand	54
	Verification of leakage current (if applicable)	55
8.3.5.4	Verification of overload releases	56
Sample 31042.12		
8.3.5.1	Verification of overload releases	57
8.3.5.2	Rated ultimate short-circuit breaking capacity Additional sequence of short-circuit operations on four-pole circuit-breakers (if applicable)	58-60
8.3.5.3	Verification of dielectric withstand	61
	Verification of leakage current (if applicable)	62
8.3.5.4	Verification of overload releases	63

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005



БРИТЭК
ОПРЕДЕЛЕНА

ASEFA	Test report No.: F01.04.20 Page 7 / 68
Type test according to: IEC 60947-2 Test sequence III	Type: NS630bH to 1600H


Sample Nb	Type	Test	Ir	Ics Tested	Supply	pages
31042.05	NS1600H	Single Ph.	1600A	42kA/240V	Upper	8-14
31042.06	NS630bH	Single Ph.	630Ax0,4	42kA/240V	Upper	15-21
31042.07	NS1600H	Single Ph.	1600A	39kA/254V	Upper	22-28
31042.08	NS1600H	Single Ph.	1600A	25,2kA/398V	Lower	29-35
31042.09	NS1600H	3 Ph.	1600A	70kA/415V	Upper	36-42
31042.10	NS630bH	3 Ph.	630Ax0,4	70kA/415V	Upper	43-49
31042.11	NS1600H	3 Ph.	1600A	65kA/440V	Upper	50-56
31042.12	NS1600H	3 Ph.	1600A	42kA/690V	Lower	57-63

The MICROLOGIC tripping unit being independent of the temperature, the connections used for testing tripping characteristics differ from those given in the tables of standard (refer to IEC 60947-2 note 2 of 8.3.5.1)

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
Ed. 2.1 form 39

Date August 19th 2005



**ВЯНО С
ОРИГИНАЛ**

ASEFA		Test report No.: F01.04.20 Page 8 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.05	
Standard and clause	Kind of tests and requirements	Test values Results	
60947-1 Table 9, 10 and 11	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY		
	Cabling characteristics Cable ./ mm² Bar 100 x 5 mm Number 2 Length ./ mm Tightening torque 50 Nm Reference temperature 40 °C ± 2 °C Ambient temperature 22,5 °C Correction factor (k = 1 for releases Independent of ambient temperature) k 1 Current setting value I_n Test current either k x 2.0 x I _n 3200 A 8.3.5.1 Test sequence II (I _{cs} = I _{cu}) before 8.3.4.1 8.3.5.1 Test sequence III before 8.3.5.2 8.3.6.1 Test sequence IV before 8.3.6.2 8.3.6.6 Test sequence IV after 8.3.6.5 8.3.7.4 Test sequence V before 8.3.7.5 8.3.8.1 Combined test sequence before 8.3.8.2 A.5 Verification of discrimination before 8.3.5.2 A.6.3 Verification of back-up protection before 8.3.5.2 or k x 2.5 x I _n ./ A 8.3.5.4 Test sequence II (I _{cs} = I _{cu}) after 8.3.4.5 8.3.5.4 Test sequence III after 8.3.5.3 8.3.7.8 Test sequence V after 8.3.7.7 8.3.8.7 Combined test sequence after 8.3.8.6 A.5 Verification of discrimination after 8.3.5.3 A.6.3 Verification of back-up protection after 8.3.5.3 C.4 Individual pole short-circuit test sequence H.4 Test sequence for circuit-breakers for IT-systems Tripping time (for twice the value of current setting on single pole) Neutral ≤ 270 s 220 s Ph ₁ ≤ 270 s 226 s Ph ₂ ≤ 270 s 220 s Ph ₃ ≤ 270 s 221 s		
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM			

Date August 19th 2005



БЪЛГАРИЯ
 ООД
 ГРЕНОБЛ
 ФОРМ 46


ASEFA		Test report No.: F01.04.20 Page 9 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.05
Standard and clause	Kind of tests and requirements	Test values Results
8.3.5.2 8.3.6.4 8.3.7.6	ADDITIONAL SEQUENCE OF SHORT-CIRCUIT OPERATIONS ON FOUR POLE CIRCUIT-BREAKERS Test made on the same sample as for the three-pole short-circuit or on a new sample	same/new new
	Rated operational voltage U_e	415 V
	Test voltage	$U_e/\sqrt{3}$ 240 V
	Recovery voltage	$1.05 \times U_e/\sqrt{3}$ 252 V
	Rated ultimate short-circuit breaking capacity I_{cu}	42 kA
	Rated short-time withstand current I_{cw}	19.2 kA
	Short-circuit breaking capacity of the fourth pole (by arrangement) (not less than 60 % of I_{cu} or I_{cw} as applicable)	42 kA
Table 11	Power factor	0,25 0,25(+0;-0,05)
	Frequency	50/60 Hz 50 Hz
8.3.2.1	Control supply voltage	$0.85 \times U_e$./. V ./. V
7.2.1.1.3	Maximum value of the closing time	./. ms
	Sequence of operation	O - t - CO O - t - CO
	Circuit diagram	Page 66
	Calibration of the test circuit	Pageform 169 Next page
	Safety area	Pageform Page 65
	Installation of the material tested	Pageform Page 64
	Energization direction	Top/Bottom Top
60947-1 Table 9, 10 and 11	Cabling characteristics	
	Cable	./. mm ² ./. mm ²
	Bar	./. x ./. mm 100 x 10 mm
	Number	./. 1
	Length	supply side ./. mm 500 mm load side ./. mm 0 mm
	Tightening torque	50 Nm

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM


Date August 19th 2005



БРИФ С
ОПРИМАНА

ASEFA		Test report No.: F01.04.20 Page 10 / 68
Type test according to: IEC 60947-2		Type: NS630bH to 1600H Sample 31042.05
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT	
	Oscillogram	20040283-0102 20040283-0103
	Applied voltage	260 V
	Frequency	50 Hz
	RMS current value at 20 ms	i_1 43,7 kA i_2 ./. kA i_3 ./. kA
	Average RMS. Value	43,7 kA
	Peak current maximum value	87,53 kA
	Power factor	0,23
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		Date August 19th 2005

**ВАРИО С
ОПТИКА**

ASEFA		Test report No.: F01.04.20 Page 11 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.05
Standard and clause	Kind of tests and requirements	Test values Results
7.2.1.1.3	OPERATION "O"	
	Oscillogram Peak current value i_1 Total duration Recovery voltage (phase to neutral) $U_{r(1-N)}$ Ratio between U_r and U_e U_r/U_e Joule integral Ph_1 Melting of the fusible element Yes/No Holes in the PE-sheet (if applicable) Yes/No Cracks observed Yes/No if Yes Time interval between operations 3 min	20040283.0104 75,33 kA 16,15 ms 260 V 1,08 33,15 (kA) ² s No No No Page ./. 10 min
	OPERATION "CO"	
	Oscillogram Applied voltage Peak current value i_1 Total duration Recovery voltage (phase to neutral) $U_{r(1-N)}$ Ratio between U_r and U_e U_r/U_e Joule integral Ph_1 Closing operation time Melting of the fusible element Yes/No Cracks observed Yes/No if Yes	20040283.0105 257 V 63,41 kA 22,7 ms 256 V 1,08 25,28 A ² s ./ ms No No Page ./
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		 IEC/EN 60947-2 Ed. 2-1-1991 49
Date August 19th 2005		

**ВРНО С
ОПННА**

ASEFA		Test report No.: F01.04.20 Page 12 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.05
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U_n , min. 1000 V	1000 V
8.3.3.5	Test sequence I	
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	1000 V
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s
		5 s


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM



Date August 19th 2005

**ВЯРНО С
ОПРИМКА**

ASEFA		Test report No.: F01.04.20 Page 13 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.05
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	$1.1 \times U_o = 457 \text{ V}$ 457 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (in new condition)	$\leq 0.5 \text{ mA}$./ mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$./ mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$./ mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ <1 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$./ mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$./ mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$./ mA
8.3.8.6	Combined test sequence	$\leq 2 \text{ mA}$./ mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$./ mA
H.3	Individual pole short-circuit test sequence I_T	$\leq 6 \text{ mA}$./ mA



Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
Ed. 2.1 form 25

Date August 19th 2005

ВРЪНО С
ОРИГИНАЛ

ASEFA		Test report No.: F01.04.20	
Type test according to: IEC 60947-2 Test sequence III		Page 14 / 68	
Standard and clause		Test values Results	
VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY			
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	./. mm ²	./. mm ²
	Bar	100 x 5 mm	100 x 5 mm
	Number	2	2
	Length	./. mm	500 mm
	Tightening torque		50 Nm
	Reference temperature	40 °C ± 2 °C	
	Ambient temperature		22,5 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k		1
	Current setting value	I_n	1600 A
	Test current		
	either $k \times 2.0 \times I_n$./. A	./. A
8.3.5.1	Test sequence II ($I_{cs} = I_{cu}$)	before 8.3.4.1	
8.3.5.1	Test sequence III	before 8.3.5.2	
8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5	
8.3.7.4	Test sequence V	before 8.3.7.5	
8.3.8.1	Combined test sequence	before 8.3.8.2	
A.5	Verification of discrimination	before 8.3.5.2	
A.6.3	Verification of back-up protection	before 8.3.5.2	
	or $k \times 2.5 \times I_n$	4000 A	4000 A
8.3.5.4	Test sequence II ($I_{cs} = I_{cu}$)	after 8.3.4.5	
8.3.5.4	Test sequence III	after 8.3.5.3	
8.3.7.8	Test sequence V	after 8.3.7.7	
8.3.8.7	Combined test sequence	after 8.3.8.6	
A.5	Verification of discrimination	after 8.3.5.3	
A.6.3	Verification of back-up protection	after 8.3.5.3	
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		
	Tripping time (for twice the value of current setting on single pole)		
	Neutral	≤ 270 s	133 s
	Ph ₁	≤ 270 s	126 s
	Ph ₂	≤ ./. s	./. s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM			
			Date August 19th 2005




**БАРНО С
ОПРАВКА**

ASEFA		Test report No.: F01.04.20
		Page 15 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.06
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics Cable 185 mm ² Bar ./ x ./ mm Number 1 Length ./ mm Tightening torque Reference temperature 40 °C ± 2 °C Ambient temperature Correction factor (k = 1 for releases independent of ambient temperature) k Current setting value I_n Test current either $k \times 2.0 \times I_n$ 504 A 8.3.5.1 Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1 8.3.5.1 Test sequence III before 8.3.5.2 8.3.6.1 Test sequence IV before 8.3.6.2 8.3.6.6 Test sequence IV after 8.3.6.5 8.3.7.4 Test sequence V before 8.3.7.5 8.3.8.1 Combined test sequence before 8.3.8.2 A.5 Verification of discrimination before 8.3.5.2 A.6.3 Verification of back-up protection before 8.3.5.2 or $k \times 2.5 \times I_n$./ A 8.3.5.4 Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5 8.3.5.4 Test sequence III after 8.3.5.3 8.3.7.8 Test sequence V after 8.3.7.7 8.3.8.7 Combined test sequence after 8.3.8.6 A.5 Verification of discrimination after 8.3.5.3 A.6.3 Verification of back-up protection after 8.3.5.3 C.4 Individual pole short-circuit test sequence H.4 Test sequence for circuit-breakers for IT-systems Tripping time (for twice the value of current setting on single pole) Neutral ≤ 270 s Ph ₁ ≤ 270 s Ph ₂ ≤ 270 s Ph ₃ ≤ 270 s	185 mm ² ./ x ./ mm 1 2000 mm 50 Nm 22 °C 1 630x0,4=252A 504 A ./ A 213 s 235 s 257 s 278 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Ed. 2.1 form 46
Date August 19th 2005		



БРИТЭК
 ОПИШКА

ASEFA		Test report No.: F01.04.20 Page 16 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.06
Standard and clause	Kind of tests and requirements	Test values Results
8.3.5.2 8.3.6.4 8.3.7.6	ADDITIONAL SEQUENCE OF SHORT-CIRCUIT OPERATIONS ON FOUR POLE CIRCUIT-BREAKERS Test made on the same sample as for the three-pole short-circuit or on a new sample	same/new New
	Rated operational voltage U_e	415 V
	Test voltage	$U_e/\sqrt{3}$ 240 V
	Recovery voltage	$1.05 \times U_e/\sqrt{3}$ 252 V
	Rated ultimate short-circuit breaking capacity I_{cu}	42 kA
	Rated short-time withstand current I_{cw}	./. kA
	Short-circuit breaking capacity of the fourth pole (by arrangement) (not less than 60 % of I_{cu} or I_{cw} as applicable)	./ kA
Table 11	Power factor	0.20-0.25
	Frequency	50 Hz 50 Hz
8.3.2.1	Control supply voltage	$0.85 \times U_e$./. V ./ V
7.2.1.1.3	Maximum value of the closing time	./ ms
	Sequence of operation	O - t - CO O - t - CO
	Circuit diagram	Page 66
	Calibration of the test circuit	Pageform 169 Next page
	Safety area	Pageform Page 65
	Installation of the material tested	Pageform Page 64
	Energization direction	Top/Bottom Top
60947-1 Table 9, 10 and 11	Cabling characteristics	
	Cable	./ mm ² ./ mm ²
	Bar	./ x ./ mm 100 x 10 mm
	Number	./ 1
	Length	supply side ./ mm 500 mm
		load side ./ mm 0 mm
	Tightening torque	50 Nm




БУРО С
 ОПИТИ

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
Ed. 2.1 form 48

Date August 19th 2005

ASEFA		Test report No.: F01.04.20 Page 17 / 68
Type test according to: IEC 60947-2		Type: NS630bH to 1600H Sample 31042.06
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT	
	Oscillogram	20040283-0103 20040283-0102
	Applied voltage	260 V
	Frequency	50 Hz
	RMS current value at 20 ms	i_1 43.7 kA i_2 ./ kA i_3 ./ kA
	Average RMS. Value	43.7 kA
	Peak current maximum value	87.53 kA
	Power factor	0,23
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		Date August 19th 2005

**ВЪРНО С
ОРИГИНАЛА**

ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 18 / 68
Type: NS630bH to 1600H Sample 31042.06		
Standard and clause	Kind of tests and requirements	Test values Results
7.2.1.1.3	OPERATION "O"	
	Oscillogram Peak current value I_1 Total duration Recovery voltage (phase to neutral) $U_{r(1-N)}$ Ratio between U_r and U_0 U_r/U_0 Joule integral Ph_1 Melting of the fusible element Yes/No Holes in the PE-sheet (if applicable) Yes/No Cracks observed Yes/No if Yes Time Interval between operations 3 min	20040283-0106 75.35 kA 16.4 ms 257 V 1.07 33.55 (kA) ² s No No No Page ./. 4 min
7.2.1.1.3	OPERATION "CO"	
	Oscillogram Applied voltage Peak current value I_1 Total duration Recovery voltage (phase to neutral) $U_{r(1-N)}$ Ratio between U_r and U_0 U_r/U_0 Joule integral Ph_1 Closing operation time Melting of the fusible element Yes/No Cracks observed Yes/No if Yes	20040283-0107 257 V 61.6 kA 24.6 ms 257 V 1.07 27.2 (kA) ² s ./ ms No No Page ./

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM




Date August 19th 2005

ВЪВЕДЕНА
ОПРЕДЕЛЕНА

ASEFA		Test report No.: F01.04.20 Page 19 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.06
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U_n , min. 1000 V	1000 V
8.3.3.5	Test sequence I	
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	1000 V
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 5 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		

Date August 19th 2005



**ВЯРНО С
ОФИЦИАЛНА**

ASEFA		Test report No.: F01.04.20 Page 20 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.06
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for Isolation having an operational voltage U_e greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	$1.1 \times U_e = 457 \text{ V}$ 457 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (in new condition)	$\leq 0.5 \text{ mA}$ /. mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$ /. mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$ /. mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ 5 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$ /. mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$ /. mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$ /. mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$ /. mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$ /. mA
H.3	Individual pole short-circuit test sequence I_{IT}	$\leq 6 \text{ mA}$ /. mA

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM



Date August 19th 2005

ВЕРНО С
ОРИГИНАЛ

ASEFA		Test report No.: F01.04.20
		Page 21 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.06
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics	
	Cable 185 mm ²	185 mm ²
	Bar ./. x ./. mm	./. x ./. mm
	Number 1	1
	Length ./. mm	2000 mm
	Tightening torque	50 Nm
	Reference temperature 40 °C ± 2 °C	
	Ambient temperature	21,6 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k	1
	Current setting value I _n	252 A
	Test current	
	either k x 2.0 x I _n ./. A	./. A
8.3.5.1	Test sequence II (I _{cs} = I _{cu}) before 8.3.4.1	
8.3.5.1	Test sequence III before 8.3.5.2	
8.3.6.1	Test sequence IV before 8.3.6.2	
8.3.6.6	Test sequence IV after 8.3.6.5	
8.3.7.4	Test sequence V before 8.3.7.5	
8.3.8.1	Combined test sequence before 8.3.8.2	
A.5	Verification of discrimination before 8.3.5.2	
A.6.3	Verification of back-up protection before 8.3.5.2	
	or k x 2.5 x I _n 630 A	630 A
8.3.5.4	Test sequence II (I _{cs} = I _{cu}) after 8.3.4.5	
8.3.5.4	Test sequence III after 8.3.5.3	
8.3.7.8	Test sequence V after 8.3.7.7	
8.3.8.7	Combined test sequence after 8.3.8.6	
A.5	Verification of discrimination after 8.3.5.3	
A.6.3	Verification of back-up protection after 8.3.5.3	
C.4	Individual pole short-circuit test sequence	
H.4	Test sequence for circuit-breakers for IT-systems	
	Tripping time (for twice the value of current setting on single pole)	
	NETRAL ≤ 270 s	129 s
	Ph ₁ ≤ 270 s	135 s
	Ph ₂ ≤ I _n	./. s

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM



Date August 19th 2005

ВІСНОК
ОПРАКОВАНО

ASEFA		Test report No.: F01.04.20 Page 22 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.07	
Standard and clause	Kind of tests and requirements	Test values Results	
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY		
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	J. mm ²	J. mm ²
	Bar	100 x 5 mm	100 x 5 mm
	Number	2	2
	Length	500 mm	500 mm
	Tightening torque		50 Nm
	Reference temperature	40 °C ± 2 °C	
	Ambient temperature		22,6 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k		1
	Current setting value	I _n	1600 A
	Test current		
	either k x 2.0 x I _n	3200 A	3200 A
8.3.5.1	Test sequence II (I _{cs} = I _{cu})	before 8.3.4.1	
8.3.5.1	Test sequence III	before 8.3.5.2	
8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5	
8.3.7.4	Test sequence V	before 8.3.7.5	
8.3.8.1	Combined test sequence	before 8.3.8.2	
A.5	Verification of discrimination	before 8.3.5.2	
A.6.3	Verification of back-up protection	before 8.3.5.2	
	or k x 2.5 x I _n	J. A	J. A
8.3.5.4	Test sequence II (I _{cs} = I _{cu})	after 8.3.4.5	
8.3.5.4	Test sequence III	after 8.3.5.3	
8.3.7.8	Test sequence V	after 8.3.7.7	
8.3.8.7	Combined test sequence	after 8.3.8.6	
A.5	Verification of discrimination	after 8.3.5.3	
A.6.3	Verification of back-up protection	after 8.3.5.3	
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		
	Tripping time (for twice the value of current setting on single pole)		
	Neutral	≤ 270 s	238 s
	Ph ₁	≤ 270 s	239 s
	Ph ₂	≤ 270 s	237 s
	Ph ₃	≤ 270 s	231 s

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM




TRF IEC EN 60947-2
Form 46

Date August 19th 2005


ВІСЛІВ
ОПРИМАННЯ


ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 23 / 68
Type: NS630bH to 1600H Sample 31042.07		
Standard and clause	Kind of tests and requirements	Test values Results
8.3.5.2 8.3.6.4 8.3.7.6	ADDITIONAL SEQUENCE OF SHORT-CIRCUIT OPERATIONS ON FOUR POLE CIRCUIT-BREAKERS Test made on the same sample as for the three-pole short-circuit or on a new sample	same/new New
	Rated operational voltage U_e	440 V
	Test voltage	$U_e/\sqrt{3}$ 254 V
	Recovery voltage	$1.05 \times U_e/\sqrt{3}$ 267 V
	Rated ultimate short-circuit breaking capacity I_{cu}	39 kA
	Rated short-time withstand current I_{ow}	19.2 kA
	Short-circuit breaking capacity of the fourth pole (by arrangement) (not less than 60 % of I_{cu} or I_{ow} as applicable)	39 kA
Table 11	Power factor	0.20-0.25 0.22
	Frequency	50 Hz 50 Hz
8.3.2.1	Control supply voltage	$0.85 \times U_e$./. V ./. V
7.2.1.1.3	Maximum value of the closing time	./ ms ./. ms
	Sequence of operation	O - t - CO O - t - CO
	Circuit diagram	Page 66
	Calibration of the test circuit	Pageform 169 Next page
	Safety area	Pageform Page 65
	Installation of the material tested	Pageform Page 64
	Energization direction	Top/Bottom Top
60947-1 Table 9, 10 and 11	Cabling characteristics	
	Cable	./ mm ² ./ mm ²
	Bar	./ x ./ mm 100 x 10 mm
	Number	./ 1
	Length	supply side ./ mm 500 mm
		load side ./ mm 500 mm
	Tightening torque	50 Nm
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		

Date August 19th, 2005



BTPHO C
OMTANA

ASEFA		Test report No.: F01.04.20 Page 24 / 68
Type test according to: IEC 60947-2		Type: NS630bH to 1600H Sample 31042.07
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT	
	Oscillogram	20040283-0108 20040283-0113
	Applied voltage	277 V
	Frequency	50 Hz
	RMS current value at 20 ms	i_1 39.52 kA i_2 ./. kA i_3 ./. kA
	Average RMS. Value	39.52 kA
	Peak current maximum value	83.05 kA
	Power factor	0,22
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		 ВРИПОС ОПШННАТА
		Date August 19th 2005

ASEFA		Test report No.: F01.04.20 Page 25 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.07
Standard and clause	Kind of tests and requirements	Test values Results
7.2.1.1.3	OPERATION "O"	
	Oscillogram Peak current value i_1 Total duration Recovery voltage (phase to neutral) $U_{r(1-N)}$ Ratio between U_r and U_e U_r/U_e Joule integral Ph_1 Melting of the fusible element Yes/No Holes in the PE-sheet (if applicable) Yes/No Cracks observed Yes/No if Yes Time interval between operations 3 min	20040283-0116 73 kA 16.9 ms 277 V 1.09 31.42 (kA) ² s No No No Page ./. 3 min
7.2.1.1.3	OPERATION "CO"	
	Oscillogram Applied voltage Peak current value i_1 Total duration Recovery voltage (phase to neutral) $U_{r(1-N)}$ Ratio between U_r and U_e U_r/U_e Joule integral Ph_1 Closing operation time Melting of the fusible element Yes/No Cracks observed Yes/No if Yes	20040283-0117 280 V 60.5 kA 17.9 ms 276.7 V 1.08 22.63 (kA) ² s ./ ms No No Page ./
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		Date August 19th 2005

N. 1
 2005
 08
 19
 19
 05
 08
 19
 05


ASEFA		Test report No.: F01.04.20 Page 26 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.07
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U_n , min. 1000 V	1000 V
8.3.3.5	Test sequence I	1000 V
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 5 s

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2008




БЯПЛО С
ОПТИКА

ASEFA		Test report No.: F01.04.20 Page 27 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.07
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	1.1 x U_o = 484 V 484 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (In new condition)	≤ 0.5 mA ./ mA
8.3.3.5	Test sequence I (after overload performance)	≤ 2 mA ./ mA
8.3.4.3	Test sequence II	≤ 2 mA ./ mA
8.3.5.3	Test sequence III	≤ 6 mA 0.5 mA
8.3.6.5	Test sequence IV	≤ 2 mA ./ mA
8.3.7.3	Test sequence V, stage 1	≤ 2 mA ./ mA
8.3.7.7	Test sequence V, stage 2	≤ 6 mA ./ mA
8.3.8.5	Combined test sequence	≤ 2 mA ./ mA
C.3	Individual pole short-circuit test sequence I_{su}	≤ 6 mA ./ mA
H.3	Individual pole short-circuit test sequence I_{IT}	≤ 6 mA ./ mA
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		
		Date August 19th 2005

ВЪПРОС
 ОПИТНАТА


ASEFA		Test report No.: F01.04.20		
Type test according to: IEC 60947-2 Test sequence III		Page 28 / 68		
Standard and clause		Test values Results		
<p align="center">VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY</p>				
60947-1 Table 9, 10 and 11	Cabling characteristics			
	Cable	./. mm ²	./. mm ²	
	Bar	100 x 5 mm	100 x 5 mm	
	Number	2	2	
	Length	./. mm	500 mm	
	Tightening torque		50 Nm	
	Reference temperature	40 °C ± 2 °C		
	Ambient temperature		21.3 °C	
	Correction factor (k = 1 for releases independent of ambient temperature) k		1	
	Current setting value	I _n	1600 A	
	Test current			
		either k x 2.0 x I _n	./. A	./. A
	8.3.5.1	Test sequence II (I _{cs} = I _{cu}) before 8.3.4.1		
	8.3.5.1	Test sequence III before 8.3.5.2		
	8.3.6.1	Test sequence IV before 8.3.6.2		
8.3.6.6	Test sequence IV after 8.3.6.5			
8.3.7.4	Test sequence V before 8.3.7.5			
8.3.8.1	Combined test sequence before 8.3.8.2			
A.5	Verification of discrimination before 8.3.5.2			
A.6.3	Verification of back-up protection before 8.3.5.2			
	or k x 2.5 x I _n	4000 A	4000 A	
8.3.5.4	Test sequence II (I _{cs} = I _{cu}) after 8.3.4.5			
8.3.5.4	Test sequence III after 8.3.5.3			
8.3.7.8	Test sequence V after 8.3.7.7			
8.3.8.7	Combined test sequence after 8.3.8.6			
A.5	Verification of discrimination after 8.3.5.3			
A.6.3	Verification of back-up protection after 8.3.5.3			
C.4	Individual pole short-circuit test sequence			
H.4	Test sequence for circuit-breakers for IT-systems			
	Tripping time (for twice the value of current setting on single pole)			
	Neutral	≤ 270 s	132 s	
	Ph ₁	≤ 270 s	129 s	
	Ph ₂	≤ ./. s	./. s	
	Ph ₃	≤ ./. s	./. s	

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM



Date August 19th 2005

БЪЛГАРИЯ
ОФИС
ОРИЕНТАЛ

ASEFA		Test report No.: F01.04.20 Page 29 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.08
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics Cable $.l$, mm ² Bar 100 x 5 mm Number 2 Length $.l$, mm Tightening torque Reference temperature 40 °C ± 2 °C Ambient temperature Correction factor (k = 1 for releases independent of ambient temperature) k Current setting value I_n	$.l$, mm ² 100 x 5 mm 2 500 mm 50 Nm 22.6 °C 1 1600 A
	Test current	
	either $k \times 2.0 \times I_n$	3200 A
8.3.5.1	Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1	
8.3.5.1	Test sequence III before 8.3.5.2	
8.3.6.1	Test sequence IV before 8.3.6.2	
8.3.6.6	Test sequence IV after 8.3.6.5	
8.3.7.4	Test sequence V before 8.3.7.5	
8.3.8.1	Combined test sequence before 8.3.8.2	
A.5	Verification of discrimination before 8.3.5.2	
A.6.3	Verification of back-up protection before 8.3.5.2	
	or $k \times 2.5 \times I_n$	$.l$, A
8.3.5.4	Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5	
8.3.5.4	Test sequence III after 8.3.5.3	
8.3.7.8	Test sequence V after 8.3.7.7	
8.3.8.7	Combined test sequence after 8.3.8.6	
A.5	Verification of discrimination after 8.3.5.3	
A.6.3	Verification of back-up protection after 8.3.5.3	
C.4	Individual pole short-circuit test sequence	
H.4	Test sequence for circuit-breakers for IT-systems	
	Tripping time (for twice the value of current setting on single pole)	
	Neutral ≤ 270 s	235 s
	Ph ₁ ≤ 270 s	219 s
	Ph ₂ ≤ 270 s	223 s
	Ph ₃ ≤ 270 s	223 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		
		Date August 19th 2005

БҮРҮҮС
 ОПИШЛАГА


ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 30 / 68
		Type: NS630bH to 1600H Sample 31042.08
Standard and clause	Kind of tests and requirements	Test values Results
8.3.5.2 8.3.6.4 8.3.7.6	ADDITIONAL SEQUENCE OF SHORT-CIRCUIT OPERATIONS ON FOUR POLE CIRCUIT-BREAKERS Test made on the same sample as for the three-pole short-circuit or on a new sample Rated operational voltage U_e Test voltage Recovery voltage Rated ultimate short-circuit breaking capacity I_{cu} Rated short-time withstand current I_{cw} Short-circuit breaking capacity of the fourth pole (by arrangement) (not less than 60 % of I_{cu} or I_{cw} as applicable)	same/new 690 V $U_e/\sqrt{3}$ 398 V $1.05 \times U_e/\sqrt{3}$ 418 V 25,2 kA 19,2 kA 39 kA
Table 11	Power factor Frequency	0.25 50 Hz 0.25(+0,-0,05) 50 Hz
8.3.2.1 7.2.1.1.3	Control supply voltage Maximum value of the closing time Sequence of operation Circuit diagram Calibration of the test circuit Safety area Installation of the material tested Energization direction	$0.85 \times U_e$./. V ./ ms O - t - CO Page 66 Next page Pageform Pageform Top/Bottom Page 65 Page 64 Top
60947-1 Table 9, 10 and 11	Cabling characteristics Cable Bar Number Length Tightening torque	 ./ mm ² ./ x ./ mm ./ supply side ./ mm load side ./ mm 500 mm 500 mm 50 Nm

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005




БЪЛГАРИЯ
ОПШЕНО
ОПШЕНО

ASEFA		Test report No.: F01.04.20 Page 31 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.08
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT	
	Oscillogram	20040283-0119 20040283-0122
	Applied voltage	448.56 V
	Frequency	50 Hz
	RMS current value at 20 ms	i_1 26.46 kA i_2 ./. kA i_3 ./. kA
	Average RMS. Value	26.46 kA
	Peak current maximum value	56.23 kA
	Power factor	0,2
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		 IEC/EN 60947-2 Ed. 2.1 form 169
Date August 19th 2005		

REPUBLIC
OF
SLOVAKIA

ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 32 / 68
Standard and clause		Kind of tests and requirements
		Test values Results
	OPERATION "O"	
	Oscillogram	20040283.0123
	Peak current value	I_1 54.67 kA
		I_2 ./. kA
		I_3 ./. kA
	Maximum total duration	19 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input type="checkbox"/> or $U_{r(1-N)}$ <input checked="" type="checkbox"/> 432.12 V
		$U_{r(2-3)}$ <input type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> ./. V
		$U_{r(3-1)}$ <input type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> ./. V
	Average value	U_m 432.12 V
	Ratio between U_m and U_e	U_m/U_e 1.08
	Joule integral	Ph_1 19.5 (kA) ² s
		Ph_2 ./. (kA) ² s
		Ph_3 ./. (kA) ² s
	Melting of the fusible element	Yes/No No
	Holes in the PE-sheet (if applicable)	Yes/No No
	Cracks observed	Yes/No No
	if Yes	Page ./.
	Time interval between operations	3 min 4 min
	OPERATION "CO1"	
	Oscillogram	20040283.0124
	Applied voltage	435.05 V
	Peak current value	i_1 53.75 kA
		i_2 ./. kA
		i_3 ./. kA
	Maximum total duration	18.05 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input type="checkbox"/> or $U_{r(1-N)}$ <input checked="" type="checkbox"/> 434.56 V
		$U_{r(2-3)}$ <input type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> ./. V
		$U_{r(3-1)}$ <input type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> ./. V
	Average value	U_m 434.56 V
	Ratio between U_m and U_e	U_m/U_e 1.09
	Joule integral	Ph_1 18.72 (kA) ² s
		Ph_2 ./. (kA) ² s
		Ph_3 ./. (kA) ² s
7.2.1.1.3	Closing operation time	./.
	Melting of the fusible element	Yes/No No
	Cracks observed	Yes/No No
	if Yes	Page ./.
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		

Date August 19th 2005




BANK OF ETHIOPIA

ASEFA		Test report No.: F01.04.20 Page 33 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.08
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U _e , mín. 1000 V	1380 V
8.3.3.5	Test sequence I	
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	1380 V
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 5 s

Test laboratory: F01 - GRENOBLE
ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
Ed. 2.1 form 32/04/05


Date August 19th 2005



О П И Т А Н И Я
 С П И Т А Н И Я

ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 34 / 68
Type: NS630bH to 1600H Sample 31042.08		
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	$1.1 \times U_o = 759 \text{ V}$ 759 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (in new condition)	$\leq 0.5 \text{ mA}$./ mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$./ mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$./ mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ 0 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$./ mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$./ mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$./ mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$./ mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$./ mA
H.3	Individual pole short-circuit test sequence I_{IT}	$\leq 6 \text{ mA}$./ mA


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM



Date August 19th 2005

SYRAC
DISTRIBUTION

ASEFA		Test report No.: F01.04.20 Page 36 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09	
Standard and clause	Kind of tests and requirements	Test values Results	
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY		
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	./. mm ²	./. mm ²
	Bar	100 x 5 mm	100 x 10 mm
	Number	2	1
	Length	./. mm	500 mm
	Tightening torque		50 Nm
	Reference temperature	40 °C ± 2 °C	
	Ambient temperature		22.5 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k		1
	Current setting value	I _n	1600 A
	Test current		
	either k x 2.0 x I _n	3200 A	3200 A
8.3.5.1	Test sequence II (I _{cs} = I _{cu})	before 8.3.4.1	
8.3.5.1	Test sequence III	before 8.3.5.2	
8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5	
8.3.7.4	Test sequence V	before 8.3.7.5	
8.3.8.1	Combined test sequence	before 8.3.8.2	
A.5	Verification of discrimination	before 8.3.5.2	
A.6.3	Verification of back-up protection	before 8.3.5.2	
	or k x 2.5 x I _n	./. A	./. A
8.3.5.4	Test sequence II (I _{cs} = I _{cu})	after 8.3.4.5	
8.3.5.4	Test sequence III	after 8.3.5.3	
8.3.7.8	Test sequence V	after 8.3.7.7	
8.3.8.7	Combined test sequence	after 8.3.8.6	
A.5	Verification of discrimination	after 8.3.5.3	
A.6.3	Verification of back-up protection	after 8.3.5.3	
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		
	Tripping time (for twice the value of current setting on single pole)		
	Neutral	≤ 270 s	237 s
	Ph ₁	≤ 270 s	228 s
	Ph ₂	≤ 270 s	221 s
	Ph ₃	≤ 270 s	235 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM			
Date August 19th 2005			




BRPHO C
PHHANA


ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 37 / 68
Type: NS630bH to 1600H Sample 31042.09		
Standard and clause	Kind of tests and requirements	Test values Results
8.3.5.2	RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY	
	Utilization category B	
	Rated operational voltage U_e 415 V	
	Recovery voltage $1.05 \times U_e$	435.75 V
	Rated ultimate short-circuit breaking capacity I_{cu}	70 kA
	Rated short-circuit making capacity I_{cm}	154 kA
Table 11	Power factor 0.20	0.20
	Frequency 50 Hz	50 Hz
8.3.2.1	Control supply voltage $0.85 \times U_e$./. V	./ . V
7.2.1.1.3	Maximum value of the closing time	./ ms
	Sequence of operation O - t - CO	O - t - CO
	Circuit diagram	Page 66
	Callbration of the test circuit Pageform	Next page
	Safety area Pageform	Page 65
	Installation of the material tested Pageform	Page 64
	Energization direction Top/Bottom	Top
8.3.2.1	Smallest individual enclosure (if applicable)	
	Type	./
	Kind of material	./
	Inside dimensions	
	Height	./ mm
	Width	./ mm
	Depth	./ mm
60947-1	Cabling characteristics	
Table 9, 10 and 11	Cable ./. mm ²	./ . mm ²
	Bar 100 x 5 mm	100 x 10 mm
	Number 2	1
	Length supply side ./. mm	350 mm
	load side ./. mm	350 mm
	Tightening torque	50 Nm

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005




BIPHO C
OPHMAA

ASEFA		Test report No.: F01.04.20 Page 38 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09	
Standard and clause	Kind of tests and requirements	Test values Results	
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT		
	Oscillogram	20040288-0003 20040288-0007	
	Applied voltage	440.17 V	
	Frequency	50 Hz	
	RMS current value at 20 ms	i_1	70.21 kA
		i_2	70.99 kA
		i_3	69.51 kA
	Average RMS. Value	70.23 kA	
	Peak current maximum value	156.12 kA	
Power factor	0,17		
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		 IEC/EN 60947-2 Ed. 2.1 form 169 Date August 19th 2009	

NS630 C
PRIMA

ASEFA		Test report No.: F01.04.20
		Page 39 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09
Standard and clause	Kind of tests and requirements	Test values Results
	OPERATION "O"	
	Oscillogram	20040288.0011
	Peak current value	i_1 123.58 kA
		i_2 111.73 kA
		i_3 66.26 kA
	Maximum total duration	12.8 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 443.07 V
		$U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 443.15 V
		$U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 443.16 V
	Average value	U_{rm} 443.13 V
	Ratio between U_{rm} and U_e	U_{rm}/U_e 1.06
	Joule integral	Ph_1 74.45 (kA) ² s
		Ph_2 63.58 (kA) ² s
		Ph_3 18.06 (kA) ² s
	Melting of the fusible element	Yes/No No
	Holes in the PE-sheet (if applicable)	Yes/No No
	Cracks observed	Yes/No No
	if Yes	Page ./.
	Time interval between operations	3 min 3 min
	OPERATION "CO1"	
	Oscillogram	20040288.0012
	Applied voltage	450.46 V
	Peak current value	i_1 118.6 kA
		i_2 114.5 kA
		i_3 65.68 kA
	Maximum total duration	13.6 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 444.72 V
		$U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 445.21 V
		$U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 443.97 V
	Average value	U_{rm} 444.63 V
	Ratio between U_{rm} and U_e	U_{rm}/U_e 1.07
	Joule integral	Ph_1 67.25 (kA) ² s
		Ph_2 67.14 (kA) ² s
		Ph_3 20.07 (kA) ² s
7.2.1.1.3	Closing operation time	./ ms
	Melting of the fusible element	Yes/No No
	Cracks observed	Yes/No No
	if Yes	Page ./.
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		


Date August 19th 2005



BAPMO C
 SPINBARA

ASEFA		Test report No.: F01.04.20 Page 40 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U _o , min. 1000 V	1000 V
8.3.3.5	Test sequence I	
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	1000 V
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 5 s


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM



Date August 19th 2005

DZPHO C
 OPHMATA

ASEFA		Test report No.: F01.04.20 Page 41 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	$1.1 \times U_o = 457 \text{ V}$ 457 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (In new condition)	$\leq 0.5 \text{ mA}$./ mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$./ mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$./ mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ 0.08 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$./ mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$./ mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$./ mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$./ mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$./ mA
H.3	Individual pole short-circuit test sequence I_{IT}	$\leq 6 \text{ mA}$./ mA
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		Date August 19th 2005




00100 C
 OPTIMISER

ASEFA		Test report No.: F01.04.20		
Type test according to: IEC 60947-2 Test sequence III		Page 42 / 68		
Standard and clause		Test values Results		
VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY				
60947-1 Table 9, 10 and 11	Cabling characteristics			
	Cable	./. mm ²	./. mm ²	
	Bar	100 x 5 mm	100 x 5 mm	
	Number	2	2	
	Length	./. mm	500 mm	
	Tightening torque		50 Nm	
	Reference temperature	40 °C ± 2 °C		
	Ambient temperature		18.4 °C	
	Correction factor (k = 1 for releases independent of ambient temperature) k		1	
	Current setting value	I _n	1600 A	
	Test current			
		either k x 2.0 x I _n	./. A	./. A
	8.3.5.1	Test sequence II (I _{cs} = I _{cu})	before 8.3.4.1	
	8.3.5.1	Test sequence III	before 8.3.5.2	
	8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5		
8.3.7.4	Test sequence V	before 8.3.7.5		
8.3.8.1	Combined test sequence	before 8.3.8.2		
A.5	Verification of discrimination	before 8.3.5.2		
A.6.3	Verification of back-up protection	before 8.3.5.2		
	or k x 2.5 x I _n	4000 A	4000 A	
8.3.5.4	Test sequence II (I _{cs} = I _{cu})	after 8.3.4.5		
8.3.5.4	Test sequence III	after 8.3.5.3		
8.3.7.8	Test sequence V	after 8.3.7.7		
8.3.8.7	Combined test sequence	after 8.3.8.6		
A.5	Verification of discrimination	after 8.3.5.3		
A.6.3	Verification of back-up protection	after 8.3.5.3		
C.4	Individual pole short-circuit test sequence			
H.4	Test sequence for circuit-breakers for IT-systems			
	Tripping time (for twice the value of current setting on single pole)			
	Neutral	≤ 270 s	124 s	
	Ph ₁	≤ 270 s	130 s	
	Ph ₂	≤ 270 s	128 s	
	Ph ₃	≤ 270 s	126 s	

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM


Date August 19th 2006



TRF IEC 60947-2
Ed. 2.1 form 46
BANKO C
OPRIMHADA

ASEFA		Test report No.: F01.04.20 Page 43 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.10
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics Cable $.l$ mm ² 185 mm ² Bar 40 x 5 mm $.l$ x $.l$ mm Number 2 1 Length $.l$ mm 500 mm Tightening torque 50 Nm Reference temperature 40 °C ± 2 °C Ambient temperature 22 °C Correction factor ($k = 1$ for releases independent of ambient temperature) k 1 Current setting value I_n 630*0.4=252A Test current either $k \times 2.0 \times I_n$ 504 A 504 A	
8.3.5.1	Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1	
8.3.5.1	Test sequence III before 8.3.5.2	
8.3.6.1	Test sequence IV before 8.3.6.2	
8.3.6.6	Test sequence IV after 8.3.6.5	
8.3.7.4	Test sequence V before 8.3.7.5	
8.3.8.1	Combined test sequence before 8.3.8.2	
A.5	Verification of discrimination before 8.3.5.2	
A.6.3	Verification of back-up protection before 8.3.5.2	
	or $k \times 2.5 \times I_n$ $.l$ A $.l$ A	
8.3.5.4	Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5	
8.3.5.4	Test sequence III after 8.3.5.3	
8.3.7.8	Test sequence V after 8.3.7.7	
8.3.8.7	Combined test sequence after 8.3.8.6	
A.5	Verification of discrimination after 8.3.5.3	
A.6.3	Verification of back-up protection after 8.3.5.3	
C.4	Individual pole short-circuit test sequence	
H.4	Test sequence for circuit-breakers for IT-systems	
	Tripping time (for twice the value of current setting on single pole) Neutral ≤ 270 s Ph ₁ ≤ 270 s Ph ₂ ≤ 270 s Ph ₃ ≤ 270 s	
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC 60947-2 Ed. 2.1 form 45

Date August 19, 2005




207
212
225
230
235
240
245
250
255
260
265
270
275
280
285
290
295
300
305
310
315
320
325
330
335
340
345
350
355
360
365
370
375
380
385
390
395
400
405
410
415
420
425
430
435
440
445
450
455
460
465
470
475
480
485
490
495
500

ASEFA		Test report No.: F01.04.20 Page 44 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.10	
Standard and clause	Kind of tests and requirements	Test values Results	
8.3.5.2	RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY		
	Utilization category	B	
	Rated operational voltage U_e	415 V	
	Recovery voltage	$1.05 \times U_e$	435.75 V
	Rated ultimate short-circuit breaking capacity	I_{cu}	70 kA
	Rated short-circuit making capacity	I_{cm}	154 kA
Table 11	Power factor	0.20	0.20(+0,-0.05)
	Frequency	50 Hz	50 Hz
8.3.2.1	Control supply voltage	$0.85 \times U_s$./. V
7.2.1.1.3	Maximum value of the closing time		./ ms
	Sequence of operation	O - t - CO	O - t - CO
	Circuit diagram		Page 66
	Calibration of the test circuit	Pageform	Next page
	Safety area	Pageform	Page 65
	Installation of the material tested	Pageform	Page 64
	Energization direction	Top/Bottom	Top
8.3.2.1	Smallest individual enclosure (if applicable)		
	Type		./
	Kind of material		./
	Inside dimensions		
	Height		./ mm
	Width		./ mm
	Depth		./ mm
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	./ mm ²	./ mm ²
	Bar	40 x 5 mm	40 x 5 mm
	Number	2	2
	Length		
		supply side	./ mm
		load side	./ mm
	Tightening torque		50 Nm



Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM



Date August 19th 2009



IEC/EN 60947-2
form 47

BRUNO
 OPINIA
 2009


ASEFA		Test report No.: F01.04.20 Page 45 / 68
Type test according to: IEC 60947-2		Type: NS630bH to 1600H Sample 31042.10
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT Oscillogram Applied voltage Frequency RMS current value at 20 ms Average RMS. Value Peak current maximum value Power factor	 20040288-0003 20040288-0007 440.17 V 50 Hz 50 Hz i_1 70.21 kA i_2 70.99 kA i_3 69.51 kA 70.23 kA 156.12 kA 0,17
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		  Date August 19th 2009

ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 46 / 68
Standard and clause		Test values Results
	OPERATION "O" Oscillogram Peak current value i_1 i_2 i_3 Maximum total duration Recovery voltage (phase to phase or phase to neutral) $U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> Average value U_m Ratio between U_m and U_e U_m/U_e Joule integral Ph_1 Ph_2 Ph_3 Melting of the fusible element Yes/No Holes in the PE-sheet (if applicable) Yes/No Cracks observed Yes/No if Yes Time interval between operations 3 min	20040288.0013 122.69 kA 114.04 kA 69.83 kA 13,45 ms 443.07 V 443.52 V 443.19 V 443.26 V 1.06 75.29 (kA) ² s 67.36 (kA) ² s 20.94 (kA) ² s No No No Page ./. 3 min 3 min
	OPERATION "CO1" Oscillogram Applied voltage Peak current value i_1 i_2 i_3 Maximum total duration Recovery voltage (phase to phase or phase to neutral) $U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> Average value U_m Ratio between U_m and U_e U_m/U_e Joule integral Ph_1 Ph_2 Ph_3 Closing operation time Melting of the fusible element Yes/No Cracks observed Yes/No if Yes	20040288.0014 448.34 V 70.71 kA 109.66 kA 123.37 kA 14,4 ms 442.94 V 442.13 V 442.98 V 442.68 V 1.06 27.23 (kA) ² s 49.66 (kA) ² s 79.18 (kA) ² s ./ ms No No Page ./. ./ ms
7.2.1.1.3		
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		Date August 19th 2005  


ASEFA		Test report No.: F01.04.20
		Page 58 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.12
Standard and clause	Kind of tests and requirements	Test values Results
8.3.5.2	RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY	
	Utilization category	B
	Rated operational voltage U_e	690 V
	Recovery voltage	$1.05 \times U_e$ 724.5 V
	Rated ultimate short-circuit breaking capacity	I_{cu} 42 kA
	Rated short-circuit making capacity	I_{cm} 88.2 kA
Table 11	Power factor	0.25 0.25(+0,-0.05)
	Frequency	50 Hz 50 Hz
8.3.2.1	Control supply voltage	$0.85 \times U_e$./. V ./. V
7.2.1.1.3	Maximum value of the closing time	./.. ms
	Sequence of operation	O - t - CO O - t - CO
	Circuit diagram	Page 66
	Calibration of the test circuit	Pageform Next page
	Safety area	Pageform Page 65
	Installation of the material tested	Pageform Page 64
	Energization direction	Top/Bottom Bottom
8.3.2.1	Smallest individual enclosure (if applicable)	
	Type	./..
	Kind of material	./..
	Inside dimensions	
	Height	./.. mm
	Width	./.. mm
	Depth	./.. mm
60947-1	Cabling characteristics	
Table 9, 10 and 11	Cable	./.. mm ² ./.. mm ²
	Bar	100 x 5 mm 100 x 10 mm
	Number	2 1
	Length	supply side ./.. mm 500 mm
		load side ./.. mm 500 mm
	Tightening torque	50 Nm

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM


Date August 19th 2005



BRUNER C
OPHTHAMA

ASEFA		Test report No.: F01.04.20 Page 59 / 68	
Type test according to: IEC 60947-2		Type: NS630bH to 1600H Sample 31042.12	
Standard and clause	Kind of tests and requirements	Test values Results	
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT		
	Oscillogram	20040283-0141 20040283-0150	
	Applied voltage	735,65 V	
	Frequency	50 Hz	
	RMS current value at 20 ms	I_1	42.00 kA
		I_2	42.32 kA
		I_3	43.26 kA
	Average RMS. Value	42.49 kA	
	Peak current maximum value	91.48 kA	
Power factor	0,21		
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM			
		Date August 19th 2005	

ВНИОС
ОПТИМАЛ

ASEFA		Test report No.: F01.04.20 Page 60 / 68
Type test according to: IEC 60947-2. Test sequence III		Type: NS630bH to 1600H Sample 31042.12
Standard and clause	Kind of tests and requirements	Test values Results
	<p>OPERATION "O"</p> <p>Oscillogram</p> <p>Peak current value i_1 i_2 i_3</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average value</p> <p>Ratio between U_m and U_e</p> <p>Joule integral</p> <p>Melting of the fusible element</p> <p>Holes in the PE-sheet (if applicable)</p> <p>Cracks observed if Yes</p> <p>Time interval between operations</p>	<p>20040283.0161</p> <p>59.64 kA 71.74 kA 82.66 kA</p> <p>21.05 ms</p> <p>732.16 V 720.65 V 735.93 V</p> <p>729.58 V</p> <p>1.05</p> <p>22.48 (kA)²s 27.82 (kA)²s 43.40 (kA)²s</p> <p>Yes/No No Yes/No No Yes/No No</p> <p>Page ./.</p> <p>3 min 4 min</p>
	<p>OPERATION "CO1"</p> <p>Oscillogram</p> <p>Applied voltage</p> <p>Peak current value i_1 i_2 i_3</p> <p>Maximum total duration</p> <p>Recovery voltage (phase to phase or phase to neutral)</p> <p>Average value</p> <p>Ratio between U_m and U_e</p> <p>Joule integral</p> <p>Closing operation time</p> <p>Melting of the fusible element</p> <p>Cracks observed if Yes</p>	<p>20040283.0162</p> <p>764.24 V</p> <p>77.04 kA 49.95 kA 75.50 kA</p> <p>18.4 ms</p> <p>736.72 V 727.47 V 728.68 V</p> <p>730.96 V</p> <p>1.05</p> <p>36.63 (kA)²s 18.67 (kA)²s 31.43 (kA)²s</p> <p>./ ms</p> <p>Yes/No No Yes/No No</p> <p>Page ./.</p>
7.2.1.1.3		
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		 <p>IEC/EN 60947-2 Ed. 2.1 form A1</p> <p>Date August 19th 2005</p>

BREVET
 OPTIMISATION

ASEFA		Test report No.: F01.04.20 Page 61 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.12
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U _e , min. 1000 V	1380 V
8.3.3.5	Test sequence I	
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	1380 V
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 5 s

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM


Date August 19th 2005



BREVETÉ
 OPÉRATIONNEL

ASEFA		Test report No.: F01.04.20 Page 62 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.12
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	1.1 x U_o = 759 V 759 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (In new condition)	≤ 0.5 mA ./ mA
8.3.3.5	Test sequence I (after overload performance)	≤ 2 mA ./ mA
8.3.4.3	Test sequence II	≤ 2 mA ./ mA
8.3.5.3	Test sequence III	≤ 6 mA 0.5 mA
8.3.6.5	Test sequence IV	≤ 2 mA ./ mA
8.3.7.3	Test sequence V, stage 1	≤ 2 mA ./ mA
8.3.7.7	Test sequence V, stage 2	≤ 6 mA ./ mA
8.3.8.5	Combined test sequence	≤ 2 mA ./ mA
C.3	Individual pole short-circuit test sequence I_{su}	≤ 6 mA ./ mA
H.3	Individual pole short-circuit test sequence I_{IT}	≤ 6 mA ./ mA

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM




IEC/EN 60947-2
Ed. 2.1 form 25

Date August 18th 2005



BRUNNEN
OPINIA


ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 63 / 68
Type: NS630bH to 1600H Sample 31042.12		
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics	
	Cable $.l. \text{ mm}^2$	$.l. \text{ mm}^2$
	Bar 100 x 5 mm	100 x 5 mm
	Number 2	2
	Length $.l. \text{ mm}$	3000 mm
	Tightening torque	50 Nm
	Reference temperature $40 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$	
	Ambient temperature	19.9 °C
	Correction factor ($k = 1$ for releases independent of ambient temperature) k	1
	Current setting value I_n	1600 A
	Test current	
	either $k \times 2.0 \times I_n$ $.l. \text{ A}$	$.l. \text{ A}$
8.3.5.1	Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1	
8.3.5.1	Test sequence III before 8.3.5.2	
8.3.6.1	Test sequence IV before 8.3.6.2	
8.3.6.6	Test sequence IV after 8.3.6.5	
8.3.7.4	Test sequence V before 8.3.7.5	
8.3.8.1	Combined test sequence before 8.3.8.2	
A.5	Verification of discrimination before 8.3.5.2	
A.6.3	Verification of back-up protection before 8.3.5.2	
	or $k \times 2.5 \times I_n$ 4000 A	4000 A
8.3.5.4	Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5	
8.3.5.4	Test sequence III after 8.3.5.3	
8.3.7.8	Test sequence V after 8.3.7.7	
8.3.8.7	Combined test sequence after 8.3.8.6	
A.5	Verification of discrimination after 8.3.5.3	
A.6.3	Verification of back-up protection after 8.3.5.3	
C.4	Individual pole short-circuit test sequence	
H.4	Test sequence for circuit-breakers for IT-systems	
	Tripping time (for twice the value of current setting on single pole)	
	Neutral $\leq 270 \text{ s}$	120 s
	Ph ₁ $\leq 270 \text{ s}$	118 s
	Ph ₂ $\leq 270 \text{ s}$	127 s
	Ph ₃ $\leq 270 \text{ s}$	132 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		




Date August 19th 2005



BRUNO C. OPIRHALIA

ASEFA	Test report No.: F01.04.20 Page 64 / 68
Type test according to: IEC 60947-2 Test sequence III	Type: NS630bH to 1600H
<p><u>INSTALLATION</u></p> <p>The apparatus is set up on a metallic structure, in individual enclosure, fixed on insulated bars. The safety perimeter is materialised by a metallic enclosure (see next page) connected to the neutral by a fuse.</p> <p>The apparatus are operated with an air actuator.</p>	
Test laboratory: F01 GRENOBLE ASEFA recognized PLATFORM	TRF IEC EN 60947-2 Ed. form 70 Date August 19th 2005  




ASEFA		Test report No.: F01.04.20 Page : 65 / 68
Type test according to: IEC 60947-2		Type: NS630bH to 1600H
Standard and clause	Kind of tests and requirements	Test values Results
60947-2	<p>SAFETY AREA AND DETECTION OF THE FAULT CURRENT</p> <p>Characteristics of the metallic screen</p> <ul style="list-style-type: none"> - structure <ul style="list-style-type: none"> woven wire mesh ./. perforated metal ./. expanded metal Yes - ratio hole area / total area 0,45 - 0,65 ./. - size of hole $\leq 30 \text{ mm}^2$./. mm² - coating <ul style="list-style-type: none"> bare ./. conductive plating yes <div style="display: flex; justify-content: space-around; align-items: center;">   </div> <p>Detection of the fault current</p> <ul style="list-style-type: none"> - prospective fault current in the fusible element circuit 50 A - fusible element <ul style="list-style-type: none"> . diameter of copper wire 0.1 mm . length 100 mm or . equivalent fusible element / 	<p>Top : 120 mm</p> <p>Left : 10 mm</p> <p>Right : 10 mm</p> <p>Bottom : 120 mm</p> <p>Front : 0 mm</p> <p>Back : 0 mm</p>
	<p>Test laboratory: F01 GRENOBLE ASEFA recognized PLATFORM</p>	 <p style="text-align: right; font-weight: bold; transform: rotate(-45deg);"> KIMTEK-BOA TRF IEC 60947-2 Ed 2.1 form 170 Date August 19th 2005 </p>

ASEFA		Test report No.: F01.04.20 Page 47 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.10	
Standard and clause	Kind of tests and requirements	Test values Results	
	VERIFICATION OF DIELECTRIC WITHSTAND		
	Test voltage		
	2 x U ₀ , min. 1000 V	1000 V	
8.3.3.5	Test sequence I		
8.3.4.3	Test sequence II		
8.3.5.3	Test sequence III		1000 V
8.3.6.6	Test sequence IV		
8.3.7.3	Test sequence V, stage 1		
8.3.7.7	Test sequence V, stage 2		
8.3.8.5	Combined test sequence		
B.10.3.1	Test sequence B.II		
A.5	Verification of discrimination		
A.6.3	Verification of back-up protection		
C.3	Individual pole short-circuit test sequence		
H.3	Test sequence for circuit-breakers for IT-systems		
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)		
	Test duration	5 s	5 s

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM


Date August 19th 2000



BRUNO C. OPIJANA


ASEFA		Test report No.: F01.04.20 Page 48 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.10
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	$1.1 \times U_o = 457 \text{ V}$ 457 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (in new condition)	$\leq 0.6 \text{ mA}$./ mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$./ mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$./ mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ 0.05 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$./ mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$./ mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$./ mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$./ mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$./ mA
H.3	Individual pole short-circuit test sequence I_T	$\leq 6 \text{ mA}$./ mA
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		

Date August 19th 2005




ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 49 / 68
Type: NS630bH to 1600H Sample 31042.10		
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics Cable $.l. \text{ mm}^2$ 185 mm ² Bar 40 x 5 mm $.l. \times .l. \text{ mm}$ Number 2 1 Length $.l. \text{ mm}$ 500 mm Tightening torque 50 Nm Reference temperature 40 °C ± 2 °C Ambient temperature 20.6 °C Correction factor (k = 1 for releases independent of ambient temperature) k 1 Current setting value I_n 630*0.4=252A Test current either $k \times 2.0 \times I_n$ $.l. \text{ A}$ $.l. \text{ A}$	
8.3.5.1	Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1	
8.3.5.1	Test sequence III before 8.3.5.2	
8.3.6.1	Test sequence IV before 8.3.8.2	
8.3.6.6	Test sequence IV after 8.3.6.5	
8.3.7.4	Test sequence V before 8.3.7.5	
8.3.8.1	Combined test sequence before 8.3.8.2	
A.5	Verification of discrimination before 8.3.5.2	
A.6.3	Verification of back-up protection before 8.3.5.2	
	or $k \times 2.5 \times I_n$ 630 A 630 A	
8.3.5.4	Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5	
8.3.5.4	Test sequence III after 8.3.5.3	
8.3.7.8	Test sequence V after 8.3.7.7	
8.3.8.7	Combined test sequence after 8.3.8.6	
A.5	Verification of discrimination after 8.3.5.3	
A.6.3	Verification of back-up protection after 8.3.5.3	
C.4	Individual pole short-circuit test sequence	
H.4	Test sequence for circuit-breakers for IT-systems	
	Tripping time (for twice the value of current setting on single pole) Neutral ≤ 270 s 131 s Ph ₁ ≤ 270 s 136 s Ph ₂ ≤ 270 s 127 s Ph ₃ ≤ 270 s 127 s	
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		

Date August 19th 2005



BRUNO C.
CHATELAIN

ASEFA		Test report No.: F01.04.20 Page 50 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.11	
Standard and clause	Kind of tests and requirements	Test values Results	
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY		
60947-1 Table 9, 10 and 11	Cabling characteristics Cable $.l. \text{ mm}^2$ Bar 100 x 5 mm Number 2 Length $.l. \text{ mm}$ Tightening torque Reference temperature $40^\circ\text{C} \pm 2^\circ\text{C}$ Ambient temperature Correction factor ($k = 1$ for releases independent of ambient temperature) k Current setting value I_n		$.l. \text{ mm}^2$ 100 x 5 mm 2 500 mm 60 Nm 22 °C 1 1600 A
	Test current		
	either $k \times 2.0 \times I_n$	3200 A	3200 A
8.3.5.1	Test sequence II ($I_{cs} = I_{cu}$)	before 8.3.4.1	
8.3.5.1	Test sequence III	before 8.3.5.2	
8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5	
8.3.7.4	Test sequence V	before 8.3.7.5	
8.3.8.1	Combined test sequence	before 8.3.8.2	
A.5	Verification of discrimination	before 8.3.5.2	
A.6.3	Verification of back-up protection	before 8.3.5.2	
	or $k \times 2.5 \times I_n$	$.l. A$	$.l. A$
8.3.5.4	Test sequence II ($I_{cs} = I_{cu}$)	after 8.3.4.5	
8.3.5.4	Test sequence III	after 8.3.5.3	
8.3.7.8	Test sequence V	after 8.3.7.7	
8.3.8.7	Combined test sequence	after 8.3.8.6	
A.5	Verification of discrimination	after 8.3.5.3	
A.6.3	Verification of back-up protection	after 8.3.5.3	
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		
	Tripping time (for twice the value of current setting on single pole)		
	Neutral	$\leq 270 \text{ s}$	228 s
	Ph ₁	$\leq 270 \text{ s}$	204 s
	Ph ₂	$\leq 270 \text{ s}$	215 s
	Ph ₃	$\leq 270 \text{ s}$	226 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM			
		Date August 19th 2005	




KINTEX-BROUWERIE
 OEd 2-1 totm 46

ASEFA		Test report No.: F01.04.20 Page 51 / 68		
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.11		
Standard and clause	Kind of tests and requirements	Test values Results		
8.3.5.2	RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY			
	Utilization category	B		
	Rated operational voltage U_e	440 V		
	Recovery voltage	$1.05 \times U_e$	462 V	
	Rated ultimate short-circuit breaking capacity	I_{cu}	65 kA	
	Rated short-circuit making capacity	I_{cm}	143 kA	
	Table 11	Power factor	0.20	0.20
		Frequency	50 Hz	50 Hz
	8.3.2.1	Control supply voltage	$0.85 \times U_s$./. V	./ . V
	7.2.1.1.3	Maximum value of the closing time		./ ms
	Sequence of operation	O - t - CO	O - t - CO	
	Circuit diagram		Page 66	
	Calibration of the test circuit	Pageform	Next page	
	Safety area	Pageform	Page 65	
	Installation of the material tested	Pageform	Page 64	
	Energization direction	Top/Bottom	Top	
8.3.2.1	Smallest Individual enclosure (if applicable)			
	Type		./	
	Kind of material		./	
	Inside dimensions			
	Height		./ mm	
	Width		./ mm	
	Depth		./ mm	
60947-1	Cabling characteristics			
Table 9, 10 and 11	Cable	./ mm ²	./ mm ²	
	Bar	100 x 5 mm	100 x 10 mm	
	Number	2	1	
	Length	supply side ./ mm	350 mm	
		load side ./ mm	350 mm	
	Tightening torque		50 Nm	

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM


Date August 19th 2008




BSPAG & OPTIMATA

ASEFA		Test report No.: F01.04.20 Page 52 / 68
Type test according to: IEC 60947-2		Type: NS630bH to 1600H Sample 31042.11
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT	
	Oscillogram	20040288-0015 20040288-0018
	Applied voltage	474.23 V
	Frequency	50 Hz
	RMS current value at 20 ms	i_1 66.54 kA i_2 66.80 kA i_3 64.32 kA
	Average RMS. Value	65.89 kA
	Peak current maximum value	139.08 kA
	Power factor	0,17
	Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM	

Date August 19th 2008




BRANCIA
OPINIA

ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 53 / 68
Standard and clause		Type: NS630bH to 1600H Sample 31042.11
Standard and clause	Kind of tests and requirements	Test values Results
	OPERATION "O"	
	Oscillogram	20040288.0019
	Peak current value	i_1 113.30 kA
		i_2 100.34 kA
		i_3 73.62 kA
	Maximum total duration	14.5 ms
	Recovery voltage	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 466.08 V
	(phase to phase or phase to neutral)	$U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 466.46 V
		$U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 466.07 V
	Average value	U_{rm} 466.21 V
	Ratio between U_{rm} and U_0	U_{rm}/U_0 1.05
	Joule integral	Ph ₁ 65.85 (kA) ² s
		Ph ₂ 51.57 (kA) ² s
		Ph ₃ 20.68 (kA) ² s
	Melting of the fusible element	Yes/No No
	Holes in the PE-sheet (if applicable)	Yes/No No
	Cracks observed	Yes/No No
	If Yes	Page ./.
	Time interval between operations	3 min 3 min
	OPERATION "CO1"	
	Oscillogram	20040288.0020
	Applied voltage	474.53 V
	Peak current value	i_1 109.61 kA
		i_2 97.03 kA
		i_3 77.15 kA
	Maximum total duration	20.25 ms
	Recovery voltage	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 468.37 V
	(phase to phase or phase to neutral)	$U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 468.39 V
		$U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 468.21 V
	Average value	U_{rm} 468.32 V
	Ratio between U_{rm} and U_0	U_{rm}/U_0 1.06
	Joule Integral	Ph ₁ 59.66 (kA) ² s
		Ph ₂ 47.00 (kA) ² s
		Ph ₃ 22.24 (kA) ² s
7.2.1.1.3	Closing operation time	./ ms
	Melting of the fusible element	Yes/No No
	Cracks observed	Yes/No No
	If Yes	Page ./.
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		Date August 19th 2005

ASEFA
 CERTIFIED
 PLATFORM

ASEFA		Test report No.: F01.04.20 Page 54 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.11
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U_n , min. 1000 V	1000 V
8.3.3.5	Test sequence I	
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	1000 V
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage - Main circuit of the circuit-breaker - Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 5 s

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM




Ed. 2.1 form

Date August 19th 2005

modified

BRUNO C
OPINIA

ASEFA		Test report No.: F01.04.20 Page 54 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.11
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U _n , min. 1000 V	1000 V
8.3.3.5	Test sequence I	1000 V
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 6 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		Date August 18th 2005

ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 55 / 68
Type: NS630bH to 1600H Sample 31042.11		
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	$1.1 \times U_o = 484 \text{ V}$ 484 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (in new condition)	$\leq 0.5 \text{ mA}$./ mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$./ mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$./ mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ 0.5 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$./ mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$./ mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$./ mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$./ mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$./ mA
H.3	Individual pole short-circuit test sequence I_T	$\leq 6 \text{ mA}$./ mA



Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
Ed. 2.1 form 25


Date August 19th 2005

БЕЛГАРСКА
ОПШТИНА

ASEFA		Test report No.: F01.04.20		
Type test according to: IEC 60947-2 Test sequence III		Page 56 / 68		
Standard and clause		Test values Results		
VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY				
60947-1 Table 9, 10 and 11	Cabling characteristics			
	Cable	./. mm ²	./. mm ²	
	Bar	100 x 5 mm	100 x 5 mm	
	Number	2	2	
	Length	./. mm	500 mm	
	Tightening torque		50 Nm	
	Reference temperature	40 °C ± 2 °C		
	Ambient temperature		18.4 °C	
	Correction factor (k = 1 for releases independent of ambient temperature) k		1	
	Current setting value	I _n	1600 A	
	Test current			
		either k x 2.0 x I _n	./. A	./. A
	8.3.5.1	Test sequence II (I _{cs} = I _{cu})	before 8.3.4.1	
	8.3.5.1	Test sequence III	before 8.3.5.2	
	8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5		
8.3.7.4	Test sequence V	before 8.3.7.5		
8.3.8.1	Combined test sequence	before 8.3.8.2		
A.5	Verification of discrimination	before 8.3.5.2		
A.6.3	Verification of back-up protection	before 8.3.5.2		
	or k x 2.5 x I _n	4000 A	4000 A	
8.3.5.4	Test sequence II (I _{cs} = I _{cu})	after 8.3.4.5		
8.3.5.4	Test sequence III	after 8.3.5.3		
8.3.7.8	Test sequence V	after 8.3.7.7		
8.3.8.7	Combined test sequence	after 8.3.8.6		
A.5	Verification of discrimination	after 8.3.5.3		
A.6.3	Verification of back-up protection	after 8.3.5.3		
C.4	Individual pole short-circuit test sequence			
H.4	Test sequence for circuit-breakers for IT-systems			
	Tripping time (for twice the value of current setting on single pole)			
	Neutral	≤ 270 s	137 s	
	Ph ₁	≤ 270 s	136 s	
	Ph ₂	≤ 270 s	132 s	
	Ph ₃	≤ 270 s	134 s	

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005



ВНИМАНИЕ
3
08.12.05

ASEFA		Test report No.: F01.04.20	
Type test according to: IEC 60947-2 Test sequence III		Page 57 / 68	
Standard and clause		Test values Results	
VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY			
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	.I. mm ²	.I. mm ²
	Bar	100 x 5 mm	100 x 5 mm
	Number	2	2
	Length	.I. mm	500 mm
	Tightening torque		50 Nm
	Reference temperature	40 °C ± 2 °C	
	Ambient temperature		22.5 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k		1
	Current setting value	I _n	1600 A
	Test current		
		either k x 2.0 x I _n	3200 A
	8.3.5.1	Test sequence II (I _{cs} = I _{cu}) before 8.3.4.1	
	8.3.5.1	Test sequence III before 8.3.5.2	
	8.3.6.1	Test sequence IV before 8.3.6.2	
8.3.6.6	Test sequence IV after 8.3.6.5		
8.3.7.4	Test sequence V before 8.3.7.5		
8.3.8.1	Combined test sequence before 8.3.8.2		
A.5	Verification of discrimination before 8.3.5.2		
A.6.3	Verification of back-up protection before 8.3.5.2		
	or k x 2.5 x I _n	.I. A	
8.3.5.4	Test sequence II (I _{cs} = I _{cu}) after 8.3.4.5		
8.3.5.4	Test sequence III after 8.3.5.3		
8.3.7.8	Test sequence V after 8.3.7.7		
8.3.8.7	Combined test sequence after 8.3.8.6		
A.5	Verification of discrimination after 8.3.5.3		
A.6.3	Verification of back-up protection after 8.3.5.3		
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		
Tripping time (for twice the value of current setting on single pole)			
	Neutral	≤ 270 s	
	Ph ₁	≤ 270 s	
	Ph ₂	≤ 270 s	
	Ph ₃	≤ 270 s	
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Ed. 2.1 form 46	

Date August 19th 2008



Handwritten signature and date: 12.08.2008

ASEFA


Test report No.: F01.04.20
Page : 66 / 68

Type test according to: IEC 60947-2


Type: NS630bH to 1600H

DIAGRAM OF THE TEST CIRCUIT

TEST OF RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY



VERIFICATION OF OPERATIONAL CAPABILITY




Test laboratory: F01 - GRENOBLE
ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
Ed 2.1 form 170

Date August 18th 2005

WITTEK 1004
0 012129



ASEFA

Test report No.: F01.04.20
Page : 68 / 68

Type test according to: IEC 60947-2
Test sequence III

Type: NS630bH to 1600H

APPENDIXES

APPARATUS CHARACTERISTICS

General view circuit-breaker
Tripping curve Micrologic 5.0A

GHD 1189100 Indice B
51156273AA 1/1

OSCILLOGRAMS


Calibration voltage	20040283 - 0102
Calibration current	20040283 - 0103
ASEFA 31 042.05 Opening	20040283 - 0104
ASEFA 31 042.05 Closing/Opening 1	20040283 - 0105
ASEFA 31 042.06 Opening	20040283 - 0106
ASEFA 31 042.06 Closing/Opening 1	20040283 - 0107
Calibration voltage	20040283 - 0108
Calibration current	20040283 - 0113
ASEFA 31 042.07 Opening	20040283 - 0116
ASEFA 31 042.07 Closing/Opening 1	20040283 - 0117
Calibration voltage	20040283 - 0119
Calibration current	20040283 - 0122
ASEFA 31 042.08 Opening	20040283 - 0123
ASEFA 31 042.08 Closing/Opening 1	20040283 - 0124
Calibration voltage	20040288 - 0003
Calibration current	20040288 - 0007
ASEFA 31 042.09 Opening	20040288 - 0011
ASEFA 31 042.09 Closing/Opening 1	20040288 - 0012
ASEFA 31 042.10 Opening	20040288 - 0013
ASEFA 31 042.10 Closing/Opening 1	20040288 - 0014
Calibration voltage	20040288 - 0015
Calibration current	20040288 - 0018
ASEFA 31 042.11 Opening	20040288 - 0019
ASEFA 31 042.11 Closing/Opening 1	20040288 - 0020
Calibration voltage	20040283 - 0141
Calibration current	20040283 - 0150
ASEFA 31 042.12 Opening	20040283 - 0161
ASEFA 31 042.12 Closing/Opening 1	20040283 - 0162

Test laboratory: F01 - GRENOBLE
ASEFA recognised PLATFORM


TRF IEC/EN 60947-2
Ed 2, Form 170

Date August 19th 2005


WITHDRAWN
30/08/2005



GENERAL VIEW - FIGURE 1



ВЪВЕДЕНА
ОРИГИНАЛНА
КОПИЯ



OFF (1)	In (A)	600	2000	4000	5000	6300
N1		42				
H1						
H2			82			
H3						
L1						


02	09/06/99	Rajout des crans 0 à 0,4	JOUBERT	GRELIER	
Ind / Rev	Date / Date	Modification / Modification	Nom/Name	Visa	Archiv / Microf
Projet / Projet: Compact NS630b à NS1600		Code diff. / Distrib. code		DISJONCTEUR FIXE ET DEBROCHABLE	
Dossier / Folder:		Unité / Département: DBTP		Courbe de déclenchement pour déclencheurs Micrologie 5.0, 6.0, 7.0	
GROUPE SCHNEIDER		5,1,1,5,6,2,7			

12,00 ms/cm
150,00 ms
10,00 ms

450,00 ms

Calibration of the test circuit current

42KA 88KA 236V+5% COS0.25



U12
399.00 V/cm



СЕРВИС ЦЕНТРАЛЬ
КМТЕХ

F01 20040283 - 0102

Effectué le 06/12/2004 17:12:28
Edité le 06/12/2004 17:53:53


150.00 ms
12.00 ms/cm

10.00 ms

450.00 ms

Calibration of the test circuit V

42kA 88kV 236V +5% cosφ.25



**ВЕРНО
С ОРИЖИНАЛОМ**

F01 20040283 - 0103


Effectué le 06/12/2004 17:28:35
Ecrité le 06/12/2004 17:32:59

150.00 ms
12.00 ms/cm
10.00 ms

450.00 ms

O ASEFA 31042 Sample05

42kA 88kA 236V+5% COS0.25



U12 399.00 V/cm



СЕРВИСНИ ООД БУТАК
СЕРВИСНИ ООД БУТАК

F01 20040283 - 0104

150,00 ms


12,00 ms/cm

10,00 ms

450,00 ms

CO ASEFA 31042 Sample 05

42kA 88kA 236V+5% cos0.25



U12

399,00 V/cm



CĂMĂRA DE ÎNDRĂGĂȘIRE
ȘIPIHO C
 CĂMĂRA DE ÎNDRĂGĂȘIRE

F01 20040283 - 0105


Effectué le 06/12/2004 18:03:36
 Edité le 06/12/2004 18:09:46

8.00 ms/cm
20.00 ms
10.00 ms

220.00 ms

O ASEFA 31042 Sample 05

42kA 88kA 235V+5% COS0.25



U12
399.00 V/cm



ВРНО С
ОПРЕДЕЛЕНА

F01 20040283 - 0106

Effectué le 06/12/2004 19:07:47
Edité le 06/12/2004 19:12:55

12.00 ms/cm


120.00 ms

10.00 ms

420.00 ms

CO ASEFA 31042 Sample 06

42KA 88KA 236V+5% COS0.25



U12
399.00 V/cm



ВАРНО С
КАТЕ В. 15
15.03.2004

F01 · 20040283 - 0107


Effectué le 06/12/2004 19:11:09
Edité le 06/12/2004 19:12:06

12,00 ms/cm
100,00 rms
10,00 ms

400,00 rms

Calibr. test circuit voltage

cir mono: 39KA 82KA 254V+5% COSφ.25



**BRNO C
OPRAVA**

CATIE V.1.5.3.129 page 001

F01 20040283 - 0108

Effectué le 07/12/2004 07:59:18
Edité le 18/08/2005 11:17:08

8.00 ms/cm


200.00 ms

10.00 ms

400.00 ms

Calibr. test circuit I

cir mono: 39kA 82kA 254V+5% cos0.25



19.95 kA/cm



ВЕРНО С
ОРИГИНАЛ

CATE V.1.5.3.129 page 001

F01 20040283 - 0113

Effectué le 07/12/2004 08:47:42
Edité le 18/08/2005 11:18:12

8,00 ms/cm


200,00 ms

10,00 ms

O ASEFA : N° 31042 sample N° 7

clt mono: 39kA 82kA 254V+5% cos0.25

400,00 ms



U1 19,95 kA/cm

U12 198,00 V/cm



07/12/2004 09:08:11
 Edité le 18/08/2005 11:18:54


F01 20040283 - 0116

8,00 ms/cm
200,00 ms
10,00 ms

400,00 ms

CO ASEFA : N° 31042 sample N° 7

cir mono: 39kA 82kA 254V+5% COS0.25



U1
19,96 kA/cm

U12
198,00 V/cm



[Handwritten signature]
CO ASEFA

F01 20040283 - 0117

Effectué le 07/12/2004 09:10:47
Edité le 18/08/2005 11:18:45