



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

3.3 - Fuse holder

25 Introduction / extraction manual operations.

3.4 - Measure of the resistance of the main circuit under 100 Adc

4 - TEST CONDITIONS

5 - TESTS RESULTS

| No of operating sequences | 0 | 1000 | 2000 |
|---------------------------|----|------|------|
| Pole A ($\mu\Omega$) | 35 | 34 | 37 |
| Pole B ($\mu\Omega$) | 33 | 34 | 35 |
| Pole C ($\mu\Omega$) | 35 | 36 | 38 |

During the 2000 operating cycles no malfunction as been detected in the switch disconnecter.



ВЪВЕДЕН
ОРИГИНАЛ



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

TEST REPORT
No. MT.00.3.C.098.I

Prefabricated panel Fluofix GC with SF6 three position switch disconnecter type ISFG

Lightning Impulse Voltage Test
Power Frequency Voltage Test

Test regulations applied:

IEC 298 (1990).
IEC 694 (1980).

Tests results:

The prefabricated panel Fluofix GC passed the Tests.

Date of tests: June 20th, 2000.

Tests performed by:

Manuel Martins

The laboratory chief

Rui Cardoso

| | | | | |
|------------------|---------|--|-----------------------|-------------|
| Date: 2000-07-14 | DI / RD | | T. R. MT.00.3.C.098.I | Page 1 / 25 |
|------------------|---------|--|-----------------------|-------------|

MT.00.3.C.098.I





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

1 - TECHNICAL DATA OF SWITCHGEAR

Prefabricated panel

Type: Fluofix GC

Serial no.: -

Rated voltage: 24 kV

Rated current: 630 A

Rated power-frequency withstand voltage: 50 / 60 kV

Rated lightning impulse withstand voltage: 125 / 145 kVp

Rated peak withstand current: 40 kAp

Rated short-time withstand current: 16 kA / 3 s

Rated frequency: 50 Hz

Drawing on page 7

With SF6 rotary three position switch disconnecter

Type: ISFG

Serial no.: -

Rated voltage: 24 kV

Rated current: 630 A

Rated power-frequency withstand voltage: 50 / 60 kV

Rated lightning impulse withstand voltage: 125 / 145 kVp

Breaking capacity:

Active charge: 630 A

No-load transformer: 1250 kVA

No-load cables: 16 A

Closing capacity: 40 kAp

Rated short-time withstand current: 16 kA / 3 s

Rated peak withstand current: 40 kAp

Rated frequency: 50 Hz

SF6 pressure (20 °C): 0.3 bar rel.

2 - MANUFACTURER

EFACEC, Medium Voltage Switchgear Division

3 - TEST PERFORMED

Lightning Impulse Voltage Test at 125 / 145 kVp, 1.2 / 50 μ s.

Power Frequency Voltage Test at 50 / 60 kV, 1 minute.

Note: This test report refers to tests performed within the procedure of the partial discharge tests according to IEC 298, sub-clause 6.1.9, specified on the test report n° MT.00.3.C.089.I.

Date: 2000-07-14 | DI / RD | *[Signature]* | T. R. MT.00.3.C.098.I | Page 2 / 25

БРИОС
ОПШНУЛА





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

4 - TEST CONDITIONS

Tests performed according circuit diagrams on page 6.

5 - TESTS RESULTS

According figure on page 5:

5.1 - Switch disconnectors closed

(Test to earth and between phases)

| Voltage Applied To | Connected to earth | Impulses / flashovers + | Impulses / flashovers - | Applied Voltage \pm kVp 1.2/50 μ s | Result | Oscillogram on page | Power frequency voltage kV / 1 minute | Result |
|--------------------|--------------------|-------------------------|-------------------------|--|--------|---------------------|---------------------------------------|--------|
| Aaa' | BCbcb'c'F | 15 / 0 | 15 / 0 | 125 | Passed | 8 | 50 | Passed |
| Bbb' | ACaca'c'F | 15 / 0 | 15 / 0 | 125 | Passed | 9 | 50 | Passed |
| Ccc' | ABaba'b'F | 15 / 0 | 15 / 0 | 125 | Passed | 10 | 50 | Passed |

5.2 - Switch disconnector S1 open, S2 and S3 closed

(Test to earth and between phases)

| Voltage Applied to | Connected to earth | Impulses / flashovers + | Impulses / flashovers - | Applied Voltage \pm kVp 1.2/50 μ s | Result | Oscillogram on page | Power frequency voltage kV / 1 minute | Result |
|--------------------|--------------------|-------------------------|-------------------------|--|--------|---------------------|---------------------------------------|--------|
| A | BCabea'b'c'F | 15 / 0 | 15 / 0 | 125 | Passed | 11 | 50 | Passed |
| B | ACabca'b'c'F | 15 / 0 | 15 / 0 | 125 | Passed | 12 | 50 | Passed |
| C | ABabca'b'c'F | 15 / 0 | 15 / 0 | 125 | Passed | 13 | 50 | Passed |

5.3 - Switch disconnector S1 and S3 open, S2 closed

(Test to earth and between phases)

| Voltage Applied to | Connected to earth | Impulses / flashovers + | Impulses / flashovers - | Applied Voltage \pm kVp 1.2/50 μ s | Result | Oscillogram on page | Power frequency voltage kV / 1 minute | Result |
|--------------------|--------------------|-------------------------|-------------------------|--|--------|---------------------|---------------------------------------|--------|
| a | bcABCa'b'o'F | 15 / 0 | 15 / 0 | 125 | Passed | 14 | 50 | Passed |
| b | acABCa'b'c'F | 15 / 0 | 15 / 0 | 125 | Passed | 15 | 50 | Passed |
| c | abABCa'b'c'F | 15 / 0 | 15 / 0 | 125 | Passed | 16 | 50 | Passed |

Date: 2000-07-14 | DI / RD | T. R. MT.00.3.C.098.I | Page 3 / 25

ВЪПРОС
ОПРАШЕНА





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

5.4 - Switch disconnector S1 open, S2 and S3 closed

(Test across the Isolating distance)

| Voltage Applied to | Connected to earth | Impulses / flashovers + | Impulses / flashovers - | Applied Voltage \pm kVp 1.2/50 μ s | Result | Oscillogram on page | Power frequency voltage kV / 1 minute | Result |
|--------------------|--------------------|-------------------------|-------------------------|--|--------|---------------------|---------------------------------------|--------|
| A | aa' | 15 / 0 | 15 / 0 | 145 | Passed | 17 | 60 | Passed |
| B | bb' | 15 / 0 | 15 / 0 | 145 | Passed | 18 | 60 | Passed |
| C | cc' | 15 / 0 | 15 / 0 | 145 | Passed | 19 | 60 | Passed |

5.5 - Switch disconnector S1 and S3 open, S2 closed

(Test across the Isolating distance)


| Voltage Applied to | Connected to earth | Impulses / flashovers + | Impulses / flashovers - | Applied Voltage \pm kVp 1.2/50 μ s | Result | Oscillogram on page | Power frequency voltage kV / 1 minute | Result |
|--------------------|--------------------|-------------------------|-------------------------|--|--------|---------------------|---------------------------------------|--------|
| a | Aa' | 15 / 0 | 15 / 0 | 145 | Passed | 20 | 60 | Passed |
| b | Bb' | 15 / 0 | 15 / 0 | 145 | Passed | 21 | 60 | Passed |
| c | Cc' | 15 / 0 | 15 / 0 | 145 | Passed | 22 | 60 | Passed |

5.6 - Switch disconnector S1 and S3 closed on earth position, S2 closed on service position

(Test to earth and between phases)

| Voltage applied to | Connected to earth | Impulses / flashovers + | Impulses / flashovers - | Applied Voltage \pm kVp 1.2/50 μ s | Result | Oscillogram on page | Power frequency voltage kV / 1 minute | Result |
|--------------------|--------------------|-------------------------|-------------------------|--|--------|---------------------|---------------------------------------|--------|
| a | bcF | 15 / 0 | 15 / 0 | 125 | Passed | 23 | 50 | Passed |
| b | acF | 15 / 0 | 15 / 0 | 125 | Passed | 24 | 50 | Passed |
| c | abF | 15 / 0 | 15 / 0 | 125 | Passed | 25 | 50 | Passed |


Date: 2000-07-14 DI / RD *[Signature]* T. R. MT.00.3.C.098.I 4 / 25





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION



| | | | |
|------------------|----------------------------|-----------------------|-------------|
| Date: 2000-07-14 | DI / RD <i>[Signature]</i> | T. R. MT.00.3.C.098.I | Page 5 / 25 |
|------------------|----------------------------|-----------------------|-------------|

ВІДП. С
С. П. П. П. П. П.







EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

- Lightning Impulse Voltage Test



- Power Frequency Voltage Test



Prefabricated panel Fluofix GC

| | | | | |
|------------------|---------|--|-----------------------|-------------|
| Date: 2000-07-14 | DI / RD | | T. R. MT.00.3.C.098.I | Page 6 / 25 |
|------------------|---------|--|-----------------------|-------------|


БҮЛӨГ
ОПШНАА





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION



Date: 2000-07-14 | DI / RD | *[Signature]* | T. R. MT.00.3.C.098.I | Page 7 / 25



ВАРНО
ОРГАН





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION



| | | | | |
|------------------|---------|--|-----------------------|-------|
| Date: 2000-07-14 | DI / RD | | T. R. MT.00.3.C.098.I | 08/25 |
|------------------|---------|--|-----------------------|-------|



ВЕРИТЕ СЯ
ОРИГИНАЛ





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION






ВАЖНО С
ОБЯЗКА



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION





ВІСНОВОК
ОПТИМІЗАЦІЯ



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION





ВЪРНО С
ОПРИМАНА



EFACEC ENERGY



MEDIUM VOLTAGE SWITCHGEAR DIVISION





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION



| | | | | |
|------------------|-------|--------------------|-----------------------|------------|
| Date: 2000-07-14 | DI/RD | <i>[Signature]</i> | T. R. MT.00.3.C.098.1 | 0900-13/25 |
|------------------|-------|--------------------|-----------------------|------------|

0900-13/25






EFACEC ENERGY


MEDIUM VOLTAGE SWITCHGEAR DIVISION

15 Lightning impulses - / 125 kV 1,2 / 50 μ s



No. 1
 CH1: LI
 U_p : -124.7kV
 T₁ : 1.11 μ s
 T₂ : 47.95 μ s
 HVDiv: 283.9
 Trigger: Int.
 Magnifier: 1
 CH2: OFF

16 Lightning Impulses + / 125 kV 1,2 / 50 μ s



No. 16
 CH1: LI
 U_p : 124.7kV
 T₁ : 1.13 μ s
 T₂ : 48.27 μ s
 HVDiv: 283.9
 Trigger: Int.
 Magnifier: 1
 CH2: OFF





ВАРЪС С
ОПШЕНА



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION





ВАРНО С
ОПРЕДЕЛЕНИЕ



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION



| | | | | |
|------------------|---------|--------------------|-----------------------|-------|
| Date: 2000-07-14 | DI / RD | <i>[Signature]</i> | T. R. MT.00.3.C.098.1 | 16/25 |
|------------------|---------|--------------------|-----------------------|-------|




МОНІТОРИНГ
2000-07-16





EFACEC ENERGY



MEDIUM VOLTAGE SWITCHGEAR DIVISION





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION






ВЕРИТЕЛНО
С ДАТУМ





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION






ВНИМАНИЕ
ОПТИМАЛ



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION





RECEIVED
09/08/2000




EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION






ОПТИМАЛ
СЕРВИС





EFACEC ENERGY




MEDIUM VOLTAGE SWITCHGEAR DIVISION





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION





EFACEC ENERGY
MEDIUM VOLTAGE SWITCHGEAR DIVISION

TEST REPORT
No. MT983086

Prefabricated panel Fluofix GC with SF6 three position switch disconnecter ISFG

Mechanical Tests

Test regulations applied:

IEC 129 (1984)
IEC 265-1 (1983)
IEC 694 (1980)

Tests results:


The prefabricated panel Fluofix GC passed the Tests.


Date of tests: 3 to 8 October, 1998.

Tests performed by:



Manuel Martins

The laboratory chief


Rui Cardoso



| | | | |
|----------------|---------|----------------|------------|
| Date: 98.11.04 | MT / GQ | T. R. MT983086 | Page 1 / 3 |
|----------------|---------|----------------|------------|





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

4.2 - Earth position

1000 close / open manual operations.

4.3 - Fuse holder

25 introduction / extraction manual operations.

4.4 - Measure of the resistance of the main circuit under 100 Adc

5 - TEST CONDITIONS

6 - TESTS RESULTS

| No of operating sequences | 0 | 1000 |
|---------------------------|----|------|
| Pole A ($\mu\Omega$) | 34 | 33 |
| Pole B ($\mu\Omega$) | 32 | 30 |
| Pole C ($\mu\Omega$) | 31 | 31 |

During the 1000 operating cycles no malfunction as been detected in the switch disconnecter.



EFACEC ENERGY
MEDIUM VOLTAGE SWITCHGEAR DIVISION

TEST REPORT
No. MT983088

Ring Main Unit Fluofix GC with SF6 three position switch disconnecter type ISFG

Gas tightness test

Test regulations applied:

IEC 298 (1990).

Tests results:

The Ring Main Unit Fluofix GC passed the Tests.

Date of tests: 16th and 18th September, 3rd and 8th of October 1998

Tests performed by:


Manuel Martins

The laboratory chief

Rui Cardoso

| | | | | |
|----------------|---------|--|----------------|--------|
| Date: 98.11.04 | MT / GQ | | T. R. MT983088 | Page 1 |
|----------------|---------|--|----------------|--------|

REPRODUCTION
PROHIBITED





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

1 - TECHNICAL DATA OF SWITCHGEAR

Ring Main Unit

Type: Fluofix GC
Serial no.: -
Rated voltage: 24 kV
Rated current: 630 A
Rated power-frequency withstand voltage: 50 / 60 kV
Rated lightning impulse withstand voltage: 125 / 145 kVp
Rated peak withstand current: 40 kAp
Rated short-time withstand current: 16 kA / 3 s
Rated frequency: 50 Hz
Sealed pressure system
SF6 pressure (20 °C): 0.3bar rel.

With SF6 rotary three position switch disconnecter


Type: ISFG
Serial no.: -
Rated voltage: 24 kV
Rated current: 630 A
Rated power-frequency withstand voltage: 50 / 60 kV
Rated lightning impulse withstand voltage: 125 / 145 kVp
Breaking capacity:
 Active charge: 630 A
 No-load transformer: 1250 kVA
 No-load cables: 16 A
Closing capacity: 40 kAp
Rated short-time withstand current: 16 kA / 3 s
Rated peak withstand current: 40 kAp
Rated frequency: 50 Hz

2 - MANUFACTURER

EFACEC, Medium Voltage Switchgear Division

3 - TEST PERFORMED

Gas tightness test.
SF6 gas cumulative leakage measurement.



| | | | |
|----------------|----------------------------|----------------|--------|
| Date: 98.11.04 | MT / GQ <i>[Signature]</i> | T. R. MT983088 | Page 2 |
|----------------|----------------------------|----------------|--------|

Stamp:
KIMTEX S.P.A.
Via ...
00100 Roma



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

4 - TEST CONDITIONS

Service gas: sulphur hexafluoride (SF6)

Test gas: SF6

SF6 pressure: 0.3bar (rated)

Meter type: electron capture detector with H type sinter capable of the following sensitivities:

For SF6 gas sniffing test: $1 \times 10^{-8} \text{ cm}^3 / \text{s}$

For SF6 gas cumulative leakage measurement: 0,01 ppm

The Fluofix GC main structure is a common welded steel tank, filled with sulphur hexafluoride (SF6) at 0.3 bar relative. Inside the tank are located the ISFG three-position switch disconnectors and the busbars. According to IEC test regulation 298 annex GG, the following calculations were made:

Concerning formulae:

$$T = \frac{(Pr - Pm) * Vol}{Fp * 365 * 24 * 60 * 60} \text{ years}$$

$$Fp = \frac{(Pr - Pm) * Vol}{T} \text{ bar.cm}^3/\text{s}$$

$$Frel = \frac{Fp * 365 * 24 * 60 * 60 * 100}{(Pr + 1) * Vol} \%/\text{year}$$

$$Frel = \frac{(Pr - Pm) * 100}{(Pr + 1) * T} \%/\text{year}$$

Where Pr (rated filling pressure) = 0,3 bar
Pm (minimum functional pressure) = 0,1 bar

For each Fluofix GC configuration, the values of the maximum permissible leakage rate (Fp) and relative leakage rate (Frel) were calculated for an estimated lifespan (T) of 30 years:

| Fluofix GC Configuration | Fluofix SF6 volume (cm ³) | Fp (bar*cm ³ /s) | Frel (%/year) |
|--------------------------|---------------------------------------|-----------------------------|---------------|
| 2IS + 1CIS | 426,5 x 10 ³ | 9,0 x 10 ⁻⁵ | 0,51 |
| 2IS | 261,7 x 10 ³ | 5,5 x 10 ⁻⁵ | 0,51 |
| 3IS + 1CIS | 557,4 x 10 ³ | 1,2 x 10 ⁻⁴ | 0,51 |
| 2IS + 2CIS | 591,4 x 10 ³ | 1,3 x 10 ⁻⁴ | 0,51 |
| 3IS | 392,5 x 10 ³ | 8,3 x 10 ⁻⁵ | 0,51 |
| 1IS + 1CIS | 261,7 x 10 ³ | 5,5 x 10 ⁻⁵ | 0,51 |


The SF6 gas-sniffing test would use the values of Fp for each of the Fluofix GC functions but for added security, the pass/fail level was lowered to $1,0 \times 10^{-6} \text{ bar} * \text{cm}^3/\text{s}$.

For the new value of Fp, the estimated lifespan and relative leakage rate of each Fluofix GC configuration were calculated:

$$Fp = 1,0 \times 10^{-6} \text{ bar} * \text{cm}^3/\text{s}$$

| Fluofix GC Configuration | Fluofix SF6 volume (cm ³) | Estimated lifespan (years) | Frel (%/year) |
|--------------------------|---------------------------------------|----------------------------|---------------|
| 2IS + 1CIS | 426,5 x 10 ³ | 2704 | 0.006 |
| 2IS | 261,7 x 10 ³ | 1660 | 0.009 |
| 3IS + 1CIS | 557,4 x 10 ³ | 3535 | 0.004 |
| 2IS + 2CIS | 591,4 x 10 ³ | 3751 | 0.004 |
| 3IS | 392,5 x 10 ³ | 2489 | 0.006 |
| 1IS + 1CIS | 261,7 x 10 ³ | 1660 | 0.009 |

| | | |
|----------------|---------|----------------|
| Date: 98.11.04 | MT / GQ | T. R. MT983088 |
|----------------|---------|----------------|





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

For the SF6 gas cumulative leakage measurement over a determined test time, it was used a gas tight flexible housing (see drawing on page 5) and the formula:

$$C = \frac{Fp \cdot Tt \cdot Po}{V1 - V2} \text{ (ppm)}$$

Where
 Tt is the cumulative leakage measurement test time (s)
 Po is the atmospheric pressure value (bar)
 V1 is the gas tight housing volume (cm³)
 V2 is the Fluofix GC volume (cm³)

In order to obtain expected values within the measurable range, the test time was set to 9 hours (32400s), thus obtaining the following acceptance criteria:

| Fluofix GC Configuration | Housing volume V1 (cm ³) | Fluofix volume V2 (cm ³) | Maximum admissible concentration C (ppm) |
|--------------------------|--------------------------------------|--------------------------------------|--|
| 2IS + 1CIS | 756,5 x 10 ³ | 426,5 x 10 ³ | 0,10 |
| 2IS | 464,2 x 10 ³ | 261,7 x 10 ³ | 0,16 |
| 3IS + 1CIS | 988,7 x 10 ³ | 557,4 x 10 ³ | 0,08 |
| 2IS + 2CIS | 1049,0 x 10 ³ | 591,4 x 10 ³ | 0,07 |
| 3IS | 696,2 x 10 ³ | 392,5 x 10 ³ | 0,11 |
| 1IS + 1CIS | 464,2 x 10 ³ | 261,7 x 10 ³ | 0,16 |

As the maximum admissible concentration C has no great discrepancies, the mean value of C was calculated and used (C = 0,1 ppm).

5 - TESTS RESULTS

Cumulative leakage test:

SF6 gas leakage measurement:

| Fluofix GC configuration | Test date | Test start time | Test finish time | C1 - start (ppm) | C2 - finish (ppm) |
|--------------------------|-----------|-----------------|------------------|------------------|-------------------|
| 2IS + 1CIS | 98.09.16 | 08:15 | 17:15 | 0.00 | 0.04 |
| 2IS | 98.09.16 | 08:10 | 17:10 | 0.01 | 0.06 |
| 3IS + 1CIS | 98.09.18 | 08:20 | 17:20 | 0.00 | 0.03 |
| 2IS + 2CIS | 98.09.21 | 09:00 | 18:00 | 0.01 | 0.04 |
| 3IS | 98.10.02 | 08:30 | 17:30 | 0.02 | 0.07 |
| 1IS + 1CIS | 98.10.08 | 08:00 | 17:00 | 0.03 | 0.08 |

| Fluofix GC Configuration | ΔC = C2-C1 (ppm) | Acceptance criteria | Test results |
|--------------------------|------------------|---------------------|--------------|
| 2IS + 1CIS | 0.04 | ΔC < 0.1 | Passed |
| 2IS | 0.05 | ΔC < 0.1 | Passed |
| 3IS + 1CIS | 0.03 | ΔC < 0.1 | Passed |
| 2IS + 2CIS | 0.03 | ΔC < 0.1 | Passed |
| 3IS | 0.05 | ΔC < 0.1 | Passed |
| 1IS + 1CIS | 0.05 | ΔC < 0.1 | Passed |


| | | | | |
|----------------|---------|--------------------|----------------|--|
| Date: 98.11.04 | MT / GQ | <i>[Signature]</i> | T. R. MT983088 | |
|----------------|---------|--------------------|----------------|--|

РАДИО С ОУДІС
 ПІДПИСАНО




EFACEC ENERGY
MEDIUM VOLTAGE SWITCHGEAR DIVISION

Test arrangements for cumulative leakage measurement



RECEIVED
OPERATIONS
DEPARTMENT





EFACEC ENERGY
MEDIUM VOLTAGE SWITCHGEAR DIVISION

TEST REPORT
No. MT983089

Ring Main Unit Fluofix GC with SF6 three position switch disconnector type ISFG

Kinematic Work Chain Test

Test regulations applied:

GE FND003 (1997)

Tests results:

The Ring Main Unit Fluofix GC passed the Tests.

Date of tests: 3rd of September 1998.


Tests performed by:

Manuel Martins

The laboratory chief

Rui Cardoso

| | | |
|----------------|---------|----------------|
| Date: 98.11.04 | MT / GQ | T. R. MT983089 |
|----------------|---------|----------------|







EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

5 - TESTS RESULTS

The Fluofix switch disconnector type ISFG is operated by a CI1 or CI2 type command mechanism through an operation shaft. The position indicator is of the rotative type, goes through the command mechanism and is operated by the main power contacts themselves through an independent signalization shaft. The kinetic work chain is arranged according to the next drawing:



Handwritten text: **REVISED**
30/11/04



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

The values of the force applied to the operating mechanism in order to work (F_m) were measured, along with the force delivered by the mechanical strain force limiter built in the command mechanism ($F'm$).

| Operations | Force applied F_m (N/m) | Force delivered $F'm$ (N/m) |
|----------------------------|------------------------------|--------------------------------|
| Line switch closing | 52 | 36 |
| Line switch opening | 54 | 35 |
| Earth disconnector closing | 53 | 38 |
| Earth disconnector opening | 54 | 36 |


The ISFG switch L1 phase was then blocked and then applied a force 1,5 times greater than F_m

| Operations | ISFG position | 1,5 x F_m (N/m) |
|----------------------------|-------------------------|-------------------|
| Line switch opening | Line closed and blocked | 81 |
| Earth disconnector closing | Earth open and blocked | 80 |

The force delivered by the mechanical strain force limiter ($F'm$) is of a lower value than the nominal force required to operate the mechanism (F_m) and this force is always less than 750N.

The ISFG switch and the position indicator mechanism withstands a force 1,5 times greater than F_m and there is no visible deformation of the power contacts or operating shaft.

Date: 98.11.04 MT / GQ *[Signature]* T. R. MT983089




RETRAPAR
RETRAPAR




EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

CI1 command mechanism




CI2 command mechanism



Date: 98.11.04


MT / GQ

T. R. MT983089



Page 5 /

ВЕРНО
ОПРЕДЕЛЕНА




| ASEFA | | Test report No.: F01.04.20 |
|--|---|---|
| Type test according to: IEC 60947-2 Test sequence III | | Page 30 / 68 |
| Type: NS630bH to 1600H Sample 31042.08 | | |
| Standard and clause | Kind of tests and requirements | Test values Results |
| 8.3.5.2 8.3.6.4 8.3.7.6 | ADDITIONAL SEQUENCE OF SHORT-CIRCUIT OPERATIONS ON FOUR POLE CIRCUIT-BREAKERS Test made on the same sample as for the three-pole short-circuit or on a new sample | same/new New |
| | Rated operational voltage U_e | 690 V |
| | Test voltage | $U_e/\sqrt{3}$ 398 V |
| | Recovery voltage | $1.05 \times U_e/\sqrt{3}$ 418 V |
| | Rated ultimate short-circuit breaking capacity I_{cu} | 25,2 kA |
| | Rated short-time withstand current I_{cvt} | 19,2 kA |
| | Short-circuit breaking capacity of the fourth pole (by arrangement) (not less than 60 % of I_{cu} or I_{cvt} as applicable) | 39 kA |
| Table 11 | Power factor | 0.25 0.25(+0,-0,05) |
| | Frequency | 50 Hz 50 Hz |
| 8.3.2.1 7.2.1.1.3 | Control supply voltage | $0.85 \times U_e$./. V |
| | Maximum value of the closing time | ./. ms |
| | Sequence of operation | O - t - CO O - t - CO |
| | Circuit diagram | Page 66 |
| | Calibration of the test circuit | Pageform 169 Next page |
| | Safety area | Pageform Page 65 |
| | Installation of the material tested | Pageform Page 64 |
| | Energization direction | Top/Bottom Top |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics | |
| | Cable | ./. mm ² ./. mm ² |
| | Bar | ./. x ./. mm 100 x 10 mm |
| | Number | ./. 1 |
| | Length | supply side ./. mm 500 mm |
| | | load side ./. mm 500 mm |
| | Tightening torque | 50 Nm |


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2.1 form 48




| ASEFA | | Test report No.: F01.04.20 Page 31 / 68 | |
|---|--|---|----------|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.08 | |
| Standard and clause | Kind of tests and requirements | Test values Results | |
| 60947-1 8.3.4.1.5 | CALIBRATION OF THE TEST CIRCUIT | | |
| | Oscillogram | 20040283-0119 20040283-0122 | |
| | Applied voltage | 448.56 V | |
| | Frequency | 50 Hz | |
| | RMS current value at 20 ms | I_1 | 26.46 kA |
| | | I_2 | ./. kA |
| | | I_3 | ./. kA |
| | Average RMS. Value | 26.46 kA | |
| | Peak current maximum value | 56.23 kA | |
| Power factor | 0,2 | | |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | TRF IEC/EN 60947-2 Ed. 2:1 form 169 Date August 19th 2006 | |





20060819
 169
 2:1
 Ed.

| ASEFA | | Test report No.: F01.04.20 Page 32 / 68 |
|---|--|--|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.08 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | OPERATION "O" | 20040283.0123 |
| | Oscillogram | 54.67 kA |
| | Peak current value | i_1 ./. kA i_2 ./. kA i_3 ./. kA |
| | Maximum total duration | 19 ms |
| | Recovery voltage (phase to phase or phase to neutral) | $U_{r(1-2)}$ <input type="checkbox"/> or $U_{r(1-N)}$ <input checked="" type="checkbox"/> 432.12 V $U_{r(2-3)}$ <input type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> ./. V $U_{r(3-1)}$ <input type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> ./. V |
| | Average value | U_{rm} 432.12 V |
| | Ratio between U_{rm} and U_0 | U_{rm}/U_0 1.08 |
| | Joule integral | Ph_1 19.5 (kA) ² s Ph_2 ./. (kA) ² s Ph_3 ./. (kA) ² s |
| | Melting of the fusible element | Yes/No No |
| | Holes in the PE-sheet (if applicable) | Yes/No No |
| | Cracks observed | Yes/No No |
| | If Yes | Page ./. |
| | Time interval between operations | 3 min 4 min |
| | OPERATION "CO1" | 20040283.0124 |
| | Oscillogram | 435.05 V |
| | Applied voltage | 53.75 kA |
| | Peak current value | i_1 ./. kA i_2 ./. kA i_3 ./. kA |
| | Maximum total duration | 18.05 ms |
| | Recovery voltage (phase to phase or phase to neutral) | $U_{r(1-2)}$ <input type="checkbox"/> or $U_{r(1-N)}$ <input checked="" type="checkbox"/> 434.56 V $U_{r(2-3)}$ <input type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> ./. V $U_{r(3-1)}$ <input type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> ./. V |
| | Average value | U_{rm} 434.56 V |
| | Ratio between U_{rm} and U_0 | U_{rm}/U_0 1.09 |
| | Joule Integral | Ph_1 18.72 (kA) ² s Ph_2 ./. (kA) ² s Ph_3 ./. (kA) ² s |
| 7.2.1.1.3 | Closing operation time | ./. ms |
| | Melting of the fusible element | Yes/No No |
| | Cracks observed | Yes/No No |
| | If Yes | Page ./. |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | |

Date August 19th 2005



| ASEFA | | Test report No.: F01.04.20 Page 33 / 68 |
|---|---|---|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.08 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF DIELECTRIC WITHSTAND | |
| | Test voltage | |
| | 2 x U _o , min. 1000 V | 1380 V |
| 8.3.3.5 | Test sequence I | |
| 8.3.4.3 | Test sequence II | |
| 8.3.5.3 | Test sequence III | 1380 V |
| 8.3.6.5 | Test sequence IV | |
| 8.3.7.3 | Test sequence V, stage 1 | |
| 8.3.7.7 | Test sequence V, stage 2 | |
| 8.3.8.5 | Combined test sequence | |
| B.10.3.1 | Test sequence B.II | |
| A.5 | Verification of discrimination | |
| A.6.3 | Verification of back-up protection | |
| C.3 | Individual pole short-circuit test sequence | |
| H.3 | Test sequence for circuit-breakers for IT-systems | |
| 8.3.3.2.2 a) | Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable) | |
| | Test duration | 5 s 5 s |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | |  TRF IEC/EN 60947-2 Ed. 2.1 form 32/volta Date August 19th 2008 |


| ASEFA | | Test report No.: F01.04.20 Page 34 / 68 |
|---|--|---|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.08 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF LEAKAGE CURRENT For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V. - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable) | |
| 8.3.3.2 | Test voltage | $1.1 \times U_o = 759 \text{ V}$ 759 V |
| 60947-1 7.2.7 | Application of the test voltage | |
| | Leakage current | |
| 8.3.3.2 | Test sequence I (in new condition) | $\leq 0.5 \text{ mA}$./ mA |
| 8.3.3.5 | Test sequence I (after overload performance) | $\leq 2 \text{ mA}$./ mA |
| 8.3.4.3 | Test sequence II | $\leq 2 \text{ mA}$./ mA |
| 8.3.5.3 | Test sequence III | $\leq 6 \text{ mA}$ 0 mA |
| 8.3.6.5 | Test sequence IV | $\leq 2 \text{ mA}$./ mA |
| 8.3.7.3 | Test sequence V, stage 1 | $\leq 2 \text{ mA}$./ mA |
| 8.3.7.7 | Test sequence V, stage 2 | $\leq 6 \text{ mA}$./ mA |
| 8.3.8.5 | Combined test sequence | $\leq 2 \text{ mA}$./ mA |
| C.3 | Individual pole short-circuit test sequence I_{su} | $\leq 6 \text{ mA}$./ mA |
| H.3 | Individual pole short-circuit test sequence I_{IT} | $\leq 6 \text{ mA}$./ mA |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | |  |
| | | Date August 19th 2005 |

| ASEFA | | Test report No.: F01.04.20 Page 35 / 68 | |
|--|---|--|---------------------|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.08 | |
| Standard and clause | Kind of tests and requirements | Test values Results | |
| VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY | | | |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics | | |
| | Cable | ./. mm ² | ./. mm ² |
| | Bar | 100 x 5 mm | 100 x 10 mm |
| | Number | 2 | 1 |
| | Length | ./. mm | 500 mm |
| | Tightening torque | | 50 Nm |
| | Reference temperature | 40 °C ± 2 °C | |
| | Ambient temperature | | 21.3 °C |
| | Correction factor (k = 1 for releases independent of ambient temperature) k | | 1 |
| | Current setting value | I _n | 1600 A |
| Test current | | | |
| | either k x 2.0 x I _n | ./. A | ./. A |
| 8.3.5.1 | Test sequence II (I _{cs} = I _{cu}) | before 8.3.4.1 | |
| 8.3.5.1 | Test sequence III | before 8.3.5.2 | |
| 8.3.6.1 | Test sequence IV | before 8.3.6.2 | |
| 8.3.6.6 | Test sequence IV | after 8.3.6.5 | |
| 8.3.7.4 | Test sequence V | before 8.3.7.5 | |
| 8.3.8.1 | Combined test sequence | before 8.3.8.2 | |
| A.5 | Verification of discrimination | before 8.3.5.2 | |
| A.6.3 | Verification of back-up protection | before 8.3.5.2 | |
| | or k x 2.5 x I _n | 4000 A | 4000 A |
| 8.3.5.4 | Test sequence II (I _{cs} = I _{cu}) | after 8.3.4.5 | |
| 8.3.5.4 | Test sequence III | after 8.3.5.3 | |
| 8.3.7.8 | Test sequence V | after 8.3.7.7 | |
| 8.3.8.7 | Combined test sequence | after 8.3.8.6 | |
| A.5 | Verification of discrimination | after 8.3.5.3 | |
| A.6.3 | Verification of back-up protection | after 8.3.5.3 | |
| C.4 | Individual pole short-circuit test sequence | | |
| H.4 | Test sequence for circuit-breakers for IT-systems | | |
| | Tripping time (for twice the value of current setting on single pole) | | |
| | Neutral | ≤ 270 s | 126 s |
| | Ph1 | ≤ 270 s | 131 s |
| | Ph2 | ≤ ./. s | ./. s |
| | Ph3 | ≤ ./. s | ./. s |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
Ed. 2.1 form 46

Date August 19th 2005




| ASEFA | | Test report No.: F01.04.20 Page 36 / 68 | |
|--|---|--|---------------------|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.09 | |
| Standard and clause | Kind of tests and requirements | Test values Results | |
| 60947-1 Table 9, 10 and 11 | VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY | | |
| | Cabling characteristics | | |
| | Cable | ./. mm ² | ./. mm ² |
| | Bar | 100 x 5 mm | 100 x 10 mm |
| | Number | 2 | 1 |
| | Length | ./. mm | 500 mm |
| | Tightening torque | | 50 Nm |
| | Reference temperature | 40 °C ± 2 °C | |
| | Ambient temperature | | 22.5 °C |
| | Correction factor (k = 1 for releases independent of ambient temperature) k | | 1 |
| | Current setting value I _n | | 1600 A |
| | Test current | | |
| | | | 3200 A |
| | | | 3200 A |
| | 8.3.5.1 | either k x 2.0 x I _n | 3200 A |
| 8.3.5.1 | Test sequence II (I _{cs} = I _{cn}) | before 8.3.4.1 | |
| 8.3.6.1 | Test sequence III | before 8.3.5.2 | |
| 8.3.6.6 | Test sequence IV | before 8.3.6.2 | |
| 8.3.7.4 | Test sequence IV | after 8.3.6.5 | |
| 8.3.8.1 | Test sequence V | before 8.3.7.5 | |
| A.5 | Combined test sequence | before 8.3.8.2 | |
| A.6.3 | Verification of discrimination | before 8.3.5.2 | |
| | Verification of back-up protection | before 8.3.5.2 | |
| | | ./. A | ./. A |
| 8.3.5.4 | or k x 2.5 x I _n | | |
| 8.3.5.4 | Test sequence II (I _{cs} = I _{cn}) | after 8.3.4.5 | |
| 8.3.7.8 | Test sequence III | after 8.3.5.3 | |
| 8.3.8.7 | Test sequence V | after 8.3.7.7 | |
| A.5 | Combined test sequence | after 8.3.8.6 | |
| A.6.3 | Verification of discrimination | after 8.3.5.3 | |
| C.4 | Verification of back-up protection | after 8.3.5.3 | |
| H.4 | Individual pole short-circuit test sequence | | |
| | Test sequence for circuit-breakers for IT-systems | | |
| | Tripping time (for twice the value of current setting on single pole) | | |
| | Neutral | ≤ 270 s | 237 s |
| | Ph ₁ | ≤ 270 s | 228 s |
| | Ph ₂ | ≤ 270 s | 221 s |
| | Ph ₃ | ≤ 270 s | 235 s |


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2.1 form 46




| ASEFA | | Test report No.: F01.04.20 Page 37 / 68 | |
|---|---|--|---------------------|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.09 | |
| Standard and clause | Kind of tests and requirements | Test values Results | |
| 8.3.5.2 | RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY | | |
| | Utilization category | B | |
| | Rated operational voltage U_n | 415 V | |
| | Recovery voltage | $1.05 \times U_n$ | 435.75 V |
| | Rated ultimate short-circuit breaking capacity | I_{cu} | 70 kA |
| | Rated short-circuit making capacity | I_{cm} | 154 kA |
| Table 11 | Power factor | 0.20 | 0.20 |
| | Frequency | 50 Hz | 50 Hz |
| 8.3.2.1 | Control supply voltage | $0.85 \times U_n$./. V | ./. V |
| 7.2.1.1.3 | Maximum value of the closing time | | ./. ms |
| | Sequence of operation | O - t - CO | O - t - CO |
| | Circuit diagram | | Page 66 |
| | Calibration of the test circuit | Pageform | Next page |
| | Safety area | Pageform | Page 65 |
| | Installation of the material tested | Pageform | Page 64 |
| | Energization direction | Top/Bottom | Top |
| 8.3.2.1 | Smallest individual enclosure (if applicable) | | |
| | Type | | ./. |
| | Kind of material | | ./. |
| | Inside dimensions | | |
| | Height | | ./. mm |
| | Width | | ./. mm |
| | Depth | | ./. mm |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics | | |
| | Cable | ./. mm ² | ./. mm ² |
| | Bar | 100 x 5 mm | 100 x 10 mm |
| | Number | 2 | 1 |
| | Length | supply side ./. mm | 350 mm |
| | | load side ./. mm | 350 mm |
| | Tightening torque | | 50 Nm |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | TRF IEC/EN 60947-2 Ed. 2, Form 47 | |
| | | Date August 19th 2005 | |



| ASEFA | | Test report No.: F01.04.20 Page 39 / 68 |
|---|--|--|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.09 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | OPERATION "O" | |
| | Oscillogram | 20040288.0011 |
| | Peak current value | I_1 123.58 kA I_2 111.73 kA I_3 66.26 kA |
| | Maximum total duration | 12.8 ms |
| | Recovery voltage (phase to phase or phase to neutral) | $U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 443.07 V $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 443.15 V $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 443.16 V |
| | Average value | U_{rm} 443.13 V |
| | Ratio between U_{rm} and U_0 | U_{rm}/U_0 1.06 |
| | Joule integral | Ph ₁ 74.45 (kA) ² s Ph ₂ 63.58 (kA) ² s Ph ₃ 18.06 (kA) ² s |
| | Melting of the fusible element | Yes/No No |
| | Holes in the PE-sheet (if applicable) | Yes/No No |
| | Cracks observed | Yes/No No |
| | If Yes | Page ./. |
| | Time interval between operations | 3 min 3 min |
| | OPERATION "CO1" | |
| | Oscillogram | 20040288.0012 |
| | Applied voltage | 450.46 V |
| | Peak current value | I_1 118.6 kA I_2 114.5 kA I_3 65.68 kA |
| | Maximum total duration | 13.6 ms |
| | Recovery voltage (phase to phase or phase to neutral) | $U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 444.72 V $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 445.21 V $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 443.97 V |
| | Average value | U_{rm} 444.63 V |
| | Ratio between U_{rm} and U_0 | U_{rm}/U_0 1.07 |
| | Joule integral | Ph ₁ 67.25 (kA) ² s Ph ₂ 67.14 (kA) ² s Ph ₃ 20.07 (kA) ² s |
| 7.2.1.1.3 | Closing operation time | ./ ms |
| | Melting of the fusible element | Yes/No No |
| | Cracks observed | Yes/No No |
| | If Yes | Page ./. |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | TRF IEC/EN 60947-2 Ed. 2.1 form 41 |

Date August 19th 2005




| ASEFA | | Test report No.: F01.04.20 Page 40 / 68 |
|--|---|--|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.09 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF DIELECTRIC WITHSTAND | |
| | Test voltage | |
| | 2 x U _o , min. 1000 V | 1000 V |
| 8.3.3.5 | Test sequence I | 1000 V |
| 8.3.4.3 | Test sequence II | |
| 8.3.5.3 | Test sequence III | |
| 8.3.6.5 | Test sequence IV | |
| 8.3.7.3 | Test sequence V, stage 1 | |
| 8.3.7.7 | Test sequence V, stage 2 | |
| 8.3.8.5 | Combined test sequence | |
| B.10.3.1 | Test sequence B.II | |
| A.5 | Verification of discrimination | |
| A.6.3 | Verification of back-up protection | |
| C.3 | Individual pole short-circuit test sequence | |
| H.3 | Test sequence for circuit-breakers for IT-systems | |
| 8.3.3.2.2 a) | Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable) | |
| | Test duration | 6 s 5 s |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2.1 form 32/10/19

01042009
 NS630bH
 31042.09




| ASEFA | | Test report No.: F01.04.20 |
|--|--|--|
| Type test according to: IEC 60947-2 Test sequence III | | Page 41 / 68 |
| Type: NS630bH to 1600H Sample 31042.09 | | |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF LEAKAGE CURRENT | |
| | For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V. | |
| 8.3.3.2 | - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable) | |
| | Test voltage | $1.1 \times U_o = 457 \text{ V}$ 457 V |
| 60947-1 7.2.7 | Application of the test voltage | |
| | Leakage current | |
| 8.3.3.2 | Test sequence I (In new condition) | $\leq 0.5 \text{ mA}$./ mA |
| 8.3.3.5 | Test sequence I (after overload performance) | $\leq 2 \text{ mA}$./ mA |
| 8.3.4.3 | Test sequence II | $\leq 2 \text{ mA}$./ mA |
| 8.3.5.3 | Test sequence III | $\leq 6 \text{ mA}$ 0.08 mA |
| 8.3.6.5 | Test sequence IV | $\leq 2 \text{ mA}$./ mA |
| 8.3.7.3 | Test sequence V, stage 1 | $\leq 2 \text{ mA}$./ mA |
| 8.3.7.7 | Test sequence V, stage 2 | $\leq 6 \text{ mA}$./ mA |
| 8.3.8.5 | Combined test sequence | $\leq 2 \text{ mA}$./ mA |
| C.3 | Individual pole short-circuit test sequence I_{su} | $\leq 6 \text{ mA}$./ mA |
| H.3 | Individual pole short-circuit test sequence I_{IT} | $\leq 6 \text{ mA}$./ mA |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2.1 form 23




| ASEFA | | Test report No.: F01.04.20 Page 42 / 68 |
|--|---|--|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.09 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY | |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics Cable $.l$ mm ² Bar 100 x 5 mm Number 2 Length $.l$ mm Tightening torque Reference temperature 40 °C ± 2 °C Ambient temperature Correction factor (k = 1 for releases independent of ambient temperature) k Current setting value I_n | $.l$ mm ² 100 x 5 mm 2 500 mm 50 Nm 18.4 °C 1 1600 A |
| | Test current | |
| | either $k \times 2.0 \times I_n$ | $.l$ A |
| 8.3.5.1 | Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1 | |
| 8.3.5.1 | Test sequence III before 8.3.5.2 | |
| 8.3.6.1 | Test sequence IV before 8.3.6.2 | |
| 8.3.6.6 | Test sequence IV after 8.3.6.5 | |
| 8.3.7.4 | Test sequence V before 8.3.7.5 | |
| 8.3.8.1 | Combined test sequence before 8.3.8.2 | |
| A.5 | Verification of discrimination before 8.3.5.2 | |
| A.6.3 | Verification of back-up protection before 8.3.5.2 | |
| | or $k \times 2.5 \times I_n$ | 4000 A |
| 8.3.5.4 | Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5 | |
| 8.3.5.4 | Test sequence III after 8.3.5.3 | |
| 8.3.7.8 | Test sequence V after 8.3.7.7 | |
| 8.3.8.7 | Combined test sequence after 8.3.8.6 | |
| A.5 | Verification of discrimination after 8.3.5.3 | |
| A.6.3 | Verification of back-up protection after 8.3.5.3 | |
| C.4 | Individual pole short-circuit test sequence | |
| H.4 | Test sequence for circuit-breakers for IT-systems | |
| | Tripping time (for twice the value of current setting on single pole) | |
| | Neutral ≤ 270 s | 124 s |
| | Ph ₁ ≤ 270 s | 130 s |
| | Ph ₂ ≤ 270 s | 128 s |
| | Ph ₃ ≤ 270 s | 126 s |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2.1 form 46 03 00





| ASEFA | | Test report No.: F01.04.20 |
|---|---|---|
| Type test according to: IEC 60947-2 Test sequence III | | Page 43 / 68 |
| Type: NS630bH to 1600H Sample 31042.10 | | |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY | |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics Cable $.l. \text{ mm}^2$ 185 mm ² Bar 40 x 5 mm $.l. \times .l. \text{ mm}$ Number 2 1 Length $.l. \text{ mm}$ 500 mm Tightening torque 60 Nm Reference temperature 40 °C ± 2 °C Ambient temperature 22 °C Correction factor (k = 1 for releases independent of ambient temperature) k 1 Current setting value I_n 630*0.4=252A Test current either $k \times 2.0 \times I_n$ 504 A 504 A | |
| 8.3.5.1 | Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1 | |
| 8.3.5.1 | Test sequence III before 8.3.5.2 | |
| 8.3.6.1 | Test sequence IV before 8.3.6.2 | |
| 8.3.6.6 | Test sequence IV after 8.3.6.5 | |
| 8.3.7.4 | Test sequence V before 8.3.7.5 | |
| 8.3.8.1 | Combined test sequence before 8.3.8.2 | |
| A.5 | Verification of discrimination before 8.3.5.2 | |
| A.6.3 | Verification of back-up protection before 8.3.5.2 | |
| | or $k \times 2.5 \times I_n$ $.l. A$ $.l. A$ | |
| 8.3.5.4 | Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5 | |
| 8.3.5.4 | Test sequence III after 8.3.5.3 | |
| 8.3.7.8 | Test sequence V after 8.3.7.7 | |
| 8.3.8.7 | Combined test sequence after 8.3.8.6 | |
| A.5 | Verification of discrimination after 8.3.5.3 | |
| A.6.3 | Verification of back-up protection after 8.3.5.3 | |
| C.4 | Individual pole short-circuit test sequence | |
| H.4 | Test sequence for circuit-breakers for IT-systems | |
| | Tripping time (for twice the value of current setting on single pole) Neutral ≤ 270 s 207 s Ph ₁ ≤ 270 s 212 s Ph ₂ ≤ 270 s 225 s Ph ₃ ≤ 270 s 217 s | |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | TRF IEC/EN 60947-2 Ed: 21 form 46  |
| | | Date August 19th 2005 |

| ASEFA | | Test report No.: F01.04.20 Page 44 / 68 | |
|--|---|--|-----------------------|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.10 | |
| Standard and clause | Kind of tests and requirements | Test values Results | |
| 8.3.5.2 | RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY | | |
| | Utilization category | B | |
| | Rated operational voltage U_n | 415 V | |
| | Recovery voltage | $1.05 \times U_n$ | 435.75 V |
| | Rated ultimate short-circuit breaking capacity | I_{cu} | 70 kA |
| | Rated short-circuit making capacity | I_{cm} | 154 kA |
| Table 11 | Power factor | 0,20 | 0,20(+0,-0,05) |
| | Frequency | 50 Hz | 50 Hz |
| 8.3.2.1 | Control supply voltage | $0.85 \times U_n$ J. V | J. V |
| 7.2.1.1.3 | Maximum value of the closing time | | J. ms |
| | Sequence of operation | O - t - CO | O - t - CO Page 66 |
| | Circuit diagram | | Next page |
| | Calibration of the test circuit | Pageform | |
| | Safety area | Pageform | Page 65 |
| | Installation of the material tested | Pageform | Page 64 |
| | Energization direction | Top/Bottom | Top |
| 8.3.2.1 | Smallest individual enclosure (if applicable) | | J. |
| | Type | | J. |
| | Kind of material | | |
| | Inside dimensions | | J. mm |
| | Height | | J. mm |
| | Width | | J. mm |
| | Depth | | J. mm |
| 60947-1 | Cabling characteristics | | J. mm ² |
| Table 9, 10 and 11 | Cable | | 40 x 5 mm |
| | Bar | | 2 |
| | Number | | 350 mm |
| | Length | supply side | J. mm |
| | | load side | J. mm |
| | Tightening torque | | 50 Nm |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 10th 2005




| ASEFA | | Test report No.: F01.04.20 Page 45 / 68 |
|---|--|--|
| Type test according to: IEC 60947-2 | | Type: NS630bH to 1600H Sample 31042.10 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| 60947-1 8.3.4.1.5 | CALIBRATION OF THE TEST CIRCUIT | |
| | Oscillogram | 20040288-0003 20040288-0007 |
| | Applied voltage | 440.17 V |
| | Frequency | 50 Hz |
| | RMS current value at 20 ms | I_1 70.21 kA I_2 70.99 kA I_3 69.51 kA |
| | Average RMS. Value | 70.23 kA |
| | Peak current maximum value | 156.12 kA |
| | Power factor | 0,17 |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | |  Date August 19th 2005 |

| ASEFA | | Test report No.: F01.04.20 |
|--|---------------------------------------|---|
| | | Page 46 / 68 |
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.10 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | OPERATION "O" | 20040288.0013 |
| | Oscillogram | |
| | Peak current value | i_1 122.69 kA |
| | | i_2 114.04 kA |
| | | i_3 69.83 kA |
| | Maximum total duration | 13,45 ms |
| | Recovery voltage | 443.07 V |
| | (phase to phase or phase to neutral) | 443.52 V |
| | | 443.19 V |
| | Average value | U_m 443.26 V |
| | Ratio between U_m and U_0 | U_m/U_0 1.06 |
| | Joule integral | Ph ₁ 75.29 (kA) ² s |
| | | Ph ₂ 67.36 (kA) ² s |
| | | Ph ₃ 20.94 (kA) ² s |
| | Melting of the fusible element | Yes/No No |
| | Holes in the PE-sheet (if applicable) | Yes/No No |
| | Cracks observed | Yes/No No |
| | If Yes | Page ./. |
| | Time Interval between operations | 3 min 3 min |
| | OPERATION "CO1" | 20040288.0014 |
| | Oscillogram | |
| | Applied voltage | 448.34 V |
| | Peak current value | i_1 70.71 kA |
| | | i_2 109.66 kA |
| | | i_3 123.37 kA |
| | Maximum total duration | 14,4 ms |
| | Recovery voltage | 442.94 V |
| | (phase to phase or phase to neutral) | 442.13 V |
| | | 442.98 V |
| | Average value | U_m 442.68 V |
| | Ratio between U_m and U_0 | U_m/U_0 1.06 |
| | Joule integral | Ph ₁ 27.23 (kA) ² s |
| | | Ph ₂ 49.66 (kA) ² s |
| | | Ph ₃ 79.18 (kA) ² s |
| | Closing operation time | ./ ms |
| | Melting of the fusible element | Yes/No No |
| | Cracks observed | Yes/No No |
| | If Yes | Page ./. |
| 7.2.1.1.3 | | |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005




TRF IEC/EN 60947-2
Exp 2.1 form 41

2005
 08
 19
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50

| ASEFA | | Test report No.: F01.04.20 Page 47 / 68 |
|--|---|--|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.10 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF DIELECTRIC WITHSTAND | |
| | Test voltage | |
| | 2 x U _o , mln. 1000 V | 1000 V |
| 8.3.3.5 | Test sequence I | |
| 8.3.4.3 | Test sequence II | |
| 8.3.5.3 | Test sequence III | 1000 V |
| 8.3.6.6 | Test sequence IV | |
| 8.3.7.3 | Test sequence V, stage 1 | |
| 8.3.7.7 | Test sequence V, stage 2 | |
| 8.3.8.5 | Combined test sequence | |
| B.10.3.1 | Test sequence B.II | |
| A.5 | Verification of discrimination | |
| A.6.3 | Verification of back-up protection | |
| C.3 | Individual pole short-circuit test sequence | |
| H.3 | Test sequence for circuit-breakers for IT-systems | |
| 8.3.3.2.2 a) | Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable) | |
| | Test duration | 5 s 5 s |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005




GRENOBLE
 ASEFA
 PLATFORM

| ASEFA | | Test report No.: F01.04.20 Page 48 / 68 |
|--|--|--|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.10 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF LEAKAGE CURRENT | |
| | For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V. | |
| 8.3.3.2 | - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable) | |
| | Test voltage | $1.1 \times U_o = 457 \text{ V}$ 457 V |
| 60947-1 7.2.7 | Application of the test voltage | |
| | Leakage current | |
| 8.3.3.2 | Test sequence I (in new condition) | $\leq 0.5 \text{ mA}$./ mA |
| 8.3.3.5 | Test sequence I (after overload performance) | $\leq 2 \text{ mA}$./ mA |
| 8.3.4.3 | Test sequence II | $\leq 2 \text{ mA}$./ mA |
| 8.3.5.3 | Test sequence III | $\leq 6 \text{ mA}$ 0.05 mA |
| 8.3.6.5 | Test sequence IV | $\leq 2 \text{ mA}$./ mA |
| 8.3.7.3 | Test sequence V, stage 1 | $\leq 2 \text{ mA}$./ mA |
| 8.3.7.7 | Test sequence V, stage 2 | $\leq 6 \text{ mA}$./ mA |
| 8.3.8.5 | Combined test sequence | $\leq 2 \text{ mA}$./ mA |
| C.3 | Individual pole short-circuit test sequence I_{su} | $\leq 6 \text{ mA}$./ mA |
| H.3 | Individual pole short-circuit test sequence I_{IT} | $\leq 6 \text{ mA}$./ mA |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM


Date August 19th 2005


TRF IEC/EN 60947-2
Ed. 2.1 form 25




| ASEFA | | Test report No.: F01.04.20 |
|---|--|---|
| Type test according to: IEC 60947-2 Test sequence III | | Page 49 / 68 |
| Type: NS630bH to 1600H Sample 31042.10 | | |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY | |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics | |
| | Cable | ./. mm ² 185 mm ² |
| | Bar | 40 x 5 mm /. x /. mm |
| | Number | 2 1 |
| | Length | /. mm 500 mm |
| | Tightening torque | 50 Nm |
| | Reference temperature | 40 °C ± 2 °C |
| | Ambient temperature | 20.6 °C |
| | Correction factor (k = 1 for releases independent of ambient temperature) k | 1 |
| | Current setting value | I_n 630*0.4=252A |
| | Test current | |
| | either $k \times 2.0 \times I_n$ | /. A /. A |
| 8.3.5.1 | Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1 | |
| 8.3.5.1 | Test sequence III before 8.3.5.2 | |
| 8.3.6.1 | Test sequence IV before 8.3.6.2 | |
| 8.3.6.6 | Test sequence IV after 8.3.6.5 | |
| 8.3.7.4 | Test sequence V before 8.3.7.5 | |
| 8.3.8.1 | Combined test sequence before 8.3.8.2 | |
| A.5 | Verification of discrimination before 8.3.5.2 | |
| A.6.3 | Verification of back-up protection before 8.3.5.2 | |
| | or $k \times 2.5 \times I_n$ 630 A 630 A | |
| 8.3.5.4 | Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5 | |
| 8.3.5.4 | Test sequence III after 8.3.5.3 | |
| 8.3.7.8 | Test sequence V after 8.3.7.7 | |
| 8.3.8.7 | Combined test sequence after 8.3.8.6 | |
| A.5 | Verification of discrimination after 8.3.5.3 | |
| A.6.3 | Verification of back-up protection after 8.3.5.3 | |
| C.4 | Individual pole short-circuit test sequence | |
| H.4 | Test sequence for circuit-breakers for IT-systems | |
| | Tripping time (for twice the value of current setting on single pole) | |
| | Neutral | ≤ 270 s 131 s |
| | Ph ₁ | ≤ 270 s 136 s |
| | Ph ₂ | ≤ 270 s 127 s |
| | Ph ₃ | ≤ 270 s 127 s |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | |

Date August 19th 2005





| ASEFA | | Test report No.: F01.04.20 |
|--|--|----------------------------|
| Type test according to: IEC 60947-2 Test sequence III | | Page 50 / 68 |
| Type: NS630bH to 1600H Sample 31042.11 | | |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY | |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics Cable I_n mm ² Bar 100 x 5 mm Number 2 Length I_n mm Tightening torque Reference temperature 40 °C ± 2 °C Ambient temperature 22 °C Correction factor ($k = 1$ for releases independent of ambient temperature) k 1 Current setting value I_n 1600 A Test current either $k \times 2.0 \times I_n$ 3200 A 3200 A 8.3.5.1 Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1 8.3.5.1 Test sequence III before 8.3.5.2 8.3.6.1 Test sequence IV before 8.3.6.2 8.3.6.6 Test sequence IV after 8.3.6.5 8.3.7.4 Test sequence V before 8.3.7.5 8.3.8.1 Combined test sequence before 8.3.8.2 A.5 Verification of discrimination before 8.3.5.2 A.6.3 Verification of back-up protection before 8.3.5.2 or $k \times 2.5 \times I_n$ I_n A I_n A 8.3.5.4 Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5 8.3.5.4 Test sequence III after 8.3.5.3 8.3.7.8 Test sequence V after 8.3.7.7 8.3.8.7 Combined test sequence after 8.3.8.6 A.5 Verification of discrimination after 8.3.5.3 A.6.3 Verification of back-up protection after 8.3.5.3 C.4 Individual pole short-circuit test sequence H.4 Test sequence for circuit-breakers for IT-systems Tripping time (for twice the value of current setting on single pole) Neutral ≤ 270 s 228 s Ph ₁ ≤ 270 s 204 s Ph ₂ ≤ 270 s 215 s Ph ₃ ≤ 270 s 226 s | |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM Date August 19th 2005 IEC/EN 60947-2 Ed. 2.1 form 16  | | |

| ASEFA | | Test report No.: F01.04.20 Page 52 / 68 |
|---|--|--|
| Type test according to: IEC 60947-2 | | Type: NS630bH to 1600H Sample 31042.11 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| 60947-1 8.3.4.1.5 | CALIBRATION OF THE TEST CIRCUIT | |
| | Oscillogram | 20040288-0015 20040288-0018 |
| | Applied voltage | 474.23 V |
| | Frequency | 50 Hz |
| | RMS current value at 20 ms | I_1 66.54 kA I_2 66.80 kA I_3 64.32 kA |
| | Average RMS. Value | 65.89 kA |
| | Peak current maximum value | 139.08 kA |
| | Power factor | 0,17 |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | Date August 19th 2005 |



20040288-0015
 20040288-0018

| ASEFA | | Test report No.: F01.04.20 Page 53 / 68 |
|---|--|---|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.11 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| 7.2.1.1.3 | OPERATION "O" | |
| | Oscillogram Peak current value I_1 I_2 I_3 Maximum total duration Recovery voltage (phase to phase or phase to neutral) $U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> Average value U_m Ratio between U_m and U_e U_m/U_e Joule Integral Ph_1 Ph_2 Ph_3 Melting of the fusible element Yes/No Holes in the PE-sheet (if applicable) Yes/No Cracks observed Yes/No If Yes Time interval between operations 3 min | 20040288.0019 113.30 kA 100.34 kA 73.62 kA 14.5 ms 466.08 V 466.46 V 466.07 V 466.21 V 1.05 65.85 (kA) ² s 51.57 (kA) ² s 20.68 (kA) ² s No No No Page ./. 3 min |
| 7.2.1.1.3 | OPERATION "CO1" | |
| | Oscillogram Applied voltage Peak current value I_1 I_2 I_3 Maximum total duration Recovery voltage (phase to phase or phase to neutral) $U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> Average value U_m Ratio between U_m and U_e U_m/U_e Joule Integral Ph_1 Ph_2 Ph_3 Closing operation time Melting of the fusible element Yes/No Cracks observed Yes/No If Yes | 20040288.0020 474.53 V 109.61 kA 97.03 kA 77.15 kA 20.25 ms 468.37 V 468.39 V 468.21 V 468.32 V 1.06 59.66 (kA) ² s 47.00 (kA) ² s 22.24 (kA) ² s ./ ms No No Page ./ |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | TRF IEC/EN 60947-2 form 41 Date August 19 2005  |

| ASEFA | | Test report No.: F01.04.20 Page 54 / 68 |
|---|---|---|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.11 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF DIELECTRIC WITHSTAND | |
| | Test voltage | |
| | 2 x U ₀ , min. 1000 V | 1000 V |
| 8.3.3.5 | Test sequence I | |
| 8.3.4.3 | Test sequence II | |
| 8.3.5.3 | Test sequence III | 1000 V |
| 8.3.6.5 | Test sequence IV | |
| 8.3.7.3 | Test sequence V, stage 1 | |
| 8.3.7.7 | Test sequence V, stage 2 | |
| 8.3.8.5 | Combined test sequence | |
| B.10.3.1 | Test sequence B.II | |
| A.5 | Verification of discrimination | |
| A.6.3 | Verification of back-up protection | |
| C.3 | Individual pole short-circuit test sequence | |
| H.3 | Test sequence for circuit-breakers for IT-systems | |
| 8.3.3.2.2 a) | Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable) | |
| | Test duration | 5 s 5 s |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | |  |
| | | Date August 19th 2005 |


CP 11111111

| ASEFA | | Test report No.: F01.04.20 Page 55 / 68 |
|---|--|--|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.11 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF LEAKAGE CURRENT | |
| | For circuit-breakers suitable for Isolation having an operational voltage U_o greater than 50 V. | |
| 8.3.3.2 | - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable) | |
| | Test voltage | $1.1 \times U_o = 484 \text{ V}$ 484 V |
| 60947-1 7.2.7 | Application of the test voltage | |
| | Leakage current | |
| 8.3.3.2 | Test sequence I (in new condition) | $\leq 0.5 \text{ mA}$./ mA |
| 8.3.3.5 | Test sequence I (after overload performance) | $\leq 2 \text{ mA}$./ mA |
| 8.3.4.3 | Test sequence II | $\leq 2 \text{ mA}$./ mA |
| 8.3.5.3 | Test sequence III | $\leq 6 \text{ mA}$ 0.5 mA |
| 8.3.6.5 | Test sequence IV | $\leq 2 \text{ mA}$./ mA |
| 8.3.7.3 | Test sequence V, stage 1 | $\leq 2 \text{ mA}$./ mA |
| 8.3.7.7 | Test sequence V, stage 2 | $\leq 6 \text{ mA}$./ mA |
| 8.3.8.5 | Combined test sequence | $\leq 2 \text{ mA}$./ mA |
| C.3 | Individual pole short-circuit test sequence I_{SH} | $\leq 6 \text{ mA}$./ mA |
| H.3 | Individual pole short-circuit test sequence I_T | $\leq 6 \text{ mA}$./ mA |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | |
| | | Date August 19th 2005 |



СЕРТИФИКАТ
 АСЕФА

| ASEFA | | Test report No.: F01.04.20 Page 56 / 68 | |
|---|--|--|---------------------|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.11 | |
| Standard and clause | Kind of tests and requirements | Test values Results | |
| | VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY | | |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics | | |
| | Cable | ./. mm ² | ./. mm ² |
| | Bar | 100 x 5 mm | 100 x 5 mm |
| | Number | 2 | 2 |
| | Length | ./. mm | 500 mm |
| | Tightening torque | | 50 Nm |
| | Reference temperature | 40 °C ± 2 °C | |
| | Ambient temperature | | 18.4 °C |
| | Correction factor (k = 1 for releases independent of ambient temperature) k | | 1 |
| | Current setting value | I _n | 1600 A |
| | Test current | | |
| | either k x 2.0 x I _n | ./. A | ./. A |
| 8.3.5.1 | Test sequence II (I _{cs} = I _{cu}) | before 8.3.4.1 | |
| 8.3.5.1 | Test sequence III | before 8.3.5.2 | |
| 8.3.6.1 | Test sequence IV | before 8.3.6.2 | |
| 8.3.6.6 | Test sequence IV | after 8.3.6.5 | |
| 8.3.7.4 | Test sequence V | before 8.3.7.5 | |
| 8.3.8.1 | Combined test sequence | before 8.3.8.2 | |
| A.5 | Verification of discrimination | before 8.3.5.2 | |
| A.6.3 | Verification of back-up protection | before 8.3.5.2 | |
| | or k x 2.5 x I _n | 4000 A | 4000 A |
| 8.3.5.4 | Test sequence II (I _{cs} = I _{cu}) | after 8.3.4.5 | |
| 8.3.5.4 | Test sequence III | after 8.3.5.3 | |
| 8.3.7.8 | Test sequence V | after 8.3.7.7 | |
| 8.3.8.7 | Combined test sequence | after 8.3.8.6 | |
| A.5 | Verification of discrimination | after 8.3.5.3 | |
| A.6.3 | Verification of back-up protection | after 8.3.5.3 | |
| C.4 | Individual pole short-circuit test sequence | | |
| H.4 | Test sequence for circuit-breakers for IT-systems | | |
| | Tripping time (for twice the value of current setting on single pole) | | |
| | Neutral | ≤ 270 s | 137 s |
| | Ph ₁ | ≤ 270 s | 136 s |
| | Ph ₂ | ≤ 270 s | 132 s |
| | Ph ₃ | ≤ 270 s | 134 s |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | TRF IEC/EN 60947-2 Ed. 2.1 form 46 | |
| | | Date August 19th 2005 | |




| ASEFA | | Test report No.: F01.04.20 Page 57 / 68 | |
|--|---|--|---------------------|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.12 | |
| Standard and clause | Kind of tests and requirements | Test values Results | |
| VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY | | | |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics | | |
| | Cable | ./. mm ² | ./. mm ² |
| | Bar | 100 x 5 mm | 100 x 5 mm |
| | Number | 2 | 2 |
| | Length | ./. mm | 500 mm |
| | Tightening torque | | 50 Nm |
| | Reference temperature | 40 °C ± 2 °C | |
| | Ambient temperature | | 22.5 °C |
| | Correction factor (k = 1 for releases independent of ambient temperature) k | | 1 |
| | Current setting value | <i>I_n</i> | 1600 A |
| Test current | | | |
| | either $k \times 2.0 \times I_n$ | 3200 A | 3200 A |
| 8.3.5.1 | Test sequence II ($I_{cs} = I_{cu}$) | before 8.3.4.1 | |
| 8.3.5.1 | Test sequence III | before 8.3.5.2 | |
| 8.3.6.1 | Test sequence IV | before 8.3.6.2 | |
| 8.3.6.6 | Test sequence IV | after 8.3.6.5 | |
| 8.3.7.4 | Test sequence V | before 8.3.7.5 | |
| 8.3.8.1 | Combined test sequence | before 8.3.8.2 | |
| A.5 | Verification of discrimination | before 8.3.5.2 | |
| A.6.3 | Verification of back-up protection | before 8.3.5.2 | |
| | or $k \times 2.5 \times I_n$ | ./. A | ./. A |
| 8.3.5.4 | Test sequence II ($I_{cs} = I_{cu}$) | after 8.3.4.5 | |
| 8.3.5.4 | Test sequence III | after 8.3.5.3 | |
| 8.3.7.8 | Test sequence V | after 8.3.7.7 | |
| 8.3.8.7 | Combined test sequence | after 8.3.8.6 | |
| A.5 | Verification of discrimination | after 8.3.5.3 | |
| A.6.3 | Verification of back-up protection | after 8.3.5.3 | |
| C.4 | Individual pole short-circuit test sequence | | |
| H.4 | Test sequence for circuit-breakers for IT-systems | | |
| | Tripping time (for twice the value of current setting on single pole) | | |
| | Neutral | ≤ 270 s | 223 s |
| | Ph ₁ | ≤ 270 s | 230 s |
| | Ph ₂ | ≤ 270 s | 222 s |
| | Ph ₃ | ≤ 270 s | 227 s |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
Ed. 2.1 form 46

Date August 19th 2005




| ASEFA | | Test report No.: F01.04.20 Page 58 / 68 | |
|--|---|--|----------------|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.12 | |
| Standard and clause | Kind of tests and requirements | Test values Results | |
| 8.3.5.2 | RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY | | |
| | Utilization category | B | |
| | Rated operational voltage U_n | 690 V | |
| | Recovery voltage | $1.05 \times U_n$ | 724.5 V |
| | Rated ultimate short-circuit breaking capacity | I_{cu} | 42 kA |
| | Rated short-circuit making capacity | I_{cm} | 88.2 kA |
| Table 11 | Power factor | 0.25 | 0.25(+0,-0,05) |
| | Frequency | 50 Hz | 50 Hz |
| 8.3.2.1 | Control supply voltage | $0.85 \times U_n$./. V | ./. |
| 7.2.1.1.3 | Maximum value of the closing time | | ./. |
| | Sequence of operation | O - t - CO | O - t - CO |
| | Circuit diagram | | Page 66 |
| | Calibration of the test circuit | Pageform | Next page |
| | Safety area | Pageform | Page 65 |
| | Installation of the material tested | Pageform | Page 64 |
| | Energization direction | Top/Bottom | Bottom |
| 8.3.2.1 | Smallest individual enclosure (if applicable) | | |
| | Type | | ./. |
| | Kind of material | | ./. |
| | Inside dimensions | | |
| | Height | | ./. |
| | Width | | ./. |
| | Depth | | ./. |
| 60947-1 | Cabling characteristics | | |
| Table 9, 10 and 11 | Cable | ./. | ./. |
| | Bar | 100 x 5 mm | 100 x 10 mm |
| | Number | 2 | 1 |
| | Length | supply side | ./. |
| | | load side | ./. |
| | Tightening torque | | 50 Nm |


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2006

IEC/EN 60947-2
Ed. 2.1 (01) 47



| ASEFA | | Test report No.: F01.04.20 Page 59 / 68 |
|---|--|---|
| Type test according to: IEC 60947-2 | | Type: NS630bH to 1600H Sample 31042.12 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| 60947-1 8.3.4.1.5 | CALIBRATION OF THE TEST CIRCUIT | |
| | Oscillogram | 20040283-0141 20040283-0150 |
| | Applied voltage | 735,65 V |
| | Frequency | 50 Hz |
| | RMS current value at 20 ms | i_1 42.00 kA i_2 42.32 kA i_3 43.26 kA |
| | Average RMS. Value | 42.49 kA |
| | Peak current maximum value | 91.48 kA |
| | Power factor | 0,21 |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | TRF IEC/EN 60947-2 F02.1 form 109 Date August 19th 2005 |




| ASEFA | | Test report No.: F01.04.20 |
|---|--|--|
| | | Page 60 / 68 |
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.12 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | OPERATION "O" | |
| | Oscillogram | 20040283.0161 |
| | Peak current value | i_1 59.64 kA |
| | | i_2 71.74 kA |
| | | i_3 82.66 kA |
| | Maximum total duration | 21.05 ms |
| | Recovery voltage (phase to phase or phase to neutral) | $U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 732.16 V |
| | | $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 720.65 V |
| | | $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 735.93 V |
| | Average value | U_{rm} 729.58 V |
| | Ratio between U_{rm} and U_0 | U_{rm}/U_0 1.05 |
| | Joule integral | Ph_1 22.48 (kA) ² s |
| | | Ph_2 27.82 (kA) ² s |
| | | Ph_3 43.40 (kA) ² s |
| | Melting of the fusible element | Yes/No No |
| | Holes in the PE-sheet (if applicable) | Yes/No No |
| | Cracks observed | Yes/No No |
| | If Yes | Page ./. |
| | Time interval between operations | 3 min 4 min |
| | OPERATION "CO1" | |
| | Oscillogram | 20040283.0162 |
| | Applied voltage | 764.24 V |
| | Peak current value | i_1 77.04 kA |
| | | i_2 49.95 kA |
| | | i_3 75.50 kA |
| | Maximum total duration | 18.4 ms |
| | Recovery voltage (phase to phase or phase to neutral) | $U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 736.72 V |
| | | $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 727.47 V |
| | | $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 728.68 V |
| | Average value | U_{rm} 730.96 V |
| | Ratio between U_{rm} and U_0 | U_{rm}/U_0 1.05 |
| | Joule integral | Ph_1 36.63 (kA) ² s |
| | | Ph_2 18.67 (kA) ² s |
| | | Ph_3 31.43 (kA) ² s |
| 7.2.1.1.3 | Closing operation time | ./. ms |
| | Melting of the fusible element | Yes/No No |
| | Cracks observed | Yes/No No |
| | if Yes | |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | | Page 1/1 TRF IEC/EN 60947-2 Ed. 2.1 form 41 599 AC |
| | | Date August 19th 2005 |

| ASEFA | | Test report No.: F01.04.20 Page 61 / 68 |
|--|---|--|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.12 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF DIELECTRIC WITHSTAND | |
| | Test voltage | |
| | 2 x U _o , min. 1000 V | 1380 V |
| 8.3.3.5 | Test sequence I | |
| 8.3.4.3 | Test sequence II | |
| 8.3.5.3 | Test sequence III | 1380 V |
| 8.3.6.5 | Test sequence IV | |
| 8.3.7.3 | Test sequence V, stage 1 | |
| 8.3.7.7 | Test sequence V, stage 2 | |
| 8.3.8.5 | Combined test sequence | |
| B.10.3.1 | Test sequence B.II | |
| A.5 | Verification of discrimination | |
| A.6.3 | Verification of back-up protection | |
| C.3 | Individual pole short-circuit test sequence | |
| H.3 | Test sequence for circuit-breakers for IT-systems | |
| 8.3.3.2.2 a) | Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable) | |
| | Test duration | 5 s |
| | | 5 s |

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 10th 2005

TRF IEC/EN 60947-2
Ed. 2:1 form 32
modified





| ASEFA | | Test report No.: F01.04.20 Page 62 / 68 |
|--|--|--|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.12 |
| Standard and clause | Kind of tests and requirements | Test values Results |
| | VERIFICATION OF LEAKAGE CURRENT | |
| | For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V. | |
| 8.3.3.2 | - Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable) | |
| | Test voltage $1.1 \times U_o = 759 \text{ V}$ | 759 V |
| 60947-1 7.2.7 | Application of the test voltage | |
| | Leakage current | |
| 8.3.3.2 | Test sequence I (In new condition) | $\leq 0.5 \text{ mA}$ / mA |
| 8.3.3.5 | Test sequence I (after overload performance) | $\leq 2 \text{ mA}$ / mA |
| 8.3.4.3 | Test sequence II | $\leq 2 \text{ mA}$ / mA |
| 8.3.5.3 | Test sequence III | $\leq 6 \text{ mA}$ 0.5 mA |
| 8.3.6.5 | Test sequence IV | $\leq 2 \text{ mA}$ / mA |
| 8.3.7.3 | Test sequence V, stage 1 | $\leq 2 \text{ mA}$ / mA |
| 8.3.7.7 | Test sequence V, stage 2 | $\leq 6 \text{ mA}$ / mA |
| 8.3.8.5 | Combined test sequence | $\leq 2 \text{ mA}$ / mA |
| C.3 | Individual pole short-circuit test sequence I_{su} | $\leq 6 \text{ mA}$ / mA |
| H.3 | Individual pole short-circuit test sequence I_T | $\leq 6 \text{ mA}$ / mA |


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM




Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2.1 form 25



| ASEFA | | Test report No.: F01.04.20 Page 63 / 68 | |
|--|---|---|---------------------|
| Type test according to: IEC 60947-2 Test sequence III | | Type: NS630bH to 1600H Sample 31042.12 | |
| Standard and clause | Kind of tests and requirements | Test values Results | |
| VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY | | | |
| 60947-1 Table 9, 10 and 11 | Cabling characteristics | | |
| | Cable | ./. mm ² | ./. mm ² |
| | Bar | 100 x 5 mm | 100 x 5 mm |
| | Number | 2 | 2 |
| | Length | ./. mm | 3000 mm |
| | Tightening torque | | 50 Nm |
| | Reference temperature | 40 °C ± 2 °C | |
| | Ambient temperature | | 19.9 °C |
| | Correction factor (k = 1 for releases independent of ambient temperature) k | | 1 |
| | Current setting value | I _n | 1600 A |
| Test current | | | |
| | either k x 2.0 x I _n | ./. A | ./. A |
| 8.3.5.1 | Test sequence II (I _{cs} = I _{cu}) | before 8.3.4.1 | |
| 8.3.5.1 | Test sequence III | before 8.3.5.2 | |
| 8.3.6.1 | Test sequence IV | before 8.3.6.2 | |
| 8.3.6.6 | Test sequence IV | after 8.3.6.5 | |
| 8.3.7.4 | Test sequence V | before 8.3.7.5 | |
| 8.3.8.1 | Combined test sequence | before 8.3.8.2 | |
| A.5 | Verification of discrimination | before 8.3.5.2 | |
| A.6.3 | Verification of back-up protection | before 8.3.5.2 | |
| | or k x 2.5 x I _n | 4000 A | 4000 A |
| 8.3.5.4 | Test sequence II (I _{cs} = I _{cu}) | after 8.3.4.5 | |
| 8.3.5.4 | Test sequence III | after 8.3.5.3 | |
| 8.3.7.8 | Test sequence V | after 8.3.7.7 | |
| 8.3.8.7 | Combined test sequence | after 8.3.8.6 | |
| A.5 | Verification of discrimination | after 8.3.5.3 | |
| A.6.3 | Verification of back-up protection | after 8.3.5.3 | |
| C.4 | Individual pole short-circuit test sequence | | |
| H.4 | Test sequence for circuit-breakers for IT-systems | | |
| Tripping time (for twice the value of current setting on single pole) | | | |
| | Neutral | ≤ 270 s | 120 s |
| | Ph ₁ | ≤ 270 s | 118 s |
| | Ph ₂ | ≤ 270 s | 127 s |
| | Ph ₃ | ≤ 270 s | 132 s |
| Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM | |  | |
| Date August 19th 2005 | | | |


| | |
|--|---|
| ASEFA | Test report No.: F01.04.20 Page 64 / 68 |
| Type test according to: IEC 60947-2 Test sequence III | Type: NS630bH to 1600H |
| <p><u>INSTALLATION</u></p> <p>The apparatus is set up on a metallic structure, in individual enclosure, fixed on insulated bars. The safety perimeter is materialised by a metallic enclosure (see next page) connected to the neutral by a fuse.</p> <p>The apparatus are operated with an air actuator.</p> | |
| Test laboratory: F01 GRENOBLE ASEFA recognized PLATFORM | TRF IEC/EN 60947-2 Ed 2.1 from 170 Date August 19th 2005  |

| ASEFA | | Test report No.: F01.04.20 Page : 65 / 68 |
|-------------------------------------|---|---|
| Type test according to: IEC 60947-2 | | Type: NS630bH to 1600H |
| Standard and clause | Kind of tests and requirements | Test values Results |
| 60947-2 | <p>SAFETY AREA AND DETECTION OF THE FAULT CURRENT</p> <p>Characteristics of the metallic screen</p> <ul style="list-style-type: none"> - structure <ul style="list-style-type: none"> woven wire mesh ./. perforated metal ./. expanded metal Yes - ratio hole area / total area 0,45 - 0,65 ./. - size of hole $\leq 30 \text{ mm}^2$./. mm² - coating <ul style="list-style-type: none"> bare ./. conductive plating yes <div style="display: flex; justify-content: space-around; align-items: center;">   </div> <p>Detection of the fault current</p> <ul style="list-style-type: none"> - prospective fault current in the fusible element circuit 50 A - fusible element <ul style="list-style-type: none"> . diameter of copper wire 0.1 mm . length 100 mm or . equivalent fusible element / | <p>Top : 120 mm</p> <p>Left : 10 mm</p> <p>Right : 10 mm</p> <p>Bottom : 120 mm</p> <p>Front : 0 mm</p> <p>Back : 0 mm</p> |
| | <p>Test laboratory: F01 GRENOBLE</p> <p>ASEFA recognized PLATFORM</p> | <p style="text-align: center;">  Date August 16th 2005 </p> |


| | |
|-------------------------------------|--|
| ASEFA | Test report No.: F01.04.20 Page : 66 / 68 |
| Type test according to: IEC 60947-2 | Type: NS630bH to 1600H |

DIAGRAM OF THE TEST CIRCUIT

TEST OF RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY



VERIFICATION OF OPERATIONAL CAPABILITY



Test laboratory: F01 - GRENOBLE
 ASEFA recognised PLATFORM



TRF IEC/EN 60947-2
 Ed 2.1 form 1

Date August 19th 2008

**ВНЕШНЕЕ
 ОПИШНАТА**


ASEFA

Test report No.: F01.04.20
Page 67 / 68


Type test according to: IEC 60947-2
Test sequence III

Type: NS630bH to 1600H

PHOTOGRAPHIE OF THE ASSEMBLY



Test laboratory: F01 - GRENOBLE
ASEFA recognised PLATFORM




TRF IEC/EN 60947-2
Ed 2.1 for 1970


Date August 19th 2000

БІЛІМ С
ОПТИМАЛІА

GENERAL VIEW - FIGURE 1



**ВАРНО С
ОРИГИНАЛА**



| OFF (1) | In (A) | 800 | 2000 | 4000 | 5000 | 6300 |
|---------|--------|-------|------|------|--------|------|
| N1 | | 42 kA | | | | |
| H1 | | | 76 | | 100 kA | |
| H2 | | 82 kA | | | 120 kA | |
| H3 | | | | | | |
| L1 | | | | | | |

| | | | | |
|--|-------------|---|-------------------|----------|
| 02 | 09/06/99 | Rajout des crans 0 à 0,4 | JOUBERT | GRELIER |
| Ind / Rev | Date / Date | Modification / Modification | Non/Name | Non/Name |
| | | | Visa | Visa |
| | | | Archiv / Microfil | |
| Projet / Projet: Compact NS630b à NS1600 | | DISJONCTEUR FIXE ET DEBROCHABLE | | |
| Dossier / Folder: | | Courbe de déclenchement pour déclencheurs Micrologie 5.0, 6.0, 7.0, 8.0, 9.0, 10.0, 12.0, 15.0, 20.0, 25.0, 30.0, 40.0, 50.0, 63.0, 80.0, 100.0, 125.0, 160.0, 200.0, 250.0, 315.0, 400.0, 500.0, 630.0, 800.0, 1000.0, 1250.0, 1600.0, 2000.0, 2500.0, 3150.0, 4000.0, 5000.0, 6300.0, 8000.0, 10000.0 | | |
| Code diff. / Dis'rib. code | | 5 1 1 5 6 7 4 A A | | |
| Unité / Département | | DBTP | | |
| Ind/Rev | | 0 1 | | |
| Folio/Sheet | | 1 | | |



BAPHA C OPIHHAJA

150,00 ms


12,00 ms/cm

10,00 ms

450,00 ms


Calibration of the test circuit current

42kA 88kA 236V+5% cosφ0.25



U12 599,00 V/cm

**ВЯНО С
ОРИГНАЛА**



450.00 ms


150.00 ms

12.00 ms/cm

10.00 ms

Calibration of the test circuit V


42KA 88kA 236V+5% COS0.25



U12

399.00 V/cm

**ВЪРНО С
ОРИГИНАЛА**



CATIE V.1.5.129 page 001

F01 20040283 - 0103

Effectué le 06/12/2004 17:28:55
Edité le 06/12/2004 17:52:59


12,00 ms/cm

150,00 ms

10,00 ms

O ASEFA 31042 Sample05

42KA 88KA 235V+5% COS0.25



U12
399,00 V/cm



БРФО С
ОПМТНАТА

F01 20040283 - 0104

Effectué le 06/12/2004 17:55:48
Edité le 06/12/2004 18:10:57

450.00 ms


150.00 ms

12.00 ms/cm

10.00 ms

CO ASEFA 31042 Sample 05


42KA 88KA 256V+5% COS0.25



U12

399.00 V/cm

OPMATHAMA
BPHO C



CMTE.V15.2.129 page 001

F01 20040283 - 0105


Effectué le 06/12/2004 18:05:36
Edité le 06/12/2004 18:09:46

8,00 ms/cm
20,00 ms
10,00 ms

220,00 mts

O ASEFA 31042 Sample 05

42KA 88KA 236V+5% COS0.25



ВРНО С
ОПМТНАЛНА



F01 20040283 - 0106

Effectué le 06/12/2004 19:07:47
Edité le 06/12/2004 19:12:55

420,00 ms


120,00 ms

12,00 ms/cm

10,00 ms

CO ASEFA 31042 Sample 06

42kA 88kA 236V+5% cos0.25




U12

599,00 V/cm

Effectué le 06/12/2004 19:11:09
Edité le 06/12/2004 19:12:06

F01 20040283 - 0107

ОПЕРАТОР
СЕРИЯ С
КАРТЕ



page 129

100,00 ms


400,00 ms

12,00 ms/cm


10,00 ms

Calibr. test circuit Voltage

cir mono: 39kA 82kA 254V+5% cos0.25



U12
198.00 V/cm



OPMIMHATA
BPHO C

F01 20040283 - 0108

Effectué le 07/12/2004 07:59:18
Edité le 18/08/2005 11:17:08



CATIE V.1.5.3.129 page 88

400,00 rms

Calibr. test circuit I

cir mono: 39kA 82kA 254V+5% cos0.25

200,00 ms
8,00 ms/cm
10,00 ms



Effectué le 07/12/2004 08:47:42
Edité le 18/08/2005 11:18:12



F01 20040283 - 0113

8.00 ms/cm
10.00 ms

400.00 ms

O ASEFA : N° 31042 sample N° 7

cir mono: 59KA 82kA 254V+5% cos0.25



F01 20040283 - 0116

Effectué le 07/12/2004 09:08:11
Edité le 18/08/2005 11:18:54

400.00 ms


200.00 ms

8.00 ms/cm

10.00 ms

CO ASEFA : N° 31042 sample N° 7

cir mono: 59KA 82kA 254V+5% cos0.25



I1 19.96 kA/cm

U12 198.00 V/cm



**БРНО С
ОПТИМАЛНА**

Effectué le 07/12/2004 09:10:47
Edité le 18/08/2005 11:16:45



F01 20040283 - 0117

8,00 ms/cm
200,00 ms
10,00 ms

400,00 ms

Calibr. test circuit voltage

cir mono: 25.2kA 53kA 398V+5% COS0.25



ОПТИКА
УПРАВЛЕНИЕ

F01 20040283 - 0119

Effectué le 07/12/2004 10:13:41
Edité le 18/03/2005 11:19:57

400.00 ms


200.00 ms

8.00 ms/cm

10.00 ms

Calibr. test circuit I

cir mono: 25.2kA 53kA 398V+5% COS0.25



ВРФО С
ОПМТНАМА



Effectué le 07/12/2004 10:46:32
Edité le 18/08/2005 11:20:29

F01 20040283 - 0122

400.00 ms

O ASEFA n° 31042 sample n° 8


cir mono: 25.2kA 53kA 398V+5% cos0.25

200.00 ms

8.00 ms/cm

10.00 ms

39.96 kV/cm



U12

396.00 V/cm

БРПО С
ОПТИМАЛ



400,00 ms


200,00 ms

8,00 ms/cm

10,00 ms

CO ASEFA n° 31042 sample n° 8

цир моно: 25.2kA 53kA 398V+5% cos0.25



100 500 2kA/cm

U12

596,00 V/cm

**БЮРО С
ДИПТИНАМА**



F01 20040283 - 0124




Effectué le 07/12/2004 11:02:15
Ecrité le 18/08/2005 11:21:15

150.00 ms

10.00 ms/cm

Calibr. test circuit U

70KA-154kA-415+5%-COS 0.20



ОПТИМАЛ
КАРГО С



VOLTA 20040288 - 0003

Effectué le 06/12/2004 07:19:29
Edité le 18/08/2005 11:27:52

400,00 ms



200,00 ms

8,00 ms/cm

10,00 ms

Calibr. test circuit I

70KA-154KA-415+5%-COS 0.20







Effectué le 06/12/2004 07:55:04
Edité le 18/08/2005 11:28:12

F01 20040288 - 0007

8,00 ms/cm
200,00 ms
10,00 ms

O NS1600H
70kA - 415V

400,00 ms



БРПН С
ОПМТНАТА

F01 20040288 - 0011

Effectué le 06/12/2004 09:28:17
Edité le 18/08/2005 11:28:59

400.00 ms




200.00 ms

8.00 ms/cm


10.00 ms

CO NS1600H

70KA - 415V



BRHD C
OPM/MTALIA



Effectué le 06/12/2004 09:51:18
Edité le 18/08/2005 11:29:28

F01 20040288 - 0012

400.00 ms





ASEFA 31042 Sample 10

NS630bH

200.00 ms

8.00 ms/cm

10.00 ms



БРОД С
ОПШТИНА

F01 20040288 - 0013

Effectué le 06/12/2004 10:21:48
Edité le 18/08/2005 11:30:12

400,00 ms




200,00 ms

8,00 ms/cm

10,00 ms

Calibr. test circuit U

65KA-143KA-440+5%-COS 0.20



OPREDELJENJE
BRNO C

VOLTA 20040288 - 0015

CATHE-V.1.5.3.129 page.001

Effectué le 06/12/2004 11:16:11
 Edité le 18/08/2005 11:52:55

400,00 ms


200,00 ms

8,00 ms/cm


10,00 ms

Calibr. test circuit I

65KA-143KA-440+5%-COS 0.20



OPMTRALTA
BPRHO C



Effectué le 06/12/2004 11:58:38
Edité le 18/08/2005 11:52:49

VOLTA 20040288 - 0018





400,00 ms

ASEFA 31042 Sample 11

200,00 ms

8,00 ms/cm

10,00 ms






F01 20040288 - 0019

Effectué le 06/12/2004 12:15:58
Edité le 18/08/2005 11:55:06

400.00 RMS


CO1 ASEFA 31042 Sample 11

8.00 ms/cm
200.00 ms
10.00 ms



Effectué le 06/12/2004 12:18:45
Edité le 18/08/2005 11:53:33

F01 20040288 - 0020



400,00 ms





Calibration of the test circuit U

cir tri: 42kA - 88.2kA - 690V+5% - cos0.25

200,00 ms

8,00 ms/cm

10,00 ms



ВЕРИМО
ОПРЕДЕЛЕНА

F01 20040283 - 0141

Effectué le 06/01/2005 16:24:45
Edité le 18/08/2005 11:23:27


КМТЭК ДОД - БНАРИЯ
УЛ. ТИШИНСКА 129 page 001

400,00 ms

Calibration of the test circuit current


cir tfr: 42kA - 88.2kA - 690V+5% - cos0.25

200,00 ms
8,00 ms/cm
10,00 ms



19.99 kA/cm

19.99 kA/cm



OPM/THAJIA
BSPRO G

Effectué le 06/01/2005 17:56:20
Edité le 18/08/2005 11:23:45



F01 20040283 - 0150

8.00 ms/cm
200.00 ms
10.00 ms

400.00 ms

Opening ASEFA 31.042 Sample 12

cir trif: 42kA 88.2kA 690V+5% cos0.25



BUREAU CENTRAL DE METROLOGIE
ROMANIA
CARTI V. 129 page 001

F01 20040283 - 0161

Effectué le 10/01/2005 09:24:51
Edité le 18/08/2005 11:24:37

400.00 ms


200.00 ms

10.00 ms

8.00 ms/cm


Closing ASEFA 31.042 Sample 12

cir tri: 42kA 88.2kA 690V+5% cos0.25



15
 10.00 mA/cm
 U12
 510.00 V/cm

17
 10.00 mA/cm
 U23
 515.00 V/cm



BUREAU CENTRAL DE METROLOGIE

F01 20040283 - 0162

Effectué le 10/01/2005 09:28:17
Ecrité le 18/08/2005 11:25:17



Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

Списък на проведените изпитвания на Триполюсни автоматични прекъсвачи НН с лят корпус, от 160 А до 1250 А, с електронна защита, категория А

1. Капацитет на пробив при номинално късо съединение;
2. Претоварване;
3. Диелектрична якост;
4. Ток на утечка;

13.01.2016г.

Подпис и печат





TRANSLATION AGENCY

50 Hristo Smirnenski Blvd.
1164, Sofia, Bulgaria

T +359 2 9804090
F +359 2 9817160
office@greg-bg.com
www.greg-bg.com

Превод от френски на български език

COFRAC

Френски комитет за акредитация
Сертифициране на индустриални продукти и услуги

ДИПЛОМА ЗА АКРЕДИТАЦИЯ

Настоящият документ удостоверява, че

ASEFA

Бул. Женеерал Льоуклер 33 – 92260 ФОНТЪОНЕ О РОЗ, Седекс

е акредитирано съгласно норма NF EN 4501 I и правилата за прилагане на Френския комитет за акредитация относно

Сертифициране посредством проби на устройства тип електрически и/или електронни под номер 5-0037

Обхватът и валидността на акредитацията са уточнени в удостоверението или влязлото в сила изменение.
По време на този период, организацията се ангажира да спазва във всеки момент изискванията на акредитацията.

Издадено в Париж на 15 декември 2002 година


Председател на секционен комитет: подпис не се чете

Директор на Френски комитет за акредитация: подпис не се чете

Долуподписаният, Светомир Радков Минчев, удостоверявам верността на извършения от мен превод от френски на български език на настоящия документ: Акредитация. Преводът се състои от 1 страница.


Подпис:

Светомир Радков Минчев



D'ACCREDITATION

cofrac



**CERTIFICATION PRODUITS
INDUSTRIELS & SERVICES**

Diplôme d'Accréditation

Ce document atteste que :

ASEPA

33, avenue du Général Leclerc - 92260 FONTENAY AUX ROSES Cedex

est accréditée selon la norme NF EN 45011 et les règles d'application du COFRAC pour la
Certification par essai de type des dispositifs électriques et/ou électroniques
sous le numéro **5-0037**

*La portée et la validité de l'accréditation sont précisées dans l'attestation ou
l'avenant en vigueur qui lui a été délivré. Durant cette période, l'organisme s'engage à respecter à tout moment
les exigences de l'accréditation.*

Fait à Paris, le 15 décembre 2002

Le Président
du Comité de section :

Le Directeur du COFRAC :



REPORT OF PERFORMANCE

CLIENT EFAGEC ENERGIA Máquinas e Equipamentos Eléctricos, S.A.
S. Mamede de Infesta, Portugal

MANUFACTURER EFAGEC ENERGIA Máquinas e Equipamentos Eléctricos, S.A.
S. Mamede de Infesta, Portugal

APPARATUS A three-phase SF₆ switch as part of an SF₆-insulated ring main unit type Fluorix GC7F

DESIGNATION ISRG

RATINGS ASSIGNED BY THE MANUFACTURER

| | | | | | | |
|----------------------------|-------|----|--|-------|-----|------------|
| Voltage | 24 | KV | Making current at | 24 KV | 40 | kApeak |
| Normal current | 630 | A | Short-time current | | | |
| Frequency | 50 | Hz | Peak value | | 40 | kApeak |
| Number of poles | 3 | | rms value | 16 | kA | during 3 s |
| Breaking current at | 24 KV | | SF ₆ -insulation pressure at 20°C | | 1.3 | bar(abs) |
| Mainly active load | 630 | A | | | | |
| Cable-charging | 25 | A | | | | |
| Closed loop | 630 | A | | | | |
| First-pole-to-clear factor | 1.5 | | | | | |

The tests have been carried out in accordance with the client's instructions.

Date of tests 19th November 1988

The performance of the apparatus tested and the observations made during the tests have been recorded in the tables with test results and the oscillograms

THIS REPORT CONSISTS OF:

| | |
|------------------|------|
| Pages | 13 |
| Circuit diagrams | 1 |
| Oscillograms | 8 |
| Drawings | 14 |
| Photographs | 6 |
| Summary sheet | B70E |

© Copyright: Publication or reproduction of the contents of this report in any other form than a complete copy to the letter, is not allowed without our written consent.



KEMA Nederland B.V.

A.L.J. Jansen
Arnhem, January 1989



| TYPE OF TEST | COMPONENT | POSITION | PAGE |
|------------------------------|-----------|----------------|------|
| No-load test | Switch(S) | Line position | 4 |
| Short-circuit making test | | | 5 |
| No-load test | | | 6 |
| Short-circuit making test | | | 7 |
| No-load test | | | 8 |
| No-load test | | Earth position | 9 |
| Short-circuit breaking tests | | | 10 |
| No-load test | | | 11 |
| Short-circuit making test | | | 12 |
| No-load test | | | 13 |

The tests were witnessed by:

Name:

Carvalho, M.
Martins, J.
Martins, M.

Company:

EFACEC ENERGIA, Máquinas e Equipamentos Eléctricos, S.A.,
S. Mamede de Infésia, Portugal

The tests were observed by:

Name:

Bronsveld, A.J.

Company:

KEMA,
Arnhem, The Netherlands

Drawings:

The manufacturer has guaranteed that the equipment submitted for tests has been manufactured in accordance with the following drawings.

KEMA has verified that these drawings adequately represent the equipment tested.

- EMT598697 Rev. 0
- EMT698696 Rev. 0
- EMT598692 sheet 1 of 2 Rev. 0
- EMT598692 sheet 2 of 2 Rev. 0
- EMT598693 Rev. 0
- EMT598698 Rev. 0
- AMT598140 Rev. 0
- DMT598138 Rev. 0
- DMT598139 Rev. 0
- EMT598006 Rev. 0
- DMT598008 Rev. 0
- EMT695514 Rev. 0
- CMT695129 Rev. b
- DMT696014 Rev. 0


Photographs

- 858405
- 858406
- 858806 to 858809.

Note:


On request of the client the test parameters of this report were based on a rated voltage of 12 kV and a rated making current of 63 kA peak.

ВЕРИТЕЛНО
ОПРЕДЕЛЕНИЕ



TEST ARRANGEMENT

RMU



S1, S2, S3: (SFG) three-position switch-disconnector (line / open / earth)

ВЪВЕДНО
ОПИСАНИЕ
С ЧЕРТЕЖ




TABLE WITH NO. LOAD TEST RESULTS


REPORT 710-98 PAGE 8
 SFG - Insulation resistance at 20 °C: 120.5 MΩ (above)

Data of mechanical independent manual closing (openings):
 For test purposes operated by robot.

Condition before test: Unit in service condition. Right-hand switch (S1) under test. Switch operating in line position.

| Date and test | Operation and time interval | Voltage closing coil | Current closing coil | Closing time | Voltage opening coil | Current opening coil | Opening time | Opening pressure | SF ₆ insulation pressure at 20 °C | Remarks |
|---------------|-----------------------------|----------------------|----------------------|--------------|----------------------|----------------------|--------------|------------------|--|---------|
| | | V | A | ms | V | A | ms | bar | MPa (abs) | |
| 981119-4042 | ⊙ | | | | | | | | 1.23 | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |

Data of travel recorder: Attached to main contact shaft; Non-linear with contact travel.



ВЪПРОС
 ОТВЕТА
 L1
 L2

KEMET

TABLE WITH NO LOAD TEST RESULTS

REPORT NO. 581119 PAGE 13
 SFG - insulation pressure at 20°C (13 bar/189)
 Data of mechanism: (dependent on actual closing sequence)
 For test purposes operated by robot

Condition before tests: Unit in same condition; Right-hand system (S) under test; Switch opening for earth position.

| Date and test | Operation time interval | Voltage closing coil | Current closing coil | Closing time | Voltage opening coil | Current opening coil | Opening time | Operating pressure | SFG insulation pressure at 20°C (bar/abs) | Remarks |
|---------------|-------------------------|----------------------|----------------------|--------------|----------------------|----------------------|--------------|--------------------|---|---------|
| 581119, 4050 | ⊙ | V | A | ms | V | A | ms | bar | 1.3 | (1) |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |

Conductor in position: Photograph 58406.
 Fixed and moving contacts line position: moderately burnt, moderately burnt, moderately burnt. Photographs 58407, 58408, 58409.
 Date of travel record: Switches to main contact shut. Non-fused with contact travel.
 (1) No oscillogram due to failure of recorder.
 BRITISH KEMEX ELECTRIC CO. LTD.
 BRUNNEN
 PHOTOGRAPHIC SERVICES
 If values are given they are to be read: L1, L2, L3

