

TEST REPORT
DENEY RAPORU

Customer Name : Nikdim LTD.
Müşterinin Adı
Customer Address : 80, 23-rd Pehoten Shipchenski polk blvd. 6100 Kananlak, Bulgaria
Müşterinin Adresi
Description of Sample : 12 kV Indoor Type Post Insulator
Nümunenin Tanımı
Trade Mark / Type : Nikdim / PAK-10
Marka / Tip
Test(s) Performed : Dry Lightning-Impulse Withstand Voltage Test
Yapılan Deney(ler) : Dry Power-Frequency Withstand Voltage Test
Test Standart(s) : IEC 60168: 1994 + A1: 1997 + A2: 2000
Deney Standart(lar)ı
Serial Number(s) : 9511101 / T2
Seri No(lar)
Reception Date of Sample : 15.07.2017
Numune Kabul Tarihi
Test Date(s) : 15.07.2017
Deney Tarih(ler)i
Number of Pages of the Report : 14
Raporun Sayfa Sayısı
Test(s) Result(s) : Passed / Geçti Failed / Geçmedi Other / Diğer
Deney Sonuçları

HILKAR is accredited by TÜRKAK under registration number AB-0665-T for TS EN ISO IEC 17025:2012 as test laboratory.

Deney Laboratuvarı olarak faaliyet gösteren HILKAR, TÜRKAK'tan AB-0665-T ile TS EN ISO IEC 17025:2012 standardına göre akredite edilmiştir.

The Turkish Accreditation Agency (TURKAK) is a signatory to the European co-operation for the Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.

Türk Akreditasyon Kurumu (TÜRKAK) deney raporlarının tanınırlığı konusunda Avrupa Akreditasyon Birliği (EA) ile Çok Taraflı Anlaşma ve Uluslararası Laboratuvar Akreditasyon Birliği (ILAC) ile karşılıklı tanıma antlaşması imzalamıştır.

The test and/or measurements results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Deney ve/veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metotları, bu sertifikanın tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.



Date
Tarih

10.08.2017

Person in Charge of Test
Deney Sorumlusu
Laboratory Technician

M. Kaya

На основание чл.2 от ЗЗЛД

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

Bu rapor, Laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürlü raporlar geçersizdir.

FRM.11 / REV03 / 06.2017

Sayfa / Page 1 / 14

ВЯРНО С ОРИГИНАЛА

1. IDENTIFICATION OF THE TEST SAMPLE:

Description of the Sample : 12 kV Indoor Type Post Insulator
Trade Mark / Type : Nikdim / PAK-10
Serial Number : 9511101 / T2
Technical Specification / Drawing : See the Clause 5
Contract No : FT.DNY-07.003.2017
Product Condition at Arrival : New

2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Manufacturer : Nikdim
Type : PAK-10
Rated Voltage : 12 kV
Power Frequency Withstand Voltage : 38 kV
Lightning Impulse Withstand Voltage : 75 kV
Creepage Distance : 11,3 mm / kV
Material : Porcelain C110
Color of Glaze : White
Dimensions : See the Clause 5

3. TEST(S) PROGRAM:


Witnessed By : Mr. Dechko Dechev
Dry Lightning-Impulse Withstand Voltage Test : IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5
Dry Power-Frequency Withstand Voltage Test : IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7

4. APPLIED TEST(S):

- Test results are only belong to the tested sample.
- The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$ which for a normal distribution corresponds to a coverage probability of approximately 95 %.

4.1 Dry Lightning-Impulse Withstand Voltage Test:

- 4.1.1 Sample Standard : IEC 60168: 1994 + A1: 1997 + A2: 2000
IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5
- 4.1.2 Test Standard : IEC 60060-1: 2010 Clause 7
IEC 60273: 1990
- 4.1.3 Equipment Used : BHT / Lightning Impulse Test System (K003)
Madgetech / Environmental Conditions Recorder (K274)
- 4.1.4 Environmental Conditions : Ambient Temperature : 26,6 °C
Ambient Humidity : 64,3 %RH
Air Pressure : 1007,9 mbar
- 4.1.5 Test Circuit Diagram :



- IG : Darbe Jeneratörü / Impulse Generator
VD : Hibrit Gerilim Bölücü / Hybrid Voltage Divider
T : Yükseltici Trafo / Step-up Transformer
F : Metal Gövde / Frame

Deney Numunesi / Test Sample

4.1.6 Test Criteria and Measurement Results:


S. No	Voltage Ut Applied to	Earth Connected to	Insulated from Earth	Test Voltage (%)	Test Voltage (kV/peak) (75 kV/peak ±%3)	Peak Time t ₁ (µs) (1,2 µs ± 30 %)	Tail Time t ₂ (µs) (50 µs ± 20 %)	Result(s)
1	Top of Insulator	Mounting Face of Insulator		50-80	52,45	1,315	48,46	
					67,27 ¹⁾	1,183	51,11	Affirmative <input type="checkbox"/> Negative <input checked="" type="checkbox"/>
				100	71,78 ¹⁾	1,171	52,04	Affirmative <input type="checkbox"/> Negative <input checked="" type="checkbox"/>
					72,21 ¹⁾	1,116	51,71	Affirmative <input type="checkbox"/> Negative <input checked="" type="checkbox"/>
					74,95	1,140	51,72	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					74,52	1,097	51,96	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					74,82	1,193	51,68	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					76,48	1,178	52,09	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					75,97	1,196	51,88	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					76,61	1,262	51,67	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					76,10	1,176	51,99	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					75,47	1,171	52,06	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					74,90	1,203	51,99	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					75,35	1,205	51,91	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					75,76	1,164	52,14	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					75,46	1,148	52,32	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					74,65	1,149	51,66	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					74,68	1,125	52,08	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
75,81	1,200	51,51	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>					
2				50-80	-51,21	1,297	48,82	
					-75,12	1,155	51,04	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
				100	-75,67	1,183	51,00	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-75,69	1,194	50,33	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-75,63	1,207	51,53	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-75,44	1,209	51,80	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-75,84	1,190	51,69	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-76,03	1,184	51,03	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-76,22	1,256	51,02	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-75,94	1,210	51,67	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-74,22	1,149	51,51	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-76,52	1,281	51,17	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-74,38	1,117	51,70	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-75,84	1,176	52,21	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					-74,86	1,208	51,85	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
-75,97	1,214	51,71	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>					

Remarks:

1) Out of voltage tolerance, additional impulses were applied instead.

4.1.7 Oscillograms:

4.1.7.1 S. No:1 / Positive Impulses




Handwritten signature


Handwritten signature

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.


ВЕРНО С ОРИГИНАЛА

Handwritten signature and circular stamp







4.1.7.2 S. No:2 / Negative Impulses



This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

ВЕРНО С ОРИГИНАЛА





4.1.8 Remarks, Comments and Statements of Compliance:


- Test voltage were applied as per IEC 60273:1990 Table-1
- Tests were applied without considering atmospheric correction.
- Measurement Uncertainty of K003: U_1 : 2,206% t_1 : 4,791 % t_2 : 2,620%
- The insulator was mounted vertically upright on a horizontal earthed metal support consisting of a U-channel section with the flanges pointing downwards which has a width about equal to the diameter of the mounting face of the insulator and a length longer than twice the height of the insulator, and was placed 1,1 m above ground.
- A cylindrical conductor, maintained in the horizontal plane and perpendicular to the earthed support, was attached to the top of the insulator. The length of the conductor was longer than 1,5 times the height of the insulator and it was extended 1 m on each side of the insulator axis. The diameter of the conductor was 30 mm.
- 12 kV indoor type post insulator with Nikdim brand, PAK-10 type and 9511101 / T2 serial number, has been tested and passed successfully to the Dry Lightning-Impulse Withstand Voltage Test as per IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5 the withstand voltage procedure.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

ВАРНО С ОРИГИНАЛА

4.2 Dry Power-Frequency Withstand Voltage Test:

- 4.1.1 Sample Standard : IEC 60168: 1994 + A1: 1997 + A2: 2000
IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7
- 4.1.2 Test Standard : IEC 60060-1: 2010 Clause 6
IEC 60273: 1990
- 4.1.3 Equipment Used : Baur / 100 kVac High Voltage Test System (K001)
Madgetech / Environmental Conditions of the Recorder (K274)
- 4.1.4 Environmental Conditions : Ambient Temperature : 26,6 °C
Ambient Humidity : 64,3 %RH
Air Pressure : 1007,9 mbar
- 4.1.5 Test Circuit Diagram :



4.2.5 Test Criteria and Measurement Results:


S. No	Voltage Ut Applied to	Earth Connected to	Insulated from Earth	Test Voltage (kVrms) (28 kVrms ±%1)	Frequency (Hz)	Time (sec.)	Result(s)	
1	Top of Insulator	Mounting Face of Insulator	-	38,12	50	60	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>

4.2.6 Remarks, Comments and Statements of Compliance:

- Test voltage were applied as per IEC 60273:1990 Table-1
- Tests were applied without considering atmospheric correction.
- Measurement Uncertainty of K001: U_c : 1,409%
- The post insulator was mounted vertically upright on a horizontal earthed metal support consisting of a U-channel section with the flanges pointing downwards which has a width about equal to the diameter of the mounting face of the insulator and a length longer than twice the height of the insulator, and was placed 1,1 m above ground.
- A cylindrical conductor, maintained in the horizontal plane and perpendicular to the earthed support, was attached to the top of the insulator. The length of the conductor was longer than 1,5 times the height of the insulator and it was extended 1 m on each side of the insulator axis. The diameter of the conductor was 30 mm.
- 12 kV indoor type post insulator with Nikdim brand, PAK-10 type and 9511101 / T2 serial number, has been tested and passed successfully to the Dry Power-Frequency Withstand Voltage Test as per IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.



5. TECHNICAL DRAWING(S) of the TEST SAMPLE:



1. Material: porcelain C110 according to IEC 60672.
2. Colour of glaze - white,
3. Maximum working voltage - 12 kV,
4. The general tolerances are according to DIN 40680,
5. Electrical parameters according to IEC 60168.


				ND 92.12.00.00				
Alter	Number	No of circums	Signature	Date	Support Insulators for indoor mounting type PAK 10	Stage	Mass	Maçıaş
Developed		İbâv						1:1
Controlled		Dörov				Sheet 1	As sheet 1	
Controlled		Dongv				"NIKDIM" OOD		

6. PHOTO(S) of the TEST SAMPLE:



This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

ВЯРНО С ОРИГИНАЛА





NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA
HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA

Matriculation certificate: J16/312/1999, VAT number: RO3871599

Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890

www.icmet.ro; E-mail: market@icmet.ro



TEST REPORT
No. 45966 / 11.08.2017


1. CUSTOMER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
2. MANUFACTURER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
3. TESTED PRODUCT:	Indoor Post Insulator type PAK 10
4. REFERENCE STANDARD:	Customer requirements (IEC 60168:2001, clause 5.2.4)
5. PERFORMED TESTS:	Mechanical failing load test. Bending test
6. TEST DATE:	10.08.2017
7. TEST RESULTS:	The product passed the test.

The test report contains 5 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies 2, 3, 4 are sent to the customer.

HEAD OF HVD – TECHNICAL MANAGER,

HEAD OF TESTING TEAM,

Dipl. E На основание чл.2 от ЗЗЛД



Warnings:

- The results refer only to the tested product.
- Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- All signatures of the present report are original ones.

ВЯРНО С ОРИГИНАЛА

Cod F-01.22.01(e)
© ICMET Craiova – 2017



CONTENT

1. Identification of the test product	page 3
2. Technical characteristics established by manufacturer	page 3
3. Tests program	page 3
4. Responsible for test	page 3
5. Present at the test	page 3
6. Tests description and test results presentation	page 4
Annex	page 5

**1. IDENTIFICATION OF THE TEST PRODUCT**

Type:	PAK 10
Serial / year:	2011
Technical Specification / Drawing:	Drawing no. ND 92.12.00.00 - Support insulators for indoor mounting type PAK 10
Contract / Test order:	705.2/876/03.08.2017
Internal test order:	23362/07.08.2017
Product receiving date:	08.08.2017
Product condition at receiving:	New

2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER

Maximum working voltage	12 kV
Mechanical failing load	4000 N (indicated by the customer)

3. TESTS PROGRAM

Mechanical failing load test. Bending test

Customer requirements
(IEC 60168:2001, clause 5.2.4)**4. RESPONSIBLE FOR TEST**

Dipl. Eng. Luminita Tascau

5. PRESENT AT THE TEST**ВЯРНО С ОРИГИНАЛА**

Cod F-01.22.01(e)
© ICMET Craiova - 2017

6. MECHANICAL FAILING LOAD TEST. BENDING TEST

Test date:	10.08.2017
Test standard:	Customer requirements (IEC 60168:2001, clause 5.2.4)
Atmospheric conditions:	t = 28 °C; RH = 53%
Equipment used:	<ul style="list-style-type: none">• Manual lever hoist SAFETEX 3000 kg, manufacturer SC Delta Flex SRL Bucuresti• Tension load cell, model CTL 1000 kg, serial no. 201106182, manufacturer LAUMAS ELECTRONICA Italy, CC no. F - 03/329/2017, SC GELUTECH Laboratory of Forces SRL
Test procedure:	The post insulator was subjected to a bending load to verify the mechanical failing load of 4000 N as specified in Annex 1 to the contract. The load was applied perpendicular to the axis of the post insulator, to the free end (see Photo 1). The specified bending load was reached.
Test results:	The product passed the test.





Photo 1

Annex 1



1. Material: porcelain C110 according to IEC 60672.
2. Colour of glaze - white.
3. Maximum working voltage - 12 kV.
4. The general tolerances are according to DIN 40680.
5. Electrical parameters according to IEC 60168.

					ND 92.12.00.00			
Alter	№	№ of docum.	Signature	Date	Support insulators for indoor mounting type PAK 10	Stage	Mass	Мащаб
Developed		Iliev						1:1
Controlled		Donev				Sheet 1	All sheet 1	
Controlled		Donev				"NIKDIM" OOD		

-- End of test report --

ВЯРНО С ОРИГИНАЛА



TEST REPORT
DENEY RAPORU

Customer Name : Nikdim LTD.
Müşterinin Adı
Customer Address : 80, 23-rd Pehoten Shipchenski polk blvd. 6100 Kananlak, Bulgaria
Müşterinin Adresi
Description of Sample : 12 kV Indoor Type Post Insulator
Numunenin Tanımı
Trade Mark / Type : Nikdim / PAM-10
Marka / Tip
Test(s) Performed : Dry Lightning-Impulse Withstand Voltage Test
Yapılan Deney(ler) : Dry Power-Frequency Withstand Voltage Test
Test Standart(s) : IEC 60168: 1994 + A1: 1997 + A2: 2000
Deney Standart(lar)ı
Serial Number(s) : 9511106 / T4
Seri No(lar)
Reception Date of Sample : 15.07.2017
Numune Kabul Tarihi
Test Date(s) : 15.07.2017
Deney Tarih(ler)i
Number of Pages of the Report : 14
Raporun Sayfa Sayısı
Test(s) Result(s) : Passed / Geçti Failed / Geçmedi Other / Diğer
Deney Sonuçları

HILKAR is accredited by TÜRKAK under registration number AB-0665-T for TS EN ISO IEC 17025:2012 as test laboratory.

Deney Laboratuvarı olarak faaliyet gösteren HILKAR, TÜRKAK'tan AB-0665-T ile TS EN ISO IEC 17025:2012 standardına göre akredite edilmiştir.

The Turkish Accreditation Agency (TURKAK) is a signatory to the European co-operation for the Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.

Türk Akreditasyon Kurumu (TÜRKAK) deney raporlarının tanınırlığı konusunda Avrupa Akreditasyon Birliği (EA) ile Çok Taraflı Anlaşma ve Uluslararası Laboratuvar Akreditasyon Birliği (ILAC) ile karşılıklı tanıma anlaşması imzalamıştır.

The test and/or measurements results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Deney ve/veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metotları, bu sertifikanın tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.



Date
Tarih
10.08.2017

Person in Charge of Test
Deney Sorumlusu
Laboratory Technician
M. Zeynep

На основание чл.2 от 33ЛД

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

1. IDENTIFICATION OF THE TEST SAMPLE:

Description of the Sample	: 12 kV Indoor Type Post Insulator
Trade Mark / Type	: Nikdim / PAM-10
Serial Number	: 9511106 / T4
Technical Specification / Drawing	: See the Clause 5
Contract No	: FT.DNY-07.003.2017
Product Condition at Arrival	: New

2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Manufacturer	: Nikdim
Type	: PAM-10
Rated Voltage	: 12 kV
Power Frequency Withstand Voltage	: 38 kV
Lightning Impulse Withstand Voltage	: 75 kV
Creepage Distance	: 16,3 mm / kV
Material	: Porcelain C110
Color of Glaze	: White
Dimensions	: See the Clause 5

3. TEST(S) PROGRAM:


Witnessed By	: Mr. Dechko Dechev
Dry Lightning-Impulse Withstand Voltage Test	: IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5
Dry Power-Frequency Withstand Voltage Test	: IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7

4. APPLIED TEST(S):

- Test results are only belong to the tested sample.
- The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$ which for a normal distribution corresponds to a coverage probability of approximately 95 %.

4.1 Dry Lightning-Impulse Withstand Voltage Test:

- 4.1.1 Sample Standard : IEC 60168: 1994 + A1: 1997 + A2: 2000
IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5
- 4.1.2 Test Standard : IEC 60060-1: 2010 Clause 7
IEC 60273: 1990
- 4.1.3 Equipment Used : BHT / Lightning Impulse Test System (K003)
Madgetech / Environmental Conditions Recorder (K274)
- 4.1.4 Environmental Conditions : Ambient Temperature : 29,2 °C
Ambient Humidity : 56,1 %RH
Air Pressure : 1009,2 mbar
- 4.1.5 Test Circuit Diagram :



IG : Darbe Jeneratörü / Impulse Generator
VD : Hibrit Genilim Bölücü / Hybrid Voltage Divider
T : Yükseltici Trafo / Step-up Transformer
F : Metal Gövde / Frame

Deney Numunesi / Test Sample

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.


4.1.6 Test Criteria and Measurement Results:

S. No	Voltage Ut Applied to	Earth Connected to	Insulated from Earth	Test Voltage (%)	Test Voltage (kV/peak) (75 kV/peak ±%3)	Peak Time t ₁ (µs) (1,2 µs ± 30 %)	Tail Time t ₂ (µs) (50 µs ± 20 %)	Result(s)		
1	Top of Insulator	Mounting Face of Insulator	-	50-80	54,19	1,543	46,30			
					41086	41087	70,32 ¹⁾	1,304	50,98	Affirmative <input type="checkbox"/> Negative <input checked="" type="checkbox"/>
					41088	41089	72,94	1,163	51,49	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41090	41091	74,66	1,117	51,66	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41092	41093	73,72	1,183	51,07	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41094	41095	74,14	1,085	52,06	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41096	41097	74,38	1,237	51,27	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41098	41099	73,83	1,205	51,27	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41100	41101	74,07	1,169	51,38	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41102	41103	74,67	1,207	51,17	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41104	41105	75,90	1,232	51,08	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41106	41107	76,15	1,191	51,34	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41108	41109	74,59	1,084	51,99	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41110	41111	74,31	1,081	51,86	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
					41112	41113	74,83	1,198	51,34	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
				2	Top of Insulator	Mounting Face of Insulator	-	50-80	-50,63	1,247
	41105	41106	-76,82					1,327	50,54	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41107	41108	-76,24					1,316	50,79	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41109	41110	-74,66					1,203	50,16	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41111	41112	-75,62					1,252	51,13	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41113	41114	-73,68					1,100	51,16	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41115	41116	-75,00					1,253	50,71	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41117	41118	-76,03					1,296	50,84	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41119	41120	-75,57					1,331	50,66	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41121	41122	-76,17					1,313	50,44	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41123	41124	-75,23					1,287	51,35	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41125	41126	-73,90					1,136	51,56	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41127	41128	-74,23					1,153	50,94	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41129	41130	-75,90					1,258	51,68	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41131	41132	-76,19					1,332	50,95	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>
	41133	41134	-75,72	1,293	50,26	Affirmative <input checked="" type="checkbox"/> Negative <input type="checkbox"/>				


Remarks:
1) Out of voltage tolerance, additional impulses were applied instead.


4.1.7 Oscillograms:

4.1.7.1 S. No:1 / Positive Impulses









This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.





4.1.7.2 S. No:2 / Negative Impulses




Handwritten signature


Handwritten signature

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

ВЕРНО С ОРИГИНАЛА



This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.




4.1.8 Remarks, Comments and Statements of Compliance:

- Test voltage were applied as per IEC 60273:1990 Table-1
- Tests were applied without considering atmospheric correction.
- Measurement Uncertainty of K003: U_i : 2,206% t_1 : 4,791 % t_2 : 2,620%
- The insulator was mounted vertically upright on a horizontal earthed metal support consisting of a U-channel section with the flanges pointing downwards which has a width about equal to the diameter of the mounting face of the insulator and a length longer than twice the height of the insulator, and was placed 1,1 m above ground.
- A cylindrical conductor, maintained in the horizontal plane and perpendicular to the earthed support, was attached to the top of the insulator. The length of the conductor was longer than 1,5 times the height of the insulator and it was extended 1 m on each side of the insulator axis. The diameter of the conductor was 30 mm.
- 12 kV indoor type post insulator with Nikdim brand, PAM-10 type and 9511106 / T4 serial number, has been tested and passed successfully to the Dry Lightning-Impulse Withstand Voltage Test as per IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5 the withstand voltage procedure.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

4.2 Dry Power-Frequency Withstand Voltage Test:

- 4.1.1 Sample Standard : IEC 60168: 1994 + A1: 1997 + A2: 2000
IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7
- 4.1.2 Test Standard : IEC 60060-1: 2010 Clause 6
IEC 60273: 1990
- 4.1.3 Equipment Used : Baur / 100 kVac High Voltage Test System (K001)
Madgetech / Environmental Conditions of the Recorder (K274)
- 4.1.4 Environmental Conditions : Ambient Temperature : 29,2 °C
Ambient Humidity : 56,1 %RH
Air Pressure : 1009,2 mbar
- 4.1.5 Test Circuit Diagram



4.2.5 Test Criteria and Measurement Results:


S. No	Voltage Ut Applied to	Earth Connected to	Insulated from Earth	Test Voltage (kVrms) (28 kVrms ±%1)	Frequency (Hz)	Time (sec.)	Result(s)	
1	Top of Insulator	Mounting Face of Insulator	-	38,05	50	60	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>

4.2.6 Remarks, Comments and Statements of Compliance:

- Test voltage were applied as per IEC 60273:1990 Table-1
- Tests were applied without considering atmospheric correction.
- Measurement Uncertainty of K001: U_i: 1,409%
- The post insulator was mounted vertically upright on a horizontal earthed metal support consisting of a U-channel section with the flanges pointing downwards which has a width about equal to the diameter of the mounting face of the insulator and a length longer than twice the height of the insulator, and was placed 1,1 m above ground.
- A cylindrical conductor, maintained in the horizontal plane and perpendicular to the earthed support, was attached to the top of the insulator. The length of the conductor was longer than 1,5 times the height of the insulator and it was extended 1 m on each side of the insulator axis. The diameter of the conductor was 30 mm.
- 12 kV indoor type post insulator with Nikdim brand, PAM-10 type and 9511106 / T4 serial number, has been tested and passed successfully to the Dry Power-Frequency Withstand Voltage Test as per IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7.



This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

5. TECHNICAL DRAWING(S) of the TEST SAMPLE:




This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

6. PHOTO(S) of the TEST SAMPLE:



This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.





NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA
HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA

Matriculation certificate: J16/312/1999, VAT number: RO3871599

Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890

www.icmet.ro ; E-mail: market@icmet.ro



accredited for
TESTING



SR EN ISO 9001 17025:2005
ACCREDITATION CERTIFICATE
111036

TEST REPORT
No. 45963 / 11.08.2017

1. CUSTOMER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
2. MANUFACTURER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
3. TESTED PRODUCT:	Indoor Post Insulator type PAM 10
4. REFERENCE STANDARD:	Customer requirements (IEC 60168:2001, clause 5.2.4)
5. PERFORMED TESTS:	Mechanical falling load test. Bending test
6. TEST DATE:	10.08.2017
7. TEST RESULTS:	The product passed the test.

The test report contains 5 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies 2, 3, 4 are sent to the customer.

HEAD OF HVD – TECHNICAL MANAGER,

HEAD OF TESTING TEAM,

Dipl. Eng. Ion Buzulu

Dipl. Eng. Ion Dinu

На основание чл.2 от ЗЗЛД

Warnings:

- The results refer only to the tested product.
- Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- All signatures of the present report are original ones.

ВЪРНО С ОРГИНАЛА

God F-01.22.01(e)
© ICMET Craiova – 2017



CONTENT

1. Identification of the test product	page 3
2. Technical characteristics established by manufacturer	page 3
3. Tests program	page 3
4. Responsible for test	page 3
5. Present at the test	page 3
6. Tests description and test results presentation	page 4
Annex	page 5

**1. IDENTIFICATION OF THE TEST PRODUCT**

Type:	PAM 10
Serial / year:	2014
Technical Specification / Drawing:	Drawing no. ND 92.01.00.00 - Support insulators for indoor mounting type PAM 10
Contract / Test order:	705.2/876/03.08.2017
Internal test order:	23362/07.08.2017
Product receiving date:	08.08.2017
Product condition at receiving:	New

2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER

Maximum working voltage	12 kV
Mechanical failing load	4000 N (indicated by the customer)

3. TESTS PROGRAM

Mechanical failing load test. Bending test

Customer requirements
(IEC 60168:2001, clause 5.2.4)**4. RESPONSIBLE FOR TEST**

Dipl. Eng. Luminita Tascau 24

5. PRESENT AT THE TEST

ВЯРНО С ОРИГИНАЛА

6. MECHANICAL FAILING LOAD TEST. BENDING TEST

Test date:	10.08.2017
Test standard:	Customer requirements (IEC 60168:2001, clause 5.2.4)
Atmospheric conditions:	t = 28 °C; RH = 53%
Equipment used:	<ul style="list-style-type: none"> • Manual lever hoist SAFETEX 3000 kg, manufacturer SC Delta Flex SRL Bucuresti • Tension load cell, model CTL 1000 kg, serial no. 201106182, manufacturer LAUMAS ELECTRONICA Italy, CC. no. F - 03/329/2017, SC GELUTECH Laboratory of Forces SRL
Test procedure:	<p>The post insulator was subjected to a bending load to verify the mechanical failing load of 4000 N as specified in Annex 1 to the contract.</p> <p>The load was applied perpendicular to the axis of the post insulator, to the free end (see Photo 1).</p> <p>The specified bending load was reached.</p>
Test results:	The product passed the test.





Photo 1

Annex 1




1. Material: porcelain C110 according to IEC 60672.
2. Colour of glaze - white.
3. Maximum working voltage - 12 kV.
4. The general tolerances are according to DIN 40680.
5. Electrical parameters according to IEC 60168.

				ND 92.01.00.00				
Alter	Number	No of circums.	Signature	Date	Support insulators for indoor mounting type PAM 10	Stage	Mass	Маураб
Developed		Donev						1:1
Controlled		Donev				Sheet 1	All sheet	1
Controlled		Donev				"NIKDIM" OOD		

- End of test report -

ВЯРНО С ОПРИГИНАЛА



TEST REPORT
DENEY RAPORU

Customer Name : Nikdim LTD.
Müşterinin Adı

Customer Address : 80, 23-rd Pehoten Shipchenski polk blvd. 6100 Kananlak, Bulgaria
Müşterinin Adresi

Description of Sample : 24 kV Indoor Type Post Insulator
Numunenin Tanımı

Trade Mark / Type : Nikdim / PAK-20
Marka / Tip

Test(s) Performed : Dry Lightning-Impulse Withstand Voltage Test
Yapılan Deney(ler) : Dry Power-Frequency Withstand Voltage Test

Test Standart(s) : IEC 60168: 1994 + A1: 1997 + A2: 2000
Deney Standart(lar)ı

Serial Number(s) : 9512101 / T3
Seri No(lar)

Reception Date of Sample : 15.07.2017
Numune Kabul Tarihi

Test Date(s) : 15.07.2017
Deney Tarih(ler)i

Number of Pages of the Report : 14
Raporun Sayfa Sayısı

Test(s) Result(s) : Passed / Geçti Failed / Geçmedi Other / Diğer
Deney Sonuçları

HILKAR is accredited by TÜRKAK under registration number AB-0665-T for TS EN ISO IEC 17025:2012 as test laboratory.

Deney Laboratuvarı olarak faaliyet gösteren HILKAR, TÜRKAK'tan AB-0665-T ile TS EN ISO IEC 17025:2012 standardına göre akredite edilmiştir.

The Turkish Accreditation Agency (TURKAK) is a signatory to the European co-operation for the Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.

Türk Akreditasyon Kurumu (TÜRKAK) deney raporlarının tanınırlığı konusunda Avrupa Akreditasyon Birliği (EA) ile Çok Taraflı Anlaşma ve Uluslararası Laboratuvar Akreditasyon Birliği (ILAC) ile karşılıklı tanıma anlaşması imzalamıştır.

The test and/or measurements results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Deney ve/veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metotları, bu sertifikanın tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.



Date
Tarih

10.08.2017

Person in Charge of Test

Deney Sorumlusu
На основании чл.2 от 33ЛД

Approval

(Onaylayan)

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

1. IDENTIFICATION OF THE TEST SAMPLE:

Description of the Sample	: 24 kV Indoor Type Post Insulator
Trade Mark / Type	: Nikdim / PAK-20
Serial Number	: 9512101 / T3
Technical Specification / Drawing	: See the Clause 5
Contract No	: FT.DNY-07.003.2017
Product Condition at Arrival	: New

2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Manufacturer	: Nikdim
Type	: PAK-20
Rated Voltage	: 24 kV
Power Frequency Withstand Voltage	: 50 kV
Lightning Impulse Withstand Voltage	: 125 kV
Creepage Distance	: 8,5 mm / kV
Material	: Porcelain C110
Color of Glaze	: White
Dimensions	: See the Clause 5

3. TEST(S) PROGRAM:


Witnessed By	: Mr. Dechko Dechev
Dry Lightning-Impulse Withstand Voltage Test	: IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5
Dry Power-Frequency Withstand Voltage Test	: IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7

4. APPLIED TEST(S):

- Test results are only belong to the tested sample.
- The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2 which for a normal distribution corresponds to a coverage probability of approximately 95 %.

4.1 Dry Lightning-Impulse Withstand Voltage Test:

- 4.1.1 Sample Standard : IEC 60168: 1994 + A1: 1997 + A2: 2000
IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5
- 4.1.2 Test Standard : IEC 60060-1: 2010 Clause 7
IEC 60273: 1990
- 4.1.3 Equipment Used : BHT / Lightning Impulse Test System (K003)
Madgetech / Environmental Conditions Recorder (K274)
- 4.1.4 Environmental Conditions : Ambient Temperature : 27,9 °C
Ambient Humidity : 60,4 %RH
Air Pressure : 1007,1 mbar
- 4.1.5 Test Circuit Diagram :



IG : Darbe Jeneratörü / Impulse Generator
VD : Hibrit Gerilim Bölücü / Hybrid Voltage Divider
T : Yükseltici Trafo / Step-up Transformer
F : Metal Gövde / Frame

Deney Numunesi / Test Sample

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.


4.1.6 Test Criteria and Measurement Results:

S. No		Voltage Ut Applied to	Earth Connected to	Insulated from Earth	Test Voltage (%)	Test Voltage (kV/peak) (121,0 kV/peak \pm 3%)	Peak Time t_1 (μ s) (1,2 μ s \pm 30 %)	Tail Time t_2 (μ s) (50 μ s \pm 20 %)	Result(s)	
1	1	41050	Top of Insulator	Mounting Face of Insulator	50-80	84,34	1,178	50,90		
	1	41051				119,09	1,226	50,60	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	2	41052				118,74	1,117	51,26	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	3	41053				119,14	1,198	50,77	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	4	41054				118,88	1,213	50,76	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	5	41055				118,89	1,125	51,50	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	6	41056				120,25	1,173	51,48	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	7	41057				119,57	1,196	51,15	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	8	41058				118,84	1,131	51,17	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	9	41059				119,78	1,177	51,45	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	10	41060				118,81	1,140	51,88	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	11	41061				118,92	1,195	50,86	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	12	41062				118,41	1,119	51,50	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	13	41063				119,81	1,233	50,95	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	14	41064				119,29	1,191	50,76	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
15	41065	119,94	1,246	50,67	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>				
2	1	41067	Top of Insulator	Mounting Face of Insulator	50-80	-84,62	1,307	50,19		
	1	41068				-119,86	1,240	51,35	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	2	41069				-119,99	1,213	50,84	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	3	41070				-119,45	1,218	50,54	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	4	41071				-119,00	1,130	51,15	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	5	41072				-118,87	1,128	51,17	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	6	41073				-119,28	1,194	50,70	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	7	41074				-119,84	1,171	51,23	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	8	41075				-119,16	1,170	50,70	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	9	41076				-118,66	1,162	50,77	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	10	41077				-120,94	1,220	50,85	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	11	41078				-120,11	1,228	50,84	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	12	41079				-120,72	1,209	50,99	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	13	41080				-118,94	1,121	51,25	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	14	41081				-119,72	1,139	51,23	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
15	41082	-120,00	1,225	50,72	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>				

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

4.1.7 Oscillograms:

4.1.7.1 S. No:1 / Positive Impulses




Handwritten signature

Handwritten signature and circular stamp


This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

Bu rapor, Laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürsüz raporlar geçersizdir.

ВЕРНО С ОРИГИНАЛА



4.1.7.2 S. No:2 / Negative Impulses




[Handwritten signature]

[Handwritten signature]

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

ВЯРНО С ОРИГИНАЛА



This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

Bu rapor, Laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürsüz raporlar geçersizdir.


4.1.8 Remarks, Comments and Statements of Compliance:

- Test voltage were applied as per IEC 60273:1990 Table-1
- Tests were applied with atmospheric correction.
K1 = 0,968 K2 = 1,000 Kt = 0,968
- Measurement Uncertainty of K003: U_i: 2,206% t₁: 4,791 % t₂: 2,620%
- The insulator was mounted vertically upright on a horizontal earthed metal support consisting of a U-channel section with the flanges pointing downwards which has a width about equal to the diameter of the mounting face of the insulator and a length longer than twice the height of the insulator, and was placed 1,1 m above ground.
- A cylindrical conductor, maintained in the horizontal plane and perpendicular to the earthed support, was attached to the top of the insulator. The length of the conductor was longer than 1,5 times the height of the insulator and it was extended 1 m on each side of the insulator axis. The diameter of the conductor was 30 mm.
- 24 kV indoor type post insulator with Nikdim brand, PAK-20 type and 9:12101 / T3 serial number, has been tested and passed successfully to the Dry Lightning-Impulse Withstand Voltage Test as per IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5 the withstand voltage procedure.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

4.2 Dry Power-Frequency Withstand Voltage Test:

- 4.1.1 Sample Standard : IEC 60168: 1994 + A1: 1997 + A2: 2000
IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7
- 4.1.2 Test Standard : IEC 60060-1: 2010 Clause 6
IEC 60273: 1990
- 4.1.3 Equipment Used : Baur / 100 kVac High Voltage Test System (K001)
Madgetech / Environmental Conditions of the Recorder (K274)
- 4.1.4 Environmental Conditions : Ambient Temperature : 27,9 °C
Ambient Humidity : 60,4 %RH
Air Pressure : 1007,1 mbar
- 4.1.5 Test Circuit Diagram :



4.2.5 Test Criteria and Measurement Results:


S. No	Voltage Ut Applied to	Earth Connected to	Insulated from Earth	Test Voltage (kVrms) (50 kVrms ±%1)	Frequency (Hz)	Time (sec.)	Result(s)	
1	Top of Insulator	Mounting Face of Insulator	-	50,08	50	60	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>

4.2.6 Remarks, Comments and Statements of Compliance:

- Test voltage were applied as per IEC 60273:1990 Table-1
- Tests were applied without considering atmospheric correction.
- Measurement Uncertainty of K001: U_i : 1,409%
- The post insulator was mounted vertically upright on a horizontal earthed metal support consisting of a U-channel section with the flanges pointing downwards which has a width about equal to the diameter of the mounting face of the insulator and a length longer than twice the height of the insulator, and was placed 1,1 m above ground.
- A cylindrical conductor, maintained in the horizontal plane and perpendicular to the earthed support, was attached to the top of the insulator. The length of the conductor was longer than 1,5 times the height of the insulator and it was extended 1 m on each side of the insulator axis. The diameter of the conductor was 30 mm.
- 24 kV indoor type post insulator with Nikdim brand, PAK-20 type and 9512101 / T3 serial number, has been tested and passed successfully to the Dry Power-Frequency Withstand Voltage Test as per IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

5. TECHNICAL DRAWING(S) of the TEST SAMPLE:




1. Material: porcelain C110 according to IEC 60672.
2. Colour of glaze - white.
3. Maximum working voltage - 24 kV.
4. The general tolerances are according to DIN 40680.
5. Electrical parameters according to IEC 60168.

					ND 92.13.00.00		
Alter	Number	RE of document	Signature	Date	Support Insulators for indoor mounting type PAK 20		
					Stage	Mass	Maşab
Developed		İlkeç					1:1
Controlled		Donay			Sheet	As sheet	1
Controlled		Donay			"NIKDIM" OOD		

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

AB-0665-T
1707096
07.2017

6. PHOTO(S) of the TEST SAMPLE:




[Handwritten signature]

[Handwritten signature]

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

ВЕРНО С ОРИГИНАЛА






NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA
HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA
Matriculation certificate: J16/312/1999, VAT number: RO3871599
Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890
www.icmet.ro; E-mail: market@icmet.ro



TEST REPORT
No. 45967 / 11.08.2017

1. CUSTOMER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
2. MANUFACTURER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
3. TESTED PRODUCT:	Indoor Post Insulator type PAK 20
4. REFERENCE STANDARD:	Customer requirements (IEC 60168:2001, clause 5.2.4)
5. PERFORMED TESTS:	Mechanical failing load test. Bending test
6. TEST DATE:	10.08.2017
7. TEST RESULTS:	The product passed the test.

The test report contains 5 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies 2, 3, 4 are sent to the customer.

HEAD OF HVD – TECHNICAL MANAGER,

HEAD OF TESTING TEAM,

Dipl. Eng. Ion Burciu

Dipl. Eng. Ion Dinu

На основание чл.2 от ЗЗЛД

Warnings:

- The results refer only to the tested product.
- Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- All signatures of the present report are original ones.

ВЯРНО С ОРИГИНАЛА



CONTENT

1. Identification of the test product	page 3
2. Technical characteristics established by manufacturer	page 3
3. Tests program	page 3
4. Responsible for test	page 3
5. Present at the test	page 3
6. Tests description and test results presentation	page 4
Annex	page 5

**1. IDENTIFICATION OF THE TEST PRODUCT**

Type:	PAK 20
Serial / year:	2011
Technical Specification / Drawing:	Drawing no. ND 92.13.00.00 - Support insulators for indoor mounting type PAK 20
Contract / Test order:	705.2/876/03.08.2017
Internal test order:	23362/07.08.2017
Product receiving date:	08.08.2017
Product condition at receiving:	New

2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER

Maximum working voltage	24 kV
Mechanical failing load	4000 N (Indicated by the customer)

3. TESTS PROGRAM

Mechanical failing load test. Bending test

Customer requirements
(IEC 60168:2001, clause 5.2.4)**4. RESPONSIBLE FOR TEST**

Dipl. Eng. Luminita Tascau

21

5. PRESENT AT THE TEST

ВЯРНО С ОРИГИНАЛА

6. MECHANICAL FAILING LOAD TEST. BENDING TEST

Test date: 10.08.2017

Test standard: Customer requirements
(IEC 60168:2001, clause 5.2.4)

Atmospheric conditions: $t = 28^{\circ}\text{C}$; RH = 53%

Equipment used:

- Manual lever hoist SAFETEX 3000 kg, manufacturer SC Delta Flex SRL Bucuresti
- Tension load cell, model CTL 1000 kg, serial no. 201106182, manufacturer LAUMAS ELECTRONICA Italy, CC no. F - 03/329/2017, SC GELUTECH Laboratory of Forces SRL

Test procedure: The post insulator was subjected to a bending load to verify the mechanical failing load of 4000 N as specified in Annex 1 to the contract.
The load was applied perpendicular to the axis of the post insulator, to the free end (see Photo 1).
The specified bending load was reached.

Test results: The product passed the test.





Photo 1

Annex 1




1. Material: porcelain C110 according to IEC 60672.
2. Colour of glaze - white.
3. Maximum working voltage - 24 kV.
4. The general tolerances are according to DIN 40680.
5. Electrical parameters according to IEC 60188.

				ND 92.13.00.00			
Alter Number	Nr of docum.	Signature	Date	Support insulators for indoor mounting type PAK 20	Stage	Mass	Мащаб
Developed	Iliev						1:1
Controlled	Donev			Sheet	1	All sheet	1
Controlled	Donev			"NIKDIM" OOD			

– End of test report –

ВЯРНО С ОРИГИНАЛА



TEST REPORT
DENEY RAPORU

Customer Name : Nikdim LTD.
Müşterinin Adı
Customer Address : 80, 23-rd Pehoten Shipchenski polk blvd. 6100 Kananlak, Bulgaria
Müşterinin Adresi
Description of Sample : 24 kV Indoor Type Post Insulator
Numunenin Tanımı
Trade Mark / Type : Nikdim / PAM-20
Marka / Tip
Test(s) Performed : Dry Lightning-Impulse Withstand Voltage Test
Yapılan Deney(ler) : Dry Power-Frequency Withstand Voltage Test
Test Standart(s) : IEC 60168: 1994 + A1: 1997 + A2: 2000
Deney Standart(lar)ı
Serial Number(s) : 9511107 / T5
Seri No(lar)
Reception Date of Sample : 15.07.2017
Numune Kabul Tarihi
Test Date(s) : 15.07.2017
Deney Tarih(ler)i
Number of Pages of the Report : 14
Raporun Sayfa Sayısı
Test(s) Result(s) : Passed / Geçti Failed / Geçmedi Other / Diğer
Deney Sonuçları

HILKAR is accredited by TÜRKAK under registration number AB-0665-T for TS EN ISO IEC 17025:2012 as test laboratory.

Deney Laboratuvarı olarak faaliyet gösteren HILKAR, TÜRKAK'tan AB-0665-T ile TS EN ISO IEC 17025:2012 standardına göre akredite edilmiştir.

The Turkish Accreditation Agency (TURKAK) is a signatory to the European co-operation for the Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.

Türk Akreditasyon Kurumu (TÜRKAK) deney raporlarının tanınırlığı konusunda Avrupa Akreditasyon Birliği (EA) ile Çok Taraflı Anlaşma ve Uluslararası Laboratuvar Akreditasyon Birliği (ILAC) ile karşılıklı tanıma anlaşması imzalamıştır.

The test and/or measurements results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Deney ve/veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metotları, bu sertifikanın tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.



Date
Tarih

10.08.2017

Person in Charge of Test

На основание чл.2 от ЗЗЛД

Approval

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

1. IDENTIFICATION OF THE TEST SAMPLE:

Description of the Sample	: 24 kV Indoor Type Post Insulator
Trade Mark / Type	: Nikdim / PAM-20
Serial Number	: 9511107 / T5
Technical Specification / Drawing	: See the Clause 5
Contract No	: FT.DNY-07.003.2017
Product Condition at Arrival	: New

2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Manufacturer	: Nikdim
Type	: PAM-20
Rated Voltage	: 24 kV
Power Frequency Withstand Voltage	: 50 kV
Lightning Impulse Withstand Voltage	: 125 kV
Creepage Distance	: 8,5 mm / kV
Material	: Porcelain C110
Color of Glaze	: White
Dimensions	: See the Clause 5

3. TEST(S) PROGRAM:


Witnessed By	: Mr. Dechko Dechev
Dry Lightning-Impulse Withstand Voltage Test	: IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5
Dry Power-Frequency Withstand Voltage Test	: IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7

4. APPLIED TEST(S):

- Test results are only belong to the tested sample.
- The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$ which for a normal distribution corresponds to a coverage probability of approximately 95 %.

4.1 Dry Lightning-Impulse Withstand Voltage Test:

- 4.1.1 Sample Standard : IEC 60168: 1994 + A1: 1997 + A2: 2000
IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5
- 4.1.2 Test Standard : IEC 60060-1: 2010 Clause 7
IEC 60273: 1990
- 4.1.3 Equipment Used : BHT / Lightning Impulse Test System (K003)
Madgetech / Environmental Conditions Recorder (K274)
- 4.1.4 Environmental Conditions : Ambient Temperature : 29,3 °C
Ambient Humidity : 56,0 %RH
Air Pressure : 1009,2 mbar
- 4.1.5 Test Circuit Diagram :



- IG : Darbe Jeneratörü / Impulse Generator
VD : Hibrit Gerilim Bölücü / Hybrid Voltage Divider
T : Yükseltici Trafo / Step-up Transformer
F : Metal Gövde / Frame

Deney Numunesi / Test Sample

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

4.1.6. Test Criteria and Measurement Results:


S. No		Voltage Ut Applied to	Earth Connected to	Insulated from Earth	Test Voltage (%)	Test Voltage (kV/peak) (125 kV/peak ± %3)	Peak Time t ₁ (µs) (1,2 µs ± 30 %)	Tail Time t ₂ (µs) (50 µs ± 20 %)	Result(s)	
1	1	41122	Top of Insulator	Mounting Face of Insulator	50-80	85,29	1,276	50,65		
	1	41123				124,47	1,160	51,13	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	2	41124				125,20	1,207	50,89	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	3	41125				123,17	1,170	50,47	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	4	41126				124,18	1,236	50,48	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	5	41127				124,08	1,168	51,53	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	6	41128				124,38	1,228	50,49	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	7	41129				124,32	1,146	50,83	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	8	41130				122,74	1,126	51,34	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	9	41131				123,76	1,219	50,46	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	10	41132				123,95	1,143	51,29	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	11	41133				124,16	1,202	50,50	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	12	41134				123,27	1,129	51,27	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	13	41135				124,89	1,205	50,92	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	14	41136				124,20	1,245	50,40	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
15	41137	124,81	1,223	50,61	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>				
2	1	41139	Top of Insulator	Mounting Face of Insulator	50-80	-84,68	1,298	50,87		
	1	41140				-125,22	1,239	50,57	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	2	41141				-124,87	1,180	50,88	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	3	41142				-124,91	1,209	50,33	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	4	41143				-125,87	1,236	50,62	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	5	41144				-123,91	1,184	50,44	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	6	41145				-125,22	1,140	50,89	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	7	41146				-125,51	1,198	51,04	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	8	41147				-124,40	1,136	50,70	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	9	41148				-124,96	1,235	50,63	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	10	41149				-124,33	1,139	50,95	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	11	41150				-124,08	1,127	51,09	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	12	41151				-125,23	1,222	50,88	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	13	41152				-125,57	1,172	51,04	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
	14	41153				-124,29	1,157	50,75	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>
15	41154	-124,05	1,193	50,52	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>				

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

Bu rapor, Laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürlü raporlar geçersizdir.

4.1.7 Oscillograms:

4.1.7.1 S. No:1 / Positive Impulses




[Handwritten signature]

[Handwritten signature]


This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

ВЕРНО С ОРИГИНАЛА




This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

4.1.7.2 S. No:2 / Negative Impulses



This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

ВАРНО С ОПРИГНАЛА



This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.


Bu rapor, Laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürsüz raporlar geçersizdir.

4.1.8 Remarks, Comments and Statements of Compliance:

- Test voltage were applied as per IEC 60273:1990 Table-1
- Tests were applied without considering atmospheric correction.
- Measurement Uncertainty of K003: U_1 : 2,206% t_1 : 4,791 % t_2 : 2,620%
- The insulator was mounted vertically upright on a horizontal earthed metal support consisting of a U-channel section with the flanges pointing downwards which has a width about equal to the diameter of the mounting face of the insulator and a length longer than twice the height of the insulator, and was placed 1,1 m above ground.
- A cylindrical conductor, maintained in the horizontal plane and perpendicular to the earthed support, was attached to the top of the insulator. The length of the conductor was longer than 1,5 times the height of the insulator and it was extended 1 m on each side of the insulator axis. The diameter of the conductor was 30 mm.
- 24 kV indoor type post insulator with Nikdim brand, PAM-20 type and 9511108 / T5 serial number, has been tested and passed successfully to the Dry Lightning-Impulse Withstand Voltage Test as per IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.5 the withstand voltage procedure.

4.2 Dry Power-Frequency Withstand Voltage Test:

- 4.1.1 Sample Standard : IEC 60168: 1994 + A1: 1997 + A2: 2000
IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7
- 4.1.2 Test Standard : IEC 60060-1: 2010 Clause 6
IEC 60273: 1990
- 4.1.3 Equipment Used : Baur / 100 kVac High Voltage Test System (K001)
Madgetech / Environmental Conditions of the Recorder (K274)
- 4.1.4 Environmental Conditions : Ambient Temperature : 29,3 °C
Ambient Humidity : 56,0 %RH
Air Pressure : 1009,2 mbar
- 4.1.5 Test Circuit Diagram :



VD : Kapasitif Gerilim Bölücü / Capacitive Voltage Divider
T : 0 - 100 kVac - 0 - 500 kVac Test Trafosu / 0 - 100 kVac - 0 - 500 kVac Test Transformer
F : Metal Gövde / Frame

4.2.5 Test Criteria and Measurement Results:

S. No	Voltage Ut Applied to	Earth Connected to	Insulated from Earth	Test Voltage (kVrms) (50 kVrms ±%1)	Frequency (Hz)	Time (sec.)	Result(s)	
1	Top of Insulator	Mounting Face of Insulator	-	50,09	50	60	Affirmative <input checked="" type="checkbox"/>	Negative <input type="checkbox"/>

4.2.6 Remarks, Comments and Statements of Compliance:

- Test voltage was applied as per IEC 60273:1990 Table-1.
- Tests were applied without considering atmospheric correction.
- Measurement Uncertainty of K001: U_i : 1,409%
- The post insulator was mounted vertically upright on a horizontal earthed metal support consisting of a U-channel section with the flanges pointing downwards which has a width about equal to the diameter of the mounting face of the insulator and a length longer than twice the height of the insulator, and was placed 1,1 m above ground.
- A cylindrical conductor, maintained in the horizontal plane and perpendicular to the earthed support, was attached to the top of the insulator. The length of the conductor was longer than 1,5 times the height of the insulator and it was extended 1 m on each side of the insulator axis. The diameter of the conductor was 30 mm.
- 24 kV indoor type post insulator with Nikdim brand, PAM-20 type and 9511108 / T5 serial number, has been tested and passed successfully to the Dry Power-Frequency Withstand Voltage Test as per IEC 60168: 1994 + A1: 1997 + A2: 2000 Clause 4.7.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.


Bu rapor, Laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürlü raporlar geçersizdir.

FRM.11 / REV03 / 08.2017

Sayfa / Page 11 / 14

ВЯРНО С ОРИГИНАЛА



5. TECHNICAL DRAWING(S) of the TEST SAMPLE:



1. Material: porcelain C110 according to IEC 60672.
2. Colour of glaze - white.
3. Maximum working voltage - 24 kV.
4. The general tolerances are according to DIN 40680.
5. Electrical parameters according to IEC 60168.

				ND 92.02.00.00			
				Support insulators for indoor mounting type PAM 20		Stage Mass	
				Sheet - A: sheet		NIKOLM OOD	
After	ance	No of	Docum.	Signature	Date		
Developed		Doney					
Controlled		Doney					
Controlled		Doney					

6. PHOTO(S) of the TEST SAMPLE:




[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

ВЯРНО С ОРИГИНАЛА





NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA
HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA
Matriculation certificate: J16/312/1999, VAT number: RO3871599
Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890
www.icmet.ro ; E-mail: market@icmet.ro



Copy No. 2

accredited for
TESTING



SR EN ISO/CEI 17025:2005
ACCREDITATION CERTIFICATE
LI 1036

TEST REPORT
No. 45964 / 11.08.2017

1. CUSTOMER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
2. MANUFACTURER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
3. TESTED PRODUCT:	Indoor Post Insulator type PAM 20
4. REFERENCE STANDARD:	Customer requirements (IEC 60168:2001, clause 5.2.4)
5. PERFORMED TESTS:	Mechanical failing load test. Bending test
6. TEST DATE:	10.08.2017
7. TEST RESULTS:	The product passed the test.

The test report contains 5 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies 2, 3, 4 are sent to the customer.

HEAD OF HVD – TECHNICAL MANAGER,

HEAD OF TESTING TEAM,

Dipl. Eng. Ion Burciu

Dipl. Eng. Ion Dinu

На основание чл.2 от ЗЗЛД



Warnings:

- The results refer only to the tested product.
- Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- All signatures of the present report are original ones.

ВЯРНО С ОРИГИНАЛА

Cod F-01.22.01(e)

© ICMET Craiova – 2017



CONTENT

1. Identification of the test product	page 3
2. Technical characteristics established by manufacturer	page 3
3. Tests program	page 3
4. Responsible for test	page 3
5. Present at the test	page 3
6. Tests description and test results presentation	page 4
Annex	page 5

**1. IDENTIFICATION OF THE TEST PRODUCT**

Type:	PAM 20
Serial / year:	2017
Technical Specification / Drawing:	Drawing no. ND 92.02.00.00 - Support insulators for indoor mounting type PAM 20
Contract / Test order:	705.2/876/03.08.2017
Internal test order:	23362/07.08.2017
Product receiving date:	08.08.2017
Product condition at receiving:	New

2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER

Maximum working voltage	24 kV
Mechanical failing load	4000 N (indicated by the customer)

3. TESTS PROGRAM

Mechanical failing load test. Bending test Customer requirements
(IEC 60168:2001, clause 5.2.4)

4. RESPONSIBLE FOR TEST

Dipl. Eng. Luminita Tascau

5. PRESENT AT THE TEST

6. MECHANICAL FAILING LOAD TEST. BENDING TEST

Test date:	10.08.2017
Test standard:	Customer requirements (IEC 60168:2001, clause 5.2.4)
Atmospheric conditions:	t = 28 °C; RH = 53%
Equipment used:	<ul style="list-style-type: none">• Manual lever hoist SAFETEX 3000 kg, manufacturer SC Delta Flex SRL Bucuresti• Tension load cell, model CTL 1000 kg, serial no. 201106182, manufacturer LAUMAS ELECTRONICA Italy, CC no. F - 03/329/2017, SC GELUTECH Laboratory of Forces SRL
Test procedure:	<p>The post insulator was subjected to a bending load to verify the mechanical failing load of 4000 N as specified in Annex 1 to the contract.</p> <p>The load was applied perpendicular to the axis of the post insulator, to the free end (see Photo 1).</p> <p>The specified bending load was reached.</p>
Test results:	The product passed the test.





Photo 1

Annex 1



- End of test report -

ВАРНО С ОПРИГИНАЛА





NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA
Matriculation certificate: J16/312/1999, VAT number RO3871599
Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890
www.icmet.ro ; E-mail: market@icmet.ro



accredited for TESTING



SR EN ISO/IEC 17025:2005 ACCREDITATION CERTIFICATE LI 1036

TEST REPORT No. 45958 / 08.08.2017

- 1. CUSTOMER: NIKDIM Ltd. Address: 23rd Shipchensky Polk No. 80, 6100 Kazanlak, Bulgaria
2. MANUFACTURER: NIKDIM Ltd. Address: 23rd Shipchensky Polk No. 80, 6100 Kazanlak, Bulgaria
3. TESTED PRODUCT: Indoor post insulator 35kV type PAK 35
4. REFERENCE STANDARD: IEC 60168 : 2001
5. PERFORMED TEST: I - Dry lightning impulse voltage withstand test II - Dry power frequency voltage withstand test
6. TESTS DATE: 08.08.2017
7. TESTS RESULT: The product passed the test.

The test report contains 12 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies 2÷ 4 are sent to the customer.

HEAD OF HVD - TECHNICAL MANAGER, Dipl. eng. Ion BURCIU

HEAD OF TESTING TEAM, Dipl. eng. Ion BADEA

На основание чл.2 от ЗЗЛД

Warnings:

- a. The results refer only to the tested product.
b. Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
c. All signatures of the present report are original ones.

Code F-01.22.01(e)

© ICMET Craiova - 2017

ВЯРНО С ОРИГИНАЛА



Content	Page
➤ Identification of the test product.....	3
➤ Main technical characteristics established by manufacturer.....	3
➤ Tests program.....	3
➤ Responsible for tests.....	3
➤ Present at the test.....	3
➤ Dry lightning impulse voltage withstand test	4, 5
➤ Photo.....	5
➤ Oscillograms.....	6 ÷ 10
➤ Dry power frequency voltage withstand test.....	11
➤ Drawing.....	12



1. IDENTIFICATION OF THE TEST PRODUCT: Indoor post insulator 35kV

Type: PAK 35

Serial / year: - / 2017

Technical Specification / Drawing: - / see page 12

Client test order: Contract no. 876 / 03.08.2017

Internal test order: 23362 / 07.08.2017

Product receiving date: 07.08.2017

Product condition at receiving: New

2. MAIN TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Maximum working voltage.....36 kV

Dry lightning impulse withstand voltage 1.2 / 50 μ s:190 kV_{peak}

Dry power frequency withstand voltage :80 kV_{rms}

Material : porcelain C110

Colour of glaze: white

Note : The level of test voltages were specified by the customer .

3. TESTS PROGRAM:

- I - Dry lightning impulse voltage withstand test
- II - Dry power frequency voltage withstand test

4. RESPONSIBLE FOR TEST: Dipl. eng. Laurențiu Vlădoi (I) *feu*
/Dipl. eng. Dan Ștefan (II) *[Signature]*

5. PRESENT AT TESTS: General Manager eng.Maria Georgieva – NIKDIM Bulgaria

[Signature]

[Signature]
Code F-01.22.01(e)
© ICMET Craiova – 2017

ВЯРНО С ОРИГИНАЛА

I. DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST

1. Test date: 08.08.2017
2. Test standard: IEC 60168 : 2001, subclause 4.5
3. Equipment used:
 - Impulse generator 4.2 MV, no. 5 – 1197; connection I_2 (2 x 1);
 - $C_s = 0.288$ [μ F]; $R_s = 94$ [Ω]; $R_p = 230$ [Ω].

Addenda: C_s – equivalent capacity of impulse generator;
 R_s – equivalent serial resistance of impulse generator;
 R_p – equivalent parallel resistance of impulse generator.

Measuring system used:

- High voltage measuring system of impulse generator 4.2 MV consists of:
 - Capacitive divider of the impulse generator 4.2 MV with $k_{div} = 699.3$;
 - Digital measuring system type TR – AS 100 – 10 / 4, no.228; channel 2.

(Calibration Certificate no. 91 / 12.2016)

Measuring uncertainty for: peak value of lightning impulse is: ± 1.56 %

- for front time T_1 is ± 7.41 %,
- for tail time T_2 is ± 3.28 %.

The uncertainty stated is expanded uncertainty obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. The value of measurand lies within the assigned range of values with probability of 95%.

4. Test procedure / Test set-up: according to IEC 60168 : 2001, subclause 4.4.1

5. Atmospheric conditions; correction factors; U_{test}

Atmospheric conditions:	p [mbar]	1005
	t [$^{\circ}$ C]	26
	h_r [%]	53
Arcing distance measured [mm]:		310
Correction factors:	k_1	0.9722
	k_2	1.0151
	$k_t = k_1 \cdot k_2$	0.9868
$U_{test}(p_0, t_0, h_0)$ (-) and (+) [kV _{peak}]:		190
$U_{test}(p, t, h) = k_t \cdot U_{test}(p_0, t_0, h_0)$:		187.5

Symbols used:

- $U_{test}(p_0, t_0, h_0)$ – rated withstand voltage value;
- $U_{test}(p, t, h)$ – test voltage corrected to atmospheric conditions;

6. Test circuit diagram:




Fig. 1

Legend: EUT – Equipment under test



Legend: EUT – Equipment under test

Notes:

1. The test was performed by the withstand voltage procedure with 15 impulses.
2. The standard 1.2 / 50 μ s lightning impulse was used. For wave parameters see oscillograms from pages 6 + 10.




Photo 1

7. Test result: The product passed the test.

Code F-01.22.01(e)

© ICMET Craiova – 2017.









ВЯРНО С ОРИГИНАЛА



LI lightning-impulse						
no.	Up [kV]	T1[μ s]	T2[μ s]	Tc[μ s]	Ip[A]	remark
316978	96.1	1.44	45.1			RFW / PAK 35
316994	191	1.44	45.5			FW / PAK 35
316995	190	1.42	45.6			FW / PAK 35
316997	188	1.43	45.6			FW / PAK 35
316998	189	1.43	45.6			FW / PAK 35
316999	187	1.43	45.7			FW / PAK 35
317000	189	1.43	45.6			FW / PAK 35
317001	191	1.43	45.7			FW / PAK 35
317002	188	1.43	45.7			FW / PAK 35
317003	190	1.43	45.6			FW / PAK 35
317004	190	1.43	45.6			FW / PAK 35
317005	190	1.43	45.7			FW / PAK 35
317006	189	1.43	45.7			FW / PAK 35
317007	189	1.43	45.6			FW / PAK 35
317008	189	1.43	45.7			FW / PAK 35
317009	189	1.43	45.6			FW / PAK 35
317010	-98.3	1.43	45.8			RFW / PAK 35
317011	-188	1.43	45.6			FW / PAK 35
317012	-188	1.43	45.7			FW / PAK 35
317013	-189	1.43	45.3			FW / PAK 35
317014	-188	1.43	45.5			FW / PAK 35
317015	-189	1.43	45.6			FW / PAK 35
317016	-189	1.43	45.5			FW / PAK 35
317017	-189	1.43	45.5			FW / PAK 35
317018	-189	1.43	45.5			FW / PAK 35
317019	-189	1.43	45.6			FW / PAK 35
317020	-190	1.43	45.6			FW / PAK 35
317021	-189	1.43	45.5			FW / PAK 35
317022	-189	1.43	45.6			FW / PAK 35
317023	-190	1.43	45.6			FW / PAK 35
317024	-190	1.43	45.4			FW / PAK 35
317025	-189	1.43	45.3			FW / PAK 35









Notes: 1. UP-peak value of testing voltage; T1, T2, T_c – front, tail and chopping time – parameters of testing impulse wave;









2. RFW – reduced wave 50 – 75%; FW – full wave 100%



Handwritten signature

ВАРНО С ОРИГИНАЛА













[Handwritten signature]

ВЯРНО С ОРИГИНАЛА

[Handwritten signature]



II. DRY POWER FREQUENCY VOLTAGE WITHSTAND TEST

1. Test date: 08.08.2017
2. Test standard: IEC 60168:2001, subclause 4.7
3. Equipment used:
 - Test transformer 350 kVA / 350 kV, no.3 – 1963

Measuring system:

- AC measuring system 350 kV consists of:
 - high voltage compressed gas capacitor type MCF 75 / 350P, no.853889 and low voltage arm type H90, no.898939;
 - digital peak voltmeter type MU-17, no. 910396;
 - coaxial measuring cable, 75Ω.

(Calibration Certificate no.41 / 04.2015).

Measuring uncertainty is $\pm 1.6\%$.

The reported uncertainty is an expanded uncertainty, based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95 %.

4. Test procedure / Test set-up: according to IEC 60168 : 2001, subclause 4.4.1

5. Atmospheric condition, correction factors, U_{test}

Atmospheric conditions:	p [mbar]	1005
	t [°C]	26
	h_r [%]	53
Arcing distance measured [mm]:		310
Correction factors:	k_1	0.983
	k_2	1.0162
	$k_t = k_1 \cdot k_2$	0.9989
Frequency:	[Hz]	50
Time:	[sec]	60
$U_{test}(p_0, t_0, h_0)$:	[kV _{rms}]	80
$U_{test}(p, t, h) = k_t \cdot U_{test}(p_0, t_0, h_0)$:		79.9

Symbols used:

- $U_{test}(p_0, t_0, h_0)$ – rated withstand voltage value;
- $U_{test}(p, t, h)$ – test voltage corrected to atmospheric conditions.

6. Test circuit diagram:





Fig. 2

7. Test result: The product passed the test.


ВЯРНО С ОРИГИНАЛА



1. Material: porcelain C110 according to IEC 60672.
2. Colour of glaze - white.
3. Maximum working voltage - 36 kV.
4. The general tolerances are according to DIN 40680.
5. Electrical parameters according to IEC 60168.

					ND 92.14.00.00			
Alter	Number	№ of docum.	Signature	Date	Support insulators for indoor mounting type PAK 35	Stage	Mass	Масаф
Developed		Petrov						
Controlled		Donev				Sheet 1	All sheet	1
						"NIKDIM" OOD		
Controlled		Iliev						

– end of test report –



NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA
HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA
Matriculation certificate: J16/312/1999, VAT number: RO3871599
Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890
www.icmet.ro ; E-mail: market@icmet.ro



Copy No. 2

accredited for
TESTING



SR EN ISO/CEI 17025:2005
ACCREDITATION CERTIFICATE
LI 1036

TEST REPORT
No. 45983 / 24.08.2017

1. CUSTOMER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
2. MANUFACTURER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
3. TESTED PRODUCT:	Indoor Post Insulator type PAK 35
4. REFERENCE STANDARD:	Customer requirements (IEC 60168:2001, clause 5.2.4)
5. PERFORMED TESTS:	Mechanical failing load test. Bending test
6. TEST DATE:	23.08.2017
7. TEST RESULTS:	The product passed the test

The test report contains 5 pages and is edited in 4 copies, copy no.1 remains in laboratory and copies 2, 3, 4 are sent to the customer.


HEAD OF HVD – TECHNICAL MANAGER,

HEAD OF TESTING TEAM,

Dipl. Eng. Ion Burciu


Dipl. Eng. Ion Dinu

На основание чл.2 от ЗЗЛД



Warnings:

- The results refer only to the tested product.
- Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- All signatures of the present report are original ones.



ВЯРНО С ОПРИГНАЛА

Cod F-01.22.01(e)

© ICMET Craiova – 2017



CONTENT

1. Identification of the test product	page 3
2. Technical characteristics established by manufacturer	page 3
3. Tests program	page 3
4. Responsible for test	page 3
5. Present at the test	page 3
6. Tests description and test results presentation	page 4
Annex	page 5

**1. IDENTIFICATION OF THE TEST PRODUCT**

Type:	PAK 35
Serial / year:	-
Technical Specification / Drawing:	Drawing no. ND 92.14.00.00 - Support insulators for indoor mounting type PAK 35
Contract / Test order:	Add. Act No.1 to the Contract No. 705.2/876/03.08.2017
Internal test order:	23377/23.08.2017
Product receiving date:	23.08.2017
Product condition at receiving:	New


2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER

Maximum working voltage	36 kV
Mechanical failing load	4000 N (indicated by the customer)

3. TESTS PROGRAM



Mechanical failing load test. Bending test Customer requirements
(IEC 60168:2001, clause 5.2.4)

4. RESPONSIBLE FOR TEST

Dipl. Eng. Radu Serban Georgescu 

5. PRESENT AT THE TEST

Maria Georgieva-NIKDIM Ltd.



ВЯРНО С ОРИГИНАЛА

6. MECHANICAL FAILING LOAD TEST. BENDING TEST

Test date:	23.08.2017
Test standard:	Customer requirements – 4000 N (IEC 60168:2001, clause 5.2.4)
Atmospheric conditions:	t = 28 °C; RH = 53%
Equipment used:	<ul style="list-style-type: none">• Manual lever hoist SAFETEX 3000 kg, manufacturer SC Delta Flex SRL Bucharest• Tension load cell, model CTL 1000 kg, serial no. 201106182, manufacturer LAUMAS ELECTRONICA Italy, CC no. F - 03/329/2017, SC GELUTECH Laboratory of Forces SRL
Test procedure:	<p>The post insulator was subjected to a bending load, to verify the mechanical failing load of 4000 N, as specified in Annex 1 of the contract.</p> <p>The load was applied perpendicular to the axis of the post insulator, to the free end (see Photo 1).</p> <p>The specified bending load was reached.</p>
Test results:	The product passed the test.





Photo 1




1. Material: porcelain C110 according to IEC 60672.
2. Colour of glaze - white.
3. Maximum working voltage - 38 kV.
4. The general tolerances are according to DIN 40880.
5. Electrical parameters according to IEC 60188.

				ND 92.14.00.00			
Alter Number	Nº of docum.	Signature	Date	Support Insulators for indoor mounting type PAK 35	Stage	Mass	Матцаб
Developed	Petrov						
Controlled	Donesv				Sheet 1	All sheet 1	
Controlled	Ilyov				"NIKDIM" OOD		

- End of test report -

ВАРНО С ОРИГИНАЛА





NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA

HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA

Matriculation certificate: J16/312/1999, VAT number RO3871599

Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890

www.icmet.ro ; E-mail: market@icmet.ro



accredited for
TESTING



SR EN ISO/CEI 17025:2005
ACCREDITATION CERTIFICATE
LI 1036

TEST REPORT

No. 45959 / 08.08.2017

1. **CUSTOMER: NIKDIM Ltd.**
Address: 23rd Shipchensky Polk No. 80, 6100.Kazanlak, Bulgaria
2. **MANUFACTURER: NIKDIM Ltd.**
Address: 23rd Shipchensky Polk No. 80, 6100 Kazanlak, Bulgaria
3. **TESTED PRODUCT: Indoor post insulator 35kV type PAM 35**
4. **REFERENCE STANDARD: IEC 60168 : 2001**
5. **PERFORMED TEST:**
 - I – Dry lightning impulse voltage withstand test
 - II – Dry power frequency voltage withstand test
6. **TESTS DATE: 08.08.2017**
7. **TESTS RESULT: The product passed the test.**

The test report contains 12 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies 2÷ 4 are sent to the customer.

HEAD OF HVD – TECHNICAL MANAGER,

Dipl. eng. [На основание чл.2 от 33ЛД](#)

HEAD OF TESTING TEAM,

Warnings:

- a. The results refer only to the tested product.
- b. Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- c. All signatures of the present report are original ones.

Code F-01.22.01(e)

© ICMET Craiova – 2017

ВЯРНО С ОРИГИНАЛА



Content

Page

➤ Identification of the test product.....	3
➤ Main technical characteristics established by manufacturer.....	3
➤ Tests program.....	3
➤ Responsible for tests.....	3
➤ Present at the test.....	3
➤ Dry lightning impulse voltage withstand test	4, 5
➤ Photo	5
➤ Oscillograms.....	6 ÷ 10
➤ Dry power frequency voltage withstand test.....	11
➤ Drawing.....	12



1. IDENTIFICATION OF THE TEST PRODUCT: Indoor post insulator

Type: PAM 35

Serial / year: - / 2017

Technical Specification / Drawing: - / see page 12

Client test order: Contract no. 876 / 03.08.2017

Internal test order: 23362 / 07.08.2017

Product receiving date: 07.08.2017

Product condition at receiving: New

2. MAIN TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Maximum working voltage.....36 kV

Dry lightning impulse withstand voltage 1.2 / 50 μ s:.....190 kV_{peak}

Dry power frequency withstand voltage :80 kV_{rms}

Material : porcelain C110


Colour of glaze: white

Note : The level of test voltages were specified by the customer .

3. TESTS PROGRAM:

- I - Dry lightning impulse voltage withstand test
- II - Dry power frequency voltage withstand test

4. RESPONSIBLE FOR TEST: Dipl. eng. Laurențiu Vlădoi (I) *[Signature]*
/Dipl. eng. Dan Ștefan (II) *[Signature]*



5. PRESENT AT TESTS: General Manager eng. Maria Georgieva -- NIKDIM Bulgaria

[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРИГИНАЛА

I. DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST

1. Test date: 08.08.2017

2. Test standard: IEC 60168 : 2001, subclause 4.5

3. Equipment used:

- Impulse generator 4.2 MV, no. 5 – 1197; connection I₂ (2 x 1);
- C_s = 0.288 [μF]; R_s = 94 [Ω]; R_p = 230 [Ω].

Addenda: C_s – equivalent capacity of impulse generator;
 R_s – equivalent serial resistance of impulse generator;
 R_p – equivalent parallel resistance of impulse generator.

Measuring system used:

- High voltage measuring system of impulse generator 4.2 MV consists of:
 - Capacitive divider of the impulse generator 4.2 MV with k_{div} = 699.3;
 - Digital measuring system type TR – AS 100 – 10 / 4, no.228; channel 2.
 (Calibration Certificate no. 91 / 12.2016)

Measuring uncertainty for: peak value of lightning impulse is: ± 1.56 %

- for front time T₁ is ± 7.41 %,
- for tail time T₂ is ± 3.28 %.

The uncertainty stated is expanded uncertainty obtained by multiplying the standard uncertainty by the coverage factor k = 2. The value of measurand lies within the assigned range of values with probability of 95%.

4. Test procedure / Test set-up: according to IEC 60168 : 2001, subclause 4.4.1.

5. Atmospheric conditions; correction factors; U_{test}

Atmospheric conditions:	p [mbar]	1005
	t [°C]	27
	h _r [%]	51
Arcing distance measured [mm]:		335
Correction factors:	k ₁	0.969
	k ₂	1.0219
	k _t = k ₁ · k ₂	0.9902
U _{test} (p ₀ , t ₀ , h ₀) (-) and (+) [kV _{peak}]:		190
U _{test} (p, t, h) = k _t · U _{test} (p ₀ , t ₀ , h ₀):		188.1

Symbols used:

- U_{test}(p₀, t₀, h₀) – rated withstand voltage value;
- U_{test}(p, t, h) – test voltage corrected to atmospheric conditions;

6. Test circuit diagram:




Fig. 1

Legend: EUT – Equipment under test



Notes:

1. The test was performed by the withstand voltage procedure with 15 impulses.
2. The standard 1.2 / 50 μ s lightning impulse was used. For wave parameters see oscillograms from pages 6 + 10.




Photo 1

7. Test result: The product passed the test.

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]









ВЯРНО С ОРИГИНАЛА



LI lightning-impulse						
no.	Up [kV]	T1[μ s]	T2[μ s]	Tc[μ s]	Ip[A]	remark
317027	-98.8	1.42	45.7			RFW / PAM 35
317028	-189	1.43	45.4			FW / PAM 35
317029	-188	1.43	45.5			FW / PAM 35
317030	-187	1.42	45.6			FW / PAM 35
317031	-189	1.43	45.5			FW / PAM 35
317032	-189	1.43	45.6			FW / PAM 35
317033	-190	1.43	45.6			FW / PAM 35
317034	-190	1.43	45.6			FW / PAM 35
317035	-190	1.43	45.4			FW / PAM 35
317036	-190	1.42	45.6			FW / PAM 35
317037	-190	1.43	45.5			FW / PAM 35
317038	-190	1.43	45.6			FW / PAM 35
317039	-190	1.43	45.5			FW / PAM 35
317040	-189	1.43	45.7			FW / PAM 35
317041	-189	1.43	45.6			FW / PAM 35
317042	-190	1.43	45.6			FW / PAM 35
317043	95.8	1.42	45.4			RFW / PAM 35
317045	189	1.44	45.6			FW / PAM 35
317046	188	1.43	45.8			FW / PAM 35
317047	190	1.43	45.7			FW / PAM 35
317048	190	1.43	45.6			FW / PAM 35
317049	189	1.43	45.6			FW / PAM 35
317050	189	1.43	45.7			FW / PAM 35
317051	188	1.43	45.6			FW / PAM 35
317052	188	1.44	45.6			FW / PAM 35
317053	189	1.43	45.6			FW / PAM 35
317054	189	1.44	45.8			FW / PAM 35
317055	189	1.43	45.7			FW / PAM 35
317056	189	1.43	45.6			FW / PAM 35
317057	189	1.43	45.6			FW / PAM 35
317058	189	1.43	45.6			FW / PAM 35
317059	189	1.42	45.6			FW / PAM 35

Notes: 1. UP-peak value of testing voltage; T1, T2, Tc – front, tail and chopping time – parameters of testing impulse wave;









2. RFW – reduced wave 50 – 75%; FW – full wave 100%











[Handwritten signature]

[Handwritten signature]

ВАРНО С ОРИГИНАЛА













[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРИГИНАЛА



II. DRY POWER FREQUENCY VOLTAGE WITHSTAND TEST

1. Test date: 08.08.2017
2. Test standard: IEC 60168:2001, subclause 4.7
3. Equipment used:
 - Test transformer 350 kVA / 350 kV, no.3 – 1963

Measuring system:

- AC measuring system 350 kV consists of:
 - high voltage compressed gas capacitor type MCF 75 / 350P, no.853889 and low voltage arm type H90, no.898939;
 - digital peak voltmeter type MU-17, no. 910396;
 - coaxial measuring cable, 75Ω.

(Calibration Certificate no.41 / 04.2015).

Measuring uncertainty is $\pm 1.6\%$.

The reported uncertainty is an expanded uncertainty, based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95 %.

4. Test procedure / Test set-up: according to IEC 60168 : 2001, subclause 4.4.1

5. Atmospheric condition, correction factors, U_{test}

Atmospheric conditions:	p [mbar]	1005
	t [°C]	27
	h _r [%]	51
Arcing distance measured [mm]:		335
Correction factors:	k ₁	0.9841
	k ₂	1.0151
	k _t = k ₁ · k ₂	0.999
Frequency:	[Hz]	50
Time:	[sec]	60
$U_{test}(p_0, t_0, h_0)$:	[kV _{rms}]	80
$U_{test}(p, t, h) = k_t \cdot U_{test}(p_0, t_0, h_0)$:		79.92

Symbols used:

- $U_{test}(p_0, t_0, h_0)$ – rated withstand voltage value;
- $U_{test}(p, t, h)$ – test voltage corrected to atmospheric conditions.

6. Test circuit diagram:





Fig. 2

7. Test result: The product passed the test.


ВЯРНО С ОПРИГИНАЛА



1. Material: porcelain C110 according to IEC 60672.
2. Colour of glaze - white.
3. Maximum working voltage - 36 kV.
4. The general tolerances are according to DIN 40680.
5. Electrical parameters according to IEC 60168.

				ND 92.03.00.00				
Alter	Number	No of clocum.	Signature	Date	Support insulators for indoor mounting type PAM 35	Stage	Mass	Mauqa6
Developed		Iliev						1:1
Controlled		Donev				Sheet 1	All sheet	1
Controlled		Donev				"NIKDIM" OOD		

- end of test report -



NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA
HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA
Matriculation certificate: J16/312/1999, VAT number: RO3871599
Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890
www.icmet.ro ; E-mail: market@icmet.ro



TEST REPORT
No. 45984 / 24.08.2017

1. CUSTOMER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
2. MANUFACTURER:	NIKDIM Ltd. 23rd Shipchensky Polk No 80, 6100 Kazanlak, Bulgaria
3. TESTED PRODUCT:	Indoor Post Insulator type PAM 35
4. REFERENCE STANDARD:	Customer requirements (IEC 60168:2001, clause 5.2.4)
5. PERFORMED TESTS:	Mechanical failing load test. Bending test
6. TEST DATE:	23.08.2017
7. TEST RESULTS:	The product passed the test

The test report contains 5 pages and is edited in 4 copies, copy no.1 remains in laboratory and copies 2, 3, 4 are sent to the customer.

HEAD OF HVD – TECHNICAL MANAGER,

HEAD OF TESTING TEAM,

Dipl. Eng. Ion Burciu

Dipl. Eng. Ion Dinu

На основание чл.2 от ЗЗЛД

Warnings:

- The results refer only to the tested product.
- Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- All signatures of the present report are original ones.

ВЯРНО С ОПРИГНАЛА

Cod F-01:22.01(e)

© ICMET Craiova – 2017



CONTENT

1. Identification of the test product	page 3
2. Technical characteristics established by manufacturer	page 3
3. Tests program	page 3
4. Responsible for test	page 3
5. Present at the test	page 3
6. Tests description and test results presentation	page 4
Annex	page 5

**1. IDENTIFICATION OF THE TEST PRODUCT**

Type:	PAM 35
Serial / year:	-
Technical Specification / Drawing:	Drawing no. ND 92.03.00.00 - Support insulators for indoor mounting type PAM 35
Contract / Test order:	Add. Act No.1 to the Contract No.705.2/876/03.08.2017
Internal test order:	23377/23.08.2017
Product receiving date:	23.08.2017
Product condition at receiving:	New

2. TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER

Maximum working voltage	36 kV
Mechanical failing load	4000 N (indicated by the customer)

3. TESTS PROGRAM

Mechanical failing load test. Bending test Customer requirements
(IEC 60168:2001, clause 5.2.4)

4. RESPONSIBLE FOR TEST

Dipl. Eng. Radu Serban Georgescu 

5. PRESENT AT THE TEST

Maria Georgieva- NIKDIM Ltd.

ВЯРНО С ОРИГИНАЛА

6. MECHANICAL FAILING LOAD TEST. BENDING TEST

Test date:	23.08.2017
Test standard:	Customer requirements -- 4000 N (IEC 60168:2001, clause 5.2.4)
Atmospheric conditions:	t = 26 °C; RH = 50%
Equipment used:	<ul style="list-style-type: none">• Manual lever hoist SAFETEX 3000 kg, manufacturer SC Delta Flex SRL Bucharest• Tension load cell, model CTL 1000 kg, serial no. 201106182, manufacturer LAUMAS ELECTRONICA Italy, CC no. F - 03/329/2017, SC GELUTECH Laboratory of Forces SRL
Test procedure:	<p>The post insulator was subjected to a bending load, to verify the mechanical failing load of 4000 N, as specified in Annex 1 of the contract.</p> <p>The load was applied perpendicular to the axis of the post insulator, to the free end (see Photo 1).</p> <p>The specified bending load was reached.</p>
Test results:	The product passed the test.





Photo 1

Annex 1



-End of test report -

ВЯРНО С ОРИГИНАЛА





NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA
HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA
Matriculation certificate: J-16/312/1999, VAT number RO3871599
Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890
www.icmet.ro ; E-mail: market@icmet.ro



accredited for
TESTING



SR EN ISO/CEI 17025:2005
ACCREDITATION CERTIFICATE
LI 1036

TEST REPORT

No. 45970 / 09.08.2017

1. CUSTOMER: NIKDIM Ltd.

Address: 23rd Shipchensky Polk No. 80, 6100 Kazanlak, Bulgaria

2. MANUFACTURER: NIKDIM Ltd.

Address: 23rd Shipchensky Polk No. 80, 6100 Kazanlak, Bulgaria

3. TESTED PRODUCT: Indoor to Indoor Bushing type PrB 10

4. REFERENCE STANDARD: IEC 60137 : 2017

5. PERFORMED TEST:

- I - Dry lightning impulse voltage withstand test
- II - Dry power frequency voltage withstand test

6. TESTS DATE: 10.08.2017

7. TESTS RESULT: The product passed the test.

The test report contains 12 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies 2÷ 4 are sent to the customer.

HEAD OF HVD – TECHNICAL MANAGER,
Dipl. eng. Ion BURCIU

HEAD OF TESTING TEAM,
Dipl. eng. Ion BADEA

На основание чл.2 от ЗЗЛД

Warnings:

- a. The results refer only to the tested product.
- b. Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- c. All signatures of the present report are original ones.

ВЯРНО С ОПРИГИНАЛА

Code F-01.22.01(e)

© ICMET Craiova – 2017



Content

Page

➤ Identification of the test product.....	3
➤ Main technical characteristics established by manufacturer.....	3
➤ Tests program.....	3
➤ Responsible for tests.....	3
➤ Present at the test.....	3
➤ Dry lightning impulse voltage withstand test	4, 5
➤ Photo.....	5
➤ Oscillograms.....	6 + 10
➤ Dry power frequency voltage withstand test.....	11
➤ Drawing.....	12



1. IDENTIFICATION OF THE TEST PRODUCT: Indoor to Indoor Bushing 10kV/400A

Type: PrB 10

Serial / year: - / 2017

Technical Specification / Drawing: - / see page 7

Client test order: Contract no. 876 / 03.08.2017

Internal test order: 23362 / 07.08.2017

Product receiving date: 10.08.2017

Product condition at receiving: New

2. MAIN TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Maximum working voltage (Um).....12 kV

Rated current (Ir)..... 200A, 400A, 630A, 1000A

Dry lightning impulse withstand voltage 1.2 / 50 μ s:.....75 kV_{peak}

Dry power frequency withstand voltage.....42 kV_{rms}

Material : porcelain C110

Colour of glaze: brown

Note : Level of voltage test (42kV) for the dry power frequency withstand voltage test was specified by the customer.

3. TEST PROGRAM:

- I – Dry lightning impulse voltage withstand test
- II – Dry power frequency voltage withstand test

4. RESPONSIBLE FOR TEST: Dipl. eng. Laurențiu Vlădoi (I)
/ Dipl. eng. Dan Ștefan (II)

5. PRESENTS AT TESTS: General Manager eng. Maria Georgieva – NIKDIM Bulgaria

ВЪРНО С ОПРИГИНАЛА

DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST

1. Test date: 10.08.2017
2. Test standard: IEC 60137 : 2017 subclause 8.4
3. Equipment used:
 - Impulse generator 4.2 MV, no. 5 – 1197; connection I₁ (1 x 1);
 - C_s = 0.576 [μF]; R_s = 47 [Ω]; R_p = 115 [Ω].

Addenda: C_s – equivalent capacity of impulse generator;
 R_s – equivalent serial resistance of impulse generator;
 R_p – equivalent parallel resistance of impulse generator.

Measuring system used:

- High voltage measuring system of impulse generator 4.2 MV consists of:
 - Capacitive divider of the impulse generator 4.2 MV with k_{div} = 345.1;
 - Digital measuring system type TR – AS 100 – 10 / 4, no.228; channel 2.
- (Calibration Certificate no. 91 / 12.2016)

Measuring uncertainty for: peak value of lightning impulse is: ± 1.38 %

- for front time T₁ is ± 8.44 %,
- for tail time T₂ is ± 3.39 %.

The uncertainty stated is expanded uncertainty obtained by multiplying the standard uncertainty by the coverage factor k = 2. The value of measurand lies within the assigned range of values with probability of 95%.


4. Test procedure / Test set-up: according to IEC 60137 : 2017, subclause 8.4.
5. Atmospheric conditions; correction factors; U_{test}

Atmospheric conditions:	p [mbar]	1005
	t [°C]	27
	h _r [%]	51
Arcing distance measured [mm]:		220
Correction factors:	k ₁	0.9831
	k ₂	1.0131
	k _t = k ₁ · k ₂	0.9960
U _{test} (p ₀ , t ₀ , h ₀) (-) and (+) [kV _{peak}]:		75
U _{test} (p, t, h) = k _t · U _{test} (p ₀ , t ₀ , h ₀):		74.7

Symbols used:

- U_{test}(p₀, t₀, h₀) – rated withstand voltage value;
- U_{test}(p, t, h) – test voltage corrected to atmospheric conditions;

6. Test circuit diagram:



Legend: EUT – Equipment under test



Notes:

1. The test was performed applying 15 voltage impulses of positive polarity and 15 voltage impulses of negative polarity on the test voltage to 75kV peak (see foto).
2. The standard 1.2 / 50 μ s lightning impulse was used. For wave parameters see oscillograms from pages 6 + 10.




Photo 1

7. Test result: The product passed the test.

ВЯРНО С ОРИГИНАЛА

Code F-01.22.01(e)









© ICMET Craiova - 2017



project : 45970						
LI lightning-impulse						
no.	Up [kV]	T1[μ s]	T2[μ s]	Tc[μ s]	Ip[A]	remark
317241	-39.3	1.28	45			RFW / PRB 10
317242	-73.5	1.28	44.8			FW / PRB 10
317243	-74	1.28	44.7			FW / PRB 10
317244	-73.8	1.27	44.8			FW / PRB 10
317245	-73.8	1.27	44.8			FW / PRB 10
317246	-73.8	1.28	44.8			FW / PRB 10
317247	-73.9	1.27	44.7			FW / PRB 10
317248	-73.6	1.28	44.8			FW / PRB 10
317249	-73.5	1.28	44.8			FW / PRB 10
317250	-73.9	1.28	44.9			FW / PRB 10
317251	-74	1.28	44.8			FW / PRB 10
317252	-73.9	1.28	44.7			FW / PRB 10
317253	-73.8	1.27	44.7			FW / PRB 10
317254	-73.8	1.28	44.9			FW / PRB 10
317255	-73.5	1.28	44.7			FW / PRB 10
317256	-74.1	1.28	44.8			FW / PRB 10
317258	43.5	1.29	44.9			RFW / PRB 10
317259	73.8	1.29	44.7			FW / PRB 10
317260	74	1.29	44.7			FW / PRB 10
317261	73.9	1.28	44.7			FW / PRB 10
317262	74.7	1.28	44.7			FW / PRB 10
317263	73.5	1.28	44.7			FW / PRB 10
317264	74.1	1.28	44.7			FW / PRB 10
317265	73.7	1.28	44.7			FW / PRB 10
317266	73.9	1.28	44.8			FW / PRB 10
317267	74.1	1.28	44.7			FW / PRB 10
317268	74.2	1.29	44.8			FW / PRB 10
317269	74.2	1.28	44.8			FW / PRB 10
317270	73.8	1.28	44.7			FW / PRB 10
317271	73.8	1.28	44.7			FW / PRB 10
317272	74.2	1.28	44.8			FW / PRB 10
317273	73.9	1.28	44.7			FW / PRB 10

Notes: 1. UP-peak value of testing voltage; T1, T2, Tc – front, tail and chopping time – parameters of testing impulse wave;

2. RFW – reduced wave 50 – 75%; FW – full wave 100%



















Handwritten signature

ВЯРНО С ОРИГИНАЛА

Code F-01.22.01(e)









© ICMET Craiova - 2017





Handwritten signature

ВЕРНО С ОРИГИНАЛОМ



II. DRY POWER FREQUENCY VOLTAGE WITHSTAND TEST

1. Test date: 11.08.2017
2. Test standard: IEC 60137 : 2017, subclause 8.2.
3. Equipment used:
 - Test transformer 350 kVA / 350 kV, no.3 – 1963

Measuring system:

- AC measuring system 350 kV consists of:
 - high voltage compressed gas capacitor type MCF 75 / 350P, no.853889 and low voltage arm type H90, no.898939;
 - digital peak voltmeter type MU-17, no. 910396;
 - coaxial measuring cable, 75Ω.

(Calibration Certificate no.41 / 04.2015).

Measuring uncertainty is $\pm 1.6\%$.

The reported uncertainty is an expanded uncertainty, based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95 %.

4. Test procedure / Test set-up: according to IEC 60137 : 2017, subclause 8.2

5. Atmospheric condition, correction factors, U_{test}

Atmospheric conditions:	p [mbar]	1004
	t [°C]	27
	h_r [%]	51
Arcing distance measured [mm]:		220
Correction factors:	k_1	0.9905
	k_2	1.0028
	$k_t = k_1 \cdot k_2$	0.9992
Frequency:	[Hz]	50
Time:	[sec]	60
$U_{test}(p_0, t_0, h_0)$:	[kV _{rms}]	42
$U_{test}(p, t, h) = k_t \cdot U_{test}(p_0, t_0, h_0)$:		41.97

Symbols used:

- $U_{test}(p_0, t_0, h_0)$ – rated withstand voltage value;
- $U_{test}(p, t, h)$ – test voltage corrected to atmospheric conditions.

6. Test circuit diagram:






Fig. 2

7. Test result: The product passed the test.

ВЪРНО С ОПРИВНАТА



- end of test report -




NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA

HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA
Matriculation certificate: J16/312/1999, VAT number RO3871599
Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890
www.icmet.ro ; E-mail: market@icmet.ro



TEST REPORT

No. 45962 / 09.08.2017

1. **CUSTOMER: NIKDIM Ltd.**
Address: 23rd Shipchensky Polk No. 80, 6100 Kazanlak, Bulgaria
2. **MANUFACTURER: NIKDIM Ltd.**
Address: 23rd Shipchensky Polk No. 80, 6100 Kazanlak, Bulgaria
3. **TESTED PRODUCT: Indoor to Indoor Bushing type PrB 20kV**
4. **REFERENCE STANDARD: IEC 60137 : 2017**
5. **PERFORMED TEST:**
 - I – Dry lightning impulse voltage withstand test
 - II – Dry power frequency voltage withstand test
6. **TESTS DATE: 10÷11.08.2017**
7. **TESTS RESULT: The product passed the test.**

The test report contains 12 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies 2÷ 4 are sent to the customer.

HEAD OF HVD – TECHNICAL MANAGER,

Dipl На основание чл.2 от ЗЗЛД

HEAD OF TESTING TEAM,

EA

Warnings:

- a. The results refer only to the tested product.
- b. Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- c. All signatures of the present-report are original ones.

ВАРНО С ОПИТИВАТИА

Code F-01 22.01(e)
© ICMET Craiova – 2017



Content	Page
➤ Identification of the test product.....	3
➤ Main technical characteristics established by manufacturer.....	3
➤ Tests program.....	3
➤ Responsible for tests.....	3
➤ Present at the test.....	3
➤ Dry lightning impulse voltage withstand test	4, 5
➤ Photo.....	5
➤ Oscillograms.....	6 ÷ 10
➤ Dry power frequency voltage withstand test.....	11
➤ Drawing.....	12



1. IDENTIFICATION OF THE TEST PRODUCT: Indoor to Indoor Bushing 20kV; 400A

Type: PrB 20

Serial / year: - / 2017

Technical Specification / Drawing: - / see page 12

Client test order: Contract no. 876 / 03.08.2017

Internal test order: 23362 / 07.08.2017

Product receiving date: 10.08.2017

Product condition at receiving: New

2. MAIN TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Maximum working voltage (Um):.....24 kV

Rated current (Ir):..... 200A, 400A, 630A, 1000A

Dry lightning impulse withstand voltage 1.2 / 50 µs: 125 kV_{peak}

Dry power frequency withstand voltage:..... 65 kV_{rms}

Material : porcelain C110

Colour of glaze: brown

Note : The level of dry power frequency withstand voltage was specified by the customer.

3. TEST PROGRAM:

- I - Dry lightning impulse voltage withstand test
- II - Dry power frequency voltage withstand test

4. RESPONSIBLE FOR TEST: Dipl. eng. Laurențiu Viădoi (I)
Dipl. eng. Dan Ștefan (II)

5. PRESENTS AT TESTS: General Manager eng. Maria Georgieva – NIKDIM Bulgaria



DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST

1. Test date: 10.08.2017

2. Test standard: IEC 60137 : 2017 subclause 8.4

3. Equipment used:

- Impulse generator 4.2 MV, no. 5 – 1197; connection I₁ (1 x 1);
- C_s = 0.576 [μF]; R_s = 47 [Ω]; R_p = 115 [Ω].

Addenda: C_s – equivalent capacity of impulse generator;
 R_s – equivalent serial resistance of impulse generator;
 R_p – equivalent parallel resistance of impulse generator.

Measuring system used:

- High voltage measuring system of impulse generator 4.2 MV consists of:
 - Capacitive divider of the impulse generator 4.2 MV with k_{div} = 345.1;
 - Digital measuring system type TR – AS 100 – 10 / 4, no.228; channel 2.
 (Calibration Certificate no. 91 / 12.2016)

Measuring uncertainty for: peak value of lightning impulse is: ± 1.38 %
 for front time T₁ is ± 8.44 %,
 for tail time T₂ is ± 3.39 %.

The uncertainty stated is expanded uncertainty obtained by multiplying the standard uncertainty by the coverage factor k = 2. The value of measurand lies within the assigned range of values with probability of 95%.

4. Test procedure / Test set-up: according to IEC 60137 : 2017, subclause 8.4.


5. Atmospheric conditions; correction factors; U_{test}

Atmospheric conditions:	p [mbar]	1005
	t [°C]	27
	h _r [%]	52
Arcing distance measured [mm]:		275
Correction factors:	k ₁	0.969
	k ₂	1.0277
	k _t = k ₁ · k ₂	0.9958
U _{test} (p ₀ , t ₀ , h ₀) (-) and (+) [kV _{peak}]:		125
U _{test} (p, t, h) = k _t · U _{test} (p ₀ , t ₀ , h ₀):		124.5

Symbols used:

- U_{test}(p₀, t₀, h₀) – rated withstand voltage value;
- U_{test}(p, t, h) – test voltage corrected to atmospheric conditions;

6. Test circuit diagram:



Legend: EUT – Equipment under test

Notes:

1. The test was performed applying successively 15 voltage impulses of positive polarity and 15 voltage impulses of negative polarity. (see photo from page 5).
2. The standard 1.2 / 50 μ s lightning impulse was used. For wave parameters see oscillograms from pages 6 + 10.
3. Only one external flashover occurred (see oscillogram 317214) from page 6.





Photo 1

7. Test result: The product passed the test.











ВЯРНО С ОРИГИНАЛА

Code F-01.22.01(e)
© ICMET Craiova – 2017



LI lightning-impulse						
no.	Up [kV]	T1[μ s]	T2[μ s]	Tc[μ s]	Ip[A]	remark
317208	-65.6	1.27	44.7			RFW / PRB 20
317209	-124	1.29	44.7			FW / PRB 20
317210	-124	1.28	44.7			FW / PRB 20
317211	-124	1.29	44.8			FW / PRB 20
317212	-123	1.28	44.8			FW / PRB 20
317213	-123	1.28	44.8			FW / PRB 20
317214	-125	1.3		17.7		FW / PRB 20
317215	-124	1.29	44.8			FW / PRB 20
317216	-124	1.29	44.8			FW / PRB 20
317217	-123	1.28	44.7			FW / PRB 20
317218	-124	1.28	44.7			FW / PRB 20
317219	-124	1.28	44.8			FW / PRB 20
317220	-124	1.29	44.6			FW / PRB 20
317221	-124	1.28	44.8			FW / PRB 20
317222	-124	1.28	44.6			FW / PRB 20
317223	-124	1.28	44.7			FW / PRB 20
317224	65.5	1.28	44.9			RFW / PRB 20
317225	124	1.27	44.7			FW / PRB 20
317226	124	1.28	44.8			FW / PRB 20
317227	124	1.27	44.7			FW / PRB 20
317228	124	1.28	44.8			FW / PRB 20
317229	123	1.27	44.7			FW / PRB 20
317230	123	1.28	44.8			FW / PRB 20
317231	123	1.27	44.7			FW / PRB 20
317232	124	1.27	44.7			FW / PRB 20
317233	123	1.28	44.7			FW / PRB 20
317234	124	1.28	44.7			FW / PRB 20
317235	124	1.27	44.7			FW / PRB 20
317236	124	1.28	44.7			FW / PRB 20
317237	124	1.27	44.8			FW / PRB 20
317238	123	1.28	44.8			FW / PRB 20
317239	124	1.28	44.7			FW / PRB 20









Notes: 1. UP-peak value of testing voltage; T1, T2, Tc – front, tail and chopping time – parameters of testing impulse wave;
2. RFW – reduced wave 50 – 75%; FW – full wave 100%











ВАРНО С ОРИГИНАЛА









Code F-01.22.01(e)

©ICMET Craiova - 2017





ВАРНО С ОРИГИНАЛА



II. DRY POWER FREQUENCY VOLTAGE WITHSTAND TEST

1. Test date: 11.08.2017
2. Test standard: IEC 60137 : 2017, subclause 8.2.
3. Equipment used:
 - Test transformer 350 kVA / 350 kV, no.3 – 1963

Measuring system:

- AC measuring system 350 kV consists of:
 - high voltage compressed gas capacitor type MCF 75 / 350P, no.853889 and low voltage arm type H90, no.898939;
 - digital peak voltmeter type MU-17, no. 910396;
 - coaxial measuring cable, 75Ω.

(Calibration Certificate no.41 / 04.2015).

Measuring uncertainty is ± 1.6 %..

The reported uncertainty is an expanded uncertainty, based on a standard uncertainty multiplied by a coverage factor k = 2, providing a level of confidence of approximately 95 %.

4. Test procedure / Test set-up: according to IEC 60137 : 2017, subclause 8.2

5. Atmospheric condition, correction factors, U_{test}

Atmospheric conditions:	p [mbar]	1005
	t [°C]	25
	h _r [%]	58
Arcing distance measured [mm]:		275
Correction factors:	k ₁	0.9840
	k ₂	1.0148
	k _t = k ₁ · k ₂	0.9986
Frequency:	[Hz]	50
Time:	[sec]	60
$U_{test}(p_0, t_0, h_0)$:	[kV _{rms}]	65
$U_{test}(p, t, h) = k_t \cdot U_{test}(p_0, t_0, h_0)$:		64.9

Symbols used:

- $U_{test}(p_0, t_0, h_0)$ – rated withstand voltage value;
- $U_{test}(p, t, h)$ – test voltage corrected to atmospheric conditions.

6. Test circuit diagram:






Fig. 2

7. Test result: The product passed the test.

ВЯРНО С ОПРИВИНАТА



- 1. Material: porcelain C110 according to IEC 60672.
- 2. Colour of glaze - brown.
- 3. Maximum working voltage - 24 kV.
- 4. Rated current through the bushing - 400A.
- 5. The general tolerances are according to DIN 40680.
- 6. Electrical parameters according to IEC 60137.

		ND 62.03.02.00	
Approved	Checked	Bushing insulators type PrB 20/400	
Designed	Drawn	Scale	1:1
		"NIKDIM" OOD	

- end of test report -



NATIONAL INSTITUTE FOR RESEARCH, DEVELOPMENT
AND TESTING IN ELECTRICAL ENGINEERING

ICMET CRAIOVA

HIGH VOLTAGE DIVISION

Low and High Voltage Testing Laboratory

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA
Matriculation certificate: J16/312/1999, VAT number RO3871599
Phone: + 40 0351 402425, 404888; Fax: +40 0351 404890
www.icmet.ro ; E-mail: market@icmet.ro



accredited for
TESTING



SR EN ISO/CEI 17025:2005
ACCREDITATION CERTIFICATE
LI 1036

TEST REPORT

No. 45957 / 08.08.2017

1. CUSTOMER: NIKDIM Ltd.

Address: 23rd Shipchensky Polk No. 80, 6100 Kazanlak, Bulgaria

2. MANUFACTURER: NIKDIM Ltd.

Address: 23rd Shipchensky Polk No. 80, 6100 Kazanlak, Bulgaria

3. TESTED PRODUCT: Outdoor to Indoor Bushing type PrBO 10

4. REFERENCE STANDARD: IEC 60137 : 2017

5. PERFORMED TEST:

- I - Dry lightning impulse voltage withstand test
- II - Dry power frequency voltage withstand test
- III - Wet power frequency voltage withstand test

6. TESTS DATE: 08.08.2017

7. TESTS RESULT: The product passed the test.

The test report contains 14 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies 2-4 are sent to the customer.

HEAD OF HVD - TECHNICAL MANAGER,

Dipl. eng. Ion BURCIU

HEAD OF TESTING TEAM,

Dipl. eng. Ion BADEA

На основание чл.2 от ЗЗЛД

Warnings:

- a. The results refer only to the tested product.
- b. Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
- c. All signatures of the present report are original ones.

Code F-01.22.01(e)

© ICMET Craiova - 2017

ВЯРНО С ОРИГИНАЛА



Content	Page
➤ Identification of the test product.....	3
➤ Main technical characteristics established by manufacturer.....	3
➤ Tests program.....	3
➤ Responsible for tests.....	3
➤ Present at the test.....	3
➤ Dry lightning impulse voltage withstand test	4, 5
➤ Photo.....	5
➤ Oscillograms.....	6 + 10
➤ Dry power frequency voltage withstand test.....	11
➤ Wet power frequency voltage withstand test.....	12, 13
➤ Drawing.....	14



1. IDENTIFICATION OF THE TEST PRODUCT: Outdoor to Indoor Bushing 10kV/400A

Type: PrBO 10

Serial / year: - / 2017

Technical Specification / Drawing: -- / see page 14

Client test order: Contract no. 876 / 03.08.2017

Internal test order: 23362 / 07.08.2017

Product receiving date: 07.08.2017

Product condition at receiving: New

2. MAIN TECHNICAL CHARACTERISTICS ESTABLISHED BY MANUFACTURER:

Maximum working voltage(Um):..... 12 kV

Rated current (Ir):..... 200A, 400A, 630A, 1000A

Dry lightning impulse withstand voltage 1.2 / 50 μs: 75 kV_{peak}

Dry power frequency withstand voltage test:42 kV_{rms}

Wet power frequency withstand voltage test:28 kV_{rms}

Material : porcelain C110

Colour of glaze: brown

Note :

1. The dry power frequency withstand voltage test was performed at the customer request.

2. The level of dry and wet power frequency withstand voltages was specified by customer.

3. TESTS PROGRAM:

- I - Dry lightning impulse voltage withstand test
- II - Dry power frequency voltage withstand test
- III - Wet power frequency voltage withstand test

4. RESPONSIBLE FOR TEST: Dipl. eng. Laurențiu Vlădoi (I)
Dipl. eng. Dan Ștefan (II, III)

5. PRESENT AT TESTS: General Manager eng. Maria Georgieva – NIKDIM Bulgaria



ВЯРНО С ОРИГИНАЛА

I. DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST

1. Test date: 08.08.2017

2. Test standard: IEC 60137 : 2017 subclause 8.4

3. Equipment used:

- Impulse generator 4.2 MV, no. 5 – 1197; connection I₁ (1 x 1);
- C_s = 0.576 [μF]; R_s = 47 [Ω]; R_p = 115 [Ω].

Addenda: C_s – equivalent capacity of impulse generator;
 R_s – equivalent serial resistance of impulse generator;
 R_p – equivalent parallel resistance of impulse generator.

Measuring system used:

- High voltage measuring system of impulse generator 4.2 MV consists of:
 - Capacitive divider of the impulse generator 4.2 MV with k_{div} = 345.1;
 - Digital measuring system type TR – AS 100 – 10 / 4, no.228; channel 2.
 (Calibration Certificate no. 91 / 12.2016)

Measuring uncertainty for: peak value of lightning impulse is: ± 1.38 %

- for front time T₁ is ± 8.44 %,
- for tail time T₂ is ± 3.39 %.

The uncertainty stated is expanded uncertainty obtained by multiplying the standard uncertainty by the coverage factor k = 2. The value of measurand lies within the assigned range of values with probability of 95%.

4. Test procedure / Test set-up: according to IEC 60137 : 2017, subclause 8.4.

5. Atmospheric conditions; correction factors; U_{test}

Atmospheric conditions:	p [mbar]	1005
	t [°C]	26
	h _r [%]	53
Arcing distance measured [mm]:		185
Correction factors:	k ₁	0.9782
	k ₂	1.0174
	k _t = k ₁ · k ₂	0.9952
U _{test} (p ₀ , t ₀ , h ₀) (-) and (+) [kV _{peak}]:		75
U _{test} (p, t, h) = k _t · U _{test} (p ₀ , t ₀ , h ₀):		74.6

Symbols used:

- U_{test}(p₀, t₀, h₀) – rated withstand voltage value;
- U_{test}(p, t, h) – test voltage corrected to atmospheric conditions;

6. Test circuit diagram:




Fig. 1

Legend: EUT – Equipment under test



Notes:

1. The test was performed applying successively 15 voltage impulses of positive polarity and 15 voltage impulses of negative polarity (see photos from page 5).
2. The standard 1.2 / 50 μ s lightning impulse was used. For wave parameters see oscillograms from pages 6 + 10,




Photo 1

7.Test result: The product passed the test.

ВЯРНО С ОРИГИНАЛА

II. DRY POWER FREQUENCY VOLTAGE WITHSTAND TEST

1. Test date: 08.08.2017
2. Test standard: IEC 60137 : 2017, subclause 8.2.
3. Equipment used:
 - Test transformer 350 kVA / 350 kV, no.3 – 1963

Measuring system:

- AC measuring system 350 kV consists of:
 - high voltage compressed gas capacitor type MCF 75 / 350P, no.853889 and low voltage arm type H90, no.898939;
 - digital peak voltmeter type MU-17, no. 910396;
 - coaxial measuring cable, 75Ω.

(Calibration Certificate no.41 / 04.2015).

Measuring uncertainty is $\pm 1.6\%$.

The reported uncertainty is an expanded uncertainty, based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95. %.

4. Test procedure / Test set-up: according to IEC 60137 : 2017, subclause 8.2

5. Atmospheric condition, correction factors, U_{test}

Atmospheric conditions:	p [mbar]	1005
	t [°C]	26
	h _r [%]	53
Arcing distance measured [mm]:		185
Correction factors:	k ₁	0.9955
	k ₂	1.0042
	k _t = k ₁ · k ₂	0.9997
Frequency:	[Hz]	50
Time:	[sec]	60
$U_{test}(p_0, t_0, h_0)$:	[kV _{rms}]	42
$U_{test}(p, t, h) = k_t \cdot U_{test}(p_0, t_0, h_0)$:		41.98

Symbols used:

- $U_{test}(p_0, t_0, h_0)$ – rated withstand voltage value;
- $U_{test}(p, t, h)$ – test voltage corrected to atmospheric conditions.

6. Test circuit diagram:




Fig. 2

7. Test result: The product passed the test.