

1. Предмет на изпитването:

Изпитван детайл от системата: херметичен проход BKD 150-K/150
капачка BKD 150-D3/60

Подготовка на изпитването: виж рисунка приложение 1

Провеждане на изпитването: Подготовката на изпитването се осъществява от сътрудник на заявителя на измерването. След охлаждане съгласно изискването на изпитването до -25°C , системата е подложена на изпитване под водно налягане от 5 бара. Силата на установеното водно налягане беше измерена и отчетена за период от 24 часа.

Измервателна техника: Измервателен усилвател тип MGC/MC55

Датчик за налягане тип P8AP/10

Дата на изпитването: 29.06.2001 до 02.07.2001

Провел изпитването: Миахел Гом

2. Резултати от измерването:

Таблица с резултати:

Изпитване	Среда на изпитване	Налягане /бара/	Продължителност на изпитването /часа/	Налягане в началото на изпитването /бара/	Налягане в края на изпитването /бара/
1	Вода със защита от замръзване	5	60	5,11	4,99

През цялото време не се наблюдава изпускане на вода.

Лекото спадане на налягането е възстановено чрез охлаждане на средата на изпитването.

Графично изображение:

3. Забележки

Няма

Приложение № 1



Fraunhofer Institut
Fertigungstechnik
Materialforschung

Prüfbericht WP-PB-A301033Go-002 (Abschrift)
Der Prüfbericht umfasst 3 Blätter und 1 Anlage

Aufgabenstellung Messung der Dichtigkeit einer Kabeldurchführung der Fa. Doyma GmbH & Co des Typs BKD 150 gegenüber Wasserdruck bei -25°C

Auftraggeber DOYMA GmbH & Co
Industriestraße 43-57
28876 Oyten

Auftrags/Lieferschein Nr. vom 25.06.2001

Prüflabor Fraunhofer - Institut für Fertigungstechnik und Angewandte
Materialforschung (IFAM)
Labor für Werkstoffprüfung, Metallographie und Analytik
Wiener Straße 12
D - 28359 Bremen
Tel. +49 (0) 4 21 / 22 46 - 4 00
Fax. +49 (0) 4.21 / 22 46 - 4 30

Prüfgegenstände Kabeldurchführungssystem BKD 150

Eingangsdatum 25.06.2001

Hinweise Das Prüfergebnis bezieht sich ausschließlich auf die genannten Prüfgegenstände.
Ohne schriftliche Genehmigung des Prüflabors darf dieser Prüfbericht nicht auszugsweise vervielfältigt werden.
Soll vom Auftraggeber auf die Inanspruchnahme des Prüflabors hingewiesen werden, muss die vollständige Anschrift des Prüflabors angegeben werden.

Ausstellungsdatum Bremen, den 02.08.2001

Unterschrift

K. Borede

ВЕРНО С
ОПТИМАЛНА



[Handwritten signature]

1. Prüfgegenstand

Zu prüfende Einzelteile des Systems: Einfach-Dichtpackung BKD 150-K/150
Systemdeckel BKD 150-D3/60

Prüfvorrichtung: s. Zeichnung Anlage 1

Versuchsdurchführung: Die Prüfvorrichtung wurde von einem Mitarbeiter des Auftraggebers für die Messung vorbereitet.
Nach Kühlung der Prüfanordnung auf -25°C wurde das System mit einem Wasserdruck von 5 bar beaufschlagt.
Die Höhe des anstehenden Wasserdruckes wurde über einen Zeitraum von > 24 Stunden gemessen und aufgezeichnet.

Messtechnik: HBM-Messverstärker Typ MGC / MC55
(IFAM-Prüfmittel Nr.: A4.110-0001)

HBM-Druckaufnehmer Typ P8AP/10
(IFAM-Prüfmittel Nr.: D2.2110-0002)

Prüfdatum: 29.06.2001 bis 02.07.2001

Prüfer: Michael Gomm



Михаило
Гомм
↓


2. Messergebnisse

Ergebnistabelle:

Prüfung	Prüfmedium	Prüfdruck [bar]	Prüfdauer [Stunden]	Druck zu Beginn der Messung [bar]	Druck am Ende der Messung [bar]
1	Wasser mit Frostschutz	5	60	5.11	4.99

Es war zu keinem Zeitpunkt ein Wasseraustritt zu beobachten.
Der leichte Druckabfall ist durch die Abkühlung des Prüfmedium zurückzuführen.

Graphische Darstellung:




3. Bemerkungen

keine



ВЕРИТЕЛНО
ОПРЕДЕЛЕНИЕ

Anlage Nr. 1 zu IFAM Prüfbericht
 WP-PB-170/103390-002



ВЕРИТЕ С
 ОПРЕДЕЛЕНИЯ






София, бул. Самоков 1, тел. +359 884 00 55 78, +359 884 00 55 79,

<http://www.ngtechnology.org/>, office@ngtechnology.org

**Инструкции за експлоатация и монтаж
на
БКТП 800kVA/20/0,4kV типово изпитано
тип
CTRS**




БДС EN 62271-202:2007

2016г.



**ЖИМТЕХ-БЪЛГАРИЯ
ООД**



PPR 1410

Qualification of
Indoor Termination for
Single Core Polymeric
Insulated Cable 24 kV

Type: IXSU-F5131
(POLT-24D/1XI)

Pages: 17
Appendix: -


Tested by: FGH Mannheim-Germany
Date: 7.2.2000

© Reports may only be used in their original form

tyco
Electronics

Energy Division

AMP
Raychem
SIMEL



Tyco Electronics Raychem GmbH
Haldgraben 6
D-85621 Otlobrunn
Munich, Germany
Tel. +49 89 6089-0
Fax +49 89 6089-346

ВАРНО С
ОРИГИНАЛ



Accredited testing laboratory to DIN EN 45001 for subject

Test Certificate

No. : HV 00006/1 E

Reference: HV-K-9912



DAT-P-020/92-01

High-voltage apparatus,
switchgear and controlgear

DAT-P-020/92-12

High-voltage cables
and accessories

DAT-P-020/92-21

Voltage quality flicker

Apparatus: Indoor termination for screened single core
polymeric insulated cables up to 24 kV
70 - 240 mm²
type: IXSU-F5131 equivalent to type: POLT-24D/1XI

Manufacturer: Tyco Electronics Raychem GmbH
Haidgraben 6
D - 85521 Ottobrunn / München

Customer: Tyco Electronics Raychem GmbH
Haidgraben 6
D - 85521 Ottobrunn / München

Test Specification: CEN/LEC HD 629.1 S1:1996 table 3 no. 1 - 8, 10 and 12 - 14 (page 12)

Tests performed: D.C. voltage dry withstand
A.C. voltage dry withstand
partial discharge at ambient temperature
impulse voltage at elevated temperature
electrical heat cycling in air
partial discharge at elevated and ambient temperature
thermal short circuit (conductor)
impulse voltage at ambient temperature
A.C. voltage dry withstand
humidity

Test Result: The Tyco Electronics Raychem - Indoor termination, Type IXSU-F5131,
passed successfully the testing as detailed further.

Mannheim, 07.02.2000



FORSCHUNGSGEMEINSCHAFT FÜR
ELEKTRISCHE ANLAGEN UND STROMWIRTSCHAFT E.V.

Test Engineer:



Place and date of test: FGH-test laboratory Mannheim-Rheinau, 19.8. - 30.11.1999

Number of sheets: 17

BRAND C
ORIGINAL

A Test Certificate

is issued for equipment having passed tests according to valid standards, accepted specifications or recommendations performed in order to prove ratings. It is also issued if the relevant standard considers the determination of characteristic data and this determination has been carried out according to valid standards, accepted specifications or recommendations.

Equipment to be tested must be clearly identified by a nameplate according to the relevant standard and by suitable drawings or, if the standard does not require a nameplate, by suitable drawings and, if necessary, descriptions. In certain cases lists of parts may be necessary.

The Test Certificate confirms that during the test of an equipment according to the applied test specification the criteria for the behaviour of the test object during the test and for its condition after the test have been fulfilled.

A Test Report

is issued for tests which do not meet all requirements for a Test Certificate. The Test Report indicates all conditions under which the test has been performed as well as information about the behaviour of the equipment during test and its condition after test.

A Report

is issued for investigations which do not have the character of proving tests.

Under reference to DIN EN 45001 FGH states the following:

- The accreditation of FGH or any of its test documents by themselves in no way constitute or imply product approval by DATech or any other body.
- If a client refers to the accreditation of FGH this reference shall include the accreditation body, i.e. DATech, the relevant scope of the accreditation of FGH and the appropriate registration number.
- The test results included in test documents issued by FGH relate only to the items tested.
- The test documents issued by FGH shall not be reproduced, except in full, without the written approval of FGH.



**ВАРНО С
ОРИГИНАЛА**

table of contents

- 1. Description of the test objects**
- 2. Specification of the test routines**
- 3. Test procedures**
 - 3.1. D.C. voltage withstand
 - 3.2. A.C. voltage withstand
 - 3.3. Partial discharge measurement
 - 3.4. Impulse impulse voltage withstand test
 - 3.5. Electrical heat cycling in air
 - 3.6. Thermal short-circuit test (conductor)
 - 3.7. Humidity test
- 4. Table of test results**



**ВАРНО С
ОРИГИНАЛА**

1. Description of the test objects

Manufacturer: Tyco Electronics Raychem GmbH
Haidgraben 6
D - 85521 Ottobrunn / München

Type of the test objects: Indoor termination for screened single core
polymeric insulated cables up to 24 kV
70 - 240 mm²
type: IXSU-F5131

kit content, manufacturer-drawing and assembly instructions
see page 11

Type of the cable: NA2XS2Y 12,7 / 22 kV
cable with aluminium conductors, cross-linked PE-insulation,
screen of copper and thermoplastic PE-sheath
cross-section 150 mm²
all combinations of cables and terminations had a length of about 3,1 m
(cable-manufacturer : Kabelmetall)

Numbers and test sequences of the test objects:

cable sample FGH no.	test sequence according to HD 629.1 S1 table 3
2011	A1
2012	A1
2001	A2
2002	A2
2005	A3
2006	A3
2009	A3

Mounting: The assembling of the terminations was made at Tyco Electronics Raychem.

ВАРНО С
ОРЪЖИНАТА



2. Specification of the test routines according to CENELEC HD 629.1 S1:1996, table 3, test sequence A1, A2 and A3

The following tests were made in chronological order:

	Test	Test sequence and FGH cable no.			Test requirements
		A1	A2	A3	
1	D.C. voltage dry withstand	2011 2012	2001 2002		15 minutes at $6 U_0$ (76 kV) negative polarity
2	A.C. voltage dry withstand	2011 2012	2001 2002		5 minutes at $4,5 U_0$ (57 kV)
3	Partial discharge at ambient temperature	2011 2012			max. 10 pC at $1,73 U_0$ (22 kV)
4	Impulse voltage at elevated temperature	2011 2012			10 impulses of each polarity
5	Electrical heat cycling in air	2011 2012			3 cycles at $2,5 U_0$ (32 kV)
6	Partial discharge at elevated and ambient temperature	2011 2012			max. 10 pC at $1,73 U_0$ (22 kV)
7	Electrical heat cycling in air	2011 2012			123 cycles at $2,5 U_0$ (32 kV)
8	Partial discharge at elevated and ambient temperature	2011 2012			max. 10 pC at $1,73 U_0$ (22 kV)
10	Thermal short circuit (conductor)		2001 2002		2 short circuits to raise conductor to θ_{SC} of the cable
12	Impulse voltage at ambient temperature	2011 2012	2001 2002		10 impulses of each polarity
13	A.C. voltage dry withstand	2011 2012	2001 2002		15 minutes at $2,5 U_0$ (32 kV)
14	Humidity			2005 2006 2009	300 h duration at $1,25 U_0$ (16 kV)



3. Test procedures

3.1. D.C. voltage withstand

The smoothing condenser in parallel to the test object had a capacitance of 300 nF. The ripple factor was less than 1%. The test voltage of 76 kV was applied to the test object during 15 min.

3.2. A.C. voltage withstand

The power frequency voltage was generated by a 10-kVA-transformer with a rated primary voltage of 220 V and a rated secondary voltage of 125 kV. The voltage measurement was carried out with a capacitive divider (100 pF, ratio = 1818) and a peak voltmeter reading $\sqrt{2}$.

During the test a voltage of 57 kV was applied for 5 min.

3.3. Partial discharge measurement

The test was performed in accordance with IEC 270 using a partial discharge detector Tettex type 9126. The amplifier band width range of this measuring instrument covered 40 kHz through 200 kHz.

At a test voltage level of 22 kV the level of partial discharge was less than 10 pC.




Fig. 1: measurement of partial discharge

3.4. Impulse voltage withstand test

The tests were performed in accordance with IEC 230.

The time between two impulses was approximately 20 s. The characteristics of the applied impulse voltage were within the limits (front time $T_1 = 1...5 \mu s$ and time to half value $T_2 = 40...60 \mu s$). A digital impulse voltmeter was used to measure the peak values of the lightning impulses in combination with a ohmic voltage divider.

The tests were carried out by applying 10 consecutive impulses with a peak value of 125 kV, positive and negative polarity.

The atmospheric conditions were:

$T_1 = 1,51 \mu s$	$T_2 = 52,63 \mu s$
temperature:	15°C
air pressure:	1017 mbar
humidity:	43,5%






Fig. 2: impulse wave shape of the positive polarity (first and last of the 10 impulses)




Fig. 3: impulse wave shape of the negative polarity (first and last of the 10 impulses)




Figure 4: test circuit of impulse voltage test

ВЪРНО С
ОРИГИНАЛА



3.5. Electrical heat cycling in air

The electrical cycling test comprises 126 heating cycles.
 The tests were performed in accordance with HD 628 S1 : 1996, item 9.
 Cycles of 5 hours heating and 3 hours cooling were carried out. The voltage is continuously applied during the cycling at a level of 32 kV (phase-earth).

All 126 cycles were carried out in air.

In order to heat the conductors to 95°C – 100°C, the cables were loaded to 482 A.
 The conductor temperature was measured on an identical cable with the same current as the test loop. One record of the temperature-time-curve is shown in Fig. 5.





Fig. 5: temperature-time-curve of electrical heat cycling
 scale division 0 \triangleq 20 °C
 scale division 80 \triangleq 100 °C

ВАРНО С
 ОРМГНАЛА



3.6. Thermal short-circuit test (conductor)

The test was performed in accordance with HD 628 S1 : 1996, item 11.

By this test the samples were subjected to a symmetrical fault current of 1 sec. duration in order to heat the conductor up to 250°C. This procedure was carried out 2 times. Between the tests the samples had cooled down to ambient temperature.

1. short-circuit test: $I_{eff} = 18,5 \text{ kA}$ $t = 1 \text{ s}$

2. short-circuit test: $I_{eff} = 18,5 \text{ kA}$ $t = 1 \text{ s}$

FGH - LV 122-99/269




Fig. 6: current/time-curve, thermal short-circuit test (conductor)

ВАРНО С
ОРИГИНАЛ



3.7. Humidity test

The discharging rate of atomised water was $0,34 \text{ l/m}^2\text{h}$. Throughout the test duration, the spray water conductivity was $(70 \pm 10) \text{ mS/m}$. During the test a voltage of 16 kV was applied to the test objects.





Fig. 7+8: terminations before humidity test






Fig. 9+10: terminations after humidity test

**ВАРНО С
ОРИГИНАЛ**



4. Table of test results


Tests according to CENELEC HD 629.1 S1:1996, table 3, test sequence A1, A2 and A3

The following tests were made in chronological order, cable sample FGH no.2001, 2002, 2005, 2006, 2009, 2011, 2012:

	Test	Test sequence and FGH cable no.			Test results
		A1	A2	A3	
1	D.C. voltage dry withstand 15 minutes at 6 U ₀ (76 kV) negative polarity	2011 2012	2001 2002		passed
2	A.C. voltage dry withstand 5 minutes at 4,5 U ₀ (57 kV)	2011 2012	2001 2002		passed
3	Partial discharge at ambient temperature max. 10 pC at 1,73 U ₀ (22 kV)	2011 2012			≤ 10 pC
4	Impulse voltage at elevated temperature t _{conductor} = 96,3 °C 10 impulses of each polarity, Ū = 125 kV	2011 2012			passed
5	Electrical heat cycling in air 3 cycles, 5/3 h t _{conductor} = 98 °C Ū/√2 = 32 kV	2011 2012			passed
6	Partial discharge at elevated and ambient temperature max. 10 pC at 1,73 U ₀ (22 kV)	2011 2012			≤ 10 pC
7	Electrical heat cycling in air 123 cycles, 5/3 h t _{conductor} = 98 °C Ū/√2 = 32 kV	2011 2012			passed
8	Partial discharge at elevated and ambient temperature max. 10 pC at 1,73 U ₀ (22 kV)	2011 2012			≤ 10 pC
10	Thermal short circuit (conductor) 2 short circuits to raise conductor to θ _{SC} of the cable		2001 2002		passed
12	Impulse voltage at ambient temperature 10 impulses of each polarity, Ū = 125 kV	2011 2012	2001 2002		passed
13	A.C. voltage dry withstand 15 minutes at 2,5 U ₀ (32 kV)	2011 2012	2001 2002		passed
14	Humidity 300 h duration at 1,25 U ₀ (16 kV)			2005 2006 2009	passed 3 terminations in test room

The Tyco Electronics Raychem – Indoor termination, IXSU-F5131, passed successfully the testing as detailed above.

ВЪВЕДЕНА
ОПШЕНА



kit content of the indoor termination
for screened single core polymeric insulated cable 70-240 mm² up to 24 kV

QTY	description	
3	HVOT-50/16-340/242(S3)	insulating tubing with integrated stress control
3	S1189-1-100(A3)	filler tape for screen cut
3	S1085-3-200	sealant tape for screen wires
1	BPP-0778-8/99	installation instruction

ВЪРНО С
ОРМОНАТА





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
УЦСО Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web:www.kimtech.bg
e-mail: office@kimtech.bg

Списък на проведените изпитвания на щепселна кабелна глава /адаптор/ тип RICS

1. Изпитване с променливо напрежение 50kV, 50Hz;
2. Изпитване частичен разряд;
3. Изпитване устойчивост при номинално импулсно напрежение;
4. Изпитване продължително променливо напрежение с циклични токови натоварвания;
5. Изпитване комутация/включване/изключване;
6. Изпитване термично късо съединение;
7. Изпитване издръжливост с циклични токови натоварвания;
8. Изпитване циклично електрическо нагряване във въздух;
9. Изпитване импулсно напрежение при околна температура;
10. Изпитване частичен разряд при околна температура;
11. Влажност;

13.01.2016г.

Подпис и печат



Independent, accredited testing station · Member laboratory of STL and LOVAG

TYPE TEST REPORT

No. 1213.1607.6.939

Tyco Electronics Raychem GmbH
 Finsinger Feld 1
 85521 Ottobrunn
 GERMANY

CLIENT

Tyco Electronics Raychem GmbH

MANUFACTURER

Screened separable cable connector for single-core cables with extruded plastic insulation

TEST OBJECT

RSS5-52xx-R

TYPE

12 test samples

SERIAL NO.

Rated voltage	U_0/U	12.7/22 kV	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Maximum value between two phase conductors	U_m	24 kV	
Rated current		250 A	
Rated cross-section range		50 mm ²	

CENELEC Harmonization Document HD 629.1 S2: 2006-02
 DIN VDE 0278-629.1 (VDE 0278 Teil 629-1): 2002-06
 IEC 61442: 2005-04
 DIN VDE 0278-442 (VDE 0278 Teil 442): 2006-01

NORMATIVE DOCUMENT

Test sequences D1 and D2 as well as Special tests Nos. 17 to 21

RANGE OF TESTS PERFORMED

22 May 2007 to 12 December 2007

DATE OF TEST

The type test of test sequences D1 and D2 as well as the Special tests 17, 18, 19, 20 and 21 have been PASSED.

TEST RESULT

Pannicke
 PROF. DR. J. PANNICKE
 Managing director
 Berlin, 31 March 2008

D. Jegust
 D. JEGUST
 Test engineer in charge



Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DA Tech) e.V. in the fields of hv. apparatus and switchgear, power cables and power cable accessories, lv. apparatus and switchgear, insulation equipment and switching and control equipment.

Contents	Sheet
1. Participants in the test.....	3
2. Test performed.....	3
3. Identity of the test object.....	5
3.1 Technical data and characteristics.....	5
3.2 Identity documents.....	5
4. Tests of test sequence D1.....	6
4.1 Test laboratory.....	6
4.2 Normative document.....	6
4.3 Required test parameters.....	7
4.4 Test arrangement.....	9
4.5 Test and measuring circuits.....	11
4.6 Test results.....	16
4.7 Assessment of the results of test sequence D1.....	25
5. Tests of test sequence D2.....	27
5.1 Test laboratory.....	27
5.2 Normative document.....	27
5.3 Required test parameters.....	27
5.4 Test arrangement.....	28
5.5 Test and measuring circuits.....	29
5.6 Test results.....	31
5.7 Assessment of the tests of test sequence D2.....	36
6. Special tests (tests Nos. 17 to 21).....	37
6.1 Test laboratory.....	37
6.2 Normative documents.....	37
6.3 Required test parameters.....	37
6.4 Test arrangement.....	38
6.5 Test and measuring circuits.....	39
6.6 Test results.....	43
6.7 Assessment of special tests.....	46
7. Photos.....	47
8. Oszillogramme.....	50
9. Drawings.....	55
10. Identification of test cable.....	61


This test document consists of 61 sheets.

Distribution

Copy No. 1 In English:

Tyco Electronics Raychem GmbH

**ВЯРНО С
ОРИГИНАЛА**
Copy No. 1



1. Participants in the test

Mr. Jegust IPH test engineer in charge
 Mr. Moritz IPH test engineer (short-circuit tests and screen fault current initiation test)
 Mr. Schad Tyco Electronics Raychem GmbH (partially present)


2. Test performed

All tests of the test sequences D1, D2 as well as special tests Nos. 17 to 21 in the following order:

Test sequence	Test	Type of test
D1	1	DC voltage dry withstand test
	2	AC voltage dry withstand test
	3	Partial discharge test at ambient temperature
	4	Impulse voltage test at elevated temperature
	5	Electrical heat cycling test ¹⁾ in air
	6	Electrical heat cycling test ¹⁾ in water
	7	Disconnection/connection
	8	Partial discharge test at elevated and ambient temperatures
	9	Impulse voltage test at ambient temperature
	10	AC voltage dry withstand test

Test sequence	Test	Type of test
D2	1	DC voltage dry withstand test
	2	AC voltage dry withstand test
	3	Thermal short-circuit test of the conductor
	4	Dynamic short-circuit test of the conductor
	5	Disconnection/connection
	6	Impulse voltage test at ambient temperature
	7	AC voltage dry withstand test

**ВЯРНО С
ОРИГИНАЛА**



Test performed (continued)

Test sequence	Test	Type of test
Special tests	17	Screen resistance measurement
	18	Leakage current measurement ²⁾
	19	Screen fault current initiation test ³⁾
	20	Operating force test
	21	Test of capacitive test point performance ⁴⁾

The thermal short-circuit test of the screen does not apply because the test object is equipped neither with a connection to the metal screen nor with an adapter for the metal screen of the cable.

Test sequence D3 does not apply, as the test specimen is not equipped with an operating eye. Special tests Nos. 17 to 19 and 21 have been carried out on separate test objects.

Note to the tests:

CENELEC Harmonization Document HD 629.1 S2: 2006-02 and IEC 61442: 2005-04 use different terms with regard to the types of test. Below you find the terms of the normative document of the test procedure:

- 1) Heating cycles voltage test
- 2) Screen leakage current measurement
- 3) Screen fault current initiation test
- 4) Test of capacitive test point performance



**ВАЖНО С
ОРИГИНАЛА**

3. Identity of the test object

3.1 Technical data and characteristics

The technical data and characteristics of the test object are defined by the following parameters and specified by the client

Test object: Screened separable cable connector for single-core cables with extruded plastic insulation
 Type: RSSS-52xx-R
 Manufacturer: Tyco Electronics Raychem GmbH
 Serial No: 12 test samples
 Year of manufacture: 2006

Rated characteristics: Rated voltage U_0/U 12.7/22 kV
 Maximum value between two phase conductors U_m 24 kV
 Rated current 250 A
 Rated cross-section range of the conductor 50 mm²

Design: Type of cable connection Screened separable straight connector, with capacitive test point

Cable Screened single-core cable with extruded plastic insulation,

Cable marking N2XS(F)2Y 1x50 RM/16 mm² 12/20 kV
 Designation of manufacturer NEXANS
 Material of conductor Cu
 Material of screen Cu

3.2 Identity documents

The manufacturer confirms that the test object has been manufactured in compliance with the drawings given in this document. IPH did not verify this compliance in detail. The identity of the test object is fixed by the following drawings and data submitted by the client:

Name of drawing	Drawing No.	Date of drawing	Author	Notes
Installations Instruction Type RSSS	EPP-0579	1/01	Tyco Electronics	Sheets 35 to 60

Entry of test objects at IPH: 28 March 2007



**ВАЖНО С
ОРИГИНАЛА**

4. Tests of test sequence D1

4.1 Test laboratory

High-voltage test laboratory, high-voltage hall 2

4.2 Normative document

CENELEC Harmonization Document HD 629.1 S2: 2006-02
DIN VDE 0278-629.1 (VDE 0278 Teil 629-1): 2002-06
IEC 61442: 2005-04
DIN VDE 0278-442 (VDE 0278 Teil 442): 2006-01




**ВЯРНО С
ОРИГИНАЛА**

4.3 Required test parameters

Test No.	Type of test	Required test parameters
1	DC voltage dry withstand test	Test voltage $6 \times U_0$: 76 kV Duration of test: 15 min Polarity: Negative
2	AC voltage dry withstand test	Test voltage $4.5 \times U_0$: 57 kV Test frequency: 50 Hz Duration of test: 5 min
3	Partial discharge test at ambient temperature	Prestress voltage $2.25 \times U_0$: 29 kV Measuring voltage $2.00^{1)} \times U_0$: 25 kV Prestress duration: 1 min Measuring time: 1 min
4	Impulse voltage test at elevated temperature	Front time: 1.2 μ s Virtual time to half value: 50 μ s Test voltage: 125 kV Number of impulses: 10 impulses Polarity: pos./neg. Conductor temperature: 95 - 100 °C ²⁾
5	Electrical heat cycling test in air	<ul style="list-style-type: none"> • Continuous AC voltage Test voltage $2.5 \times U_0$: 32 kV Test frequency: 50 Hz Duration of test: 21 day • Thermal cycles Number of cycles: 63 Cycle (8 h): 5 hours of heating + 3 hours of cooling Conductor temperature during the last 2 hours of heating cycle: 95 - 100 °C ²⁾
6	Electrical heat cycling test in water	See test No. 5, additionally Height of water: 1 m
7	Disconnection/connection	Number of complete operations: 5
8	Partial discharge test at ambient temperature and elevated temperature	See test No. 3, except Conductor temperature: θ_U resp. 95 - 100 °C ²⁾
9	Impulse voltage test at ambient temperature	See test No. 4, except Conductor temperature: Duration of test: 15 min

ВАРНО С
 ОПИТНАЯ



Required test parameters (continued)

Test No.	Type of test	Required test parameters	
10	AC voltage dry withstand test	Test voltage $2.5 \times U_0$:	32 kV
		Test frequency:	50 Hz
		Duration of test:	15 min

Notes to the table of required test parameters:

- 1) CENELEC Harmonization Document HD 629.1 S2: 2006-2, Table 7, requires the partial discharge to be measured at a measuring voltage of $1.73 \times U_0$ or $2.00 \times U_0$ respectively. The measurement was done at $2 \times U_0$ because the standard of the cable used for the test requires a test voltage $> 1.73 \times U_0$.
- 2) Acc. to EN 61442: 2005-04, Clause 9, the heating current to be applied in this test depends on the set conductor temperature. HD 620 specifies that this shall be 5 K to 10 K above the maximum permissible cable conductor temperature of 90 °C for XLPE-insulated cables. In the given case this requirement resulted in a heating current, which exceeded the current carrying capacity respectively the rated current of the bushing. The resulting higher thermal load of the bushing was accepted and was agreed with the client before the test was started.

**ВЯРНО С
ОРИГИНАЛА**



4.4 Test arrangement

The client arranged each of the four cable connectors under test (test objects) on a test line. Every two of the test objects were connected by a coupling unit of DJ250-2 type (manufacturer: Cooper). The test objects were mounted on cable lines of approx. 3 m length and of N2XS(F)2Y-1x50 RM/16 mm²-12/20 kV type. To apply the test voltage, each of the test lines had additionally been equipped with one auxiliary sealing end of EPKT 24C1XI type (manufacturer Tyco Electronics Raychem). All test voltages were applied to the core against the cable screen, which was connected to the test earth.

The tests did not start earlier than 24 hours after the installation of the accessories on the cable lines.

4.4.1 DC voltage test (test 1)

Test arrangement to IEC 61442: 2005-04, Clause 5

4.4.2 AC voltage test (test 2)

Test arrangement to IEC 61442: 2005-04, Clause 4

4.4.3 Partial discharge test at ambient temperature (test 3)

Test arrangement to IEC 61442: 2005-4, Clause 7, with the following simplifications:

Due to the short cable lengths, neither double impulse diagram nor terminating impedance or reflexion suppressor were used. The PD calibrator was connected in parallel to the test object only at the detector-remote end.

4.4.4 Impulse voltage test at elevated temperature (test 4)

Test arrangement to IEC 61442: 2005-04, Clause 6


The conductors of the four test objects were connected in series. To obtain the necessary elevated (conductor) temperature, the conductor of the single-core cable was heated with single-phase AC on the basis of the induction principle by leading the conductor loop through a heating transformer. The supply voltage of the heating circuit was automatically controlled. So, the elevated conductor temperature remained constant ± 2 K during the last 2 hours of the 5-hour heating cycle.

4.4.5 Electrical heat cycling test in air (test 5)

Test arrangement to IEC 61442: 2005-04, Clauses 4 and 9

For the test arrangement of the heating circuit see Sub-clause 4.4.4. The ambient temperature was kept to $20 \text{ }^\circ\text{C} \pm 5 \text{ K}$. The thermal cycling was implemented by a test cycle control facility.

**ВАРНО С
ОРИГИНАЛА**



Test arrangement (continued)

4.4.6 Electrical heat cycling test in water (test 6)

In addition to the test arrangement to Sub-clause 4.4.5, the test objects were arranged in a water-filled tank (water bath). The water-level was 1 m above the upper edge of the test objects (see Figure 1).




Figure 1: Test of the connectors in water bath (schematic diagram)

4.4.7 Disconnection/connection (test 7)

None

4.4.8 Partial discharge test at elevated and ambient temperatures (test 8)

See Sub-clause 4.4.3

For the test at elevated temperature see also Sub-clause 4.4.4.

4.4.9 Impulse voltage test at ambient temperature (test 9)

See Sub-clause 4.4.4, but without additional conductor heating

4.4.10 AC voltage test (test 10)

See Sub-clause 4.4.2

ВЯРНО С
ОРИГИНАЛА



4.5 Test and measuring circuits

4.5.1 DC voltage test (test 1)


Technical data of test circuit

DC voltage source

Test transformer:	Rated voltage	100 kV
	Rated power	8 kVA
	Rated frequency	50 Hz
Rectifier:	Rated voltage	135 kV
	Rated current	15 mA
Smoothing capacitor:	Capacitance	10 nF

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	Ohmic divider with MU11 (TuRD) peak voltmeter	Ratio 560



- E Supply
- PTr Test transformer with variable transformer connected in series
- GI Rectifier
- CG Smoothing capacitor
- 1 Measuring point
- PO Test object

Figure 2: Test and measuring circuit for the DC voltage test



**ВАЖНО С
ОРИГИНАЛА**

Test and measuring circuits (continued)

4.5.2 AC voltage test (tests 2 and 10)


Technical data of test circuit

Single-phase AC voltage source

Test transformer:	Rated voltage	125 kV
	Rated power	100 kVA
	Rated frequency	50 Hz
	Damping resistance	0.67 kΩ

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	Capacitive divider with MU11 (TuRD) peak voltmeter	Ratio 864



- E Supply
- PTr Test transformer with variable transformer connected in series
- R_d Damping resistance
- 1 Measuring point
- PO Test object

Figure 3: Test and measuring circuit for the AC voltage test



[Handwritten signature]
**ВАРНО С
 ОРНИМАЛА**

Test and measuring circuits (continued)


4.5.3 Partial discharge test at elevated and ambient temperatures (tests 3 and 8)

Technical data of test circuit

Test transformer:	Rated voltage	125 kV
	Rated power	100 kVA
	Rated frequency	50 Hz
	Damping resistance	0,67 kOhm

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	- Capacitive divider with MU11 peak voltmeter (TuRD)	Ratio 864
2	Partial discharges	- Coupling capacitor of WMCF type (TuRD) - Coupling four pole of COPL542A type - PD measuring station of MPD540 type - USB Interface 502 - PD calibrator of CAL542 type (mtronix)	$C_k = 1 \text{ nF}$ Band width = 300 MHz Center frequency 400 kHz Output 10 pC



- E Supply
- PTr Test transformer with variable transformer connected in series
- Z_s Blocking impedance
- C_k Coupling capacitor
- Z_m Coupling four pole (measuring impedance)
- C-T. Capacitive divider
- HE Auxillary sealing end
- 1, 2 Measuring points
- PO Test object

Figure 4: Test and measuring circuit for the partial discharge test (schematic without heating circuit, for the heating circuit see Figure 6/Sheet 15)



**ВАРИАНТ С
ОРИГИНАЛОМ**

Test and measuring circuits (continued)


4.5.4 Impulse voltage test at elevated and ambient temperatures (tests 4 and 9)

Technical data of test circuit

Impulse circuit:	Number of stages	$n =$	2
	Impulse capacitance	$C_S =$	70 nF
	Loading capacitance	$C_B =$	1.5 nF
	Damping resistance	$R_D =$	122 Ω
	Discharge resistance	$R_E =$	1100 Ω


Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	R divider of SMR 10/770 type (made by TuRD) with digital measuring Instrument of DMI 551 type (made by Haefely) and TDS 220 digital oscilloscope (made by Tektronix)	Ratio 466.9



- GI Rectifier
- C_S Impulse capacitance
- ZFS Spark gap
- R_E Discharge resistance
- R_D Damping resistance
- C_B Loading capacitance
- PO Test object
- 1 Measuring point

Figure 5: Test and measuring circuit for the Impulse voltage test (without heating circuit for this see Figure 6, but connection of Impulse generator instead of single-phase AC voltage source)



**ВАРИАНТ С
ОРИГИНАЛОМ**

Test and measuring circuits (continued)

4.5.5 Electrical heat cycling in air and in water, resp. (tests 5 and 6)

Technical data of test circuit

Single-phase continuous AC voltage source


Test transformer:	Rated voltage	125 kV
	Rated power	100 kVA
	Rated frequency	50 Hz

Heating circuit

Heating transformers:	Rated primary voltage	380 V
	Rated power	57 kVA
	Max. secondary current	1000 A
	Rated frequency	50 Hz

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	Capacitive divider with MU11 peak voltmeter (TURD)	Ratio 864
2	Heating current	LH 2040 prong-type ammeter	2000-A (AC) measuring range
3	Temperature	CoCo thermocouples in connection with Almeno temperature measuring system of 2290-3 type (made by Ahlbom)	--



- Str Variable transformer
- Ht Heating transformer
- 1 - 3 Measuring points
- Pir Test transformer with variable transformer connected in series

Figure 6: Test and measuring circuit for the electrical heat cycling tests in air and in water, resp. (schematic diagram)

4.5.6 Disconnection/connection (test 7)

None




4.6 Test results

4.6.1 DC voltage test (test 1)

Polarity: Negative

Duration of test after having reached full voltage: 15 min

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	
1	Conductor	Screen	-76	No disruptive discharge
2	Conductor	Screen		No disruptive discharge
3	Conductor	Screen		No disruptive discharge
4	Conductor	Screen		No disruptive discharge

Notes:

Two test lines were tested together, they were connected by a coupling unit.

**ВЕРНО С
ОПРЕДЕЛЕНА**




Test results (continued)

4.6.2 AC voltage test (test 2)

Duration of test after having reached full voltage: 5 min
 Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C


Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
1	Conductor	Screen	57	No disruptive discharge
2	Conductor	Screen		No disruptive discharge
3	Conductor	Screen		No disruptive discharge
4	Conductor	Screen		No disruptive discharge



Notes:

Two test lines were tested together, they were connected by a coupling unit.

**ВАЖНО С
ОРИГИНАЛА**




Test results (continued)

4.6.3 Partial discharge test at ambient temperature (test 3)

Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C

Calibration of the test circuit by calibrator output 10 pC

Measured PD values

Test arrangement			Prestress voltage	Measuring voltage	Measured PD value
			(1 min)	(1 min)	
No. of test object	Voltage applied to	Earthed	kV	kV	pC
1	Conductor	Screen	29	25	1 ¹⁾
2	Conductor	Screen			
3	Conductor	Screen			
4	Conductor	Screen			

Notes:

Two test lines were tested together, they were connected by a coupling unit

¹⁾ Basic disturbance level at same value



Test results (continued)

4.6.4 Impulse voltage test at elevated temperature (test 4)

Full wave: Front time $T_1 = 2.92 \mu s$
 Virtual time to half value $T_2 = 50.4 \mu s$

Test temperature: Ambient temperature $18 \text{ }^\circ\text{C}$
 Conductor temperature $95.100 \text{ }^\circ\text{C}$

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	Number of Impulses/dlsruptive dlscharges
1	Conductor	Screen	+125 ¹⁾ -125 ¹⁾	10/0 ¹⁾ 10/0 ¹⁾
2	Conductor	Screen		
3	Conductor	Screen		
4	Conductor	Screen		

Notes:

¹⁾ All four test lines were connected to form one closed conductor loop for heating the latter. Therefore, all test lines were simultaneously tested. Providing separate test results for each of the test lines is not possible.



**ВЯРНО С
ОРИГИНАЛА**

Test results (continued)

4.6.5 Electrical heat cycling test in air (test 5)

Duration of test: 21 days
 Test frequency: 50 Hz
 Test temperature: Ambient temperature 25 °C
 Conductor temperature 95..100 °C
 Number of load cycles: 63

Test arrangement			Continuous AC withstand voltage	Heating current	Result
No. of test object	Voltage applied to	Earthed			
1	Conductor	Screen	32 ¹⁾	341 ^{1),2)}	No disruptive discharge
2	Conductor	Screen			No disruptive discharge
3	Conductor	Screen			No disruptive discharge
4	Conductor	Screen			No disruptive discharge

Notes:

- ¹⁾ All four test lines were connected to form one closed conductor loop for heating the latter. Therefore, all test lines were simultaneously tested. Providing separate test results for each of the test lines is not possible.
- ²⁾ The heating current was regulated in such a way that a constant conductor temperature was obtained after approx. 3 hours of heating. This was kept constant ± 2 K for the remaining 2 hours of the 5-hour heating period.



**ВЫРОБ С
ОРИГИНАЛ**

Test results (continued)

4.6.6 Electrical heat cycling test in water (test 6)

Duration of test: 21 days
 Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Water temperature 21 °C
 Conductor temperature 95..100 °C
 Number of load cycles: 63

Test arrangement			Continuous AC withstand voltage	Heating current	Result
No. of test object	Voltage applied to	Earthed			
1	Conductor	Screen			No disruptive discharge
2	Conductor	Screen	32 ¹⁾	350 ^{1), 2)}	No disruptive discharge
3	Conductor	Screen			No disruptive discharge
4	Conductor	Screen			No disruptive discharge

Notes:

- ¹⁾ All four test lines were connected to form one closed conductor loop for heating the latter. Therefore, all test lines were simultaneously tested. Providing separate test results for each of the test lines is not possible.
- ²⁾ The heating current was regulated in such a way that a constant conductor temperature was obtained after approx. 3 hours of heating. This was kept constant ± 2 K for the remaining hours of the 5-hour heating period.

4.6.7 Disconnection/connection (test 7)

Each of the four test objects was disconnected and connected altogether five times as specified by the manufacturer's assembly instructions. No visible damage was found on the contact

**ВАЖНО С
ОРИГИНАЛ**




Test results (continued)

4.6.8 Partial discharge test at elevated and ambient temperatures (test 8)

Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C and elevated, resp. 95..100 °C
 Calibration of the test circuit by callibrator output 10 pC

Measured PD values

Test arrangement			Prestress voltage (1 min)	Measuring voltage (1 min)	Measured PD value
					
No. of test object	Voltage applied to	Earthed	kV	kV	pC
Measured PD values at elevated temperature					
1	Conductor	Screen	29	25	< 3 ¹⁾
2	Conductor	Screen			
3	Conductor	Screen			
4	Conductor	Screen			
Measured PD values at ambient temperature					
1	Conductor	Screen	29	25	< 1,0 ^{1), 2)}
2	Conductor	Screen			
3	Conductor	Screen			
4	Conductor	Screen			

Notes:

- ¹⁾ Two of the respective test lines were connected to form one closed conductor loop for heating the latter. Thus, two test lines were simultaneously tested. Providing separate test results for each of the test lines is not possible.
- ²⁾ Basic disturbance level at same value
- ³⁾ The test lines were separated for the PD measurement.

**ВЫПОЛНЕНО
ОРИГИНАЛ**




Test results (continued)

4.6.9 Impulse voltage test at ambient temperature (test 9)

Full wave: Front time $T_1 = 1.25 \mu s$
 Virtual time to half value $T_2 = 55.0 \mu s$


Test temperature: Ambient temperature $20^\circ C$
 Conductor temperature $20^\circ C$

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	Number of Impulses/disruptive discharges
1	Conductor	Screen		
2	Conductor	Screen	+125	10/0
3	Conductor	Screen	-125	10/0
4	Conductor	Screen		

Notes:

All test lines were tested simultaneously.


**ВРФО С
ОПШННА**



Test results (continued)

4.6.10 AC voltage test (test 10)

Duration of test after having reached full voltage: 15 min
 Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	
1	Conductor	Screen	32	No disruptive discharge
2	Conductor	Screen		
3	Conductor	Screen		
4	Conductor	Screen		

Notes:

All test lines were tested simultaneously.



**ВАРНО С
ОРИГИНАЛ**

4.7 Assessment of the results of test sequence D1

- Test 1

In the DC voltage test at -76 kV/15 min, no disruptive discharge occurred on any of the four test objects.

- Test 2

In the 50-Hz AC voltage test at 57 kV/5 min, no disruptive discharge occurred on any of the four test objects.

- Test 3

In the partial discharge test at ambient temperature and at 50-Hz AC voltage of 25 kV, none of the four test objects exceeded the permissible maximum partial discharge value of 10 pC. The partial discharge value measured was not higher than 1.0 pC.

- Test 4

In the impulse voltage test at elevated temperature with 10 test impulses of 125-kV lightning impulse voltage 1.2/50 of each polarity, no disruptive discharge occurred on any of the four test objects.

- Test 5

All of the four test objects were subjected to 63 electrical heat cycles in air. In the simultaneous 50-Hz continuous AC voltage test at 32 kV, no disruptive discharge occurred on any of the four test objects.

- Test 6

All of the four test objects were subjected to 63 electrical heat cycles in water. No disruptive discharge occurred on any of the four test objects, when they were tested simultaneously in water and by 50-Hz continuous AC voltage of 32 kV.

- Test 7

After 5 complete operations of disconnection and connection, no visible damage was found on the contact.

- Test 8

In the partial discharge test at elevated and ambient temperatures at 50-Hz AC voltage of 25 kV, none of the four test objects exceeded the permissible maximum partial discharge value of 10 pC. The partial discharge value measured was not higher than 3 pC.



**ВЯРНО С
ОРИГИНАЛА**

Assessment of the results of test sequence D1 (continued)

• Test 9

In the impulse voltage test at ambient temperature with 10 test impulses of 125-kV lightning impulse voltage 1.2/50 of each polarity, no disruptive discharge occurred on any of the four test objects.

• Test 10

In the 50-Hz AC voltage test at 32 kV/15 min, no disruptive discharge occurred on any of the four test objects.

All of the four test objects meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2 2006-2.

The tests of test sequence D1 have been PASSED.



**ВАРНО С
ОРМОНАТА**

5. Tests of test sequence D2

5.1 Test laboratory

High-voltage test laboratory, high-voltage hall 2 and
High-power test laboratory, high-current bay

5.2 Normative document

CENELEC Harmonization Document HD 629.1 S2; 2006-02
DIN VDE 0278-629.1 (VDE 0278 Teil 629-1); 2002-06
IEC 61442; 2005-04
DIN VDE 0278-442 (VDE 0278 Teil 442); 2006-01

5.3 Required test parameters

Test No.	Type of test	Required test parameters	
1	DC voltage test	Test voltage $6 \times U_0$: Duration of test: Polarity:	76 kV 15 min Negative
2	AC voltage test	Test voltage $4.5 \times U_0$: Test frequency: Duration of test:	57 kV 50 Hz 5 min
3	Thermal short-circuit test of the conductor	Short-circuit-conductor final temperature: Number of short-circuits:	250 °C 2
5	Disconnection/connection	Number of complete operations:	5
6	Impulse voltage test at ambient temperature	Front time: Virtual time to half value: Test voltage: Number of impulses: Polarity: Conductor temperature:	1.2 μ s 50 μ s 125 kV 10 impulses pos./neg. θ_u
7	AC voltage test	Test voltage $2.5 \times U_0$: Test frequency: Duration of test:	32 kV 50 Hz 15 min



**ВАРЮ С
ОРИГИНАЛА**

5.4 Test arrangement

Each of the three connectors under test was arranged on a test line by the client. The connectors were completed by bushings or terminations. The test objects were mounted on cable lines of approx. 3-m length and of N2XS(F)2Y-1x50 RM/16 mm²-12/20 kV type. To apply the test voltage, each of the test lines had additionally been equipped with one auxiliary sealing end of EPKT type (made by Tyco Electronics Raychem).

All test voltages were applied to the core against the cable screen, which was connected to the test earth. The tests did not start earlier than 24 hours after the installation of the accessories on the cable lines.

5.4.1 DC voltage test (test 1)

Test arrangement to IEC 61442: 2005-04, Clause 5

5.4.2 AC voltage test (test 2)

Test arrangement to IEC 61442: 2005-04, Clause 4

5.4.3 Thermal short-circuit test of the conductor (test 3)

Test arrangement to IEC 61442: 2005-04, Clause 11

The three test objects were arranged on an assembly plate on equal level with phase centres distances of 110 mm. Additionally the cables were fixed by cable clamps at a distance of 350 mm measured from the bushing end. For the test, a short-circuit bridge of 30 mm x 10 mm was connected at the three bushings, and the auxiliary sealing end sides of the three test lines were connected three-pole to the short-circuit current source.

5.4.4 Disconnection/connection (test 5)

None

5.4.5 Impulse voltage test at ambient temperature (test 6)

Test arrangement to IEC 61442: 2005-04, Clause 6

5.4.6 AC voltage test (test 7)

See Sub-clause 5.4.2



ВЫПОЛНЕНО
ОПЫТНИКАМ

5.5 Test and measuring circuits

5.5.1 DC voltage test (test 1)

See Sub-clause 4.5.1

5.5.2 AC voltage test (test 2)

See Sub-clause 4.5.2

5.5.3 Thermal short-circuit test of the conductor (test 3)

See following sheet

5.5.4 Disconnection/connection (test 5)

None

5.5.5 Impulse voltage test at ambient temperature (test 6)

See Sub-clause 4.5.4

5.5.6 AC voltage test (test 7)

See Sub-clause 4.5.2




ВЕРНО
ОПРАВДАНО

Test and measuring circuits (continued)

Thermal short-circuit test (test 3)

Technical data of test circuits

Test requirement	Short-circuit tests	
Test No.	207 4195 and 207 4196	
Number of phases (Test circuit)	3	
Number of poles/phases (Test object)	3	
Power frequency Hz	50	
Power factor $\cos \varphi$	0.015	
Earthing conditions	Generator / grid	Not earthed
	Short-circuit transformer	Earthed
	Short-circuit point	Not earthed




- | | | | |
|----|---------------------------|-------|---------------------|
| E | Power supply (grid) | TO | Test object |
| SI | Master breaker | I | Current measurement |
| Dr | Making switch | U | Voltage measurement |
| L | Current-limiting reactor | 1 - 3 | Measuring points |
| Tr | Short-circuit transformer | | |

Figure 7: Test and measuring circuit for the thermal short-circuit test of the conductor

Technical data of measuring circuits

Measuring point	Symbol	Measured quantity	Measuring sensor/device
1	I L1	Current of conductor L1	Rogowski measuring device
2	I L2	Current of conductor L2	Rogowski measuring device
3	I L3	Current of conductor L3	Rogowski measuring device

Recording Instrument: BE 256 transient recorder system



BRUNNEN
ONLINE

5.6 Test results

5.6.1 DC voltage test (test 1)

Polarity: Negative

Duration of test after having reached full voltage: 15 min

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
			kV	
5	Conductor	Screen	-76	No disruptive discharge
6	Conductor	Screen	-76	No disruptive discharge
7	Conductor	Screen	-76	No disruptive discharge


Notes: -



Test results (continued)

5.6.2 AC voltage test (test 2)

Duration of test after having reached full voltage: 5 min
 Test frequency: 50 Hz
 Test temperature: Ambient temperature 20 °C
 Conductor temperature 20 °C

Test arrangement			Test voltage	Result
No. of test object	Voltage applied to	Earthed		
				
			kV	
5	Conductor	Screen	57	No disruptive discharge
6	Conductor	Screen	57	No disruptive discharge
7	Conductor	Screen	57	No disruptive discharge

Notes: -

**ВЫПОЛНЕНО
ОПТИМАЛЬНО**



Test results (continued)

5.6.3 Thermal short-circuit test of the conductor (test 3)

Condition of test object before test:	Prestressed by previous tests
Connection of the test object:	By 50-mm ² cable
Short-circuit point:	At the bushings
Ambient temperature:	16 °C

Test parameters:

Test No.		207 4195	207 4196
Test voltage	V	455	455
Peak short-circuit current	kA	L1	16.7
		L2	12.1
		L3	15.9
Symmetrical short-circuit current	kA	L1	9.52
		L2	9.40
		L3	9.56
	Average	9.49	9.50
Duration of short-circuit	ms	909	916
Joule Integral 10 ⁶	A ² s	L1	82.9
		L2	81.7
		L3	83.5
Symmetrical short-circuit current 1 s	kA	9.05	9.09
Notes		-	-
Evaluation		OK	OK

Notes:

OK: The test object is able to carry the short-circuit current.

Condition of test object after test:

The test objects did not show any externally visible changes or damage.



**ВЕРНО С
ОРИГИНАЛА**

Test results (continued)


5.6.4 Disconnection/connection (test 5)

Each of the three test objects was disconnected and connected altogether five times as specified by the manufacturer's assembly Instructions. No visible damage was found on the contact.

5.6.5 Impulse voltage test at ambient temperature (test 6)

Full wave: Front time $T_1 = 1.46 \mu s$
 Virtual time to half value $T_2 = 53 \mu s$

Test temperature: Ambient temperature $20 \text{ }^\circ\text{C}$
 Conductor temperature $20 \text{ }^\circ\text{C}$

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	Numbers of impulses/disruptive discharges
5	Conductor	Screen		
6	Conductor	Screen	+125 -125	10/0 10/0
7	Conductor	Screen		

Notes:

All test lines were tested simultaneously.



**ВРНО С
ОРИГИНАЛ**

TYPE TEST REPORT NO. 1213.1607.6939

SHEET 35


Test results (continued)

5.6.6 AC voltage test (test 7)

Duration of test after having reached full voltage: 15 min

Test frequency: 50 Hz

Test temperature: Ambient temperature 20 °C
Conductor temperature 20 °C

Test arrangement			Test voltage	Result
				
No. of test object	Voltage applied to	Earthed	kV	
5	Conductor	Screen	32	No disruptive discharge
6	Conductor	Screen		
7	Conductor	Screen		

Notes:

All test lines were tested simultaneously.

**ВЕРНО С
ОРИГИНАЛОМ**



5.7 Assessment of the tests of test sequence D2

• Test 1

In the DC voltage test at -76 kV/15 min, no disruptive discharge occurred on any of the three test objects.

• Test 2

In the 50-Hz AC voltage test at 57 kV/5 min, no disruptive discharge occurred on any of the three test objects.

• Test 3

In the thermal short-circuit test of the conductor with a thermally equivalent current of 9.1 kA/1 s, no visible damage was detected on any of the three test objects.

• Test 5

After 5 complete operations of disconnection and connection, no visible damage was found on the contact.

• Test 6

In the Impulse voltage test at ambient temperature with 10 test Impulses of 125-kV lightning Impulse voltage 1.2/50 of each polarity, no disruptive discharge occurred on any of the three test objects.

• Test 7

In the 50-Hz AC voltage test at 32 kV/15 min, no disruptive discharge occurred on any of the three test objects.

All of the three test objects meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2 2006-2.

The tests of the test sequence D2 have been PASSED.

**ВЫПОЛНЕНО
ОПРЕДЕЛЕНИЕ**



6. Special tests (tests Nos. 17 to 21)

6.1 Test laboratory

Low-voltage test laboratory, test room 7 (test No. 17)
 High-voltage test laboratory, high-voltage hall 2 (tests Nos. 18, 20 and 21)
 High-power test laboratory, test bay 3 (test No. 19)

6.2 Normative documents

CENELEC Harmonization Document HD 629.1 S2: 2006-02
 DIN VDE 0278-629.1 (VDE 0278 Teil 629-1): 2002-06
 IEC 61442: 2005-04
 DIN VDE 0278-442 (VDE 0278 Teil 442): 2006-01

6.3 Required test parameters

Test No.	Type of test	Required test parameters
17	Screen resistance measurement	Temperature during exposure to heat: (120±2) °C Duration of thermal ageing: 168 h
18	Leakage current measurement	Test voltage U_m : 24 kV
19	Screen fault current initiation test	<ul style="list-style-type: none"> • Solidly earthed system Test voltage: 12.7 kV¹⁾ Test current: 10 kA Duration of current flow: 0.2 s Number of tests: 2 • Unearthed or Impedance-earthed system Test voltage: 12.7 kV¹⁾ Test current: Minimum 10 A Test procedure: Start C-1 s O-2 min C-2 min O-2 min C 1 min O end
20	Operating force test	$F \geq 900$ N
21	Capacitive test point performance	-

Note:

1) Test parameter complies with normative document. If lower values are applied the test will become more severe.

ВАРНО С
ОРИГИНАЛА



6.4 Test arrangement

6.4.1 Screen resistance measurement (test No. 17)

Test arrangement to IEC 61442: 2005-04, Clause 15

Only one single connector body was used for the measurement. For the definite and reproducible measurement of the resistance on the screen two rings made of bare copper wire and of approx. 1-mm width were fixed to the screen. They served as fixed electrodes for the resistance measurement.

6.4.2 Leakage current measurement (test No. 18)

Test arrangement to IEC 61442: 2005-04, Clause 16

The client installed one test object on a short length of cable, which was equipped with an auxiliary sealing end on its other end, and completed it with a bushing. Subsequently, a square metal foil of 25 cm² was fitted to the outer conductive layer of the test object in the region of the bushing. When the AC test voltage was applied to the test object, the leakage current from metal foil to earth was measured.

6.4.3 Screen fault current initiation test (test No. 19)

Test arrangement to IEC 61442: 2005-04, Clause 17

A bushing was centrally arranged in a metal plate of 600 x 600 x 5, which was vertically fixed to a test rack. Each of the test objects, installed on a short length of cable by the client, was fixed to the bushing and the screen was earthed in accordance with the manufacturer's instructions. The other end of each length of cable was equipped with an auxiliary sealing end. For the test with solidly earthed system, a threaded rod of 10 mm Ø was arranged in the region of the transition from the conductor to the cable lug in the body of the connector under test so that a connection was established from the cable lug through a drilled hole to the inner and outer conducting layers of the connector body. For the test with unearthed or impedance earthed systems, a drilled hole was used instead of the rod. It had a copper wire of 0.2 mm Ø for bridging the insulation between the inner and outer screens and for initiating the arc. In both cases, neither the rod nor the wire protruded beyond the outer conducting layer of the connector body.

6.4.4 Operating force test of the cable connector (test No. 20)

Test arrangement to IEC 61442: 2005-04, Clause 18

One connector was assembled according to the client's instructions and was mounted on a bushing using a gliding agent provided by the client.

6.4.5 Capacitive test point performance (test No. 21)

Test arrangement to IEC 61442: 2005-04, Clause 20

One connector was installed on a short length of cable by the client and the screen was earthed in accordance with the manufacturer's instructions. The test object was equipped with a mating bushing.




**ВЯРНО С
ОРИГИНАЛА**

6.5 Test and measuring circuits

6.5.1 Screen resistance measurement (test No. 17)

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Resistance	Digital hand multimeter of 137 type (KEITHLEY)	Measuring range R - 2 kΩ



1 Measuring point
PO Test object

Figure 8: Measuring circuit for resistance measurement on the screen



Test and measuring circuits (continued)

6.5.2 Leakage current measurement (test No. 18)


Technical data of test circuit

Single-phase AC voltage source

Test transformer: Rated voltage 125 kV
 Rated power 100 kVA
 Rated frequency 50 Hz
 Damping resistance 0.67 kΩ

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Test voltage	Capacitive divider with MU11 (TuRD) peak voltmeter	Ratio 864
2	Test current	Digital hand multimeter of 137 type (KEITHLEY)	MB 0.2 mA AC



- E Supply
- PTr Test transformer with variable transformer connected in series
- R_d Damping resistance
- R Resistance
- 1, 2 Measuring points
- PO Test object

Figure 9: Test and measuring circuit for the leakage current measurement




Test and measuring circuits (continued)

6.5.3 Screen fault current Initiation test (test No. 19)

Technical data of test circuit

Test requirement	Screen fault current test	
Test No.	107 4009, 107 6200 and 107 6201	
Number of phases (Test circuit)	2	
Number of poles/phases (Test object)	1	
Power frequency Hz	50	
Power factor $\cos \varphi$	< 0.15	
Connection of short-circuit transformers	I/I	
Short-circuit power	120 MVA	
Earthing conditions	Grid	Not earthed
	Short-circuit transformer	Earthed



- E Power supply (grid)
- Sl Master breaker
- Dr Making switch
- L1, L2 Current limiting reactors
- Tr Short-circuit transformer
- 1, 2 Measuring points
- I Current measurement
- U Voltage measurement
- TO Test object

Figure 10: Test and measuring circuit for the screen fault current Initiation test

Technical data of measuring circuits

Test No.	Measuring point	Symbol	Measured quantity	Measuring sensor/device
107 4009, 107 6200 and 107 6201	1	I	Short-circuit current	Current transformer
	2	U	Test voltage	RC divider

Recording Instrument
BE 256 transient recorder




6.5.4 Capacitive test point performance (test No. 21)

Capacitance measurement by differential bridge

The capacitance C_x to be measured was connected to a capacitance measuring bridge together with the well-known capacitance C_n .

Technical data of measuring circuit

Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	Capacitance	C-tan δ measuring bridge of VFM type (made by MWB)	Measuring range x 100 pF
2	Test voltage	Capacitive divider with MU11 (made by TuRD) peak voltmeter	



- G Sine-wave generator
- C_x Capacitance to be determined
- L, S Cable conductor or cable screen
- KP Capacitive test point
- C_n Comparison capacitance
- 1, 2 Measuring points

Figure 11: Test and measuring circuit for determining the capacitive test point performance



6.6 Test results

6.6.1 Screen resistance measurement (test No. 17)

Test temperature: Ambient temperature 20 °C
 Temperature during exposure to heat: 120 °C
 Time of exposure to heat: 168 h

Test arrangement		Resistance Ω	Result
No. of test object	Condition of test object		
8	Before exposure to heat	164	OK
8	After exposure to heat	280	OK

OK: The resistance measured before and after the exposure to heat was significantly below the maximum permissible value of 5000 Ω .

6.6.2 Leakage current measurement (test No. 18)

Test temperature: Ambient temperature 20 °C

Test arrangement			Test voltage kV	Leakage current μ A	Result
No. of test object	Voltage applied to	Earthed			
9	Conductor	Screen	24	< 5	OK

OK: The leakage current was below the maximum permissible value of 0.5 mA.

OK
 ВЕРНО
 ОПРЕДЕЛЕНА



Test results (continued)

6.6.3 Screen fault current Initiation test (test No. 19)

Test requirement: Screen fault current test for Impedance-earthed systems

Type of test object: RSSS-5225-R 250 A

Ambient temperature: 19 °C

Test No.	107 ...	4007	4009		
Test object	No.	-	10		
Cycle		-	C _{1s} - O _{2min} - C _{2min} - O _{2min} - C _{1min} - O		
Test voltage	kV	12.8	12.8	12.8	12.8
Test current	A	15.5	15.5	15.5	15.5
Time of test	s	0.2	1	120	60
Notes		1)	2)	2)	2)
Evaluation		-	OK	OK	OK

Notes:

- 1) Current setting
 - 2) The test object is capable of properly carrying the fault current.
- OK: During the making cycle the arc was ignited or re-ignited, respectively.
 During the making time, the current flow was present.
 A fault in the insulation is reliably detectable.

Test requirement: Screen fault current test for solidly earthed systems

Type of test object: RSSS-5225-R 250 A

Ambient temperature: 19 °C

Test No.	107	6199	6200	6201
Test object	No.	-	9	9
Test voltage	kV	12.8	12.8	12.8
Peak current	kA	29.5	27.5	24.5
Test current	kA	11.0	11.0	11.0
Time of test	s	210	200	200
Notes		1)	2)	2)
Evaluation		-	OK	OK

Notes:

- 1) Current setting
 - 2) The test object is capable of properly carrying the fault current.
- OK: For the case of a disruptive discharge the screen of the connector is able to carry a current which is sufficient to trip the protection device.

BRAND C
OPTIMANIA



Test results (continued)

6.6.4 Operating force test (test No. 20)


Cold conditioning for 12 h at $-20\text{ }^{\circ}\text{C}$, withdrawal force = 414 N

6.6.5 Capacitive test point performance (test No. 21)

Test temperature:

Ambient temperature

23 $^{\circ}\text{C}$

Test arrangement			Capacitance of test point KP		Notes
					
No. of test object	Voltage applied to	Earthed	Towards cable screen C_{te}	Towards cable conductor C_{tc}	
			pF	pF	
12	L (conductor)	Screen connection of the connector body	-	10.3	OK
12	S (screen)	Conductor	13.5	-	OK

Notes:

OK: The ratio of C_{te} to C_{tc} was $13.5\text{ pF}:10.3\text{ pF} \approx 1.31$, and thus ≤ 12 as specified by the normative document



ВАНО С
ОПШНАТА

6.7 Assessment of special tests

• Test 17

The resistance measured before and after the exposure to heat at 120 °C/168 h was 280 and 164 Ω, resp. This was significantly below the maximum permissible value of 5000 Ω.

• Test 18

The leakage current measured at an applied AC test voltage of 24 kV fell below the maximum permissible value of 0,5 mA with a measured value of 5 μA.

• Test 19

- Solidly earthed systems

For the case of a disruptive discharge the screen of the connector is able to carry a fault current which is sufficient to trip the protection device. The fault was reliably initiated within 3 s. The screen is able to discharge an arc to earth. The current is sufficient to operate the circuit protection.

- Unearthed or Impedance-earthed systems

During the making cycle the arc was ignited or re-ignited, respectively. During the making time, the current flow was present. A fault in the insulation is reliably detectable. During the making cycle, the arc was ignited resp. re-ignited at 12.1 kV. During the making time, the current flow was present at 12.1 kV. A fault in the insulation is reliably detectable.

• Test 20

The withdrawal force was determined to be 414 N. Thus it is below the maximum permissible value of 900 N.

• Test 21

The ratio of C_{10} to C_{12} was determined to be 1.31, which is ≤ 12 as specified by the normative document.

The test objects meet the requirements specified by CENELEC Harmonization Document HD 629.1 S2: 2006-2.

The special tests Nos. 17 to 21 have been PASSED.



7. Photos




Figure 12: View of one test object





Figure 13: Arrangement for the electrical heat cycling test In air for test sequence D1



ВАРМБ
ОПШНАТА




Figure 14: View of the test objects for the test sequence D2 (mounted on bushings)




Figure 15: Test object No. 9 after the screen fault current Initiation test (solidly earthed system)

ВЯРНОС
ОПРЕДЕЛЕНА









Figure 16: Test object No. 10 after the screen fault current Initlation test (unearthed or Impedance-earthed systems)

ВАРИАНТ
ОРИГИНАЛ





8. Oszillogramme

Test-No. 1074009



ВАРИАНТ
ОРИГИНАЛ







София, бул. Самоков 1, тел. +359 884 00 55 78, +359 884 00 55 79,

<http://www.ngtechnology.org/>, office@ngtechnology.org

Предназначение:

Комплектният бетонов трансформаторен пост CTRS е предназначен за захранване на битови и промишлени потребители от кабелни линии до 20 kV. Трансформаторната подстанция представлява самостоятелна постройка с възможност за външно обслужване.

Трансформаторната подстанция CTRS е напълно завършен в фабрични условия продукт включващ трансформатор, разпределителна уредба средно напрежение до 20 кУ, уредба ниско напрежение до 0,4 kV и всички необходими допълнителни устройства в съответствие с нормативните документи и изискванията на конкретния проект.

I. Изисквания за експлоатация:

Трансформаторната подстанция CTRS е предназначена за обслужване от правоспособен персонал на ЧЕЗ – България АД, притежаващ съответните квалификационни групи.

- Условия по експлоатация - за монтаж на открито.
- Температура на околната среда - от - 25°C до +40°C.
- Надморска височина - над 1000 м.
- Максимална влажност на въздуха - 96% при 20°C.
- Замърсяване - околната среда без токопроводими прахове, активни газове и пари.
- Околна среда - взривобезопасна и пожаробезопасна околна среда.
- Обвивка - моно блок от водоуплътен бетон с топло изолирани врати за достъп към разпределителни уредби средно и ниско напрежение и две срещуположни врати на отделението за трансформатора с вентилационни решетки със специален профил осигуряващи охлаждане на трансформатора. Клас на обвивката съгласно БДС 133010.
- Защита от насекоми гризачи и птици - осигурява се посредством специални мрежи поставени зад вентилационните решетки на вратите.
- Заземление - всички метални части на комплектния трансформаторен пост са заземени посредством общ вътрешен заземителен контур, който се свързва с външния заземителен контур чрез болтове разположени от двете страни на БКТП.
- Осветление - трансформаторния пост има осветителни тела и ключове за тяхното управление във всяко



М. П. **ИНЖЕНЕР**
С. ДИМИТРОВ

помещение. Същите се захранват преди главния прекъсвач на уредба НН и са защитени с предпазител със стопяема вложка и с нужната комутационна възможност.

- Защита от конденз - конструкцията на обвивката, покрива, вратите и системата за вентилация на трансформаторния пост осигурява сигурна защита на стените и тавана от конденз.
- Безопасна работа - предвидени са всички мероприятия съгласно изискванията БДС 60439-1-2002 и Наредба № 3 от 9 юни 2004 г. за устройството на електрическите уредби и електропроводните линии.
- Трансформаторния пост CTRS се съпровожда от инструкция за експлоатация на български език независимо от фирмата производител на разпределителната уредба /КРУ/, която е вложена в него.

II. Монтаж


Трансформаторния пост CTRS не изисква фундамент за монтаж. Същият се монтира в изкоп с размери, с дълбочина мах-80см. На дъното предварително е подготвена трамбована пясъчна възглавница. При необходимост се извършва нивелация на трафопоста.

Присъединяват се изходните шини на предварително подготвения заземителен контур /К_{заземление} < 4/ към заземителните болтове, намиращи се на страничните стени на БКТП. По този начин се осъществява връзка между вътрешно изпълнения заземителен контур и външния и всички съоръжения на комплектния трансформаторен пост, както и всички метални части се заземяват.

- Отвори за кабели - в основата на обвивката, която представлява бетонов моно блок са предвидени до 5 броя отвори от към страна на уредба средно напрежение. При преминаване на захранващите кабели през тях е необходимо да се използва съответната кабелна арматура осигуряваща целостта на кабелната изолация. Всеки трансформаторен пост се окомплектована с необходимата кабелна арматура в зависимост от изискванията на конкретния проект.

III. Данни за конструкцията:

- Степен на защита - IP-33D
- Издръжливост на удар - 20 J
- Издръжливост на покрива - 3300 K/t²
- Клас на обвивката - 10
- Устойчивост на огън - В
- Устойчивост на огън на стените и тавана - 120 мин
- Минимално разстояние от други сгради (зависи от типа на съседните постройки) - от 10 до 12 м.





София, бул. Самоков 1, тел. +359 884 00 55 78, +359 884 00 55 79,

<http://www.ngtechnology.org/>, office@ngtechnology.org

IV. Основни технически данни:

Стандарти :

БДС EN 62271-202:2007

БДС 60439-1-2002


Наредба № 3 от 9 юни 2004 г. за устройството на електрическите уредби и електропроводните линии

Наредба №2 "Противопожарни строителни норми"

Наредба №3 "Минимални изисквания за осигуряване на здравословни и безопасни условия на труд"

1. Напрежение на страна високо напрежение - 20 kV
2. Максимално работно напрежение на страна високо напрежение - 24 kV
3. Работно напрежение (U_e) на страна ниско напрежение - 0,4 kV
4. Номинална честота - 50 Hz
5. Брой фази - 3
6. Ниво на изолацията на страна високо напрежение - 50 kV
7. Напрежение на изолацията (U) на страна ниско напрежение - 690 V
8. Издържано импулсно напрежение ($U_{1,2/50ms}$) на страна високо напрежение- 125 kV
9. Издържано импулсно напрежение (U_{imp}) на страна ниско напрежение - 6 kV
10. Номинален ток на мрежов мощностен Разединител (I_n) – 630 A
11. Номинален ток на входа на ККУ за разпределение и управление на страна Н.Н. (I_n) – 1250 A
12. Краткотрайно издържан ток (ток на термична устойчивост) на страна В.Н.- 16 kA/1§
13. Ток на динамична устойчивост на страна високо напрежение -50 kA
14. Максимална мощност на БКТП - 800 kVA
15. Мощност на трансформатора - 800 kVA
16. Краткотрайно издържан ток (ток на термична устойчивост) (I_{cm}) на страна Н.Н.- 17 kA/1§
17. Ток на динамична устойчивост (I_{pk}) на страна ниско напрежение : 50 kA
18. Клас на обвивка на БКТП: IP 33D

V. Характеристики на част средно напрежение:



В трансформаторния пост CTRS е предвидена възможност за монтаж на комплектни разпределителни устройства /КРУ/ с комбинация от 1 до 4 интегрирани функционални блока FlouFix на фирма EFACES. Същите притежават следните основни характеристики:

- FlouFix е гама от фабрично сглобени, тествани и свободно стоящи шкафове с вградени в тях тоководещи части /шини/, комутационна защита и измервателна апаратура. Електрическите и механични работни механизми са разположени зад челна плоча, с визуално указване на мнемосхема на положението на комутационната апаратура (затворено, отворено и заземено).

- FlouFix са самостоятелни изцяло изолирани блокове. Състоят се от :

- Хермитизиран метален корпус от неръждаема (без необходимост от поддръжка) стомана, където са групирани заедно частите под напрежение, мощностен разединител, зеземител, комбинация предпазител-мощностен разединител или прекъсвач.

- Отделение за ниско напрежение.

- Отделение за задвижващия механизъм.

- Отделение за предпазители за функциите мощностен разединител-предпазители.

- Корпусът на уредбите FlouFix е напълнен с SF6 с манометрично налягане 0.5 bar. Херметичността му, която се проверява систематично в заводски условия, осигурява на комутационната апаратура очаквано време на живот от 30 години

- Работните характеристики, получени за уредбите FlouFix, съответствуват на определението за "херметично затворена система под налягане" в съответствие с препоръките на IEC. Мощностния разединител и заземителят осигуряват на оператора всички необходими гаранции при работа.

- Уредбите FlouFix са предназначени за работа на закрито.

- В уредбите FlouFix са предвидени всички блокировки непозволяващи погрешни комутации.

- Уредбите FlouFix са с подвижни контакти с три стабилни положения (отворено, затворено и заземено) с вертикален ход. Конструкцията му прави едновременно затваряне на разединителя или на прекъсвача и заземителя *невъзможно*. Заземителят притежава включвателна способност за къси съединения, според изискванията на стандартите.

- Уредбите FlouFix притежават както изолираща, така и прекъсваща функция.

- Достъпът до кабелното отделение може да се блокира със заземителя и/или мощностния разединител или прекъсвача.

- Заземяване - специален работен лост затваря и отваря заземителните контакти. Отворът, позволяващ достъп до лоста се блокира от капак, който може да се отвори когато същностния разединител или прекъсвачът е отворен и остава блокиран, когато същия е затворен.

- Индикатори на положението на комутационната апаратура - поставени са директно върху работните валове на устройството с подвижни контакти. Дават определено показание на положението на комутационното устройство.

- Задействащ лост - същият е конструиран с анти-рефлексно устройство, предотвратяващо всякакъв опит за непосредствено повторно отваряне на мощностния разединител





София, бул. Самоков 1, тел. +359 884 00 55 78, +359 884 00 55 79,

<http://www.ngtechnology.org/>, office@ngtechnology.org

или на зеземителя след затварянето.

- Заклучващи устройства - могат да се използват от 1 до 3 ключалки за предотвратяване на :

- Достъп до работния лост на мощностния разединител или на прекъсвача.
- Достъп до работния лост на зеземителя.
- Задействуване на изключващия бутон с натискане.

- Здравата, устойчива, надеждна и нечувствителна към въздействията на околната среда конструкция на FlouFix води до много малка вероятност за повреда във вътрешността на комплексното комутационно устройство. Независимо от това, за да се гарантира максимална безопасност на персонала, устройствата FlouFix са конструирани да издържат, без опасност на оператора, вътрешна дъга предизвикана от номиналния ток на късо съединение за 1 секунда. Случайното свърхналягане в резултат на вътрешната дъга се ограничава от отварянето на предпазния клапан на дъното на металния кожух. Газът се отвежда до задната част на FlouFix без да засегне условията в предната част. Устройствата отговарят на шестте критерия, посочени в Приложение АА на БДС 60439-1-2002 след проведено изпитание за 20кУ стандартно изпитване.

- Дъгогасенето се осъществява на принципа на автопродухване в среда от 8Р6 газ.





София, бул. Самоков 1, тел. +359 884 00 55 78, +359 884 00 55 79,

<http://www.ngtechnology.org/>, office@ngtechnology.org

VI. Характеристики на част ниско напрежение:

Автоматичните прекъсвачи са със следната изключвателна възможност:

- за Авт. Прекъсвачи 1250К 3P - 50 кА, 380/4V

Вертикалните разединители са със следната изключвателна възможност:

- за 400А 3P - 50 кА, 400/230V.
- за 1000А 3P - 50 кА, 400/230V.

Токовете трансформатори са с клас на точност - 0,5.



ВЕРИФИЦИРАНО
09/09/2013
2013/09/09



"МИНПРОЕКТ" ЕАД

ИЗПИТВАТЕЛЕН ЦЕНТЪР "МИНПРОЕКТ"

2351 с. Драгичево ☎ 077182911, 077182240

ЛАБОРАТОРИЯ ЗА ИЗПИТВАНЕ НА ВЗРИВОЗАЩИТЕНИ СЪОРЪЖЕНИЯ
☎ 077182340

ПРОТОКОЛ ОТ ИЗПИТВАНЕ
№ 07 от 10.07.2013 г.

Наименование на продукта (тип, марка, вид): Бетонен комплектен трансформаторен пост ТИП – СТРС.

Наименование на производителя: „ЕН ДЖИ ТЕХНОЛОДЖИ“ ООД

Заявител на изпитването: „ЕН ДЖИ ТЕХНОЛОДЖИ“ ООД

Заявка/писмо за изпитване: 08/28.06.2013 г. Изпитване за отелен на защита IP 33D

Методи за изпитване: БДС EN 60529-А1:2004

№ на образеца по входящо изходящия дневник: Опитен образец

Дата на получаване на образеца за изпитване: Образеца е изпитан на мястото на производство.


Количество на изпитваните образци: Един брой.

Данни на образците за изпитване: Посочоните в конструктивната документация.

Документи придружаващи образците за изпитване: Конструктивна документация.

Дата на извършване на изпитването: 04.07.2013 г.

РЫКОВОДИТЕЛ НА ИЗПИТВАТЕЛНАТА ЛАБОРАТОРИЯ



(Илиг. В. Стоянов)

Забележка: Резултатите от изпитванията се отнасят само за изпитваните образци. Протоколът от изпитването или не може да се размножават без писменото одобрение на Изпитвателната лаборатория. Копия от протокола се легализират и разпространяват само със син печат на Изпитвателния център. Корекция и допълнения към протокола от изпитването се извършват само със следващ документ на Изпитвателната лаборатория. Протоколът е отпечатан в два екземпляра.



Handwritten mark or signature.

ИЗПОЛЗВАНИ ТЕХНИЧЕСКИ СРЕДСТВА ЗА ИЗМЕРВАНЕ

№ по ред	Техническо средство за измерване	ИДВ. №	№ на свидетелството за калибриране
1.	Термометър цифров №03	III-2-8	123D/19.04.2013г.
2.	Пробници към стенд за прахозащита	III-2-23	
3.	Приспособление от стенд за водозащита за втора характеристична цифра 3	V-2-7	

Забележка: Резултатите от изпитванията се отнасят само за изпитваните образци. Протоколът от изпитването или части от него не може да се размножават без писменото съгласие на Изпитвателната лаборатория. Копия от протокола се доставяват и разпространяват само със син печат на Изпитвателния център. Корекции и допълнения към протокола от изпитването се извършват само със следващ документ на Изпитвателната лаборатория. Протоколът е отпечатан в два екземпляра.

ВАРНО С
ОПРАТНИЦИ


"МЕДИКО" ЕООД
гр. Севлиево ул. "Хр. Спиридонов" №3, тел./факс: 0675/3 53 87;
гр. Габрово ул. „Чумерна“ №15А, тел./факс: 066/866 100;
тел./факс: 02/971 98 09; 0882/025 079

Акредитиран Орган за контрол от вид "С" "ФРС"
от ИАБСА, страна по ЕА МЛА в областта Органи за контрол.
Сертификат за акредитация Рег. № 100 ОК от Вид "С"/13.02.2012г.
валиден до 31.12.2014г., съгласно изискванията на стандарт ВДС EN ISO/IEC 17020:2005

СЕРТИФИКАТ ЗА КОНТРОЛ

№3880/05.07.2013г.

1. Клиент: "ЕН ДЖИ ТЕХНОЛОДЖИ" ООД
Адрес: гр. София, бул. „Самоков“ №1
2. Обект: Трафопост
Адрес: гр. София, ул. „Капитан Любен Кондаков“ №5

3. Контролирани параметри:
3.1. Еквивалентно ниво на шум

4. Заключение.

4.5. Еквивалентното ниво на шум, dBA, съгласно протокол №3880-1/05.07.2013г. и №3880-2/05.07.2013г., съответства на изискванията на Наредба №6/ДВ бр.58/2006г. за ден.

Приложение: Протоколи от контрол №3880-1 (2 листа) и №3880-2 (2 листа) са неразделна част от Сертификат за контрол №3880/05.07.2013 г., общо 5 листа.

Извършил оценка на съответствието

Ръководител на звено:
(инж. Р. Панайотов)

Дата: 05.07.2013г.

Ръководител на
органа за контрол:
/Д-р Кр. Стойнова/

Не се допуска използването на копия от настоящия сертификат за контрол или на части от него освен с писмено разрешение на органа за контрол издал сертификата. Сертификатът може да бъде отнет при неправомерно позоваване или неправилна употреба.



ОПРЕДЕЛЕНА
ВЪРНА ОБОЗНАЧКА

EDUJKO

“Медико” ЕООД
гр. Севлиево ул. “Хр. Спиридонов” №3, тел./факс: 0675/3 53 87
гр. Габрово ул. „Чумерна” №15А, тел./факс: 066/866 100
тел./факс: 02/971 98 09; 0882/025 079
e-mail: mediko_stm@abv.bg, www.mediko.org

Акредитиран Орган за контрол от вид “С” “ФРС”
от ИА БСА, страна по ЕА МЛА в областта Органи за контрол.
Сертификат за акредитация Рег. №100 ОК от Вид “С”/13.02.2012г.
валиден до 31.12.2014г., съгласно изискванията на стандарт БДС EN ISO/IEC17020:2005

Лист 1 от 2
Всичко листове 2

ПРОТОКОЛ
ОТ КОНТРОЛ НА ШУМ В ЖИЛИЩНИ И ОБЩЕСТВЕНИ СГРАДИ
№3880-1/05.07.2013г.

1. Клиент: “ЕН ДЖИ ТЕХНОЛОДЖИ” ООД
Адрес: гр. София, бул. „Самоков” №1
2. Обект: Трафопост
Адрес: гр. София, ул. „Капитан Любен Кондаков” №5
3. Вид на обекта: нов
4. Основание за контрола: Заявка – дата 01.07.2013г.
5. Контролиран параметър:
 - 5.1. Еквивалентно ниво на шум, dBA
6. Нормативни актове:
 - 6.1. Метод на контрол: БДС 15471-1982г.
 - 6.2. Нормативни изисквания: Наредба №6/ДВ бр.58/2006г.
7. УСЛОВИЯ ПРИ КОНТРОЛА:
 - 7.1. Източници на шум: Трансформатор.
 - 7.2. Характер на шума: Променлив.
8. РЕЗУЛТАТИ ОТ КОНТРОЛА:



ВРЪНО С
ОРИГИНАЛА



№ по ред	Място на измерване	Еквивалентно ниво на шум, dBA /ден/		Еквивалентно ниво на шум, dBA /вечер/		Еквивалентно ниво на шум, dBA /нощ/	
		Изчислено	Норма	Изчислено	Норма	Изчислено	Норма
1	2	3	4	5	6	7	8
1.	Графопост /пред трансформатор/	58,9	60,0	-	-	-	-

9. ЗАБЕЛЕЖКА: Нима

10. ТЕХНИЧЕСКО СРЕДСТВО: Интегриращ шумомер NL-20, Идент. №01010829, свидетелство за калибр. № 068 – ИАВ/28.04.2011г.; Пистолфон – РР 101, Германия, Идент. №31033, Свидетелство за калибриране №067-ИАВ/28.04.2011г.

Дата на извършване на контрола: 01.07.2013г.

Извършили контрола:

1.  (г-нх. Пламен Стоянов)
 2.  (г-нх. Иван Иванов)



ВРЪН С
ОПРЕДЕЛЕНИЕ

EDUJKO

“Медико” ЕООД
гр. Севлиево ул. “Хр. Спиридонов” №3, тел./факс: 0675/3 53 87
гр. Габрово ул. „Чумерна” №15А, тел./факс: 066/866 100
тел./факс: 02/971 98 09; 0882/025 079
e-mail: mediko_stm@abv.bg, www.mediko.org

Акредитиран Орган за контрол от вид “С” “ФРС”
от ИА БСА, страна по ЕА МЛА в областта Органи за контрол.
Сертификат за акредитация Рег. №100 ОК от Вид “С”/13.02.2012г.
валиден до 31.12.2014г., съгласно изискванията на стандарт БДС EN ISO/IEC17020:2005


Лист 1 от 2
Венчко листово 2

**ПРОТОКОЛ
ОТ КОНТРОЛ НА ШУМ В РАЗЛИЧНИ ТЕРИТОРИИ И УСТРОЙСТВЕНИ ЗОНИ В
УРБАНИЗИРАНИ ТЕРИТОРИИ И ИЗВЪН ТЯХ**

№3880-2/05.07.2013г.

1. Клиент: **“ЕН ДЖИ ТЕХНОЛОДЖИ” ООД**
Адрес: гр. София, бул. „Самоков” №1
2. Обект: **Трафопост**
Адрес: гр. София, ул. „Капитан Любен Кондаков” №5
3. Вид на обекта: **в експлоатация**
4. Основание за контрола: **Заявка – дата 01.07.2013г.**
5. Контролиран параметър:
 - 5.1. **Еквивалентно ново на шум, dBA**
6. **Нормативни актове:**
 - 6.1. **Метод на контрол: БДС 15471-1982г.**
 - 6.2. **Нормативни изисквания: Наредба №6/ДВ бр.58/2006г.**
7. **УСЛОВИЯ ПРИ КОНТРОЛА:**
 - 7.1. **Източници на шум: Трансформатор.**
 - 7.2. **Характер на шума: Променлив.**
8. **РЕЗУЛТАТИ ОТ КОНТРОЛА:**

**ВАРНО С
ОРГАНИЗАЦИЯ**





№ по ред	Място на измерване	Еквивалентно ниво на шум, dBA /ден/		Еквивалентно ниво на шум, dBA /вечер/		Еквивалентно ниво на шум, dBA /нощ/	
		Изчислено	Норма	Изчислено	Норма	Изчислено	Норма
1	2	3	4	5	6	7	8
1.	Трафопост /1м. от трафопост/	50,3	70,0	-	-	-	-
2.	Трафопост /4,1м. от трафопост по-посока на фасадите с вентилационни решетки/	33,8	70,0	-	-	-	-
3.	Трафопост /под 4,1м. от трафопост по посока на фасадите без вентилационни решетки/	34,1	70,0	-	-	-	-

9. ЗАБЕЛЕЖКА: Оценката на съответствието е извършена съгласно нормативните изисквания на Наредба №6/ДВ бр.58/2006г. /приложение №2 към чл. 5 – таблица №2, т. 6/

10. ТЕХНИЧЕСКО СРЕДСТВО: Интегриращ шумомер NL-20, Идент. №01010829, свидетелство за калибр. № 068 – ИАВ/28.04.2011г.; Цисгофон – PF 101, Германия, Идент. №31033, Свидетелство за калибриране №067-ИАВ/28.04.2011г.

Дата на извършване на контрола: 01.07.2013г.

Извършили контрола:

1.  (инж. Пламен Симеонов)
 2.  (инж. Иван Иванов)



ВАРНО С
ОПРЕДЕЛЯНЕ

„ЕЛКИП“ ООД	Стр. 1 от 3
ИЗПИТВАТЕЛЕН ПРОТОКОЛ БДС EN 62271 – 202:2007 Комплектни подстанции за високи / ниски напрежения изработени в заводски условия	
Протокол Пореден №: 003 Изпитал (+подпис).....: К. Петров Проверил (+подпис).....: Е. Александров Ръководител (+подпис).....: А. Атанасов Дата на издаване.....: 17.07.2013 г. Съдържание.....: 3 страници	
Изпитал: Име.....: „ЕЛКИП“ ООД Адрес.....: Република България, гр. Радомир, ж.к. „Гърляница“, бл. 1	
Клиент: Име.....: „Ен Джи Технолоджи“ ООД Адрес.....: Република България, гр. София, бул. Самоков № 1	
Спецификация на изпитването: Стандарт.....: БДС EN 62271 – 202:2007	
Изпитван образец: Описание.....: Комплектен трансформаторен пост с бетонов корпус изработен в заводски условия Означение на модела и/или типа, №.....: CTRS до 800 kVA Производител.....: „Ен Джи Технолоджи“ ООД Резултат от изпитването: Горепосоченият продукт: отговаря / не отговаря	



Д-р Петров К.
 17.07.2013 г.

Резултати от изпитването:

Метод на изпитване съгласно клауза:	Кратко описание на изискването / изпитването:	Изискване съгласно клауза:	Норма / предписание:	Резултат Измерено / наблюдавано	Заклучение (удовлетворява) да / не
1.	2.	3.	4.	5.	6.
	<p>6.3. БДС EN 62271 – 202:2007 Трансформаторът и комплектното комутационно устройство за разпределение и управление за ниско напрежение във вътрешността на обвивката от клас 10 на изработения в заводски условия комплектен трансформаторен пост с бетонов корпус за високи/ниски напрежения издържат изпитване за определяне превишенията на температурата</p>		да	Да	да
	<p>6.3.2. БДС EN 62271 – 202:2007 Измерените прегрявания при температура на въздуха извън обвивката $t_{oc} = 15^{\circ}\text{C}$ на:</p> <ul style="list-style-type: none"> - Трансформатора: <ul style="list-style-type: none"> охлаждаща течност (маслото) в горните слоеве, К намотките на трансформатора, К - разглежданата част (5 вериги) от комплектното комутационно устройство за разпределение и управление за ниско напрежение при условна стойност на обявен коефициент на едновременност 0,8 клеми на външни изолирани проводници органи за ръчно задействане с изолационни повърхности, К достъпни външни обвивки с метални повърхности, К 		≤ 60 ≤ 70	58 67	да да
			≤ 70	39	да
			≤ 25	13	да
			≤ 30	10	да



17.07.2013
0 11:25:57

1. Обявен клас на обвивката на БКТП – 10

Случай на заключение при изпитването
Изпитаният образец удовлетворява изискването – Да
Изпитаният образец не удовлетворява изискването – Не
Дата на заявяване на изпитването – 03.06.2013 г.
Дата (и) на провеждане на изпитването - 17.07.2013 г.



МЕДИЦИНСКО
ОБЩЕСТВО

Протокол от изпитване: WP-PB-0301033 Go-001 /копие/

Предмет на изпитването: Измерване херметичност на кабелен проход на фирма Дойма тип VKD 150 срещу Хелий

Клиент: Дойма ГмбХ и Ко
Индустриштрассе № 43-57
28876 Ойтен

Поръчка/Док. за експедиция: от 25.06.2001 г.

Изпитвателна лаборатория: Фрауенхофер – Институт за технология и изследване на материали
Лаборатория за изпитаване на материал, металография и анализ
Винер Штрассе 12
D-28359 Бремен
Тел. +49 /0/4 21/2246-4 00
факс +49 /0/4 21/2246-4 30

Обект на изпитването: Уплътнителна система VKD 150

Начална дата: 25.06.2001

Указания: Резултатите се отнасят само за горепосочения обект на изпитване. Без писменото одобрение на изпитвателната лаборатория този протокол от изпитване не може да бъде частично разпространяван. Ако поръчителят на изпитването трябва да дава указания от името на изпитвателната лаборатория, трябва да се посочва пълния препис от изпитвателната лаборатория

Дата на издаване: Бремен, 02.08.2001

Подпис:



1. Предмет на изпитването:

Изпитван детайл от системата: херметичен проход BKD 150-K/150
капачка BKD 150-D3/60

Подготовка на изпитването: виж рисунка приложение 1

Провеждане на изпитването: Подготовката на изпитването се осъществява от сътрудник на заявителя на измерването. След подлагане на изпитваните проходи с налягане от 5 бара с Хелий, беше измерено частично налягане на газа с помощта на Детектор за Хелий Leybold UL 200.

изискването на изпитването до -25°C , системата е подложена на изпитване под водно налягане от 5 бара. Силата на установеното водно налягане беше измерена и отчетена за период от 24 часа.

Измервателна техника: Измервателен усилвател тип MGC/MC55

Датчик за налягане тип P8AP/10
Детектор за Хелий Leybold UL 200.

Дата на изпитването: 25.06.2001

Провел изпитването: Миахел Гом

2. Резултати от измерването:

Таблица с резултати:

Изпитване	Среда на изпитване	Налягане /бара/	Измерено частично налягане /mbar l/s/	Частично налягане на атмосферата /mbar l/s/
1	Хелий	5	4.8 E-6	4.8 E-6

Тъй като беше измерено само атмосферното частично налягане, от това може да се установи, че няма пропуск на Хелий.

3. Забележки

Херметичността при Хелий на проходната система KD, при изпитване в бетонова основа е представено в протокол от изпитване WP-PB-398012-007 от 28.01.1999 с измерено частично налягане от $5,4\text{E}-6$ мбара.

Приложение № 1

Приложение № 2



Fraunhofer Institut
Fertigungstechnik
Materialforschung

Prüfbericht WP-PB-A301033Go-001 (Abschrift)
Der Prüfbericht umfasst 3 Blätter und 2 Anlage

Aufgabenstellung Messung der Dichtigkeit einer Kabeldurchführung der Fa. Doyma GmbH & Co des Typs BKD 150 gegenüber Helium

Auftraggeber DOYMA GmbH & Co
Industriestraße 43-57
28876 Oyten

Auftrags/Lieferschein Nr. vom 25.06.2001

Prüflabor Fraunhofer - Institut für Fertigungstechnik und Angewandte
Materialforschung (IFAM)
Labor für Werkstoffprüfung, Metallographie und Analytik
Wiener Straße 12
D - 28359 Bremen
Tel. +49 (0) 4 21 / 22 46 - 4 00
Fax. +49 (0) 4 21 / 22 46 - 4 30

Prüfgegenstände Kabeldurchführungssystem BKD 150

Eingangsdatum 25.06.2001

Hinweise Das Prüfergebnis bezieht sich ausschließlich auf die genannten Prüfgegenstände.
Ohne schriftliche Genehmigung des Prüflabors darf dieser Prüfbericht nicht auszugsweise vervielfältigt werden.
Soll vom Auftraggeber auf die Inanspruchnahme des Prüflabors hingewiesen werden, muss die vollständige Anschrift des Prüflabors angegeben werden.

Ausstellungsdatum Bremen, den 02.08.2001

Unterschrift

H. Porede

ИЗПЪЛНЕНО
3 ОЖИВА



1. Prüfgegenstand

Zu prüfende Einzelteile des Systems: Einfach-Dichtpackung BKD 150-K/150
Systemdeckel BKD 150-D3/60

Prüfvorrichtung: s. Zeichnung Anlage 1

Versuchsdurchführung: Die Prüfvorrichtung wurde von einem Mitarbeiter des Auftraggebers für die Messung vorbereitet.
Nach Beaufschlagung des Prüfdruckes von 5 bar mit Helium, wurde der Partikeldruck des Gases mit Hilfe eines Heliumdetektors Leybold UL 200 gemessen.

Messtechnik: HBM-Messverstärker Typ MGC / MC55
(IFAM-Prüfmittel Nr.: A4.110-0001)

HBM-Druckaufnehmer Typ P8AP/10
(IFAM-Prüfmittel Nr.: D2.2110-0002)

Leybold Heliumdetektor Typ UL 200

Prüfdatum: 25.06.2001

Prüfer: Michael Gomm



МИХАИЛ
ГОММ

2. Messergebnisse

Ergebnistabelle:

Prüfung	Prüfmedium	Prüfdruck [bar]	gemessener Partikeldruck [mbar l/s]	Partikeldruck der Atmosphäre [mbar l/s]
1	Helium	5	$\approx 4.8 \text{ E-6}$	$\approx 4.8 \text{ E-6}$

Da nur der atmosphärische Partikeldruck gemessen wurde, ist davon auszugehen, dass kein Helium aus der Prüfvorrichtung austrat.

3. Bemerkungen

Die Helium-Dichtigkeit der Dichtpackung des KD-Systems in einem Betonprüfkörper wird im Prüfbericht WP-PB-398012-007 der IFAM vom 28.01.1999 mit einem gemessenen Partialdruck von 5.4 E-6 mbar nachgewiesen.


Der Versuchsaufbau ist in Form einer Skizze in Anlage 2 dargestellt.




ИЗВЕЩАНИЕ
О РЕЗУЛТАТАТ

K

Anlage Nr. 1 zu IFAM Prüfbericht
WP:PB 470/67790-001





Betonblock

Dichtpackung+
Abdichtsystem

Abdichtung der
Prüfglocke

Prüfglocke

Normflansche

Dichtelement

Helium
5 bar

Wasser

Wasser

Anlage Nr. 2 zu IFAM Prüfbericht
WP-PB 130 10 83 90 001

ИЗПЪЛНИЛО
О СЪДЕКА



Измерване херметичност на кабелен проход
тип KD 85 D1/75 срещу Хелий

копие

Протокол от изпитване: WP-PB-398012-007
Поръчка от: 19.08.1999

Дойма ГмбХ и Ко
Индустриштрассе № 43-57
28876 Ойтен

Фрауенхофер – Институт за технология и изследване на
материали
Лаборатория за изпитаване на материал, металография и
анализ

Винер Штрассе 12
D-28359 Бремен
Тел. +49 /0/4 21/2246-4 00
факс +49 /0/4 21/2246-4 30

М. Бреде

М. Гом

Бремен, 03.09.2002



1. Задача:

Предмет на изследването беше кабелен проход тип KD 85/D1-75, който беше предоставен за изпитване от Дойма ГмбХ и Ко, Ойтен /заявител/.

Целта на изследването беше измерване на интензивността на теч, която има кабелния проход при подлагане на налягане с Хелий от 5 бара.

2. Провеждане на изследването:

Изпитваният обект беше подготвен от сътрудник на заявителя в института за измервания /Приложение WP-PB-398012-007-01/. След подлагане на налягане от 5 бара с Хелий, беше измерено частичното налягане на Хелия с помощта на Детектор за Хелий тип Leybold UL 200.

Следното изследване с изпитван обект тип KD беше проведено:

Изпитване	Изпитван обект	Брой	Период на изпитването	Среда на изпитването	Налягане при to
			/h/		/bar/
	KD 85-D1/75	1	-	Хелий	5

3. Резултати

При този изпитван обект беше измерено частично налягане от максимално $5,4E-6$ мбара. Нормалното частично налягане на Хелий във въздух е $4,8E-6$ мбара.

Дейностите бяха проведени в съответствие с общите търговски условия на дружеството Фрауенхофер.



Fraunhofer Institut
Fertigungstechnik
Materialforschung

Messung der Dichtigkeit einer Kabeldurchführung des Typs KD 85 D1/75 gegenüber Helium

Abschrift

Kurzbericht WP-PB-398012-007 zum
Angebot Nr. 398012
Auftragseingang: 19.08.1998

DOYMA GmbH & Co
Industriestraße 43-57

D-28876 Oyten

Fraunhofer - Institut für Fertigungstechnik und Angewandte Materialforschung
(IFAM)
Labor für Werkstoffprüfung, Metallographie und Analytik
Wiener Straße 12
D - 28359 Bremen

M. Brede

M. Brede

M. Gomm

M. Gomm



Bremen, 03.09.2002

1 Aufgabenstellung

Gegenstand der Untersuchung war eine Kabeldurchführung des Typ KD 85-D1/75, die von DOYMA GmbH & Co, Oyten (Auftraggeber AG) zur Prüfung beigestellt worden waren.

Ziel der Untersuchung war die Messung der Leckrate, die diese Kabeldurchführung bei Beaufschlagung mit Helium unter einem Druck von 5 bar erreicht.

2 Durchführung des Versuches

Der Versuchskörper wurde von Mitarbeitern des AG im Institut für die Messung in die entsprechende Versuchsvorrichtung (Anlage WP-PB-398012-007-1) eingebaut. Nach Beaufschlagung mit Helium unter einem Druck von 5 bar wurde der Partialdruck des Heliums mit Hilfe eines Heliumdetektors Leybold UL 200 gemessen.

Folgender Versuch mit einem Prüfkörper des Typs KD wurde durchgeführt:

Prüfung	Prüfkörper	Anzahl	Sollprüfzeitraum	Prüfmedium	Druck bei t_0
			[h]		[bar]
	KD 85-D1/75	1	-	Helium	5

3 Ergebnis

Bei diesem Prüfkörper wurde ein Partialdruck von maximal $5.4E-6$ mbar gemessen. Der normale Partialdruck von Helium in der Luft beträgt $4.8E-6$ mbar.


Die Arbeiten werden unter Zugrundelegung der allgemeinen Geschäftsbedingungen der Fraunhofer-Gesellschaft durchgeführt.

Bremen, 28.01.99/Wu



ИЗДАНО
2000

Aufbau Heliumprüfung



Anlage Nr. zu IFAM Prüfbericht
WP-PB-..... 298012.007



ВЪЗНЕСЕНО
ВЪЗНЕСЕНО



БЪЛГАРСКА СЛУЖБА
ЗА АКРЕДИТАЦИЯ

СЕРТИФИКАТ
ЗА АКРЕДИТАЦИЯ

„МЕДИКО“ ЕООД
ОРГАН ЗА КОНТРОЛ
„ФАКТОРИ НА РАБОТНАТА СРЕДА“ ОТ ВИД С

ЕИК: 107518480

Адрес на управление:
5400 гр. Севлиево, ул. „Христо Спиридонов“ № 3

Адрес на офис:
5300 гр. Габрово, ул. „Чумерна“ № 15А

ОБХВАТ НА АКРЕДИТАЦИЯ:

Контрол на:

Електрически уредби и съоръжения до 1000 V

Климатични и вентилационни инсталации

Химични агенти във въздуха на работна среда

Физични фактори на работна и битова среда

Вибрации, предавани на системата ръка-рамо и на цялото тяло

Електромагнитни полета

Физическо натоварване

АКРЕДИТИРАН СЪГЛАСНО БДС EN ISO/IEC 17020:2005

Заповед № 183/13.02.2012 г е неделима част от сертификата за акредитация,
общо5... страници

Валиден до:31.12.2014г.

БСА рег. № 100 ОКС...

Изпълнителен директор:

Инж. Елза Янева

Дата на първоначална
акредитация: 27.06.2003 г.

Дата на преакредитация: 23.12.2010 г. София 13.02.2012 г.



ROMANIAN ACCREDITATION ASSOCIATION - RENAR

Bucharest, Calea Vitan no. 242, sector 3, zip code 031301
CIF RO 4311980



RENAR is EA-MLA signatory for Testing.

ACCREDITATION CERTIFICATE No. LI 004

Romanian Accreditation Association – RENAR, being recognized as National Accreditation Body by OG 23/2009, herewith attests that the organization:

NATIONAL INSTITUTE FOR RESEARCH-DEVELOPMENT AND TESTING IN ELECTRICAL ENGINEERING – ICMET CRAIOVA

Decebal Avenue no. 118A, Craiova, county Dolj

through

HIGH POWER TESTING LABORATORY FOR ELECTRICAL EQUIPMENT (HPTL)

fulfills the requirements of **SR EN ISO/CEI 17025:2005** and is competent to carry on **TESTING** activities, as it is detailed in the Annex of the present accreditation certificate.

This accreditation is maintained provided that the accreditation criteria established by the Romanian Accreditation Association – RENAR are met continuously.

The present certificate includes Annex no. 1 (9 pages), which is an integrated part of this certificate.

In order to check the validity of the accreditation certificate, including the Annex, the website of RENAR shall be consulted: www.renar.ro.

Date of Initial accreditation: 22.11.2010

Date of accreditation renewal: 21.11.2014

The accreditation is valid until: 20.11.2018

GENERAL DIRECTOR

PRESIDENT OF THE ACCREDITATION COUNCIL

Cătălina Viorica NEAGUE

PhD. Eng. Dumitru DINU



Partial reproduction of this certificate is forbidden.

REPRODUCED
BY THE
ACCREDITATION
COUNCIL

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаната, Мария Цветкова в качеството си на Управител на „Ен Джи Технолоджи“ ООД, декларирам на собствена отговорност, че продуктът:

Стоманобетонена конструкция за бетонов комплектен трансформаторен пост

произведен от „Ен Джи Технолоджи“ ООД
с адрес: гр. София 1528, НПЗ Искър,
ул. „Кап. Любен Кондаков“ № 5

за който се отнася тази декларация, е в съответствие с изискванията на:

БДС EN 13670-1:2009

и Наредба за съществените изисквания към строежите и оценяване съответствието на строителните продукти.

Декларацията се издава въз основа на:

Сертификат за производствен контрол
№ НСИСОСП-3288 от 05.07.2013 г.

Издаден от:


„Ен Джи Ен“ ООД - гр. Хасково


с адрес: гр. Хасково 6300, Търговски комплекс XXI век, ет. 4 офис 5,
Разрешение РОССП-05 от 12.11.2007 г. и Нотифициран орган от
Европейската комисия NB 1888.

Декларирам, че ми е известна отговорността, която нося съгласно чл.
313 от НК.

дата: 08.08.2013 г.
гр. София

Управител:





INSULATED ADAPTER TERMINATION SYSTEM (RICS) FOR SF6-INSULATED SWITCHGEAR UP TO 24 kV

KEY FEATURES

- Perfect sealing, electrical insulation and electrical connection
- Connection to bushing Type C according EN80181
- Insulating adapter is compatible with all Raychem terminations
- Adapters are water tight
- Universal technology increasing the reliability, irrespective of the type of cable used in the network

TE Connectivity's (TE) Raychem insulating adapter RICS (630 A) is for the connection on outer cone bushings Type C according to EN-50181. It is compatible with all Raychem terminations and can thus be used to connect any type of cable, irrespective of whether it is paper or plastic insulated or has one or three cores.


The Insulated adapter termination system provides perfect sealing, electrical insulation and an electrical connection between Raychem terminations and SF6-insulated switchgear up to 24 kV. The compact design of the adapters and their clear cut profiles simplify installation. The electrical connection with the aid of a stud renders additional fastening systems unnecessary.

TE Energy has several decades of experience in the field of hermetically insulated termination systems for medium voltage applications. The adapters are watertight and can operate under extreme environmental conditions with severe pollution.

Customers can count on consistent, high quality products, driven by TE's proven innovation and backed by our extraordinary customer support.




Insulated Adapter Termination System



RICS adapters come in various types:

T-adapter with or without surge arrester

Thick walled insulator made of high quality elastomer with sealing face over the termination, bushing cone and plug. The electrical connection is made with a terminal stud and the cable lug of the termination. Two cable connection is possible. A special plug which allows cable testing without disconnecting the adapter is also offered. The design of the adapter for connecting the RDA surge arrester is basically identical. The elastomer insulator has an additional lead-in duct for the surge arrester. Scope of supply (for three phases) insulator, plug, terminal stud, small accessories and installation instructions.



Straight adapter

A thick walled, heat-shrinkable insulating sleeve provides a hermetic seal over the cone of the bushing and the termination. The adapter area is smoothed with a meltable filler strip. Scope of supply (for three phases) heat-shrinkable insulating sleeving, filler strip, small accessories and installation instructions. Terminal stud and lug must be enclosed.



PRODUCT SELECTION INFORMATION

Description	System Voltage (kV)	Gross Section (mm²)	Diameter of termination (mm)
RICS-5113	12	25 - 50	17,5 - 24
RICS-5123	12	70 - 150	21,5 - 28
RICS-5133	12	185 - 240	27 - 35
RICS-5143	12	300	32,5 - 42
RICS-5123	24	25 - 70	21,5 - 28
RICS-5133	24	90 - 185	27 - 35
RICS-5143	24	240 - 300	32,5 - 42
Kits to connect surge arrester RDA:			
RICS-5139	12	185 - 240	27 - 35
RICS-5149	12	300	32,5 - 42
RICS-5139	24	185 - 240	27 - 35
RICS-5149	24	300	32,5 - 42

TESTING

The adapters conform to IEC 540, and VDE 0278 specifications, as well as to the Raychem specification PPS 3013. The test requirements and results are summarized in Raychem Test Report PPR 1106, which is available on request.

te.com/energy

©2014 TE Connectivity Ltd, family of companies. All Rights Reserved. EPP-0532-10/H

Raychem, TE Connectivity and TE connectivity (logo) are trademarks. Other logos, product and/or company names might be trademarks of their respective owners. While TE has made every reasonable effort to ensure the accuracy of the information in this brochure, TE does not guarantee that it is error-free, nor does TE make any other representation, warranty or guarantee that the information is accurate, correct, reliable or current. TE reserves the right to make any adjustments to the information contained herein at any time without notice. TE expressly disclaims all implied warranties regarding the information contained herein, including, but not limited to, any implied warranties of merchantability or fitness for a particular purpose. The dimensions in this catalog are for reference purposes only and are subject to change without notice. Specifications are subject to change without notice. Consult TE for the latest dimensions and design specifications.

FOR MORE INFORMATION: TE Technical Support Centers

USA: +1 800 327 6996
 France: +33 380 583 200
 UK: +44 0870 870 7500
 Germany: +49 896 089 903
 Spain: +34 916 630 400
 Benelux: +32 16 351 731
 Canada: +1 (905) 475-6222
 Mexico: +52 (0) 55-1106-0800
 Latin/S. America: +54 (0) 11-4733-2200
 China: +86 (0) 400-820-6015


ENERGY /// INSULATED ADAPTER TERMINATION SYSTEM



tyco


Electronics

**RSES/RSSS
Screened Adaptor System
250 A, 24 kV**



БЪЛГАРИЯ
КИМТЕХ

ENERGY DIVISION




Raychem separable Screened Adaptors are designed to connect single-core polymeric cables to medium voltage equipment (transformers, switchgears, motors etc.) up to 24 kV.


Made of crosslinked EPDM and protected with a minimum 3 mm moulded conductive shield connected to earth, Raychem deadbreak adaptors are suitable for both indoor and outdoor installations.

Their wide application range allows a minimum number of bodies to cover several different cable cross-sections without the need for additional cable adaptors. The cut-back dimensions for all cable sizes are the same for RSSS and RSES.

Raychem Screened Adaptors are equipped with a capacitive test point to ensure that the circuit is not energised before disconnection. The capacitive test point is protected by a conductive cap. A range of high strength bimetallic compression connectors tested to VDE 0220 are offered to connect both aluminium and copper conductor cables. After cable preparation and lubrication, the Raychem Screened Adaptors can simply be slid into place under virtually all conditions. A separable mounting system provides for an easy installation of the adaptor onto the bushing.




In addition, Rayvolve tubing or heat-shrink phase-marking sleeves are offered as an option, to provide a superior environmental seal.




Rayvolve Sealing



Cold applied technology. Rayvolve is used in conjunction with a pressure sensitive mastic and is simply rolled into place. Thus a reliable moisture seal is achieved. The use of Rayvolve is particularly recommended for applications where a torch is unavailable or cannot be used.



Heat-Shrinkable Sealing

Moisture seal and phase marking. A reliable moisture seal can also be produced by using a mastic in conjunction with a heat-shrinkable sleeve. This solution has the additional advantage of providing phase marking. A standard torch carried by most joiners is used.





1 Screened Body

A 3 mm conductive moulded outer screen is permanently bonded to the EPDM insulating material of the body.

2 Capacitive Test Point

Used to determine if the circuit is energised; can also be used for phasing. Electrically protected by a cap made of EPDM.

3 Stress cone

Computer designed, it relieves electrical stress at the cable screen cut of the termination.

4 Conductive Cable Entrance

The 25 mm conductive end provides a connection to the cable screen.

5 Earthing Eye

Provides a connection point for the screen of the body to the earth.

6 Inner Screen

Conductive insert provides a "Faraday cage" around the compression connector and eliminates corona at rated voltage.

7 Retaining Shoulder

To fix a retaining collar onto the adaptor for easy installation with two screws.

8 Compression Pin-Connector

Bimetallic compression pin-connector designed with locking ring, to connect both aluminium and copper conductor cables.

9 Lifting Eye


A lifting eye firmly attached to a moulded-in insert provides a secure connection point.

10 Pin

Tin plated copper electrode, designed and tested to carry 250 A continuous current. The hexagonal wrench to fix the pin onto connector is supplied with each kit.

11 Compression Connector

Bimetallic compression connector to connect both aluminium and copper conductor cables.



RSES/RSSS**Screened Adaptor System 250 A, 24 kV**

Technical data	RSES	RSSS
Cable Insulation Diameter Range	13.5 - 33.5 mm	13.5 - 26.5 mm
Connector Cross section Range	16 - 120 mm ²	16 - 95 mm ²
Maximum System Voltage	24 kV	24 kV
Continuous Current Rating	250 A	250 A
Basic Impulse Level	125 kV	125 kV
Partial Discharge at 2 U ₀	< 5 pc	< 5 pc
AC Voltage Withstand, 1 min	50 kV	50 kV
DC Voltage Withstand, 30 min	96 kV	96 kV

The adaptors have been tested in accordance with the international specifications (e.g. ANSI/IEEE 386, IEC 640, VDE 0278). The bimetallic connectors have been tested in accordance with VDE 0220 on aluminium and copper conductors. All adaptors pass the routine tests including: AC Voltage Withstand, Partial Discharge Extinction and Test Point Voltage Test.

Selection Table**Screened Elbow Adaptors**

Diameter over insulation	Cross section (Al or Cu conductor)						
	16 mm ²	25 mm ²	35 mm ²	50 mm ²	70 mm ²	95 mm ²	120 mm ²
13.5 - 17.4 mm	RSES 5201	RSES 5202	RSES 5203	RSES 5205	-	-	-
16.3 - 20.8 mm	RSES 5211	RSES 5212	RSES 5213	RSES 5215	RSES 5217	RSES 5219	-
19.6 - 24.1 mm	-	-	RSES 5223	RSES 5225	RSES 5227	RSES 5229	RSES 5224
23.1 - 27.7 mm	-	-	-	RSES 5235	RSES 5237	RSES 5239	RSES 5234
27.9 - 33.5 mm	-	-	-	-	-	RSES 5249	RSES 5244

Screened Straight Adaptors

Diameter over insulation	Cross section (Al or Cu conductor)					
	16 mm ²	25 mm ²	35 mm ²	50 mm ²	70 mm ²	95 mm ²
13.5 - 17.4 mm	RSSS 5201	RSSS 5202	RSSS 5203	RSSS 5205	-	-
16.3 - 20.8 mm	RSSS 5211	RSSS 5212	RSSS 5213	RSSS 5215	RSSS 5217	RSSS 5219
19.6 - 24.1 mm	-	-	RSSS 5223	RSSS 5225	RSSS 5227	RSSS 5229
21.0 - 26.5 mm	-	-	-	RSSS 5255	RSSS 5257	RSSS 5259

Add mod. code -R to kit number for cold applied tubing Rayvolve.
Add mod. code -P to kit number for heat shrink tubing with phase marking.

tyco
Electronics

Tyco Electronics Raychem GmbH
Flinsinger Feld 1, 85521 Otobrunn/Munich, Germany
Phone: +49-89-6089-0, Fax: +49-89-6086345
<http://energy.tycoelectronics.com>

All of the above information, including drawings, illustrations and specific designs, reflects our present understanding and is to the best of our knowledge and belief correct and reliable. Users, however, should independently evaluate the suitability of each product for the desired application. Under no circumstances does this constitute an assurance of any particular quality or performance. Such an assurance is only provided in the context of our product specifications or explicit contractual arrangements. Our liability for these products is set forth in our standard terms and conditions of sale. RAYCHEM is a trademark.

Energy Division – economical solutions for the electrical power industry: cable accessories, connectors & fittings, electrical equipment, instruments, lighting controls, insulators & insulation enhancement and surge arresters.

a vital part of your world

© Tyco Electronics EPP 0473 10/06



Универсални адаптори за КРУ с вакуум или елегаз

Нарастващата популярност на SF₆-КРУ (Комплексни разпределителни устройства с изолация от елегаз) определи разработването на съединителна система към проходните изолятори. Raucher разработи за тази цел две системи: EN-50181 тип С (400/630 А) и тип А (250 А).

За проходни изолятори по EN-50181 тип С (400/630 А):
Изолираните адаптори RICS и RCAB (630 А) са съвместими с кабелните глави на Raucher и могат да се прилагат при кабели с пластмасова и хартиено-импрегнирана изолация, едножилни и трижилни кабели.

За повече информация – Стр. 42.

Екранираните адаптори RST1 са предназначени за присъединяване на кабели с пластмасова изолация, без използване на кабелни глави – подробности на стр. 44.

За проходни изолятори по EN-50181 тип А (250 А):
Екранираните адаптори RSES и RSSS (250А) са напълно съвместими с кабелни глави за кабели с пластмасова изолация, проектирани за връзка между КРУ и трансформатор. Подробности са дадени на стр. 44.

Опростен монтаж
Компактният дизайн на адапторите и изчистен профил улесняват монтажа. Стандартният шкаф не изисква скъпо струващи модификации за присъединяване на хартиено-маслен кабел или импулсен разрядник.


Надеждност
Raucher има опит от няколко десетилетия в областта на херметично изолираните кабелни глави за средно напрежение. Адапторите са водонепроницаеми и с гарантирано непрекъсваемо действие, дори при сурови климатични условия и в силно замърсени райони.

Изпитвания
Адапторите отговарят на CENELEC HD829.1S, IEC 640, VDE 0278 и ANSI IEEE 386, както и на вътрешен стандарт на Raucher PPS 3013, освен това те са изпитвани едновременно с различни типове КРУ. Условията на изпитване и резултатите са обобщени в доклади, които могат да се предоставят при поискване.

Изолирана система глава-адаптор за КРУ до U_m 24 kV


Изолираната система глава-адаптор осигурява абсолютна херметичност, електрическа изолация и електрическа връзка между кабелната глава на Raucher и SF₆-КРУ за напрежение до 24 kV. Проходният изолатор (630 А) отговаря на EN-50181 тип С (400/630 А). Изолираните адаптори са съвместими с всички кабелни глави на Raucher. Кутията на КРУ трябва да бъде снабдена с подходяща защита срещу електрически шок. Обикновено това се постига със samozаклучващ се метален капак, който е монтиран към КРУ. Освен това той предпазва персонала от работа под напрежение.

Изолиран Т-адаптор RICS



- 1 Конусовиден проходен изолатор
- 2 RICS-адаптор
- 3 RCAB-адаптор
- 4 Кабелна глава Raucher

Изолиран прав адаптор RCAB



RICS – Изолиран Т-адаптор с или без импулсен разрядник

Дебелостенен изолатор, направен от висококачествен еластомер с херметизираща част върху главата, конусовидната втулка и запушалка. Електрическата връзка се осигурява от клемна-шифт и кабелната обувка на главата. Предлага се специална кабелна обувка, която позволява изпитване на кабели без разкачване. Конструкцията на адаптор с импулсен разрядник е идентична. Изолаторът еластомер има допълнителен проходен отвор за присъединяване на разрядник тип RDA. Предлага се адаптори и за два кабелни входа.

RCAB – Изолиран прав адаптор

Много гъвкав изолатор, направен от висококачествен еластомер, осигурява херметична връзка върху втулката и кабелната глава. Кабелната обувка на главата се присъединява просто към клемна-шифт на адаптора чрез болт и райка. Дълг при открити пространства, адапторът може да се напълва с масло или втулката, като дава достъп при изпитване на кабели. Високата гъвкавост из тялото на адаптора обикновено херметична връзка и позволява използването му при различни типове кабели при еднакво сечение.




RICS, RCAB – Изолирани T-образни адаптори и прави адаптори за SF₆-КРУ с проходни изолятори съгласно EN-50181 тип С (400/630 А), 10 kV и 20 kV

Тип кабелна глава

RICS – T-адаптор

RICS – T-адаптор за паралелно свързване на ОПН тип RDA

RICS – двоен-T-адаптор




Сечение (mm ²)	Обозначение за поръчка	Сечение (mm ²)	Обозначение за поръчка	Сечение (mm ²)	Обозначение за поръчка
Кабели с пластмасова изолация					
1- и 3-жилни кабели 10 kV с кабелни обувки Тип POLT, TFTI					
25– 50	RICS-5113	185–240	RICS-5139	185–240	RICS-5137
70–150	RICS-5123	300	RICS-5149	300	RICS-5147
185–240	RICS-5133				
300	RICS-5143				
1- и 3-жилни кабели 20 kV с пресова обувка Тип POLT, TFTI					
10– 70	RICS-5123	95–185	RICS-5139	95–185	RICS-5137
95–185	RICS-5133	240–300	RICS-5149	240–300	RICS-5147
240–300	RICS-5143				
1- и 3- жилни кабели 10 kV, с винтова кабелна обувка тип POLT, TFTI					
ML-1-13 50– 95*	RICS-5123	95–150	RICS-5139	95–150	RICS-5137
ML-2-17 95–150	RICS-5133	150–240	RICS-5149	150–240	RICS-5147
ML-4-17 150–240	RICS-5143	240–300	RICS-5149	240–300	RICS-5147
ML-5-17 240–300	RICS-5143				
1- и 3- жилни кабели 20 kV, с винтова кабелна обувка тип POLT					
ML-1-13 25– 70	RICS-5123	70–150	RICS-5139	70–150	RICS-5137
ML-2-17 70–150	RICS-5133	150–185	RICS-5149	150–185	RICS-5147
ML-4-17 150–240**	RICS-5143	240–300	RICS-5149	240–300	RICS-5147
ML-6-17 240–300	RICS-5143				
Хартиено-маслени кабели					
Поясна изолация 3-жилни к-ли (MI and MIND) 10 kV Тип GUST, EPKT-45					
35	RICS-5113	120–185	RICS-5139	120–185	RICS-5137
50– 95	RICS-5123	240	RICS-5149	240	RICS-5147
120–185	RICS-5133				
240	RICS-5143				
с винтови каб.обувки Тип GUST–L16					
35– 50	RICS-5123	70–120	RICS-5139	70–120	RICS-5137
70–120	RICS-5133	150–240	RICS-5149	150–240	RICS-5147
150–240	RICS-5143				
Екранирани 1- и 3-жилни кабели 20 kV Тип IDST					
35– 70	RICS-5133-01-12				
95–150	RICS-5133-01				
150–240	RICS-5143-01				

* За 3-жилни глави 10 kV с винтови обувки ML-1-13, RICS-5123 е подходящ до max. 70 mm².
 ** За 3-жилни глави 20 kV с винтови обувки ML-4-17, RICS-5143 е подходящ до max. 185 mm².

Забележка: Всички адаптори RICS-5113 и RICS-5123 са конструирани за работа с кабелни обувки с диаметър на отвора 13 mm.
 Всички други типове са конструирани за работа с отвор на обувката 17 mm. Ако е добавен код -12 към обозначението за поръчка, може да се използват кабелни обувки с диаметър на отвора 13 mm, например – RICS-5133-12.
 Изделия с код -12 не се доставят за комплекти с импулсни разрядници и за двойни адаптори.
 Адаптори RICS с кондензаторна буска се доставят по заявка.

Други типове адаптори се доставят по заявка.

КРИТЕХ
 БУРГАС



RSES, RSSS – Екранирани Г-образни и прави адаптори КРУ с вакуум или елегаз и трансформатори с проходни изолятори съгласно EN-50181 тип А (250 А), 10 kV и 20 kV

Екранираните адаптори на Raychem са конструирани за свързване на едножилни кабели с пластмасова изолация към SF₆-КРУ или трансформатори за напрежение до 24 kV. Адапторите херметизират проходния изолятор според изискванията на EN 50181 тип А (250А). Връзката може да се изпълни като права или правоъгълна.

Конструкция

Дебелостенният адаптор с вграден стрес-контрол осигурява херметичност и електрическа връзка на втулката и кабела. Произведен от омрежен EPDM и защитен чрез заземен залепен проводим екран с дебелина минимум 3 mm, адапторът е подходящ за монтаж на открито и закрито. Специалната конструкция и подборът на материалите позволяват използването на широка гама кабели. Така адапторите са независими от допуските в размерите и не изискват специални кабелни адаптори. Подготовката на кабела и размерите на разделката са еднакви за Г-образния адаптор и за правия адаптор.


Адапторите са снабдени с кондензаторен датчик, за предпазване от работа под напрежение. Датчикът е защитен от капачка.

В комплекта се доставят биметални висококачествени съединители, изпитани по VDE 0220 за присъединяване на кабели с алуминиеви или медни жила.


Монтаж

След подготовката на кабела и пресоване на кабелната обвивка, адапторът леко се напъхва на мястото си. При Г-образния адаптор съединителният болт се завива през обвивката с шесто-гранен ключ, доставен в комплекта. Етапният монтаж позволява лесно инсталиране на адаптора върху втулката. За осигуряване на херметичност между адаптора и кабелната обвивка се препоръчва Rayvolve – тръба или термосвиваема тръба за обозначаване на фазите.



Екраниран Г-образен адаптор



Екраниран прав адаптор




- 1 Екранирано тяло с вграден стрес-контрол
- 2 Кондензаторен датчик
- 3 Заземително ухо
- 4 Допълнителна присъединителна точка
- 5 Съединителен болт
- 6 Херметизираща тръба Rayvolve



КРИМТЕХ
БУРГАС





PPR-2857

Изолирана система глава адаптор за
SF6 КРУ до 24 kV

RICS

Изпитано от: **DET NORSKE VERITAS AS**, Норвегия

Дата: Издаден **2014-12-23**, валиден до **2018-12-31**

Стр.: 3

Приложение: -

Tyco Electronics Raychem GmbH
a TE Connectivity Ltd. Company
TE Energy
Flinsinger Feld 1
85521 Ottobrunn/Munich, Germany
Tel: +49-89-6089-0
Fax: +49-89-6096-345
energy.te.com

© 2011 Tyco Electronics Raychem GmbH



DNV GL

Сертификат No:

E-13892

Док. No:

828.20

Id:

262.1-009445-2

Сертификат за типово одобрение

Това удостоверява, че:

Глава и муфа за кабел

с тип и обозначение

RICS изолирана система глава адаптор 24kV

Издадено на:

Tyco Electronics Raychem GmbH

Отобрун, Германия

е в съответствие с

Правилата на Норске Веритас за класификация на кораби, високо скоростни и плавателни съдове и на Норске Веритас стандарти

Приложение :

Изолирана система глава адаптор RICS за SF6 КРУ до 24 kV.

Този сертификат е валиден до: **2018-12-31.**

Издаден на **2014-12-23**

DNV GL място: Есен

за **DNV GL**

Одобрил инженер: Ивар Бул

Марит Лауман
Директор отдел

Този сертификат е предмет на сроковете и условията на гърба на документа. Всяка съществена промяна или конструкция може да направи този сертификат невалиден. Срокът на валидност се отнася до сертификата за типово одобрение, а не до одобрението на оборудването.

Описание на продукта

Изолурана глава (RICS адаптори) за едножилни и 3-жилни пластмасови кабели до 24 kV

Напрежение kV	Ток [A]	Изолация на жилата Диаметър [mm]	Референтен номер Материал на проводника
Единична връзка:			
24	630	17,5 – 24	RICS-5113
24	630	21,5 – 28	RICS-5123
24	630	27 – 35	RICS-5133
24	630	32,5 – 42	RICS-5143
Двойна връзка:			
24	95	27 – 35	RICS-5137
24	120	27 – 35	RICS-5733
24	150	32,5 – 42	RICS-5147
24	185	32,5 – 42	RICS-5743

Приложение/Ограничение

Монтажът трябва да се извърши в съответствие с инструкцията за монтаж на производителя. В съответствие с правилата на DNV, максималното напрежение е 15kV. DNV може да приеме по-високо напрежение при специални приложения.

Одобрена документация

Брошура EPP 0532 1/10

Инструкция за монтаж:

EPP 0270 T адаптор 400A 24kV EN50181 "тип B"

EPP 0271 T адаптор 400/630A 24kV EN50181 "тип C"

EPP 0280 Двоен T Adaptor 400/630A 24kV EN50181

Протоколи от изпитвания:

PPR 866: Квалификация от 630A RICS двоен T-адаптор за напрежение клас 12.7/22(24)kV с два кабели на фаза

PPR 1106: Пре-квалификация на изолирана система адаптор 400/630A до 24kV в съответствие с VDE 0278, част 6

PPR 787: Квалификация на кабелни глави за хартиени и пластмасови кабели до клас 12.7/22(24)kV

PPR 865

Дългосрочно изпитване на RICS адаптор по ANSI/IEEE-386 Проходен профил и на 630A HN 52-S61 and DIN47636 проход

Изпитването е проведено

Изпитването е проведено в съответствие с CENELEC HD 629.1 S21 (2006-02), VDE 0278 Part 6, ANSI/IEEE-386.

Маркиране на продукта


Raychem – RICS по – Напрежение – Партида №

Периодична оценка

Обхватът на периодична оценка е да се провери, че условията, посочени в типовото одобрение са спазени и че не са направени изменения в дизайна на продукта или избора на материали.

Одновни елементи на проучването са:


- Проверка на фабричната моста, избрана на случаен принцип от производствената линия

- 
- Проверка на резултати от изпитването на мострата и рутинните изпитвания. Ако протоколите от изпитвания не са на разположение, ще се проведат изпитвания в съответствие с изпитването на мострата и рутинните изпитвания.
 - Преглед на документацията за типово одобрение
 - Преглед на възможна промяна в дизайн, материали и изпълнение .
 - Осигуряване проследяване на маркировка на производителя и на сертификата за типово

одобрение

Изследването да се извършва най-малко веднъж на две години.

Край на сертификата



PPR-2857

**Insulated Adapter Termination System for
SF6 Insulated Switchgear up to 24 kV**

RICS

Tested by: **DET NORSKE VERITAS AS, Norway**

Date: **Issued 2014-12-23, valid until 2018-12-31**

Pages: **3**

Appendix: **—**

Tyco Electronics Raychem GmbH
a TE Connectivity Ltd. Company
TE Energy
Finsinger Feld 1
85521 Ottobrunn/Munich, Germany
Tel: +49-89-6089-0
Fax: +49-89-6096-345
energy.te.com

© 2011 Tyco Electronics Raychem GmbH



ОПРЕДЕЛЕНА
ОТ КОМИТЕТО
НА СЪДИЩАТА

Handwritten signature or mark.

DNV GL

Certificate No:
E-13892
File No:
828.20
Job Id:
262.1-009445-2

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Termination and Joint for Cable

with type designation(s)
RICS insulated adapter termination system 24kV

Issued to

Tyco Electronics Raychem GmbH
OTTOBRUNN, Germany

is found to comply with
Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards

Application :

Insulated adapter termination system RICS for SF6 insulated switchgear up to 24 kV.

This Certificate is valid until **2018-12-31**.

Issued at **Høvik** on **2014-12-23**

DNV GL local station: **Essen**

for **DNV GL**

Approval Engineer: **Ivar Bull**

.....
Marit Laumann
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment systems installed.



Certificate No: **E-13892**
File No: **828.20**
Job Id: **262.1-009445-2**

Product description

Shrouded terminations (RICS adaptors) for single and 3-Core Medium Voltage Terminations up to 24 kV Plastic Cables

Voltage class kV	Current [A]	Core Insulation Diameter [mm]	Reference number Conductor material: Copper
SINGLE CONNECTION:			
24	630	17,5 – 24	RICS-5113
24	630	21,5 – 28	RICS-5123
24	630	27 – 35	RICS-5133
24	630	32,5 – 42	RICS-5143
DOUBLE CONNECTION:			
24	95	27 – 35	RICS-5137
24	120	27 – 35	RICS-5733
24	150	32,5 – 42	RICS-5147
24	185	32,5 – 42	RICS-5743

Application/Limitation

Installation to be done in accordance with manufacturer's installation instructions.
According to DNV Rules, maximum voltage is 15kV. DNV may accept higher voltages for special applications.

Type Approval documentation

Brochure EPP 0532 1/10

Installation Instructions:

EPP 0270 T Adaptor 400A 24kV EN50181 "Type B"
EPP 0271 T Adaptor 400/630A 24kV EN50181 "Type C"
EPP 0280 Double T Adaptor 400/630A 24kV EN50181

Test reports:

PPR 866: Qualification of 630A RICS double T-adaptor for the voltage class 12.7/22(24)kV with two cables per phase

PPR 1106: Re-qualification of Insulated adaptor system 400/630A up to 24kV according to VDE 0278 Part 6

PPR 787: Qualification of separable plant termination fore paper and polymeric cable up to the voltage class 12.7/22(24)kV

PPR 865

Long term testing of RICS adaptor on ANSI/IEEE-386 Bushing profile and on 630A HN 52-S61 and DIN 47636 Bushing

Tests carried out

Tested according to CENELEC HD 629.1 S21 (2006-02), VDE 0278 Part 6, ANSI/IEEE-386.

Marking of product

Raychem – RICS no – Voltage class – Batch no.

Periodical assessment

The scope of the Periodical assessment is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)




Certificate No: **E-13892**
File No: **828.20**
Job Id: **262.1-009445-2**


- Check results from Production Sample Tests (PST) and Routine tests (RT). If test reports are not available, tests according to PST and RT shall be carried out
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensure traceability between manufacturer's product type marking and Type Approval Certificate.

Survey to be performed at least every second year.

END OF CERTIFICATE

ДИПЛОМ
ОПРЕДЕЛЕНИЕ





Test Report

PPR 1106

Requalification
of Insulated Adaptor System
400 / 630 A up to 24 kV
according to
VDE 0278 Part 6

Type: RICS

Pages: 16

Appendices: 2

Date: 27.09.94

Tested by: Ernst Liegl

Signature:

Date: 27.09.94

Prepared by: Ernst Liegl

Signature:

Date: 27.09.94

Approved by: Thomas Escherich

Signature:


Date: 29.9.94

© Raychem Reports may only be used in their original form

Raychem

Raychem GmbH
Electrical Products Division
Haidgraben 6
D-85521 Ottobrunn
Munich, Germany
Tel. (089) 6089-0
Fax (089) 6096345
(re-order point)

RECEIVED
DATE 27.09.94
BY [illegible]



PPR 1106

Test Object: Insulated Adaptor System Type RICS for outer cone connection (DIN 47636 Part 5).

Date: 26. September 1994

Requirements: DIN VDE 0278 Part 6/2.91 and Part 1/2.91

Conclusion: The insulated Adaptors RICS 5133 400 / 630 A 24 kV, have passed the test according to DIN VDE 0278 Part 6/2.91

Manufacturer: Raychem GmbH
Electrical Products Division
Haldgraben 6
D-85521 Ottobrunn

Location of Test: Raychem Ottobrunn
EPM Testfield, Munich

Test Purpose: Requalification



**ВЯРНО С
ОРИГИНАЛА**

PPR 1106

Preparation of Test Objects:

Preparation

The Raychem Terminations EPKT 24C1X1 were installed according to the enclosed Raychem installation instruction EPP 0275 8/92. According to EPP 0271 9/93, the sheds provided with the termination kit, were not installed.

The insulated Adaptors RICS 5133 were installed according to the enclosed Raychem installation instruction EPP 0271 9/93 and connected to a bushing (DIN 47636 Part 5).

Number of samples: 4
Cables: XLPE Insulated Al-cable
NA2XS2Y 150 mm² 24 kV
Cable Length: Approx. 2,5 m

Test: Test according to DIN VDE 0278:
VDE Specifications for Power Cable Accessories, with rated voltages U up to 30 kV (U_m up to 36 kV).
Part 1/2.91 "Requirements and Test Procedures",
Part 6/2.91 "Plug-in Type or Screw-Type Encapsulated Cable Connections above 1 kV (U_m > 1.1 kV)".



**ВЯРНО С
ОРИГИНАЛА**

A handwritten signature in black ink, appearing to be a stylized 'R' or similar character.

PPR 1106

Test procedure and results according to VDE 0278 Part 6 :

Test No.	Type of Test	described in VDE 0278 Part 1 Section	Page
1	A.C. Voltage Test 50 kV, 50 Hz, 1 min.	3.1	5
2	Partial Discharge Test (pC) at 24 kV	3.6	6
3	Nominal Impulse Voltage Withstand Test, 10 pulses each of positive and negative polarity, 125 kV	3.3	8
4	Continuous A.C. Voltage Test with cyclic current loads; 30 kV, 483 A, 2 load cycles	3.5	10
5	Test of detachability, 5 times	3.17	10
6	Continuous A.C. Voltage Test, same as 4, but 1 load cycle	3.5	10
7	Partial Discharge, same as 2	3.6	11
8	Continuous A.C. Voltage Test, same as 4, but 60 load cycles	3.5	11
9	Thermal Short-Circuit Test, 17,8 kA/1 sec (6 load applications)	3.7	12
10	Test of detachability, 5 times	3.17	12
11	Continuous A.C. Voltage Test, same as 4, but 54 load cycles	3.5	13
12	Partial Discharge Test, same as 2	3.6	13
13	Tightness Test with cyclic current loads, 483 A, 9 load cycles	3.11.2	14
14	Nominal Impulse Voltage Withstand Test, same as 3	3.3	14
15	D.C. Voltage Test 96 kV, 30 min.	3.2	15



ВЯРНО С
ОРИГИНАЛА

PPR 1106




Photo of a Test Specimen

4



ВЪРНО С
ОРИГИНАЛА

1. A.C. Voltage Test according to Section 3.1


An effectively sinusoidal a.c. voltage of $50 \text{ kV}_{\text{rms}}$, 50 Hz was applied between the conductor and the grounded screen for 1 min.

The voltage was continuously increased within 10 seconds to the specified value and was then held constant during the required duration of the test.

relative humidity of air	atmospheric pressure	temperature
43%	1016 mbar	24°C

Result

No breakdown occurred on any of the test loops.



- ST = Regulating Transformer
- HT = High-Voltage Transformer
- P = Test Specimen
- SW = Measuring Transformer
- M = Voltage Measuring Instrument

Fig. 2 Connection Diagram for A.C. Voltage Test



**ВАРЪД С
ОРИГИНАЛА**

2. Partial Discharge Test according to Section 3.6

Test connection, coupling quadripole series connected with test loops (see Fig. 3).




Fig. 3 Connection Diagram for Partial Discharge Test

- T_r : High-Voltage Source
- U : High-Voltage Measuring System
- Z : Impedance
- Z_A : Coupling Quadripole
- C_p : Test Specimen
- C_k : Coupling Capacitor
- D : Detector
- Q : Calibrating Unit



**ВАЖНО С
ОРИГИНАЛА**

Performance of Test

The bushings were made corona-free by using ball electrodes, and an a.c. test voltage of 28.8 kV was applied for 1 min.

Then the voltage was decreased to the a.c. test voltage $U_{PD} = 24$ kV, and within 1 minute the maximum value of the partial discharge magnitude was measured.

relative humidity of air	atmospheric pressure	temperature
43 %	1016 mbar	24°C

Result of Partial Discharge Test

Test Loop No.	Partial Discharge (pC)
1	< 5
2	< 5
3	< 5
4	< 5

Admissible Partial Discharge Magnitude: 20 pC



**ВЯРНО С
ОРИГИНАЛА**


3. Nominal Impulse Voltage Withstand Test according to Section 3.3

The test was performed with an impulse voltage of which the rise time was approx. $1.2 \mu\text{s}$ and the half-value decay time was approx. $50 \mu\text{s}$.

The test loops were exposed to 10 impulses each of an impulse voltage of 125 kV of positive and negative polarity between the conductor and the grounded screen.

Subsequently the equivalent connection diagram of the impulse voltage circuit is shown (see Fig. 4).

Fig. 4 Test with Impulse Voltage
Schematic Equivalent Diagram of the Impulse Circuit



- C_s = Impulse Capacity
- F = Spark Gap Discharger
- R_e = Discharge Resistor
- L = Impulse Circuit Inductive Resistor
- R_d = Damping Resistor
- P_r = Test Specimen
- T = Impulse Voltage Divider
- M = Impulse Voltage Measuring Instrument



**ВЪРНО С
ПОТВЕРЖЕНИЕ**

PPR 1106



relative humidity of air	atmospheric pressure	temperature
43 %	1016 mbar	24°C

Result

No breakdown occurred on any of the test loops.

The following impulse oscillograms of the Test Loop No. 1 do not show any discrepancy from the calibration oscillogram.

The oscillograms of the Test Loops No. 2 to 4 were identical to that of Test Loop No. 1.



**ВАРНО С
ОРИГИНАЛА**

4. Continuous A.C. Voltage Test with Cyclic Current Load according to Section 3.5

The test loops, suspended free in the air, according to DIN VDE 0278 Part 1/2.91 Section 3.5a, were subjected to 2 load cycles with a continuously applied a.c. test voltage of 30 kV. Each load cycle consisted of a 5 hours' load period and a 3 hours' cooling-down period.

The current was calculated with the conversion factor 1.33 (according to DIN VDE 0278 Part 1/2.91 Table 1 Page 3 and DIN VDE 0298 Part 2 Draft 7.90 Table 12 Column 8), it amounted to 483 A at a conductor temperature of 95°C.

Ambient temperature during the load cycles: approx. 20°C.

Result

No breakdown occurred on any of the test loops.

5. Test of Detachability according to Section 3.17

The adaptors were disconnected and connected 5 times.

6. Continuous A.C. Voltage Test with Cyclic Current Load according to Section 3.5

Same as Test No. 4, but one load cycle only.

Result

No breakdown occurred on any of the test loops.



**ВЯРНО С
ОРИГИНАЛА**

7. Partial Discharge Test according to Section 3.6

After the 3rd load cycle the Partial Discharge Test as per Test No. 2 was repeated.

relative humidity of air	atmospheric pressure	temperature
56 %	1017 mbar	25°C

Result of Partial Discharge Test

Test Loop No.	Partial Discharge (pC)
1	< 5
2	< 5
3	< 5
4	< 5

Admissible Partial Discharge Magnitude: 20 pC

8. Continuous A.C. Voltage Test with Cyclic Current Load according to Section 3.5

Same as Test No. 4, but 60 load cycles

Result


No breakdown occurred on any of the test loops.



**ВЯРНО С
ОРИГИНАЛА**

9. Thermal Short Circuit Test according to Section 3.7

The thermally equivalent short circuit current during one second according to DIN VDE 0278 Part 1/2.91 Table 2 Is: 17.8 kA. This short circuit load application was repeated five times, each time after the conductor had cooled down to ambient temperature. (Ambient temperature 20°C).



Result

The oscillograms of the test loops No. 2 to 4 were identical to that of test loop No. 1. A visual check did not show any deterioration on the test loops.

10. Test of Detachability according to Section 3.17

Same as Test No. 5.



ВЯРНО С
ОРИГИНАЛА

11. Continuous A.C. Voltage Test with Cyclic Current Load according to Section 3.5

Same as Test No. 3, but 54 load cycles.

Result

No breakdown occurred on any of the test loops.

12. Partial Discharge Test according to Section 3.6

After the 117th load cycle the Partial Discharge Test as per Test No. 2 was repeated.

relative humidity of air	atmospheric pressure	temperature
45 %	1029 mbar	29°C

Result of Partial Discharge Test

Test Loop No.	Partial Discharge (pC)
1	< 5
2	< 5
3	< 5
4	< 5

Admissible Partial Discharge Magnitude: 20 pC



**ВЯРНО С
ОРИГИНАЛА**

13. Tightness Test according to Section 3.11.2 with Cyclic Current Load according to Section 3.4

The test loops were arranged in a water-filled tank in such a way that the cable plug was submerged in the water.

Arranged in this way they were exposed to 9 load cycles according to Section 3.4.

14. Nominal Impulse Voltage Withstand Test according to Section 3.3

Same as Test No. 3.

relative humidity of air	atmospheric pressure	temperature
45 %	1024 mbar	28°C

Result

No breakdown occurred on any of the test loops.



The following impulse oscillograms of the Test Loop No. 1 do not show any discrepancy from the calibration oscillogram.

The oscillograms of the Test Loops No. 2 to 4 were identical to that of Test Loop No. 1.



**ВЯРНО С
ОРИГИНАЛА**

PPR 1106



15.

D.C. Voltage Test according to Section 3.2

The test loops were subjected to a d.c. voltage of 96 kV for 30 minutes.

The a.c. voltage content of the d.c. voltage amounted to approx. 3%.


Result

No breakdown occurred on any of the test loops.

15

ВЯРНО С
ОРИГИНАЛА





Test Report

PPR 866

Qualification of RICS
Double-T-Adaptor
630 A, 24 kV
according to PPS 3013

Pages: 4 Appendices: 1

Prepared by:
Johanna Wachter

Signature:
Johanna Wachter

Approved by:
Stephen Hey

Signature:
S. Hey

Date:
3. 11. 1989

© Raychem Report may only be used unchanged

Raychem

**ВЯРНО С
ОРИГИНАЛА**




Introduction

This report gives qualification details of the RICS-Double-T-Adaptor system with two cables per phase for 630 A bushings with profiles according to DIN 47636 (Figure 1). The test sequence is detailed on page 3 and is based on the Raychem Master Specification PPS 3013. This latter specification contains more detailed test information.

The cables used were single-core 24 kV, 150 mm², aluminium stranded conductors, with cross-linked polyethylene insulation. RICS 5733 + RICS 5137 were installed according to Installation Instruction EPP 0280 7/89 (Appendix I). The cables were terminated with EPKT 24C1XI. The 3 RICS-Double-T-Adaptor were installed with a minimum phase spacing of 90 mm and minimum distance to earth of 25 mm.

The location of parts in completed Double-T-Adaptor are shown in Fig. 3.

Figure 1: Bushing Profile



ВЯРНО С
ОРИГИНАЛА



Test Sequence

Test	Method	Conditions	Requirement
A.C. Voltage Withstand	IEC 60	55 kV for 1 minute	No breakdown and no flashover
Partial Discharge	IEC 270	15 kV 24 kV	< 3 pC <20 pC
Impulse Voltage Withstand	IEC 60 IEC 230	125 kVp 10 positive and 10 negative 1.2/50 μ S	No breakdown and no flashover
Load Cycling	VDE 0278	63 load cycles (5h/3h) 565 Amps, 30 kV max. cable conductor temp. 95°C to VDE	No breakdown and no flashover
Partial Discharge	IEC 270	as above	
Thermal Short Circuit* (Fig. 2)	VDE 0278	17.4 kA per cable two 1 sec shots	
Load Cycling	VDE 0278	as above	
Partial Discharge	IEC 270	as above	
A.C. Voltage Withstand	IEC 60	48 kV for 4 hours	No breakdown and no flashover
Impulse Voltage Withstand	IEC 60 IEC 230	as above	
D.C. Voltage Withstand	IEC 60	96 kV for 30 minutes	No breakdown and no flashover
Humidity	IEC 466 VDE 0278	100 h at 15 kV water conductivity 800 μ S/cm	No breakdown No flashover No visible tracking
Submersion Test	Load Cycling under water	100 hours 15 kV, 565 Amps	No breakdown

*Thermal short circuit tests performed at EPM, Independent Test Laboratory, Munich.


Conclusion

The three Double-T-Adaptors, each with two cables per phase, successfully completed the test sequence.





ОРИГИНАЛ

Figure 3: Location of parts in completed Double-T-Adaptor






Test-No. 1076200



ВЫНОС
ОРИГИНАЛ




Test-No. 1076201




БАЗИД С
ОПТИМАЛНА

Test-No. 2074195



ВАЖНО С
ОПТИМАЛНА

Test-No. 2074196



ВАЖНО С
ОРИГИНАЛА





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване


тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg


Списък на проведените изпитвания на щепселна кабелна глава, права/адаптор/ тип RSSS

1. Изпитване издръжливост с постоянно напрежение;
2. Изпитване издръжливост с променливо напрежение;
3. Изпитване частичен разряд при околна температура;
4. Изпитване импулсно напрежение при околна температура;
5. Изпитване циклично електрическо нагряване във въздух;
6. Изпитване циклично електрическо нагряване във вода;
7. Изпитване комутация/включване/изключване;
8. Изпитване частичен разряд при околна температура;

13.01.2016г.

Подпис и печат





PPR-2527

**Test Report of
screened seperable
cable connector for
single-core cables with
extruded plastic
insulation
Type: RSES-52xx-R**

Tested by: IPH Berlin

Date: 01. April 2008

Pages: 66

Appendix: —

Tyco Electronics Raychem GmbH
Energy Division
Finsinger Feld 1
D-85521 Ottobrunn
Munich, Germany
Tel.: +49-89-6089-0
Fax: +49-89-6096-345
<http://energy.tycoelectronics.com>

© Raychem Reports may only be used in their original form

ВАЖНО С
ОПРЕДЕЛЕНА



Tyco Electronics
Our commitment. Your advantage.

Energy Division