

Testing laboratory for climatic, mechanical
and corrosive environmental stress



Deutsche
Akkreditierungsstelle
D-PL-19102-01-00

CERTIFICATE of QUALITY TEST

Test report No. 10220.01 / 13

Client	Siemens AG IC SG EA PRO D 6 2 Wernerwerkdam 5 13629 Berlin	
Equipment under test	Protection Relay specimen 1	Overcurrent Protection 7SJ663 $\frac{1}{2}$ of 19" for panel flush mounting
	Protection Relay specimen 2	Overcurrent Protection 7SJ662 $\frac{1}{3}$ of 19" for panel flush mounting
Purpose	Test of the climatic resistance and of the operability according to the standards and to the demands of the client	
Test program	Cold according to IEC 60068-2-1 and IEC 60255-1 Heating according to IEC 60068-2-2 and IEC 60255-27 Dry heat according to IEC 60068-2-2 and IEC 60255-1 Slow temperature change according to IEC 60068-2-14 and IEC 60255-1 Damp heat; cyclic according to IEC 60068-2-30 and IEC 60255-1 Cold according to IEC 60068-2-1 and IEC 60255-1 Dry heat according to IEC 60068-2-2 and IEC 60255-1 Fast temperature change according to IEC 60068-2-14 and IEC 60255-1	
Test period	12 November 2013 to 7 January 2014	
Realization / results	see page 2 to 5	
Total number of pages	11 pages (including 2 appendices)	
Test result	The tests of the climatic resistance and of the operability were realized according to the test program. Neither damages nor noticeable problems were determined. <u>The further evaluation will be done by the client.</u>	

На основание чл.36а ал.3 от ЗОП

AUCOTEAM GmbH
Storkower Str. 115a
10407 Berlin
Tel.: 030 42188-0
Fax: 030 4232709
www.aucoteam.de

Amtsgericht Berlin Charlottenburg HRB 38393
USt-ID-Nr. DE 137 190 620
Geschäftsführer:
Dipl.-Ing. Bernd Rhiemer
Dipl.-Ing. Werner Zuchhold

BIC BEVODEBB
IBAN DE56 1007 0000 6201 8410 78
Commerzbank AG
BIC DRESDEFF100
IBAN DE53 1008 0000 0400 4292 00



1 Purpose

Test of the climatic resistance and of the operability according to the standards and to the demands of the client.

2 Equipment under test (EUT)

Protection Relay	Overcurrent Protection 7SJ663
specimen 1	Prototype 020
model	1/2 of 19" for panel flush mounting
MLFB	7SJ6632-5KB90-3RH7-L0R/BB
Firmware	V04.00.03
DIGSI-Software	V4.88

Module in Device 7SJ663

1. Display Board with the serial Number 600000 245043
2. Current / Voltage input Board M102/3/6 - 2 with the serial Number 600000 245123
3. Power supply Board PS BO OB – 230 AC with the serial Number CB1311000174
4. BIO Board with the serial Number 600000 208677
5. BIO Board with the serial Number 600000 208676
6. CPU Board with the serial Number 600000 245060
7. ETH Board with the serial Number 600000 238963
8. BIO Board with the serial Number 600000 255772

Settings in Device 7SJ663

1. Overcurrent \geq 10 %; configured to LED 1
2. Overvoltage \geq 10 %; configured to LED 2
3. Undervoltage \leq 10 %; configured to LED 3
4. Binary Input (BI): BI 1; BI3 – BI13; BI15 – BI25; BI27 – BI36 high active
5. BI2; BI 14; BI 26 low active
6. Binary Output (BO) BO4; BO6; BO7 are supervised

Protection Relay	Overcurrent Protection 7SJ663
specimen 2	Prototype 009
model	1/3 of 19" for panel flush mounting
MLFB	7SJ6621-5KB90-3HG7-L0D/BB
Firmware	V04.00.03
DIGSI-Software	V4.88


Module in Device 7SJ662

1. Display Board with the serial Number 600000 254760
2. Current / Voltage input Board M102/3/6 - 2 with the serial Number 000 245116
3. Power Supply Board PS BO OB – 230 AC with the serial Number CB1311000175
4. EXT. BIO Board with the serial Number 600000 255789
5. BI Board with the serial Number 600000 245100
6. CPU Board with the serial Number 600000 245053
7. ETH Board with the serial Number 600000 049730

Settings in Device 7SJ662

1. Overcurrent \geq 10 %; configured to LED 1
2. Overvoltage \geq 10 %; configured to LED 2
3. Undervoltage \leq 10 %; configured to LED 3
4. Binary Input (BI): BI 1; BI3 – BI8; BI10 – BI17; BI19 – BI21 high active
5. BI2; BI9; BI 18 low active
6. Binary Output (BO): BO4; BO6; BO7 are supervised

delivery date of the EUT 11 November 2013



3 Basics

3.1 Demands of the client

3.2 Used standards

IEC 60068-1:1988 + Corr. 1988 + A1:1992	DIN EN 60068-1:1995-03 „Environmental testing - Part 1: General and guidance“
IEC 60068-2-1:2007	DIN EN 60068-2-1; VDE 0468-2-1:2008-01 „Environmental testing - Part 2-1: Tests - Test A: Cold“
IEC 60068-2-2:2007	DIN EN 60068-2-2; VDE 0468-2-2:2008-05 „Environmental testing - Part 2-2: Tests - Test B: Dry heat“
IEC 60068-2-14:2009	DIN EN 60068-2-14; VDE 0468-2-14:2010-04 „Environmental testing - Part 2-14: Tests - Test N: Change of temperature“
IEC 60068-2-30:2005	DIN EN 60068-2-30:2006-06 „Environmental testing - Part 2-30: Tests - Test Db: Damp heat, cyclic (12 h + 12 h cycle)“
IEC 60068-3-1:2011	DIN EN 60068-3-1; VDE 0468-3-1:2012-04 „Environmental testing - Part 3-1: Supporting documentation and guidance - Cold and dry heat tests“
IEC 60255-1:2010	DIN EN 60255-1; VDE 0435-300:2010-09 „Measuring relays and protection equipment - Part 1: Common requirements“

4 Test program

4.1 Cold – test Ad

according to IEC 60068 -2-1 and IEC 60255-1

specimens	operating with measurements AC 57 V; 1.0 A and 50 Hz connected test equipment of the client
test temperature	(- 20 ± 3)°C
test duration	96:00 h
temperature rate	1.00 K/min

After the test, the specimens shall be stored at standard conditions (+20 ° C, 30% relative humidity)
for at least 2:00 h.

4.2 Heating – Dry heat – test B

according to IEC 60068 -2-2 and IEC 60255-1

specimens	operating with measurements AC 57 V; 1.0 A and 50 Hz connected test equipment of the client
test temperature	(+55 ± 2)°C
test duration	96:00 h
temperature rate	1.00 K/min


After the test, the specimens shall be stored at standard conditions (+20 ° C, 30% relative humidity)
for at least 2:00 h.

4.3 Dry heat – test Bd

according to IEC 60068 -2-2 and IEC 60255-1

specimens	operating with measurements AC 57 V; 1.0 A and 50 Hz connected test equipment of the client
test temperature	(+70 ± 2)°C
test duration	96:00 h
temperature rate	1.00 K/min

After the test, the specimens shall be stored at standard conditions (+20 ° C, 30% relative humidity)
for at least 2:00 h.



4.4 Slow temperature change – test Nb

according to IEC 60068 -2-14 and IEC 60255-1

specimens	operating with measurements AC 57 V; 1.0 A and 50 Hz connected test equipment of the client
lower test temperature	(- 25 ± 3)°C
upper test temperature	(+70 ± 2)°C
storage time	each 12:00 h
changover time	each 5:00 h (20 K/h)
test duration	170:00 h (5 cycles, each 34:00 h)

After the test, the specimens shall be stored at standard conditions (+20 ° C, 30% relative humidity) for at least 2:00 h.

4.5 Damp heat, cyclic – test Db

according to IEC 60068-2-30 and IEC 60255-1

specimens	operating with measurements AC 57 V; 1.0 A and 50 Hz connected test equipment of the client
lower test temperature	(+ 25 ± 3)°C
relative humidity	(97 ± 3) %
upper test temperature	(+55 ± 2)°C
relative humidity	(93 ± 3) %
storage time	each 9:00 h
changover time	each 3:00 h (0,17 K/min)
test duration	144:00 h (6 cycles, each 24:00 h)

After the test, the specimens shall be stored at standard conditions (+20 ° C, 30% relative humidity) for at least 2:00 h.

4.6 Cold – test Ad

according to IEC 60068 -2-1 and IEC 60255-1

specimens	not operating
test temperature	(- 40 ± 3)°C
test duration	96:00 h
temperature rate	1.00 K/min

After the test, the specimens shall be stored at standard conditions (+20 ° C, 30% relative humidity) for at least 2:00 h.

4.7 Dry heat – test Bd

according to IEC 60068 -2-2 and IEC 60255-1

specimens	operating with measurements AC 57 V; 1.0 A and 50 Hz connected test equipment of the client
test temperature	(+85 ± 2)°C
test duration	16:00 h
temperature rate	1.00 K/min


After the test, the specimens shall be stored at standard conditions (+20 ° C, 30% relative humidity) for at least 2:00 h.

4.8 Fast temperature change – test Na

according to IEC 60068 -2-14 and IEC 60255-1

specimens	not operating
lower test temperature	(- 25 ± 3)°C
upper test temperature	(+70 ± 2)°C
storage time	each 2:00 h
changover time	each < 10 s
test duration	240:00 h (60 cycles, each 4:00 h)

After the test, the specimens shall be stored at standard conditions (+20 ° C, 30% relative humidity) for at least 2:00 h.



5 Realization

The environmental tests were carried out one by one according to the program of testing methods (complex 4.1 to 4.8), according to the standards and to the demands of the client. The tests were realized one by one according to the test sequence.

Visual inspection

Before and after each single test, each specimen was examined visually for cracks, breaks, distortions, mechanical and thermal damages.

Functional test

Before, partly during and after the test, a functional test was realized.

Measuring and test equipment

climatic chamber 4 KPK 400 (SN: 010/90, Feutron)
temperature shock chamber 66 VT7012 (SN: 58566159610010, Vötsch)
power supply DC EA-PSI 8160-05R (SN: 1231540004, EA)

Test equipment provided by the client

Laptop Siemens Nixdorf; Type Scenic Mobile 700; Inv No. 6500 0133
Omicron; Type CMC 156; Inv. No 6500 0103
Siemens Multizet S; Inv. No. G330168
Siemens Multizet S; Inv. No. 211051
Relay Contact Supervision; Type Siemens 09.2012
Programmable Power Supply; Type EA-PS 18160-04R; Inv. No. 0590

6 Results

During and after the climatic tests of the

Protection Relay Overcurrent Protection 7SJ663 (Prototype 020) and Protection Relay Overcurrent Protection 7SJ662 (Prototype 009) with

- **Cold** (- 20°C, 96 h operating) - **Test Ad**
- **Dry heat** (+55°C, 96 h operating) - **Test B**
- **Dry heat** (+70°C, 96 h operating) - **Test Bd**
- **Slow temperature change** (- 25°C / +70°C, 5 x 34 h operating) - **Test Nb**
- **Damp heat, cyclic** (+25°C, 97 % r. h. / +55°C, 97 % r. h. 6 x 24 h operating) - **Test Db**
- **Cold** (- 40°C, 96 h not operating) - **Test Ad**
- **Dry heat** (+85°C, 96 h operating) - **Test Bd**
- **Fast temperature change** (- 25°C / +70°C, 60 x 4 h not operating) - **Test Na**

neither cracks, breaks, distortions nor any other thermal damages were determined.

The operability of both specimens was ensured at any time before, during and after each test.


The tests of the climatic resistance and of the operability were realized according to the test program.

Neither damages nor noticeable problems were determined.


The further evaluation will be done by the client.

The results of the test only refer to the above mentioned equipment under test. The report or individual pages of this testing report may only be copied following the written consent of the testing laboratory. This testing report-No. 10220.01 / 13 includes 5 pages and appendix 1 to 2.

appendix 1 - climatic protocols
appendix 2 - pictures




000334



Temperature behavior of climatic test chamber KPK 4 during the tests with dry heat and cold

000335


Appendix 1 to test report-No. 10220.01 / 13 page 2 / 5



Temperature behavior of climatic test chamber KPK 4 during the test with slow temperature change




000336



Climatic behavior of climatic test chamber KPK 4 during the tests with damp heat cyclic

БЯРНО С
София
оригинал


23.12.2013
MIG 23 12.2013
000337




Temperature behavior of climatic test chamber KPK 4 during the tests with dry heat and cold

ВЯРНОСТЬ
ОРИГИНАЛА

000338




Appendix 1 to test report-No. 10220.01 / 13 page 5 / 5




Temperature behavior of temperature shock chamber during the test with fast temperature change

ВЯРНОСТ
ОРИГИНАЛА




000339

Pictures




picture 1

**Protection Relay Overcurrent Protection 7SJ663
and Overcurrent Protection 7SJ662
in climatic chamber KPK 4
during the climatic tests**




picture 2

**Protection Relay Overcurrent Protection 7SJ663
and Overcurrent Protection 7SJ662
in climatic chamber KPK 4
during the climatic tests**



picture 3


**Protection Relay Overcurrent Protection 7SJ663
and Overcurrent Protection 7SJ662
in temperature shock chamber TSS 66
during the temperature shock test**



picture 4

**Protection Relay Overcurrent Protection 7SJ663
and Overcurrent Protection 7SJ662
in temperature shock chamber TSS 66
during the temperature shock test**

Cm



Testing laboratory for climatic, mechanical
and corrosive environmental stress



Deutsche
Akreditierungsstelle
D-PL-19102-01-00

CERTIFICATE of QUALITY TEST

Test report No. 10220.02 / 13

Client	Siemens AG IC SG EA PRO D 6 2 Wernerwerkdam 5 13629 Berlin	
Equipment under test	Protection Relay specimen 3	Overcurrent Protection 7SJ663 $\frac{1}{2}$ of 19" for panel flush mounting
	Protection Relay specimen 4	Overcurrent Protection 7SJ662 $\frac{1}{3}$ of 19" for panel flush mounting
Purpose	<i>Test of the climatic resistance and of the operability according to the standards and to the demands of the client</i>	
Test program	Damp heat, steady state according to IEC 60068-2-78 and IEC 60255-1	
Test period	11 November 2013 to 7 January 2014	
Realization / results	see page 2 to 3	
Total number of pages	5 pages (including 2 appendices)	
Test result	The tests of the climatic resistance and of the operability were realized according to the test program. Neither damages nor noticeable problems were determined. The further evaluation will be done by the client.	

На основание чл.36а ал.3 от
ЗОП

На основание чл.36а ал.3 от
ЗОП

Ab
Storkower Str. 115a
10407 Berlin
Tel. 030 42188-0
Fax 030 4232709
www.aucoteam.de

Gesellschaft: Berlin Charlottenburg HRB 38393
Amtsgericht Berlin Charlottenburg USt-ID-Nr. DE 137 190 620
Geschäftsführer:
Dipl.-Ing. Bernd Rühmeyer
Dipl.-Ing. Werner Zuchhold

Berliner Volksbank
BLZ 100 600 600
IBAN DE56 1009 0000 0100 8411 38
Correkt Bank AG
UIC: DRESDEN 100
IBAN DE55 1008 0000 0400 4292 00

ОБЩЕСТВО С ОГРАНИЧЕННОЙ
ОТВЕТСТВЕННОСТЬЮ
СОФИЯ
УКРАЇНА
MIG 23 0000341

1 Purpose

Test of the climatic resistance and of the operability according to the standards and to the demands of the client.

2 Equipment under test (EUT)

Protection Relay	Overcurrent Protection 7SJ663
specimen 3	Prototype 021
model	1/2 of 19" for panel flush mounting
MLFB	7SJ6632-5KB90-3RH7-L0R/BB
Firmware	V04.00.03
DIGSI-Software	V4.88

Module in Device 7SJ663

1. Display Board with the serial Number 600000 245043
2. Current / Voltage input Board M102/3/6 - 2 with the serial Number 600000 245123
3. Power supply Board PS BO OB – 230 AC with the serial Number CB1311000174
4. BIO Board with the serial Number 600000 208677
5. BIO Board with the serial Number 600000 208676
6. CPU Board with the serial Number 600000 245060
7. ETH Board with the serial Number 600000 238963
8. BIO Board with the serial Number 600000 255772

Settings in Device 7SJ663

1. Overcurrent \geq 10 %; configured to LED 1
2. Overvoltage \geq 10 %; configured to LED 2
3. Undervoltage \leq 10 %; configured to LED 3
4. Binary Input (BI): BI 1; BI3 – BI13; BI15 – BI25; BI27 – BI36 high active
5. BI2; BI 14; BI 26 low active
6. Binary Output (BO) BO4; BO6; BO7 are supervised

Protection Relay	Overcurrent Protection 7SJ663
specimen 4	Prototype 008
model	1/3 of 19" for panel flush mounting
MLFB	7SJ6621-5KB90-3HG7-L0D/BB
Firmware	V04.00.03
DIGSI-Software	V4.88


Module in Device 7SJ662

1. Display Board with the serial Number 600000 254760
2. Current / Voltage input Board M102/3/6 - 2 with the serial Number 000 245116
3. Power Supply Board PS BO OB – 230 AC with the serial Number CB1311000175
4. EXT. BIO Board with the serial Number 600000 255789
5. BI Board with the serial Number 600000 245100
6. CPU Board with the serial Number 600000 245053
7. ETH Board with the serial Number 600000 049730

Settings in Device 7SJ662

1. Overcurrent \geq 10 %; configured to LED 1
2. Overvoltage \geq 10 %; configured to LED 2
3. Undervoltage \leq 10 %; configured to LED 3
4. Binary Input (BI): BI 1; BI3 – BI8; BI10 – BI17; BI19 – BI21 high active
5. BI2; BI9; BI 18 low active
6. Binary Output (BO): BO4; BO6; BO7 are supervised

delivery date of the EUT 11 November 2013



000342

3 **Basics**

3.1 **Demands of the client**

3.2 **Used standards**

IEC 60068-1:1988 + Corr. 1988 + A1:1992	DIN EN 60068-1:1995-03 „Environmental testing - Part 1: General and guidance“
IEC 60068-2-78:2001	DIN EN 60068-2-78:2002-09 „Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state“
IEC 60255-1:2010	DIN EN 60255-1; VDE 0435-300:2010-09 „Measuring relays and protection equipment - Part 1: Common requirements“

4 **Test program**

Damp heat, steady state – test Cab

according to IEC 60068-2-78 and IEC 60255-1

specimens operating with measurements AC 57 V; 1.0 A and 50 Hz
connected test equipment of the client

test temperature $(+40 \pm 2)^\circ\text{C}$

relative humidity $(93 \pm 3) \%$

test duration 1344:00 h (56 d)

temperature rate 1.00 K/min

After the test, the specimens shall be stored at standard conditions ($+20^\circ\text{C}$, 30% relative humidity)
for at least 2:00 h.

5 **Realization**

The environmental test was carried out one by one according to the program of testing methods (complex 4), according to the standards and to the demands of the client.

The test was realized one by one according to the test sequence.

Visual inspection

Before and after the test, each specimen was examined visually for cracks, breaks, distortions, mechanical and thermal damages.

Functional test

Before, during and after the test, a functional test was realized.

Measuring and test equipment

climatic chamber 1 KPK 600 (SN: 132/90, Feutron)

Test equipment of the client

Bremer-Transformator; Type BV 26929; Inv-No P.203855

Omicron; Type CMC 156; Inv. No 6500 0103

6 **Results**

During and after the climatic tests of the

Protection Relay Overcurrent Protection 7SJ663 (Prototype 021) and

Protection Relay Overcurrent Protection 7SJ662 (Prototype 008) with

- Damp heat, steady state ($+40^\circ\text{C}$, 93 % r. h. 1344 h operating)

- Test Cab

neither cracks, breaks, distortions nor any other thermal damages were determined.


The operability of both specimens was ensured at any time before, during and after each test.

**The tests of the climatic resistance and of the operability
were realized according to the test program.**


Neither damages nor noticeable problems were determined.

The further evaluation will be done by the client.

The results of the test only refer to the above mentioned equipment under test. The report or individual pages of this testing report may only be copied following the written consent of the testing laboratory.
This testing report-No. 10220.02 / 13 includes 3 pages and appendix 1 to 2
appendix 1 - climatic protocols
appendix 2 - pictures



Appendix 1 to test report-No. 10220.02 / 13 page 1 / 1




Climatic behavior of climatic test chamber KPK 1 during the tests with damp heat,
steady state

ВЯРНОС
ОФИЦИАЛА


23.03.2013
MIG 23 LTD
София
000344

Pictures




picture 1

Protection Relay Overcurrent Protection 7SJ663
and Overcurrent Protection 7SJ662
in climatic chamber KPK 1 with test equipment
during the climatic test




picture 2

Protection Relay Overcurrent Protection 7SJ663
and Overcurrent Protection 7SJ662
in climatic chamber KPK 1
during the climatic test



picture 3

Protection Relay Overcurrent Protection 7SJ663
with test equipment of the client
during the final functional test



picture 4

Protection Relay Overcurrent Protection 7SJ6632
with test equipment of the client
during the final functional test



000345

Testing laboratory for climatic, mechanical
and corrosive environmental stress



CERTIFICATE of QUALITY TEST

Deutsche
Akreditierungsstelle
D-PL-19102-01-00

Test report - No. 10220.03 / 13



Client	Siemens AG Infrastructure & Cities Sector IC SG EA PRO D 6 2 Wernerwerkdam 5 13629 Berlin	
Equipment under test	Protection Relay specimen 7 and 9	Overcurrent Protection 7SJ663 $\frac{1}{2}$ of 19" for panel flush mounting
	Protection Relay specimen 8 and 10	Overcurrent Protection 7SJ662 $\frac{1}{3}$ of 19" for panel flush mounting
Purpose	Environmental Test of the normal service and transportability	
Test program	Vibration according to IEC 60068-2-6 / IEC 60255-21-1 Shock according to IEC 60068-2-27 / IEC 60255-21-2 Seismic test according to IEC 60068-3-3 / IEC 60255-21-3	
Test period	6 January to 9 January 2014	
Realization / results	see page 2 to 6	
Total number of page	14 (inclusive 2 appendixes)	
Test result	<p>The tests of the normal service and transportability under defined conditions of the Protection Relays were realized according to the standards.</p> <p>Neither damages nor noticeable problems were determined.</p> <p>The further evaluation will be done by the client.</p>	

На основание чл.36а ал.3 от ЗОП

На основание чл.36а ал.3 от ЗОП

AUCOTEAM GmbH
Sorkower Str. 115a
10407 Berlin
tel. 030 42188-0
fax 030 4232709
www.aucoteam.de

Sitz der Gesellschaft: Berlin
Amtsgericht Berlin Charlottenburg HRB 38393
USt-ID-Nr. DE 137 190 620
Geschäftsführer:
Dipl.-Ing. Bernd Klemmeler
Dipl.-Ing. Werner Zomhoff



000346

1 Purpose

Environmental test of the dynamic-mechanical robustness and of the operability of the **Protection Relays** under defined normal service and transport conditions according to the standards.

2 Equipment under test (EUT)

Protection Relay	Overcurrent Protection 7SJ663
specimen 7	Prototype 004
specimen 9	Prototype 027
model	1/2 of 19" for panel flush mounting
MLFB	7SJ6632-5KB90-3RH7-L0R/BB
Firmware	V04.00.03
DIGSI-Software	V4.88

Module in Device 7SJ663

1. Display Board with the serial Number 600000 245043
2. Current / Voltage input Board M102/3/6 - 2 with the serial Number 600000 245123
3. Power supply Board PS BO OB – 230 AC with the serial Number CB1311000174
4. BIO Board with the serial Number 600000 208677
5. BIO Board with the serial Number 600000 208676
6. CPU Board with the serial Number 600000 245060
7. ETH Board with the serial Number 600000 238963
8. BIO Board with the serial Number 600000 255772

Settings in Device 7SJ663

1. Overcurrent \geq 10 %; configured to LED 1
2. Overvoltage \geq 10 %; configured to LED 2
3. Undervoltage \leq 10 %; configured to LED 3
4. Binary Input (BI): BI 1; BI3 – BI13; BI15 – BI25; BI27 – BI36 high active
5. BI2; BI 14; BI 26 low active
6. Binary Output (BO) BO4; BO6; BO7 are supervised

Protection Relay

Overcurrent Protection 7SJ663

specimen 8	Prototype 001
specimen 10	Prototype 002
model	1/3 of 19" for panel flush mounting
MLFB	7SJ6621-5KB90-3HG7-L0D/BB
Firmware	V04.00.03
DIGSI-Software	V4.88

Module in Device 7SJ662


1. Display Board with the serial Number 600000 254760
2. Current / Voltage input Board M102/3/6 - 2 with the serial Number 000 245116
3. Power Supply Board PS BO OB – 230 AC with the serial Number CB1311000175
4. EXT. BIO Board with the serial Number 600000 255789
5. BI Board with the serial Number 600000 245100
6. CPU Board with the serial Number 600000 245053
7. ETH Board with the serial Number 600000 049730

Settings in Device 7SJ662

1. Overcurrent \geq 10 %; configured to LED 1
2. Overvoltage \geq 10 %; configured to LED 2
3. Undervoltage \leq 10 %; configured to LED 3
4. Binary Input (BI): BI 1; BI3 – BI8; BI10 – BI17; BI19 – BI21 high active
5. BI2; BI9; BI 18 low active
6. Binary Output (BO): BO4; BO6; BO7 are supervised

delivery date of the EUT

11 November 2013



000347

3 Basics

3.1 Demands of the client

3.2 Used standards

IEC 60068-2-6:2007
"Environmental testing - Part 2-6
IEC 60068-2-27:2008
"Environmental testing - Part 2-27
IEC 60068-2-47:2005
"Environmental testing - Part 2-47
IEC 60068-3-3 / 1991 and
"Environmental testing -
IEC 60255-21-1 / 1988
IEC 60255-21-2 / 1988
IEC 60255-21-3 / 1993

DIN EN 60068-2-6; VDE 0468-2-6:2008-10
Tests - Test Fc: Vibration (sinusoidal)"
DIN EN 60068-2-27; VDE 0468-2-27:2010-02
Tests - Test Ea and guidance: Shock"
DIN EN 60068-2-47:2006-03
Tests - Mounting of specimens for vibration,
impact and similar dynamic tests"
DIN IEC 60068-3-3 / 09.93
Seismic tests for equipment"
"Electrical relays - Vibration sinusoidal"
"Electrical relays - Shock and bump"
"Electrical relays - Seismic tests"

4 Test program

4.1 Vibration, sinusoidal – test Fc (transport and storage)


according to IEC 60068-2-6 / IEC 60255-21-1, class 2

specimens 7 and 8	non operating
frequency range	5 Hz - 150 Hz
vibration amplitude	± 7.5 mm (below 8 Hz)
acceleration	20 m/s^2 (2 g) (above 8 Hz)
sweep rate	1 octave/min
number of axes	3 (each shifted by 90°)
test duration	10:00 h (20 cycles per axis / 3 x 3:20 h)

4.2 Vibration, sinusoidal – test Fc (stationary use)

according to IEC 60068-2-6 / IEC 60255-21-1, class 2

specimens 7 and 8	operating with measurements AC 57 V; 1.0 A and 50 Hz connected test equipment of the client
frequency range	10 Hz - 150 Hz
vibration amplitude	± 0.075 mm (below 58 Hz)
acceleration	10 m/s^2 (1 g) (above 58 Hz)
sweep rate	1 octave/min
number of axes	3 (each shifted by 90°)
test duration	8:00 h (20 cycles per axis / 3 x 2:40 h)



4.3 Shock, half-sine – test Ea (resistance)

according to IEC 60068-2-27 / IEC 60255-21-2, class 1

specimens 9 and 10	non operating
pulse shape	half-sine
acceleration	150 m/s ² (15 g)
pulse duration	11 ms
number of directions	6 (3 axes, each shifted by 90° and with 2 directions)
test duration	18 shocks (3 shocks per direction)

4.4 Bump, half-sine – test Ea (transport and storage)

according to IEC 60068-2-29 / IEC 60255-21-2, class 1

specimens 9 and 10	non operating
acceleration	100 m/s ² (10 g)
pulse duration	16 ms
number of directions	6 (3 axes, each shifted by 90° and with 2 directions)
test duration	6000 shocks (1000 shocks per direction)

4.5 Shock, half-sine – test Ea (stationary use)

according to IEC 60068-2-27 / IEC 60255-21-2, class 1


specimens 9 and 10	operating with measurements AC 57 V; 1.0 A and 50 Hz connected test equipment of the client
acceleration	50 m/s ² (5 g)
pulse duration	11 ms
number of directions	6 (3 axes, each shifted by 90° and with 2 directions)
test duration	60 shocks (10 shocks per direction)

4.6 Seismic tests – test Fc (stationary use)

according to IEC 60068-3-3 / IEC 60255-21-3, class 2

specimens 9 and 10	operating with measurements AC 57 V; 1.0 A and 50 Hz connected test equipment of the client
frequency range	3 Hz - 35 Hz
crossover frequency	8 Hz - 9 Hz
vibration amplitude /	± 8 mm / 20 m/s ² (2 g) (horizontal axis - X and Z)
acceleration	± 4 mm / 10 m/s ² (1 g) (vertical axis - Y)
sweep rate	1 octave/min
number of axes	3 (each shifted by 90°)
test duration	1:00 h (1 cycle per axis / 3 x 0:20 h)

С
М



000349

5 Realization

The environmental tests were carried out one by one according to the program of testing methods (complex 4.1 to 4.6), according to the standards and to the demands of the client. The tests were performed according to the demands of the client as following:

dynamic-mechanical tests of specimens 7 and 8

vibration, sinusoidal, Y-axis	test Fc (transport and storage)	complex 4.1
vibration, sinusoidal, X-axis	test Fc (transport and storage)	complex 4.1
vibration, sinusoidal, Z-axis	test Fc (transport and storage)	complex 4.1
vibration, sinusoidal, Z-axis	test Fc (stationary use)	complex 4.2
vibration, sinusoidal, X-axis	test Fc (stationary use)	complex 4.2
vibration, sinusoidal, Y-axis	test Fc (stationary use)	complex 4.2

dynamic-mechanical tests of specimens 9 and 10

shock, half-sine, Y-axis	test Ea (resistance)	complex 4.3
bump, half-sine, Y-axis	test Ea (transport and storage)	complex 4.4
shock, half-sine, X-axis	test Ea (resistance)	complex 4.3
bump, half-sine, X-axis	test Ea (transport and storage)	complex 4.4
shock, half-sine, Z-axis	test Ea (resistance)	complex 4.3
bump, half-sine, Z-axis	test Ea (transport and storage)	complex 4.4
shock, half-sine, Z-axis	test Ea (stationary use)	complex 4.5
seismic test, Z-axis	test Fc (stationary use)	complex 4.6
shock, half-sine, X-axis	test Ea (stationary use)	complex 4.5
seismic test, X-axis	test Fc (stationary use)	complex 4.6
shock, half-sine, Y-axis	test Ea (stationary use)	complex 4.5
seismic test, Y-axis	test Fc (stationary use)	complex 4.6

Measuring and test equipment

shaker	TV59335/AIT-440 (SN: 054-09, TIRA)
control channel 1 (vibr. table)	acceleration sensor 353B34 (SN: 86256, PCB)
control channel 2 (test frame)	acceleration sensor 352C34 (SN: 64428, PCB)
measuring channel 3 (specimen 8 / 10)	acceleration sensor 352C22 (SN: LW135715, PCB) – red
measuring channel 4 (specimen 7 / 9)	acceleration sensor 352C22 (SN: 126372, PCB) – brown
power supply DC	EA-PSI 8160-05R (SN: 1231540004, EA)

Test equipment provided by the client

Laptop Siemens Nixdorf; Type Scenic Mobile 700; Inv No. 6500 0133

Omicron; Type CMC 156; Inv. No 6500 0103

Siemens Multizet S; Inv. No. G330168

Siemens Multizet S; Inv. No. 211051

Relay Contact Supervision; Type Siemens 09.2012

Programmable Power Supply; Type EA-PS 18160-04R; Inv. No. 0590

Functional test

Before, partly during and after the test, the functional tests were realized by the client by using hardware test program.

Visual inspection

Before, during and after each test, the respectable specimen was examined for any possible mechanical damages.

Fastening of the EUT during vibration and shock

During the tests the specimens were fixed to two 19"-mounting-rails (top and bottom):

C73165-A63-C209-2 without relief cut also by using M4-screws.

Both mounting rails were mounted to a test frame with four M6-screws, which was directly installed in all three axes on the sliding / vibration table.


The real inset conditions were simulated, see pictures appendix 2.

Arrangement of the acceleration sensors

First of all, the specimen was observed in each axes for any possible resonance points

(resonance = 5-times the response acceleration of the EUT). ВЪРНОС

Each one additional acceleration sensor was fixed directly on the housing of the specimens, see vibration protocols appendix 1.



6 Results

During the tests under normal service and transport conditions of the **Protection Relay Overcurrent Protection 7SJ663 (specimen 7 - Prototype 004)** and **Protection Relay Overcurrent Protection 7SJ662 (specimen 8 - Prototype 001)** with

- **Vibration, sinusoidal (transport and storage, class 2)** – test Fc
- **Vibration, sinusoidal (stationary use, class 2)** – test Fc

no mechanical damages or any other changes of the test components were found.

During and after each single test, the operability of the specimens was ensured.

Following acceleration answers was determined:

- **vibration (transport and storage, 5 Hz – 150 Hz, 20 m/s² / ±7,5 mm)**

X-axis	124 Hz	30.0 m/s ²	(1.50-times the response acceleration at housing specimen 7, 7SJ663)
	115 Hz	36.4 m/s ²	(1.82-times the response acceleration at housing specimen 8, 7SJ662)
Y-axis	88 Hz	90.2 m/s ²	(4.51-times the response acceleration at housing specimen 7, 7SJ663)
	98 Hz	88.2 m/s ²	(4.41-times the response acceleration at housing specimen 7, 7SJ663)
Z-axis	92 Hz	75.8 m/s ²	(3.79-times the response acceleration at housing specimen 8, 7SJ662)
	80 Hz	112.4 m/s ²	(5.62-times the resonance at the housing of specimen 7, 7SJ663)
	79 Hz	59.2 m/s ²	(2.96-times the response acceleration at housing specimen 8, 7SJ662)

- **vibration (stationary use, 10 Hz – 150 Hz, 10 m/s² / ±0,075 mm)**

X-axis	124 Hz	15.4 m/s ²	(1.54-times the response acceleration at housing specimen 7, 7SJ663)
	117 Hz	17.5 m/s ²	(1.75-times the response acceleration at housing specimen 8, 7SJ662)
Y-axis	90 Hz	32.2 m/s ²	(3.22-times the response acceleration at housing specimen 7, 7SJ663)
	89 Hz	16.6 m/s ²	(1.66-times the response acceleration at housing specimen 8, 7SJ662)
Z-axis	116 Hz	45.6 m/s ²	(4.56-times the response acceleration at housing specimen 8, 7SJ662)
	80 Hz	54.8 m/s ²	(5.48-times the resonance at the housing of specimen 7, 7SJ663)
	80 Hz	29.8 m/s ²	(2.98-times the response acceleration at housing specimen 8, 7SJ662)

During the tests under normal service and transport conditions of the

Protection Relay Overcurrent Protection 7SJ663 (specimen 9 - Prototype 027) and **Protection Relay Overcurrent Protection 7SJ662 (specimen 10 - Prototype 002)** with

- **Shock, half-sine (stationary use, class 1)** – test Ea
- **Shock, half-sine (resistance, class 1)** – test Ea
- **Bump, half-sine (transport and storage, class 1)** – test Ea
- **Seismic test (stationary use, class 2)** – test Fc

no mechanical damages or any other changes of the test components were found.

During and after each single test, the operability of the specimens was ensured.

Following acceleration answers was determined:

- **seismic test (stationary use, 3 Hz – 35 Hz, 20 m/s² (10 m/s²) / ± 8 mm (± 4 mm))**

X-axis	no response acceleration at the housing of specimens
Y-axis	no response acceleration at the housing of specimens
Z-axis	no response acceleration at the housing of specimens


The tests of the normal service and transportability under defined conditions of the Protection Relays were realized according to the standards.

Neither damages nor noticeable problems were determined.




The further evaluation will be done by the client.


The results of the test only refer to the above mentioned equipment under test.

The report or individual pages of this test report may only be copied following the written consent of the test laboratory. The test report-No. 10220.03 / 13 includes 6 pages and appendix 1 to 2.
appendix 1 – vibration and shock protocols appendix 2 – pictures




000351






Vibration, sinusoidal, specimen 7 / 8, X-axis, stationary use 10 Hz - 150 Hz, ± 0.075 mm / 10 m/s²




Vibration, sinusoidal, specimen 7 / 8, Y-axis, stationary use 10 Hz - 150 Hz, ± 0.075 mm / 10 m/s²




Vibration, sinusoidal, specimen 7 / 8, Z-axis, stationary use 10 Hz - 150 Hz, ± 0.075 mm / 10 m/s²

000353


appendix 1 of test report-No. 10220.03 / 13 page 3 / 6



Shock, half-sine, specimen 9 / 10, X-axis, resistance 150 m/s², 11 ms





Shock, half-sine, specimen 9 / 10, Y-axis, resistance 150 m/s², 11 ms





Shock, half-sine, specimen 9 / 10, Z-axis, resistance 150 m/s², 11 ms

000354


appendix 1 of test report-No. 10220.03 / 13 page 4 / 6



Bump, specimen 9 / 10, X-axis, transport and storage 100 m/s², 16 ms






Bump, specimen 9 / 10, Y-axis, transport and storage 100 m/s², 16 ms



Bump, specimen 9 / 10, Z-axis, transport and storage 100 m/s², 16 ms




000355

appendix 1 of test report-No. 10220.03 / 13 page 5 / 6




000356

appendix 1 of test report-No. 10220.03 / 13 page 6 / 6




000357

Pictures




picture 1

Overcurrent Protection 7SJ663 (specimen 7)
and Overcurrent Protection 7SJ662 (specimen 8)
on sliding table with test equipment
vibration tests in X-axis




picture 2

Overcurrent Protection 7SJ663 (specimen 7)
and Overcurrent Protection 7SJ662 (specimen 8)
on sliding table with acceleration sensors
vibration tests in X-axis




picture 3

Overcurrent Protection 7SJ663 (specimen 7)
and Overcurrent Protection 7SJ662 (specimen 8)
on vibration table with test equipment
vibration tests in Y-axis




picture 4

Overcurrent Protection 7SJ663 (specimen 7)
and Overcurrent Protection 7SJ662 (specimen 8)
on sliding table with acceleration sensors
vibration tests in Y-axis



picture 5


Overcurrent Protection 7SJ663 (specimen 7)
and Overcurrent Protection 7SJ662 (specimen 8)
on sliding table with test equipment
vibration tests in Z-axis




picture 6

Overcurrent Protection 7SJ663 (specimen 7)
and Overcurrent Protection 7SJ662 (specimen 8)
on sliding table with acceleration sensors
vibration tests in Z-axis


000358




picture 7
Overcurrent Protection 7SJ663 (specimen 9)
and Overcurrent Protection 7SJ662 (specimen 10)
on sliding table with test equipment
shock and seismic tests in X-axis




picture 8
Overcurrent Protection 7SJ663 (specimen 9)
and Overcurrent Protection 7SJ662 (specimen 10)
on sliding table with acceleration sensors
shock and seismic tests in X-axis




picture 9
Overcurrent Protection 7SJ663 (specimen 9)
and Overcurrent Protection 7SJ662 (specimen 10)
on vibration table with test equipment
shock and seismic tests in Y-axis



picture 10
Overcurrent Protection 7SJ663 (specimen 9)
and Overcurrent Protection 7SJ662 (specimen 10)
on sliding table with acceleration sensors
shock and seismic tests in Y-axis



picture 11
Overcurrent Protection 7SJ663 (specimen 9)
and Overcurrent Protection 7SJ662 (specimen 10)
on sliding table with test equipment
shock and seismic tests in Z-axis



picture 12
Overcurrent Protection 7SJ663 (specimen 9)
and Overcurrent Protection 7SJ662 (specimen 10)
on sliding table with acceleration sensors
shock and seismic tests in Z-axis

000359

Testing laboratory for climatic, mechanical
and corrosive environmental stress

CERTIFICATE of QUALITY TEST

Test report No. 10220.05 / 13

Client	Siemens AG IC SG EA PRO D 6 2 Wernerwerkdam 5 13629 Berlin	
Equipment under test	Protection Relay specimen 5	Overcurrent Protection 7SJ663 $\frac{1}{2}$ of 19" for panel flush mounting
	Protection Relay specimen 6	Overcurrent Protection 7SJ662 $\frac{1}{3}$ of 19" for panel flush mounting
Purpose	<i>Test of the climatic and corrosive resistance according to the standards and to the demands of the client.</i>	
Test program	Corrosive gas SO₂ Corrosive gas H₂S Corrosive gas 4 components	according to IEC 60068-2-42 according to IEC 60068-2-43 according to IEC 60068-2-60
Test period	12 November 2013 to 21 January 2014	
Realization / results	see page 2 to 4	
Total number of page	14 (inclusive 3 appendixes)	
Test result	<p>The tests were realized according to the standards and to the demands of the client.</p> <p>The further evaluation will be done by</p> <div style="border: 1px solid red; padding: 5px; display: inline-block;"> На основание чл.36а ал.3 от ЗОП </div>	

На основание чл.36а ал.3 от
ЗОП




На основание чл.36а ал.3 от
ЗОП

Test engineer

AU
Storkower Str. 315a
10407 Berlin
Tel. 030 42188-0
Fax 030 4232709
www.aucoteam.de

Gesellschaft Berlin
Amtsgericht Berlin Charlottenburg HRB 38393
USt-ID-Nr. DE 137 190 620
Geschäftsführer:
Dipl.-Ing. Bernd Rhlemeyer
Dipl.-Ing. Werner Zuchhold

Berliner Volksbank eG
BIC BEVODEBB
IBAN DE56 1009 0000 8301 8410 28
Commerzbank AG
BIC DRESDEFF100
IBAN DE53 1008 0000 0400 4292 00



1 Purpose

Test of the corrosive resistance according to the standards and to the demands of the client.

2 Equipment under test (EUT)

Protection Relay

specimen 5	Overcurrent Protection 7SJ663
model	Protoype 025
MLFB	1/2 of 19" for panel flush mounting
Firmware	7SJ6632-5KB90-3RH7-L0R/BB
DIGSI-Software	V04.00.03
	V4.88

Module in Device 7SJ663

1. Display Board with the serial Number 600000 245043
2. Current / Voltage input Board M102/3/6 - 2 with the serial Number 600000 245123
3. Power supply Board PS BO OB – 230 AC with the serial Number CB1311000174
4. BIO Board with the serial Number 600000 208677
5. BIO Board with the serial Number 600000 208676
6. CPU Board with the serial Number 600000 245060
7. ETH Board with the serial Number 600000 238963
8. BIO Board with the serial Number 600000 255772

Settings in Device 7SJ663

1. Overcurrent \geq 10 %; configured to LED 1
2. Overvoltage \geq 10 %; configured to LED 2
3. Undervoltage \leq 10 %; configured to LED 3
4. Binary Input (BI): BI 1; BI3 – BI13; BI15 – BI25; BI27 – BI36 high active
5. BI2; BI 14; BI 26 low active
6. Binary Output (BO) BO4; BO6; BO7 are supervised

Protection Relay

specimen 6	Overcurrent Protection 7SJ663
model	Protoype 013
MLFB	1/3 of 19" for panel flush mounting
Firmware	7SJ6621-5KB90-3HG7-L0D/BB
DIGSI-Software	V04.00.03
	V4.88

Module in Device 7SJ662


1. Display Board with the serial Number 600000 254760
2. Current / Voltage input Board M102/3/6 - 2 with the serial Number 000 245116
3. Power Supply Board PS BO OB – 230 AC with the serial Number CB1311000175
4. EXT. BIO Board with the serial Number 600000 255789
5. BI Board with the serial Number 600000 245100
6. CPU Board with the serial Number 600000 245053
7. ETH Board with the serial Number 600000 049730

Settings in Device 7SJ662

1. Overcurrent \geq 10 %; configured to LED 1
2. Overvoltage \geq 10 %; configured to LED 2
3. Undervoltage \leq 10 %; configured to LED 3
4. Binary Input (BI): BI 1; BI3 – BI8; BI10 – BI17; BI19 – BI21 high active
5. BI2; BI9; BI 18 low active
6. Binary Output (BO): BO4; BO6; BO7 are supervised

delivery date of the EUT

11 November 2013



000361

3 Basics

3.1 Demands of the client

3.2 Used standards

IEC 60068-1:1988 + Corr. 1988 + A1:1992	DIN EN 60068-1:1995-03
„Environmental testing - Part 1: General and guidance"	
IEC 60068-2-42:2003	DIN EN 60068-2-42:2004-04
„Environmental testing - Part 2-42: Tests - Test Kc: Sulphur dioxide test for contacts and connections"	
IEC 60068-2-43:2003	DIN EN 60068-2-43:2004-04
„Environmental testing - Part 2-43: Tests - Test Kd: Hydrogen sulphide test for contacts and connections"	
IEC 60068-2-60:1995	DIN EN 60068-2-60:1996-09
„Environmental testing - Part 2-60: Tests - Test Ke: Flowing mixed gas corrosion test"	

4 Test program

4.1 Corrosive gas, single gas SO₂ – test Kc

according to IEC 60068 -2-42

specimens	not operating
test temperature	(+25 ± 2)°C
relative humidity	(75 ± 5) %
corrosive atmosphere	(25 ± 5) ppm SO ₂
test duration	240:00 h (10 d)

4.2 Corrosive gas, single gas H₂S – test Kd

according to IEC 60068 -2-43

specimens	not operating
test temperature	(+25 ± 2)°C
relative humidity	(75 ± 5) %
corrosive atmosphere	(10 ± 5) ppm H ₂ S
test duration	240:00 h (10 d)

4.3 Corrosive gas, mixed gas, 4 components – test Ke


according to IEC 60068 -2-60

specimens	not operating
test temperature	(+25 ± 2)°C
relative humidity	(75 ± 5) %
corrosive atmosphere	0.01 ppm H ₂ S 0.20 ppm SO ₂ 0.20 ppm NO ₂ 0.01 ppm Cl ₂
test duration	240:00 h (10 d)

5 Realization

The environmental tests were carried out one by one according to the program of testing methods (complex 4.1 to 4.3), according to the standards and to the demands of the client.
The tests were performed according to the demands of the client as following:





000362



Test report-No. 10220.05 / 13 page 4 / 4

5.1 Corrosive gas, single gas SO₂ – test Kc

This test was realized at the test lab Rail System Testing GmbH (RST).

test period
realization

12 November to 22 November 2013

see appendix 2 - test report No. P50-13-0537_1-en,
Rail System Testing GmbH (RST), 3 December 2013

5.2 Corrosive gas, single gas H₂S – test Kd

This test was realized at the test lab Rail System Testing GmbH (RST).

test period
realization

22 November to 2 December 2013

see appendix 2 - test report No. P50-13-0537_1-en,
Rail System Testing GmbH (RST), 22 October 2013

After the corrosive test, the functionality of the specimens was checked.

5.3 Corrosive gas, mixed gas, 4 components – test Ke

This test was realized at the test lab Technologie-Zentrum Oberflächentechnik u. Umweltschutz (TZO) Leipzig GmbH.

test period
realization

10 January to 20 January 2014

see appendix 3 - test report No. 366/13

Labor für Umwelterprobung Werkstoffprüfung u. Analytik
des Technologie-Zentrum Oberflächentechnik u. Umweltschutz
(TZO) Leipzig GmbH, 20 January 2014

After the corrosive test, the functionality of the specimens was checked.

6 Results

6.1 Corrosive gas, single gas SO₂ and H₂S – test Kc and Kd

After the corrosive tests of the

Protection Relay Overcurrent Protection 7SJ663 (Prototype 020) and
Protection Relay Overcurrent Protection 7SJ662 (Prototype 009) with

- **Corrosive gas SO₂** - test Kc

(25 ppm SO₂, 25 °C, 75 % r. h., 10 d not operating)

- **Corrosive gas H₂S** - test Kd

(10 ppm H₂S, 25 °C, 75 % r. h., 10 d not operating)

the no visible changes was determined at both specimens.

After the corrosive test, the functionality of the 2 specimens was ensured.

6.3 Corrosive gas, mixed gas, 4 components – test Ke

After the corrosive tests of the

Protection Relay Overcurrent Protection 7SJ663 (Prototype 020) and
Protection Relay Overcurrent Protection 7SJ662 (Prototype 009) with

- **Corrosive gas 4 components** - test Ke

(0.01 ppm H₂S, 0.20 ppm SO₂, 0.20 ppm NO₂, 0.01 ppm Cl₂, 25 °C, 75 % r. h., 10 d not operating)

the no visible changes was determined at both specimens.

After the corrosive test, the functionality of the 2 specimens was ensured.

The tests were realized according to the standards
and to the demands of the client.

The further evaluation will be done by the client.

The results of the test only refer to the above mentioned equipment under test. The report or individual
pages of this testing report may only be copied following the written consent of the testing laboratory.
This testing report-No. 10220.05 / 13 includes 4 pages and appendix 1 to 3.


The realized corrosive tests are not included in the scope of accreditation.

The realization of these tests was carried out in accredited laboratories.

appendix 1 – pictures


appendix 2 – test report No. P50-13-0537_1-en, Rail System Testing GmbH (RST), 2 December 2013

appendix 3 – test report No. 366/13, TZO Leipzig GmbH, 20 January 2014




000363


pictures




picture 1
Overcurrent Protection 7SJ663 (Prototype 020)
1/2 of 19" for panel flush mounting
before the corrosive tests




picture 2
Overcurrent Protection 7SJ662 (Prototype 009)
1/3 of 19" for panel flush mounting
before the corrosive tests




picture 3
Overcurrent Protection 7SJ663 (Prototype 020)
1/2 of 19" for panel flush mounting
before the corrosive tests



picture 4
Overcurrent Protection 7SJ662 (Prototype 009)
1/3 of 19" for panel flush mounting
before the corrosive tests




picture 5
Overcurrent Protection 7SJ663 (Prototype 020)
1/2 of 19" for panel flush mounting
functional test before the corrosive tests




picture 6
Overcurrent Protection 7SJ662 (Prototype 009)
1/3 of 19" for panel flush mounting
functional test before the corrosive tests


Appendix 1 to test report-No. 10220.05 / 13 page 2 / 3




picture 7
Overcurrent Protection 7SJ663 (Prototype 020)
no visible changes
after the corrosive tests Kc and Kd




picture 8
Overcurrent Protection 7SJ662 (Prototype 009)
no visible changes
after the corrosive tests Kc and Kd




picture 9
Overcurrent Protection 7SJ663 (Prototype 020)
no visible changes
after the corrosive tests Kc and Kd




picture 10
Overcurrent Protection 7SJ662 (Prototype 009)
no visible changes
after the corrosive tests Kc and Kd




picture 11
Overcurrent Protection 7SJ663 (Prototype 020)
no visible changes
after the corrosive tests Kc and Kd




000365




picture 13
Overcurrent Protection 7SJ663 (Prototype 020)
no visible changes
after the corrosive test Ke (mixed gas)




picture 14
Overcurrent Protection 7SJ662 (Prototype 009)
no visible changes
after the corrosive test Ke (mixed gas)




picture 15
Overcurrent Protection 7SJ663 (Prototype 020)
no visible changes
after the corrosive test Ke (mixed gas)



picture 16
Overcurrent Protection 7SJ662 (Prototype 009)
no visible changes
after the corrosive test Ke (mixed gas)



picture 17
Overcurrent Protection 7SJ663 (Prototype 020)
functionality was ensured
after the corrosive test Ke (mixed gas)



picture 18
Overcurrent Protection 7SJ662 (Prototype 009)
functionality was ensured
after the corrosive test Ke (mixed gas)

СОФИЯ
23.11.2012
ОРИГИНАЛА



000366



TESTING THE WORLD
FOR TOMORROW

Customer:

Aucoteam GmbH
Prüflabor – GB P
Mr. Geburtig
Storkower Straße 115 a
10407 Berlin



Environmental Lab

RST Rail System Testing GmbH

Philipp-Pflorr-Straße 10
16761 Hennigsdorf



Materials Lab

Fon +49 (0)3302 49982 0
Fax +49 (0)3302 49982 15



Fire Lab

www.rst-labs.de
info@rst-labs.de



New Technologies

Test Report No.

P50-13-0537_1-en

Environmental Tests

Order No.:

50-13-0537

This report includes
3 pages.

Date:

03/12/2013

phone: 03302 49982 54

Test engineer:

Mrs. Förster

Documentation:

fr

Delivery date specimen: 12/11/ 2013

Test date: 12/11/2013 until 02/12/2013

Specimen: 2 pieces protection devices (specimen No. 50-13-0537-5 and 6)
(for details see page 2)

Relevant specification:

- Test Kd; Hydrogen sulphide test for contacts and connections based of DIN EN 60068-2-43 (edition 04/2004)
- Test Kc; Sulphur dioxide test for contacts and connections according to DIN EN 60068-2-42 (edition 04/2004)
- Visual inspection
(for details see page 2)

Objective:


Proof of the stability of the protection devices at the conditions mentioned in the relevant specification.

Results:

The protection devices were tested according to the relevant specification.
No visible changes and no visible corrosion effects of the specimens were detected after the exposures in comparison to the initial states (for details see page 3).

Bernd Sommerfeld
Head of the Environmental Lab

The results refer only to the specimens above mentioned.
This Test Report must always be copied entirely. Any copying of extracts and publication require the prior consent of the Laboratory.



Manager
Dipl.-Ing. G. Schmidt

Landesbank Berlin
Konto 133 80 800
BLZ 100 500 00

BIC: BE LA DE BE
IBAN: DE44 1005
0000 0013 3808 00

Amtsgericht Neuruppin
HfB 6580 OPR
USt-Id. DE813 68 62 94

DAkkS
Deutsche
Akkreditierungsstelle
D-PL-13012-01-00

U

b

000367



TESTING THE WORLD
FOR TOMORROW

Page 2 of 3 to the Test Report No. P50-13-0537_1-en

1 Specimen

2 pieces protection devices

specimen No. 50-13-0300-..	version/type
5	7SJ6632-5KB90-3RH7-L0R/BB
6	7SJ6621-5KB90-3HG7-L0D/BB

2 Relevant Specification

2.1 Exposures (sequence of tests)

2.1.1 Test Kd; Hydrogen sulphide test for contacts and connections according to DIN EN 60068-2-43 (edition 04/2004)

concentration H₂S: (10 ... 15) ppm
exposure temperature: (25 ± 2) °C
relative humidity: (75 ± 5) %
test duration: 10 days

2.1.2 Test Kc: Sulphur dioxide test for contacts and connections according to DIN EN 60068-2-42 (edition 04/2004)

concentration SO₂: (25 ± 5) ppm
exposure temperature: (25 ± 2) °C
relative humidity: (75 ± 5) %
test duration 10 days

2.2 Evaluations


2.2.1 Visual inspection

Examination of the changes in relation to the initial states of the specimens
inspection times: after each exposure

3 Test procedure

3.1 Test setup


The test setup of the noxious gas tests is shown in the following figure 1.



RST/9E5WQ89D_F00003441

fig. 1

test setup:
specimen in the test chamber



Manager
Dipl.-Ing. G. Schmidt

Landesbank Berlin
Konto 133 80 800
BLZ 100 500 00

BIC: BE LA DE BE
IBAN: DE44 1005
0000 0013 3808 00

Amtsgericht Neuruppin
HRG 6580 OPR
USt-Id. DE 813 68 62 94

000368



TESTING THE WORLD
FOR TOMORROW

Page 3 of 3 to the Test Report No. P50-13-0537_1-en

3.2 Exposure diagram

The stress sequences of the noxious gas tests are shown in the following diagram 1:




Diagram 1: Loading by Test Kc: Sulphur dioxide and test Kd: Hydrogen sulphide

remark: failure of the test chamber on 17 November 2013

3.3 Test equipment

The test and measuring instruments as well as the calibration status were checked before using.

Test equipment	Inv. No.
Noxious gas test chamber type C+10/600-SG (CTS-SG 2), manufacturer CTS	7993 0771

4 Results

4.1 Visual inspection


No visible changes, no visible corrosion effects of the specimens were detected after the exposures in comparison to the initial states:

- before the exposures

specimen No. 50-13-0537-5: back cover sheet (delivery status): some fingerprints
specimen No. 50-13-0537-6: without findings

- after the exposures

specimen No. 50-13-0537-5 and -6: no visible changes, no visible corrosion effects



Manager
Dipl.-Ing. G. Schmidt

Landesbank Berlin
Konto 133 80 800
BLZ 100 500 00

BIC: BE LA DE BE
IBAN: DE44 1005
0000 0013 3800 00

Amtsgericht Neuruppin
HRB 6580 OPR
USt-Id. DE 813 68 62 94

000369

**Labor für Umwelterprobung
und Werkstoffprüfung**

Telefon +49 (0) 3 41 / 4 84 32 - 25
Telefax +49 (0) 3 41 / 4 84 32 - 14
E-Mail umwelterprobung@tzo-leipzig.de

**Technologie-Zentrum für Oberflächentechnik
und Umweltschutz Leipzig GmbH**

Hornstraße 5 • D-04249 Leipzig
Telefon +49 (0) 3 41 / 4 84 32 - 0 • Fax +49 (0) 3 41 / 4 84 32 - 14
E-Mail info@tzo-leipzig.de

TEST REPORT

No. 366/13

Client

AUCOTEAM GmbH
Test laboratory / GB P
Mr. Geburtig
Storkower Straße 115 a
D-10407 Berlin

Date of order

2013-12-04

test order no. 95.13.0944.1

Date of receiving the specimens

2013-12-05

Period of testing

2014-01-10 to 2014-01-20

1 TEST OBJECT

1.1 Designation / Number of pieces

Safety device SIPROTEC with coated printed boards / 2 pieces
labelled with 7SJ662 and 7SJ663

1.2 Producer

Siemens AG

2 TASK

Testing to determine the resistance against flowing mixed gas in accordance with
DIN EN 60068-2-60 : 1996-09, Test Ke, Method 4


3 TEST PROGRAMME

3.1 Initial examinations

3.1.1 Test of function

carried out by the client

3.1.2 Visual inspection



page 1 of 2 pages

000370

**3.2 Loading by flowing mixed gas in accordance with DIN EN 60068-2-60, Test Ke,
Method 4**

Test device Corrosion test chamber K 750 TZO Leipzig GmbH
Measurement of the gas concentration by Zellweger analytics TOX GAS MONITOR 7100

Concentration of Hydrogen sulphide (H ₂ S)	0,01 cm ³ / m ³ (ppm)	(10 ± 5) ppb
Concentration of Nitrogen dioxide (NO ₂)	0,2 cm ³ / m ³ (ppm)	(200 ± 20) ppb
Concentration of Chlorine (Cl ₂)	0,01 cm ³ / m ³ (ppm)	(10 ± 5) ppb
Concentration of Sulphur dioxide (SO ₂)	0,2 cm ³ / m ³ (ppm)	(200 ± 20) ppb
Temperature	(25 ± 1) °C	
Relative Humidity	(75 ± 3) %	
Test duration	10 d	
Exposition	see annex, figure 1	

3.3 Final examinations carried out by the client

4 RESULTS

4.1 Initial examinations

4.1.1 Test of function see the record written by the client

4.1.2 Visual inspection

Damages or defects are not visible.

4.2 Final examinations see the record written by the client


Leipzig, 2014-01-20

Laboratory for Environmental
Testing and Material Testing

Annex sheet 1 and 2

Dr.-Ing. Frank Erler
Laboratory Manager

The test result is true only for the specimen(s) mentioned in the clause „test object (specimen)“. It is allowed to copy the complete test report only. When the test report shall be copied in the form of extracts the agreement must be given by the test laboratory for them.



TZO/LUW
Client: AUCOTEAM GmbH Test laboratory
Date of order: 2013-12-04

Annex sheet 1
to
Test report 366/13




Figure 1 Exposition in the test chamber



TZO/LUW
Client: AUCOTEAM GmbH Test laboratory
Date of order: 2013-12-04

Annex sheet 2
to
Test report 366/13

Schadgasanalytik mit dem Zellweger analytics TOX GAS MONITOR 7100

Measurement of the gas concentration by Zellweger analytics TOX GAS MONITOR 7100

TZO GMGH
LEIPZIG
SERIES 7100 SN-5394

OPTICS
CALIBRATION

Stickstoffdioxid // Nitrogen dioxide

PERFORMED

ON AT

01/10/14 09:00:30

NEW Q IS 1.020

OLD Q WAS 1.015

CARD SPAN - 1718

CARD ZERO - 600

ACTUAL SPAN- 2173

ACTUAL ZERO- 1077

10.01.14 No.

10.01.14 No.

11:30	204	PPB	NO ₂ /L
11:27	202	PPB	NO ₂ /L
11:25	204	PPB	NO ₂ /L
11:23	202	PPB	NO ₂ /L
11:21	205	PPB	NO ₂ /L
11:18	205	PPB	NO ₂ /L
11:16	208	PPB	NO ₂ /L
11:14	200	PPB	NO ₂ /L
11:12	202	PPB	NO ₂ /L
11:09	209	PPB	NO ₂ /L
11:07	202	PPB	NO ₂ /L
11:05	203	PPB	NO ₂ /L
11:03	205	PPB	NO ₂ /L
11:00	200	PPB	NO ₂ /L

Chlor // Chlorine

10.01.14 No.

Schwefeldioxid // Sulphur dioxide

10:07	10	PPB	CL2/L
09:57	11	PPB	CL2/L
09:46	10	PPB	CL2/L
09:36	10	PPB	CL2/L
09:26	10	PPB	CL2/L

10.01.14 No.


14:02	206	PPB	SO ₂ /L
13:59	207	PPB	SO ₂ /L
13:57	202	PPB	SO ₂ /L
13:54	205	PPB	SO ₂ /L
13:52	205	PPB	SO ₂ /L
13:49	207	PPB	SO ₂ /L
13:47	202	PPB	SO ₂ /L
13:44	202	PPB	SO ₂ /L
13:42	205	PPB	SO ₂ /L
13:39	207	PPB	SO ₂ /L
13:36	203	PPB	SO ₂ /L
13:34	208	PPB	SO ₂ /L
13:31	205	PPB	SO ₂ /L

Schwefelwasserstoff //
Hydrogen sulphide

10.01.14 No.

12:45	10	PPB	H2S/L
12:35	10	PPB	H2S/L
12:25	10	PPB	H2S/L
12:15	10	PPB	H2S/L
12:05	10	PPB	H2S/L

ВЯРНО С
ОРИГИНАЛА



000373

ДОКУМЕНТ 7.2

С
Э

ДЕКЛАРАЦИЯ

че предложеното оборудване в процедурата отговаря на минималните технически изисквания на Възложителя, посочени в таблица 7

Долуподписаният Антон Иванов Илиев, в качеството ми на представляващ „МИГ 23“ ЕООД, участник в процедура за изпълнение на обществена поръчка с реф. № PPD 19-103 и предмет: „Модернизация (ретрофит /проектиране, реконструкция, доставка и монтаж на машини и съоръжения, подготовка и въвеждане в експлоатация/) на възлови разпределителни станции 20 (10) кВ и изграждане на вериги на телемеханика в регион „Ловеч - Враца“, регион „Монтана – Видин“ и регион „Плевен“

ДЕКЛАРИРАМ, ЧЕ:

че предложеното от нас оборудване в процедурата, отговаря на минималните технически изисквания на СТАНДАРТ НА МАТЕРИАЛА ЗА ПОСОЧНА ЦИФРОВА ЗАЩИТА ЗА ВЪЗДУШНИ И КАБЕЛНИ ЕЛЕКТРОПРОВОДНИ ЛИНИИ СР. Н., посочени в таблица 7, както следва:

Характеристики на работната среда:

№	Характеристика	Стойност
1.	Място на монтиране	На закрито
2.	Максимална температура на околната среда	До + 55°C
3.	Минимална температура на околната среда	Минус 20°C
4.	Надморска височина	До 1000 m
5.	Относителна влажност	До 90% при 20°C

Параметри на електрическата разпределителна мрежа:

№	Параметър	Стойност	
1.	Номинални напрежения	10 000 V	20 000 V
2.	Максимални работни напрежения	12 000 V	24 000 V
3.	Номинална честота	50 Hz	
4.	Брой на фазите	3	
5.	Заземяване на звездния център	През активно съпротивление	

Общи технически параметри, характеристики и др. данни за посочна цифрова защита за въздушни и кабелни електропроводни линии Ср.Н., за които Участникът декларира, че предложеното от него оборудване отговаря на посочените минимални технически изисквания на Възложителя, посочени в таблицата по-долу:

№	Параметър/характеристика	Минимални технически изисквания
1.	Зашити и автоматика:	
-	Трифазна двустъпална максималнотокова защита с независими от тока характеристики	Да
-	Трифазна едностъпална бързодействаща токова отсечка с независими от тока характеристики	Да
-	Трифазна двустъпална токова земна защита с независими от тока характеристики	Да
-	Автоматично повторно включване (АПВ)	Да

000374

MIG 23 Ltd

www.mig23-bg.com
mv@mig23-bg.com

№	Параметър/характеристика	Минимални технически изисквания
-	За земна защита, резултатният земен ток да се изчислява от ЦЗ, като в съответния ѝ токов вход може да бъде присъединен както токов трансформатор тип „ФЕРАНТИ“, така и филтър за токове с нулева последователност, изпълнен чрез три фазни токови трансформатори. Начинът на присъединяването на ЦЗ за отчитане на токовете на земно съединение да се определя индивидуално за всеки конкретен случай.	Да
-	Всяка една от защитните функции, които са интегрирани в една защита да е с възможност за извеждане от действие, независимо от другите.	Да
-	ЦЗ да има възможност за създаване и поддържане на минимум два набора от настройки и конфигурации, които могат да се избират дистанционно или от мястото на експлоатация.	Да
-	Заштите да следят и сигнализират за възникване на несиметричен режим.	Да
-	Всички защици трябва да притежават свободно програмируеми цифрови входове, изходи и светодиодна индикация, както и възможност за задаване на продължителността на импулса за изключване за всеки цифров изход по отделно.	Да
-	Да е осигурена аварийна сигнализация при неизпълнена команда, подаване на неразрешени команди и други.	Да
-	ЦЗ трябва да имат 2 нива на достъп, реализирани с пароли и да позволяват: - потребителска настройка на комуникацията от място(от лицев панел) или дистанционно(от лицев панел, с преносим компютър и дистанционно). - потребителска настройка на защитните функции, конфигуриране и тестване от място (от лицев панел, с преносим компютър и дистанционно).	Да
-	При отпадане на захранването да се запазват въведените настройки, конфигурации, аварийната и архивната информация.	Да
-	Контрол на броя и вида на изключванията на прекъсвачите.	Да
-	Всеки запис в регистъра на аварийна информация, да съдържа астрономическо време и пълни данни, характеризиращи събитието. Регистраторът на аварийна информация да осигурява и осцилографна информация с история и предистория за зададен времеви интервал за регистрирано събитие.	Да
-	Всички защици трябва да притежават вграден LCD/LED-дисплей за визуализиране на текущо измерваните ефективни стойности (модул и фаза) на всеки от аналоговите входове на устройството и аварийната информация.	Да
-	Всяка защита да притежава стандартен интерфейс за комуникация по Ethernet, RS-485, стандартен интерфейс за комуникация с персонален компютър, необходим при оствъществяване на функции по настройка, конфигуриране и изчитане на регистрирана от защитата информация и съответно програмно осигуряване.	Да
-	Комуникационния интерфейс за връзка с RTU да се счита като неразделна част от ЦЗ. Комуникационния интерфейс да има светодиодна индикация за режима на работа.	Да
-	ЦЗ трябва да включва система за самоконтрол и самодиагностика, включително и на комуникациите с вътрешни и външни потребители.	Да
-	Да се осигури възможност за щутиране на токовите вериги и присъединяване на външна измервателна техника на изградените клемореди.	Да

000375

MIG 23 Ltd

www.mig23-bg.com
mv@mig23-bg.com

№	Параметър/характеристика	Минимални технически изисквания
2.	Номинално оперативно напрежение	от 24 до 220 V DC ± 20 % и 220 V AC ± 20 %
3.	Буфер на захранването	≤ 50 ms
4.	Консумация на защитата при I_{in}	≤ 0.3 VA
5.	Номинален ток, I_{in}	5 A
6.	Клеми на токови и оперативни вериги	Винтови клеми позволяващи присъединяване на медни проводници, клас 1, със сечение между 1,5 mm ² и 4 mm ² (Степен на защита: min IP20).
7.	Лицев панел:	
-	Наличие на LCD/LED дисплей и светодиодна индикация на лицевия панел за мнемосхема, заработка, изключване, неизправност на защитата и др.(Дисплеят трябва да бъде ясно четим при всички възможни условия на осветление в помещението, дори при пълен мрак).	Да
-	Брой на светодиодните индикатори с възможност за мигаща индикация и наличие на два цвята при промяна на състоянието, зелен-червен (програмируеми).	≥ 8
-	Заводски програмирани светодиоди за състоянието на ЦЗ.	≥ 2
-	Визуализиране на дисплея на параметрите за настройка и на текущите и архивирани данни от работата на защитата.	Да
-	Наличие на клавиатура за визуализиране на информация от работата на устройството, за настройка и конфигуриране и за управление на прекъсвача.	Да
-	Степен на защита на лицев панел	≥ IP 54
8.	Комуникации:	
-	Наличие на стандартен интерфейс и протокол съгласно MODBUS TCP/IP и IEC 61850 или еквиваленти за оптична или жична връзка с локална мрежа за предаване на информация от дневника на събития и от аварийния регистратор и за управление на силовото комутиращо устройство.	БДС EN 61850, MODBUS TPC/IP или еквиваленти
-	Достъп от PC и от собствената клавиатура до промяна на настройките и на вградените защитни и комуникационни функции.	Да
-	Достъп от PC и от собствената клавиатура до промяна на конфигурацията.	Да
-	Наличие на стандартен интерфейс на лицевия панел за връзка с преносим компютър.	Да
-	Наличие на сменяема парола за различните нива на достъп до данните за настройките на: - комуникационни функции на ЦЗ; - защитни функции на ЦЗ.	Да
-	Буфериране на информацията при повреда в комуникациите.	Да
9.	Регистратори:	
-	Наличие на функция "регистратор на събития" (fault recorder).	Да
-	Точност на записа при регистриране на събития.	≥ 1 ms
-	Брой и съдържание на регистрираните събития - вид заработилата защита, вид на късото съединение, дата/време.	≥ 10
-	Наличие на функция „аварийен регистратор“ (disturbance recorder).	Да
-	Скорост на сканиране.	≥ 1000 Hz
-	Обем на буфера за регистриране на аварийни събития.	≥ 15 s

000376

MIG 23 Ltd

www.mig23-bg.com
mv@mig23-bg.com

№	Параметър/характеристика	Минимални технически изисквания
10.	Софтуер	<p>а) Софтуерът за параметризация да е последна версия и с min 20 (двойсет) бесплатни лицензии). В потребителската си част, да е напълно документиран и така структуриран, че да може да се променят и добавят бързо нови функции.</p> <p>б) Надграждането (upgrade) и обновяването (update) на софтуерът (firmware) на ЦЗ се предоставя на възложителя бесплатно за срока на експлоатация на ЦЗ.</p> <p>в) ЦЗ трябва да позволяват тестване и обслужване на отделни локални устройства без да се повлиява работата на останалите. Изпитването на двоичните входове и изходи не трябва да предизвика загуба или промяна на данни от входа или към изхода, който се тества. ЦЗ при тези проби не трябва да стартира или рестартира своята вътрешна логика, нито да се отрази на данните, които са архивирани в нея.</p> <p>г) Софтуерът на ЦЗ трябва да изпълнява основно следните функции:</p> <ul style="list-style-type: none">• управление и блокировки на команди към високоволтовото оборудване тип на защитата;• сигнализиране и архивиране на състоянието на високоволтовото оборудване;• измерване на аналогови величини от измервателните трансформатори към съответните присъединения;• изчисляване на аналогови величини;• архивиране, обработка и визуализиране на данни от аварийните регистратори;• настройка и конфигуриране на всяка защитна функция;• настройка и конфигуриране на комуникационния интерфейс;• съхраняване на събития и измерени аналогови стойности;• поддържане на база данни, възможност за конфигуриране и за потребителско дефиниране на различни видове справки;• самотестване и самодиагностика на ЦЗ;• моделиране и симулация;

MIG 23 Ltd

www.mig23-bg.com
mv@mig23-bg.com

№	Параметър/характеристика	Минимални технически изисквания
11.	Монтаж	<p>а) ЦЗ трябва да са изградени като система за вграждане в 19" рамка на шкаф и да притежават пълна независимост от външни електромагнитни влияния.</p> <p>б) При конкретна заявка да е възможен следния монтаж: преден монтаж тип Panel surface и заден монтаж тип Flush/Rack Mounted.</p> <p>в) Всички операции трябва да се извършват от лицевата част, като не трябва да е необходим достъп отстрани.</p>
12.	Маркировка	<p>Маркировката трябва да бъде надеждно и трайно нанесена. Типът, номиналните данни, сериен номер, хардуерна и софтуерна версия на ЦЗ трябва да бъдат маркирани в буквено-цифров вид. Всички клемореди, клеми, платки, слотове и т.н. трябва да бъдат ясно маркирани. Обикновени самозалепващи стикери не са допустими.</p>
13.	Опаковка	<p>а) Подходяща опаковка предпазваща от механични повреди и атмосферни влияния при транспортиране и съхранение.</p> <p>б) Върху опаковката трябва да има етикет, съдържащ следната информация:</p> <ul style="list-style-type: none"> • наименование и/или логото на производителя; • тип на защитата; • сериен номер; • дата на производство; • страна на производство; • общо тегло, kg.
14.	Окомплектовка	<p>- Лицензиран потребителски софтуер, с min 5 безплатни лицензии) и кабел за връзка на защитата със преносим компютър(или друго техническо решение), както и други аксесоари в зависимост от указанията на производителя.</p> <p>- Списък на адресите, съгласно т.6.5 от таблица 6</p>
15.	Проектна експлоатационна дълготрайност, год.	≥ 20 години

Г

ХУ

Х

000378

MIG 23 Ltd

www.mig23-bg.com
mv@mig23-bg.com

Технически данни за посочна цифрова защита за въздушни и кабелни електропроводни линии Ср.Н., за които Участникът декларира, че предложеното от него оборудване отговаря на посочените минимални технически изисквания на Възложителя, посочени в таблицата по-долу:

№	Технически параметър	Минимални технически изисквания
1.	Двоични изходи:	
-	Номинално работно напрежение на изходните контакти	от 24 до 220 V DC ± 20% и 220 V AC ± 20 %
-	Допустим ток при отваряне на контактите при L/R<40ms (при 220V AC)	≥ 0.1 A
-	Траен допустим ток през затворен контакт (при 220V AC)	≥ 5 A
-	Краткотраен допустим ток през затворен контакт (при 220V AC)	≥ 30 A за 4 s
-	Брой програмириеми изходи	≥ 7
2.	Аналогови входове:	
2.1	Токови входове	
-	Брой токови входове – Ia, Ib, Ic, 3Io	4
-	Номинален ток	5 A
-	Термично претоварване в токовите вериги:	-
-	• Трайно	4 ln постоянно
-	• За 30 s	30 ln
-	• За 1 s	100 ln
-	Динамично претоварване за ½ T	250 ln
2.2	Напреженови входове	
-	Брой напреженови входове – Ua, Ub, Uc, 3Uo	4
-	Номинално фазно напрежение	100/√3 V
-	Допустимо продължително претоварване	2 Un
-	Измервани и изчислени величини:	-
-	-Фазови токове и 3Io	4
-	-Фазови напрежения и напрежение 3Uo	4
-	-Линейни напрежения	3
-	-Активна мощност и енергия с посока	Да
-	-Реактивна мощност и енергия с посока	Да
-	-Пълна мощност и енергия	Да
-	-Cos φ - капацитивен, индуктивен	Да
-	-Честота	Да
-	Грешка при измерване на ефективните стойности на I в диапазона от 0.1-1.2 ln в % от измерената стойност	≥ 1
-	Грешка при измерване на ефективните стойности на U в диапазона от 0.8-1.2 Un в % от измерената стойност	≥ 1
-	Грешка при изчисление на P, Q, S в диапазона 0.1-1 ln и 0.8-1.2 Un в % от измерената стойност	≥ 1
-	Грешка при измерване на енергия	≥ 1
3.	Двоични входове:	
-	Номинално захранващо напрежение	от 24 до 220 V DC ± 20 % и 220 V AC ± 20 %
-	Брой програмириеми входове	≥ 12
4.	Функционални изисквания:	
-	Трифазна максималнотокова защита (МТЗ) с независимо от тока закъснение	Да
-	Наличие на две стъпала по ток и по време	Да
-	Бързодействие на защитата с включено време на цифровия изход	≤ 35 ms
-	Трифазна токова защита (ТО) с независимо от тока закъснение	Да
-	Наличие на две стъпала по ток и по време	Да

000373

MIG 23 Ltd

www.mig23-bg.com
mv@mig23-bg.com

-	Бързодействие на защитата с включено време на цифровия изход	$\leq 35 \text{ ms}$
-	Токова земна защита (T33), с независимо от тока забавяне, за мрежа средно напрежение, заземена през активно съпротивление	Да
-	Наличие на четири стъпала по ток и по време	Да
-	Бързодействие на защитата с включено време на цифровия изход	$\leq 35 \text{ ms}$
-	Inrush функция по втори хармоник блокировка по II хармоник	Да
4.1	Настройка на времерелетата за МТЗ:	
-	Диапазон на настройка по ток към съответните стъпала	$0,1+25 \text{ In}$ стъпка 0,01 или ∞
-	Диапазон на настройка на времерелетата към съответните стъпала	$0,00+60,00 \text{ s}$ със стъпка 0,01
4.2	Настройка на времерелетата за ТО:	
-	Диапазон на настройка по ток към съответните стъпала	$0,1+12,5 \text{ In}$ стъпка 0,01 или ∞
4.3	Настройка на времерелетата за ТЗЗ:	
-	Диапазон на настройка по ток към съответните стъпала	$0,05+25 \text{ In}$ стъпка 0,01 или ∞
-	Диапазон на настройка на времерелетата към съответните стъпала	$0,00+60,00 \text{ s}$ със стъпка 0,01
5.	Трифазно АПВ	Да
-	Кратност на АПВ	≥ 3
-	Пускане на АПВ - от вътрешна РЗ или от несъответствие	Да
-	Блокиране на АПВ от външни контакти и от вътрешни логически променливи (задействане на ТО) и др.	Да
-	Наличие на вграден часовник (астрономично време) Д/М/Г час:мин:сек:милисек и възможност за синхронизация.	Да
-	Възможност за дефиниране на повече от един комплект настройки на ЦЗ.	Да

Дата 31.10.2019 г.

Декларатор:

На основание чл.36а ал.3 от
ЗОП



000389

ДОКУМЕНТ 8

С

Х

и

ДЕКЛАРАЦИЯ

че предложеното оборудване в процедурата отговаря на минималните технически изисквания на Възложителя, посочени в таблица 8

Долуподписаният Антон Иванов Илиев, в качеството ми на представляващ „МИГ 23“ ЕООД, участник в процедура за изпълнение на обществена поръчка с реф. № PPD 19-103 и предмет: „Модернизация (ретрофит /проектиране, реконструкция, доставка и монтаж на машини и съоръжения, подготовка и въвеждане в експлоатация) на възлови разпределителни станции 20 (10) kV и изграждане на вериги на телемеханика в регион „Ловеч - Враца“, регион „Монтана – Видин“ и регион „Плевен“

ДЕКЛАРИРАМ, ЧЕ:

че предложеното от нас оборудване в процедурата, отговаря на минималните технически ИЗИСКВАНИЯ КЪМ КОМУНИКАЦИЯ НА ЦЗ И КОНТРОЛЕР С RTU, посочени в таблица 8, както следва:

№	Параметър/характеристика	Минимални технически изисквания
1.	Всяка защита и контролер да притежава стандартен интерфейс за комуникация по Ethernet, RS-485 или оптичен интерфейс, стандартен интерфейс за комуникация с персонален компютър и съответно програмно осигуряване.	Да
-	Комуникацията между RTU и ЦЗ, чрез оптичен интерфейс се осъществява с HFBR-4516Z connector .	Да
-	Комуникацията между RTU и ЦЗ, чрез четирипроводна или двупроводна мрежа RS-485 се осъществява с RJ-45.	Да
-	Комуникацията между ЦЗ и персонален компютър се осъществява с USB порт.	Да
-	Комуникационния интерфейс за връзка с RTU да се счита като неразделна част от ЦЗ. Комуникационния интерфейс да има светодиодна индикация за режима на работа.	Да
2.	ЦЗ трябва да включва система за самоконтрол и самодиагностика, на комуникациите с вътрешни и външни потребители.	Да
3.	Наличие на сменяема парола за достъп до данните за настройките на комуникационните функции.	Да
4.	Наличие на стандартен интерфейс и протокол съгласно MODBUS TCP/IP и IEC 61850 по жична връзка с локална мрежа за предаване на информацията .	Да
5.	Потребителска настройка на комуникацията по комуникационен протокол:	-
-	При осъществяване на комуникацията по комуникационен протокол съгласно БДС EN 61850-5	Потребителска настройка на IP адрес на ЦУ (ЦЗ и контролер)
-	При осъществяване на комуникацията по комуникационен протокол съгласно MODBUS TCP/IP	Потребителска настройка на MODBUS server адрес на ЦУ (ЦЗ и контролер)
6.	Предаване на данни :	Адресите на всички цифрови входове, цифрови изходи, аналогови входове и изчислени аналогови величини по съответният комуникационен протокол

Дата 31.10.2019 г.

Декларатор:

На основание чл.36а ал.3 от
ЗОП

1381