


ASEFA		Test report No.: F01.04.20 Page 30 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.08
Standard and clause	Kind of tests and requirements	Test values Results
8.3.5.2 8.3.6.4 8.3.7.6	ADDITIONAL SEQUENCE OF SHORT-CIRCUIT OPERATIONS ON FOUR POLE CIRCUIT-BREAKERS Test made on the same sample as for the three-pole short-circuit or on a new sample	same/new New
	Rated operational voltage U_e	690 V
	Test voltage	$U_e/\sqrt{3}$ 398 V
	Recovery voltage	$1.05 \times U_e/\sqrt{3}$ 418 V
	Rated ultimate short-circuit breaking capacity I_{cu}	25,2 kA
	Rated short-time withstand current I_{cw}	19,2 kA
	Short-circuit breaking capacity of the fourth pole (by arrangement) (not less than 60 % of I_{cu} or I_{cw} as applicable)	39 kA
Table 11	Power factor	0.25 0.25(+0,-0,05)
	Frequency	50 Hz 50 Hz
8.3.2.1 7.2.1.1.3	Control supply voltage	$0.85 \times U_e$./. V ./ . V
	Maximum value of the closing time	./ . ms ./ . ms
	Sequence of operation	O - t - CO O - t - CO
	Circuit diagram	Page 66 Page 66
	Calibration of the test circuit	Pageform 169 Next page
	Safety area	Pageform Page 65
	Installation of the material tested	Pageform Page 64
	Energization direction	Top/Bottom Top
60947-1 Table 9, 10 and 11	Cabling characteristics	
	Cable	./ . mm ² ./ . mm ²
	Bar	./ . x ./ . mm 100 x 10 mm
	Number	./ . 1
	Length	supply side ./ . mm 500 mm
		load side ./ . mm 500 mm
	Tightening torque	50 Nm

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005





TRF IEC/EN 60947-2
Ed. 2.1 form 48

Vertical stamp on the right edge of the page, partially obscured.


ASEFA		Test report No.: F01.04.20 Page 31 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.08
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.6	CALIBRATION OF THE TEST CIRCUIT	
	Oscillogram	20040283-0119 20040283-0122
	Applied voltage	448.56 V
	Frequency	50 Hz
	RMS current value at 20 ms	I_1 26.46 kA I_2 ./. kA I_3 ./. kA
	Average RMS. Value	26.46 kA
	Peak current maximum value	56.23 kA
	Power factor	0,2
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Form 169

Date August 19th 2008



ASEFA		Test report No.: F01.04.20 Page 32 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.08
Standard and clause	Kind of tests and requirements	Test values Results
	OPERATION "O"	
	Oscillogram	20040283.0123
	Peak current value	i_1 54.67 kA i_2 ./. kA i_3 ./. kA
	Maximum total duration	19 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input type="checkbox"/> or $U_{r(1-N)}$ <input checked="" type="checkbox"/> 432.12 V $U_{r(2-3)}$ <input type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> ./. V $U_{r(3-1)}$ <input type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> ./. V
	Average value	U_{rm} 432.12 V
	Ratio between U_{rm} and U_0	U_{rm}/U_0 1.08
	Joule integral	Ph_1 19.5 (kA) ² s Ph_2 ./. (kA) ² s Ph_3 ./. (kA) ² s
	Melting of the fusible element	Yes/No No
	Holes in the PE-sheet (if applicable)	Yes/No No
	Cracks observed if Yes	Yes/No No Page ./.
	Time interval between operations	3 min 4 min
	OPERATION "CO1"	
	Oscillogram	20040283.0124
	Applied voltage	435.05 V
	Peak current value	i_1 53.75 kA i_2 ./. kA i_3 ./. kA
	Maximum total duration	18.05 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input type="checkbox"/> or $U_{r(1-N)}$ <input checked="" type="checkbox"/> 434.56 V $U_{r(2-3)}$ <input type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> ./. V $U_{r(3-1)}$ <input type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> ./. V
	Average value	U_{rm} 434.56 V
	Ratio between U_{rm} and U_0	U_{rm}/U_0 1.09
	Joule integral	Ph_1 18.72 (kA) ² s Ph_2 ./. (kA) ² s Ph_3 ./. (kA) ² s
7.2.1.1.3	Closing operation time	./. ms
	Melting of the fusible element	Yes/No No
	Cracks observed if Yes	Yes/No No Page ./.
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		


Date August 19th 2005



ASEFA		Test report No.: F01.04.20 Page 33 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.08	
Standard and clause	Kind of tests and requirements	Test values Results	
	VERIFICATION OF DIELECTRIC WITHSTAND		
	Test voltage		
	2 x U _{cr} , min. 1000 V	1380 V	
8.3.3.5	Test sequence I		
8.3.4.3	Test sequence II		
8.3.5.3	Test sequence III		1380 V
8.3.6.5	Test sequence IV		
8.3.7.3	Test sequence V, stage 1		
8.3.7.7	Test sequence V, stage 2		
8.3.8.5	Combined test sequence		
B.10.3.1	Test sequence B.II		
A.5	Verification of discrimination		
A.6.3	Verification of back-up protection		
C.3	Individual pole short-circuit test sequence		
H.3	Test sequence for circuit-breakers for IT-systems		
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)		
	Test duration	5 s	5 s

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM


TRF IEC/EN 60947-2
Ed. 2.1 form 32/volta
Date August 1901 2008




ASEFA		Test report No.: F01.04.20 Page 34 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.08
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for isolation having an operational voltage U_n greater than 60 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	$1.1 \times U_n = 759 \text{ V}$ 759 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (in new condition)	$\leq 0.5 \text{ mA}$./ mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$./ mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$./ mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ 0 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$./ mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$./ mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$./ mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$./ mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$./ mA
H.3	Individual pole short-circuit test sequence I_{IT}	$\leq 6 \text{ mA}$./ mA

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005




ASEFA		Test report No.: F01.04.20	
Type test according to: IEC 60947-2 Test sequence III		Page 35 / 88	
Type: NS630bH to 1800H Sample 31042.08			
Standard and clause	Kind of tests and requirements	Test values Results	
VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY			
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	./. mm ²	./. mm ²
	Bar	100 x 5 mm	100 x 10 mm
	Number	2	1
	Length	./. mm	500 mm
	Tightening torque		50 Nm
	Reference temperature	40 °C ± 2 °C	
	Ambient temperature		21.3 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k		1
	Current setting value	I _n	1600 A
Test current			
	either k x 2.0 x I _n	./. A	./. A
8.3.5.1	Test sequence II (I _{cs} = I _{cu})	before 8.3.4.1	
8.3.5.1	Test sequence III	before 8.3.5.2	
8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5	
8.3.7.4	Test sequence V	before 8.3.7.5	
8.3.8.1	Combined test sequence	before 8.3.8.2	
A.5	Verification of discrimination	before 8.3.5.2	
A.6.3	Verification of back-up protection	before 8.3.5.2	
	or k x 2.5 x I _n	4000 A	4000 A
8.3.5.4	Test sequence II (I _{cs} = I _{cu})	after 8.3.4.5	
8.3.5.4	Test sequence III	after 8.3.5.3	
8.3.7.8	Test sequence V	after 8.3.7.7	
8.3.8.7	Combined test sequence	after 8.3.8.6	
A.5	Verification of discrimination	after 8.3.5.3	
A.6.3	Verification of back-up protection	after 8.3.5.3	
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		
Tripping time (for twice the value of current setting on single pole)			
	Neutral	≤ 270 s	126 s
	Ph1	≤ 270 s	131 s
	Ph2	≤ ./. s	./. s
	Ph3	≤ ./. s	./. s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM			
Date August 19th 2005		TRF IEC/EN 60947-2 Ed. 2.1 form 46	




ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 36 / 68
Type: NS630bH to 1600H Sample 31042.09		
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics	
	Cable $.l. mm^2$	$.l. mm^2$
	Bar 100 x 5 mm	100 x 10 mm
	Number 2	1
	Length $.l. mm$	500 mm
	Tightening torque	50 Nm
	Reference temperature 40 °C ± 2 °C	
	Ambient temperature	22.5 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k	1
	Current setting value I_n	1600 A
	Test current	
	either $k \times 2.0 \times I_n$	3200 A
8.3.5.1	Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1	
8.3.5.1	Test sequence III before 8.3.5.2	
8.3.6.1	Test sequence IV before 8.3.6.2	
8.3.6.6	Test sequence IV after 8.3.6.5	
8.3.7.4	Test sequence V before 8.3.7.5	
8.3.8.1	Combined test sequence before 8.3.8.2	
A.5	Verification of discrimination before 8.3.5.2	
A.6.3	Verification of back-up protection before 8.3.5.2	
	or $k \times 2.5 \times I_n$ $.l. A$	$.l. A$
8.3.5.4	Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5	
8.3.5.4	Test sequence III after 8.3.5.3	
8.3.7.8	Test sequence V after 8.3.7.7	
8.3.8.7	Combined test sequence after 8.3.8.6	
A.5	Verification of discrimination after 8.3.5.3	
A.6.3	Verification of back-up protection after 8.3.5.3	
C.4	Individual pole short-circuit test sequence	
H.4	Test sequence for circuit-breakers for IT-systems	
	Tripping time (for twice the value of current setting on single pole)	
	Neutral $\leq 270 s$	237 s
	Ph ₁ $\leq 270 s$	228 s
	Ph ₂ $\leq 270 s$	221 s
	Ph ₃ $\leq 270 s$	235 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
Date August 19th 2005		


TRF IEC/EN 60947-2
Ed. 2.1 form 46



ASEFA		Test report No.: F01.04.20 Page 37 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09	
Standard and clause	Kind of tests and requirements	Test values Results	
8.3.5.2	RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY		
	Utilization category	B	
	Rated operational voltage U_o	415 V	
	Recovery voltage	$1.05 \times U_o$	435.75 V
	Rated ultimate short-circuit breaking capacity	I_{cu}	70 kA
	Rated short-circuit making capacity	I_{cm}	154 kA
Table 11	Power factor	0.20	0.20
	Frequency	50 Hz	50 Hz
8.3.2.1	Control supply voltage	$0.85 \times U_s$ / V	/ V
7.2.1.1.3	Maximum value of the closing time		/ ms
	Sequence of operation	O - t - CO	O - t - CO
	Circuit diagram		Page 66
	Calibration of the test circuit	Pageform	Next page
	Safety area	Pageform	Page 65
	Installation of the material tested	Pageform	Page 64
	Energization direction	Top/Bottom	Top
8.3.2.1	Smallest individual enclosure (if applicable)		
	Type		/.
	Kind of material		/.
	Inside dimensions		
	Height		/ mm
	Width		/ mm
	Depth		/ mm
60947-1	Cabling characteristics		
Table 9, 10 and 11	Cable	/ mm ²	/ mm ²
	Bar	100 x 5 mm	100 x 10 mm
	Number	2	1
	Length	supply side / mm	350 mm
		load side / mm	350 mm
	Tightening torque		50 Nm
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM			
		Date August 19th 2005	

ASEFA		Test report No.: F01.04.20 Page 38 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT	
	Oscillogram	20040288-0003 20040288-0007
	Applied voltage	440.17 V
	Frequency	50 Hz / 50 Hz
	RMS current value at 20 ms	i_1 70.21 kA i_2 70.99 kA i_3 69.51 kA
	Average RMS. Value	70.23 kA
	Peak current maximum value	156.12 kA
	Power factor	0,17
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Ed. 2.1 form 169
Date August 19th 2005		

ASEFA		Test report No.: F01.04.20
		Page 39 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09
Standard and clause	Kind of tests and requirements	Test values Results
	OPERATION "O"	
	Oscillogram	20040288.0011
	Peak current value	I_1 123.58 kA
		I_2 111.73 kA
		I_3 66.26 kA
	Maximum total duration	12.8 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 443.07 V
		$U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 443.15 V
		$U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 443.16 V
	Average value	U_m 443.13 V
	Ratio between U_m and U_e	U_m/U_e 1.06
	Joule Integral	Ph_1 74.45 (kA) ² s
		Ph_2 63.58 (kA) ² s
		Ph_3 18.06 (kA) ² s
	Melting of the fusible element	Yes/No No
	Holes in the PE-sheet (if applicable)	Yes/No No
	Cracks observed	Yes/No No
	if Yes	Page ./.
	Time interval between operations	3 min 3 min
	OPERATION "CO1"	
	Oscillogram	20040288.0012
	Applied voltage	450.46 V
	Peak current value	I_1 118.6 kA
		I_2 114.5 kA
		I_3 65.68 kA
	Maximum total duration	13.8 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 444.72 V
		$U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 445.21 V
		$U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 443.97 V
	Average value	U_m 444.63 V
	Ratio between U_m and U_e	U_m/U_e 1.07
	Joule Integral	Ph_1 67.25 (kA) ² s
		Ph_2 67.14 (kA) ² s
		Ph_3 20.07 (kA) ² s
7.2.1.1.3	Closing operation time	./ ms
	Melting of the fusible element	Yes/No No
	Cracks observed	Yes/No No
	if Yes	Page ./.
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Ed. 2.1 form 41
Date August 19th 2005		


ASEFA		Test report No.: F01.04.20 Page 40 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U _n , min. 1000 V	1000 V
8.3.3.5	Test sequence I	1000 V
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 5 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Ed. 2.1 form 32/v01g
Date August 19th 2005		

ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 41 / 68
Type: NS630bH to 1600H Sample 31042.09		
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for Isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage	$1.1 \times U_o = 457 \text{ V}$ 457 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (in new condition)	$\leq 0.5 \text{ mA}$./. mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$./. mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$./. mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ 0.08 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$./. mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$./. mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$./. mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$./. mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$./. mA
H.3	Individual pole short-circuit test sequence I_{IT}	$\leq 6 \text{ mA}$./. mA

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM


Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2.1 form 28



ASEFA		Test report No.: F01.04.20 Page 42 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.09
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics Cable I_n mm ² Bar 100 x 5 mm Number 2 Length I_n mm Tightening torque Reference temperature 40 °C ± 2 °C Ambient temperature Correction factor ($k = 1$ for releases independent of ambient temperature) k Current setting value I_n	I_n mm ² 100 x 5 mm 2 500 mm 50 Nm 18.4 °C 1 1600 A
	Test current	
	either $k \times 2.0 \times I_n$	I_n A
8.3.5.1	Test sequence II ($I_{cs} = I_{cu}$) before 8.3.4.1	
8.3.5.1	Test sequence III before 8.3.5.2	
8.3.6.1	Test sequence IV before 8.3.6.2	
8.3.6.6	Test sequence IV after 8.3.6.5	
8.3.7.4	Test sequence V before 8.3.7.5	
8.3.8.1	Combined test sequence before 8.3.8.2	
A.5	Verification of discrimination before 8.3.5.2	
A.6.3	Verification of back-up protection before 8.3.5.2	
	or $k \times 2.5 \times I_n$ 4000 A	4000 A
8.3.5.4	Test sequence II ($I_{cs} = I_{cu}$) after 8.3.4.5	
8.3.5.4	Test sequence III after 8.3.5.3	
8.3.7.8	Test sequence V after 8.3.7.7	
8.3.8.7	Combined test sequence after 8.3.8.6	
A.5	Verification of discrimination after 8.3.5.3	
A.6.3	Verification of back-up protection after 8.3.5.3	
C.4	Individual pole short-circuit test sequence	
H.4	Test sequence for circuit-breakers for IT-systems	
	Tripping time (for twice the value of current setting on single pole)	
	Neutral ≤ 270 s	124 s
	Ph ₁ ≤ 270 s	130 s
	Ph ₂ ≤ 270 s	128 s
	Ph ₃ ≤ 270 s	126 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Ed. 2.1 from 16 JAN 2005
Date August 19th 2005		

ASEFA		Test report No.: F01.04.20 Page 43 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.10
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics	
	Cable ./ mm²	185 mm ²
	Bar 40 x 5 mm	./ x ./ mm
	Number 2	1
	Length ./ mm	500 mm
	Tightening torque	50 Nm
	Reference temperature 40 °C ± 2 °C	
	Ambient temperature	22 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k	1
	Current setting value I_n	630*0.4=252A
	Test current	
	either k x 2.0 x I _n 504 A	504 A
8.3.5.1	Test sequence II (I _{cs} = I _{cu}) before 8.3.4.1	
8.3.5.1	Test sequence III before 8.3.5.2	
8.3.6.1	Test sequence IV before 8.3.6.2	
8.3.6.6	Test sequence IV after 8.3.6.5	
8.3.7.4	Test sequence V before 8.3.7.5	
8.3.8.1	Combined test sequence before 8.3.8.2	
A.5	Verification of discrimination before 8.3.5.2	
A.6.3	Verification of back-up protection before 8.3.5.2	
	or k x 2.5 x I _n ./ A	./ A
8.3.5.4	Test sequence II (I _{cs} = I _{cu}) after 8.3.4.5	
8.3.5.4	Test sequence III after 8.3.5.3	
8.3.7.8	Test sequence V after 8.3.7.7	
8.3.8.7	Combined test sequence after 8.3.8.6	
A.5	Verification of discrimination after 8.3.5.3	
A.6.3	Verification of back-up protection after 8.3.5.3	
C.4	Individual pole short-circuit test sequence	
H.4	Test sequence for circuit-breakers for IT-systems	
	Tripping time (for twice the value of current setting on single pole)	
	Neutral ≤ 270 s	207 s
	Ph ₁ ≤ 270 s	212 s
	Ph ₂ ≤ 270 s	225 s
	Ph ₃ ≤ 270 s	217 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Ed: 2.1 form 46
		Date August 19th 2005




ASEFA		Test report No.: F01.04.20
		Page 44 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.10
Standard and clause	Kind of tests and requirements	Test values Results
8.3.5.2	RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY	
	Utilization category	B
	Rated operational voltage U_n	415 V
	Recovery voltage	$1.05 \times U_n$ 435.75 V
	Rated ultimate short-circuit breaking capacity	I_{cu} 70 kA
	Rated short-circuit making capacity	I_{cm} 154 kA
Table 11	Power factor	0,20 0.20(+0,-0,05)
	Frequency	50 Hz 50 Hz
8.3.2.1	Control supply voltage	$0.85 \times U_n$./. V ./. V
7.2.1.1.3	Maximum value of the closing time	./. ms
	Sequence of operation	O - t - CO O - t - CO
	Circuit diagram	Page 66
	Calibration of the test circuit	Pageform Next page
	Safety area	Pageform Page 65
	Installation of the material tested	Pageform Page 64
	Energization direction	Top/Bottom Top
8.3.2.1	Smallest individual enclosure (if applicable)	
	Type	./.
	Kind of material	./.
	Inside dimensions	
	Height	./. mm
	Width	./. mm
	Depth	./. mm
60947-1	Cabling characteristics	
Table 9, 10 and 11	Cable	./. mm ² ./. mm ²
	Bar	40 x 5 mm 40 x 5 mm
	Number	2 2
	Length	supply side ./. mm 350 mm
		load side ./. mm 350 mm
	Tightening torque	50 Nm

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 10th 2005



IEC/EN 60947-2
Ed. 21 form 47


ASEFA		Test report No.: F01.04.20 Page 45 / 68	
Type test according to: IEC 60947-2		Type: NS630bH to 1600H Sample 31042.10	
Standard and clause	Kind of tests and requirements	Test values Results	
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CRCUIT		
	Oscillogram	20040288-0003 20040288-0007	
	Applied voltage	440.17 V	
	Frequency	50 Hz	
	RMS current value at 20 ms	I_1	70.21 kA
		I_2	70.99 kA
		I_3	69.51 kA
	Average RMS. Value	70.23 kA	
Peak current maximum value	156.12 kA		
Power factor	0,17		
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		 IEC/EN 60947-2 Ed. 2.3 form 169 Date August 19th 2006	

ASEFA		Test report No.: F01.04.20
		Page 46 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.10
Standard and clause	Kind of tests and requirements	Test values Results
	OPERATION "O"	
	Oscillogram	20040288.0013
	Peak current value	I_1 122.69 kA
		I_2 114.04 kA
		I_3 69.83 kA
	Maximum total duration	13,45 ms
	Recovery voltage	443.07 V
	(phase to phase or phase to neutral)	443.52 V
		443.19 V
	Average value	U_{mm} 443.26 V
	Ratio between U_{mm} and U_0	U_{mm}/U_0 1.06
	Joule Integral	Ph ₁ 75.29 (kA) ² s
		Ph ₂ 67.36 (kA) ² s
		Ph ₃ 20.94 (kA) ² s
	Melting of the fusible element	Yes/No No
	Holes in the PE-sheet (if applicable)	Yes/No No
	Cracks observed	Yes/No No
	if Yes	Page ./.
	Time interval between operations	3 min 3 min
	OPERATION "CO1"	
	Oscillogram	20040288.0014
	Applied voltage	448.34 V
	Peak current value	I_1 70.71 kA
		I_2 109.66 kA
		I_3 123.37 kA
	Maximum total duration	14,4 ms
	Recovery voltage	442.94 V
	(phase to phase or phase to neutral)	442.13 V
		442.98 V
	Average value	U_{mm} 442.68 V
	Ratio between U_{mm} and U_0	U_{mm}/U_0 1.06
	Joule integral	Ph ₁ 27.23 (kA) ² s
		Ph ₂ 49.66 (kA) ² s
		Ph ₃ 79.18 (kA) ² s
	Closing operation time	./ ms
7.2.1.1.3	Melting of the fusible element	Yes/No No
	Cracks observed	Yes/No No
	if Yes	Page ./.


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 16th 2005


TRF IEC/EN 60947-2
Ed. 2.1 form 41




20040288.0013
 20040288.0014

ASEFA		Test report No.: F01.04.20 Page 47 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.10
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U_e , min. 1000 V	1000 V
8.3.3.5	Test sequence I	1000 V
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 5 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		 Date August 19th 2005

ASEFA		Test report No.: F01.04.20 Page 48 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.10
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage $1.1 \times U_o = 457 \text{ V}$	457 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (in new condition)	$\leq 0.5 \text{ mA}$ / mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$ / mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$ / mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ 0.05 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$ / mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$ / mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$ / mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$ / mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$ / mA
H.3	Individual pole short-circuit test sequence I_{IT}	$\leq 6 \text{ mA}$ / mA
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
Date August 19th 2005		




ASEFA		Test report No.: F01.04.20	
Type test according to: IEC 60947-2 Test sequence III		Page 49 / 68	
Standard and clause		Kind of tests and requirements	
		Test values Results	
VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY			
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	./. mm ²	185 mm ²
	Bar	40 x 5 mm	./ x ./ mm
	Number	2	1
	Length	./ mm	500 mm
	Tightening torque		50 Nm
	Reference temperature	40 °C ± 2 °C	
	Ambient temperature		20.6 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k		1
	Current setting value	I _n	630*0.4=252A
Test current			
	either k x 2.0 x I _n	./ A	./ A
8.3.5.1	Test sequence II (I _{cs} = I _{cu})	before 8.3.4.1	
8.3.5.1	Test sequence III	before 8.3.5.2	
8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5	
8.3.7.4	Test sequence V	before 8.3.7.5	
8.3.8.1	Combined test sequence	before 8.3.8.2	
A.5	Verification of discrimination	before 8.3.5.2	
A.6.3	Verification of back-up protection	before 8.3.5.2	
	or k x 2.5 x I _n	630 A	630 A
8.3.5.4	Test sequence II (I _{cs} = I _{cu})	after 8.3.4.5	
8.3.5.4	Test sequence III	after 8.3.5.3	
8.3.7.8	Test sequence V	after 8.3.7.7	
8.3.8.7	Combined test sequence	after 8.3.8.6	
A.5	Verification of discrimination	after 8.3.5.3	
A.6.3	Verification of back-up protection	after 8.3.5.3	
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		
Tripping time (for twice the value of current setting on single pole)			
	Neutral	≤ 270 s	131 s
	Ph ₁	≤ 270 s	136 s
	Ph ₂	≤ 270 s	127 s
	Ph ₃	≤ 270 s	127 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM			
Date August 19th 2005			



ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 50 / 68
Type: NS630bH to 1600H Sample 31042.11		
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics Cable $.l. \text{ mm}^2$ Bar 100 x 5 mm Number 2 Length $.l. \text{ mm}$ Tightening torque Reference temperature $40 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$ Ambient temperature Correction factor ($k = 1$ for releases independent of ambient temperature) k Current setting value I_n Test current either $k \times 2.0 \times I_n$ 3200 A 8.3.5.1 Test sequence II ($I_{cs} = I_{ca}$) before 8.3.4.1 8.3.5.1 Test sequence III before 8.3.5.2 8.3.6.1 Test sequence IV before 8.3.6.2 8.3.6.6 Test sequence IV after 8.3.6.5 8.3.7.4 Test sequence V before 8.3.7.5 8.3.8.1 Combined test sequence before 8.3.8.2 A.5 Verification of discrimination before 8.3.5.2 A.6.3 Verification of back-up protection before 8.3.5.2 or $k \times 2.5 \times I_n$ $.l. \text{ A}$ 8.3.5.4 Test sequence II ($I_{cs} = I_{ca}$) after 8.3.4.5 8.3.5.4 Test sequence III after 8.3.5.3 8.3.7.8 Test sequence V after 8.3.7.7 8.3.8.7 Combined test sequence after 8.3.8.6 A.5 Verification of discrimination after 8.3.5.3 A.6.3 Verification of back-up protection after 8.3.5.3 C.4 Individual pole short-circuit test sequence H.4 Test sequence for circuit-breakers for IT-systems Tripping time (for twice the value of current setting on single pole) Neutral $\leq 270 \text{ s}$ Ph ₁ $\leq 270 \text{ s}$ Ph ₂ $\leq 270 \text{ s}$ Ph ₃ $\leq 270 \text{ s}$	$.l. \text{ mm}^2$ 100 x 5 mm 2 500 mm 50 Nm 22 $^\circ\text{C}$ 1 1600 A 3200 A 3200 A $.l. \text{ A}$ $.l. \text{ A}$ 228 s 204 s 215 s 226 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		

Date August 19th 2005



IEC/EN 60947-2
Ed. 2.1 form 18



ASEFA		Test report No.: F01.04.20 Page 51 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.11	
Standard and clause	Kind of tests and requirements	Test values Results	
8.3.5.2	RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY		
	Utilization category	B	
	Rated operational voltage U_e	440 V	
	Recovery voltage	$1.05 \times U_e$	462 V
	Rated ultimate short-circuit breaking capacity	I_{cu}	65 kA
	Rated short-circuit making capacity	I_{cm}	143 kA
Table 11	Power factor	0.20	0.20
	Frequency	50 Hz	50 Hz
8.3.2.1	Control supply voltage	$0.85 \times U_e$./. V	./. V
7.2.1.1.3	Maximum value of the closing time		./. ms
	Sequence of operation	O - t - CO	O - t - CO
	Circuit diagram		Page 66
	Calibration of the test circuit	Pageform	Next page
	Safety area	Pageform	Page 65
	Installation of the material tested	Pageform	Page 64
	Energization direction	Top/Bottom	Top
8.3.2.1	Smallest individual enclosure (if applicable)		
	Type		./.
	Kind of material		./.
	Inside dimensions		
	Height		./. mm
	Width		./. mm
	Depth		./. mm
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	./. mm ²	./. mm ²
	Bar	100 x 5 mm	100 x 10 mm
	Number	2	1
	Length	supply side ./. mm	350 mm
		load side ./. mm	350 mm
	Tightening torque		50 Nm


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005



ASEFA		Test report No.: F01.04.20 Page 52 / 68
Type test according to: IEC 60947-2		Type: NS630bH to 1600H Sample 31042.11
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CIRCUIT	
	Oscillogram	20040288-0015 20040288-0018
	Applied voltage	474.23 V
	Frequency	50 Hz 50 Hz
	RMS current value at 20 ms	I_1 66.54 kA I_2 66.80 kA I_3 64.32 kA
	Average RMS. Value	65.89 kA
	Peak current maximum value	139.08 kA
	Power factor	0,17
	Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM	

Date August 19th 2005




20050819
 07:11:11
 07:11:11


ASEFA		Test report No.: F01.04.20 Page 53 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.11	
Standard and clause	Kind of tests and requirements	Test values Results	
7.2.1.1.3	OPERATION "O"	20040288.0019	
	Oscillogram		
	Peak current value	I_1	113.30 kA
		I_2	100.34 kA
		I_3	73.62 kA
	Maximum total duration		14.5 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/>	466.08 V
		$U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/>	466.46 V
		$U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/>	466.07 V
	Average value	U_m	466.21 V
	Ratio between U_m and U_e	U_m/U_e	1.05
	Joule Integral	Ph ₁	65.85 (kA) ² s
		Ph ₂	51.57 (kA) ² s
		Ph ₃	20.68 (kA) ² s
	Melting of the fusible element	Yes/No	No
	Holes in the PE-sheet (if applicable)	Yes/No	No
	Cracks observed	Yes/No	No
	If Yes		Page ./.
	Time Interval between operations	3 min	3 min
7.2.1.1.3	OPERATION "CO1"	20040288.0020	
	Oscillogram		
	Applied voltage		474.53 V
	Peak current value	I_1	109.61 kA
		I_2	97.03 kA
		I_3	77.15 kA
	Maximum total duration		20.25 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/>	468.37 V
		$U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/>	468.39 V
		$U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/>	468.21 V
	Average value	U_m	468.32 V
	Ratio between U_m and U_e	U_m/U_e	1.06
	Joule integral	Ph ₁	59.66 (kA) ² s
		Ph ₂	47.00 (kA) ² s
		Ph ₃	22.24 (kA) ² s
	Closing operation time		./ ms
	Melting of the fusible element	Yes/No	No
	Cracks observed	Yes/No	No
	If Yes		Page ./.

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005



TRF IEC/EN 60947-2
E01.2.1 form 41

ASEFA		Test report No.: F01.04.20 Page 54 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.11
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U _e , min. 1000 V	1000 V
8.3.3.5	Test sequence I	1000 V
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s 5 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		Date August 19th 2005

1000 V
 5 s
 5 s

ASEFA		Test report No.: F01.04.20 Page 55 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.11	
Standard and clause	Kind of tests and requirements	Test values Results	
	VERIFICATION OF LEAKAGE CURRENT		
	For circuit-breakers suitable for Isolation having an operational voltage U_o greater than 50 V.		
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)		
	Test voltage	$1.1 \times U_o = 484 \text{ V}$	484 V
60947-1 7.2.7	Application of the test voltage		
	Leakage current		
8.3.3.2	Test sequence I (In new condition)	$\leq 0.5 \text{ mA}$./. mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$./. mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$./. mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$	0.5 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$./. mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$./. mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$./. mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$./. mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$./. mA
H.3	Individual pole short-circuit test sequence I_{IT}	$\leq 6 \text{ mA}$./. mA
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM			
		Date August 19th 2005	


СЕРТИФИКАТ
 НА
 АСЕКВА
 ПЛАТФОРМА
 № 001/05

ASEFA		Test report No.: F01.04.20
Type test according to: IEC 60947-2 Test sequence III		Page 56 / 68
Type: NS630bH to 1600H Sample 31042.11		
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY	
60947-1 Table 9, 10 and 11	Cabling characteristics Cable I_n mm ² Bar 100 x 5 mm Number 2 Length l_n mm Tightening torque Reference temperature 40 °C ± 2 °C Ambient temperature Correction factor (k = 1 for releases independent of ambient temperature) k Current setting value I_n	I_n mm ² 100 x 5 mm 2 500 mm 50 Nm 18.4 °C 1 1600 A
	Test current	
	either $k \times 2.0 \times I_n$	I_n A
8.3.5.1	Test sequence II ($I_{cs} = I_{cr}$) before 8.3.4.1	
8.3.5.1	Test sequence III before 8.3.5.2	
8.3.6.1	Test sequence IV before 8.3.6.2	
8.3.6.6	Test sequence IV after 8.3.6.5	
8.3.7.4	Test sequence V before 8.3.7.5	
8.3.8.1	Combined test sequence before 8.3.8.2	
A.5	Verification of discrimination before 8.3.5.2	
A.6.3	Verification of back-up protection before 8.3.5.2	
	or $k \times 2.5 \times I_n$	4000 A
8.3.5.4	Test sequence II ($I_{cs} = I_{cr}$) after 8.3.4.5	
8.3.5.4	Test sequence III after 8.3.5.3	
8.3.7.8	Test sequence V after 8.3.7.7	
8.3.8.7	Combined test sequence after 8.3.8.6	
A.5	Verification of discrimination after 8.3.5.3	
A.6.3	Verification of back-up protection after 8.3.5.3	
C.4	Individual pole short-circuit test sequence	
H.4	Test sequence for circuit-breakers for IT-systems	
	Tripping time (for twice the value of current setting on single pole)	
	Neutral ≤ 270 s	137 s
	Ph ₁ ≤ 270 s	136 s
	Ph ₂ ≤ 270 s	132 s
	Ph ₃ ≤ 270 s	134 s


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2.1 form 49



ASEFA		Test report No.: F01.04.20 Page 57 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.12	
Standard and clause	Kind of tests and requirements	Test values Results	
	VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY		
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	./. mm ²	./. mm ²
	Bar	100 x 5 mm	100 x 5 mm
	Number	2	2
	Length	./. mm	500 mm
	Tightening torque		50 Nm
	Reference temperature	40 °C ± 2 °C	
	Ambient temperature		22.5 °C
	Correction factor (k = 1 for releases independent of ambient temperature) k		1
	Current setting value	I _n	1800 A
	Test current		
	either k x 2.0 x I _n	3200 A	3200 A
8.3.5.1	Test sequence II (I _{cs} = I _{cu})	before 8.3.4.1	
8.3.5.1	Test sequence III	before 8.3.5.2	
8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5	
8.3.7.4	Test sequence V	before 8.3.7.5	
8.3.8.1	Combined test sequence	before 8.3.8.2	
A.5	Verification of discrimination	before 8.3.5.2	
A.6.3	Verification of back-up protection	before 8.3.5.2	
	or k x 2.5 x I _n	./. A	./. A
8.3.5.4	Test sequence II (I _{cs} = I _{cu})	after 8.3.4.5	
8.3.5.4	Test sequence III	after 8.3.5.3	
8.3.7.8	Test sequence V	after 8.3.7.7	
8.3.8.7	Combined test sequence	after 8.3.8.6	
A.5	Verification of discrimination	after 8.3.5.3	
A.6.3	Verification of back-up protection	after 8.3.5.3	
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		
	Tripping time (for twice the value of current setting on single pole)		
	Neutral	≤ 270 s	223 s
	Ph ₁	≤ 270 s	230 s
	Ph ₂	≤ 270 s	222 s
	Ph ₃	≤ 270 s	227 s
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Ed. 2.1 form 46	
		Date August 19th 2005	





ASEFA		Test report No.: F01.04.20
		Page 58 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.12
Standard and clause	Kind of tests and requirements	Test values Results
8.3.5.2	RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY	
	Utilization category B	
	Rated operational voltage U_0 690 V	
	Recovery voltage $1.05 \times U_0$	724.5 V
	Rated ultimate short-circuit breaking capacity I_{cu}	42 kA
	Rated short-circuit making capacity I_{cm}	88.2 kA
Table 11	Power factor 0.25	0.25(+0,-0.05)
	Frequency 50 Hz	50 Hz
8.3.2.1	Control supply voltage $0.85 \times U_s$./. V	./.. V
7.2.1.1.3	Maximum value of the closing time	./.. ms
	Sequence of operation O - t - CO	O - t - CO
	Circuit diagram	Page 66
	Calibration of the test circuit	Next page
	Safety area	Page 65
	Installation of the material tested	Page 64
	Energization direction	Bottom
8.3.2.1	Smallest individual enclosure (if applicable)	
	Type	./..
	Kind of material	./..
	Inside dimensions	
	Height	./.. mm
	Width	./.. mm
	Depth	./.. mm
60947-1	Cabling characteristics	
Table 9, 10 and 11	Cable	./.. mm ²
	Bar	100 x 5 mm
	Number	2
	Length	supply side ./.. mm
		load side ./.. mm
	Tightening torque	50 Nm


Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

STRF IEC/EN 60947-2
Ed. 2.1.01/47



ASEFA		Test report No.: F01.04.20 Page 59 / 68
Type test according to: IEC 60947-2		Type: NS630bH to 1600H Sample 31042.12
Standard and clause	Kind of tests and requirements	Test values Results
60947-1 8.3.4.1.5	CALIBRATION OF THE TEST CRUIT	
	Oscillogram	20040283-0141 20040283-0150
	Applied voltage	735,65 V
	Frequency	50 Hz
	RMS current value at 20 ms	I_1 42.00 kA I_2 42.32 kA I_3 43.26 kA
	Average RMS. Value	42.49 kA
	Peak current maximum value	91.48 kA
	Power factor	0,21
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		TRF IEC/EN 60947-2 Ed. 2.1 form 16 
		Date August 19th 2005


ASEFA		Test report No.: F01.04.20 Page 60 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.12
Standard and clause	Kind of tests and requirements	Test values Results
	OPERATION "O"	
	Oscillogram	20040283.0161
	Peak current value	i_1 59.64 kA i_2 71.74 kA i_3 82.66 kA
	Maximum total duration	21.05 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 732.16 V $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 720.65 V $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 735.93 V
	Average value	U_{mm} 729.58 V
	Ratio between U_{mm} and U_o	U_{mm}/U_o 1.05
	Joule Integral	Ph ₁ 22.48 (kA) ² s Ph ₂ 27.82 (kA) ² s Ph ₃ 43.40 (kA) ² s
	Melting of the fusible element	Yes/No No
	Holes in the PE-sheet (if applicable)	Yes/No No
	Cracks observed if Yes	Yes/No No Page ./.
	Time interval between operations	3 min 4 min
	OPERATION "CO1"	
	Oscillogram	20040283.0162
	Applied voltage	764.24 V
	Peak current value	i_1 77.04 kA i_2 49.95 kA i_3 75.50 kA
	Maximum total duration	18.4 ms
	Recovery voltage (phase to phase or phase to neutral)	$U_{r(1-2)}$ <input checked="" type="checkbox"/> or $U_{r(1-N)}$ <input type="checkbox"/> 736.72 V $U_{r(2-3)}$ <input checked="" type="checkbox"/> or $U_{r(2-N)}$ <input type="checkbox"/> 727.47 V $U_{r(3-1)}$ <input checked="" type="checkbox"/> or $U_{r(3-N)}$ <input type="checkbox"/> 728.68 V
	Average value	U_{mm} 730.96 V
	Ratio between U_{mm} and U_o	U_{mm}/U_o 1.05
	Joule Integral	Ph ₁ 36.63 (kA) ² s Ph ₂ 18.67 (kA) ² s Ph ₃ 31.43 (kA) ² s
7.2.1.1.3	Closing operation time	./ ms
	Melting of the fusible element	Yes/No No
	Cracks observed if Yes	Yes/No No
Test laboratory: F01- GRENOBLE ASEFA recognised PLATFORM		
		Date August 19th 2005

ASEFA		Test report No.: F01.04.20 Page 61 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.12
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF DIELECTRIC WITHSTAND	
	Test voltage	
	2 x U_n , min. 1000 V	1380 V
8.3.3.5	Test sequence I	
8.3.4.3	Test sequence II	
8.3.5.3	Test sequence III	1380 V
8.3.6.5	Test sequence IV	
8.3.7.3	Test sequence V, stage 1	
8.3.7.7	Test sequence V, stage 2	
8.3.8.5	Combined test sequence	
B.10.3.1	Test sequence B.II	
A.5	Verification of discrimination	
A.6.3	Verification of back-up protection	
C.3	Individual pole short-circuit test sequence	
H.3	Test sequence for circuit-breakers for IT-systems	
8.3.3.2.2 a)	Application of the test voltage -Main circuit of the circuit-breaker -Isolating contacts of the withdrawable unit (if applicable)	
	Test duration	5 s
		5 s

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2:1 form 32
modified




ASEFA		Test report No.: F01.04.20 Page 62 / 68
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.12
Standard and clause	Kind of tests and requirements	Test values Results
	VERIFICATION OF LEAKAGE CURRENT	
	For circuit-breakers suitable for isolation having an operational voltage U_o greater than 50 V.	
8.3.3.2	- Main circuit of the circuit-breaker - Isolating contacts of a withdrawable unit (if applicable)	
	Test voltage $1.1 \times U_o = 759 \text{ V}$	759 V
60947-1 7.2.7	Application of the test voltage	
	Leakage current	
8.3.3.2	Test sequence I (In new condition)	$\leq 0.5 \text{ mA}$ / mA
8.3.3.5	Test sequence I (after overload performance)	$\leq 2 \text{ mA}$ / mA
8.3.4.3	Test sequence II	$\leq 2 \text{ mA}$ / mA
8.3.5.3	Test sequence III	$\leq 6 \text{ mA}$ 0.5 mA
8.3.6.5	Test sequence IV	$\leq 2 \text{ mA}$ / mA
8.3.7.3	Test sequence V, stage 1	$\leq 2 \text{ mA}$ / mA
8.3.7.7	Test sequence V, stage 2	$\leq 6 \text{ mA}$ / mA
8.3.8.5	Combined test sequence	$\leq 2 \text{ mA}$ / mA
C.3	Individual pole short-circuit test sequence I_{su}	$\leq 6 \text{ mA}$ / mA
H.3	Individual pole short-circuit test sequence I_{tr}	$\leq 6 \text{ mA}$ / mA

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

Date August 19th 2005

TRF IEC/EN 60947-2
Ed. 2.1 form 25





ASEFA		Test report No.: F01.04.20 Page 63 / 68	
Type test according to: IEC 60947-2 Test sequence III		Type: NS630bH to 1600H Sample 31042.12	
Standard and clause	Kind of tests and requirements	Test values Results	
VERIFICATION OF OVERLOAD RELEASES ON EACH POLE SEPARATELY			
60947-1 Table 9, 10 and 11	Cabling characteristics		
	Cable	./. mm ²	./. mm ²
	Bar	100 x 5 mm	100 x 5 mm
	Number	2	2
	Length	./. mm	3000 mm
	Tightening torque		50 Nm
	Reference temperature	40 °C ± 2 °C	
	Ambient temperature		19.9 °C
	Correction factor (k = 1 for releases independent of ambient temperature) K		1
	Current setting value	I _n	1600 A
Test current			
	either k x 2.0 x I _n	./. A	./. A
8.3.5.1	Test sequence II (I _{cs} = I _{cu})	before 8.3.4.1	
8.3.5.1	Test sequence III	before 8.3.5.2	
8.3.6.1	Test sequence IV	before 8.3.6.2	
8.3.6.6	Test sequence IV	after 8.3.6.5	
8.3.7.4	Test sequence V	before 8.3.7.5	
8.3.8.1	Combined test sequence	before 8.3.8.2	
A.5	Verification of discrimination	before 8.3.5.2	
A.6.3	Verification of back-up protection	before 8.3.5.2	
	or k x 2.5 x I _n	4000 A	4000 A
8.3.5.4	Test sequence II (I _{cs} = I _{cu})	after 8.3.4.5	
8.3.5.4	Test sequence III	after 8.3.5.3	
8.3.7.8	Test sequence V	after 8.3.7.7	
8.3.8.7	Combined test sequence	after 8.3.8.6	
A.5	Verification of discrimination	after 8.3.5.3	
A.6.3	Verification of back-up protection	after 8.3.5.3	
C.4	Individual pole short-circuit test sequence		
H.4	Test sequence for circuit-breakers for IT-systems		
	Tripping time (for twice the value of current setting on single pole)		
	Neutral	≤ 270 s	120 s
	Ph ₁	≤ 270 s	118 s
	Ph ₂	≤ 270 s	127 s
	Ph ₃	≤ 270 s	132 s

Test laboratory: F01- GRENOBLE
ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
Ed. 2.1 form 48

Date August 19th 2005




ASEFA	Test report No.: F01.04.20 Page 64 / 68
Type test according to: IEC 60947-2 Test sequence III	Type: NS630bH to 1600H
<p><u>INSTALLATION</u></p> <p>The apparatus is set up on a metallic structure, in individual enclosure, fixed on insulated bars. The safety perimeter is materialised by a metallic enclosure (see next page) connected to the neutral by a fuse.</p> <p>The apparatus are operated with an air actuator.</p>	
Test laboratory: F01 GRENOBLE ASEFA recognized PLATFORM	TRF IEC/EN 60947-2 F01-2011 F01H 170 Date August 10th 2005 


ASEFA	Test report No.: F01.04.20 Page : 66 / 68
Type test according to: IEC 60947-2	Type: NS630bH to 1600H

DIAGRAM OF THE TEST CIRCUIT

TEST OF RATED ULTIMATE SHORT-CIRCUIT BREAKING CAPACITY



VERIFICATION OF OPERATIONAL CAPABILITY



Test laboratory: F01 - GRENOBLE
 ASEFA recognised PLATFORM

TRF IEC/EN 60947-2
 Ed 2.1 form 17



**ВЯРНО С
 ОПРИМНАТА**


ASEFA

Test report No.: F01.04.20
Page 67 / 68


Type test according to: IEC 60947-2
Test sequence III

Type: NS630bH to 1600H

PHOTOGRAPHIE OF THE ASSEMBLY



Test laboratory: F01 - GRENOBLE
ASEFA recognised PLATFORM



TRF IEC/EN 60947-2
Ed 2.1 for 1970

Date August 19th 2008

БІЛІНГ
ОПТИМАЛІА

ASEFA	Test report No.: F01.04.20 Page : 68 / 68
--------------	--

Type test according to: IEC 60947-2 Test sequence III	Type: NS630bH to 1600H
--	------------------------

APPENDICES

APPARATUS CHARACTERISTICS

General view circuit-breaker Tripping curve Micrologic 5.0A	GHD 1189100 Indice B 51156273AA 1/1
--	--

OSCILLOGRAMS


Calibration voltage	20040283 - 0102
Calibration current	20040283 - 0103
ASEFA 31 042.05 Opening	20040283 - 0104
ASEFA 31 042.05 Closing/Opening 1	20040283 - 0105
ASEFA 31 042.06 Opening	20040283 - 0106
ASEFA 31 042.06 Closing/Opening 1	20040283 - 0107
Calibration voltage	20040283 - 0108
Calibration current	20040283 - 0113
ASEFA 31 042.07 Opening	20040283 - 0116
ASEFA 31 042.07 Closing/Opening 1	20040283 - 0117
Calibration voltage	20040283 - 0119
Calibration current	20040283 - 0122
ASEFA 31 042.08 Opening	20040283 - 0123
ASEFA 31 042.08 Closing/Opening 1	20040283 - 0124
Calibration voltage	20040288 - 0003
Calibration current	20040288 - 0007
ASEFA 31 042.09 Opening	20040288 - 0011
ASEFA 31 042.09 Closing/Opening 1	20040288 - 0012
ASEFA 31 042.10 Opening	20040288 - 0013
ASEFA 31 042.10 Closing/Opening 1	20040288 - 0014
Calibration voltage	20040288 - 0015
Calibration current	20040288 - 0018
ASEFA 31 042.11 Opening	20040288 - 0019
ASEFA 31 042.11 Closing/Opening 1	20040288 - 0020
Calibration voltage	20040283 - 0141
Calibration current	20040283 - 0150
ASEFA 31 042.12 Opening	20040283 - 0161
ASEFA 31 042.12 Closing/Opening 1	20040283 - 0162

Test laboratory: F01 - GRENOBLE
ASEFA recognised PLATFORM




**ВІСНОВОК
ОПРИЙМАНА**

GENERAL VIEW - FIGURE 1





**ВЪРНО С
ОРИГИНАЛА**



OFF (1)

In (A)	800	2000	4000	6000	8300
N1	42 KA				
H1	65 KA				
H2	82 KA				
H3					
L1					

02	09/06/99	Rajout des crans 0 à 0,4	JOUBERT	GRELIER	
Ind / Rev	Date / Date	Modification / Modification	Nom/Name	Visa	Nom/Name
			Préparé/Issued by	Préparé/Issued by	Archivé/ Microfil.
Projet / Projet: Compact NS630b à NS1600			DISJONCTEUR FIXE ET DEBROCHABLE		
Dossier / Folder:			Courbe de déclenchement pour déclencheurs Micrologie 5.0, 6.0, 7.0		
 GROUPE SCHNEIDER			Code ent. / Distrib. code	Unité / Département	Ind/Rev
				DBTP	5,1,1,5,6
					Folio/Sheet: 01

ВЪПРОС
 ОПИТНАТА


12.00 ms/cm

450.00 ms

10.00 ms

Calibration of the test circuit Current

42KA 88kA 236V+5% COS0.25



U12
599.00 V/cm

**ВЯРНО С
ОРИГИНАЛА**



CATIE V.1.5.3.129 page 001

F01 20040283 - 0102

Effectué le 06/12/2004 17:12:28
Edité le 06/12/2004 17:53:53

450,00 ms


150,00 ms

12,00 ms/cm

10,00 ms

Calibration of the test circuit V

42kA 88kA 236V +5% cos0.25



U12 789,00 V/cm

**БЯРНО С
ОРИГОНАЛА**



Effectué le 06/12/2004 17:28:35
Edité le 06/12/2004 17:52:59

F01 20040283 - 0103


CATIE V:1.5.3.129 page 001

150.00 ms
12.00 ms/cm
10.00 ms

450.00 ms

O ASEFA 31042 Sample05

42KA 88KA 236V+5% COS0.25



U12
399.00 V/cm



БРФО С
ОПМТНАЛТА

450,00 ms


150,00 ms

12,00 ms/cm

10,00 ms

CO ASEFA 31042 Sample 05


42KA 88kA 236V+5% COS0.25



U12

399,00 V/cm

БРФО С
ОПМТНАМА



СНИМЪТЪТ 129 page 001

F01 20040283 - 0105


Effectué le 06/12/2004 18:05:36
Edité le 06/12/2004 18:09:46

8,00 ms/cm
10,00 ms

220,00 ms

O ASEFA 31042 Sample 05

42KA 88KA 236V+5% COS0.25




U12
599,00 V/cm

ВРНО С
ОПМННАТА



F01 20040283 - 0106

Effectué le 06/12/2004 19:07:47
Edité le 06/12/2004 19:12:55




 SYR
 KAMTEX
 CATIE V.53/129

Effectué le 06/12/2004 19:11:09
Edité le 06/12/2004 19:12:06


F01 20040283 - 0107

12,00 ms/cm
10,00 ms


400,00 ms

Calibr. test circuit voltage

cir mono: 39kA 82kA 254V+5% cos0.25



U12
198,00 V/cm



OPMTRHATA
BPPO C

F01 20040283 - 0108

Effectué le 07/12/2004 07:59:18
Edité le 18/08/2005 11:17:08

400,00 ms


200,00 ms

8,00 ms/cm


10,00 ms

Calibr. test circuit I

cir mono: 39KA 82kA 254V+5% cos0.25



19.95 kA/cm



СИТИЕ УТИС. 129 page 001

F01 20040283 - 0113


Effectué le 07/12/2004 08:47:42
Ecrité le 18/08/2005 11:18:12

8,00 ms/cm
200,00 ms
10,00 ms


400,00 ms

O ASEFA : N° 31042 sample N° 7

cir mono: 39KA 82KÅ 254V+5% COSØ.25



ВРНО С
ОПРИМАНА



F01 20040283 - 0116

SCALE 1:5.3.129 page 001

Effectué le 07/12/2004 09:08:11
Edité le 18/08/2005 11:18:54

400.00 ms


200.00 ms

8.00 ms/cm

10.00 ms

CO ASEFA : N° 31042 sample N° 7

cir mono: 39kA 82kA 254V+5% COS0.25



I1
19.96 kA/cm

U12
198.00 V/cm



ВРФО С
ОПМННАМА

F01 20040283 - 0117


Effectué le 07/12/2004 09:10:47
Ecrité le 18/08/2005 11:18:45

8,00 ms/cm
200,00 ms
10,00 ms


400,00 ms

Calibr. test circuit Voltage

cir mono: 25.2kA 53kA 398V+5% COS0.25



U12
396,00 V/cm



ОПТИКА
УПРАВЛЕНИЕ

F01 20040283 - 0119

Effectué le 07/12/2004 10:13:41
Edité le 18/08/2005 11:19:57

400,00 ms


200,00 ms

8,00 ms/cm

10,00 ms


Calibr. test circuit I

cir mono: 25.2kA 53kA 398V+5% cos0.25



10,00 V/cm

БРФО С
ОПТИМАЛА



F01 20040283 - 0122


Effectué le 07/12/2004 10:46:32
Edité le 18/08/2005 11:20:29

8,00 ms/cm
200,00 ms
10,00 ms

400,00 ms

O ASEFA n° 31042 sample n° 8


cir mono: 25.2kA 53kA 398V±5% cos0.25



U12
398,00 V/cm

398,00 V/cm

БРИД С
ОПТИКА



F01 20040283 - 0123


Effectué le 07/12/2004 10:58:47
Edité le 18/08/2005 11:20:51

400,00 ms

200,00 ms
8,00 ms/cm
10,00 ms


CO ASEFA n° 31042 sample n° 8

cir mono: 25.2kA 53kA 398V+5% cos0.25



10 50 25V/cm

U12
396,00 V/cm



Effectué le 07/12/2004 11:02:15
Edité le 18/08/2005 11:21:15


F01 20040283 - 0124

10,00 ms/cm
150,00 rms
10,00 ms


Calibr. test circuit U

70kA-154kA-415+5%-COS 0.20


400,00 rms



U12
492.60 V/cm



U23
496.20 V/cm



U31
495.50 V/cm

ОПТИМАЛ
ВЕРНО С



VOLTA 20040288 - 0003

400,00 ms


200,00 ms

8,00 ms/cm

10,00 ms

calibr. test circuit I

70KA-154KA-415+5%-COS 0.20



59,99 KA/CM

59,78 KA/CM

59,55 KA/CM



OPMITHATA
BAPHO C




F01 20040288 - 0007

Effectué le 06/12/2004 07:55:04
Edité le 18/08/2005 11:28:12


200,00 ms
8,00 ms/cm
10,00 ms

400,00 ms

O NS1600H
70KA - 415V



BRPHO C
DRMTHADIA



F01 20040288 - 0011





Effectué le 06/12/2004 09:28:17
Edité le 18/08/2005 11:28:59

400,00 ms

8,00 ms/cm
200,00 ms
10,00 ms

CO NS1600H

70kA - 415V



F01 20040288 - 0012





Effectué le 06/12/2004 09:31:18
Edité le 18/08/2005 11:29:28

200.00 ms
8.00 ms/cm
10.00 ms

400.00 ms

ASEFA 31042 Sample 10

NS630bH



OPMTHADIA
BRPHO C

F01 20040288 - 0013

CATIE V.1.5.S.129 page 001

Effectué le 06/12/2004 10:21:48
Edité le 18/08/2005 11:50:12




400,00 ms

200,00 ms

8,00 ms/cm

10,00 ms

CO ASEFA 31042 sample 10



BRAND C
OPREMIHATMA

Effectué le 06/12/2004 10:24:50
Edité le 18/08/2005 11:32:01

F01 20040288 - 0014


Page 0 of 29

8,00 ms/cm
200,00 ms
10,00 ms

Calibr. test circuit U


65KA-143KA-440+5%-COS 0.20

400,00 ms




U12

492,60 V/cm




U23

496,20 V/cm



U31

495,50 V/cm



BRPD C
OPMTHALIA

VOLTA 20040288 - 0015

EMTE-V.1.5.3.129 page 001


Effectué le 06/12/2004 11:16:11
Edité le 18/08/2005 11:52:35

400.00 ms

200.00 ms
8.00 ms/cm
10.00 ms

Calibr. test circuit I

65KA-143KA-440+5%-COS 0.20



OPMTRIA
BPPH C



VOLTA 20040288 - 0018

Effectué le 06/12/2004 11:56:58
Edité le 18/08/2005 11:52:49

8,00 ms/cm
200,00 ms
10,00 ms





ASEFA 31042 Sample 11

400,00 ms

U12
492,60 V/cm

U23
496,20 V/cm

U31
495,50 V/cm



F01 20040288 - 0019

Effectué le 06/12/2004 12:15:38
Edité le 18/08/2005 11:53:06




400.00 ms

CO1 ASEFA 31042 Sample 11

200.00 ms

3.00 ms/cm

10.00 ms



Effectué le 06/12/2004 12:18:45
Ecrité le 18/08/2005 11:53:53

F01 20040288 - 0020







8,00 ms/cm
200,00 ms
10,00 ms

Calibration of the test circuit U

cir tri: 42kA - 88.2kA - 690V+5% - cos0.25

400,00 ms



BRNAPAR DOO
OPREDELJENJE

ŠKIF: 129 page 001

F01 20040283 - 0141


Effectué le 06/01/2005 16:24:45
Edité le 18/08/2005 11:23:27

400,00 ms

Calibration of the test circuit current


cir tri: 42kA - 88.2kA - 690V +5% - COS0.25

200,00 ms
10,00 ms
8,00 ms/cm



17 19,99 kA/cm


17 19,99 kA/cm



OPMITHATA
BRPHO C

F01 20040283 - 0150

Effectué le 06/01/2005 17:56:20
Edité le 18/08/2005 11:23:45



400.00 ms

Opening ASEFA 31.042 Sample 12


cir tri: 42kA 88.2kA 690V+5% cos0.25

8.00 ms/cm
200.00 ms
10.00 ms

U12
510.00 V/cm

U25
508.00 V/cm

U25
508.00 V/cm



BSPRO C
DRMINKATA

F01 20040283 - 0161

CATIE V. 129 page 001

Effectué le 10/01/2005 09:24:51
Edité le 18/08/2005 11:24:57

400.00 ms


200.00 ms

8.00 ms/cm

10.00 ms


Closing ASEFA 31.042 Sample 12

cir tri: 42kA 88.2kA 690V+5% COS0.25



U12
510.00 V/cm

U23
515.00 V/cm



BUREAU CENTRAL DE RECHERCHES ET D'ESSAIS
SOCIÉTÉ BELGE DE REPRÉSENTATION INDUSTRIELLE

F01 20040283 - 0162

CATIE V.1.5.3.129 page 001

Effectué le 10/01/2005 09:28:17
Edité le 18/08/2005 11:25:17



Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
tyco Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

Списък на проведените изпитвания на Триполюсни автоматични прекъсвачи НН с лят корпус, от 160 А до 1250 А, с електронна защита, категория А

1. Капацитет на пробив при номинално късо съединение;
2. Претоварване;
3. Диелектрична якост;
4. Ток на утечка;

13.01.2016г.

Подпис и печат





TRANSLATION AGENCY

50 Hristo Smirnenski Blvd.
1164, Sofia, Bulgaria

T +359 2 9804090
F +359 2 9817160
office@greg-bg.com
www.greg-bg.com

Превод от френски на български език

COFRAC

Френски комитет за акредитация
Сертифициране на индустриални продукти и услуги

ДИПЛОМА ЗА АКРЕДИТАЦИЯ

Настоящият документ удостоверява, че

ASEFA

Бул. Женеерал Лъоклер 33 – 92260 ФОНТЪОНЕ О РОЗ, Седекс

е акредитирано съгласно норма NF EN 45011 и правилата за прилагане на Френския комитет за акредитация относно

Сертифициране посредством проби на устройства тип електрически и/или електронни под номер 5-0037

Обхватът и валидността на акредитацията са уточнени в удостоверението или влязлото в сила изменение. По време на този период, организацията се ангажира да спазва във всеки момент изискванията на акредитацията.

Издадено в Париж на 15 декември 2002 година

Председател на секционен комитет: подпис не се чете

Директор на Френски комитет за акредитация: подпис не се чете

Долуподписаният, Светомир Радков Минчев, удостоверявам верността на извършения от мен превод от френски на български език на настоящия документ: Акредитация. Преводът се състои от 1 страница.

Подпис: 
Светомир Радков Минчев



DIPLOME D'ACCREDITATION

cofrac



Diplôme d'Accréditation

Ce document atteste que :

ASEFA

33, avenue du Général Leclerc - 92260 FONTENAY-AUX-ROSES Cedex

est accréditée selon la norme NF EN 45011 et les règles d'application du COFRAC pour la
Certification par essai de type des dispositifs électriques et/ou électroniques
sous le numéro 5-0037

La portée et la validité de l'accréditation sont précisées dans l'attestation ou l'avenant en vigueur qui lui a été délégué. Durant cette période, l'organisme s'engage à respecter à tout moment les exigences de l'accréditation.



Fait à Paris, le 15 décembre 2002

Le Président
du Comité de section :

Le Directeur du COFRAC :



FLUORFIX



RMU isolado em SF6

SF6 insulated RMU

Aparelhagem de Média Tensão
Medium Voltage Switchgear



Características gerais

- Quadro compacto com isolamento em SF6
- Equipado com Interruptor seccionador de corte em SF6
- Com disjuntor de corte no vácuo
- Desenvolvido segundo a Norma Internacional CEI 62271-200
- Insensível às condições ambientais
- Versão compacta ou modular
- Resistente ao arco interno
- Vida eléctrica e mecânica acrescidas (classe E3-M3)
- Tanque em inox

General characteristics

- SF6 insulated compact switchgear
- Equipped with SF6 switch disconnector
- Equipped with vacuum circuit breaker
- Developed according the International Standard CEI 62271-200
- Insensitive to environmental conditions
- Modular or compact version
- Internal arc resistant
- Increased mechanical and electrical life (class E3-M3)
- Stainless steel tank


BAPHO C
OPRIMIBILIA



Características técnicas | Technical data

Características eléctricas Electrical data		12	17,5	24	16
Tensão nominal Rated voltage	kV	12	17,5	24	16
Nível de isolamento/Insulation level de choque/Impulse (1/2/50ns) (frecuencia industrial/power frequency (50Hz/60min))	kV pico/kV peak KV.en.caz/KV.T.on.s	28 75	38 95	50 125	70 170
Corrente nominal Rated current	A ate/up to 630	ate/up to 630	ate/up to 630	ate/up to 630	ate/up to 630
Corrente nominal de curta duração Rated short time current	kA eficaz/ kA rms	16/20 (3s); 25 (1s)	16 (3s); 20 (1s)	16 (3s); 20 (1s)	16 (3s); 20 (1s)
Corrente de fecho sobre curto-circuito Short-circuit making current	kA pico/ kA peak	50/63	40/50	40/50	40/50
Temperatura ambiente Ambient temperature	°C	55; 240 (outras sob pedido/other under request)			
Dimensões (21S-16S) Dimensions (21S-16S)					
Altura Height	mm		1275		1728
Largura width	mm		1190		1350
Profundidade Depth	mm		777		900

Funções típicas | Typical functions




Efacec Energia, Máquinas e Equipamentos, S.A.
Unidade de Negócios Aparelhagem

Sede/Main Office:

Ap. 1018 | 4446-992 S. Mamede Infesta | Portugal | Tel: +351 229 562 300 | Fax: +351 229 562 300 | e-mail: efacec@efacec.pt | web: www.efacec.com


Delegação/Office:

Rua da Garegem, nº1 | 2790-078 Carnaxide | Portugal | Tel: +351 214 163 600 | Fax: +351 214 163 620



Devido ao contínuo desenvolvimento, as características podem ser alteradas sem aviso prévio. Não é válido como diagrama definitivo. Due to our policy of continuous development, specifications may change without notice. Not valid as a definitive item.

Mod. AP01 B0910 A1



FLUOFIX GC

Компактно разпределително
устройство тип RMU
изолирано в елегаз SF6


ИНСТРУКЦИИ ЗА ПОЛЗВАНЕ
№453030009

ВЪРНО С
ОПТИМАЛНА



СЪДЪРЖАНИЕ

1. ОСНОВНИ ТЕХНИЧЕСКИ ХАРАКТЕРИСТИКИ	3
2. МОДУЛНИ ЕДИНИЦИ	4
2.1 Модулна единица IS	4
2.2 Модулна единица CIS	4
2.3 Модулна единица DC	5
2.4 Модулна единица SB	5
2.5 Модулна единица M	5
2.6 Модулна единица CD	6
3. КОМПАКТНИ ЕДИНИЦИ	6
3.1 Модулна единица 2IS+CIS	6
3.2 Модулна единица 2IS+SB	6
3.3 Модулна единица 3IS	7
3.4 Модулна единица 2IS+DC	7
3.5 Модулна единица 2IS+2CIS	7
3.6 Други конфигурации	7
4. ОБЩО ОПИСАНИЕ НА МОДУЛНИТЕ ЕДИНИЦИ	8
5. ОБЩО ОПИСАНИЕ НА МЕХАНИЗМИТЕ ЗА УПРАВЛЕНИЕ	9
6. ПРЕДЛАГАНИ ОПЦИИ ЗА МЕХАНИЗМИТЕ ЗА УПРАВЛЕНИЕ	10
6.1 Заклучване с катинар	10
6.2 Заклучване със заключалка	10
6.3 Електрическо оборудване	10
7. СИСТЕМА ЕЛЕГАЗ SF6	11
8. ИЗПРАЩАНЕ	11
9. ПОЛУЧАВАНЕ	12
10. ИНСТАЛИРАНЕ	13
10.1 Подготовка на пода	13
10.2 Разопаковане	13
10.3 Монтаж на място	13
10.4 Съединяване на разширяеми модулни единици	13
10.5 Закрепване към пода	15
10.6 Свързване на заземителната мрежа	15
10.7 Свързване на кабелите	16
10.8 Монтиране на предпазителите	17
10.9 Определяне размерите на предпазителите	18
11. ПУСКАНЕ В ДЕЙСТВИЕ	19
11.1 Задължителни проверки	19
11.2 Комутационни операции с апарата	19
11.3 Захранване на входните кабели	19
11.4 Проверка за наличие на напрежение	19
11.5 Проверка на последователността на фазите при Функциите "Вход"	20
11.6 Захранване на шината и на комбинираната защита от предпазителите	20
12. ПРИНЦИП НА РАБОТА	20
12.1. Оперирание с механизмите за управление	20
12.2. Отваряне на заземителя (приложимо при двата вида механизми на управление: C11 e C12)	21
12.3. Затваряне на заземителя (приложимо при двата вида механизми на управление: C11 e C12)	21
12.4. Затваряне на прекъсвача (механизми на управление C11 - Функция вход/ изход)	22
12.5. Отваряне на прекъсвача (механизъм на управление C11 - Функция вход/ изход)	22
12.6. Затваряне на прекъсвача и зареждане за отваряне (механизъм на управление C12 - функция Защита на трансформатор)	23
12.7. Отваряне на прекъсвача (механизъм на управление C12 - функция Защита на трансформатор)	23
13. СЪХРАНЕНИЕ	24
14. ТЕСТВАНЕ НА КАБЕЛИ	24
15. ПОДМЯНА	25
15.1 Подмяна на сигналните лампи за наличие на напрежение	25
15.2 Подмяна на предпазителите	25
16. РЕЗЕРВНИ ЧАСТИ	25




1. ОСНОВНИ ТЕХНИЧЕСКИ ХАРАКТЕРИСТИКИ

Номинално напрежение	12 kV	17,5 kV	24 kV	36 kV
Изолационно ниво				
С промишлена честота (50Hz - 1 мин.)	28 kV	38 kV	50 kV	70 kV
Импулсно (1,2 / 50µs)	75 kV	95 kV	125 kV	170 kV
Номинален ток				
На шините	630 A	630 A	630 A	630 A
Вход/ изход	400 A 630 A	400 A 630 A	400 A 630 A	400 A 630 A
Защита с предпазител	200 A	200 A	200 A	200 A
Защита с прекъсвач	400 A 630 A	400 A 630 A	400 A 630 A	400 A 630 A
Ток при късо съединение	16 kA (3s) 20 kA (1s)	16 kA (3s) 20 kA (1s)	16 kA (3s) 20 kA (1s)	16 kA (3s) 20 kA (1s)
Изключвателна способност	40 kA 50 kA	40 kA 50 kA	40 kA 50 kA	40 kA 50 kA
Честота	50 Hz	50 Hz	50 Hz	50 Hz
Вътрешна дъга (IAC A-FL)	Até 20kA 1s	Até 20kA 1s	Até 20kA 1s	Até 20kA 1s
Околна температура	-5 a 40 °C	-5 a 40 °C	-5 a 40 °C	-5 a 40 °C
Номинално напрежение на запълване (при 20°C)	0,3 bar rel	0,3 bar rel	0,3 bar rel	0,3 bar rel
Категория загуба на непрекъснатост на услугата	LSC 2A (в съответствие със CEI 62271-200)			
Клас изолационни стени	PI (в съответствие със CEI 62271-200)			
Индекс на защита (CEI 60529 и EN 50102)	IP65 (отделение за средно напрежение) IP3XC (отделение на механизма за управление) IP 3XC (кабелно отделение) IK09 (отделение за средно напрежение) IK08			

Размери на модулните единици до 24 kV

Единица	Ширина (mm)	Височина (mm)	Дълбочина (mm)	Тегло (kg)
IS	370	1279	727	125
CIS	450	1279	727	155
DC	450	1279	727	155
SB	450	1279	727	115
M	750	1279	892	140
2IS+CIS	1190	1279	727	300
2IS+SB	1190	1279	727	290
3IS	1110	1279	727	270
2IS+DC	1190	1279	727	300
2IS+2CIS	1640	1279	727	400
3IS+CIS	1560	1279	727	380
3IS+2CIS	2010	1279	727	500
4IS	1480	1279	727	360




Размери на модулните единици от 36 kV

Единица	Ширина (mm)	Височина (mm)	Дълбочина (mm)	Тегло (kg)
IS	450	1729	900	230
CIS	450	1729	900	250
SB	450	1729	900	185
M	1000	1729	1155	225
2IS+CIS	1350	1729	900	480
2IS+SB	1350	1729	900	465
3IS	1350	1729	900	430
2IS+2CIS	1800	1729	900	640
3IS+CIS	1800	1729	900	610
4IS	1800	1729	900	575

2. МОДУЛНИ ЕДИНИЦИ



2.1 Модулна единица IS



Функция Разединител (IS)

Единица за вход/ изход на проводници, оборудвана с разединител ISFG (механизъм за управление C11).

2.2 Модулна единица CIS




Функция Защита на трансформатор (CIS)

Единица за защита на трансформатор, оборудвана с държач за предпазители и разединител ISFG (механизъм за управление C12).





2.3 Модулна единица DC



Функция Защита на проводници (DC)

Единица за защита на проводници, оборудвана с вакуумен прекъсвач DIVAC (механизъм за управление CDV) и с разединител ISFG (механизъм за управление C11).



2.4 Модулна единица SB



Функция Изключване на шини (SB)

Единица за изключване на шини, оборудвана с разединител ISFG (механизъм за управление C11).

2.5 Модулна единица M



Функция Измерване (M)

Единица за измерване. Може да бъде оборудвана с токови и мощностни трансформатори.



ВАРНО С
ОПТИМАЛНА



2.6 Модулна единица CD



Функция Директен вход (CD)
Единицата позволява да се осъществи директен вход или изход с проводници.



3. КОМПАКТНИ ЕДИНИЦИ

Наличните компактни конфигурации на Fluofix GC са получени чрез комбиниране на следните основни функции:

- Функция вход/ изход с разединител (Функция IS)
- Функция защита на трансформатор чрез предпазители (Функция CIS)
- Функция директен вход/ изход (Функция CD)
- Функция кабелна защита чрез прекъсвач (Функция DC)
- Функция изключване на шини (Функция SB)

Компактните единици Fluofix GC могат да бъдат разширяеми или не разширяеми.



3.1 Модулна единица 2IS+CIS



Компактна единица 2IS+CIS

Компактна единица с 2 функции Разединител (IS) и 1 функция Защита на трансформатор чрез предпазители (CIS).

3.2 Модулна единица 2IS+SB



Компактна единица 2IS+SB

Компактна единица с 2 функции Разединител (IS) и 1 функция Изключване на шини (SB).



Единицата е разширяема дясната страна.



ВАРНО С ОНБ

efacesc



3.3 Модулна единица 3IS



Компактна единица 3IS

Компактна единица с 3 функции Разединител (IS).



3.4 Модулна единица 2IS+DC



Компактна единица 2IS+DC

Компактна единица с 2 функции Разединител (IS) и 1 функция Защита на проводници чрез прекъсвач (DC).

3.5 Модулна единица 2IS+2CIS



Компактна единица 2IS+2CIS

Компактна единица с 2 функции Разединител (IS) и 2 функции Защита на трансформатор чрез предпазители (CIS).

3.6 Други конфигурации

Други конфигурации могат да бъдат предоставени по поръчка.





ОПТИМАЛНО
ВЪРНО С




4. ОБЩО ОПИСАНИЕ НА МОДУЛНИТЕ ЕДИНИЦИ

- 1- Аксесоари за повдигане на модула
- 2- Отделение на механизмите за управление
- 3- Свързване на заземителната мрежа
- 4- Панел за достъп до кабелите
- 5- Непроницаем корпус от неръждаема стомана
- 6- Отделение за ниско напрежение
- 7- Индикатор за наличие на напрежение
- 8- Държач за предпазители с изолация от епоксидна смола
- 9- Панел за достъп до предпазителите
- 10- Кабели за средно напрежение



5. ОБЩО ОПИСАНИЕ НА МЕХАНИЗМИТЕ ЗА УПРАВЛЕНИЕ

- 1 - Ръчка за управление на прекъсвач или заземител
- 2 - Индикатор за положението на прекъсвача
- 3 - Винтове за закрепване на предния панел
- 4 - Заклучалка за блокиране на заземителя на положение "отворено" (по желание)
- 5 - Заклучалка за блокиране на заземителя на положение "затворено" (по желание)
- 6 - Заклучалка за блокиране на прекъсвач на положение "отворено" (по желание)
- 7 - Индикатор за наличие на напрежение
- 8 - Отвор за поставяне на ключе за блокиране управлението на заземителя
- 9 - Отвор за вкарване на ръчката за управление на заземителя
- 10 - Механизъм за управление на заземителя
- 11 - Отвор за вкарване на ръчката за управление на прекъсвача
- 12 - Механизъм за управление на прекъсвача (Механизъм за управление тип C11 на Функция IS)
- 13 - Отвор за поставяне на ключе за блокиране управлението на прекъсвача
- 14 - Манометър за измерване налягането на елегаза (SF6)
- 15 - Блокращ превключвател при вкарване на ръчката
- 16 - Механизъм за управление на прекъсвача (механизъм за управление тип C12 на Функция CIS)
- 17 - Бутон за ръчно отваряне на прекъсвача (само за Функции CIS с C12)



	Принцип на действие	Примери за приложение
C11(M)	Механизъм за управление тип "Tumbler". Затварянето и отварянето се извършват ръчно или електрически, посредством моторизирана система със скорост, независеща от действието на оператора.	Използван при Функция IS. Основно оборудване при Функциите "вход/ изход" (Дежурно инсталиране или махане на част от мрежа) C11M позволява дистанционно управление на разединителя ISFG.
C12(M)	Механизъм за управление тип "Tumbler", оборудван със система за задържане само при отварянето. Операторът извършва ръчно операцията по затваряне, последвана от операция на зареждане на механизма. По този начин механизмът за управление може да извърши операция по отваряне за съкратено време (<100 ms) чрез действието на електромагнит, патрон на предпазител или бутон.	Използван при Функция CIS. Изключване на прекъсвача чрез стопяване на един или повече предпазители (защита от натоварване чрез комбинирани предпазители). Изключване на прекъсвача чрез задействане на защитни релета на трансформаторите. Отваряне на прекъсвача.

Принцип на действие на механизма "Tumbler"

Задействането на ръчката натяга пружината, докато се достигне състояние извън равновесие. При това положение пружината се освобождава като се отпуска рязко независимо от оператора.




БУРНО С efacec

6. ПРЕДЛАГАНИ ОПЦИИ ЗА МЕХАНИЗМИТЕ ЗА УПРАВЛЕНИЕ

6.1 Заклучване с катинар

Този тип заклучване се състои в използването на катинари, които не позволяват достъпа до отвора за вкарване на ръчката. Всички прекъсвачи и разединители са подготвени за поставянето на катинари.




6.2 Заклучване със ключалка

Този вид заклучване се състои в използване на ключалки, които не позволяват достъп до отвора за вкарване на ръчката. Всяка ключалка има по един ключ, който може да бъде изваден само при заклучено положение.

Възможно е (по желание) да се поставят 3 ключалки, с които да се осъществят следните блокировки:

- А - Прекъсвач на положение "отворен"
- В - Заземител на положение "отворен"
- С - Заземител на положение "затворен"



6.3 Електрическо оборудване

Командното управление на разединителите и прекъсвачите може да бъде оборудвано с моторизирани съоръжения, първична намотка, микропроцесори за сигнализация или други съоръжения, подходящи за дистанционното управление на модулната единица.


Ако е нужно (по желание), може да се добави допълнително отделение за ниско напрежение, даващо възможност да се инсталира друго необходимо оборудване.

7. СИСТЕМА ЕЛЕГАЗ SF6

FLUOFIX GC е капсуловано до живот съоръжение (съгласно стандарт IEC 62271). Непропускливостта на това съоръжение е осигурено чрез различни рутинни тестове. Очакваният му експлоатационен живот е 30 години.


Непроницаемият корпус от неръждаема стомана на FLUOFIX GC се пълни с елегаз (SF6) при относително налягане от 0,3 бара. Винаги когато е необходимо, премахнете SF6 от вътрешността на корпуса (корпусът е проектиран така че да издържа на абсолютен вакуум), като препоръчителната процедура е следната:

- Отстранете капака на механизма за управление.
- Отстранете индикатора на налягане (инсталиран е върху вентила).
- Вентилът ще стане тогава достъпен.



Характеристики на вентила, използван в корпусите FLUOFIX GC:

Производител: DIL0
 Модел: Ref. 3-408-R008 AL
 Размер: DN6
 Вентилът трябва да е устойчив на
 разпадащ се елегаз (SF6).






8. ИЗПРАЩАНЕ

Модулните единици FLUOFIX GC се изпращат с прекъсвач в положение "отворен" и заземител в положение "затворен".

Модулните единици FLUOFIX GC се изпращат всяка поотделно върху дървен палет (закрепен с четири винта и покрит с прозрачно фолио).

Акcesoарите за монтаж и свързване на модулните единици FLUOFIX GC се доставят в отделна опаковка.




ВЪРНО С
 ОПОРНИМА
 еfacec

9. ПОЛУЧАВАНЕ

Установете кои са получените модулни единици и се уверете във:

- Функцията съгласно краткото описание
- Табелката с характеристики
- Доброто състояние на оборудването

Уверете се, че е налице опаковката с допълнителното оборудване. При установяване на нередности трябва да ги отбележите в разписката за доставка.






Пакетите трябва да останат закрепени върху дървения палет до момента на монтирането им.

Пакетите трябва да се преместват с помощта на следните уреди:

- Мостов кран
- Хидравличен високоповдигач

За да се осигури безопасността на маневриращото лице и на самото оборудване, модулните единици трябва да бъдат транспортирани странично (не ги движете напред).



Пакетите трябва да се съхраняват в оригиналната им опаковка, да се пазят от прах, водни пръски и такива от химикали, в добре проветрявано и сухо помещение при температура от -25° C до +40° C.

10. ИНСТАЛИРАНЕ


10.1 Подготовка на пода

Подът трябва да притежава минимална гладкост от 2mm/m с цел монтажът да се улесни и да се постигне добър краен вид.

10.2 Разопаковане

Когато пакетите са близо до мястото, където ще се извърши монтажът, в следния ред:

- Отстранете прозрачното фолио.
- Отворете вратата на кабелното отделение (уверете се, че заземителите са затворени).
- Махнете четирите винта, поддържащи пакета върху основата (ключ № 17).
- Внимателно завъртете модулната единица, с цел да освободите основата и да я поставите на земята следвайки инструкцията за движение.





10.3 Монтаж на място

- Отстранете предната врата на кабелното отделение
- Поставете модулната единица и проверете дали стои вертикално, ако е необходимо изравнете
- Закрепете я към пода

10.4 Съединяване на разширяеми модулни единици


Разширяемите единици могат да се комбинират единствено и само с други разширяеми единици.

Разширяемите единици се доставят със защитна, изолираща запушалка. Запушалката трябва просто да бъде извадена, за да се свържат 2 единици.





За да свържете 2 разширяеми единици е необходимо:

- Да отстраните изолиращата запушалка
- Да поставите клемми за уравниряване на електрично поле (по 3 във всяка единица)
- Да поставите разширителния конектор.



Точки за поставяне на клемми за уравниряване на електрично поле




Забележка:

Почистете и поставете силикон върху повърхността на разширителния конектор на модулните единици, за да улесните операцията.


10.5 Закрепване към пода

Разгледайте плана за разполагане на модулните единици, където е дадена конфигурацията, общите размери и препоръчаните точки за закрепване към пода. Модулните единици се закрепят към пода посредством винтове M8 (4 точки на закрепване на крайните клетки).



10.6 Свързване на заземителната мрежа


Всички компоненти NORMAFIX (шини, кабелни връзки, предпазители и др.) са свързани помежду си и са заземени посредством обща мрежа. Вижте на диаграмата на долната фигура точката на свързване на общата шина.




(*) - Точки на свързване на общата шина

10.7 Свързване на кабелите


FLUOFIX GC е проектиран, за да бъдат използват разглобяеми, предварително оформени (екранирани и не екранирани) или термосвиваеми конектори от следните видове:



Прав конектор





Г-образен конектор



Т-образен конектор

Т-образни конектори за втулки 400/630А на Функциите "вход/ изход". Конекторите трябва да бъдат съвместими с изолирани медни или алуминиеви проводници. Могат да бъдат използвани конектори Raychem RST1, Euromold K400 или подобни.


Прави или Г-образни конектори за втулки 200А. Конекторите трябва да бъдат съвместими с изолирани медни или алуминиеви проводници. Могат да бъдат използвани конектори Raychem RSES или R5SS, Euromold K158LR или K152SR, или подобни.



Изборът на кабели и конектори е отговорност на клиента. Кабелите и конекторите трябва да бъдат съвместими с оборудването на FLUOFIX GC.

Използвайте конектори с характеристики, отговарящи на стандартите DIN 47636 и EDF HN52-S-61.

Следвайте инструкциите на производителя на конектори при инсталирането на кабелните конектори.




10.8 Монтиране на предпазителите


Отворете вратичката на отделениято за предпазителите.

(Заземителят трябва да бъде затворен).

Свалете капачката на държача за предпазител, завъртайки ръчката в посока обратна на часовниковата стрелка.




Махнете ръчката и завъртете с ръка капачката в посока обратна на часовниковата стрелка. Капачката на държача за предпазител ще се освободи.



Поставете предпазителя в капачката на държача (посока на патрона: към капачката).

Поставете обратно капачката (заедно с предпазителя), следвайки обратния ред на действие.

(Уверете се, че капачката е поставена в правилната посока).



Забележка: Почистете коничната повърхност на капачката (не е необходимо да използвате силикон).

10.9 Определяне размерите на предпазители

Предпазители тип High Rupture Capacity (HRC) "Backup-fuses", произведени съгласно стандарт CEI 60282 / DIN 43625.

При максимална околна температура от 40° C, максималната загуба на мощност е 55 W.

Мощност на трансформатора kVA	Първично напрежение на трансформатора					
	Номинален ток (A) I_N (**)					

(*) При определянето на вида предпазител трябва се вземе под внимание допустимата загуба на напрежение (посочена в листовката на предпазителите).

(**) Когато (I_N е при $-5^{\circ}\text{C} \leq T \leq +40^{\circ}\text{C}$) и мощността на трансформатора е > 1000 kVA, максималният свръхток е 1.2 IS.



11. ПУСКАНЕ В ДЕЙСТВИЕ

11.1 Задължителни проверки

- Проверете дали са свързани правилно шината, кабелите, заземяванията и помощните нисковолтови вериги.
- Проверете дали са монтирани правилно предпазители, дефлекторите на шините и кабелите и на панелите на кабелното отделение.
- Проверете дали индикаторът за налягане е в положение зелено.

11.2 Комутационни операции с апарата


- Проверете правилното функциониране на апарата и блокировките, като включите и изключите няколко пъти прекъсвачите и разединителите.

11.3 Захранване на входните кабели

- Проверете дали всички разединители са в положение "отворен".

11.4 Проверка за наличие на напрежение

- След като кабелите на Функция IS "А" са захранени, проверете дали светят индикаторите за наличие на напрежение L1, L2 и L3, монтирани на командното табло.
- Пуснете захранването на кабелите на Функция IS "В" и проверете дали светят индикаторите за наличие на напрежение.



11.5 Проверка на последователността на фазите при Функциите "Вход"

Проверете последователността на фазите, използвайки подвижното тестващо устройство "С", като за целта:

- Вкарайте клема "С" в точката за тестване на устройство L3 на функция "А"
- Вкарайте клема "С" в точката за тестване на устройство L3 на функция "В"

Ако има последователност:

- Лампичките на контролните устройства L3 на функциите са със слаба светлина.
- Лампичката на подвижното устройство "С" светва.

Ако няма последователност:

- Лампичките на контролното устройство L3 на функциите "А" и "В" светват.
- Лампичката на подвижното устройство "С" изгасва.

Повторете същите операции за фазите L1 и L2.

Забележка: За да проверите правилното функциониране на подвижното устройство за проверка на последователност на фази, свържете двете му клеми с двете фази от същата клетка: лампичката трябва да светне.


11.6 Захранване на шината и на комбинираната защита от предпазители

- Затворете прекъсвача(ите) на входната(ите) клетка(и).
- Затворете прекъсвача(ите) на изходната(ите) клетка(и).
- Проверете дали индикаторите за наличие на напрежение L1, L2 и L3 на последната клетка светят.


12. ПРИНЦИП НА РАБОТА

12.1. Оперирание с механизмите за управление


Пакетите с модулите се изпращат с прекъсвач в положение "отворен" и заземител в положение "затворен". Моторизирано задвижване не може да се осъществи ако ръчката за ръчно управление е поставена.




Механизмът се задейства с помощта на блокираща заден ход ръчка, чиято функция е да не позволи на прекъсвача да премине в положение "отворен" веднага след като е бил в положение "затворен".



Прекъсвач затворен
Заземител отворен



Прекъсвач отворен
Заземител отворен




Прекъсвач отворен
Заземител затворен

12.2. Отваряне на заземителя (приложимо при двата вида механизми на управление: CI1 е CI2)


- Тази операция е възможна единствено ако заземителят е затворен.
- Преместете превключвателя на механизма за блокиране на заден ход.
- Вкарайте ръчката в отвора за управление на заземителя.
- Отворете заземителя, повдигайки ръчката до положение отворено в посока обратна на часовниковата стрелка.

Това действие ще позволи да се затвори предния панел с кабелите и да се освободи позицията на отворения прекъсвач.



12.3. Затваряне на заземителя (приложимо при двата вида механизми на управление: CI1 е CI2)

- Тази операция е възможна единствено ако прекъсвачът и в положение "отворен".
- Вкарайте ръчката в отвора за управление на заземителя.
- Уверете се че кабелите не са под напрежение (вижте индикаторите за наличие на напрежение).
- Затворете заземителя, повдигайки ръчката до крайно положение в посока на часовниковата стрелка.




При тази операция:

- заземителят се затваря.
- панелът за достъп до кабелите се отваря.
- прекъсвачът се блокира в положение "отворен".


12.4. Затваряне на прекъсвача (механизми на управление CI1 - Функция вход/изход)

- Тази операция е възможна единствено ако заземителят е в положение "отворен".
- Вкарайте ръчката в отвора за управление на прекъсвача.
- Завъртете ръчката до крайно положение в посока на часовниковата стрелка - прекъсвачът се затваря рязко.
- Механизмът за управление на заземителя се блокира в положение "отворен".




12.5. Отваряне на прекъсвача (механизъм на управление CI1 - Функция вход/изход)

- Тази операция е възможна единствено ако заземителят е в положение "затворен".
- Вкарайте ръчката в отвора за управление на прекъсвача.
- Завъртете ръчката до положение отворено в посока обратна на часовниковата стрелка в положение "отворен" - прекъсвачът се отваря рязко.
- Механизмът за управление на заземителя тогава се отблокира.



12.6. Затваряне на прекъсвача и зареждане за отваряне (механизъм на управление CI2 - функция Защита на трансформатор)

- Тази операция е възможна единствено ако заземителят е в положение "отворен".
- Вкарайте ръчката в отвора за управление на прекъсвача.
- Завъртете с ръка в посока на часовниковата стрелка до крайно положение.
- Прекъсвачът се затваря и ръчката не може да бъде махната.




Внимание, задължителна операция след затварянето на ISFG:

- Завъртете задължително ръчката в посока обратна на часовниковата стрелка, за да заредите пружината.
- След това може да се махне ръчката. Прекъсвачът тогава е вече готов за отваряне (завъртете ключа в посока обратна на часовниковата стрелка).

12.7. Отваряне на прекъсвача (механизъм на управление CI2 - функция Защита на трансформатор)

Операцията на отваряне на прекъсвача може да бъде извършена:

- Ръчно (бутон на механизма за управление)
- Чрез първична намотка (по желание)
- С предпазители (механично задвижване на предпазителите)



13. СЪХРАНЕНИЕ

Fluofix GC е продукт, който не се нуждае от поддръжка, след като вече всички активни части и основната верига се намират във вътрешността на резервоара, пълен с елегаз (SF6).


При все това, след продължително изключване от режим на работа или винаги, когато има прекъсване на режима на работа, се препоръчва извършването на някои операции:

- Визуална проверка, за да се уверите в доброто състояние на съоръжението.
- Проверка на правилното функциониране на механизмите за управление и на блокировките.
- Проверка на правилното поставяне на кабелните конектори.

14. ТЕСТВАНЕ НА КАБЕЛИ

Ред за извършване на тестването на кабели


- Отворете разединителя.
- Затворете заземителя.
- Отстранете панела за достъп до кабелното отделение.
- Инжектирайте напрежение директно в кабелния конектор (производителите на конектори разполагат с допълнителни съоръжения за тестване на кабели).
- След края на тестването се върнете в началното положение.



Инжектиране на напрежение

По желание, единиците Fluofix могат да бъдат оборудвани със специални изпитателни гнезда за тестване на кабели (виж рисунката). Те позволяват кабелите да се тестват без да има пряк достъп до кабелните конектори.

- Отворете разединителя.
- Затворете заземителя.
- Отстранете заземителните шини, които са съединени на късо с изпитателните гнездата.
- Инжектирайте напрежение, за да тествате кабелите.
- След края на тестването се върнете в началното положение.




Изпитателно гнездо


15. ПОДМЯНА

15.1 Подмяна на сигналните лампи за наличие на напрежение


За да подмените сигналните лампи за наличие на напрежение, следвайте реда, посочен на илюстрациите. Не са необходими инструменти.



След като отстраните индикатора на напрежението, прекъснете връзката. Свържете ново индикатора на напрежението и го поставете отново на мястото му. Ако единицата е под напрежение, индикаторът ще светне веднага.



Връзка



15.2 Подмяна на предпазители

За да подмените предпазителите, следвайте инструкциите, посочени в точка 10.8 от "Монтаж на предпазители".

Препоръчва се едновременна подмяна на трите предпазителя.

16. РЕЗЕРВНИ ЧАСТИ

Препоръчват се следните резервни части:


- Лампи за индикатора на напрежение
- Предпазители (ако е приложимо)
- Първична намотка (ако е приложимо)



efacet


ВЪРНО С
ОРИГИНАЛА

FRONTAL VIEW




SIDE VIEW

IS FUNCTION (SWITCH DISCONNECTOR)




SIDE VIEW


CIS FUNCTION (TRANSFORMER PROTECTION)




SINGLE LINE DIAGRAM



LAY-OUT



Floor setting to be checked
according to cable with gauge



CABLES (DRY INSULATEUR)	SECTION (mm ²)	BENDING RADIUS	h
SINGLE	< = 50	370	400
SINGLE	70 < X < 120	440	450
SINGLE	120 a 150	450	500
SINGLE	185 a 240	600	550
THREE	< = 150	550	660
THREE	150 a 185	650	770
THREE	185 a 240	840	900

Техническое задание ИСО 2768-m ou APES 9802S
 Incumbent to the manufacturer to ensure compliance with the requirements of the standard.
 Incumbent to the manufacturer to ensure compliance with the requirements of the standard.
 Incumbent to the manufacturer to ensure compliance with the requirements of the standard.

General Tolerances: ISO 2768-m or APES 9802S
 All dimensions in mm unless otherwise specified.
 Incumbent to the manufacturer to ensure compliance with the requirements of the standard.

Scale: 1:1

Project: -

Issue: -

Drawn by: AP01336A1
 Checked by: E1620
 Approved by: -

Material: Fluorocarbon 240V-930A-10kVA/3s

Quantity: -

Unit: -

Part: -


EFACEC
 AP01336A1-1
 AP01336A1-1

Tender in CEZ for kisoks
 EFACEC Central Europe Limited S.R.L.
 Arrangement & Installation

Revision / Revisão: 1/1
 Index / Índice: -
 Number / Número: -
 Date / Data: -




FRONTAL VIEW




SIDE VIEW

IS FUNCTION (SWITCH DISCONNECTOR)




SIDE VIEW

CIS FUNCTION (TRANSFORMER PROTECTION)




SINGLE LINE DIAGRAM


IS FUNCTION IS FUNCTION IS FUNCTION



LAY-OUT




From setting to be inserted
which is cubic after pump




Tel: +354 216 2121 or APES 98025
General Telephone: ISD 2768-01 or APES 98025

CABLES (DRY INSULATOR)	SECTION (mm ²)	BENDING RADIUS	h
SINGLE	< = 50	370	400
SINGLE	70 < X < 120	440	450
SINGLE	120 a 150	450	500
SINGLE	185 a 240	600	550
THREE	< = 150	550	680
THREE	150 a 185	650	770
THREE	185 a 240	840	900


Project	APES 98025		
Client	Tender in CEZ for kiskos		
Contract	EFACEC Central Europe Limited S.R.L.		
Reference	Arrangement & Installation		
Revision	I/1		
Number	AP1301336A1_2		
Date	2002-07-19		
Author	E. E. E.		
Check	E. E. E.		
Drawn	E. E. E.		
Approved	E. E. E.		
Scale	1:1		
Material	E. E. E.		
Quantity	E. E. E.		
Unit	E. E. E.		
Remarks	E. E. E.		




FRONTAL VIEW




SIDE VIEW IS FUNCTION (SWITCH DISCONNECTOR)




SIDE VIEW CIS FUNCTION (TRANSFORMER PROTECTION)




SINGLE LINE DIAGRAM



LAY-OUT



Floor setting to be executed
according to cable with grooves



CABLES (DRY INSULATEUR)	SECTION (mm2)	BENDING RADIUS	b
SINGLE	< = 50	370	400
SINGLE	70 < X < 120	440	450
SINGLE	120 a 150	450	500
SINGLE	185 a 240	600	550
THREE	< = 160	550	660
THREE	150 a 165	650	770
THREE	185 a 240	840	900

Tolerancias gerais: ISO 2768-m ou APES 98025

General Tolerances: ISO 2768-m or APES 98025

Este documento é propriedade da EFACEC. As informações, especificações, condições de montagem e uso devem ser utilizadas apenas para o equipamento EFACEC. Não são permitidas a reprodução, a distribuição ou a utilização em equipamentos de terceiros sem a autorização expressa da EFACEC.

This document is the property of EFACEC. The information, specifications, assembly conditions and use must be used only for EFACEC equipment. Reproduction, distribution or use in third party equipment without the express authorization of EFACEC is not permitted.

Proj.: -

Proj.: -



EFACEC
S.A.
AV. 1001336A1-4

Tender in CEZ for kiskos
EFACEC Central Europe Limited S.R.L.
Arrangement & Installation

Page / Pág.
1/1

Revision / Revisão
Number / Número

Data / Dia

ТОВА ОБОРУДВАНЕ СЪДЪРЖА
ФЛУОРИРАНИ ПАРНИКОВИ ГАЗОВЕ
ПО ПРОТОКОЛА ОТ КИТО.

СЕРЕН ХЕКСАФУОРИД SF6.

ХЕРМЕТИЧНА СИСТЕМА ПОД НАЛЯГАНЕ СПОРЕД IEC 62271-1
SF6 газа съдържащ се в тази електрическа система
трябва да бъде рециклиран и не изпуснат в атмосферата.

Масата в килограми на газа е написана на табелата с данните.

FLUOFIX GC

Efacesc

Сериен N:

IEC 62271-1/100/102/200

Ur:	kV	Fr:	Hz	Ud:	kV
-----	----	-----	----	-----	----

Ik:	kA	tk:	s	Ip:	kA
-----	----	-----	---	-----	----

Ir:	A	Up:	kV	Pre:	Mpa
-----	---	-----	----	------	-----

Ua:

Чертеж:

Поз:

Маса на SF6 газ:

IAC

О.Н. / Прод./Номер

Година на производство:

ВЪРНО С
ОПТИМАЛНА



THIS EQUIPMENT CONTAINS
 FLUORINATED GREENHOUSE GASES
 COVERED BY THE KYOTO PROTOCOL

SULPHUR HEXAFLUORIDE GAS (SF6)

Sealed pressure system acc. IEC 62271-1.

SF6 gas contained in this electrical equipment
 shall be recovered and not released into the
 atmosphere.

Mass in kilograms referred to in the nameplate.



efatec

FLUOFIX GC

S/N:

IEC 62271-1/100/102/200

Ur:	kV	fr:	Hz	Ud:	kV
Ik:	kA	tk:	s	Ip:	kA
Ir:	A	Up:	kV	Pre:	MPa

Ua:

Wiring Diagram:

Pos.:

Mass of SF6 gas

IAC:

O.F. / P/N:

Manufacturing Year:



ВРРНО С
 ОПРМНАМ





Кимтех България ООД
1113 гр. София
ул. Акад. Георги Бончев № 20

официален дистрибутор на
~~Lucas~~ Electronics
кабели, трансформатори,
електрооборудване

тел: 02 9733373
факс: 02 9733370
web: www.kimtech.bg
e-mail: office@kimtech.bg

Списък на проведените изпитвания на КРУ с SF6 12/24(25)kV

1. Температурен тест.
2. Вътрешна дъга
3. Механични тестове и на късо съединение
4. Краткотраен и пиков ток
5. Диелектрични
6. Издръжливост - механични тестове
7. Ниво на защита
8. Включвателна и изключвателна способност
9. Включвателна и изключвателна способност на късо съединение
10. Разни

13.01.2016г.

Подпис и печат:



Test Report

CESI

Approved

Page 1

Client EFACEC Energia, Máquinas e Equipamentos Eléctricos, S.A

Address of the Client Apartado 1018 - 4466 - 952 S. Mamede de Infesta - PORTUGAL

Tested samples/items A.C. three-phase SF₆ gas-insulated metal-enclosed switchgear (RMU) for indoor application

Tests carried out Arcing due to internal fault

Standards/Specifications IEC 62271-200 (2003)

Tests date from December 3, 2008 to December 3, 2008

The results reported in this document relate only to the tested samples/items.
Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 13

No. of pages annexed 4

Issue date April 29, 2009

Prepared QED - Beccarini Pierangelo

Verified QED - Arneodo Giorgio, PPR - Ronchi Daniele

Approved LAP - Il Responsabile - Nicolini Roberto



DT0001G rev. 04

CESI
Centro Elettrotecnico
Sperimentale Italiano
Giacinto Motta spa

Via R. Rubattino 54
20134 Milano - Italia
Telefono +39 022125.1
Fax +39 0221255440
<http://www.cesi.it>

Capitale sociale 8 550 000 Euro
interamente versato
Codice fiscale e numero
iscrizione CCLIAA 00793580150

Registro Imprese di Milano
Sezione Ordinaria
N. R.E.A. 429222
P.I. IT00793580150

BIPHO C
OPINIA

Tests witnessed by

Mr. M. Martins
Mr. E. Barbosa
Mr. L. Pinto

BFACEC Energia, Máquinas e Equipamentos Eléctricos, S.A
BFACEC Energia, Máquinas e Equipamentos Eléctricos, S.A
BFACEC Energia, Máquinas e Equipamentos Eléctricos, S.A

Identification of the object Not requested.

The drawings ref. No.A9012486 No.1 and 2 have been annexed to this document on the request of the Client.
CESI has not checked the details of these drawings.


Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: A8035509

The measurement uncertainties of the test results reported in the document are the following:

voltage: $\pm 5\%$; current: $\pm 5\%$; time: $\pm 5\%$; temperature: $\pm 2\text{ }^{\circ}\text{C}$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

ВЯНОС
ОПТИКА



Contents	Page	Test date
<p>Rated characteristics of the tested object assigned by the Client</p> <p>Test arrangement</p> <p>Composition of the tested object</p> <p>Test procedure (Supply points and arc initiation points)</p> <p>Tests carried out</p> <p> Three-phase arcing due to internal fault test with 16,5 kA for 1,02 s on busbar compartment</p> <p>Assessment of the test</p> <p>Test circuit</p> <p>Photos</p> <p>Pages annexed</p> <p> Oscillograms (No.2)</p> <p>Reference documents annexed</p> <p> Client's drawings - CESI Ref.No. A9012486 (No.2)</p>	<p>4</p> <p>5</p> <p>6</p> <p>7</p> <p>8</p> <p>9</p> <p>10</p> <p>11 to 13</p>	<p>December 3, 2008</p>

**ВЯРНО С
ОПРЕДЕЛЕНА**



Test Report

CESI

A9006689-1

Approved

Page 4

Rated characteristics of the tested object assigned by the Client

Metal-enclosed switchgear

Manufacturer	BFACEC Energia, Máquinas e Equipamentos Eléctricos, SA
Type	Fluofix GC
Serial number	S18002990
Voltage	24 kV
Insulation level	
Lightning impulse withstand voltage	125/145 kV
Power frequency withstand voltage	50/60 kV
Frequency	50 Hz
Normal current	630 A
Short-time withstand current	16 kA
Peak withstand current	40 kA
Short-circuit duration	3 s
Internal fault : Short-circuit current	16 kA
Internal fault : Short-circuit duration	0,5 s
Internal fault : Classification IAC (Initials for Internal Arc Classified)	AF
Pressure of SF6 gas for interruption and insulation	0,13 MPa abs.

Functional unit : Busbar compartment

Number of phases	3
Number and section of the busbars	1 // 32 x 5 mm ²
Voltage	24 kV
Normal current	630 A
Short-time withstand current	16 kA
Short-circuit duration	3 s

Functional unit : Feeder cable compartment



EXPHO C
TRUHANIA

Arcing due to internal fault

Purpose of the test




The purpose of the test is to assess the behaviour of the apparatus under arcing stress due to an internal fault at the light of the criteria listed in Annex A of IEC 62271-200.

Test arrangement

The test arrangement (choice of the functional units, their number, equipment, position in the room and place of the initiation of the arc) was indicated by the client.

The complete board was placed in the hall in observance of the dimensions of the actual installation in service.

The room was represented by the floor, the ceiling and two perpendicular walls, as shown in the following figures:



i : Position of indicators

- A : 200 cm
- B : 50 cm
- C : 30 cm
- D : 10 cm
- E : 128 cm
- F : 250 cm
- G : 10 cm

The indicators for observing the thermal effects of the gases were fitted vertically, placed up to a height of 2 m and at distance of 30 cm from the metal enclosure.


Other indicators were placed horizontally at a height of 2 m above the floor and between 30 cm and 80 cm from the enclosure.

The indicators used during the tests consisted of pieces of black cretonne (150 g/m²), fitted in frames of steel sheet having dimensions 150 mm × 150 mm.

High speed motion pictures


During the test, pictures were taken by high speed video camera.

ВЪПРОС
 ОПИТНАТА




Arcing due to internal fault

Composition of the tested object




ВЯРО С
ОПТИМАЛ




Arcing due to internal fault

Test procedure (Supply points and arc initiation points)



ВЪРНО С
ОПРИМАНА



Three-phase arcing due to internal fault test with 16,5 kA for 1,02 s

Test circuit : See D0010 Supply circuit : Insulated Power factor : <0,15 Frequency : 50 Hz Enclosure of the apparatus : Earthed

Test arrangement : See page 5

Test procedure : See page 7

Supply point of the apparatus : Cable compartment, left unit

Arc initiation point : 1 - (Busbar compartment)

The arc was initiated among the phases by means of metallic wire of 0,5 mm in diameter

The SF6 gas was replaced by air at atmospheric pressure


Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
2	1	kA 16,5	kA 43,0

Condition of the apparatus before the tests: new.

Date: December 3, 2008

Test No.	Oscillogram No.	Functional unit under test No.	Compartment under test	Applied voltage Phase to phase KV	Duration s	Test current		Maximum overpressure Bar	Photos		Notes
						rms value kA	Peak value kA		before the test No.	after the test No.	
1	4	-	Busbar compartment	20,5	1,02	16,5	43,0	-	1-2	3	-

Condition of the apparatus after the tests: see next page.



ВРПНГ
ОПНМ
Test Report

CESI

Assessment of the test (Based on IEC 62271-200)

Test No.	Criterion (Fulfilled – See note No. – Not applicable)				
	No.1	No.2	No.3	No.4	No.5
1	Fulfilled	Fulfilled	Fulfilled	Fulfilled	Fulfilled

The following criteria listed in the mentioned Standard have been allowed for the assessment of arcing effects:

Criterion No.1

Correctly secured doors and covers do not open. Deformations are accepted, provided that no part comes as far as the position of the indicators or the walls (whichever is the closest) in every side. The switchgear and controlgear do not need to comply with its IP code after the test.

To extend the acceptance criterion to an installation mounted closer to the wall than tested (refer to item a) of A.3.2), two additional conditions shall be met:

- the permanent deformation is less than the intended distance to the wall;
- exhausting gases are not directed to the wall.

Criterion No.2

- No fragmentation of the enclosure occurs within the time specified for the test.
- Projections of small parts, up to an individual mass of 60 g, are accepted.

Criterion No.3

Arcing does not cause holes in the accessible sides up to a height of 2 m.

Criterion No.4

Indicators do not ignite due to the effect of hot gases.

Should they start to burn during the test, the assessment criterion may be regarded as having been met, if proof is established of the fact that the ignition was caused by glowing particles rather than hot gases. Pictures taken by high-speed cameras, video or any other suitable means can be used by the test laboratory to establish evidence.

Indicators ignited as a result of paint or stickers burning are also excluded.


Criterion No.5

The enclosure remains connected to its earthing point. Visual inspection is generally sufficient to assess compliance. In case of doubt, the continuity of the earthing connection shall be checked (refer to 6.6, point b)).



**ВЯНО С
ОПШНАА**

Test circuit D0010



Symbols used in this diagram are the same as those on the oscillograms.



**ВЕРНО С
ОРИГИНАЛ**





Photo No.1



**ВЪРНО С
ОРИГИНАЛ**





Photo No.2








Photo No.3

D1093IG



БЯРНО С
ОРИГИНАЛ

Ip.T = 43 kA




1061 1070 1080 1090 1100 1110 1120 1130 1140 1150 1160 1170 1180 1194
1 [ms/div.]
A8035509, Oscill. No. 0002

Sam: 3SEC, Osc: 803F, Cal: 8D3F



CEST
OPRIMIA
BAPHO C

$I_p \cdot T = 43,4 \text{ kA}$
 $dt = 1,02 \text{ s}$



1061 1100 1150 1200 1250 1300 1350 1400 1450 1500 1550 1600 1650 1700 1750 1800 1850 1900 1950 2000 2050 2105
10 [ms/div.]
A8035509, Oscill. No. 0004

Sam.: 3SEC, Osc: BD3F, Cal: BD3F



ВНИИЭС
ОПТИМАЛ
CESI P148

Independent, accredited testing station · Member laboratory of STL and LOVAG

TYPE TEST REPORT

NO. 2197.2090578.0340

EFACEC Energia, Máquinas e Equipamentos Elétricos, SA.
Apartado 1018
4466-952 S. Mamede de Infesta
PORTUGAL

CLIENT

EFACEC Energia, Máquinas e Equipamentos Elétricos, SA.

MANUFACTURER

Three-phase metal-enclosed SF₆-insulated medium voltage switchgear

TEST OBJECT

Fluofix GC

TYPE

S 18002991

SERIAL NO.

Rated voltage	U_r	24 kV	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Rated normal current	I_r	630 A	
Rated peak withstand current	I_p	50 kA	
Rated short-time withstand current	I_k	20 kA	
Rated duration of short-circuit	t_k	1 s	
Internal arcing classification		IAC AFL 20 kA 1 s	

IEC 62271-200: 2003-11

IEC 62271-1: 2007-10

NORMATIVE
DOCUMENT

Test under conditions of arcing due to Internal fault


RANGE OF TESTS
PERFORMED

4 and 5 June 2009

DATE OF TEST

The ratings of the test object related to the scope of test have been proved. The test has been PASSED

TEST RESULT

H. GLABSCH
Senior engineer


W. MORITZ
Test engineer in charge

Berlin, 05 August 2009



Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DAkT) e.V. in the fields of high voltage apparatus and switchgear, power cables and power cable accessories, LV apparatus and switchgear, installation equipment and switching and control equipment.
Institut „Prüfwerk für elektrische Hochleistungstechnik“ GmbH (IPH Berlin) is a subsidiary of CESI SpA, Milan.

ВАРНО С
СЕРТИФИКАТ



Contents	Sheet
1. Present at the test.....	3
2. Test performed.....	3
3. Identity of the test object.....	4
3.1 Technical data and characteristics.....	4
3.2 Identity documents.....	5
4. Test under conditions of arcing due to internal fault.....	6
4.1 Test laboratory.....	6
4.2 Normative document.....	6
4.3 Required test parameters.....	6
4.4 Test arrangement.....	7
4.5 Test and measuring circuits.....	8
4.6 Test results.....	10
4.7 Evaluation of test.....	13
5. Photos.....	14
6. Oscillograms.....	24
7. Drawing.....	27

This test document consists of 31 sheets.

Distribution

Copy No. 1 in English:

EFACEC Energia, Máquinas e Equipamentos Eléctricos, S.A.

The test results relate only to the object tested.
 This document is confidential. Its transfer to third parties as well as its reproduction in extracts require the consent of the client.




1. Present at the test

Mr. Moritz	IPH test engineer in charge
Mr. Martins	EFACEC AMT
Mr. Barbosa	EFACEC AMT

2. Test performed

Test under conditions of arcing due to Internal fault

**ВАРНО С
ОРИГИНАЛА**

3. Identity of the test object

3.1 Technical data and characteristics

The technical data and characteristics of the test object are defined by the following parameters and specified by the client.

Test object: Three-phase metal-enclosed SF₆-insulated medium voltage switchgear
 Type: Fluofix GC
 Manufacturer: EFACEC Energia, Máquinas e Equipamentos Electricos, S.A.
 Serial No.: S 18002991
 Year of manufacture: 2009

Data:	Rated voltage	U_r	24 kV
	Rated short-duration power-frequency withstand voltage	U_d	50 kV
	Rated lightning impulse withstand voltage	U_p	125 kV
	Rated frequency	f_r	50 Hz
	Rated normal current	I_r	630 A
	Rated peak withstand current	I_p	50 kA
	Rated short-time withstand current	I_k	20 kA
	Rated duration of short-circuit	t_k	1 s
	Internal arcing classification		IAC AFL 20 kA 1 s

Characteristics:	Number of functional units	3
	Height	1275.3 mm
	Width	1190 mm
	Depth	727 mm
	Insulating medium	SF ₆
	Rated Pressure (abs rel. to 20 °C)	0.03 MPa
	Pressure relief disc dimension	See drawing
	Insulating medium during test	Air
	Unit bottom	open
	Busbar dimensions	Ø 16 mm
	Busbar pole centres distance	115 mm
	Unit bottom	open

Built-in components: Three position switch-disconnector

**ВАЖНО С
ОПРЕДЕЛЕНИЕ**



3.2 Identity documents

The manufacturer confirms that the test object has been manufactured in compliance with the drawings given in this document. IPH did not verify this compliance in detail.
 The identity of the test object is fixed by the following drawings and data submitted by the client:

Name of drawing	Drawing No.	Date of drawing	Author	Notes
Fluofix GC 2 IS + 1 CIS	33108059	18.02.08	EFACEC	Sheet 27
Overpressure protection valve	DI1501259	20.03.04	EFACEC	Sheet 28
Extremity panel	33109326	22.05.09	EFACEC	Sheet 29
Riveted door	33108567	22.07.08	EFACEC	Sheet 30
Assembled tank	33107698	30.11.07	EFACEC	Sheet 31

Entry of test object at IPH: 3 June 2009

**ВАРНО С
ОПШИНАТА**



КИМТЕХ-БЪЛГАРИЯ
ООО
КИМТЕХ
БЪЛГАРИЯ

4. Test under conditions of arcing due to internal fault

4.1 Test laboratory

High-power test laboratory, test bay 1

4.2 Normative document

IEC 62271-200: 2003-11

4.3 Required test parameters


Required test values as agreed with the client:

Peak current	50 kA
Short-circuit current	20 kA
Duration of short-circuit	1 s
Internal arcing classification	IAC AFL 20 kA 1 s

Distances of the test object to the walls of the room mock-up			Spacing of Indicators
Front	F	Freely accessible	300 mm
Left side wall	L	Freely accessible	300 mm
Right side wall	L	100 mm	None
Rear side	R	100 mm	None
Ceiling height above test object		600 mm	-

Assessment of the behaviour under conditions of arcing due to internal fault on the basis of the criteria 1 to 5 of IEC 62271-200: 2003-11.

**ВЕРНО С
ОПРЕДЕЛЕНА**



4.4 Test arrangement

The switchgear consisted of three functional units arranged as an assembly. The test was conducted in a mock-up of a room with a ceiling height of 600 mm above the switchgear. The switchgear was set up with its right side wall having a distance of 100 mm and with its rear side wall having a distance of 100 mm to the corner of the room mock-up. The front and left roof projection was >1000 mm. A mock-up of a cable duct was used.

Fabric indicators representing type A accessibility were placed vertically in front of the operator's side and of the left side wall of the switchgear up to a height of 2 m in a uniform and in a checkerboard pattern thus covering an area of 40-50 %. The spacing between indicators and switchgear was 300 mm.





Figure 1: Points of Ignition

4.5 Test and measuring circuits

Technical data of test circuits


Test requirement	Tests under conditions of arcing due to internal fault	
Test No.	109 2638, 109 2643, 109 2654	
Number of phases (Test circuit)	3	
Number of poles/phases (Test object)	3	
Power frequency Hz	50	
Power factor $\cos \varphi$	c 0.15	
Earthing conditions	Grid	Not earthed
	Short-circuit transformer	Not earthed
	Short-circuit point	Not earthed
Short-circuit transformer	D/d	



E Supply
 MB Master breaker
 MS Making switch
 L Current-limiting reactor
 Tr Short-circuit transformer

I Current measurement
 U Voltage measurement
 TO Test object
 1 - 6 Measuring points

Figure 2: Test circuit



**ВАРНО С
 ОПИТНАТА**

Technical data of measuring circuits

Measuring point	Symbol	Measured quantity	Measuring sensor/device
1	I L1	Short-circuit current L1	Rogowski measuring device
2	U L1	Voltage L1	RC divider
3	I L2	Short-circuit current L2	Rogowski measuring device
4	U L2	Voltage L2	RC divider
5	I L3	Short-circuit current L3	Rogowski measuring device
6	U L3	Voltage L3	RC divider
-	P _{ges}	Arc power	Calculated value
-	W	Arc energy	Calculated value
Recording instrument BE 256 transient recorder system			



**БАН С
ОФИЦИАЛНА**


4.6 Test results

Test requirement: Test under conditions of arcing due to internal fault

Test No.	109	2638
Test voltage	kV	12.2
Prospective peak short-circuit current	kA	L1 43.3
		L2 39.4
		L3 53.2
Prospective symmetrical short-circuit current	kA	L1 20.2
		L2 20.4
		L3 20.3
		Average 20.3
Duration of short-circuit	s	1.01
Notes		1)

Notes:

- 1) Verification of the prospective short-circuit current at the test object's input terminals



**ВАЖНО С
ОПТИМАЛНА**

Test results (continued)

Test requirement: Test under conditions of arcing due to Internal fault
 Date of test: 4 June 2009
 Condition of test object before test: New
 Supply of test object: Three-phase at the cable terminal of unit 2
 Arc initiation: Three-phase on the busbar in the gas tank using metal wire of 0.5 mm diameter
 Direction of the arc: To left
 Arrangement of indicators: In front of the switchgear and on the left side of unit 1

Test No.	109	2643
Test voltage	kV	12.1
Peak current	L1	39.6
	L2	40.8
	L3	51.4
Short-circuit current	L1	20.1
	L2	20.2
	L3	20.1
	Average	20.1
Duration of short-circuit	s	1.01
Equivalent duration of short-circuit related to a symmetrical short-circuit current of	s	1.02
	kA	20.0
Maximum power	MW	34.0
Energy converted	MWs	15.1

Notes and condition of test object after test:

Criteria of assessment 1 to 5 of IEC 62271-200: 2003-11:	Compliance:
1 Correctly secured doors, covers etc, do not open. Deformations are accepted provided that no part on any side comes as far as the position of the indicators or walls.	Yes
2 No fragmentation of the enclosure occurs within the time specified for the test. Projections of small parts, up to an individual mass of 60 g, are accepted.	Yes
3 Arcing does not cause holes in the accessible sides up to a height of 2.0 m.	Yes
4 Indicators do not ignite due to the effect of hot gases.	Yes
5 The enclosure remains connected to its earthing point.	Yes



**ВАРНО С
ОПИТНАТА**


Test results (continued)

Test requirement: Test under conditions of arcing due to internal fault
 Date of test: 5 June 2009
 Condition of test object before test: New
 Supply of test object: Three-phase at the cable terminal of unit 2
 Arc initiation: Two-phase between L1-L2 on the cable connections of unit 1 using metal wire of 0.5 mm diameter
 Direction of the arc: Downwards
 Arrangement of Indicators: In front of the switchgear and on the left side of unit 1

Test No.	109	2654
Test voltage	kV	12.1
Peak current	L1	44.7
	L2	44.7
	L3	-
Short-circuit current	L1	17.5
	L2	17.5
	L3	-
	Average	-
Duration of short-circuit	s	1.01
Equivalent duration of short-circuit	s	1.02
related to a symmetrical short-circuit current of	kA	0.87 x 20.0
Maximum power	MW	44.5
Energy converted	MWs	9.5

Notes and condition of test object after test:

Criteria of assessment 1 to 5 of IEC 62271-200: 2003-11:		Compliance:
1	Correctly secured doors, covers etc, do not open. Deformations are accepted provided that no part on any side comes as far as the position of the indicators or walls.	Yes
2	No fragmentation of the enclosure occurs within the time specified for the test. Projections of small parts, up to an individual mass of 60 g, are accepted.	Yes
3	Arcing does not cause holes in the accessible sides up to a height of 2.0 m.	Yes
4	Indicators do not ignite due to the effect of hot gases.	Yes
5	The enclosure remains connected to its earthing point.	Yes



**БЯРО С
ОПТИМАЛНА**

4.7 Evaluation of test

The test object was subjected to a test under conditions of arcing due to an internal fault with a prospective peak current of 53.2 kA and a prospective short-circuit current of 20.3 kA for a duration of short-circuit of 1.01 s.

Assessment of the behaviour under conditions of arcing due to an internal fault on the basis of the criteria 1 to 5 of IEC 62271-200: 2003-11. The criteria were met in:

Test No. 109 2644 - three-phase arc initiation in the gas tank

Test No. 109 2654 - two-phase arc initiation at the cable connection.

The internal arcing classification of IAC AFL 20 kA 1 s has been proved.

The test has been PASSED.

ВАРНО С
ОФИЦИАЛНА



Client EFACEC Energia, Máquinas e Equipamentos Eléctricos, S.A

Address of the Client Apartado 1018 - 4466 - 952 S. Mamede de Infesta - PORTUGAL

Tested samples/items AC three phase SF6 gas-insulated metal-enclosed switchgear (RMU), for indoor/outdoor application, consisting of three functional units

Tests carried out Short-time withstand and peak withstand current tests
Short-circuit making tests

Standards/Specifications IEC 62271-200 (2003)
IEC 62271-102 (2003)
IEC 60265-1 (1998)

Tests date from November 13, 2008 to November 13, 2008

The results reported in this document relate only to the tested samples/items.
Partial reproduction of this document is permitted only with the written permission from CESI.

PUBBLICATO A8035825 (PAD - 1138001)

No. of pages 12


No. of pages annexed 17

Issue date December 10, 2008


Prepared LAP - Beccarini Pierangelo

Verified LAP - Arneodo Giorgio, LAP - Ghezzi Giuseppe

Approved LAP - Nicolini Roberto



D10001G rev.04



Tests witnessed by

Mr. M. Martins	BFACEC
Mr. E. Barbosa	BFACEC
Mr. L. Pinto	BFACEC

Identification of the object Not requested.
The drawings ref. No.A8034422 No.1 to 7 have been annexed to this document on the request of the Client.
CESI has not checked the details of these drawings.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: A8033054

The measurement uncertainties of the test results reported in the document are the following:
voltage: $\pm 5\%$; current: $\pm 5\%$; time: $\pm 5\%$; temperature: $\pm 2^\circ\text{C}$
The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.


Receipt date of the sample November 12, 2008

ВАРХО С
ОПТИМАЛНА



Contents	Page	Test date
Rated characteristics of the tested object assigned by the Client	4-5	
Table of the no-load operations	6	
Test arrangement	7	
Power frequency voltage withstand dry test on the main circuit	8	
Tests carried out	9	November 13, 2008
Three-phase short-time withstand and peak withstand current test with 1,02 kA for 3,00 s on cables earthing switch	10	November 13, 2008
Three-phase short-circuit making tests; test duty No.5 with a prospective peak current of 2,38 kA at 24,1 kV on cables earthing switch	11	
Test circuit	12	
Photos		
Pages annexed		
Oscillograms (No.10)		
Reference documents annexed		
Client's drawings -		
CESI Ref.No.A8034422 (No.7 pages)		

**БЯПРОС
ОПТИМАЛНА**




CESI

Test Report

Rated characteristics of the tested object assigned by the Client

Metal-enclosed	
Manufacturer	EFACEC Energia, Máquinas e Equipamentos Eléctricos, S.A
Type	Fluoffix GC
Serial number	S 18002990
Voltage	24 kV
Insulation level	
Lightning impulse withstand voltage	
To earth and between phases	125 kV
Across the isolating distance	145 kV
Power frequency withstand voltage	
To earth and between phases	50 kV
Across the isolating distance	60 kV
Frequency	50 Hz
Normal current	630 A
Short-time withstand current	
Main circuit	16 kA
Earthing circuit	16 kA
Peak withstand current	
Main circuit	40 kA
Earthing circuit	40 kA
Short-circuit duration	3 s
Pressure of SF6 gas for insulation (referred to 20 °C)	0,13 MPa abs.



Cont'd

General purpose switch	
Manufacturer	BFACEC Energia, Máquinas e Equipamentos Eléctricos, S.A
Type	ISFG
Serial number	37326730
Switching operations class	E3
Mechanical endurance class	M1
Voltage	24 kV
Insulation level	
Lightning impulse withstand voltage	125 kV
To earth and between phases	145 kV
Across the isolating distance	
Power frequency withstand voltage	50 kV
To earth and between phases	60 kV
Across the isolating distance	50 Hz
Frequency	630 A
Normal current	630 A
Mainly active load breaking current	630 A
Closed-loop breaking current	6,30 A
No-load transformer breaking current	25 A
Cable-charging breaking current	25 A
Line-charging breaking current	100 A
Earth fault breaking current	75 A
Cable and line-charging breaking current under earth fault conditions	40 kA
Short-circuit making current	16 kA
Short-time withstand current	3 s
Short-circuit duration	
Earthing switch	
Making capability class	E2
Supply side	
Short-circuit making current	40 kA
Short-time withstand current	16 kA
Short-circuit duration	3 s
Pressure of SF6 for breaking (referred to 20 °C)	0,13 MPa abs.
Cables earthing switch	
Making capability class	E2
Supply side	
Short-circuit making current	2,50 kA
Short-time withstand current	1,00 kA
Short-circuit duration	3 s
Pressure of SF6 for Making (referred to 20 °C)	0,13 MPa abs.

**БЪЛГАРСКО
ОБЩЕСТВО**




D1232IG

Table of the no-load operations

Vn: Rated voltage of the auxiliary device

Oscillogram No.	Operating sequence	Opening device		Supply voltage Closing device		Motor		Gas operating pressure for Interruption		Opening time	Closing time	Opening time	Made		
		V	% Vn	V	% Vn	V	% Vn	MPa abs.	MPa abs.				ms	ms	before the test No.
8	C			110	-	-	-	-	-	-	1577	-	ms	2	-



Test Report


CESI

Approved

A8035825

Page 6

D8006 - Test arrangement



Test performed No.	Apparatus under test	Supply on point	Load or short-circuit on point
1 to 6	Cables earthing switch	A	B




ВАРНО С
ОРИГИНАЛ

Power frequency voltage withstand dry test on the main circuit

Tests effected	Applied voltage (kV for 60 s) across the pole		
	R	S	T
After the test No.6	40	40	40

Note: No discharge occurred during the test.



D1066IG

Three-phase short-time withstand and peak withstand current test with 1,02 kA for 3,00 s

Test circuit : Sec D0026 Power factor : <0,15 Frequency : 50 Hz

Test arrangement : See page 7
Pressure of SF6 gas during the test : 0,12 MPa abs


Under test: Cables earthing-switch

Condition of the apparatus before the tests: new, see photos No.1 and 2 Supply side of the test circuit connected to : see page 7

Date: November 13, 2008

Test No.	Oscillogram		Duration s	Maximum peak kA	Test current			Average kA	Notes
	No.	Sheets			Phase	rms value kA	Phase		
1	7	2	3.00	2,58	T	T	1,02	-	

Condition of the apparatus after the tests: after the test the cables earthing switch operated properly.



Test Report

CESI

Approved

A8035825

Page 9

Three-phase short-circuit making tests; test duty No.5 with a prospective peak current of 2,58 kA at 24,1 kV

Test circuit : See D0026 Power factor : <0,15 Frequency : 50 Hz

No.	Prospective test current	
	Oscillogram	Peak value
10	Sheets 1	kA 2,58

Supply voltage for operating device		
Closing	Opening	Motor
V d.c.	V d.c.	V d.c.
110	-	-


Test arrangement : See page 7
Pressure of SF6 gas during the test : 0,12 MPa abs

Under test: Cables earthing-switch
Condition of the apparatus before the tests: as after the test No.1 Supply side of the test circuit connected to : see page 7

Date: November 13, 2008

Test No.	Oscillogram		Operating sequence	Applied voltage Phase to earth kV	Making current Peak value kA	Phase	rms value kA	Current		Duration s	Closing time ms	Pre-arcing time ms
	No.	Sheets						Average	ms			
2	12	1	C	13,9 13,9 13,9	2,47	T	0,98 0,98 0,98	0,98	-	0,20	-	-
3	13	1	C	13,9 13,9 13,9	2,57	S	0,98 0,98 0,98	0,98	-	0,20	-	-
4	14	1	C	13,9 15,9 13,9	2,56	T	0,98 0,98 0,98	0,98	-	0,20	-	-
5	15	1	C	13,9 13,9 13,9	2,55	S	0,98 0,98 0,98	0,98	-	0,20	-	-
6	17	1	C	13,9 13,9 13,9	2,54	R	0,98 0,98 0,98	0,98	-	0,20	-	-

Condition of the apparatus after the tests: after the tests the cables earthing switch operated properly, see verifications on page 8.



CESI

Test Report

Approved

Page 10

A8035825



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

TEST REPORT
No. MT.99.3.C.072.I

Ring Main Unit Fluofix GC with SF6 three position switch disconnector type ISFG

Trip linkages mechanical reliability test

Test regulations applied:

- IEC 420 (1990).
- IEC 282-1 (1985).
- IEC 298 (1990).

Tests results:

The Ring Main Unit Fluofix passed the tests

Date of tests: February 2nd, 1999.

Tests performed by:

Manuel Martins

The laboratory chief

Rui Cardoso

Date: 99.06.30	MT / ID	T. R. MT.99.3.C.072.I
----------------	---------	-----------------------



ДИПЛОМ
СЕРТИФИКАТ



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

1 - TECHNICAL DATA OF SWITCHGEAR

Ring Main Unit
 Type: Fluofix GC
 Serial no.: Prototype
 Rated voltage: 24 kV
 Rated current: 630 A
 Rated power-frequency withstand voltage: 50 kV
 Rated lightning impulse withstand voltage: 125 kVp
 Rated peak withstand current: 40 kAp
 Rated short-time withstand current: 16 kA / 3 s
 Rated frequency: 50 Hz
 SF6 pressure (20°C): 0.3 bar rel.
 See drawing on page 4.

With SF6 rotary three position disconnecter
 Type: ISFG - Fuse Switch function
 Serial no.: Prototype
 Rated voltage: 24 kV
 Rated current: 200 A
 Rated power-frequency withstand voltage: 50 / 60 kV
 Rated lightning impulse withstand voltage: 125 / 145 kVp
 Breaking capacity:
 Active charge: 200 A
 No-load transformer: 1250 kVA
 No-load cables: 16 A
 Rated short-time withstand current: 16 kA / 3 s
 Rated peak withstand current: 40 kAp
 Rated frequency: 50 Hz
 See drawing of fuse casing on page 5 and trip mechanism on page 6.

2 - MANUFACTURER

EFACEC, Medium Voltage Switchgear Direction.

3 - TESTS PERFORMED

Current limiting fuses with built-in striker pin linkages mechanical reliability test, In accordance with IEC420 (point 6.106.2) with 100 operating cycles according to the following scheme:

No. of operations	Pole tested	Striker energy	Total no. of operations
30	L1	Minimum	30
30	L2	Minimum	60
30	L3	Minimum	90
10	L1 L2 L3	Maximum	100

- Recorded characteristics at the start and the end of the test
- ISFG switch tripping time for the striker pin
 - Minimum striker energy needed in order to trip the ISFG switch;
 - Minimum striker travel needed in order to trip the ISFG switch.

Date: 99.06.30	MT / ID <i>Jr</i>	T. R. MT.99.3.C.072.1
----------------	-------------------	-----------------------



Page 2 / 6

**ВЪПРОС
ОРИГИНАЛ**



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

4 - TEST CONDITIONS

It was used fuse striker simulators delivering the strike energy of a medium type fuse striker.

For the minimum striker energy operations, the fuse striker simulator delivered the strike energy of $0.5J \pm 0.05J$ with a total strike travel of 9 mm.

For the maximum striker energy operations, it was used three fuse striker simulators working simultaneously, each delivering the strike energy of $1.5J \pm 0.05J$ with a total strike travel of 9 mm.

5 - TESTS RESULTS

Test start			
Parameters		Value	Units
ISF switch tripping time	Pole L1	61	ms
	Pole L2	60	ms
	Pole L3	59	ms
Minimum striker energy	Pole L1	0.24	J
	Pole L2	0.29	J
	Pole L3	0.29	J
Minimum striker travel	Pole L1	8	mm
	Pole L2	8	mm
	Pole L3	8	mm


Test start F.N.S.			
Parameters		Value	Units
ISF switch tripping time	Pole L1	58	ms
	Pole L2	59	ms
	Pole L3	56	ms
Minimum striker energy	Pole L1	0.24	J
	Pole L2	0.26	J
	Pole L3	0.29	J
Minimum striker travel	Pole L1	8	mm
	Pole L2	8	mm
	Pole L3	8	mm

During the 100 operating cycles no malfunction has been detected.

There is no remarkable change of characteristics after the test.

After the 100 operating cycles and using a fuse striker dummy 9mm long inserted in each phase at a time, it was observed that the ISFG switch cannot remain closed after the spring recharge operation.

Date: 99.06.30	MT / ID <i>[Signature]</i>	T. R. MT.99.3.C.072.I	Page 3/6
----------------	----------------------------	-----------------------	----------






Stamp: КИМТЕХ БУРГАС



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION


Fluoffix GC Ring Main Unit



Date: 99.06.30

MT / ID *[Signature]*

T. R. MT.99.3.C.072



**ВАРИАНТ С
ОРИГИНАЛ**



EFACEC ENERGY
MEDIUM VOLTAGE SWITCHGEAR DIVISION

TEST REPORT
No. DI.02.3.15.036.I

Prefabricated panel Fluofix GC with SF6 three position switch disconnecter type ISFG

Temperature rise tests at 37.5 A with 43 A SIBA fuses

Test regulations applied:

IEC 298 (1990).
IEC 694 (1980).
IEC 282-1 (1985).

Tests results:

The temperature rises did not exceed the permissible values in accordance with the above mentioned standards at an ambient air temperature not exceeding 40 °C.


Date of tests: 3rd of August, 2001.


Tests performed by:

Manuel Martins

The laboratory manager

Miguel Carvalho

Date: 2002.02.15  T. R. DI.02.3.15.036.I





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

1 - TECHNICAL DATA OF SWITCHGEAR

Prefabricated panel

Type: Fluofix GC
Serial no.: -
Rated voltage: 24 kV
Rated current: 630 A
Rated power-frequency withstand voltage: 50 / 60 kV
Rated lightning impulse withstand voltage: 125 / 145 kVp
Rated peak withstand current: 63 kAp
Rated short-time withstand current: 25 kA / 1 s
Rated frequency: 50 Hz

with SF6 rotary three position switch disconnector

Type: ISFG
Serial no.: -
Rated voltage: 24 kV
Rated current: 630 A
Rated power-frequency withstand voltage: 50 / 60 kV
Rated lightning impulse withstand voltage: 125 / 145 kVp
Breaking capacity:
Active charge: 630 A
No-load transformer: 1250 kVA
No-load cables: 16 A
Closing capacity: 40 kAp
Rated short-time withstand current: 25 kA / 1 s
Rated peak withstand current: 63 kAp
Rated frequency: 50 Hz
SF6 pressure (20°C): 0.3 bar rel.

Medium voltage fuses


Type: SIBA
Rated voltage: 24 kV
Rated current: 43 A

Resistance measurement

L1 fuse: 33.8 mΩ
L2 fuse: 34.0 mΩ
L3 fuse: 33.6 mΩ

2 - MANUFACTURER

EFACEC, Medium Voltage Switchgear Division

Date: 2002.02.15		T. R. DI.02.3.15.036.I	Page
------------------	---	------------------------	------





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIVISION

3 - TESTS PERFORMED

Temperature rise test with 37.5 Aac - 50 Hz.

4 - TEST CONDITIONS

A compact switchgear provided with a SF6 switch disconnectors type ISFG.
The tests were performed under 37.5 A three - phase. Supply was ensured through the three phases of the cable compartment (Ring - left side), the short-circuit point was done in the three phases cables (Fuse protection) .

Supply connections from current transformer to the switchgear: 1 x 95 mm² copper.
The supply connections has been connected to the cables compartment.

5 - TESTS RESULTS

The maximum permissible temperature rises are:
- At a silver coated connection: 75 °C
- At a silver coated contact: 65 °C

The temperature rises with a current of 37.5 Aac did not exceed the permissible values in accordance with above mentioned standards at an ambient air temperature not exceeding 40 °C.

6 - MEASURING VALUES

According drawing on page 4:

Measuring points	Designation	Temperature rise in °C
1	Fuse holder contact	50.0
2		52.3
3		52.6
4	Terminal fuse (back)	59.6
5		61.6
6		60.2
7	Terminal fuse (front)	57.0
8		59.1
9		59.0
10	Fuse holder cover contact (fuse side)	56.9
11		61.2
12		59.2
13	Fuse holder cover contact (holder side)	52.2
14		56.9
15		55.9

Date: 2002.02.15

T. R. DI.02.3.15.036.I

Page 3 / 4


БЛЮС
ОРГАНИЗМ





EFACEC ENERGY
MEDIUM VOLTAGE SWITCHGEAR DIVISION


Ambient air temperature: 26.9 °C



Handwritten signature

Date: 2002.02.15	<i>Handwritten signature</i>	T. R. DI.02.3.15.036.I	Page 4
------------------	------------------------------	------------------------	--------

ВАРНО С ОРЪЖИЯТА



КЪМТЕХ
БЪЛГАРИЯ
БУРГАС



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

TEST REPORT
No. MT.00.3.C.075.I

Ring Main Unit Fluofix GC with SF6 three position switch disconnector type ISFG

Measurement of the insulation resistance

Test regulations applied:

IEC 298 (1990).
IEC 694 (1996).

Tests results:

The prefabricated panel Fluofix GC passed the tests.

Date of tests: 28th Mars 2000


Tests performed by:

Manuel Martins

The laboratory chief

Rui Cardoso

Date: 2000.05.31	MT / ID		T. R. MT.00.3.C.075.I	Page 5
------------------	---------	--	-----------------------	--------





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

1 - TECHNICAL DATA OF SWITCHGEAR

Prefabricated panel

Type: Fluofix GC
Serial no.: -
Rated voltage: 24 kV
Rated current: 630 A
Rated power-frequency withstand voltage: 50 / 60 kV
Rated lightning impulse withstand voltage: 125 / 145 kVp
Rated peak withstand current: 40 kAp
Rated short-time withstand current: 16 kA / 3 s
Rated frequency: 50 Hz
Drawing on page 5

With SF6 rotary three position switch disconnector

Type: ISFG
Serial no.: -
Rated voltage: 24 kV
Rated current: 630 A
Rated power-frequency withstand voltage: 50 / 60 kV
Rated lightning impulse withstand voltage: 125 / 145 kVp
Breaking capacity:
Active charge: 630 A
No-load transformer: 1250 kVA
No-load cables: 16 A
Closing capacity: 40 kAp
Rated short-time withstand current: 16 kA / 3 s
Rated peak withstand current: 40 kAp
Rated frequency: 50 Hz
SF6 pressure (20 °C): 0.3 bar rel.

2 - MANUFACTURER

EFACEC, Medium Voltage Switchgear Direction

3 - TEST PERFORMED


Measurement of the insulation resistance

4 - TEST CONDITIONS

Tests performed according circuit diagram on page 4.

Tests performed under 5000 Vdo.

Date: 2000.05.31	MT / ID	<i>[Signature]</i>	T. R. MT.00.3.C.075.I	2 / 5
------------------	---------	--------------------	-----------------------	-------





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

5 - TESTS RESULTS

According drawing on page 4:

5.1 - ISFG's switch disconnectors closed in service position

(Test between phases)

Resistance (M Ω)		
L1 - L2 A - B	L1 - L3 A - C	L2 - L3 B - C
> 50 000	> 50 000	> 50 000

5.2 - ISFG's switch disconnectors closed in service position

(Test between phases and earth)

Resistance (M Ω)		
L1 - earth A - F	L2 - earth B - F	L3 - earth C - F
> 50 000	> 50 000	> 50 000

Date: 2000.05.31 MT / ID *[Signature]* T. R. MT.00.3.C.075.1 Page 5




ВРЪНС
ОРЪЖИЯ



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION



Prefabricated panel Fluofix GC

Date: 2000.05.31	MT / ID	<i>[Signature]</i>	T. R. MT.00.3.C.075.I	Page 4 / 5
------------------	---------	--------------------	-----------------------	------------




**ВЪНШНО С
ОПРЕДЕЛЯНЕ**



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION



Date: 2000.05.31

MT / ID

T. R. MT.00.3.C.079

БЪЛГАРИЯ Page 5 / 5



ВЯРНО С
ОРИГИНАЛА



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

**TEST REPORT
No. MT.00.3.C.078.I**

Ring Main Unit Fluofix GC with SF6 three position switch disconnector type ISFG

Partial discharge measurements

Test regulations applied:

IEC 270 (1981),
IEC 298 (1990).

Tests results:

The prefabricated panel Fluofix GC passed the tests.

Date of tests: January 14th 1999

Tests performed by:

Manuel Martins

The laboratory chief

Rui Cardoso

1 - TECHNICAL DATA OF SWITCHGEAR

Prefabricated panel

Date: 2000.06.07	MT / ID		T. R. MT.00.3.C.078.I	Page 1/3
------------------	---------	--	-----------------------	----------

БЪЛГАРСКО
СТАНДАРТИЗАЦИОННО
УЧРЕЖДЕНИЕ





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

Type: Fluofix GC
Serial no.: -
Rated voltage: 24 kV
Rated current: 630 A
Rated power-frequency withstand voltage: 50 / 60 kV
Rated lightning impulse withstand voltage: 125 / 145 kVp
Rated peak withstand current: 40 kAp
Rated short-time withstand current: 16 kA / 3 s
Rated frequency: 50 Hz
Drawing on page 5

With SF6 rotary three position switch disconnecter

Type: ISFG
Serial no.: -
Rated voltage: 24 kV
Rated current: 630 A
Rated power-frequency withstand voltage: 50 / 60 kV
Rated lightning impulse withstand voltage: 125 / 145 kVp
Breaking capacity:
 Active charge: 630 A
 No-load transformer: 1250 kVA
 No-load cables: 16 A
Closing capacity: 40 kAp
Rated short-time withstand current: 16 kA / 3 s
Rated peak withstand current: 40 kAp
Rated frequency: 50 Hz
SF6 pressure (20 °C): 0.3 bar rel.

2 - MANUFACTURER

EFACEC, Medium Voltage Switchgear Direction


3 - TEST PERFORMED

Partial discharge measurement for 10 pC discharge level.

4 - TEST CONDITIONS

Tests carried out according to IEC 298, annex FF, procedure B.
The voltage set-up transformer was connected to each phase successively and earth was applied to all the parts earthed in service.
The prestress voltage applied was $1.3 \times U_n = 1.3 \times 24 = 31.2$ kV.

Date: 2000.06.07	MT / ID	<i>[Signature]</i>	T. R. MT.00.3.C.078.I	Page 2 / 5
------------------	---------	--------------------	-----------------------	------------





EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

The test voltage for partial discharge measurement was $1.1 \times U_n = 1.1 \times 24 = 26.4$ kV.
Tests performed before and after the dielectric tests.

See test circuits diagram on page 4.

5 - TESTS RESULTS

Voltage applied according to test circuits diagram on page 4.

5.1 - Before dielectric tests

ISFG's switch disconnectors closed in service position.


Phase measured	Partial discharge inception voltage (kV)	Partial discharge extinction voltage (kV)	Partial discharge quantity at 26.4 kV (pC)	Results
Aaa'	29	28	≤ 10 pC	Passed
Bbb'	28	27	≤ 10 pC	Passed
Ccc'	29	27	≤ 10 pC	Passed

5.2 - After dielectric tests

ISFG's switch disconnectors closed in service position.

Phase measured	Partial discharge inception voltage (kV)	Partial discharge extinction voltage (kV)	Partial discharge quantity at 26.4 kV (pC)	Results
Aaa'	28	27	≤ 10 pC	Passed
Bbb'	28	27	≤ 10 pC	Passed
Ccc'	29	28	≤ 10 pC	Passed

Date: 2000.06.07	MT / ID <i>[Signature]</i>	T. R. MT.00.3.C.078.I	Page 3 / 5
------------------	----------------------------	-----------------------	------------






EFACEC ENERGY


MEDIUM VOLTAGE SWITCHGEAR DIRECTION

Partial discharge measurement circuits



Cx: test object
Cb: discharge free capacitor

Fluofix GC single line diagram



ВАРИО С
ОРИЕНТАЛ






EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

Prefabricated panel Fluofix GC



Date: 2000.06.07

MT / ID

T. R. MT.00.3.C.078

Page 5 / 5



ВАРНО С
ОРИЕНТАЛ



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

**TEST REPORT
No. MT.00.3.C.153.I**

Prefabricated panel Fluofix GC with SF6 three position switch disconnector type ISFG

Mechanical Tests

Test regulations applied:

- IEC 60129
- IEC 60265-1
- IEC 60694

Tests results:

The prefabricated panel Fluofix GC passed the Tests.

Date of tests: 16 to 22 May, 2000.

Tests performed by:

Manuel Martins

The laboratory chief

Rui Cardoso



1 - TECHNICAL DATA

Date: 2000.07.19	MT / ID	T. R. MT.00.3.C.153.I	Page 1 / 3
------------------	---------	-----------------------	------------



EFACEC ENERGY

MEDIUM VOLTAGE SWITCHGEAR DIRECTION

SF6 rotary three position switch disconnecter

Type: ISFG
 Serial no.: -
 Rated voltage: 24 kV
 Rated current: 630 A
 Rated power-frequency withstand voltage: 50 / 60 kV
 Rated lightning impulse withstand voltage: 125 / 145 kVp
 Breaking capacity:
 Active charge: 630 A
 No-load transformer: 1250 kVA
 No-load cables: 16 A
 Closing capacity: 63 kAp
 Rated short-time withstand current: 16 kA / 3 s
 Rated peak withstand current: 40 kAp
 Rated frequency: 50 Hz
 SF6 pressure (20 °C): 0.3 bar rel.

Command

Type: CHM
 Command with a motor kit, 110 Vdc.

2 - MANUFACTURER

EFACEC, Medium Voltage Switchgear Direction.

3 - TEST PERFORMED

3.1 - Service position


Mechanical operation test with 2000 close / open operations.

No of operating sequences	Control Voltage	Operating sequence
1800	Rated	C - 15s - O - 15s
100	minimum (85 % Un)	
100	maximum (110 % Un)	
Total:		2000

3.2 - Earth position

1000 close / open manual operations.

Date: 2000.07.19	MT / ID	T. R. MT.00.3.C.153	Page
------------------	---------	---------------------	------



ВРЪЗКА
ОПРЕДЕЛЕНИЕ