

СПИСЪК НА ПРОВЕЖДАНИТЕ ИЗПИТВАНИЯ НА ЛИНЕЙНИ ЗАЩИТНО-КОМУТАЦИОННИ АПАРАТИ НИСКО НАПРЕЖЕНИЕ (НН) ЗА ВЕРТИКАЛЕН МОНТАЖ

Линейни защитно-комутационни апарати ниско напрежение (НН) за вертикален монтаж (ВНР):

ARS 2-6-V/400 A

ARS 3-6-V/630 A

Производство на: APATOR® SA

Улица: Zolkiewskiego 13/29, Пощенски код: 87-100, Населено място: Torun, Страна: Poland

Телефонен номер: +48 56/ 61 91 627

Номер на телефакс+48 56/ 61 91 295

e-mail: trade@apator.com.pl

Homepage: www.apator.com.pl

Типовите изпитвания се провеждат съгласно изискванията на стандарти:

БДС EN 60269-1:2007 - Комутационни апарати за ниско напрежение. Част 1: Общи правила (IEC 60947-1:2007)

БДС EN 60947-3:2009+A1+A2 - Комутационни апарати за ниско напрежение. Част 3: Товарови прекъсвачи, разединители, товарови прекъсвач-разединители и апарати, комбинирани със стопяеми предпазители (IEC 60947-3:2008+A1+A2)

Рутинните (контролни) изпитания се провеждат на представителна извадка от произведените количества съгласно горепосочените стандарти, както следва:

1. Визуална проверка и контрол на продуктите, част от непрекъснатата система за следене на качеството;
2. Контролни изпитвания и сравнение на измерените стойности с нормативно указаните. Маркиране на всеки ВНР с идентификационен и сериен номер, запазване в архивен масив;
3. Механични рутинни изпитвания съгласно предписанията на горепосочените стандарти;
4. Проверка на проектните и фактически размери, контактни повърхности на изделията.

15.01.2020 г.

Кандидат: ИНТЕРКОМПЛЕКС ООД

На основание чл.36а ал.3 от
ЗЗП

тел

60

Примечание TC 1.4

POLSKIE CENTRUM AKREDYTACJI
POLISH CENTRE FOR ACCREDITATION



Sygnatariusz EA MLA
EA MLA Signatory

CERTYFIKAT AKREDYTACJI
LABORATORIUM BADAWCZEGO
ACCREDITATION CERTIFICATE OF TESTING LABORATORY
Nr AB 044

Potwierdza się, że: / This is to confirm that:

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
BIURO BADAWCZE ds. JAKOŚCI
LABORATORIUM BADAWCZE
ul. M. Pożaryskiego 28, 04-703 Warszawa


spełnia wymagania normy PN-EN ISO/IEC 17025:2005
meets requirements of the PN-EN ISO/IEC 17025:2005 standard

Akredytowana działalność jest określona w Zakresie Akredytacji Nr AB 044
Accredited activity is defined in the Scope of Accreditation No AB 044

Akredytacja pozostaje w mocy pod warunkiem przestrzegania
wymagań jednostki akredytującej określonych w kontrakcie Nr AB 044
This accreditation remains in force provided the Laboratory observes
the requirements of Accreditation Body defined in the Contract No AB 044

Certyfikat akredytacji ważny do dnia 20.06.2014 r.
The certificate of accreditation is valid until 20.06.2014

Akredytacji udzielono dnia 30.11.1995 r.
Accreditation was granted on 30.11.1995



DYREKTOR
POLSKIEGO CENTRUM AKREDYTACJI

EUGENI

На основании чл.36а ал.3 от
30П

Warszawa, 4 czerwca 2010 roku

ВАРНО С
ОРИГИНАЛА

61

ЕТ "АДИС - 9 -
Анелия Митева"

АГЕНЦИЯ ЗА
ПРЕВОДИ

Адрес на управление: 4023 Пловдив, ж.р.Тракия, бл.20, ет.9, ап.53, тел: 032/ 826632; 266292

Превод от полски език

APATOR SA

Декларация СЕ за съответствие

| | |
|---|--|
| № | 0023/04 |
| Производител: | APATOR SA |
| Адрес: | ул. Золкиевскиего 13/29; 87-100 Торун Полша |
| Обозначение на продукта (име, тип): | Вертикални разединители с ножови предпазители тип ARS 2- |
| Декларираме, че посочения продукт съответства на следните изисквания: | |
| Европейски директиви: | 73/23/ЕЕС + 93/68/ЕЕС Директива за ниско напрежение, касаеща хармонизирането на правните предписанията на държавите членки, които се отнасят за електрическата техника, предназначена за използване в определени граници на напрежение. |
| Съгласувани стандарти и/или стандарти на IEC: | PN-EN 60947-1 Комутационна и контролна апаратура ниско напрежение Част 1: Общи решения PN-EN 60947-3 Комутационна и контролна апаратура ниско напрежение Част 3: Превключватели, разединители, превключващи разединители и комбинирани устройства със стопяеми предпазители |
| Държавни норми и/или техническа документация: | Техническа документация и комплект от чертежи 63-811216-*; 63-811217-*; 63-811463-* |
| Документи идентифициращи стоката: | Каталожна карта "Ножови включватели серия ARS, PBS" №1/2003/1. |
| Град, дата: | Торун, 30.04.2004г. |
| Име, фамилия, длъжност, подпис: | Генерален Директор Януш Пнеджвидзки Подпис: не се чете |

В случай на въвеждане на изменения на продукта, несъгласувани с производителя или ако използването не е съгласно предназначението, тази декларация става невалидна.

Подписаната Анелия Иванова Митева удостоверявам верността на извършения от мен превод от полски език на български език на приложения документ - "Декларация СЕ за съответствие". Преводът се състои от 1 (една) страница.

На основание чл.36а ал.3 от ЗОП



ВЕРНО
ОРИГИНАЛ

APATORSA®

DEKLARACJA CE ZGODNOŚCI EC Declaration of conformity



| | |
|--|---|
| Nr No | 0023/04 |
| Producent Manufacturer | APATOR SA |
| Adres Address | ul. Żółkiewskiego 13/29; 87-100 Toruń PL |
| Oznaczenie produktu (nazwa, typ) Product designation (name, type) | Rozłączniki izolacyjne bezpiecznikowe listwowe typu ARS 2- |

Deklarujemy, że oznaczony wyrób jest zgodny z następującymi wymaganiami:
It is declared that the designed product is in conformity with the provisions of the following requirements:

Dyrektyw europejskich:
European Directives:

73/23/EEC + 93/68/EEC

Dyrektywa niskonapięciowa dotycząca harmonizacji przepisów prawnych państw członkowskich odnoszących się do sprzętu elektrycznego przeznaczonego do użytkowania w określonych zakresach napięć.

Norm zharmonizowanych
i/lub norm IEC:
Harmonised standards
and/or IEC standards:

PN-EN 60947-1

Aparatura rozdzielcza i sterownicza niskonapięciowa
Część 1: Postanowienia ogólne
PN-EN 60947-3

Aparatura rozdzielcza i sterownicza niskonapięciowa
Część 3: Rozłączniki, odłączniki, rozłączniki izolacyjne
i zestawy łączników z bezpiecznikami topikowymi

Norm krajowych
i/lub dokumentacji technicznych:
National standards
and/or technical specification:

Dokumentacja techniczna rysunki zestawcze:
63-811216-^{*}; 63-811217-^{*}; 63-811463-^{*}

Dokumenty identyfikujące wyrób:
Product identification documents:

Karta katalogowa „Łączniki listwowe serii ARS, PBS”
Nr 1/2003/1 .

Miejscowość, data
Place, date


Toruń, 2004.04.30

Imię nazwisko stanowisko podpis
Name, surname, function, signature

На основании чл.36а ал.3 от ЗОП

W przypadku wprowadzenia niezgodnych z producentem zmian w wyrobie lub zastosowania go niezgodnie z przeznaczeniem niniejsza deklaracja traci ważność.

If any changes of the product are not agreed with the manufacturer or the product is inappropriately used, this declaration becomes null and void.



ВЕРНО С
ОРИГИНАЛА

Приложение **ТС-1.6**
към **Технически спецификации**
по процедура **PPD 19-130**

ДЕКЛАРАЦИЯ

за съответствие на предлаганото изпълнение

Долуподписаният, **ЕХИЯЗАР ГАРАБЕД УЗУНЯН**, с л.к. № На основание чл.36а ал.3 от ЗОП
На основание чл.36а ал.3 от ЗОП качеството ми на управител на **"ИНТЕРКОМПЛЕКС"** ООД, кандидат за участие в обществена поръчка чрез събиране на оферти с обява с предмет: „Доставка на линейни защитно-комутационни апарати ниско напрежение (НН) за вертикален закрит монтаж“, реф. № PPD 17-162, с възложител „ЧЕЗ Разпределение България“ АД

ДЕКЛАРИРАМ:

1. Доставяните от фирма „Интеркомплекс“ ООД линейни защитно-комутационни апарати ниско напрежение (НН) за вертикален монтаж (ВНР), типове ARS 2-6-V/400A, производство на "АПАТОР" – Полша, отговарят напълно на изискванията на техническата спецификация на този стандарт за материал, вкл. на параграфи „Характеристика на материала“ и „Съответствие на предложеното изпълнение със нормативно-техническите документи“.
2. Правя настоящата декларация на основание СЕ декларация на производителя.

Известно ми е, че при деклариране на неверни данни, нося наказателна отговорност по чл. 313 от НК.

15.01.2020 г.

Участник: ИНТЕРКОМПЛЕКС ООД

На основание чл.36а ал.3 от ЗОП

тел



64

ИНСТРУКЦИЯ

ЗА ТРАНСПОРТИРАНЕ, СЪХРАНЕНИЕ, МОНТАЖ И ЕКСПЛОАТАЦИЯ НА ЛИНЕЙНИ ЗАЩИТНО-КОМУТАЦИОННИ АПАРАТИ НИСКО НАПРЕЖЕНИЕ (НН) ЗА ВЕРТИКАЛЕН МОНТАЖ (ВНР)

Транспорт и съхранение

Линейните защитно-комутационни апарати ниско напрежение (НН) за вертикален монтаж (ВНР) се доставят в индивидуална единична опаковка от картон.

Съхраняват се в сухи, проветриви помещения, годни за съхраняване на електротехническо оборудване.

Монтаж и експлоатация

Линейните защитно-комутационни апарати ниско напрежение (НН) за вертикален монтаж се монтират в касетата посредством специални контактни скоби (куки), без пробиване на токопроводещите шини.

За присъединяване на захранващите кабели, ВНР са съоръжени с V-съединителна арматура. **ДА СЕ СПАЗВА ОБОЗНАЧЕНИЕТ ВЪРТЯЩ МОМЕНТ НА ЗАТЯГАНЕ НА КЛЕМАТА!**

Отварянето и затварянето на ВНР да се извършва с резки движения, без да се удря затварящия лост.

Работата с предпазители трябва да се извършва единствено и само от квалифициран и упълномощен за това персонал. Снемането и поставянето на предпазители от гнездата на разединителите да се извършва **САМО** в положение "отворено/заклучено", чрез движение на лоста надолу по неговата дължина. Отключва се в обратна посока.

При необходимост от подмяна на ВНР се действа в следния ред:

- сваля се предпазния капак на клемния блок
- развива се затягащия болт на V-клемите и се отстраняват кабелите,
- отваря се ВНР,
- изважда се изцяло капакът с предпазители,
- свалят се капачките на ревизионните отвори,
- разхлабват се болтовете (3 бр.) на контактните скоби,
- с движение нагоре и напред се отстранява корпусът на ВНР.

Монтажът на новия разединител се извършва в обратен ред. При провеждане на такива дейности, разединителите и предпазители да се поставят върху чисти и сухи повърхности, по възможност, във фабричната им опаковка.

[Handwritten signatures and marks]
65

Подмяната на изгорял предпазител се извършва, като се отвори блокът с носачите на ВП, изважда се изгорелият и се поставя нов. Разединителят се затваря с рязко движение, но без удар. При това, за да се осигури безопасна работа, блокът с предпазителите се "заклучва" в извадено положение чрез движение на лоста надолу по неговата дължина. Отключва се в обратна посока.

Задължително се взимат мерки за безопасност съгласно утвърдените наредби и правилници и осигуряване на изискваните лични предпазни средства при работа по електрически мрежи.



Да не се правят опити за ремонт или модификация на ВПР!

Поддръжка

ВПР не изискват специална поддръжка. Веднъж на 6 месеца да се прави инспекция на контактната система и при необходимост да се нанася контактна смазка.

15.01.2020 г.

Участник: ИНТЕРКОМПЛЕКС ООД



На основание чл.36а ал.3 от
ЗОП



66

Приложение ТС 2.2
към Технически спецификации
по процедура PPD 19-130

ТЕХНИЧЕСКО ОПИСАНИЕ НА ЛИНЕЙНИ ЗАЩИТНО-КОМУТАЦИОННИ
АПАРАТИ НИСКО НАПРЕЖЕНИЕ (НН) ЗА ВЕРТИКАЛЕН МОНТАЖ

Линейните защитно-комутационни апарати ниско напрежение (НН) за вертикален монтаж (ВНР) е предназначен за включване, изключване, разединяване и защита на кабелни линии НН. ВНР е с конструкция, позволяваща едновременното прекъсване на веригата на трифазното захранване, чрез общо управление на полюсите.

Предлаганите ВНР са с обявен работен ток **630 А**, за директен монтаж върху събирателни токови шини с междуосово разстояние **185 mm**. Закрепването към шините се извършва чрез специални скоби (куки), които осигуряват неподобимия контакт, без да е нужно да се пробиват отвори в шините.

В разединителите се монтират високомощни предпазители със стопяема вложка НН (ВПНН), система А (НН система), с характеристика **gG**, **размер 3**, съответстващи на БДС EN 60269-1:2007 и БДС HD 60269-2:2007.

Конструкцията на предлаганите ВНР осигурява възможност същите да бъдат "заклучвани" както в положение "отворен", така и в положение "затворен", за да се избегне произволно включване/изключване. Това се обезпечават само с едно движение на командния лост нагоре/надолу.

За удобство на обслужващите специалисти е осигурена възможност за тестване състоянието на предпазителите, без да е необходимо отваряне на ВНР, както и видимост за състоянието на челния индикатор на ВПНН.

Триполюсният вертикален предпазител-разединител за **630 А**, с общо управление на полюсите е изпитан и отговаря на съответните за този тип изделия български и международни стандарти както следва:

- БДС EN 60947-1:2007+A1:2011+A2:20014 „Комутационни апарати за ниско напрежение. Част 1: Общи правила“ (IEC 60947-1:2007); и
- БДС EN 60947-3:2009+A1:2012+A2:2015 „Комутационни апарати за ниско напрежение. Част 3: „Товарови прекъсвачи, разединители, товарови прекъсвач-разединители и апарати, комбинирани с предпазители.“ (IEC 60947-3:2008), (IEC 60947-3:2008/A1:2012), (IEC 60947-3:2008/A2:2015)

Чертежи с размери има в приложения каталог

15.01.2020 г.

Участник: ИНТЕРКОМПЛЕКС ООД

На основание чл.36а ал.3 от
ЗОП

.....
тел



Применение ТС 2.3



Test Report issued under the responsibility of:






| | |
|--|--|
| TEST REPORT IEC/EN 60947-3 Low-voltage switchgear and controlgear Part 3: Switches, disconnectors, switch-disconnectors and fuse combination units | |
| Report Reference No. | LA-08.122/E |
| Date of issue | 2008-07-31 |
| Total number of pages | 48 |
| CB/CCA Testing Laboratory | BBJ-SEP TESTING LABORATORY |
| Address | 04-703 Warszawa, ul. Pożaryskiego 28, POLAND |
| Applicant's name | APATOR S.A. |
| Address | 87-100 Toruń, ul. Żółkiewskiego 21/29 POLAND |
| Test specification: | |
| Standard..... | <input checked="" type="checkbox"/> IEC 60947-3:1999 (Second Edition) + A1:2001 + A2:2005 in conjunction with IEC 60947-1:2004 (Fourth Edition) <input checked="" type="checkbox"/> EN 60947-3:1999 + A1:2001 + A2:2005 in conjunction with EN 60947-1:2004 |
| Test procedure..... | CCA |
| Non-standard test method..... | N/A |
| Test Report Form No. | IECEN60947_3B |
| Test Report Form(s) Originator..... | OVE |
| Master TRF | Dated 2006-08 |
| Copyright © 2006 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved. | |
| This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. | |
| If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. | |
| This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02. | |
| If this Test Report Form is used by non-CCA members, the CIG logo and the reference to the CCA Procedure shall be removed. | |
| This report is not valid as a CCA Test Report unless signed by an approved CCA Testing Laboratory and appended to a CCA Test Certificate issued by an NCB in accordance with CCA | |
| Test item description | Fuse-switch disconnectors |
| Trade Mark | |
| Manufacturer | APATOR S.A. 87-100 Toruń ul. Żółkiewskiego 21/29 POLAND |
| Model/Type reference | ARS 3 |
| Ratings | see page 4 |

СТОВАРІВАННЯ ЕЛЕКТРИЧІВ ПОЛСКИХ
ЦЕНТРА БИДАННІВ ДІС ЯКОСТІ ОДЛІН
ЗАКЛАД АПАРАТІВ НИСЬКІГО НАПІВІА
20-150 ЛіЛІа, ул. Рапсцького 18/15



ВЕРНО С
ОРИГИНАЛ

68

| | |
|--|---|
| Testing procedure and testing location: | |
| <input checked="" type="checkbox"/> CB/CCA Testing Laboratory: |  BBJ-SEP TESTING LABORATORY |
| Testing location/ address.....: 20-150 Lublin, ul. Rapackiego 13/15, POLAND | |
| <input type="checkbox"/> Associated CB Laboratory: | |
| Testing location/ address.....: N/A | |
| Tested by (name + signature).....: Dariusz Szczepanowski  | |
| Approved by (+ signature): Leszek Krzyżanowski  | |
| <input type="checkbox"/> Testing procedure: TMP | |
| Tested by (name + signature).....: N/A | |
| Approved by (+ signature): N/A | |
| Testing location/ address.....: N/A | |
| <input type="checkbox"/> Testing procedure: WMT | |
| Tested by (name + signature).....: N/A | |
| Witnessed by (+ signature).....: N/A | |
| Approved by (+ signature): N/A | |
| Testing location/ address.....: N/A | |
| <input type="checkbox"/> Testing procedure: SMT | |
| Tested by (name + signature).....: N/A | |
| Approved by (+ signature): N/A | |
| Supervised by (+ signature).....: N/A | |
| Testing location/ address.....: N/A | |
| <input type="checkbox"/> Testing procedure: RMT | |
| Tested by (name + signature).....: N/A | |
| Approved by (+ signature): N/A | |
| Supervised by (+ signature).....: N/A | |
| Testing location/ address.....: N/A | |

| Summary of testing: | | | | |
|---------------------|---------|---|----------------------|-----------------|
| Test sequence | Clause | Requirements - Test | Sample No. | Verdict |
| 0 | 5 | Product information | A3/10 | P |
| | 7 | Constructional and performance requirements | A3/10, A3/11, A3/15 | P |
| I | 8.3.3.1 | Temperature rise | | P |
| | 8.3.3.2 | Dielectric properties | | P |
| | 8.3.3.3 | Making and breaking capacity | A3/1 (AC-22B, 690 V) | P |
| | 8.3.3.4 | Dielectric verification | A3/6 (AC-21B, 690 V) | P |
| | 8.3.3.5 | Leakage current | A3/4 (AC-22B, 400 V) | P |
| | 8.3.3.6 | Temperature-rise verification | A3/5 (AC-21B, 400 V) | P |
| | 8.3.3.7 | Strength of actuator mechanism | — | N/A |
| II | 8.3.4.1 | Operational performance | A3/3 (AC-22B, 690 V) | P |
| | 8.3.4.2 | Dielectric verification | A3/7 (AC-21B, 690 V) | P |
| | 8.3.4.3 | Leakage current | A3/8 (AC-22B, 400 V) | P |
| | 8.3.4.4 | Temperature-rise verification | A3/9 (AC-21B, 400 V) | P |
| III | 8.3.5 | Short-circuit performance capability | — | N/A |
| IV | 8.3.6.2 | Fuse protected short-circuit withstand | 2W | P ^{*)} |
| | 8.3.6.3 | Dielectric verification | | P |
| | 8.3.6.4 | Leakage current | | P |
| | 8.3.6.5 | Temperature-rise verification | | P |
| V | 8.3.7.1 | Overload test | A3/10 | P |
| | 8.3.7.2 | Dielectric verification | | P |
| | 8.3.7.3 | Leakage current | | P |
| | 8.3.7.4 | Temperature-rise verification | | P |

*) Short-circuit breaking capacity with alternating current test was carried out at Laboratorium Badawcze Aparatury Rozdzielczej of Instytut Elektrotechniki in Warsaw. The particular results of the test are given in test report No. 7670/NBR/08 from 2008-06-12, see Annex to this report.

Summary of compliance with National Differences: —

TRF No. IECEN60947_3B










STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O'LBEM
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Piapackiego 13/15



ВАЖНОЕ
 ОРИГИНАЛ

69

Copy of marking plate:

| | | | |
|--|--|---|---|
|  APATOR Typ ARS 3-6-M  Nr <input type="text"/>  |  APATOR Typ ARS 3-1-V  Nr <input type="text"/>  | | |
| $U_n=690V \sim$ AC-21B/690V AC-22B/690V | $I_n=I_e=630A$ 3 $P_n=60W$ 40-60Hz IP 30 PN-EN 60947-3 | $U_n=690V \sim$ AC-21B/690V AC-22B/690V | $I_n=I_e=630A$ 3 $P_n=60W$ 40-60Hz IP 30 PN-EN 60947-3 |
|  APATOR Typ ARS 3-1-2V  Nr <input type="text"/>  | | | |
| $U_n=690V \sim$ AC-21B/690V AC-22B/690V | $I_n=I_e=630A$ 3 $P_n=60W$ 40-60Hz IP 30 PN-EN 60947-3 | | |

Marking of samples for tests:

| Type of fuse-switch disconnecter | Number of samples | Date of receipt |
|----------------------------------|---|-----------------|
| ARS 3-6-M | A3/1, A3/2, A3/3, A3/4, A3/5, A3/6, A3/7, A3/8, A3/9, A3/10, | 2008-05-16 |
| | 2W (sample tested at IEL in Warsaw) | — |
| ARS 3-1-V | A3/11, A3/12, A3/13, A3/14, | 2008-05-16 |
| ARS 3-1-2V | A3/15, A3/16, A3/17, A3/18 | |

TRF No. IECEN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE DŁG JAKOŚCI OLLbim
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Rappackiego 13/15

| | |
|--|---------------------------|
| Test item particulars | |
| - method of operation..... | Manual |
| - switching positions..... | O I |
| - number of poles..... | 3 |
| - kind of current..... | AC |
| - number of phases..... | 3 |
| - rated frequency (Hz)..... | 40...60 Hz |
| - number of positions of the main contacts..... | 2 |
| Rated and limiting values, main circuit..... | |
| - rated operational voltage U_e (V)..... | 400 V, 690 V - AC |
| - rated insulation voltage U_i (V)..... | 1000 V |
| - rated impulse withstand voltage U_{imp} (kV)..... | 12 kV |
| - conventional free air thermal current I_{th} (A)..... | 630 A |
| - conventional enclosed thermal current I_{the} (A)..... | — |
| - rated operational current I_e (A)..... | 630 A |
| - rated uninterrupted current I_u (A)..... | 630 A |
| - utilization category..... | AC-22B, AC-21B |
| Short-circuit characteristic..... | |
| - rated short-time withstand current I_{cw} (kA)..... | — |
| - rated short-time making capacity I_{cm} (kA)..... | — |
| - rated conditional short-circuit current..... | 100 kA (fuse link 630 A) |
| Rated and limiting values, auxiliary circuits..... | |
| - rated operational voltage (V)..... | — |
| - rated frequency (Hz)..... | — |
| - number of circuits..... | — |
| - number and kind of contact elements..... | — |
| Co-ordination of short-circuit protective devices..... | |
| - kind of protective device..... | fuse link 630 A gG |
| Possible test case verdicts: | |
| - test case does not apply to the test object..... | N/A |
| - test object does meet the requirement..... | P (Pass) |
| - test object does not meet the requirement..... | F (Fail) |
| Testing | |
| Date of receipt of test item..... | 2008-05-16 |
| Date (s) of performance of tests..... | 2008-05-16 ... 2008-07-31 |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI OŁUBIN
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 OŁUBIN, ul. Flakowska 30 13:15



ВЕРНО С
 ОРИГИНАЛ

20



General remarks:

The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.
"(See Enclosure #)" refers to additional information appended to the report.
"(See appended table)" refers to a table appended to the report.

Note: EN Group Differences together with National Differences and Special National Conditions, if any, are in the Appendix to the main body of this TRF.


Throughout this report a comma (point) is used as the decimal separator.

General product information: —

| IEC / EN 60947-3 | | | |
|------------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 5.2 | MARKING | | P |
| | Marking on equipment itself or on nameplate or nameplates attached to the equipment and legible from the front after mounting | | P |
| | - indication of the open and closed position | Visible isolating distance between open contacts | P |
| | - suitability for isolation |  | P |
| | - disconnectors AC-20 and DC-20 only; marked "Do not operate under load" | | N/A |
| | Marking on equipment not needed to be visible after mounting: | | P |
| | - manufacturer's name or trademark |  | P |
| | - type designation or serial number | ARS 3 | P |
| | - rated operational current | See copies of marking plates | P |
| | - rated operational voltage | 690 V - AC | P |
| | - utilization category | AC-22B, AC-21B | P |
| | - rated frequency | 40 - 60 Hz | P |
| | - manufacturer's claim for compliance with IEC/EN 60947-3 | EN 60947-3 | P |
| | - degree of protection | | N/A |
| | Marking on fuse-combination units: | | P |
| | - fuse type | 3 gG | P |
| | - maximum rated current | 630 A | P |
| | - power loss of the fuse-link | 60 W | P |
| | Identification of terminals: | | P |
| | - line terminals | | P |
| | - load terminals | L1, L2, L3 | P |
| | - neutral pole terminal | | N/A |
| | - protective earth terminal | | N/A |
| | Data in the manufacturer's published information: | | P |
| | - rated insulation voltage | 1000 V | P |
| | - rated impulse withstand voltage for equipment suitable for isolation or when determined | 12 kV | P |
| | - pollution degree, if different from 3 | 3 | P |
| | - rated duty | Uninterrupted duty | P |
| | - rated short-time withstand current and duration | | N/A |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Papazkiego 13/15



ОРГАНІЗАЦІЯ

51

| IEC / EN 60947-3 | | | |
|------------------|--|----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - rated short-circuit making capacity | | N/A |
| | - rated conditional short-circuit current | 100 kA (500V AC) | P |
| 7.1 | CONSTRUCTION | | P |
| 7.1.1 | Materials | | P |
| 7.1.1.1 | Resistance to abnormal heat and fire | | P |
| | Glow-wire test according to IEC 60695-2-10 and IEC 60695-2-11 | | |
| | Parts made of insulating material necessary to retain current-carrying parts in position: test temperature 960 °C | | P |
| | No visible flame and no sustained glowing | see appended table 7.1.1.1 | P |
| | Flames and glowing extinguish within 30 s | see appended table 7.1.1.1 | P |
| | No ignition of the tissue paper | see appended table 7.1.1.1 | P |
| | Parts of insulating material not necessary to retain current-carrying parts in position, even though in contact with them: test temperature 650 °C | | P |
| | No visible flame and no sustained glowing | see appended table 7.1.1.1 | P |
| | Flames and glowing extinguish within 30 s | see appended table 7.1.1.1 | P |
| | No ignition of the tissue paper | see appended table 7.1.1.1 | P |
| 7.1.2 | Current-carrying parts and their connection | | P |
| 7.1.3 | Clearances..... : | see appended table 7.1.3 | P |
| | Creepage distances | see appended table 7.1.3 | P |
| | Pollution degree | 3 | |
| | Comparative tracking index (V) | 500 V | |
| | Material group | II | |
| 7.1.4 | Actuator | | P |
| 7.1.4.1 | Insulation | | |
| | Actuator insulated from live parts for | | |
| | - rated insulation voltage | 1000 V | P |
| | - rated impulse withstand voltage | 12 kV | P |
| | Actuator made of metal | | |
| | - connected to a protective conductor or provided with an additional insulation | | N/A |
| | Actuator made of or covered by insulating material : | — | |
| | - internal metal parts, which might become accessible in the event of an insulation failure, are also insulated from live parts for the rated insulation voltage | | N/A |

| IEC / EN 60947-3 | | | |
|------------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.1.4.2 | Direction of movement | | P |
| | The direction of operation for actuators shall where applicable conform to IEC 60447 | | P |
| | There is no doubt of the "I" and "O" position and the direction of operation | | P |
| 7.1.5 of Part 1 | Indication of contact position | | P |
| 7.1.5.1 | Indicating means | Visible isolating distance between open contacts in the open position | P |
| 7.1.5.2 | Indication by the actuator | | P |
| 7.1.6 | Additional safety requirements for equipment suitable for isolation | | P |
| 7.1.6.1 | Additional constructional requirements for equipment suitable for isolation (U _e > 50 V): | | P |
| | - marking according to 5.2.1b | | P |
| | - indication of the position of the contacts | | P |
| | - construction of the actuating mechanism | | P |
| | - minimum clearances across open contacts (see Table XIII, Part 1) (mm) | 14 mm | — |
| | - measured clearances (mm) | 33 mm | P |
| | - test U _{imp} across gap (kV) | 18,1 kV | P |
| 7.1.6.2 | Supplementary requirements for equipment with provision for electrical interlocking with contactors or circuit-breakers: | | N/A |
| | Auxiliary switch is rated according to IEC 60947-5-1 (unless the equipment is rated AC-23) | | N/A |
| | Time interval between opening of the contacts of the auxiliary contact and the contacts of the main poles: ≥20 ms | — | — |
| | Measured time interval (ms) | — | N/A |
| | During the closing operation the contacts of the auxiliary switch closes after or simultaneously with the contacts of the main poles | | N/A |
| 7.1.6.3 | Supplementary requirements for equipment provided with means for padlocking the open position: | | N/A |
| | The locking means is so designed that it cannot be removed with the appropriate padlock(s) installed | | N/A |
| | Test force F applied to the actuator in an attempt to operate to the closed position (N) | — | — |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWOZE D/S JAKOŚCI O LUBA
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Piapackiego 13.15

72

| IEC / EN 60947-3 | | | |
|------------------|---|-------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Rated impulse withstand voltage (kV) | — | — |
| | Test Uimp on open main contacts at the test force | | N/A |
| 7.1.7 of Part 1 | Terminals | | P |
| 7.1.7.1 | All parts of terminals which maintain contact and carry current are of metal having adequate mechanical strength | (see 8.2.4 below) | P |
| | Terminal connections are such that necessary contact pressure is maintained | (see 8.2.4 below) | P |
| | Terminals are so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal | (see 8.2.4 below) | P |
| | Terminals do not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage is not reduced below the rated value | (see 8.2.4 below) | P |
| 8.2.4 | Mechanical properties of terminals | Terminals of type V | P |
| | Mechanical strength of terminals | Sample No A3/11 | P |
| | Maximum cross-sectional area of conductor (mm ²) | 300 mm ² (rigid) | — |
| | Diameter of thread (mm) | 13,8 mm | — |
| | Torque (Nm) | 1,1 x 40 Nm = 44 Nm | — |
| | 5 times on 2 separate clamping units | | P |
| | Testing for damage to and accidental loosening of conductor (flexion test) | | P |
| | Conductor of the smallest cross-sectional area (mm ²) | 70 mm ² (flexible) | — |
| | Number of conductor of the smallest cross section: | 1 | — |
| | Diameter of bushing hole (mm) | 19,1 mm | — |
| | Height between the equipment and the platen | 368 mm | — |
| | Mass at the conductor(s) (kg) | 10,4 kg | — |
| | 135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Pull-out test | | P |
| | Force (N), applied for 1 min. | 285 N | — |
| | During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |

| IEC / EN 60947-3 | | | |
|------------------|---|-----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Conductor of the largest cross-sectional area (mm ²) | 300 mm ² (rigid) | — |
| | Number of conductor of the largest cross section : | 1 | — |
| | Diameter of bushing hole (mm) | 28,6 mm | — |
| | Height between the equipment and the platen : | 464 mm | — |
| | Mass at the conductor(s) (kg) | 22,7 kg | — |
| | 135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Pull-out test | | P |
| | Force (N), applied for 1 min. : | 578 N | — |
| | During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Conductor of the largest and smallest cross-sectional area (mm ²) | | — |
| | Number of conductor of the smallest cross section, number of conductor of the largest cross section : | | — |
| | Diameter of bushing hole (mm) | | — |
| | Height between the equipment and the platen : | | — |
| | Mass at the conductor(s) (kg) | | — |
| | 135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit | | N/A |
| | Pull-out test | | N/A |
| | Force (N), applied for 1 min. : | | — |
| | During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit | | N/A |
| 7.1.7.2 | Connection capacity | | P. |
| | Type of conductors | Rigid/flexible | — |
| | Minimum cross-sectional area of conductor (mm ²) : | 70 mm ² | — |
| | Maximum cross-sectional area of conductor (mm ²) | 300 mm ² | — |
| | Number of conductors simultaneously connectable to the terminal | 1 | — |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE DLA JAKOŚCI O'LEBIA
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Piapackiego 13/15



СТОВОРИЩЕ
 ОПИТУВАНА


73

| IEC / EN 60947-3 | | | |
|------------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.2.4 | Mechanical properties of terminals | Terminals of type 2V | P |
| | Mechanical strength of terminals | Sample No. A3/15 | P |
| | Maximum cross-sectional area of conductor (mm ²) | 2x240 mm ² (rigid) | — |
| | Diameter of thread (mm) | 11,8 mm | — |
| | Torque (Nm) | 1,1 x 40 Nm = 44 Nm | — |
| | 5 times on 2 separate clamping units | | P |
| | Testing for damage to and accidental loosening of conductor (flexion test) | | P |
| | Conductor of the smallest cross-sectional area (mm ²) | 50 mm ² (flexible) | — |
| | Number of conductor of the smallest cross section: | 2 | — |
| | Diameter of bushing hole (mm) | 15,9 mm | — |
| | Height between the equipment and the platen | 343 mm | — |
| | Mass at the conductor(s) (kg) | 9,5 kg | — |
| | 135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Pull-out test | | P |
| | Force (N), applied for 1 min. | 236 N | — |
| | During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Conductor of the largest cross-sectional area (mm ²) | 240 mm ² (rigid) | — |
| | Number of conductor of the largest cross section : | 2 | — |
| | Diameter of bushing hole (mm) | 28,6 mm | — |
| | Height between the equipment and the platen | 464 mm | — |
| | Mass at the conductor(s) (kg) | 20 kg | — |
| | 135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Pull-out test | | P |
| | Force (N), applied for 1 min. | 578 N | — |
| | During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Conductor of the largest and smallest cross-sectional area (mm ²) | 240 mm ² + 50 mm ² | — |

| IEC / EN 60947-3 | | | |
|------------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Number of conductor of the smallest cross section, number of conductor of the largest cross section : | 1 1 | — |
| | Diameter of bushing hole (mm) | 28,6 mm | — |
| | Height between the equipment and the platen | 464 mm | — |
| | Mass at the conductor(s) (kg) | 20 kg | — |
| | 135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Pull-out test | | P |
| | Force (N), applied for 1 min. | 578 N | — |
| | During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Conductor of the largest and smallest cross- sectional area (mm ²) | 50 mm ² + 240 mm ² | — |
| | Number of conductor of the smallest cross section, number of conductor of the largest cross section : | 1 1 | — |
| | Diameter of bushing hole (mm) | 15,9 mm | — |
| | Height between the equipment and the platen | 343 mm | — |
| | Mass at the conductor(s) (kg) | 9,5 kg | — |
| | 135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| | Pull-out test | | P |
| | Force (N), applied for 1 min. | 236 N | — |
| | During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit | | P |
| 7.1.7.2 | Connection capacity | | P |
| | Type of conductors | Rigid/flexible | — |
| | Minimum cross-sectional area of conductor (mm ²) : | 50 mm ² | — |
| | Maximum cross-sectional area of conductor (mm ²) | 240 mm ² | — |
| | Number of conductors simultaneously connectable to the terminal | 2 | — |
| 7.1.7.3 | Connection | | P |
| | Terminals for connection to external conductors are readily accessible during installation | | P |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE DLA JAKOŚCI O Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Rapackiego 13/15



СТОВОРІЗС
 ОРІТІНАЛА

24

| IEC / EN 60947-3 | | | |
|------------------|--|--------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Clamping screws and nuts do not serve to fix any other component | | P |
| 7.1.7.4 | Terminal identification and marking | | P |
| | Terminal intended exclusively for the neutral conductor | | N/A |
| | Protective earth terminal | | N/A |
| | Other terminals | L1, L2, L3 | P |
| 7.1.8 | Additional requirements for equipment provided with a neutral pole | | N/A |
| | Equipment provided with a pole intended for the connection of neutral, this pole shall be clearly marked by the letter "N" | | N/A |
| | The switched neutral pole does not break before and does not make after the other poles except | | N/A |
| | - a pole having the appropriate short-circuit breaking and making capacity is used as neutral pole, all poles may operate together | | N/A |
| | Conventional thermal current of neutral pole | | N/A |
| 7.1.9 | Provisions for protective earthing | | N/A |
| 7.1.9.1 | The exposed conductive parts are electrically interconnected and connected to a protective earth terminal | | N/A |
| 7.1.9.2 | Protective earth terminal is readily accessible | | N/A |
| | Protective earth terminal is suitably protected against corrosion | | N/A |
| | Electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors | | N/A |
| | Protective earth terminal has no other functions | | N/A |
| 7.1.9.3 | Protective earth terminal marking and identification | | N/A |
| 7.1.10 | Enclosure for equipment | | P |
| 7.1.10.1 | Design | | P |
| | When the enclosure is opened, all parts requiring access for installation and maintenance are readily accessible | Integral enclosure | P |
| | Sufficient space is provided inside the enclosure | | P |

| IEC / EN 60947-3 | | | |
|------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | The fixed parts of a metal enclosure are electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor | | N/A |
| | Under no circumstances a removable metal part of the enclosure is insulated from the part carrying the earth terminal when the removable part is in place | | N/A |
| | The removable parts of the enclosure are firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations | | N/A |
| | When an enclosure is so designed as to allow the covers to be opened without the use of tools, means is provided to prevent loss of the fastening devices | | N/A |
| | If the enclosure is used for mounting push-buttons, it is not possible to remove the buttons from the outside of the enclosure | | N/A |
| 7.1.10.2 | Insulation | | N/A |
| | If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining is securely fixed to the enclosure | | N/A |
| 7.1.11 | Degree of protection of enclosed equipment | | N/A |
| | Degree of protection | — | N/A |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lubin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lubin, ul. Narpackiego 13/15



Handwritten initials or signature.

| IEC / EN 60947-3 | | | |
|------------------|---|-------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3 | TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS | | P |
| 8.3.3.1 | Temperature-rise | Samples Nos. A3/10, A3/11 and A3/15 | P |
| | ambient temperature 10-40 °C | See appended tables 8.3.3.1 | — |
| | test enclosure W x H x D (mm x mm x mm) | — | — |
| | material of enclosure | — | — |
| | Main circuits, test conditions: | | — |
| | - conventional thermal current I _{th} (A) | 630 A | — |
| | - conventional enclosed thermal current I _{the} (A) . : | — | — |
| | - cable/busbar cross-section (mm ²) / length (mm) : | 2x185 mm ² | — |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | APATOR | — |
| | - manufacturer's model or type reference | WTNH gG | — |
| | - rated current (A) | 630 A | — |
| | - power loss (W) | 43 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | Measured temperature-rise | See appended tables 8.3.3.1 | P |
| | Auxiliary circuits, test conditions: | | N/A |
| | - rated operation current (A) | — | — |
| | - cable cross-section (mm ²) | — | — |
| | Measured temperature-rise | — | N/A |
| 8.3.3.2 | Test of dielectric properties | Samples Nos. A3/10, A3/11 and A3/15 | P |
| | Rated impulse withstand voltage (kV) | 12 kV | — |
| | - test U _{imp} main circuits (kV) | 14,5 kV | P |
| | - test U _{imp} auxiliary circuits (kV) | — | N/A |
| | - test U _{imp} on open main contacts (equipment suitable for isolation) (kV) | 18,1 kV | P |
| | Power-frequency withstand voltage (V) | 2200 V | — |
| | - main circuits, test voltage for 5 sec. (V) | 5 s | P |
| | - control and auxiliary circuits, test voltage for 5 sec. (V) | — | N/A |
| | Devices, which have been disconnected for the power-frequency withstand voltage test | — | N/A |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE DLA JAKOŚCI O LUBIN
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lubin, ul. Rapackiego 13/15

| IEC / EN 60947-3 | | | |
|------------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Equipment suitable for isolation, leakage current not exceed 0,5 mA | | — |
| | Test voltage 1,1 Ue (V) | 759 V | — |
| | Measured leakage current (mA) | 0,010 mA | P |
| 8.3.3.3 | Making and breaking capacity | Sample No.: A3/1 | P |
| | - utilization category | AC-22B | — |
| | - rated operational voltage Ue (V) | 690 V | — |
| | - rated operational current Ie (A) or power (kW) .. | 630 A | — |
| | Conditions for make/break operations or make operation, AC-22B: | | P |
| | - test voltage, U = 1,05 Ue.....(V): | L1: 725 V L2: 726 V L3: 725 V | — |
| | - test current, I = 3x Ie (A): | L1: 1916 A L2: 1929 A L3: 1926 A | — |
| | - power factor.....: | L1: 0,69 L2: 0,68 L3: 0,68 | — |
| | Conditions for break operation, AC-22B | | P |
| | - test voltage, U = 1,05 Ue.....(V): | L1: 725 V L2: 726 V L3: 725 V | — |
| | - test current, I = 3x Ie (A): | L1: 1916 A L2: 1929 A L3: 1926 A | — |
| | - power factor | L1: 0,69 L2: 0,68 L3: 0,68 | — |
| | Number of make/break or make and break operations | 5 make 5 break | P |
| | - recovery voltage duration (≥ 50 ms) | 725 V | P |
| | - current duration (ms) | 425 ms | — |
| | - time interval between operations | 35 s | P |
| | Characteristic of transient recovery voltage for AC-22 and AC-23 only | | P |
| | - oscillatory frequency (kHz) | 48,44 kHz | — |
| | - measured oscillatory frequency (kHz) | L1: 47,90 kHz L2: 48,90 kHz L3: 48,30 kHz | P |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH

BIURO BADAWCZE DLA JAKOŚCI O Lublin
ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA

20-150 Lublin, ul. Filipkowska 13/15


26

| IEC / EN 60947-3 | | | |
|------------------|--|----------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - factor γ | L1: 1,09 L2: 1,11 L3: 1,10 | P |
| 8.3.3.3.5 | Behaviour of the equipment during making and breaking capacity tests | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.3.3.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 150 N (before the test 130 N) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.3.4 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.3.5 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole ... | — | N/A |
| | Leakage current (other utilization categories): ≤ 2 mA/pole | 0,091 mA | P |
| 8.3.3.6 | Temperature-rise verification | | P |
| | - conductor cross-section (mm ²) | 2x185 mm ² | — |
| | - test current I_e (A) | 630 A | — |
| | Measured temperature-rise | See appended tables 8.3.3.6 | P |

| IEC / EN 60947-3 | | | |
|------------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3.3 | Making and breaking capacity | Sample No.: A3/4 | P |
| | - utilization category | AC-22B | — |
| | - rated operational voltage U_e (V) | 400 V | — |
| | - rated operational current I_e (A) or power (kW) ... | 630 A | — |
| | Conditions for make/break operations or make operation, AC-22B: | | P |
| | - test voltage, $U = 1,05 U_e$(V): | L1: 420 V L2: 420 V L3: 421 V | — |
| | - test current, $I = 3$x I_e (A): | L1: 1910 A L2: 1900 A L3: 1912 A | — |
| | - power factor..... | L1: 0,65 L2: 0,66 L3: 0,66 | — |
| | Conditions for break operation, AC-22B | | P |
| | - test voltage, $U = 1,05 U_e$(V): | L1: 420 V L2: 420 V L3: 421 V | — |
| | - test current, $I = 3$x I_e (A): | L1: 1910 A L2: 1900 A L3: 1912 A | — |
| | - power factor | L1: 0,65 L2: 0,66 L3: 0,66 | — |
| | Number of make/break or make and break operations | 5 make 5 break | P |
| | - recovery voltage duration (≥ 50 ms) | 420 V | P |
| | - current duration (ms) | 410 ms | — |
| | - time interval between operations | 35 s | P |
| | Characteristic of transient recovery voltage for AC-22 and AC-23 only | | P |
| | - oscillatory frequency (kHz) | 74,93 kHz | — |
| | - measured oscillatory frequency (kHz) | L1: 72,95 Hz L2: 73,80 kHz L3: 73,30 kHz | P |
| | - factor γ | L1: 1,13 L2: 1,08 L3: 1,10 | P |
| 8.3.3.3.5 | Behaviour of the equipment during making and breaking capacity tests | | P |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O'LEŚŃ
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Napulskiego 13-15



ОРИГИНАЛ


27

| IEC / EN 60947-3 | | | |
|------------------|--|-------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.3.3.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 150 N (before the test 110 N) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.3.4 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~..... : | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.3.5 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole ... : | — | N/A |
| | Leakage current (other utilization categories): ≤ 2 mA/pole) | 0,009 mA | P |
| 8.3.3.6 | Temperature-rise verification | | P |
| | - conductor cross-section (mm ²) | 2 x 185 mm ² | — |
| | - test current I_e (A) | 630 A | — |
| | Measured temperature-rise..... | see appended tables 8.3.3.6 | P |

| IEC / EN 60947-3 | | | |
|------------------|---|-------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3.3 | Making and breaking capacity | Sample No.: A3/6 | P |
| | - utilization category | AC-21B | — |
| | - rated operational voltage U_e (V) | 690 V | — |
| | - rated operational current I_e (A) or power (kW) .. | 630 A | — |
| | Conditions for make/break operations or make operation, AC-21B: | | P |
| | - test voltage, $U = 1,05 U_e$(V): | L1: 725 V L2: 725 V L3: 725 V | — |
| | - test current, $I = 1,5$x I_e (A): | L1: 968 A L2: 975 A L3: 956 A | — |
| | - power factor | L1: 0,95 L2: 0,94 L3: 0,94 | — |
| | Conditions for break operation, AC-21B | | P |
| | - test voltage, $U = 1,05 U_e$(V): | L1: 725 V L2: 725 V L3: 725 V | — |
| | - test current, $I = 1,5$x I_e (A): | L1: 968 A L2: 975 A L3: 956 A | — |
| | - power factor | L1: 0,95 L2: 0,94 L3: 0,94 | — |
| | Number of make/break or make and break operations | 5 make 5 break | P |
| | - recovery voltage duration (≥ 50 ms) | 725 V | P |
| | - current duration (ms) | 400 ms | — |
| | - time interval between operations | 35 s | P |
| | Characteristic of transient recovery voltage for AC-22 and AC-23 only | | N/A |
| | - oscillatory frequency (kHz) | — | — |
| | - measured oscillatory frequency (kHz) | L1: L2: L3: | N/A |
| | - factor γ | L1: L2: L3: | N/A |
| 8.3.3.3.5 | Behaviour of the equipment during making and breaking capacity tests | | P |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Rapackiego 13/13




88

| IEC / EN 60947-3 | | | |
|------------------|--|-------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.3.3.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 150 N (before the test 130 N) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.3.4 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ : | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.3.5 | Leakage current | | P |
| | test voltage ($1,1 U_e$) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole ... : | — | N/A |
| | Leakage current (other utilization categories): ≤ 2 mA/pole) | 0,010 mA | P |
| 8.3.3.6 | Temperature-rise verification | | P |
| | - conductor cross-section (mm^2) | $2 \times 185 \text{ mm}^2$ | — |
| | - test current I_e (A) | 630 A | — |
| | Measured temperature-rise..... | see appended tables 8.3.3.6 | P |

| IEC / EN 60947-3 | | | |
|------------------|---|-------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3.3 | Making and breaking capacity | Sample No.: A3/5 | P |
| | - utilization category | AC-21B | — |
| | - rated operational voltage U_e (V) | 400 V | — |
| | - rated operational current I_e (A) or power (kW) .. | 630 A | — |
| | Conditions for make/break operations or make operation, AC-21B: | | P |
| | - test voltage, $U = 1,05 U_e$(V): | L1: 420 V L2: 420 V L3: 421 V | — |
| | - test current, $I = 1,5$x I_e (A): | L1: 950 A L2: 951 A L3: 953 A | — |
| | - power factor | L1: 0,95 L2: 0,95 L3: 0,95 | — |
| | Conditions for break operation, AC-21B | | P |
| | - test voltage, $U = 1,05 U_e$(V): | L1: 420 V L2: 420 V L3: 421 V | — |
| | - test current, $I = 1,5$x I_e (A): | L1: 950 A L2: 951 A L3: 953 A | — |
| | - power factor | L1: 0,95 L2: 0,95 L3: 0,95 | — |
| | Number of make/break or make and break operations | 5 make 5 break | P |
| | - recovery voltage duration (≥ 50 ms) | 420 V | P |
| | - current duration (ms) | 410 ms | — |
| | - time interval between operations | 35 s | P |
| | Characteristic of transient recovery voltage for AC-22 and AC-23 only | | N/A |
| | - oscillatory frequency (kHz) | — | — |
| | - measured oscillatory frequency (kHz) | L1: L2: L3: | N/A |
| | - factor γ | L1: L2: L3: | N/A |
| 8.3.3.3.5 | Behaviour of the equipment during making and breaking capacity tests | | P |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE DLA JAKOŚCI O LUBIA
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Papackiego 13/15



29

| IEC / EN 60947-3 | | | |
|------------------|--|-------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.3.3.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 140 N (before the test 110 N) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.3.4 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ : | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.3.5 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole ... : | — | N/A |
| | Leakage current (other utilization categories): ≤ 2 mA/pole) | 0,010 mA | P |
| 8.3.3.6 | Temperature-rise verification | | P |
| | - conductor cross-section (mm ²) | 2x185 mm ² | — |
| | - test current I_e (A) | 630 A | — |
| | Measured temperature-rise | see appended tables 8.3.3.6 | P |
| 8.3.3.7 | Strength of actuator mechanism | | N/A |
| 8.2.5 | Verification of the strength of actuator mechanism and position indicating device | | N/A |
| | - actuator type (fig.) | 1e | — |
| 8.2.5.2.1 | Dependent and independent manual operation | — | N/A |
| | - actuating force for opening (N) | 90 N | — |
| | - test force with blocked main contacts (N) | — | — |
| | - used method to keep the contact closed | — | — |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
BIURO BADAWCZE D/S JAKOŚCI O LUBLI
ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
20-150 Lublin, ul. Hapackiego 13/15

| IEC / EN 60947-3 | | | |
|------------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | During and after the test, open position not indicated..... : | The main contacts position is visible in the open position – test not applicable | N/A |
| | Equipment with locking mean, no locking in the open position while test force is applied..... : | — | N/A |
| 8.2.5.2.2 | Dependent power operation | — | N/A |
| | - main contacts fixed together in the closed position:..... : | — | N/A |
| | - used method to keep the contact closed..... : | — | N/A |
| | - 110% of the rated supply voltage applied to the equipment (3 times)..... : | — | N/A |
| | During and after the test, open position not indicated..... : | — | N/A |
| | Equipment show no damage impairing its normal operation..... : | — | N/A |
| | Equipment with locking mean, no locking in the open position while test force is applied..... : | — | N/A |
| 8.2.5.2.3 | Independent power operation | — | N/A |
| | - main contacts fixed together in the closed position:..... : | — | N/A |
| | - used method to keep the contact closed..... : | — | N/A |
| | - stored energy of the power operator released (3 times)..... : | — | N/A |
| | During and after the test, open position not indicated..... : | — | N/A |
| | Equipment show no damage impairing its normal operation..... : | — | N/A |
| | Equipment with locking mean, no locking in the open position while test force is applied..... : | — | N/A |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Piapackiego 13/15



OPUSTRZANA

80

| IEC / EN 60947-3 | | | |
|------------------|---|-------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.4 | TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY | | P |
| 8.3.4.1 | Operational performance test | Sample No A3/3 | P |
| | - utilization category | AC-22B | — |
| | - rated operational voltage (V) | 690 V | — |
| | - rated operational current (A) | 630 A | — |
| | Test conditions for electrical operation cycles: | | — |
| | - test voltage (V) | L1: 691 V L2: 692 V L3: 691 V | — |
| | - test current (A) | L1: 644 A L2: 643 A L3: 641 A | — |
| | - power factor/time constant | L1: 0,80 L2: 0,80 L3: 0,80 | — |
| | Number of cycles with current | 200 | P |
| | Number of cycles without current | 800 | P |
| | First test sequence (with/without current) | without current | — |
| | Second test sequence (with/without current) | with current | — |
| | - time interval between first and second test sequence | 8000 s | — |
| 8.3.4.1.5 | Behaviour of the equipment during the operational performance test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.4.1.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 120 N (before the test 110 N) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |


TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O/Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Rapackiego 13/15

| IEC / EN 60947-3 | | | |
|------------------|--|-------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.4.2 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ : | 1380 V | — |
| | No breakdown or flashover | | P |
| 8.3.4.3 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole : | — | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | 0,011 mA | P |
| 8.3.4.4 | Temperature-rise verification | | P |
| | - conductor cross-section (mm ²) | 2x185 mm ² | — |
| | - test current I_e (A) | 630 A | — |
| | Measured temperature-rise | see appended tables 8.3.4.4 | P |
| 8.3.4.1 | Operational performance test | Sample No A3/8 | P |
| | - utilization category | AC-22B | — |
| | - rated operational voltage (V) | 400 V | — |
| | - rated operational current (A) | 630 A | — |
| | Test conditions for electrical operation cycles: | | — |
| | - test voltage (V) | L1: 400 V L2: 400 V L3: 401 V | — |
| | - test current (A) | L1: 638 A L2: 640 A L3: 635 A | — |
| | - power factor/time constant | L1: 0,80 L2: 0,80 L3: 0,80 | — |
| | Number of cycles with current | 200 | P |
| | Number of cycles without current | 800 | P |
| | First test sequence (with/without current) | without current | — |
| | Second test sequence (with/without current) | with current | — |
| | - time interval between first and second test sequence | 4000 s | — |
| 8.3.4.1.5 | Behaviour of the equipment during the operational performance test | | P |
| | Test performed without: | | — |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE DLA JAKOŚCI O/Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Piapackiego 13/15




81

| IEC / EN 60947-3 | | | |
|------------------|--|-------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.4.1.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 150 N (before the test 110 N) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.4.2 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ : | 1380 V | — |
| | No breakdown or flashover | | P |
| 8.3.4.3 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole : | — | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | 0,010 mA | P |
| 8.3.4.4 | Temperature-rise verification | | P |
| | - conductor cross-section (mm ²) | 2x185 mm ² | — |
| | - test current I_e (A) | 630 A | — |
| | Measured temperature-rise | see appended tables 8.3.4.4 | P |
| 8.3.4.1 | Operational performance test | | P |
| | - utilization category | AC-21B | — |
| | - rated operational voltage (V) | 690 V | — |
| | - rated operational current (A) | 630 A | — |
| | Test conditions for electrical operation cycles: | | — |
| | - test voltage (V) | L1: 691 V L2: 691 V L3: 691 V | — |

| IEC / EN 60947-3 | | | |
|------------------|---|-------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - test current (A) | L1: 650 A L2: 636 A L3: 634 A | — |
| | - power factor/time constant | L1: 0,95 L2: 0,94 L3: 0,95 | — |
| | Number of cycles with current | 200 | P |
| | Number of cycles without current | 800 | P |
| | First test sequence (with/without current) | without current | — |
| | Second test sequence (with/without current) | with current | — |
| | - time interval between first and second test sequence | 2600 s | — |
| 8.3.4.1.5 | Behaviour of the equipment during the operational performance test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.4.1.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 130 N (before the test 110 N) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.4.2 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1380 V | — |
| | No breakdown or flashover | | P |
| 8.3.4.3 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | — | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | 0,011 mA | P |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Napackiego 13/13



82

| IEC / EN 60947-3 | | | |
|------------------|---|-------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.4.4 | Temperature-rise verification | | P |
| | - conductor cross-section (mm ²) | 2x185 mm ² | — |
| | - test current I _e (A) | 630 A | — |
| | Measured temperature-rise..... | see appended tables 8.3.4.4 | P |
| 8.3.4.1 | Operational performance test | Sample No A3/9 | P |
| | - utilization category | AC-21B | — |
| | - rated operational voltage (V) | 400 V | — |
| | - rated operational current (A) | 630 A | — |
| | Test conditions for electrical operation cycles: | | — |
| | - test voltage (V) | L1: 401 V L2: 401 V L3: 402 V | — |
| | - test current (A) | L1: 636 A L2: 639 A L3: 635 A | — |
| | - power factor/time constant | L1: 0,96 L2: 0,96 L3: 0,96 | — |
| | Number of cycles with current | 200 | P |
| | Number of cycles without current | 800 | P |
| | First test sequence (with/without current) | without current | — |
| | Second test sequence (with/without current) | with current | — |
| | - time interval between first and second test sequence | 3000 s | — |
| 8.3.4.1.5 | Behaviour of the equipment during the operational performance test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.4.1.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Rappackiego 13/13


| IEC / EN 60947-3 | | | |
|------------------|---|-------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 160 N (before the test 110 N) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.4.2 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~..... : | 1380 V | — |
| | No breakdown or flashover | | P |
| 8.3.4.3 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | — | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | 0,010 mA | P |
| 8.3.4.4 | Temperature-rise verification | | P |
| | - conductor cross-section (mm ²) | 2x185 mm ² | — |
| | - test current I_e (A) | 630 A | — |
| | Measured temperature-rise..... | see appended tables 8.3.4.4 | P |

Handwritten signature

Handwritten signature

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE DLA JAKOŚCI O LUBŁIN
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Piapaukiego 13/15



ВЕРНО С
 ОРИГИНАЛА

83

| IEC / EN 60947-3 | | | |
|------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.5 | TEST SEQUENCE III: SHORT-CIRCUIT PERFORMANCE CAPABILITY | | N/A |
| | Requirements of this clause not applicable to the tested products | | |

| IEC / EN 60947-3 | | | |
|------------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT | | P |
| | Short-circuit breaking capacity test was carried out at Laboratorium Badawcze Aparatury Rozdzielczej of Instytut Elektrotechniki in Warsaw. The particular results of the test are given in test report No. 7670/NBR/08 | | — |
| | Protective device details: | Sample No.: 2W | —P— |
| | - manufacturer's name, trademark or identification mark | APATOR | — |
| | - manufacturer's model or type reference | WTNH 3 gG | — |
| | - rated voltage (V) | 500 V | — |
| | - rated current (A) | 630 A | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | 420 V | — |
| | test current (kA) | 100 kA | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,2 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | — |
| | - max. let-through current (kA) | L1: 21,86 kA L2: 33,99 kA L3: 60,02 kA | — |
| | - Joule integral I^2dt (A ² s) | L1: 1280 kA ² s L2: 2390 kA ² s L3: 4510 kA ² s | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1 m/s | — |
| | - point at which the measurement is made | Actuator | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1 m/s | — |
| | - max. let-through current (kA) | L1: 1,31 kA L2: 34,98 kA L3: 35,32 kA | — |
| | - Joule integral I^2dt (A ² s) | L1: — kA ² s L2: 1860 kA ² s L3: 1840 kA ² s | — |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWOZE D/S JAKOSCI O Lublin
 ZAKLAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Flapackiego 13/15

84

| IEC / EN 60947-3 | | | |
|------------------|--|-------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Test performed without: | | |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 150 N (before the test 110 N) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~..... : | 1380 V | |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole : | — | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,010 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | - conductor cross-section (mm ²) | 2x185 mm ² | |
| | - test current I_e (A) | 630 A | |
| | Measured temperature-rise..... : | see appended table 8.3.6.5 | P |

| IEC / EN 60947-3 | | | |
|------------------|---|----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.7 | TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY | | P |
| 8.3.7.1 | Overload test | Sample No. A3/10 | P |
| | ambient temperature 10-40 | 24 °C | — |
| | test enclosure W x H x D (mm x mm x mm) | — | — |
| | material of enclosure | — | — |
| | test current 1,6xI _{th} or 1,6xI _{th} (A) | 1008 A | — |
| | cable/busbar cross-section (mm ²) / length (mm) .. | 2x185 mm ² | — |
| | Fuse-link details: | | P |
| | - manufacturer's name, trademark or identification mark | APATOR WTNH 3 | — |
| | - rated current (A) | 630 A | — |
| | - power loss (W) | 44 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - time duration of the overload test (s) | 1624 s | — |
| | Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed | 5 min open and close | P |
| | Required opening force not greater than the test force of 8.2.5.2 and table 8 | 110 N | P |
| | The equipment has not undergone any impairment hindering such operation | | P |
| 8.3.7.2 | Dielectric verification | | P |
| | test voltage: 2*U _e with a minimum of 1000V~ | 1380 N | — |
| | No flashover or breakdown | | P |
| 8.3.7.3 | Leakage current | | P |
| | test voltage (1,1 U _e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole | — | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | 0,011 mA | P |
| 8.3.7.4 | Temperature-rise verification | | P |
| | Fuse links aged during the overload test are replaced by new fuse-links | | P |
| | - conductor cross-section (mm ²) | 630 A | — |
| | - test current I _e (A) | 2x185 mm ² | — |
| | Measured temperature-rise | see appended table 8.3.7.4 | P |

TRF No. IEC/EN60947_3B

| IEC / EN 60947-3 | | | |
|------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.4 | ELECTROMAGNETIC COMPATIBILITY TESTS | | P |
| 8.4.1 | Immunity | | P |
| 8.4.1.1 | Equipment not incorporating electronic circuits: no tests necessary | | P |
| 8.4.1.2 | Equipment incorporating electronic circuits: | | N/A |
| | Equipment utilizing circuits in which all components are passive are not required to be tested | | N/A |
| | All other equipment, requirements according to 7.3.3.2 and limits according table 6 apply | | N/A |
| | Performed tests : see _____ | | N/A |
| | No unintentional separation or closing of contacts has occurred during these tests : | | N/A |
| 8.4.2 | Emission | | P |
| 8.4.2.1 | Equipment not incorporating electronic circuits: no tests necessary | | P |
| 8.4.2.2 | Equipment incorporating electronic circuits: | | N/A |
| | Equipment utilizing circuits in which all components are passive are not required to be tested | | N/A |
| | All other equipment, requirements according to 7.3.3.2 and limits according table 7 apply | | N/A |
| | Performed tests : see _____ | | N/A |

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Napackiego 13.13

| IEC / EN 60947-3 | | | |
|---------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| Annex A (normative) | | | N/A |
| A | Equipment for direct switching of a single motor | | N/A |
| | Requirements of this clause not applicable to the tested products | | |

Handwritten signature

Handwritten signature

TRF No. IEC/EN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
BIURO BADAWCZE D/S JAKOŚCI O Lubin
ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
20-150 Lubin, ul. Zapackiego 13/15



ВЕРНО С
ОПТИЧНАА

86

| IEC / EN 60947-3 | | | |
|------------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 7.1.3 | TABLE: Clearance and creepage distance measurements | | | | | | P |
|----------------------------------|---|--------|--------------|-----------------------------|---------|-------------------|----------|
| Type of fuse-switch disconnecter | clearance cl and creepage distance dcr at/of: | Up (V) | U r.m.s. (V) | required cl (mm) case A / B | cl (mm) | required dcr (mm) | dcr (mm) |
| ARS 3-6-M | L-L | 12 kV | 1000 | 14 / 4,5 | 20,9 | 14 | 55,6 |
| | L-A | | | | 9,1 | | 15,0 |
| ARS 3-1-V | L-L | | | | 18,1 | | 55,6 |
| | L-A | | | | 9,1 | | 15,0 |
| ARS 3-1-2V | L-L | | | | 13,6 | | 55,6 |
| | L-A | | | | 9,1 | | 15,0 |
| supplementary information: — | | | | | | | |

| 7.1.1.1 | TABLE: resistance to heat and fire. Glow-wire flammability test. | | | | | | P |
|---|--|------------------|---|---|-----------------|--------------------------|---------|
| | Conditioning time | 24 h | | | | | |
| | Ambient temperature | 20 °C | | | | | |
| | Relative humidity | 50 % | | | | | |
| | Time of glow-wire tip application (t _a) | (30 ± 1) s | | | | | |
| Tested part / material / market name / color | Thickness of material | Wire temperature | Duration from tip application to ignition | Duration from tip application to flames extinguishing | Height of flame | Specified layer ignition | Verdict |
| | mm | °C | (t) s | (t _a) s | mm | no / yes | |
| Viewer I, Viewer II, terminals housing / polycarbonate / Lexan 9945A / transparent | 2 | 650 | 0 | 0 | 0 | no | P |
| Enclosure, actuator, cover, conductor / poliamid / Starflam RX06082 / grey or black | 3 | 650 | 0 | 0 | 0 | no | P |
| Base, arc chamber, terminals cover, blocking plate / poliamid / Starflam RF0057E / grey | 2 | 960 | 5 | 31 | 3 | no | P |
| supplementary information: | | | | | | | |
| Test carried out on parts from equipment. | | | | | | | |
| Criteria of acceptance: t _b ≤ t _a + 30 s. | | | | | | | |

TRF No. IECEN60947_3B


STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Kapackiego 13/13

| IEC / EN 60947-3 | | | |
|--|---|-----------------|-----------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3.1 | TABLE: Temperature-rise (measurements) | Sample No A3/10 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 60 | 70 |
| | L2 | 69 | |
| | L3 | 68 | |
| | U | 57 | |
| | V | 59 | |
| | W | 60 | |
| Manual operating means: metallic / non-metallic | | —/12 | 15/25 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/39 | 30/40 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/42 | 40/50 |
| supplementary information: ambient temperature 25 °C | | | |

| IEC / EN 60947-3 | | | |
|--|---|-----------------|-----------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3.1 | TABLE: Temperature-rise (measurements) | Sample No A3/11 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 63 | 70 |
| | L2 | 68 | |
| | L3 | 65 | |
| | U | 49 | |
| | V | 52 | |
| | W | 51 | |
| Manual operating means: metallic / non-metallic | | —/11 | 15/25 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/38 | 30/40 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/46 | 40/50 |
| supplementary information: ambient temperature 25 °C | | | |

TRF No. IECEN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lubin
 ZAKŁAD APARATOWNISKIEGO NAPIĘCIA
 20-150 Lubin, ul. Napoleońskiego 13/13



ЗЕРНО С
 ОРИГИНАЛ

87

| IEC / EN 60947-3 | | | |
|------------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 8.3.3.1 | TABLE: Temperature-rise (measurements) | Sample No A3/15 | P |
|--|--|-----------------|-----------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 67 | 70 |
| | L2 | 69 | |
| | L3 | 68 | |
| | U | 59 | |
| | V | 60 | |
| | W | 61 | |
| Manual operating means: metallic / non-metallic | | —/12 | 15/25 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/39 | 30/40 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/48 | 40/50 |
| supplementary information: ambient temperature 25 °C | | | |

| 8.3.3.6 | TABLE: Temperature-rise (measurements) | Sample No A3/1 | |
|--|--|-----------------|-----------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 60 | 80 |
| | L2 | 74 | |
| | L3 | 66 | |
| | U | 51 | |
| | V | 53 | |
| | W | 57 | |
| Manual operating means: metallic / non-metallic | | —/7 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/27 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/45 | 50/60 |
| supplementary information: ambient temperature 24 °C | | | |

TRF No. IECEN60947_3B


STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE DŁG JAKOŚCI O LUBLIN
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Piapackiego 13/15

| IEC / EN 60947-3 | | | |
|--|---|--------------------|--------------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3.6 | TABLE: Temperature-rise (measurements) | Sample No A3/4 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 60 | 80 |
| | L2 | 49 | |
| | L3 | 52 | |
| | U | 47 | |
| | V | 42 | |
| | W | 46 | |
| Manual operating means: metallic / non-metallic | | —/12 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/30 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/39 | 50/60 |
| supplementary information: ambient temperature 24 °C | | | |

| 8.3.3.6 TABLE: Temperature-rise (measurements) | | | |
|--|----|--------------------|--------------------|
| | | Sample No A3/5 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 60 | 80 |
| | L2 | 62 | |
| | L3 | 56 | |
| | U | 45 | |
| | V | 49 | |
| | W | 40 | |
| Manual operating means: metallic / non-metallic | | —/13 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/32 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/40 | 50/60 |
| supplementary information: ambient temperature 24 °C | | | |

TRF No. IECEN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JARCÓSIŃ O/Lublin
 ZAKŁAD APARATOWYŃNISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Niepackiego 13/13



ВІСНИК
 ОРГАНІЗАЦІЇ

88

| IEC / EN 60947-3 | | | |
|--|---|-----------------|-----------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3.6 | TABLE: Temperature-rise (measurements) | Sample No A3/6 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 70 | 80 |
| | L2 | 79 | |
| | L3 | 66 | |
| | U | 77 | |
| | V | 78 | |
| | W | 76 | |
| Manual operating means: metallic / non-metallic | | —/14 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/44 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/47 | 50/60 |
| supplementary information: ambient temperature 24 °C | | | |


| | | | |
|--|---|-----------------|-----------------|
| 8.3.4.4 | TABLE: Temperature-rise (measurements) | Sample No A3/3 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 62 | 80 |
| | L2 | 75 | |
| | L3 | 74 | |
| | U | 79 | |
| | V | 74 | |
| | W | 80 | |
| Manual operating means: metallic / non-metallic | | —/15 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/45 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/59 | 50/60 |
| supplementary information: ambient temperature 24 °C | | | |

| IEC / EN 60947-3 | | | |
|--|--|-----------------|-----------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.4.4 | TABLE: Temperature-rise (measurements) | Sample No A3/7 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 52 | 80 |
| | L2 | 67 | |
| | L3 | 50 | |
| | U | 79 | |
| | V | 78 | |
| | W | 77 | |
| Manual operating means: metallic / non-metallic | | —/13 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/48 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/53 | 50/60 |
| supplementary information: ambient temperature 25 °C | | | |

| IEC / EN 60947-3 | | | |
|--|--|-----------------|-----------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.4.4 | TABLE: Temperature-rise (measurements) | Sample No A3/8 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 48 | 80 |
| | L2 | 47 | |
| | L3 | 46 | |
| | U | 52 | |
| | V | 54 | |
| | W | 54 | |
| Manual operating means: metallic / non-metallic | | —/10 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/26 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/31 | 50/60 |
| supplementary information: ambient temperature 24 °C | | | |

TRF No. IECEN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI O Lublin
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Napackiego 13/15



29

| IEC / EN 60947-3 | | | |
|--|---|--------------------|--------------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.4.4 | TABLE: Temperature-rise (measurements) | Sample No A3/9 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 45 | 80 |
| | L2 | 44 | |
| | L3 | 43 | |
| | U | 56 | |
| | V | 53 | |
| | W | 52 | |
| Manual operating means: metallic / non-metallic | | —/10 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/28 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/35 | 50/60 |
| supplementary information: ambient temperature 25 °C | | | |

| | | | |
|--|---|--------------------|--------------------|
| 8.3.6.5 | TABLE: Temperature-rise (measurements) | Sample No. 2 W | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 53 | 80 |
| | L2 | 54 | |
| | L3 | 50 | |
| | U | 52 | |
| | V | 54 | |
| | W | 56 | |
| Manual operating means: metallic / non-metallic | | —/11 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/37 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/41 | 50/60 |
| supplementary information: ambient temperature 23 °C | | | |


| IEC / EN 60947-3 | | | |
|--|--|------------------|-----------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.7.4 | TABLE: Temperature-rise (measurements) | Sample No. A3/10 | P |
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | L1 | 57 | 80 |
| | L2 | 66 | |
| | L3 | 60 | |
| | U | 54 | |
| | V | 50 | |
| | W | 49 | |
| Manual operating means: metallic / non-metallic | | —/10 | 25/35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | —/36 | 40/50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | —/42 | 50/60 |
| supplementary information: ambient temperature 24 °C | | | |

Handwritten signature

Handwritten signature

TRF No. IECEN60947_3B



STOWARZYSZENIE ELEKTRYKÓW POLSKICH
 BIURO BADAWCZE D/S JAKOŚCI OLEBUT
 ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
 20-150 Lublin, ul. Niepackiego 13.13



ВЛРНО С
 ОРИГИНАЛ

90

Photos of ARS 3



ARS 3- 6 – M

TRF No. IECEN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
BIURO BADAWCZE DNG JAKOŚCI O Lubin
ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
20-150 Lubin, ul. Piłsudskiego 131/3

Photos of ARS 3



ARS 3-1-V

TRF No. IECEN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
BIURO BADAWCZE D/S JAKOŚCI O/Lublin
ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
20-150 Lublin, ul. Raabickiego 13/15



an

Photos of ARS 3



ARS 3- 1 - 2V

TRF No. IECEN60947_3B

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
BIURO BADAWCZE DLA JAKOŚCI O.Lublin
ZAKŁAD APARATÓW NISKIEGO NAPIĘCIA
20-150 Lublin, ul. Hapłańskiego 12/13

СПИСЪК НА ПРОВЕЖДАНИТЕ ИЗПИТВАНИЯ НА ЛИНЕЙНИ ЗАЩИТНО-КОМУТАЦИОННИ АПАРАТИ НИСКО НАПРЕЖЕНИЕ (НН) ЗА ВЕРТИКАЛЕН МОНТАЖ

Линейни защитно-комутационни апарати ниско напрежение (НН) за вертикален монтаж (ВНР):

ARS 2-6-V/400 A

ARS 3-6-V/630 A

Производство на: APATOR® SA

Улица: Zolkiewskiego 13/29, Пощенски код: 87-100, Населено място: Torun, Страна: Poland

Телефонен номер: +48 56/ 61 91 627

Номер на телефакс+48 56/ 61 91 295

e-mail: trade@apator.com.pl

Homepage: www.apator.com.pl

Типовите изпитвания се провеждат съгласно изискванията на стандарти:

БДС EN 60269-1:2007 - Комутационни апарати за ниско напрежение. Част 1: Общи правила (IEC 60947-1:2007)

БДС EN 60947-3:2009+A1+A2 - Комутационни апарати за ниско напрежение. Част 3: Товарови прекъсвачи, разединители, товарови прекъсвач-разединители и апарати, комбинирани със стопяеми предпазители (IEC 60947-3:2008+A1+A2)

Рутинните (контролни) изпитания се провеждат на представителна извадка от произведените количества съгласно горепосочените стандарти, както следва:

1. Визуална проверка и контрол на продуктите, част от непрекъснатата система за следене на качеството;
2. Контролни изпитвания и сравнение на измерените стойности с нормативно указаните. Маркиране на всеки ВНР с идентификационен и сериен номер, запазване в архивен масив;
3. Механични рутинни изпитвания съгласно предписанията на горепосочените стандарти;
4. Проверка на проектните и фактически размери, контактни повърхности на изделията.

15.01.2020 г.

Кандидат: ИНТЕРКОМПЛЕКС ООД

На основание чл.36а ал.3 от
ЗОП

тел

92

Применение ТС 2.4

POLSKIE CENTRUM AKREDYTACJI
POLISH CENTRE FOR ACCREDITATION



Sygnatariusz EA MLA
EA MLA Signatory

CERTYFIKAT AKREDYTACJI
LABORATORIUM BADAWCZEGO
ACCREDITATION CERTIFICATE OF TESTING LABORATORY
Nr AB 044

Potwierdza się, że: / This is to confirm that:

STOWARZYSZENIE ELEKTRYKÓW POLSKICH
BIURO BADAWCZE ds. JAKOŚCI
LABORATORIUM BADAWCZE
ul. M. Pożaryskiego 28, 04-703 Warszawa


spełnia wymagania normy PN-EN ISO/IEC 17025:2005
meets requirements of the PN-EN ISO/IEC 17025:2005 standard

Akredytowana działalność jest określona w Zakresie Akredytacji Nr AB 044
Accredited activity is defined in the Scope of Accreditation No AB 044

Akredytacja pozostaje w mocy pod warunkiem przestrzegania
wymagań jednostki akredytującej określonych w kontrakcie Nr AB 044
This accreditation remains in force provided the Laboratory observes
the requirements of Accreditation Body defined in the Contract No AB 044

Certyfikat akredytacji ważny do dnia 20.06.2014 r.
The certificate of accreditation is valid until 20.06.2014

Akredytacji udzielono dnia 30.11.1995 r.
Accreditation was granted on 30.11.1995



POL [На основании чл.36а ал.3 от ЗОП](#)

Warszawa, 4 czerwca 2010 roku

ВАРНО С
ОРИГИНАЛ

93

**ЕТ "АДИС - 9 -
Анелия Митева"**

**АГЕНЦИЯ ЗА
ПРЕВОДИ**

Адрес на управление: 4023 Пловдив, ж.р.Тракия, бл.20, ет.9, ап.53, тел: 032 826632; 266292

Превод от полски език

APATOR SA


Декларация CE за съответствие

| | |
|--|--|
| № | 0024/04 |
| Производител: | APATOR SA |
| Адрес: | ул. Золкневскиего 13/29; 87-100 Торун Полша |
| Обозначение на продукта (име, тип): | Вертикални разединители с ножови предпазители тип ARS 3- |
| Декларирам, че посочения продукт съответства на следните изисквания: | |
| Европейски директиви: | 73/23/ЕЕС + 93/68/ЕЕС Директива за ниско напрежение, касаеща хармонизирането на правните предписанията на държавите членки, които се отнасят за електрическата техника, предназначена за използване в определени граници на напрежение. |
| Съгласувани стандарти и/или стандарти на IEC: | PN-EN 60947-1 Комутационна и контролна апаратура ниско напрежение Част 1: Общи решения PN-EN 60947-3 Комутационна и контролна апаратура ниско напрежение Част 3: Превключватели, разединители, превключващи разединители и комбинирани устройства със стопяеми предпазители |
| Държавни норми и/или техническа документация: | Техническа документация и комплект от чертежи 63-811216-*; 63-811217-*; 63-811463-* |
| Документи идентифициращи стоката: | Каталожна карта "Ножови включватели серия ARS, PBS" №1/2003/1. |
| Град, дата: | Торун, 30.04.2004г. |
| Име, фамилия, длъжност, подпис: | Генерален Директор Януш Ниедзвидзки Подпис: не се чете |

В случай на въвеждане на изменения на продукта, несъгласувани с производителя или ако използването не е съгласно предназначението, тази декларация става невалидна.

Подписаната Анелия Иванова Митева удостоверявам верността на извършения от мен превод от полски език на български език на приложения документ "Декларация за съответствие". Преводът се състои от 1 (една) страница.

На основание чл.36а ал.3 от ЗОП



ВЕРНО С
ОРИГИНАЛА

9A

APATOR[®] SA



DEKLARACJA CE ZGODNOŚCI EC Declaration of conformity




| | |
|----------------------------------|--|
| Nr | 0024/04 |
| No | |
| Producent | APATOR SA |
| Manufacturer | |
| Adres | ul. Żółkiewskiego 13/29; 87-100 Toruń PL |
| Address | |
| Oznaczenie produktu (nazwa, typ) | Rozłączniki izolacyjne bezpiecznikowe listwowe |
| Product designation (name, type) | typu ARS 3- |

Deklarujemy, że oznaczony wyrób jest zgodny z następującymi wymaganiami:
It is declared that the designed product is in conformity with the provisions of the following requirements:

| | |
|---|---|
| Dyrektyw europejskich: European Directives: | 73/23/EEC + 93/68/EEC Dyrektywa niskonapięciowa dotycząca harmonizacji przepisów prawnych państw członkowskich odnoszących się do sprzętu elektrycznego przeznaczonego do użytkowania w określonych zakresach napięć. |
| Norm zharmonizowanych i/lub norm IEC: Harmonised standards and/or IEC standards: | PN-EN 60947-1 Aparatura rozdzielcza i sterownicza niskonapięciowa Część 1: Postanowienia ogólne PN-EN 60947-3 Aparatura rozdzielcza i sterownicza niskonapięciowa Część 3: Rozłączniki, odłączniki, rozłączniki izolacyjne i zestawy łączników z bezpiecznikami topikowymi |
| Norm krajowych i/lub dokumentacji technicznych: National standards and/or technical specification: | Dokumentacja techniczna rysunki zestawcze: 63-811216-*; 63-811217-*; 63-811463-* |
| Dokumenty identyfikujące wyrób: Product identification documents: | Karta katalogowa „Łączniki listwowe serii ARS, PBS” Nr 1/2003/1 . |
| Miejscowość, data Place, date | Toruń, 2004.04.30 |
| Imię nazwisko stanowisko podpis Name, surname, function, signature | <div style="border: 1px solid red; padding: 5px;">На основании чл.36а ал.3 от ЗОП</div> |

*W przypadku wprowadzenia niezgodnych z producentem zmian w wyrobie lub zastosowania go niezgodnie z przeznaczeniem niniejsza deklaracja traci ważność.
If any changes of the product are not agreed with the manufacturer or the product is inappropriately used, this declaration becomes null and void.*



ВЯРНИК
ОПРЕДЕЛЕНИЯ

Приложение ТС-2.6
към Технически спецификации
по процедура PPD 19-130

ДЕКЛАРАЦИЯ

за съответствие на предлаганото изпълнение

Долуподписаният, **ЕХИЯЗАР ГАРАБЕД УЗУНЯН**, с л.к. На основание чл.36а ал.3 от ЗОП г. от МВР, гр. Пловдив, На основание чл.36а ал.3 от ЗОП правител на "ИНТЕРКОМПЛЕКС" ООД, кандидат за участие в обществена поръчка чрез събиране на оферти с обява с предмет: „Доставка на линейни защитно-комутационни апарати ниско напрежение (НН) за вертикален закрит монтаж“, реф. № PPD 19-130, с възложител „ЧЕЗ Разпределение България“ АД

ДЕКЛАРИРАМ:

1. Доставяните от фирма „Интеркомплекс“ ООД, линейни защитно-комутационни апарати ниско напрежение (НН) за вертикален монтаж (ВМР), тип ARS 3-6-V/630A, производство на "АПАТОР" – Полша, отговарят напълно на изискванията на техническата спецификация на този стандарт за материал, вкл. на параграфи „Характеристика на материала“ и „Съответствие на предложеното изпълнение със нормативно-техническите документи“.
2. Правя настоящата декларация на основание декларация на производителя.

Известно ми е, че при деклариране на неверни данни, нося наказателна отговорност по чл. 313 от НК.

15.01.2020 г.

Участник: ИНТЕРКОМПЛЕКС ООД

На основание чл.36а ал.3 от
ЗОП

тел

Приложение 3
към предложение за изпълнение на поръчката
по процедура реф.№ PPD 19-130


СРОКОВЕ ЗА ДОСТАВКА

| № | Наименование | Мярка | Количество със срок на доставка до 7 кал. дни | Количество със срок на доставка до 30 кал. дни |
|----------|--|----------|---|--|
| 1 | 2 | 3 | 4 | 5 |
| 1 | Вертикален предпазител-разединител НН 400 А, с триполюсно управление | бр. | 5 | 15 |
| 2 | Вертикален предпазител-разединител НН 630 А, с триполюсно управление | бр. | 3 | 3 |

Забележки:

- 1/ Срокът на доставките започва да тече от датата на изпращане на поръчката.
- 2/ Количествата в колона 4, със срок на доставка до 7 /седем/ календарни дни, се доставят след SAP поръчка до посочените складове на Възложителя за покриване на спешни нужди на Възложителя.
Възложителят може да поръчва посоченото спешно количество веднъж месечно.
- 3/ В случай, че крайният срок на доставката съвпада с празничен или неработен ден, то доставката се извършва не по-късно от първия работен ден след изтичането на срока.
- 4/ При поръчки на Възложителя на количества в рамките на потвърдените от Изпълнителя и недоставени в посочените срокове, ще бъдат налагани неустойки, съгласно условията на договора.
- 5/ Възложителят може да поръчва количества по-малки от посочените в колони 4 и 5.
- 6/ Възложителят може да поръчва количества по-високи от посочените в колони 4 и 5, като това обстоятелство ще бъде посочено текстово в съответната поръчка изпратена към Изпълнителя. С потвърждението на поръчката, Изпълнителят вписва в същата очаквана дата за доставка на количествата надвишаващи посочените в колони 4 и 5.
- 7/ Количествата за доставка в колони 4 и 5 са отделни и независими едно от друго.
- 8/ Количествата за доставка в колона 5 не включват в себе си количествата за доставка в колона 4.
- 9/ Възложителят има право да направи едновременно поръчки за доставка на количества от колони 4 и 5.

15.01.2020 г.



Участ

На основание чл.36а ал.3 от ЗОП

