






51249068XA



GPS91/15178



Printed
12/12/2003





client: MONTAN GEBLID S.A. - Grenoble (France)

object: Three pole metal enclosed air insulated intelligent EMS system type 2M.
Equipped with an increased operating frequency 400 Hz insulated switch
type 1 EMS.

characteristics of the tested object assigned by the Client

rated voltage: 11.5/24 kV rated current: 530 A rated frequency: 50 Hz
other characteristics listed on page 2

the tests have been made in accordance with client's instructions
based on IEC 865 (1982)

test date: June 18th, 1991
June 20th, 1991

the performance of the apparatus tested and the observations made during the
tests have been recorded in the table with the test results and oscillograms

this document is composed by 11 pages, 12 oscillograms

Milan, August 7th, 1991

test engineer

F. Lo Monaco
F. Lo Monaco

Vertical stamp: 1991 AUG 10 10:10

Large handwritten signature

keywords: 917010293 120100 234300 340200 410700 530010

This test report is not a certificate of conformity, nor are the results given responsibility for the IEC 865 supplied by the manufacturer.
This statement may not be reproduced otherwise than in its entirety with the CESI's authorisation.

Handwritten signature

rated characteristics of the tested object assigned by the client:



switch	17.5/24	kV
voltage	50	Hz
frequency	630	A
normal current	40	kA
short-circuit making current	16	kA
short-time withstand current	2	s
short circuit duration		
earthing switch	40	2A
short-circuit making current	16	2A
short-time withstand current	2	s
short-circuit duration		
gas pressure for interruption	1.3 bar abs.	

Identification of the object effected.

The tested object truly conforms to the drawings of its type supplied by the Client. These drawings identified by CESI with embossing press and numbered GPS- 91/015167 1 to 12 are assembled in a folder.

Vertical stamp or text on the right side of the page.



This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings selected by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

Table of tests performed

Date	Type of test	no. page
SHORT-TIME AND PEAK WITHSTAND CURRENT TESTS		
June 18th 1991	No.1 test with 16 KA for 1 s on the switch	5
June 18th 1991	No.1 test with 16 KA for 1 s on the earthing switch	6
SHORT-CIRCUIT MAKING TESTS		
June 20th 1991	No.2 tests with 41.2 KA and 41 KA (peak) at 24 KV on the switch	6
June 20th 1991	No.2 tests with 41 KA and 39.5 KA (peak) at 24 KV on the earthing switch	7
THREE PHASE MAINLY ACTIVE LOAD CURRENT SWITCHING TESTS		
June 22th 1991	No.2 tests with 400 A at 24 KV	8

tests witnessed by

Mr. Laurens - MERLIN GERIN S.A.
Mr. Dubois - MERLIN GERIN S.A.

This test report is not a certificate of conformity, nor do the results necessarily confirm the ratings supplied by the manufacturer. This report may not be reproduced otherwise than in its entirety without CESI's authorization.

arrangement of the object for the tests

The tested apparatus was assembled with two other apparatus of same system (see photo on page 11).

The figure below shows the electric diagram of the complete setting (single phase diagram of a three phase circuit):



1 : switch and earthing switch under test

2-3 : auxiliary switches

A-B-C : cables

For the short time current test on the switch : cables A connected to the supply, switches 1 and 2 in closed position, cables B short circuited at the bottom.

For the short time current test on the earthing switch : cables A connected to the supply, earthing switch 1 in closed position.

For the short circuit making tests on the switch : cables A connected to the supply, switch 2 in closed position, cables B short circuited at the bottom.

For the short circuit making tests on the earthing switch : cables A connected to the supply.

For the mainly active load current switching tests : cables A connected to the supply, switch 2 in closed position, cables B connected to the load.

During all the tests the switch 3 was in open position.

During the tests on the switch the metal enclosure was insulated from earth but connected thereto by a copper wire 0.1 mm in diameter and 30 mm long to indicate any significant leakage current to earth.

short-time and peak withstand current tests

test circuit conditions

circuit diagram use page 9

power factor ≤ 0.15

frequency 50 Hz

test arrangement: see page 4

conditions of the apparatus before the tests: new

test no.	oscill. no.	duration "	test current			notes
			maximum peak value kA	r.m.s. value kA	average kA	
1	1	1.01	- 41.0	16.0 16.0 16.0	16.0	test on the switch
2	2	1.21	- 41.0	16.0 15.8 15.8	16.0	test on the earthing switch

conditions of the apparatus after the tests: external parts as before the tests, internal parts not inspected.

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. The document may not be reproduced otherwise than in its entirety without CESI's authorisation.

three phase short circuit making tests

tests on the switch

with 16.0 kA

34.0 kV

test circuit conditions

circuit diagram see page 9

power factor < 0.15

frequency 50 Hz

conditions of the apparatus before the test: as after the test: as 1

test	no.	3	4			
oscillograms	no.	284	285			
operating duty		C	C			
applied voltage (phase-to-neutral)	kV	13.8	13.8			
		13.8	13.8			
		13.8	13.8			
making current (peak value) phase	kA	41.5	41.5			
		41.5	41.5			
current	kA	16.0	16.0			
		16.0	16.0			
		16.0	16.0			
duration of	closing	ms	-			
	prearc	ms	-			
control voltage of operating devices for	closing	V	-			
	motor	V	-			
gap operating pressure for	operation	bar	-			
	interruption	bar	1.4	1.4		

conditions of the apparatus after the test: external parts as before the tests, internal parts not inspected.

This test report is not a certificate of conformity, nor do the results given necessarily conform to the ratings supplied by the manufacturer. This document may not be reproduced or further distributed without CESI's authorization.

three phase short circuit making tests

tests on the testing system

with 1000 kA

24.0 kV

test circuit conditions

circuit diagram see page 5

power factor ≈ 0.25

frequency 50 Hz



conditions of the apparatus before the test: as after the test, see 2

test	no.	A	B
oscillations	no.	286	287
operating duty		C	C
applied voltage (phase-to-neutral)	kV	15.8	15.8
		13.8	13.8
		13.8	13.8
making current (peak value) phase	kA	41.0	39.5
		C	E
current	kA	16.0	16.0
		16.0	16.0
		16.0	16.0
duration of	closing	ms	-
	proceed	ms	-
contact voltage of operating device for	closing	V	-
	motor	V	-
max operating pressure for	operation	bar	-
	interruption bar		1.4

condition of the apparatus after the test: external parts as before the test, internal parts not inspected.

This test report is not a certificate of conformity nor do the results of the test justify action on the ratings supplied by the manufacturer. This document may not be reproduced or revised in any way without CESI's authorization.

Three-phase mainly active load current switching tests

test duty

with 400 A at 24.0 kV

test circuit conditions

circuit diagram see page 10

supply circuit

power factor: ≤ 0.7
 frequency: 50 Hz
 neutral condition: method
 TRV: see 44 kV LS 54 20

impedance: 6.0 Ω
 (20 % of the total impedance of the circuit)

load circuit

power factor: 0.7
 neutral condition: insulated

frequency: 50 Hz
 damping factor:

average voltage of operating devices for: closing - V
 opening - V
 motor - V
 gas opening pressure for: operation - bar abs.
 breaking 1.4 bar abs.

conditions of the apparatus before the tests: as after the test no. 4


test		no. 7	8
outlet		no. 208	209
operating duty		C-0	C-0
voltage with open apparatus	phase-to-neutral kV	13.8	13.8
		13.8	13.8
		13.8	13.8
voltage with open apparatus	phase-to-phase kV	24.0	24.0
inrush making current		KA	-
maximum closing overvoltage	supply side kV	-	-
	load side kV	-	-
breaking current	A	400	400
	A	400	400
average		A	400
maximum opening overvoltage	supply side kV	-	-
	load side kV	-	-
castrikes		no.	-
		phase	-
duration of	closing	ms	-
	opening	ms	-
	process	ms	-
	arc	ms	10

conditions of the apparatus after the tests: external parts as before the tests
 internal parts not inspected.

note after all the tests: the performance of the apparatus is considered satisfactory for the tests performed.

This test report is not a certified document. It is the property of CESI. It is necessary to refer to the ratings supplied by the manufacturer.
 This document may not be reproduced or transmitted in any form or by any means, without CESI's authorization.


circu diagram



sempre il valore di un parametro è lo stesso di quello del precedente

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced elsewhere without CESI's authorization.

circuit diagram




Vertical text or stamp on the right side of the diagram.

Figure 1 shows the diagram and the connection on the test board.

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

1282



RECEIVED
CESI
APR 11 1989

This test report is not a certificate of conformity, nor do the results given necessarily conform to the test as stipulated by the manufacturer. This document may not be reproduced otherwise than in its entirety without Cesi's authorization.

Presented with notes

Handwritten mark

08
28. 07

15
28. 45

05
28. 24

15
28. 24

07
28. 24

11
28. 24

46.0 2A

44.0 2A

46.0 2A

4.016

DATE TIME INCLUDE


UNIT - UPE 150/000000
TYPE - UPE 150/000000
TYPE - UPE 150/000000
TYPE - UPE 150/000000

4790

Large handwritten mark

Handwritten signature

15500001
48.115.0A



[Handwritten signature]

PROB 11... 200 MHz... 200 MHz... 200 MHz... 200 MHz... 200 MHz... 200 MHz...
1000 - 200 MHz... 1000 - 200 MHz... 1000 - 200 MHz... 1000 - 200 MHz... 1000 - 200 MHz... 1000 - 200 MHz...
200 MHz... 200 MHz... 200 MHz... 200 MHz... 200 MHz... 200 MHz...
200 MHz... 200 MHz... 200 MHz... 200 MHz... 200 MHz... 200 MHz...


10000000
00000000

[Handwritten signature]

[Handwritten signature]

175 6407
48,002 N4
30-44-100 2000

Handwritten mark



175 6407 48,002 N4 30-44-100 2000


175 6407 48,002 N4 30-44-100 2000
175 6407 48,002 N4 30-44-100 2000
175 6407 48,002 N4 30-44-100 2000

Handwritten signature

Handwritten signature

13. 10. 1971
47. 28. 19. 63
10. 10. 1971

Handwritten mark



13. 10. 1971
47. 28. 19. 63
10. 10. 1971


13. 10. 1971
47. 28. 19. 63
10. 10. 1971

Handwritten mark

Handwritten mark

1/2

0.1 0.2 0.3 0.4 0.5 0.6 0.7 0.8 0.9 1.0 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.9 2.0 2.1 2.2 2.3 2.4 2.5 2.6 2.7 2.8 2.9 3.0 3.1 3.2 3.3 3.4 3.5 3.6 3.7 3.8 3.9 4.0 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 5.0 5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8 5.9 6.0 6.1 6.2 6.3 6.4 6.5 6.6 6.7 6.8 6.9 7.0 7.1 7.2 7.3 7.4 7.5 7.6 7.7 7.8 7.9 8.0 8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 9.0 9.1 9.2 9.3 9.4 9.5 9.6 9.7 9.8 9.9 10.0







24 MS

4151 - 005 100/100mm Hg
 150/90/70/40
 85%

1804
 1804
 1804

51249069XA

GPS91/15200



0
1
2
3
4
5
6
7
8
9

[Handwritten signature]

[Handwritten mark]

Handwritten mark

table of tests performed

date	type of test	see page
June 18th 1991	<p style="text-align: center;">SHORT TIME AND PEAK WITHSTAND CURRENT TEST</p> <p>Test on the searching switch downstream the fuse with 2 kA for 1 s.</p>	8

GERLIN GERIN S.A.

tests witnessed by

Mr. Laurens - GERLIN GERIN S.A.
Mr. Dubroqua - GERLIN GERIN S.A.

Handwritten signature


Handwritten signature

Handwritten signature

This test report is not a certificate of conformity, nor do the results given necessarily conform to the standards supplied by the manufacturer. This document may not be reproduced otherwise than it is entirely without Cesi's authorization.

arrangement of the object for the tests

The tested apparatus was assembled with two other apparatus of SMG system (see photo on page 7).
 The figure below shows the electric diagram of the complete setting (single phase diagram of a three phase circuit) :



- 4 : earthing switch under test
- 1-2-3 : auxiliary switches
- A-B-C : cables

During the tests the cables C were connected to the supply and the switch 4 was in closed position. All the other switches were in open position.

028-91/015200
 Page 4

short-circ and peak withstand current tests

test circuit conditions

circuit diagram see page 6 power factor < 0.15 frequency 50 Hz

test arrangements: see page 4

conditions of the apparatus before the tests: see


test no.	circuit no.	duration s	test current			notes
			maximum peak value kA	r.m.s. value kA	average kA	
1	3	1.01	- - 5.20	2.00 2.00 2.00	2.00	after the test the operating switch operated correctly.

conditions of the apparatus after the tests: as before the test.

note after the test : the performance of the apparatus is considered satisfactory for the test performed.

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings specified by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorisation.


circuit-diagram



symbols used in this diagram are the same as on the oscillograms

This test report is not a certificate of conformity, nor do the results given necessarily confirm the values indicated by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

h/




Page 10

This test report is not a certificate of conformity, nor do the results given necessarily equal the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without the written authorization.

[Handwritten signatures and scribbles]

0141511021 81408



0151 - RPS 1812012223 70001111370000 4
 Tipo prova - 74094 - CCL - 1M1 2000 1.1515
 0254.000021 000000 000000 000000 000000 000000

0141511021 81408
 0141511021 81408


5/

[Handwritten signature]

[Handwritten signature]




[Handwritten signature]

1810



51249070XA

GPS91/15201



h

client: REALTECH S.A. - Grenoble (France)

object: Three pole metal enclosed air insulated switchgear RM6 system type RM.
Fitted with an internal operating frequency SF6 gas insulated switch.
Type IQ RM6.

characteristics of the tested object assigned by the client

rated voltage 17,5/24 kV rated current 200 A rated frequency 50 Hz
other characteristics listed on page 1

the tests have been made in accordance with client's instructions
based on IEC 694 (1988)

test date: June 18th, 1991

the performance of the apparatus tested and the observations made during the
tests have been recorded in the table with the test results and oscillograms

this document is composed by 7 pages, 2 oscillograms

01/015791
REALTECH S.A.
Grenoble
France

millon, August 19th, 1991

test engineer

F. Le Senec
F. Le Senec

[Signature]

[Signature]

[Signature]

[Signature]

[Signature]

01/012281
keywords : 120120 234308 360300 453701 536010

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer.
This document may not be reproduced others in their entirety without CESI's authorisation.


Table of tests performed

date	type of test	see page
June 18th 1991	<p style="text-align: center;">SHORT-TIME AND PEAK WITHSTAND CURRENT TEST</p> <p>Test on the earthing switch downstream the fence with 2 KA for 1 s.</p>	5

01/015201
 18/06/91
 18

Tests witnessed by


Mr. Lauferas - MERLIN GERIN S.A.
 Mr. Dubrojan - MERLIN GERIN S.A.



This test report is not a certificate of conformity, nor do the results given necessarily confirm the claims made by the manufacturer. This document may not be reproduced otherwise than in its entirety without CCSI's authorization.

arrangement of the object for the tests

The tested apparatus was assembled with two other apparatus of SMC system (see photo on page 7).
 The figure below shows the electric diagram of the complete setting (single phase diagram of a three phase circuit):



- 4 : earthing switch under test
- 1-2-3 : auxiliary switch
- A-B-C : cables

During the tests the cables C were connected to the supply and the switch 4 was in closed position. All the other switches were in open position.



[Handwritten signature]

[Handwritten signature]

short time and peak withstand current tests

test circuit conditions

circuit diagram see page 6

power factor < 0.15

frequency 50 Hz

test arrangement: see page 4

conditions of the apparatus before the test: new

test no.	oscill. no.	duration s	test current			notes
			maximum peak value kA	r.m.s. value kA	average kA	
1	3	1.01	- - 5.20	2.00 2.00 2.00	2.00	after the test the earthing switch operated correctly.

conditions of the apparatus after the test: as before the test


note after the test : the performance of the apparatus is considered satisfactory for the test performed.





This test report is not a certificate of conformity, nor do the results given necessarily confirm the values supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.


circuit-diagram



note: see in this diagram for the same as on the pag. 4/4/01/015201

[Handwritten signatures]

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.







This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

51249072XA

Handwritten mark

GPS91/15203



Faint, illegible handwritten text

Handwritten signature

Handwritten signature

Handwritten signature

client MERLIN GERIN S.A. - Grenoble (France)

object Three pole metal enclosed air insulated switchgear GIS system type TR.
Fitted with an increased operating frequency SF6 gas insulated switch
type T 8M6.

characteristics of the tested object assigned by the Client

rated voltage 24 kV rated current 630 A rated frequency 50 Hz
other characteristics listed on page 2

the tests have been made in accordance with client's instructions
based on IEC 694 (1980)

test date June 21st, 1991

the performance of the apparatus tested and the observations made during the
tests have been recorded in the table with the test results and oscillograms

this document is composed by 7 pages, 4 oscillograms

order, August 22nd, 1991

test engineer

F. Le Monast

91/015284
keywords : 120100 234303 360201 450307 530010

This test report is not a certificate of conformity, nor do the results given necessarily confirm the claims supplied by the manufacturer.
This document may not be reproduced otherwise than in its entirety without CESI's authorization.

rated characteristic of the tested object assigned by the client:

switch	
voltage	24 kV
frequency	50 Hz
normal current	630 A
short-circuit making current	50 kA
short-time withstand current	20 kA
short-circuit duration	1 s
earthing switch	
short-circuit making current	10 kA
short-time withstand current	20 kA
short-circuit duration	1 s
gas pressure for interruption	1.4 bar abs.

Identification of the object affected.


The tested object truly conforms to the drawings of its type supplied by the Client. These drawings identified by CESI with embossing press and numbered GPS- 91/015203 1 to 12 are assembled in a folder.



[Handwritten signatures and scribbles]

arrangement of the object for the tests

The tested apparatus was assembled with two other apparatus of SM6 system (see photo on page 2).
 The figure below shows the electric diagram of the complete setting (single phase diagram of a three phase circuit):



1 : switch and earthing switch under test

2-3 : auxiliary switches

A-B-C : cables

For the short time current test on the switch : cables A connected to the supply, switches 1 and 2 in closed position, cables B short circuited at the bottom.

For the short time current test on the earthing switch : cables A connected to the supply, earthing switch 1 in closed position.

During the test on the switch the metal enclosure was insulated from earth but connected thereto by a copper wire 0.1 mm in diameter and 30 mm long to indicate any significant leakage current to earth.

This test report is not a certificate of conformity, nor do the results given necessarily conform to the values assumed by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

1826

short-time and peak withstand current tests

test circuit conditions

circuit diagram see page 6 power factor ≤ 0.15 frequency 50 Hz

test arrangement: see page 4

conditions of the apparatus before the tests: new


Test no.	oscill. no.	duration s	Test current			notes
			maximum peak value kA	r.m.s. value kA	average kA	
1	1	1.01	- 50.0	20.0 20.0 20.0	20.0	test on the switch
2	2	1.01	- 50.0	20.0 20.0 20.0	20.0	test on the earthing switch

conditions of the apparatus after the tests: external parts as before the tests, internal parts not inspected.

note after the tests : the performance of the apparatus is considered satisfactory for the tests performed.

This test report is not a certificate of conformity, nor do the results given necessarily refer to the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

circuit-diagram




symbols used in this diagram are the same as on the test program

[Handwritten signatures]

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

Handwritten mark



Vertical text on the right side of the image, possibly a date or reference number.

Handwritten signature


Handwritten signature

Handwritten signature

This test report is not a certificate of conformity, nor do the results necessarily establish that the product supplied by the manufacturer. This document may not be reproduced or otherwise used in its entirety without CCSI's authorization.

1. The patient is a 45-year-old male with a history of hypertension and hyperlipidemia. He was brought to the ER by ambulance with a chief complaint of chest pain and shortness of breath. The patient is currently on a regular schedule of Lisinopril and Atorvastatin.

50.0 Hz



[Handwritten signature]

[Handwritten signature]

[Handwritten signature]





[Handwritten signature]

ECG 12 LEAD

11/15/2011

51249139XA

MP91/012987



RECEIVED
MAY 19 1991

[Handwritten signature]

[Handwritten signature]

CLIENT : MERRAIN GERIN - GRENOBLE CEDEX (France)

APPARATUS TESTED : THREE POLE METAL-ENCLOSED AIR INSULATED SWITCHGEAR SM6 SYSTEM TYPE IM. Fitted with an increased operating frequency SF6 gas insulated switch type I SM6. (see photo CD1).

DESIGNATION : IK

CHARACTERISTICS ASSIGNED BY THE CLIENT TO THE APPARATUS:

- Rated voltage (U) : 17.5/24 kV
 - Rated normal current : 400 A

Other characteristics are listed on page 2.

TESTS PERFORMED : - Measurement of the resistance of the main circuit
 - Verification of temperature rise limits

TESTS MADE IN ACCORDANCE WITH : the Client instruction based on IEC STANDARD Publication 298 (1981) and IEC 694 (1988).

DATE OF TESTS : 18th June 1991

The performance of the apparatus tested and the observations made during the tests, have been recorded in the tables with the results and oscillograms.

This document is composed by 7 pages

91/012987, 17th September 1991

Responsible for the document:

(M. J. ...)

91/012987

Keywords: 120120 355108 510206 440204 530311 629408

This test report is the property of CESI. The results give a necessary opinion on the ratings supplied by the manufacturer. This document may not be reproduced or otherwise used in its entirety without CESI's authorization.

OTHER CHARACTERISTICS ASSIGNED BY THE CLIENT TO THE APPARATUS

- Rated frequency : 50 Hz
- Rated short-time withstand current of the main circuit : 20 kA
- Rated peak withstand current of the main circuit : 50 kA
- Rated duration of short-circuit : 1 s
- Rated short-time withstand current of the earthing circuit : 20 kA
- Rated peak withstand current of the earthing circuit : 50 kA
- Rated duration of short-circuit : 1 s

THE TESTS WERE WITNESSED BY:

Mr. LAURENS - MERLIN GERIN S.A.

Mr. DUBROCCA - MERLIN GERIN S.A.

TEST REPORT
 N° 12987
 MP-91/012987
 1991

IDENTIFICATION OF THE APPARATUS:

The tested apparatus truly conforms to the drawings of its type supplied by the client. These drawings, identified by CESI with embossing press and numbered GPR 91/012987 from 001 to 012 are assembled in a folder.

This test report is not a certificate of conformity, nor is the test. It does not necessarily confirm the ratings supplied by the manufacturer. Its dissemination may not be made without the prior written consent of CESI.

2/


CONTENTS

TEST EFFECTED	DESCRIPTION ON PAGE
- Measurement of the resistance of the main circuit before and after the temperature-rise test.	4
- Verification of temperature rise limits	5
- Photo of the tested apparatus	7

[Handwritten signatures]

This test report is not a certificate of conformity, nor do the results given necessarily confirm the findings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

Handwritten mark



RECEIVED
C. J. ...

~~PHOTO 001~~

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced other than in its entirety without CESI's authorization.

Handwritten signature

Handwritten mark

1841

51249142XA

MP91/012992







EXHIBIT 3

Handwritten signature

Handwritten signature

CLIENT : MERLIN GERIN - GRENOBLE CEDEX (France)

APPARATUS TESTED : THREE POLE METAL-ENCLOSED AIR INSULATED SWITCHGEAR SM6 SYSTEM TYPE IM. Fitted with an increased operating frequency SF6 gas insulated switch type I SM6. (see photo 001).

DESIGNATION : IM

CHARACTERISTICS ASSIGNED BY THE CLIENT TO THE APPARATUS:

- Rated voltage (U) : 17.5/24 kV
- Rated normal current : 630 A

Other characteristics are listed on page 2.

TESTS PERFORMED : - Measurement of the resistance of the main circuit
- Verification of temperature rise limits

TESTS MADE IN ACCORDANCE WITH : the Client instruction based on IEC STANDARD Publication 298 (1981) and IEC 694 (1980).

DATE OF TESTS : 18th June 1991

The performance of the apparatus tested and the observations made during the tests, have been recorded in the tables with the results and oscillograms.

this document is composed by 7 pages

18th, 17th September 1991

Responsible for the document
(U. ...)

91/012992

Keywords: 120100 235105 340204 440204 530310 624404

This test report is not a certificate of conformity. It is the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

CONTENTS

TEST EFFECTED	DESCRIPTION ON PAGE
- Measurement of the resistance of the main circuit before and after the temperature-rise test.	4
- Verification of temperature rise limits	5
- Photo of the tested apparatus	7

[Handwritten signature]

[Handwritten signature]

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

[Handwritten signature]

1845

VERIFICATION OF TEMPERATURE RISE LIMITS

Test arrangement

- The apparatus tested was placed on the floor of the test room in the same conditions as in normal service.
- The three phase a.c. low-voltage supply was connected to the incoming terminals of the apparatus tested by means of one flexible copper conductor per phase having a cross-sectional area of 240 mm² and 2 meters in length.

Measurement of the temperature

- The ambient air temperature was obtained from the average of the temperatures measured by means of three copper-constantane thermocouples immersed inside oil sumps containing about half a litre of oil, distributed around the apparatus tested at about its average height and at a distance of about 1m.
- The temperature of all other parts were measured by copper-constantane thermocouples.

Test currents

- The test was carried out with a three-phase current having a r.m.s. value of 630 A - 50 Hz.

Test results

The maximum temperature rise at the thermal steady state ($\Delta t \leq 1^\circ\text{C/h}$) with an ambient air temperature of 23.8°C were:

MEASURED PARTS	TEMPERATURE RISE K	
	Measured	Admitted
- Incoming terminal, phase 1	52.0	65
- Incoming terminal, phase 2	52.0	65
- Incoming terminal, phase 3	51.3	65
- Upper fixed contact of the switch-disconnector, phase 1	52.9	65
- Upper fixed contact of the switch-disconnector, phase 2	55.4	65
- Upper fixed contact of the switch-disconnector, phase 3	51.5	65
- Upper moving contact of the switch-disconnector, phase 1	54.4	65
- Upper moving contact of the switch-disconnector, phase 2	55.5	65
- Upper moving contact of the switch-disconnector, phase 3	53.6	65
- Lower moving contact of the switch-disconnector, phase 1	51.6	65
- Lower moving contact of the switch-disconnector, phase 2	52.2	65
- Lower moving contact of the switch-disconnector, phase 3	50.5	65
- Lower fixed contact of the switch-disconnector, phase 1	47.8	65
- Lower fixed contact of the switch-disconnector, phase 2	48.4	65
- Lower fixed contact of the switch-disconnector, phase 3	47.4	65
- Ambient SF6 temperature inside the pole of the switch-disconnector, phase 1	37.4	-
- Ambient SF6 temperature inside the pole of the switch-disconnector, phase 2	37.6	-
- Ambient SF6 temperature inside the pole of the switch-disconnector, phase 3	37.9	-
- Main bus-bar, phase 1	56.2	-
- Main bus-bar, phase 2	59.1	-
- Main bus-bar, phase 3	55.0	-

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.




PHOTO 001





This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

1849

Handwritten mark

51249153XA

MP91/013008



Faint vertical text or stamp

Handwritten signature

Handwritten signature

Handwritten mark

1850

CLIENT : MERLIN GERIN GRENOBLE CEDEX (France)

APPARATUS TESTED : THREE POLE METAL-ENCLOSED AIR INSULATED SWITCHGEAR SM6 SYSTEM TYPE QM, fitted with an increased operating frequency SF6 gas insulated switch type IQ SM6. (see photo 001).

DESIGNATION : QM

CHARACTERISTICS ASSIGNED BY THE CLIENT TO THE APPARATUS:

- Rated voltage (U) : 12 kV
- Rated normal current : 250 A

Other characteristics are listed on page 2.

TESTS PERFORMED : - Measurement of the resistance of the main circuit
- Verification of temperature rise limits

TESTS MADE IN ACCORDANCE WITH : the Client's instruction based on IEC STANDARD Publication 298 (1981) and IEC 694 (1969).

DATE OF TESTS : 18th June 1991

The performance of the apparatus tested and the observations made during the tests, have been recorded in the tables with the results and oscillograms.

This document is composed by 7 pages

19th September 1991

Responsible for the document (M. Ley)

91/912648

Keywords 120100 235100 310200 440200 530010 674300

This test report is not a certificate of conformity. The results given here testify to the items supplied by the manufacturer. This document may not be reproduced or used in any way without CESI's authorization.

OTHER CHARACTERISTICS ASSIGNED BY THE CLIENT TO THE APPARATUS

- Rated frequency	:	50 Hz
- Rated short-time withstand current of the main circuit	:	25 kA
- Rated peak withstand current of the main circuit	:	62.5 kA
- Rated duration of short-circuit	:	1 s
- Rated short-time withstand current of the earthing circuit	:	25 kA
- Rated peak withstand current of the earthing circuit	:	62.5 kA
- Rated duration of short-circuit	:	1 s

CHARACTERISTICS OF THE FUSE LINK

- Manufacturer	:	MERLIN GERIN S.A.
- Designation	:	FUSARC
- Rated current	:	250 A

THE TESTS WERE WITNESSED BY:

Mr. LAURENS - MERLIN GERIN S.A.

Mr. BUSBOGNA - MERLIN GERIN S.A.

DESCRIPTION OF THE APPARATUS:

The tested apparatus truly conforms to the drawings of its type supplied by the Client. These drawings, identified by CESI with embossing press and numbered GPs 91/C13162 from 001 to 013 are assembled in a folder.


CONTENTS

TEST EFFECTED	DESCRIPTION ON PAGE
- Measurement of the resistance of the main circuit before and after the temperature-rise test.	4
- Verification of temperature rise limits	5
- Photo of the tested apparatus	7

1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20

This test report is not a certificate of conformity, nor does the test it gives necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced, otherwise than in its original form, without C-ESI's authorisation.

MEASUREMENT OF THE RESISTANCE OF THE MAIN CIRCUIT



C. J. ...
 ...
 ...
 ...
 ...

MEASURE (see the above figure)	PHASE	BEFORE THE TEMPERATURE RISE TEST		AFTER THE TEMPERATURE RISE TEST	
		AMBIENT AIR TEMPERATURE °C	RESISTANCE mΩ	AMBIENT AIR TEMPERATURE °C	RESISTANCE mΩ
A - B	1	23.4	0.057	25.4	0.057
A - B	2	23.4	0.057	25.4	0.050
A - B	1	23.4	0.054	23.4	0.052

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

This test report is not a certificate of conformity, nor do the results given necessarily confirm the ratings supplied by the manufacturer. This document may not be reproduced otherwise than in its entirety without CESI's authorization.

1854