

content	page	test date
Test object characteristics	5	September 18, 2017
Reference standard	6	
Test carried out and identification of the test object	7 to 8	
Test setting for the test	9	
Test procedure	10 to 12	
Summary of test result	13	
Instrument used for the test	14	
Technical data		
Pages annexed:		
Client's drawing (arrester section assembled in thermal model) : CEST n. B7023130-n.1 page		
Client's drawing (complete arrester) : CEST n. B7024013-n.1 page		
Client's drawing (MFO resistor) : CEST n. B7020387-n.1 page		



A1001G rev.1

Test Report

Tests witnessed by:
 Mr. Anton Potapov
 Mr. Alexander Kolychek

Joint-Stock Company "Polymer-Apparat"
 Joint-Stock Company "Polymer-Apparat"

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawings, identified by CESI and numbered B7023130 n.1 & B7024013 n.1, are annexed to this document.


The data necessary to permit repetition of the tests are contained in the document marked: ---
 The reported expanded uncertainties are determined in accordance with the Publication JCGM 100 "Evaluation of measurement data - Guide to the expression of uncertainty in measurement" and are based on a standard uncertainty multiplied by a coverage factor $K=2$, which, for a normal distribution, provides a level of confidence of approximately 95%.

- : ± 3,0 %
- : ± 3,0 %
- : ± 3,0 %
- : ± 3,0 %
- : ± 10,0 %
- : ± 1,5 %

Laboratory information

September 2017
 CESI - Via Rubattino 54 - Milan
 Mr. L. Podavitte, Mr. I Guacci
 P177 (Surge Arrester laboratory)
 700006781

Receipt date of the sample



A1001G rev.2

Rated characteristics of the tested objects assigned by the Client


Polymer-housed surge arrester

Manufacturer	Joint-Stock Company "Polymer-Apparat"
Type	PA-DM-54
MO resistors supplier	Joint-Stock Company "Polymer-Apparat"
Serial no.	000035
Drawing code	PA-OPN.035.001.054.01
Arrester class	Distribution
Designation	DH
Design	B
Rated voltage - U_r	54 kV
Continuous operating voltage - U_c	43,2 kV
Rated frequency	48-62 Hz
Nominal discharge current (8/20 μ s impulse shape)	10 kA
Reference current - I_{ref}	1 mA
Year of manufacturer	08/2017

ВЯРНО С
ОПРЕДЕЛЕНИЕ

Polymer-housed surge arrester section assembled in thermal model

Manufacturer	Joint-Stock Company "Polymer-Apparat"
Type	PA-DM
MO resistors supplier	Joint-Stock Company "Polymer-Apparat"
Serial no.	000011
Drawing code	PA-DM.001.ST.01
Arrester class	Distribution
Designation	DH
Design	B
Rated voltage - U_r	1,25 x U_c
Continuous operating voltage - U_c	4,34 kV
Rated frequency	48-62 Hz
Nominal discharge current (8/20 μ s impulse shape)	10 kA
Reference current - I_{ref}	1 mA
Year of manufacturer	08/2017



A1176G

Reference Standard

IEC 60099-4 – Edition 3.0 (2014-06) – clause 8.6 & Annex B
"Metal-Oxide Surge Arresters without gaps for AC systems"

Test carried out and identification of the test objects

Test carried out	Number of test objects	Test object identification
Heat dissipation behaviour of test sample	1	PA-DM-54 - s/n. 368162
	1	PA-DM (Section) - s/n. 368160

Handwritten signature



A1176G

102

Test setting for the test




Photo no. 1

Complete arrester



A1267G





Photo no. 2

Arrester section assembled in thermal model



A1267G

**ВЯРНО С
ОРИГИНАЛА**



Test procedure on complete arrester

The complete arrester was placed in the testing laboratory (see photograph no.1 on page 7) at still air ambient temperature of 21,1 °C. The ambient temperature was held at 21,1 °C ±3K during the test. The complete arrester was supplied by the manufacturer fitted with a optical thermal sensors attached to the MO resistors (see drawing attached on this test report).

The surge arrester was heated to a temperature of approximately 140 °C by the application of a power frequency overvoltage with an amplitude above the reference voltage.

The heating time was 22 min. (the maximum time according to the reference standard is 60 min.).

When the specified temperature of about 140 °C was reached the voltage source was disconnected and the cooling time curve was determined over a period of not less than 2 hours.

Test procedure on arrester section

The arrester section was placed in the testing laboratory (see photograph no.2 on page 8) at still air ambient temperature of 22,2 °C.


The ambient temperature was held at 22,2°C ±3K during the test.

The arrester section was supplied by the manufacturer and one optical thermal sensor has been used (see drawing attached on this test report).

The MO resistor was heated to a temperature of approximately 140 °C by the application of a power frequency overvoltage with an amplitude above the reference voltage.


The heating time has been of 22 min. (the maximum time according to the reference standard is 60 min.).

When the specified temperature of about 140 °C was reached the voltage source was disconnected and the cooling time curve was determined over a period of not less than 2 hours.



[Handwritten signature]

[Handwritten signature]



**ВЯРНО С
ОРИГИНАЛА**

Test result and the calculation of the temperature compensation

The cooling curve (see pag.10) of the arrester section hasn't been for all instants equal or higher than the cooling curve of the arrester. The compensation may be made adding a ΔT to the start temperature ϑ_{start} of the prorated section during the preheating (thermal recovery part) for Operating duty test and Power-frequency voltage versus time test.

Sample	T	T _A	T ₀	T ₀ - T _A	Heating time	Date
Complete arrester	is the measured temperature during cooling every minute	21,1 °C	152,0 °C	130,9 °C	22 min	September 18, 2017
Arrester section	is the measured temperature during cooling every minute	22,2 °C	148,8 °C	125,8 °C	22 min	September 18, 2017

Legend:

- T is the measured temperature instant by instant
- T_A is the average ambient temperature during test
- T₀ is the maximum heating temperature
- T_{rel} (T-T_A) / (T₀-T_A)
- ΔT temperature compensation


The two relative temperatures T_{rel,arrester} and T_{rel,arrester section} have been plotted (see page 12) for the cooling time ($\geq 7000s$)
 During the cooling time the difference T_{rel,arrester} - T_{rel,arrester section} has been calculated and the max value has to be considered.

$K = \max(T_{rel,arrester} - T_{rel,arrester\ section}) = 0,044329149$

$\Delta T = K (T_0 - T_A)_{max} = 0,044329149 * 130,9 = 5,80 \text{ } ^\circ\text{C}$

The compensation temperature ΔT resulting from the test is 5,80 °C.


$\vartheta_{start} = 60 \text{ } ^\circ\text{C} + 5,80 \text{ } ^\circ\text{C} = 65,80 \text{ } ^\circ\text{C}$



Handwritten signature



A126410



ВЯРНО С ОПИТНАТА


A11760

185

Instruments used for temperature measurement

Instrument type	CESI no.	Note:
ASKIYANA	022469 - Rx 022468 - Tx	used surge arrester unit and surge arrester section temperature
FLUKE thermometer	030889	used for ambient temperature

Circuit A0019



Power frequency supply

- RE - programmable supply type PACIFIC A.C. Power Source 140 ASX.; CESI no. 0560408
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 60 kVA; voltage 220 V/200 kV (used for complete arrester)

Current measuring system

- R - Current shunt CESI No.31120; R= 941,4 Ω
- Electro optical system CESI No.53829/53828
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.1)


Voltage measuring system




- D - Voltage divider SAGI, CESI No.11120 (used for arrester section)
- Voltage divider SAGI, CESI No 13027 (used for complete arrester)
- Electro optical system CESI No.11517/11518
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.2)

Software system:




- SW - S.A.D. Surge arrester version 2.0

ВЯРНО С
ОРИГИНАЛА





PA.VAR.0400.30



1. Металлооксидный варистор (MOV disk)
2. Изоляционное покрытие стекла (Glass insulating collar)
3. Изоляционное покрытие полуреотак (PU insulating collar)
4. Алюминиевый электрод (Al - electrode)

CESI
B7020387001



Изм.	Лист	№ докум.	Подп.	Дата
		Потолов А.В.	Ирдыев	09.17
		Тетухов А.Л.	Семенов	09.17
		Т.контр.		
Исполн.				
Утв.	Шедлов И.В.			11.10.17
Оксид цинка				
ЗАО				
Полимер-Аппарат				
Лист	1	Листов	1	
Масса	0.177	Масшт.	1:1	
PA.VAR.0400.30				
Varistor B34/30				

ВЕРНО С
ОРИГИНАЛА

ЭЛЕКТРИК ТД

Type Test Report

Document No.	B7018645	Copy No.	1	Number of pages	24
Apparatus	Housing of polymer-housed surge arrester, classified "distribution/DH", for outdoor installation. Rated voltage = 54 kV; Nominal discharge class = 10 kA				
Designation	PA-DH-54				
Serial Number	368160				
Manufacturer	JSC Polymer-Apparat				
Client	JSC Polymer-Apparat Ak. Konstantinova Strasse, 195427 Saint-Petersburg - Russia Federation				
Tested for	—				
Date(s) of tests	September 19, 2017				
Tested by	CESI S.p.A. Via Rubattino, 54 20134 Milano - Italy				
Test performed	Insulation withstand tests on polymer-housed surge arresters (sub-clause 10.8.2): - dry lightning impulse voltage test (clause 8.2.6) - wet power-frequency voltage test (clause 8.2.8)				

ВАРНО С
ДИПЛОМАТА

PROBATIONARY USE

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with IEC 60099-4 - Edition 3.0 (2014-06)

The results shown in the record of proving tests and the affidavits attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s). The results achieved by the Manufacturer are listed on the ending page. The document applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the Manufacturer.

October 25, 2017

Date

Dal Gjorgjo Carlo
Test Engineer in charge

The Manager - Anacleto Lorenzo
Approved By Deponent Digitally Signed

Personal responsibility of this document is permitted only with the written permission from CESI Group. The authenticity of this document is guaranteed by the integrity of the signature.



LAB N° 6030

The laboratory meets the requirements of the Standard EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing Laboratories" and the list of accredited tests may be checked in the accreditation and the list of accredited tests may be checked in the VDS site: www.aacredia.it



CESI

Trust the Power of Experience

Notes

STL-Member

CESI Group members are founder members of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in 1969. STL is a forum for voluntary international cooperation of testing organizations.

CESI Group Test Documents description

Type Test Certificate of

Issued for type tests of high voltage products ($> 1 \text{ kV}_{ac}$ $> 1,5 \text{ kV}_{dc}$), which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. The Type Test Certificate consists of documents unequivocally identifying the test object and describes all conditions under which the tests were conducted. It gives evidence of the unobjectionable behavior of the test object during the tests in line with the normative documents applied as well as of the results of successful testing.

Test Certificate of (complete / selected) Type Tests

Issued for type tests of low voltage products ($< 1 \text{ kV}_{ac}$; $< 1,5 \text{ kV}_{dc}$) requested by the relevant product standard were passed. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Certificate of Design Verification

Issued for passed design verification tests according to IEC 61439. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Type Test Report

Issued for high and low voltage products if parts of selected type tests have been passed; those shall be carried out in full compliance with the relevant standards but (for high voltage products) do not fulfill all STL requirements for issuing a Type Test Certificate. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Test Report

Issued for all other tests on high and low voltage products which have been carried out according to specifications, standards and/or client instructions

On-Site Test Record

Issued as a record of results acquired during the on-site tests / measurements

Test Award

Can be additionally issued for all named types of test documents above if the tests to be referenced were passed

Tests witnessed by:

Mr Alexander Kolychev
Mr Anton Pospelov

JSC Polymer-Apparat
JSC Polymer-Apparat

Identification of the object:

effected

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawing, identified by CESI and numbered B7021732 No.1, is annexed to this document.

Test evaluation

With reference to the Standards/Specifications listed in the first page and the characteristics of the tested sample assigned by manufacturer, the carried out tests passed SUCCESSFULLY.

Revision No.	Date	Reference
0	October 25, 2017	B7018645


ОРИГИНАЛ
ВЕРНО С

The data necessary to permit repetition of the tests are contained in the document marked: ----

The reported expanded uncertainties are determined in accordance with the Publication JCGM 100 "Evaluation of measurement data - Guide to the expression of uncertainty in measurement" and are based on a standard uncertainty multiplied by a coverage factor $k = 2$, which for a normal distribution provides a level of confidence of approximately 95 %.

Peak voltage (impulse tests) $\pm 3.0 \%$
 Voltage a.c., d.c. (dielectric tests) $\pm 3.0 \%$
 Peak current (impulse tests) $\pm 3.0 \%$
 Time parameters (impulse tests) $\pm 10 \%$
 Time parameters (a.c., d.c. dielectric tests) $\pm 3.5 \%$
 Partial discharge measurement
 Atmospheric conditions: up to 10 pC; ± 1.0 pC above 10 pC; $\pm 10 \%$

Temperature: Pressure: Relative Humidity (30 to 95 % RH) ± 2.0 °C; ± 1.0 hPa; $\pm 5 \%$



September 18, 2016
 CESI - Via Rubattino 54 - Milan
 Mr L. Tiziani
 P180 (100 kV)
 70006781



Rated characteristics of the tested object assigned by the Client	Test requirements	Test procedure and results	Lighting impulse voltage test (dry)	Power-frequency voltage test (wet)	Circuit A0002 - Impulse generator	Circuit A0058 - Power frequency test circuit	Circuit A0059 - Power frequency measuring circuit	Photograph of the test object	Photograph of the test arrangement	Pages annexed:	Oscillogram (total pages:9)	Reference document annexed:	Drawing identified by CESI and numbered B7021732 No.1	
content	page	test date	5	6	7	8	September 19, 2017	9	September 19, 2017	10	11	12	13	14




Rated characteristics of the tested object assigned by the Client

Housing of polymer-housed surge arrester	
Manufacturer	JSC Polymer-Apparat -Ak. Konstantinova Str., 1 - 195427 Saint-Petersburg - Russia Federation
Type	PA-DH-54
Drawing No.	PA.OPN.035.002.054.H (dated 03.17)
Arrester classification	Distribution DH
Type of installation	outdoor
Serial number	368160
Rated voltage (U_n)	54 kV
Continuous operating voltage (U_c)	43.2 kV
Rated frequency	48+62 Hz
Nominal discharge current (8/20 μs impulse shape)	10 kA
Maximum residual voltage of the arrester for the nominal discharge current (LIPL)	133.9 kV
IEC required dry lightning impulse withstand voltage (*)	174.1 kV _{peak}
IEC required wet power-frequency withstand voltage (**)	117.8 kV _{peak}
Test value declared by the Client of dry lightning impulse withstand voltage	240.0 kV _{peak}
Test value declared by the Client of wet power-frequency withstand voltage	150.0 kV _{peak}
Number of sheds of the housing	12

(*) calculated as 1.3 times the maximum residual voltage of the arrester at nominal discharge current (LIPL)

(**) calculated as 0.88 times the lightning impulse protection level (LIPL)



NOTE: the lightning impulse protection level (LIPL or U_{pl}) is the maximum residual voltage of the arrester for the nominal discharge current

**ВЕРНО С
ОРИГИНАЛА**



Test requirements

IEC 60099-4, Edition 3.0 (2014-06) – clause 2 “Normative references”
The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*
IEC 60060-2, *High-voltage test techniques – Part 2: Measuring systems*

Test requirements
Below is an excerpt of the reference standards regarding to insulation withstand tests on polymer-housed surge arrester object of this Test Report.

IEC 60099-4 clause 10 “Test requirements on polymer-housed surge arresters”, sub-clause 10.8.2 “Insulation withstand tests” and sub-clause 8.2 “Insulation withstand tests”.

The voltage withstand tests demonstrate the voltage withstand capability of the external insulation of the arrester housing. For other designs the test has to be agreed upon between the manufacturer and the user.

The outside surface of insulating parts shall be carefully cleaned and the internal parts removed or rendered inoperative to permit these tests.

For arresters intended for use on systems of $U_s \leq 245$ kV, lightning impulse voltage tests according to 8.2.6 and power-frequency voltage tests according to 8.2.8 shall be performed on individual unit housings.

The applicable tests shall be run on the longest arrester housing. If this does not represent the highest specific voltage stress per unit length, additional tests shall be performed on the unit housing having the highest specific voltage stress. For the test, the MO resistors shall be removed from the housing or replaced by insulators.

The voltage to be applied during a withstand test is determined by multiplying the specified withstand voltage by the correction factor taking into account density and humidity (see IEC 60060-1).

Humidity correction shall not be applied for wet tests.

The external insulation of outdoor arresters shall be subjected to wet withstand tests under the test procedure given in IEC 60060-1.

Lightning impulse voltage test (sub-clause 8.2.6)

The arrester shall be subjected to a standard lightning impulse voltage dry test according to IEC 60060-1. The test voltage shall be at least 1.3 times the maximum residual voltage of the arrester at nominal discharge current.

Fifteen consecutive impulses at the test voltage value shall be applied for each polarity. The arrester shall be considered to have passed the test if no internal disruptive discharges occur and if the number of the external disruptive discharges does not exceed two in each series of 15 impulses. The test voltage shall be equal to the lightning impulse protection level of the arrester multiplied by 1.3.

Power-frequency voltage test (sub-clause 8.2.8)

The housings of arresters intended for outdoor use shall be tested in wet conditions, and housings of arresters intended for indoor use shall be tested in dry conditions.

Housings of distribution class arresters according to Table 1 shall withstand a power-frequency voltage with a peak value equal to the lightning impulse protection level multiplied by 0.88 for a duration of 1 min.



Serial No.	Impulse generator charging voltage	applied U x K _v	U _{peak} [kV]	K _v	test sample polarity					
					positive	negative				
368160	240,0	240,0	61,2	235,0	positive	negative				
					A	0	0	0	0	0
					B	0	0	0	0	0
					C	0	0	0	0	0
					D	0	0	0	0	0
					time to discharge (µs)	235,1	235,1	235,1	235,1	235,1
368160	240,0	240,0	61,3	235,0	positive	negative				
					A	0	0	0	0	0
					B	0	0	0	0	0
					C	0	0	0	0	0
					D	0	0	0	0	0
					time to discharge (µs)	235,1	235,1	235,1	235,1	235,1

Date: September 19, 2017

Atmospheric conditions and correction factor			
b	h	t _c	P _a
0,979	9,88	18,8	99,76

Measured arcing distance = 485 mm

Test object: Housing of polymer-housed surge arrester, classified "distribution DH", for outdoor installation
 Test circuit: A0002
 Arrangement: see photographs of the test set-up

Lightning impulse voltage test (dry)

A10170



[Handwritten signature]



[Handwritten signature]

A11763

Test procedure and results

The Client had removed or rendered inoperative the internal parts of the surge arrester to permit these tests. The outside surface of insulating parts was cleaned.

The arrester housing was arranged for the tests as shown on photograph No.3. The end terminal of the arrester housing was fixed to the earth.

The test voltage was applied between the upper line terminal of the arrester housing and its end terminal connected to the metallic support and earth.

The sample was identified by its serial number 368160.

Lightning impulse voltage test (sub-clause 8.2.6)
 The housing of surge arrester was subjected to a standard lightning impulse voltage dry test according to IEC 60060-1.

The applied voltage was the test voltage value declared by the Client corrected for atmospheric conditions at the time of the test.

The test voltage value declared by the Client was higher than the value calculated according to the procedure of IEC 60099-4 (1,3 times the maximum residual voltage of the arrester at nominal discharge current), therefore it is comply with the requirements of the relevant Standard.

Fifteen consecutive impulses at the determined test voltage value were applied for each polarity.

During the test no internal disruptive discharges and no external disruptive discharges occurred.

Therefore the housing of the surge arrester passed the lightning impulse voltage test

power-frequency voltage test (sub-clause 8.2.8)
 The housing of surge arrester was subjected to a power-frequency withstand voltage test in wet conditions.


The characteristics of the rain were according to IEC 60060-1.

The applied voltage was the test voltage value declared by the Client corrected for atmospheric conditions at the time of the test.


The test voltage value declared by the Client was higher than the value calculated according to the procedure of IEC 60099-4 (calculated as a peak value equal to the lightning impulse protection level multiplied by 0,88), therefore it is comply with the requirements of the relevant Standard.

Therefore the housing of the surge arrester passed the wet power-frequency voltage test

The sample withstood for one minute the applied voltage.



Circuit A000Z



Impulse generator

- No. of stages: 4
- C_g: 125 nF
- C_c: 520 Ω (3x140 + 2/200 Ω)
- R_t: 410 Ω (2x140 Ω + 1x60 Ω + 2/60 Ω + 1x40 Ω)
- C_t: --- nF

Voltage measuring system CESI No. 9792

- D - divider PASSONI & VILLA type RC series CESI No. 6700; scale factor 25600
- HV - high voltage capacitance 600 pF
- LV - low voltage unit CESI No. 6704
- K - coaxial cable
- S - attenuation and termination unit CESI No. 14924
- OSC - digital oscilloscope LECROY type HD-4096 CESI No. 58202

Measured waveshape		time		oscilloscope	
polarity	time	μs	ms	No.	
front	positive	1,17		1	
tail	positive	51,4		2	

Check of the test circuit		Measured voltage	
Changing voltage	V ₀	V _m	η
KV/stage	KV	KV	V _m / (V ₀ · D _{norm})
57,3	220,4	220,4	0,962

Additional measurements:

Reading instruments for atmospheric conditions: Data logger E+E ELEKTRONIK type HUMVLOG 20 CESI No.58065
 Software for calculation of the correction factor: Futrot UR REL rel.3.4 January 2016



A0002IG

[Handwritten signature]

Notes	Oscillogram	Test result	withstand	No.	9
			60	s	
		test duration	148,95	KV _{peak}	
		V _{AV} = k ₀ V _s (k ₀ = 25700)	5,80	V _{peak}	
		test voltage	---	KV _{peak}	
		V _{AV} = k ₁ V ₁ (k ₁ = ---)	---	V ₁	
		applied	148,95	KV _{peak}	
		required	150,0	KV _{peak}	
		test sample	368160	Serial No.	

Date: September 19, 2017

Precipitation conditions	
Water temperature	20,2 °C
Water conductivity	99,4 μS/cm
Precipitation rate (mm/min)	1,0
vertical	1,0
horizontal	1,0


Atmospheric conditions and correction factor			
b	h	ρ	h
99,76	20,3	9,71	0,993

Measured arcing distance = 485 mm

Test object: Floating of polymer-housed surge arrester, classified "distribution DF", for outdoor installation
 Test circuit: 0058 - A0059
 Arrangements: see photographs of the test set-up




**ВАРИАНТ
 КОПИЯ**



161

Circuit A0058



Power frequency test circuit

- regulation group PVI composed by:
- single-phase voltage converter PVI; power 210 kVA; voltage 380 V/0-610 V
- booster transformer PVI; power 200 kVA; voltage 600 V /6 kV
- protection resistor TELEMA; R= 2 Ω
- current transformer type CGS; ratio 50 A/5 A; CESI No.33277
- direct reading digital ammeter
- voltage transformer type ALSTOM; ratio 6 kV/100 V; CESI No.33276
- digital voltmeter FLUKE type 8842A; CESI No.05735
- variable reactor (not used)
- booster transformer CGE mod. KOC; secondary winding power 700 kVA; voltage 6 kV /350 kV; No. of units 1; ratio 58,33

Tripping of the circuit breaker S


kV	setting of instantaneous tripping		setting of time delayed tripping	
	s ₁	t ₁	s ₂	t ₂
A	50	0.05	25	0.05
S	1	30	0.5	25

Additional measurements:

- Reading instruments for atmospheric conditions: Data logger E-H ELEKTRONIK type HUMLOG 20 CESI No.58065
- Software for calculation of the correction factor: Futori UR REL rel 3.1 January 2016
- Stopwatch CPC ELETTROMECCANICA type TDN46; CESI No.38203
- Shield collecting vessel for measurement of precipitation rate CESI, CESI No.38234
- Conductivity meter data logger DELTA-OHM type HD 2106.2, CESI No.56181

Handwritten signature

Circuit A0059



Power frequency measuring circuit


- TA - current transformer type CGS; ratio 50 A/5 A; CESI No.33277
- I - direct reading digital ammeter
- TV1 - voltage transformer type ALSTOM; ratio 6 kV/100 V; CESI No.33276
- V1 - digital voltmeter FLUKE type 8842A; CESI No.05735
- D - divider PASSONI & VILLA type RC series CESI No.06700; scale factor 25700
- HV - high voltage capacitor 600 pF
- lv - low voltage unit CESI No.06704
- K - coaxial cable
- S - attenuation and termination unit CESI No.14924
- V5 - digital voltmeter AGILENT type 34401A; CESI No.55077
- TV2 - voltage transformer (not used)
- V2 - digital voltmeter (not used)

Functional check of the test circuit

V ₁	Low voltage		High voltage		k _h	V _{HV} / V ₁	k _h	V _{HV} / V ₁
	V _{1n}	I _n	V ₂	I _n				
14,684	881,0	—	—	0,6	—	—	2,0096	51,65
							25700	3517

Handwritten signature

**ВЯРНО С
ОРИГИНАЛА**



Photograph of the test object





Photo No. 1

[Handwritten signature]

**ВЯРНО С
ОРИГИНАЛА**



A1395G



ACCREDITIA
CONFORME ALLE NORME
UNI EN ISO 9001

A1268G

Photograph of the test arrangement





Photo No. 2


[Handwritten signature]



ACCREDITIA
CONFORME ALLE NORME
UNI EN ISO 9001




ВРРНО С
ОПТИМАЛНА




U.Peak= 220,37 kV
U.T1/Tr= 1,1703 μs
U.T2= 51,358 μs
U.θ'= -0,9404 %

CESI P180 B7018645 , Oscil. No. 0001




U.Peak= 220,37 kV
U.T1/Tr= 1,1703 μs
U.T2= 51,358 μs
U.θ'= -0,9404 %

CESI P180 B7018645 , Oscil. No. 0002




ВЯРНО С
ОРИГИНАЛА




U_{Peak} = 235,25 kV
U.T1/Tr = 1,1723 μs
U.T2 = 51,39 μs
U.B' = -0,9921 %

CESI P180 B7018645 , Oscil. No. 0003




U_{Peak} = 235,04 kV
U.T1/Tr = 1,171 μs
U.T2 = 51,542 μs
U.B' = -1,0872 %


CESI P180 B7018645 , Oscil. No. 0004



ВЯРНО С
ОРИГИНАЛА




CESI P180 B7018645 , Oscil. No. 0005




CESI P180 B7018645 , Oscil. No. 0006


ВЯРНО С
ОРИГИНАЛА



CESI P180 B7018645 , Oscil. No. 0007




CESI P180 B7018645 , Oscil. No. 0008



ВЯРНО С
ОРИГИНАЛА
У.Р.Е.К. 149114

U 40 kV/div



CESI P180 B7018645 , Oscil. No. 0009

Имя и фамилия

Дата и время

Знакомит

Инструмент

Стор. №

Пер. стр.

PA.OPN.035.002.054.H

1. Все размеры для справок. All dimensions for reference

				PA.OPN.035.002.054.H		
Имя	Адрес	Исполн.	Дата	METAL-OXIDE SURGE ARRESTER		Масштаб
Исполн.	Исполн. И.	Исполн. И.	Исполн. И.	PA-SI-353-SI-20/20 Resistor for IW1		1:2
Исполн.	Исполн. А.	Исполн. А.	Исполн. А.	А.А.А. (0311)		Акс. 1 Акс. 1
Исполн.	Исполн. С.	Исполн. С.	Исполн. С.	3А0		Полимер-Аппарат
Исполн.	Исполн. И.	Исполн. И.	Исполн. И.	1:12		Стор. 1/1

Test Report

Document No.	B7019592	Copy No.	1	Number of pages	28
Apparatus	MO resistors type B34/30				
Designation	—				
Serial Number	—				
Manufacturer	Joint-Stock Company "Polymer-Apparat"				
Client	Joint-Stock Company "Polymer-Apparat" Ak. Kostantinova Strasse, 1 195427 - Saint-Petersburg - Russian Federation				
Tested for	—				
Date(s) of tests	September 27-28, 2017				
Tested by	CESI S.p.A. Via Rubattino, 54 20134 Milano - Italy				
Test performed	Residual voltage tests				

CONFIDENTIAL USE
PAP/19/15/2017 (4357/07)
ОПТИКА

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with: IEC 60099-4 - Edition 3.0 (2014-06)

The cards are shown in the record of proving tests and the ovalograms attached hereto. The ratings assigned by the Manufacturer are listed on the rating paper. The document applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with the tested tests rests with the Manufacturer.

November 9, 2017

Date " November 9, 2017 " Approved By: Gregorio Marco Test Engineer in charge
The Manager: Arcidino Lorenzo Approved By: Document Digitally Signed

Partial reproduction of this document is permitted only with the written permission from CESI Group. The integrity of this document is guaranteed by the integrity of the signature.



The laboratory meets the requirements of the Standards EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing Laboratories" and the requirements of the Standards EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing Laboratories" and the requirements of the Standards EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing Laboratories". The list of accredited tests may be checked in the WEB site: www.accredia.it



Trust the Power of Experience

Notes

STL-Member

CESI Group members are founder members of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in 1969. STL is a forum for voluntary international cooperation of testing organizations.

CESI Group Test Documents description

Type Test Certificate of

Issued for type tests of high voltage products ($> 1 \text{ kV}_{\text{eff}}$ $> 1,5 \text{ kV}_{\text{eff}}$), which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. The Type Test Certificate consists of documents unequivocally identifying the test object and describes all conditions under which the tests were conducted. It gives evidence of the unobjectionable behavior of the test object during the tests in line with the normative documents applied as well as of the results of successful testing.

Test Certificate of (complete / selected) Type Tests

Issued if type tests of low voltage products ($< 1 \text{ kV}_{\text{eff}}$ $< 1,5 \text{ kV}_{\text{eff}}$) requested by the relevant product standard were passed. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Certificate of Design Verification

Issued for passed design verification tests according to IEC 61439. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Type Test Report

Issued for high and low voltage products if parts of selected type tests have been passed; those shall be carried out in full compliance with the relevant standards but (for high voltage products) do not fulfill all STL requirements for issuing a Type Test Certificate. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Test Report

Issued for all other tests on high and low voltage products which have been carried out according to specifications, standards and/or client instructions

On-Site Test Record

Issued as a record of results acquired during the on-site tests / measurements

Test Award

Can be additionally issued for all named types of test documents above if the tests to be referenced were passed

page	test date	content
5	September 27, 2017	Test object characteristics
6	September 28, 2017	Photo of the test sample
7	September 28, 2017	Reference standard
7	September 28, 2017	Test carried out
7	September 28, 2017	Test object identification
8	September 28, 2017	Test procedure
9 to 10	September 28, 2017	Lightning impulse residual voltage test
11	September 28, 2017	Steep current impulse residual voltage test (measurement of inductive error)
12	September 28, 2017	Steep current impulse residual voltage test
from page 13 to 14		Technical data
		PAGES ANNEXED:
		Oscillograms no. 13 pages
		Client's drawing - CESI no. B7020387 no. 1 page



A1001G

Tests witnessed by:

Identification of the object: Requested
 The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.
 These drawing, identified by CESI and numbered B7020387 No. 1, is annexed to this document.

ВЕРНО С ОРИГИНАЛОМ

The reported expanded uncertainties are determined in accordance with the Publication JCGM 100 "Evaluation of measurement data - Guide to the expression of uncertainty in measurement" and are based on a standard uncertainty multiplied by a coverage factor K=2, which for a normal distribution provides a level of confidence of approximately 95%

- Voltage a.c. : ± 3,0%
- Residual peak voltage (impulse tests) : ± 3,0%
- Current a.c. : ± 3,0%
- Peak current (impulse tests) : ± 3,0%
- Time (impulse tests) : ± 10,0%
- Time (a.c. tests) : ± 1,5%

September 2017
 CESI - Via Rubattino 54 - Milan
 Mr. L. Podavitte, Mr. I. Guacci
 P177 (Surge Arrester laboratory)
 7006781

ACCREDITIA S.p.A.

LABORATORY INFORMATION
 Receipt date of the sample
 Test location
 CESI testing team
 Test laboratory
 ODV SAP

A1001G

Test object characteristics (assigned by the client)

Manufacturer's name	Joint-Stock Company "Polymer-Apparat"
Arrester class	Distribution
Designation	DH
MO resistor type	B34/30
Drawing code	PA.VAR.0400.30
Nominal discharge current - [kA]	10,0
Maximum residual voltage at 10 kA - [kV]	14,36
Reference current - I_{ref} [mA]	1,0
Repetitive charge transfer rating - Q_{ref} [C]	0,4
Flat surface area [cm ²]	10,52
Rated frequency - [Hz]	48-62
Year of manufacture	February 2017

geometrical characteristics measured on MO resistor

Total height [mm]	31,1 mm
Diameter [mm]	36,6 mm

Photograph of the test objects




Photo no. 1

MO resistors type B34/30

ВЯРВА С
ОРИГИНАЛА



A11760

[Handwritten signature]



A12670

[Handwritten signature]



A12670

Reference Standard


The test was carried out according to the IEC 60099-4 – Edition 3.0 (2014-06) – Clause 8.5
 "Metal-oxide surge arresters without gaps for a.c. system"

Test carried out	Number of sample tested
Lightning impulse residual voltage test	3
Sleep current impulse residual voltage test	

Test object identification

Test object name	Identification of test sample (given by CESI)	Lot number and /s/n of the test sample (given by JSC "Polymer Apparat")
MO resistors type B3450	RV1	702.378b – 36
	RV2	702.378b – 86
	RV3	702.378b – 43

**ВЯРНО С
ОРИГИНАЛА**



A1265TG

A1265TG

Test procedure

The following tests have been carried out on the same three samples:

- a) **Lightning impulse residual voltage test**
 - wave-shape 8/20 μs
 - peak current $0.5I_{Ln} = 5.0 \text{ kA}$ - $I_n = 10.0 \text{ kA}$ & $2xI_n = 20.0 \text{ kA}$
- b) **Sleep current impulse residual voltage test**
 - wave-shape front time equal to 1 μs, tail time less than 20 μs
 - peak current $I_n = 10 \text{ kA}$

- note


Correction of the inductive error
 The inductive error was determined replacing the surge arrester section with a metal part having the same dimensions and measuring the voltage across the metal part in this condition.
 Being the inductive error (peak value) in the range 2% to 20% of the measured residual voltage (peak value) the correction was applied by subtracting the impulse voltage shape measured on the surge arrester section and the impulse voltage shape on the metal part.

Test result

See relevant pages.

[Handwritten signature]





Handwritten signature

Residual voltage tests

Lightning impulse residual voltage test.

Test circuit: A0120
Ambient temperature 22°C

Date: September 27, 2017

Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μs	Discharge current kA	Residual voltage kV	Lightning impulse protection level kV
RV1	$0.5 \times I_n$	18.4	7	8.4/18.4	5.09	13.21	14.32
	I_n	24.2	1	8.5/18.2	10.12	14.32	
	$2.0 \times I_n$	36.0	4	8.5/18.1	20.20	16.00	
	$0.5 \times I_n$	18.4	8	8.4/18.4	5.00	13.21	
RV2	I_n	24.2	2	8.5/18.2	9.99	14.19	
	$2.0 \times I_n$	36.0	5	8.5/18.1	20.14	16.01	
RV3	$0.5 \times I_n$	18.4	9	8.4/18.4	4.97	13.22	
	I_n	24.4	3	8.5/18.2	10.11	14.31	
	$2.0 \times I_n$	36.0	6	8.5/18.1	20.10	16.02	

Notes:

ВЯРНО С
ОРИГИНАЛА



Handwritten signature

Residual voltage tests

Step current impulse residual voltage test.

Measurement of the inductive error

Test circuit: A0121B

Ambient temperature : 23°C

Date: September 28, 2017

Sample	Charging voltage	Oscillogram	Current waveshape	Discharge current	Peak voltage	Inductive error
No.	kV	No.	µs	kA	V	%
aluminium block	33.3	10	1,0/2,2	10,18	270,0	< 2 (1)

Notes: (1) correction is not required

**ВЯРНО С
ОРИГИНАЛА**



[Handwritten signature]



Residual voltage tests

Step current impulse residual voltage test.

Test circuit: A0121B

Ambient temperature : 23°C


Date: September 28, 2017

Sample	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage	Step current impulse protection level
No.	kV	No.	µs	kA	kV	kV
RV1	33,3	11	1,0/2,2	9,95	15,33	15,47
RV2	33,3	12		9,95	15,40	
RV3	33,4	13		9,95	15,47	


Notes:

[Handwritten signature]






- Circuit A0121B**
- Impulse generator**
- No. of stages 1
 - Cg 0,500 μF
 - S - Spark-gap
- Voltage measuring system.**
- D - Voltage divider SAGI; CESI No.11120
 - Electro optical system type HBM CESI No. 57986(Rx) - 57991 (Tx)
 - OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1051/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.2)
- Current measuring system**
- Sh - Current Pearson CESI No.8252; 0.01 V x A
 - Electro optical system HBM CESI No. 57986(Rx) - 57987 (Tx)
 - OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1051/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.1)
- SOFTWARE SYSTEM:**
- SW - S.A.D. Surge arrester version 2.0



- Circuit A0120**
- Impulse generator**
- No. of stages 1
 - Cg 6,64 μF
 - 6 μH
 - S - Spark-gap
- Voltage measuring system.**
- D - Voltage divider SAGI; CESI No.11120
 - Electro optical system type HBM CESI No. 57986(Rx) - 57991 (Tx)
 - OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1051/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.2)
- Current measuring system**
- Sh - Current shunt CESI No.6042; R= 1,98 mΩ; peak current= 250 kA
 - Electro optical system HBM CESI No. 57986(Rx) - 57987 (Tx)
 - OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1051/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.1)
- SOFTWARE SYSTEM:**
- SW - S.A.D. Surge arrester version 2.0




Handwritten signature and a large circular stamp. The stamp contains the text 'ТОП' at the top, 'НИИ ЭЛЕКТРИКИ' around the perimeter, and 'SOFTWARE SYSTEM' in the center. There is also a handwritten '202' at the bottom right of the page.



[Handwritten signature]

СЭСІ В7019592 Oscillogram n. 2




[Handwritten signature]

[Handwritten signature]

СЭСІ В7019592 Oscillogram n. 1


ВЯРНО С
ОРИГІНАЛА





CESI B7019592 Oscillogram n. 4


[Handwritten signature]




CESI B7019592 Oscillogram n. 3

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА





CESI B7019592 Oscillogram n. 6

[Handwritten signature]





CESI B7019592 Oscillogram n. 5

[Handwritten signature]

[Handwritten signature]


**ВЕРНО С
ОРИГИНАЛОМ**





[Handwritten signature]


СЕСІ В7019592 Oscillogram n. 8




[Handwritten signature]

СЕСІ В7019592 Oscillogram n. 7


**ВЯРНО С
ОРИГІНАЛА**





CESI B7019592 Oscillogram n. 10


[Handwritten signature]




CESI B7019592 Oscillogram n. 9


[Handwritten signature]

ВЯРНО Е
ОРИГИНАЛ






СЭС1 В7019592 Oscillogram n. 12



СЭС1 В7019592 Oscillogram n. 11


ВЕРНО
ОРИГИНАЛ




Умк		Умк	
Нижний		Умк	
L-корпус		Умк	
Проб.		Умк	
Разоб.		Умк	
Изн. Лист		Умк	
Изн. Лист		Умк	
Изн. Лист		Умк	
Изн. Лист		Умк	
Изн. Лист		Умк	
Изн. Лист		Умк	
Изн. Лист		Умк	

Изд. № 10/81
Подл. и дата
Взам. инв. №
Инв. № дубл.
Подл. и дата


PA.VAR.0400.30



PA.VAR.0400.30



ВЯРНЕ
ОРИГИНАЛ



Handwritten signature

Test Report

Document No.	B7018719	Copy No.	1	Number of pages	111
Apparatus	Metal-oxide resistors type B34/30				
Designation	---				
Serial Number	---				
Manufacturer	Joint-Stock Company "Polymer-Apparat"				
Client	Joint-Stock Company "Polymer-Apparat" Ak. Kostandina Strasse 1 195427 Saint Petersburg - Russia Federation				
Tests for	---				
Date(s) of tests	September 19-21, 2017				
Tested by	CESI S.p.A. Via Rubattino, 54 20134 Milano - Italy				
Test performed	Test to verify the repetitive charge transfer rating, Qm				

HAD CONFIDENTIAL (ANSI/ISO) - CONFIDENTIAL IEC

The apparatus constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with IEC 60099-4 - Edition 3.0 (2014-05)

The results shown in the report of proving tests and the package attached herein. The entries signed by the Manufacturer are based on the IEC 60099-4.

Date: November 10, 2017

The Issuance covers the valid version of the standards of the IEC/IEC 1975:2004 "Manual Test Methods for the Comparison of Testing of Calibration Laboratories". This is the latest edition of the specification and the list of accredited labs may be obtained to the IEC web site www.iec.ch

Notes

STL-Member

CESI Group members are founder members of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in 1999. STL is a forum for voluntary international cooperation of testing organizations.

CESI Group Test Documents description

Type Test Certificate of

Issued for type tests of high voltage products (> 1 kV_a; > 1,5 kV_a), which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. The Type Test Certificate consists of documents unequivocally identifying the test object and describes all conditions under which the tests were conducted. It gives evidence of the unobjectionable behavior of the test object during the tests in line with the normative documents applied as well as of the results of successful testing.

Test Certificate of (complete / selected) Type Tests

Issued if type tests of low voltage products (< 1 kV_a; < 1,5 kV_a) requested by the relevant product standard were passed. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Certificate of Design Verification

Issued for passed design verification tests according to IEC 61439. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Type Test Report

Issued for high and low voltage products if parts of selected type tests have been passed; those shall be carried out in full compliance with the relevant standards but (for high voltage products) do not fulfill all STL requirements for issuing a Type Test Certificate. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Test Report

Issued for all other tests on high and low voltage products which have been carried out according to specifications, standards and/or client instructions

On-Site Test Record

Issued as a record of results acquired during the on-site tests / measurements

Test Award

Can be additionally issued for all named types of test documents above if the tests to be referenced were passed

Test Report



B7018719

Approved Page 3

Tests witnessed by:
Mr. Aston Potapov
Mr. Alexander Kotyubex

Joint-Stock Company "Polymer-Apparat"
Joint-Stock Company "Polymer-Apparat"

Identification of the object: Requested
The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.
These drawing, identified by CESI and numbered B7020387 No. 1, is annexed to this document.

Test evaluation
With reference to the Standards/Specifications listed in the first page and the characteristics of the tested sample assigned by manufacturer, the carried out tests passed SUCCESSFULLY.

- Voltage a.c. : ± 3,0%
- Residual peak voltage (impulse tests) : ± 3,0%
- Current a.c. : ± 3,0%
- Peak current (impulse tests) : ± 3,0%
- Time (impulse tests) : ± 10,0%
- Time (a.c. tests) : ± 1,5%

Laboratory information
Receipt date of the sample: September 2017
Test location: CESI - Via Rubattino 54 - Milan
CESI testing team: Mr. L. Podavice, Mr. I. Gucci
Test laboratory: P177 (Surge Arrester Laboratory)
ODV SAP: 70006781



page n°	test date
5	September 19, 2017
6	September 19, 2017
7	September 19, 2017
7	September 19, 2017
7	September 19, 2017
8	September 21, 2017
9	September 21, 2017
10	September 21, 2017
11 to 12	September 21, 2017
13 to 24	September 21, 2017
25 to 26	September 21, 2017
27	September 21, 2017
28	September 21, 2017

from page 29 to 30

Test object characteristics
Photographs of the test samples
References simulated
Test carried out
Test object identification
Test procedures
Summary of the test result
Residual voltage test at nominal discharge current
Reference voltage test before the test
Application of 1,1 Unom Qm
Reference voltage (laboratory-based)
Residual voltage test at nominal discharge current
Withstand capability
Reference test circuit
Date: 10/10/2017
Time: 10:00
Signature: CESI P177-001-1
Drawing: CESI P177-001-1

B7018719 Page 4
Approved
CESI
Test Report

Test object characteristics (assigned by the client)

Manufacturer's name	Joint-Stock Company "Polymer-Apparat"
Arrester class	Distribution
Designation	DH
MO resistor type	B34/30
Drawing code	PA.VAR.0400.30
Nominal discharge current - [kA]	10,0
Maximum residual voltage at 10 kA - [kV]	14,35
Reference current - I_{ref} [mA]	1,0
Repetitive charge transfer rating - Q_{rc} [C]	0,4
Rat surface area [cm ²]	10,52
Rated frequency - [Hz]	48±62
Year of manufacture	February 2017

geometrical characteristics measured on MO resistor

Total height [mm]	31,1 mm
Diameter [mm]	36,6 mm

Photograph of the test object




Photo no. 1

Metal-oxide resistor type B34/30

A112530



A12530



Reference Standard

The test was carried out according to the IEC 60099-4 - Edition 3.0 (2014-06) - Clause 8.5

"Metal-oxide surge arresters without gaps for a.c. system"

Test carried out

Test carried out	Number of sample tested
Test to verify the repetitive charge transfer rating, Q_{rc}	10

Test object identification

Test object name	Identification of the test sample (given by CESI)	Lot number and A/n of the test sample (given by JSC "Polymer-Apparat")
Metal-oxide resistors type B34/30	RCT 1	702.378b - 30
	RCT 2	702.378b - 65
	RCT 3	702.378b - 47
	RCT 4	702.378b - 62
	RCT 5	702.378b - 87
	RCT 6	702.378b - 50
	RCT 7	702.378b - 78
	RCT 8	702.378b - 68
	RCT 9	702.378b - 22
	RCT 10	702.378b - 59

Test procedure

The test consisted of the following steps:

- Measurement of the lightning impulse residual voltage at the nominal discharge current.
- Measurement of the power frequency reference voltage at the reference current.
- Calculation of the corrected values of Q_{rc} associated to each test sample according to clause 7.3.1 of the reference standard.
- Application of twenty lightning impulses 8/20 μ s delivered in ten groups of two operations each. The interval between consecutive impulses of the same group has been about 60 seconds. Between different groups the samples have been let to cool down to near ambient temperature.
- Measurement of the power frequency reference voltage at the reference current for comparison with initial value.
- Measurement of the lightning impulse residual voltage at the nominal discharge current for comparison with initial value.
- Application of a current impulse 8/20 μ s of an amplitude resulting in a current density of 0,5 kA/cm².
- Visual inspection.

Test result

The first test sequence has been performed on 10 MO resistors without any failure. The variation of the reference voltage at the reference current measured before and after the test was less than 5% (the maximum allowed variation according to reference standard is 5%). The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%). After final application of a current impulse 8/20 μ s no mechanical damage has been revealed by visual inspection. The acceptance criteria are fulfilled and therefore the test result is positive. The assigned repetitive charge transfer rating Q_{rc} , equal to 0,4 C is proved.

A12530



ВЕРНО С
СТРАЖИЦА



Summary of test results

Variation of residual voltage at the nominal discharge current

Table with 6 columns: sample, discharge current (kA), discharge voltage (kV) before and after test, and variation (%). Rows include RCT 1 through RCT 10.

Variation of the reference voltage at the reference current

Table with 4 columns: sample, reference voltage (kV) before and after test, and variation (%). Rows include RCT 1 through RCT 10.

Withstand capability to one ESD (20 μs current) level of at least 0.5 kA (peak current density) after the test

Table with 4 columns: sample, discharge current (kA), discharge voltage (kV), and Note. Note indicates 'no mechanical damage' for all samples.



A114183

Test to verify the repetitive charge transfer rating, Qrs.

Residual voltage test at nominal discharge current before the test.

Test circuit: A0120

Date: September 19, 2017

Table with 7 columns: Sample No., Requested current (kA), Charging Voltage (kV), Oscillogram No., Current waveshape (μs), Discharge current (kA), and Residual voltage (kV). Rows include RCT 1 through RCT 10.

Notes:



A114183

Test to verify the repetitive charge transfer rating, Qrs.

Reference voltage test at reference current before the test.

Test circuit: A0019

Date: September 19, 2017
Ambient temperature: 23 °C

Table for Sample No. RCT 1 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.

Table for Sample No. RCT 2 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.

Table for Sample No. RCT 3 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.

Table for Sample No. RCT 4 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.

Table for Sample No. RCT 5 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.



A115932

continued

Date: September 19, 2017

Table for Sample No. RCT 6 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.

Table for Sample No. RCT 7 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.

Table for Sample No. RCT 8 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.

Table for Sample No. RCT 9 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.

Table for Sample No. RCT 10 with columns: oscillogram No., voltage (kV), current (+mAref, -mAref, mAref), power (W), and note.



ВЯРНО С
ОРИГИНАЛА



A117930

245

Test to verify the repetitive charge transfer rating, Qrs.

Date: September 19, 2017

Residual voltage correction factor and Q_{rs} calculation

Sample No.	U _m [1] kV	Length [2] mm	U _{m, max} [3] kV/mm	Max U _{m, max} [4] kV/mm	0,97 x Max U _{m, max} [5] kV/mm	Correction factor [6]	Q _{rs} rating [7] C	Corrected Q _{rs} [8] C	Applicable range for Q _{rs} [9] C
RC1	14,11	30,92	0,456	0,459	0,455	1	0,4	0,44±0,48	0,44±0,48
RC2	14,12	30,91	0,457			1	0,4	0,44±0,48	
RC3	14,07	30,91	0,455			1	0,4	0,44±0,48	
RC4	14,15	30,89	0,458			1	0,4	0,44±0,48	
RC5	14,15	30,80	0,452			1	0,4	0,44±0,48	
RC6	14,11	30,62	0,451			1	0,4	0,44±0,48	
RC7	14,15	30,61	0,452			1	0,4	0,44±0,48	
RC8	14,21	30,64	0,454			1	0,4	0,44±0,48	
RC9	14,25	30,87	0,453			1	0,4	0,44±0,48	
RC10	14,35	30,87	0,455			1	0,4	0,44±0,48	

- [1] U_m: residual voltage at 10 kA measured on each sample
- [2] Length: length measured on each sample
- [3] U_{m, max}: residual voltage stress calculated for each sample [3] = [1] / [2]
- [4] Max U_{m, max}: Max residual voltage stress claimed by the manufacturer for the size and/or design (Maximum residual voltage at 10 kA / minimal thickness h)
- [5] 0,97 x Max U_{m, max}: Lowest limit of the residual voltage stress without applying any correction factor
- [6] Correction factor: Correction factor is calculated for each sample
 - no correction factor applied if the [3] ≥ [5]
 - correction factor applied if the [3] < [5]
- [7] Q_{rs} rating: charge transfer rating selected from the list on the Reference Standard clause 8.5.4 by the manufacturer
- [8] corrected Q_{rs}: [8] = [7] x [6]
- [9] Applicable range for Q_{rs}: the lower value is calculated as 1,1 times [8]; the higher value of the range is calculated as 1,2 times [8]

Note:
 Max U_{m, max} declared by the manufacturer: 14,36 kV
 Diameter Ø: 30,6 mm
 Min. Thickness h declared by the manufacturer: 30,6 mm

A11493



Test configuration for application of 1,1 times Q_{rs}




Photo no. 2




Photo no. 3

A11490




Test to verify the repetitive charge transfer rating, Qrs.

Application of twenty operations in ten groups of two lightning current impulse 8/20µs.

Test circuit: A0120

Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C
RCT 1	1	54,0 x 2	21	31,10	0,44
	2	54,0 x 2		31,20	0,44
	3	55,0 x 2	31	32,10	0,45
	4	55,0 x 2		31,20	0,44
	5	55,0 x 2	31	31,80	0,45
	6	55,0 x 2		31,95	0,45
	7	55,0 x 2	31	31,40	0,44
	8	55,0 x 2		31,30	0,44
	9	55,0 x 2	31	32,60	0,45
	10	55,0 x 2		32,30	0,45
	11	55,0 x 2	41	32,50	0,45
	12	55,0 x 2		32,40	0,45
	13	55,0 x 2	41	32,40	0,45
	14	55,0 x 2		32,40	0,45
	15	55,0 x 2	41	32,30	0,45
	16	55,0 x 2		32,30	0,45
	17	55,0 x 2	41	31,90	0,45
	18	55,0 x 2		31,50	0,45
	19	55,0 x 2	41	31,70	0,45
	20	55,0 x 2		31,60	0,45



Note:

[Handwritten signature]

A11490




ВАРНО С
ОРИГИНАЛА

continued

Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C
RCT 2	1	55,0 x 2	22	32,20	0,45
	2	55,0 x 2		32,70	0,45
	3	55,0 x 2	32	32,40	0,45
	4	55,0 x 2		31,20	0,44
	5	55,0 x 2	32	31,80	0,45
	6	55,0 x 2		32,13	0,45
	7	55,0 x 2	32	31,80	0,44
	8	55,0 x 2		32,20	0,45
	9	55,0 x 2	32	33,10	0,46
	10	55,0 x 2		32,80	0,46
	11	55,0 x 2	42	32,30	0,45
	12	55,0 x 2		32,50	0,45
	13	55,0 x 2	42	33,00	0,46
	14	55,0 x 2		32,70	0,46
	15	55,0 x 2	42	33,00	0,46
	16	55,0 x 2		32,57	0,45
	17	55,0 x 2	42	32,20	0,45
	18	55,0 x 2		32,80	0,46
	19	55,0 x 2	42	32,10	0,45
	20	55,0 x 2		31,94	0,45



Notes:



continued



continued
Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C
RCT 3	1	55.0 x 2		32.62	0.45
	2	55.0 x 2	23	32.64	0.45
	3	55.0 x 2		32.60	0.45
	4	55.0 x 2		31.70	0.45
	5	55.0 x 2		32.30	0.45
	6	55.0 x 2		31.70	0.44
	7	55.0 x 2		32.35	0.45
	8	55.0 x 2		32.45	0.45
	9	55.0 x 2		33.36	0.45
	10	55.0 x 2	33	33.10	0.45
	11	55.0 x 2		33.00	0.45
	12	55.0 x 2		32.50	0.45
	13	55.0 x 2		33.20	0.45
	14	55.0 x 2		31.95	0.45
	15	55.0 x 2		32.85	0.45
	16	55.0 x 2		32.90	0.45
	17	55.0 x 2		32.33	0.45
	18	55.0 x 2		31.80	0.45
	19	55.0 x 2		32.20	0.45
	20	55.0 x 2	43	32.10	0.45

Current impulse waveshape
8,7/18,0 μs

Notes:

continued

A133493



continued
Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C
RCT 4	1	55.0 x 2		32.71	0.45
	2	55.0 x 2	24	32.70	0.45
	3	55.0 x 2		33.30	0.45
	4	55.0 x 2		33.21	0.45
	5	55.0 x 2		32.72	0.45
	6	55.0 x 2		32.74	0.45
	7	55.0 x 2		32.30	0.45
	8	55.0 x 2		33.30	0.45
	9	55.0 x 2		33.35	0.45
	10	55.0 x 2	34	33.24	0.45
	11	55.0 x 2		33.20	0.45
	12	55.0 x 2		32.70	0.45
	13	55.0 x 2		33.20	0.45
	14	55.0 x 2		33.24	0.45
	15	55.0 x 2		33.20	0.45
	16	55.0 x 2		32.70	0.45
	17	55.0 x 2		32.40	0.45
	18	55.0 x 2		32.61	0.45
	19	55.0 x 2		32.60	0.45
	20	55.0 x 2	44	32.33	0.45

Current impulse waveshape
8,7/18,0 μs

Notes:

continued

A133503



continued
Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C
RCT 5	1	55.0 x 2		33.38	0.45
	2	55.0 x 2	25	33.40	0.45
	3	55.0 x 2		33.22	0.45
	4	55.0 x 2		33.20	0.45
	5	55.0 x 2		33.50	0.45
	6	55.0 x 2		32.60	0.45
	7	55.0 x 2		33.50	0.47
	8	55.0 x 2		33.02	0.45
	9	55.0 x 2		33.80	0.47
	10	55.0 x 2	35	32.85	0.45
	11	55.0 x 2		33.04	0.45
	12	55.0 x 2		33.60	0.45
	13	55.0 x 2		33.30	0.45
	14	55.0 x 2		33.74	0.47
	15	55.0 x 2		33.80	0.47
	16	55.0 x 2		33.40	0.45
	17	55.0 x 2		33.30	0.45
	18	55.0 x 2		33.00	0.45
	19	55.0 x 2		33.09	0.45
	20	55.0 x 2	45	32.80	0.45

Current impulse waveshape
8,7/18,0 μs

Notes:

continued

A133503




continued
Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C
RCT 6	1	55.0 x 2		33.80	0.47
	2	55.0 x 2	26	33.00	0.45
	3	55.0 x 2		32.50	0.45
	4	55.0 x 2		33.29	0.45
	5	55.0 x 2		33.55	0.47
	6	55.0 x 2		33.25	0.45
	7	55.0 x 2		33.50	0.45
	8	55.0 x 2		33.20	0.45
	9	55.0 x 2		33.72	0.47
	10	55.0 x 2	36	33.70	0.47
	11	55.0 x 2		33.35	0.45
	12	55.0 x 2		33.40	0.45
	13	55.0 x 2		33.70	0.47
	14	55.0 x 2		33.74	0.47
	15	55.0 x 2		33.71	0.47
	16	55.0 x 2		33.65	0.47
	17	55.0 x 2		33.50	0.45
	18	55.0 x 2		33.80	0.45
	19	55.0 x 2		33.40	0.45
	20	55.0 x 2	46	33.50	0.45

Current impulse waveshape
8,7/18,0 μs


Notes:



21-

continued
Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C
RCT 7	1	55.0 x 2	27	33.94	0.47
	2	55.0 x 2		32.92	0.45
	3	55.0 x 2		33.20	0.45
	4	55.0 x 2		33.50	0.47
	5	55.0 x 2		33.61	0.47
	6	55.0 x 2		33.70	0.47
	7	55.0 x 2		34.30	0.47
	8	55.0 x 2	33.80	0.47	
	9	55.0 x 2	33.61	0.47	
	10	55.0 x 2	37	33.70	0.47
	11	55.0 x 2	33.50	0.45	
	12	55.0 x 2	33.70	0.45	
	13	55.0 x 2	33.50	0.47	
	14	55.0 x 2	33.66	0.47	
	15	55.0 x 2	33.75	0.47	
	16	55.0 x 2	33.50	0.47	
	17	55.0 x 2	33.47	0.47	
	18	55.0 x 2	33.30	0.45	
	19	55.0 x 2	33.50	0.47	
	20	55.0 x 2	47	33.15	0.45



Notes:


continued



A133793

continued
Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C
RCT 8	1	55.0 x 2	28	34.00	0.47
	2	55.0 x 2		33.50	0.45
	3	55.0 x 2		33.40	0.45
	4	55.0 x 2		32.65	0.45
	5	55.0 x 2		33.21	0.45
	6	55.0 x 2		33.30	0.45
	7	55.0 x 2		33.41	0.45
	8	55.0 x 2		32.50	0.45
	9	55.0 x 2		32.97	0.45
	10	55.0 x 2		38	33.10
	11	55.0 x 2	33.33	0.45	
	12	55.0 x 2	33.60	0.45	
	13	55.0 x 2	33.40	0.45	
	14	55.0 x 2	33.28	0.45	
	15	55.0 x 2	33.00	0.45	
	16	55.0 x 2	32.50	0.45	
	17	55.0 x 2	31.65	0.45	
	18	55.0 x 2	32.80	0.45	
	19	55.0 x 2	33.50	0.45	
	20	55.0 x 2	48	32.70	0.45



Notes:


continued



A133710

continued
Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C
RCT 9	1	55.0 x 2	29	31.80	0.44
	2	55.0 x 2		32.00	0.44
	3	55.0 x 2		31.50	0.44
	4	55.0 x 2		33.11	0.45
	5	55.0 x 2		31.50	0.44
	6	55.0 x 2		31.55	0.44
	7	55.0 x 2		31.94	0.44
	8	55.0 x 2		31.90	0.44
	9	55.0 x 2		31.30	0.44
	10	55.0 x 2	39	32.10	0.45
	11	55.0 x 2	32.10	0.45	
	12	55.0 x 2	32.00	0.44	
	13	55.0 x 2	31.60	0.44	
	14	55.0 x 2	31.65	0.44	
	15	55.0 x 2	31.40	0.44	
	16	55.0 x 2	31.60	0.44	
	17	55.0 x 2	31.60	0.44	
	18	55.0 x 2	31.30	0.44	
	19	55.0 x 2	31.50	0.44	
	20	55.0 x 2	49	31.10	0.44



Notes:


continued



A114330


continued
Date: September 19-21, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Peak current kA	Charge C	
RCT 10	1	55.0 x 2	30	31.60	0.44	
	2	55.0 x 2		31.70	0.44	
	3	55.0 x 2		31.50	0.44	
	4	55.0 x 2		31.70	0.44	
	5	55.0 x 2		31.30	0.44	
	6	55.0 x 2		31.35	0.44	
	7	55.0 x 2		32.00	0.45	
	8	55.0 x 2		32.40	0.45	
	9	55.0 x 2		32.00	0.45	
	10	55.0 x 2		40	31.55	0.45
	11	55.0 x 2		31.60	0.44	
	12	55.0 x 2		31.80	0.44	
	13	55.0 x 2		31.30	0.44	
	14	55.0 x 2		31.70	0.44	
	15	55.0 x 2	31.30	0.44		
	16	55.0 x 2	31.50	0.44		
	17	55.0 x 2	31.10	0.44		
	18	55.0 x 2	31.30	0.44		
	19	55.0 x 2	31.10	0.44		
	20	55.0 x 2	50	31.00	0.44	



Notes:

**ВЯРНО С
ОРИГИНАЛА**



A117533

Test to verify the repetitive charge transfer rating, Qrs.

Reference voltage test at reference current after the test.

Test circuit: A0019

Date: September 21, 2017
Ambient temperature: 23 °C

Sample No. RC 1						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
51	5,34	0,633	1,000	0,532	1,24	---

Sample No. RC 2						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
52	5,22	0,572	1,000	0,510	1,11	---

Sample No. RC 3						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
53	5,32	0,578	1,000	0,510	1,11	---

Sample No. RC 4						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
54	5,26	0,579	1,000	0,508	1,09	---

Sample No. RC 5						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
55	5,28	0,582	1,000	0,514	1,14	---

continued

Date: September 21, 2017

Sample No. RC 6						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
56	5,24	0,572	1,000	0,507	1,09	---

Sample No. RC 7						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
57	5,33	0,573	1,000	0,506	1,09	---

Sample No. RC 8						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
58	5,28	0,577	1,000	0,512	1,14	---

Sample No. RC 9						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
59	5,31	0,588	1,000	0,525	1,18	---

Sample No. RC 10						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	note
60	5,31	0,580	1,000	0,508	1,11	---



Test to verify the repetitive charge transfer rating, Qrs.

Residual voltage test at nominal discharge current after the test.

Test circuit: A0120

Date: September 21, 2017

Sample No.	Requested current kA	Charging Voltage kV	Oscillogram No.	Current waveshape μs	Discharge current kA	Residual voltage kV
RC 1	10,0	24,6	61	8,9/18,1	10,03	14,38
RC 2		24,6	62		10,00	14,36
RC 3		24,6	63		10,09	14,42
RC 4		24,6	64		9,95	14,41
RC 5		24,6	65		10,06	14,34
RC 6		24,6	66		10,11	14,38
RC 7		24,6	67		10,01	14,44
RC 8		24,5	68		9,98	14,40
RC 9		24,5	69		9,95	14,43
RC 10		24,5	70		10,00	14,49

Notes:



ВЯРНО С
ОРИГИНАЛА

Test to verify the repetitive charge transfer rating, Qrs.

Final application of a current impulse 8/20 μs (withstand capability)

Test circuit: A0120

Date: September 21, 2017

Sample No.	Requested current kA	Charging Voltage kV	Oscillogram No.	Current waveshape μs	Discharge current kA	Discharge voltage kV
RC 1	5,14 (*)	19,0	71	8,3/19,0	5,41	13,40
RC 2					5,36	13,39
RC 3					5,33	13,33
RC 4					5,21	13,42
RC 5					5,37	13,39
RC 6					5,38	13,39
RC 7					5,31	13,54
RC 8					5,85	13,40
RC 9					5,41	13,45
RC 10					5,38	13,47


Notes:

- Requested current = 0,5 kA/cm² × 10,28 cm² = 5,14 kA
- (*) where 0,5 kA/cm² is peak current density
- where 10,28 cm² is surface area on the metal-oxide resistor used for this test declared by the manufacturer



21

Circuit A0019



Power frequency supply

- RE - programmable supply type PACIFIC A.C. Power Source 140 ASX; CESI no. 0560408
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO, power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI No.31120; R=941,4 Ω
- Electro optical system HBM CESI No. 57986(Rx) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.1)


Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system type HBM CESI No. 57986(Rx) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.2)

Software systems

- SW - S.A.D. Surge arrester version 2.0

Circuit A0120



Impulse generator

- No. of stages - 1 (for residual voltage at nominal current)
- 2 (for injection of Qm)
- Cg - 6,64 μF (n.1 stage)
- 3,32 μF (n.2 stage)
- Lc - 12 μH (n.1 stage) - 20 μH (n.2 stages)

S - Spark-gap

Additional two MO block have been added (for injection of Qm)

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system HBM CESI No. 57986(Rx) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R=2 mΩ; peak current=250 kA
- Electro optical system type HBM CESI No. 57986(Rx) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.1)


Software systems

- SW - S.A.D. Surge arrester version 2.0


ACCREDITED



A13013 rev.2





CESI B7018719 Oscillogram n. 1




CESI B7018719 Oscillogram n. 2

ВЯРНО С
ОРИГИНАЛ







CESI B7018719 Oscillogram n. 3



CESI B7018719 Oscillogram n. 4





CESI B7018719 Oscillogram n. 5




CESI B7018719 Oscillogram n. 6

ВЯРНО С
ОРИГИНАЛА







CESI B7018719 Oscillogram n. 7



CESI B7018719 Oscillogram n. 8




CESI B7018718 Oscillogram n. 9




CESI B7018719 Oscillogram n. 10

ВЯРНО С
ОРИГИНАЛОМ







CESI B7018719 Oscillogram n. 11



CESI B7018719 Oscillogram n. 12





CESI B7018719 Oscillogram n. 13




CESI B7018719 Oscillogram n. 14

**ВЯРНО С
ОРИГИНАЛА**







CESI B7018719 Oscillogram n. 15



CESI B7018719 Oscillogram n. 16



CESI B7018719 Oscillogram n. 17





CESI B7018719 Oscillogram n. 18

[Handwritten signature]


[Handwritten signature]

**ВЯРЮ С
ОРИГИНАЛО**







CESI B7018719 Oscillogram n. 19



CESI B7018719 Oscillogram n. 20





CESI B7018719 Oscillogram n. 21




CESI B7018719 Oscillogram n. 22

ВЯРНО С
ОРИГИНАЛА







CESI B7018719 Oscillogram n. 23



CESI B7018719 Oscillogram n. 24




CESI B7018719 Oscillogram n. 25




CESI B7018719 Oscillogram n. 26

ВЯРНО С
ОРИГИНАЛА







CESI B7018719 Oscillogram n. 27



CESI B7018719 Oscillogram n. 28




CESI B7018719 Oscillogram n. 29




CESI B7018719 Oscillogram n. 30

ВЯРНО С
ОРИГИНАЛА







CESI B7018719 Oscillogram n. 31



CESI B7018719 Oscillogram n. 32





CESI B7018719 Oscillogram n. 33




CESI B7018719 Oscillogram n. 34

ВЯРНО С
ОРИГИНАЛА







CESI B7018719 Oscillogram n. 35



CESI B7018719 Oscillogram n. 36




CESI B7018719 Oscillogram n. 37




CESI B7018719 Oscillogram n. 38

ВЕРНО
ОРИГИНАЛ







CESI B7018719 Oscillogram n. 39



CESI B7018719 Oscillogram n. 40





CESI B7018719 Oscillogram n. 41




CESI B7018719 Oscillogram n. 42

ВЯРНО С
ОРИГИНАЛА







CESI B7018719 Oscillogram n. 43



CESI B7018719 Oscillogram n. 44





CESI B7018719 Oscillogram n. 45




CESI B7018719 Oscillogram n. 46

ВЕРНО С
ОРИГИНАЛА







CESI B7018719 Oscillogram n. 47



CESI B7018719 Oscillogram n. 48




CESI B7018719 Oscillogram n. 49




CESI B7018719 Oscillogram n. 50


Handwritten signature

**ВЕРНО С
ОРИГИНАЛА**







CESI B7018719 Oscillogram n. 51



CESI B7018719 Oscillogram n. 52





CESI B7018719 Oscillogram n. 53




CESI B7018719 Oscillogram n. 54

ВЕРНО С
ОРИГИНАЛА







CESI B7018719 Oscillogram n. 55



CESI B7018719 Oscillogram n. 56




CESI B7018719 Oscillogram n. 57




CESI B7018719 Oscillogram n. 58


ВЯРНО С
ОРИГИНАЛА




234




CESI B7418719 Oscillogram n. 59



CESI B7418719 Oscillogram n. 64





CESI B7418719 Oscillogram n. 61




CESI B7418719 Oscillogram n. 62

ВЕРНО С
ОРИГИНАЛОМ







CESI B7018719 Oscillogram n. 63



CESI B7018719 Oscillogram n. 64




CESI B7018719 Oscillogram n. 65




CESI B7018719 Oscillogram n. 66

ВЯРНО С
ОРИГИНАЛА







CESI B7018719 Oscillogram n. 67



CESI B7018719 Oscillogram n. 68





CESI B7018719 Oscillogram n. 69




CESI B7018719 Oscillogram n. 70

ВЕРНО С
ОРИГИНАЛА







CESIB7018719 Oscillogram n. 71



CESIB7018719 Oscillogram n. 72




CESIB7018719 Oscillogram n. 73




CESIB7018719 Oscillogram n. 74


Handwritten signature

**ВЕРНО С
ОРИГИНАЛА**







CESI B7018719 Oscillogram n. 75



CESI B7018719 Oscillogram n. 76



CESI B7018719 Oscillogram n. 77




CESI B7018719 Oscillogram n. 78

[Handwritten signature]


**ВЯРНО С
ОРИГИНАЛА**



239



CESIB7018719 Oscillogram n. 79



CESIB7018719 Oscillogram n. 80

PA.VAR.0400.30

87020307-001

ПА. VAR.0400.30

Вариант 834/50

Артикул 0400


Контракт 340

Техническое задание

1. Неисправный конденсатор (поу. акт)
2. Извлеченная паразитная емкость (без индукции катушки)
3. Извлеченное паразитное сопротивление (по индукции катушки)
4. Альтернативный типовой ИЛ - АИСТОВИ

№ п/п	№ п/п	№ п/п	№ п/п	№ п/п	№ п/п	№ п/п	№ п/п	№ п/п	№ п/п

**ВЕРНО С
ОРИГИНАЛОМ**



240

Test Report

Document No.	B7019962	Copy No.	1	Number of pages	65
Apparatus	Polymer-housed surge arrester section type PA-DM section ST with additional thermal insulation				
Designation	---				
Serial Number	---				
Manufacturer	Joint-Stock Company "Polymer-Apparat"				
Client	Joint-Stock Company "Polymer-Apparat" Ak. Kostantinova str., 1 195427 Saint-Petersburg - Russia Federation				
Tested for	---				
Date(s) of tests	October 3 - 4, 2017				
Tested by	CESI S.p.A. Via Rubattino, 54 20134 - Milano - Italy				
Test performed	Operating duty test				

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with IEC 60094-4 - Edition 3.0 (2014-06)

The results are shown in the report of proving tests of the test object stated (1) in the report assigned by the Manufacturer and listed in the Appendix (2). The responsibility for conformity of any item with the same designation with that tested here rests with the Manufacturer.

Date: November 20, 2017
 Prepared by: *[Signature]*
 Test Engineer in Charge: *[Signature]*
 Approved by: *[Signature]*
 Document Digitally Signed

For independence of the document a portion of only with the correct permission to use it is not possible.
 The authority of this document is guaranteed by the use of digital signatures.



ACCREDIA S.p.A.
Via Rubattino, 54
20134 - Milano - Italy

The laboratory meets the requirements of the Standard EN ISO/IEC 17025:2005 General Requirements for the Competence of Testing and Calibration Laboratories. The full formal scope of the accreditation and the list of technical fields can be checked in the VQR 002239 of 02/03/2015.




Trust the Power of Experience

Notes

STL-Member

CESI Group members are founder members of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in 1959. STL is a forum for voluntary international cooperation of testing organizations.

CESI Group Test Documents description

Type Test Certificate of

Issued for type tests of high voltage products (> 1 kV_a; > 1.5 kV_a), which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides v2.0 at the time of the test. The Type Test Certificate consists of documents unequivocally identifying the test object and describes all conditions under which the tests were conducted. It gives evidence of the unobjectionable behavior of the test object during the tests in line with the normative documents applied as well as of the results of successful testing.

Test Certificate of (complete / selected) Type Tests

Issued if type tests of low voltage products (< 1 kV_a; < 1.5 kV_a) requested by the relevant product standard were passed. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Certificate of Design Verification

Issued for passed design verification tests according to IEC 61439. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Type Test Report

Issued for high and low voltage products if parts of selected type tests have been passed; those shall be carried out in full compliance with the relevant standards but (for high voltage products) do not fulfill all STL requirements for issuing a Type Test Certificate. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Test Report

Issued for all other tests on high and low voltage products which have been carried out according to specifications, standards and/or client instructions

On-Site Test Record

Issued as a record of results acquired during the on-site tests / measurements

Test Award

Can be additionally issued for all named types of test documents above if the tests to be referenced were passed

Tests witnessed by:

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object. These drawing, identified by CESI and numbered B7024364 No. 1, is annexed to this document.

Test evaluation
 With reference to the Standards/Specifications listed in the first page and the characteristics of the tested sample assigned by manufacturer, the carried out tests passed SUCCESSFULLY.

The reported expanded uncertainties are determined in accordance with the Publication JCGM 100 "Evaluation of measurement data - Guide to the expression of uncertainty in measurement" and are based on a standard uncertainty multiplied by a coverage factor k = 2, which for a normal distribution provides a level of confidence of approximately 95 %.

- Voltage a.c. : ± 3,0 %
- Residual peak voltage (impulse tests) : ± 3,0 %
- Current a.c. : ± 3,0 %
- Peak current (impulse tests) : ± 3,0 %
- Time (impulse tests) : ± 10,0 %
- Time (a.c. tests) : ± 1,5 %

Laboratory Information

Receipt date of the sample: September 2017
 Test location: CESI - Via Rubattino 54 - Milan
 CESI testing team: Mr L. Podavino - Mr L. Grassi
 Test laboratory: P177
 ODYSAP: 70006781



page	test date
5	from October 3 to October 4, 2017
6	
7	
7	
7	
8	
9	
from page 10 to 18	
from page 19 to 26	

content

Technical data

Operating duty test

Summary of test result

Test procedure

Identification

Test carried out

Test object

Characteristics of the test object

Pages numbered

"EMME SERTIMAR" EOOD

Page numbered

Client's drawing (Polymer-housed surge arrester section) - CESI no. B7024364 - n.1 page

Client's drawing (GMO arrester) - CESI no. B7024364 - n.1 page

Signature: *[Signature]*

Test object characteristics (assigned by the client)

Manufacturer's name	Joint-Stock Company "Polymer-Apparat"
Polymer-housed surge arrester section type	PA-DM section ST
Drawing code	PA-DM.001.ST.02
MO-resistor supplier's	Joint-Stock Company "Polymer-Apparat"
Metal-oxide resistor type	B3490
Arrester class	Distribution
Designation	DH
Number of MO resistor filed	1
Nominal discharge current - [kA]	10
Rated voltage - U_n [kV]	$1,077 \times U_{sc}$
Continuous operating voltage - U_c [kV]	$0,851 \times U_{sc}$
Repetitive charge transfer rating - Q_n [C]	0,4
Rated thermal charge transfer rating - Q_{th} [C]	1,1
Reference current - I_{ref} [mA]	1,0
Rated frequency - [Hz]	48+62
Year of manufacture	08/2017

geometrical characteristics measured on the MO resistor

Total height [mm]	31,1 mm
Diameter [mm]	36,6 mm

A11930



Photographs of the test object




Photo no. 1




Photo no. 2

Polymer-housed surge arrester section type PA-DM section ST with additional thermal insulation

A11930



Reference Standard

IEC 60099-4 (2001406) - Edition 3.0 - Clause 10.8.7
 "Metal-oxide surge arresters without gaps for a.c. system"

Test carried out	Number of sample tested
Operating duty test	3

Test object identification

Test object name	Identification of test sample (given by CESI)	Identification of test sample (given by JSC "Polymer-Apparat")
Polymer-housed surge arrester section type PA-DM section ST with additional thermal insulation	OD1	00006
	OD2	00007
	OD3	00008

ВЯРНО С
ОРИГИНАЛА



A11930

Test procedure

1. Test performed on Polymer-housed metal-oxide surge arrester section in open air

The test procedure consisted of the following sequence:

Initial test

- a) Measurement of the lightning impulse residual voltage at the nominal discharge current
 - b) Measurement of the power frequency reference voltage at the reference current
- Conditioning
- c) Application of a high current impulse 4700 μs at 100 kA

2. Test performed on Polymer-housed metal-oxide surge arrester section assembled in thermal mode

Thermal recovery test

- d) Calculation of the voltage correction factors
 - e) The surge arrester sections were kept in an oven at the temperature of 65 °C till thermal equilibrium (not more than twenty hours)
 - f) Injection of two lightning current impulses 8/20 μs at the rated thermal charge transfer Q_{th} . A time shorter than 100 ms after the application of the second lightning current impulse energization at U_n for 10 sec. and then at U_c for 30 min. to verify the thermal stability.
- Note:
- intervals between lightning current impulses: 60 seconds
 - nominal test frequency: 50 Hz


3. Test performed on Polymer-housed metal-oxide surge arrester section in open air

- g) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value
- h) After that the sample has cooled to ambient temperature, two current impulses 8/20 μs have been applied for to check the integrity of the internal parts. The interval between impulses was 50-60 seconds.

Test result

The visual inspection of the sample after the test has revealed no sign of physical damage. The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%). Discharge current impulses the quality grade may breakdown and the variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%). The thermal recovery was a 100%.

The acceptance criteria are fulfilled and therefore the test result is positive.



A11930

247

Summary of test results

Variation of lightning impulse residual voltage at I_L

sample	before test		after test		Variation %
	discharge current kA	residual voltage kV	discharge current kA	residual voltage kV	
OD1	10,12	14,24	10,12	14,50	+1,83
OD2	10,12	14,12	10,17	14,34	+1,56
OD3	10,13	14,13	10,18	14,25	+0,85

Variation of lightning impulse residual voltage between residual voltage measurement at I_n during initial test and residual voltage measurement at I_n during last impulse

sample	before test		after test (last impulse)		Variation %
	discharge current kA	residual voltage kV	discharge current kA	residual voltage kV	
OD1	10,12	14,24	9,95	14,47	+1,60
OD1	10,12	14,12	10,05	14,35	+1,70
OD3	10,13	14,13	10,13	14,27	+0,99

Visual inspection after the test

The visual external inspection of polymer-bonded metal-oxide surge arrester section after the test has revealed no sign of physical damage

A14482



Operating duty test

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: October 3, 2017

Sample No.	Requested current kA	Charging voltage kV	Oscillogram No.	Current waveshape μs	Discharge current kA	Residual Voltage kV
OD1	L	24,6	1	8,5/18,2	10,12	14,24
OD2		24,5	2		10,12	14,12
OD3		24,5	3		10,13	14,13

Notes:

[Handwritten signature]

A11580



Operating duty test

Reference voltage test

Test circuit: A0019

Date: October 3, 2017

Sample No. OD1						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{ref}	power W	3rd harmonic amplitude μA
4	5,48	0,852	1,00	0,561	1,43	--

Sample No. OD1						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{ref}	power W	3rd harmonic amplitude μA
5	5,42	0,850	1,00	0,556	1,38	--

Sample No. OD1						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{ref}	power W	3rd harmonic amplitude μA
6	5,40	0,857	1,00	0,561	1,41	--

[Handwritten signature]

A11580



ВЯРНО С
ВАРЕМНАЛА

A11580

Operating duty test

Conditioning: Application of one 100 kA 4/10 μs high current impulses

Test circuit: A0121

Date: October 3, 2017

Sample No.	Impulse No.	Charging voltage kV	Oscillogram No.	Discharge current kA	Current waveshape μs	Opposite polarity %
OD1	1	85,0 x 2	7	101,3	4,59,2	9,0
OD1	1	85,0 x 2	8	101,4		
OD3	1	85,0 x 2	9	101,3		

Notes:

[Handwritten signature]



24.3

Operating duty test.

Voltage correction factor and thermal energy calculations

Date: October 4, 2017

Sample No.	U _{ref} [1] kV	KU ₁ [2]	KU ₂ [3]	U ₁ ' [4] kV	U ₂ ' [5] kV
OD1	5,48	1,077	0,861	5,902	4,718
OD2	5,42			5,837	4,667
OD3	5,40			5,816	4,649

- [1] U_{ref} : measured reference voltage
- [2] KU₁ : maximum guaranteed factor for calculation of U₁' = U₁/U_{ref} (declared by the Manufacturer)
- [3] KU₂ : maximum guaranteed factor for calculation of U₂' = U₂/U_{ref} (declared by the Manufacturer)
- [4] U₁' : corrected rated voltage [4] = [1] × [2]
- [5] U₂' : corrected continuous operating voltage [5] = [1] × [3]

Sample No.	U ₁ ' kV	Requested thermal charge transfer, Q _{th}		Requested Q _{th} per impulse	
		C		C	
OD1	5,902	1,1		0,55 (±10%)	
OD2	5,837			0,55 (±10%)	
OD3	5,816			0,55 (±10%)	

A12450



Operating duty test.

Application of the lightning current impulses 8/20 μs, corrected rated voltage U₁' and corrected continuous operating U₂' for evaluation of the thermal stability.

Test circuit: A0123-A0020-A0131

Sample No.: OD1

Ambient temperature: 23 °C
Preheating temperature: 66 °C

Date: October 4, 2017

Lightning current impulses 8/20 μs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q _{th} C	Applicable range for Q _{th} C
10	1	61,0 x 2	---	38,70	0,55	0,455±0,605
11	2	61,0 x 2	---	38,60	0,55	0,455±0,605

Current impulse waveshape	
μs	
8,7/18,2	

Corrected rated voltage U₁' application

Oscillogram No.	Time s	U ₁ ' kV	Current + mA ₉₀	Current - mA ₉₀
12	0	5,902	66,0	110,0
13	10		26,0	51,0

Corrected continuous operating voltage U₂' application to evaluate the thermal stability

Oscillogram No.	Time s	U ₂ ' kV	Current + mA ₉₀	Current - mA ₉₀	Power W	Temperature °C
14	0	4,718	1,08	1,60	2,10	---
	5		0,97	0,97	1,00	---
	10		0,95	0,95	0,88	---
	15		0,94	0,94	0,82	---
15	20	0,94	0,93	0,74	---	
	25	0,93	0,92	0,69	---	
	30	0,91	0,91	0,65	---	

Note 1

continued

A12450



A12450



continued

Sample No.: OD2

Ambient temperature: 23 °C
Preheating temperature: 66 °C

Date: October 4, 2017

Lightning current impulses 8/20 μs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q _{th} C	Applicable range for Q _{th} C
17	1	61,0 x 2	---	38,55	0,55	0,455±0,605
18	2	61,0 x 2	---	38,50	0,55	0,455±0,605

Current impulse waveshape	
μs	
8,7/18,2	

Corrected rated voltage U₁' application

Oscillogram No.	Time s	U ₁ ' kV	Current + mA ₉₀	Current - mA ₉₀
19	0	5,837	65,0	109,0
20	10		25,0	49,0

Corrected continuous operating voltage U₂' application to evaluate the thermal stability

Oscillogram No.	Time s	U ₂ ' kV	Current + mA ₉₀	Current - mA ₉₀	Power W	Temperature °C
21	0	4,667	1,08	1,32	2,02	---
	5		1,07	1,04	1,10	---
	10		0,89	0,98	0,99	---
	15		0,96	0,96	0,88	---
22	20	0,94	0,94	0,77	---	
	25	0,93	0,93	0,73	---	
	30	0,92	0,92	0,67	---	

Note 1

continued

A11530



continued

Sample No.: OD3

Ambient temperature: 23 °C
Preheating temperature: 66 °C

Date: October 4, 2017

Lightning current impulses 8/20 μs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q _{th} C	Applicable range for Q _{th} C
24	1	61,0 x 2	---	38,25	0,55	0,455±0,605
25	2	61,5 x 2	---	38,50	0,55	0,455±0,605

Current impulse waveshape	
μs	
8,7/18,2	

Corrected rated voltage U₁' application

Oscillogram No.	Time s	U ₁ ' kV	Current + mA ₉₀	Current - mA ₉₀
26	0	5,816	67,0	111,0
27	10		30,0	60,0

Corrected continuous operating voltage U₂' application to evaluate the thermal stability

Oscillogram No.	Time s	U ₂ ' kV	Current + mA ₉₀	Current - mA ₉₀	Power W	Temperature °C
28	0	4,667	1,08	1,65	2,05	---
	5		0,97	0,97	1,00	---
	10		0,95	0,92	0,85	---
	15		0,94	0,94	0,80	---
29	20	0,93	0,93	0,73	---	
	25	0,93	0,94	0,68	---	
	30	0,92	0,91	0,60	---	

Note 1

A11530



244

Operating duty test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: October 4, 2017

Sample No.	Requested current kA	Charging voltage kV	Oscillogram No.	Current waveshape μs	Discharge current kA	Residual Voltage kV
OD1	10	24,6	31	8,6/18,3	10,12	14,50
OD2	10	24,6	32		10,17	14,34
OD3	10	24,6	33		10,18	14,25

Notes:

Operating duty test.

Additional two lightning impulses residual voltage measurement for check no damage occurred during the test

Test circuit: A0120

Date: October 4, 2017

Sample No.	Requested current kA	Charging voltage kV	Oscillogram No.	Current waveshape μs	Discharge current kA	Residual voltage kV
OD1	10	24,5	34	8,6/18,3	9,56	14,45
			35		9,55	14,47
			36		10,10	14,31
OD2	10	24,5	37	8,6/18,3	10,05	14,36
			38		10,18	14,25
			39		10,13	14,27

Notes:


A11263



A12877



Circuit A0019



Power frequency supply

- RE - programmable supply type PACIFIC A.C. Power Source 140 ASX; CESI no. 0560408
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI No.31120; R= 940,5 Ω
- Electro optical system HBM CESI No. 57985(Rx) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.1)

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system type HBM CESI No. 57985(Rx) - 57991 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.2)


SOFTWARE SYSTEM:

- SW - S.A.D. Surge arrester version 2.0

A00190



Circuit A0120



Impulse generator

- No. of stages 1
- Cg 6,64 pF
- Lc 6 μH
- S - Spark gap

Voltage measuring system


- D - Voltage divider SAGI; CESI No.11120
- Electro optical system type HBM CESI No. 57985(Rx) - 57991 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.2)

Current measuring system


- Sh - Current shunt CESI No.31120; R= 2,2 Ω ; Power capacity= 250 W
- Electro optical system HBM CESI No. 57985(Rx) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.1)

SOFTWARE SYSTEM:

- SW - S.A.D. Surge arrester version 2.0



245



Impulse generator

No. of stages 2
Cg 2,91 μF

S - Spark-gap

Two blocks in series have been added

Voltage measuring system (not used)

D - Voltage divider SAGI; CESI No.11120

- Electro optical system HBM CESI No. 57986(Ra) - 57991 (Tx)

OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8106/NI-PXI 5122;

- CESI No 056227- 056228 (on channel No.2)

Current measuring system

Sh - Current shunt CESI No.6042; R= 2 mΩ; peak current= 250 kA

- Electro optical system HBM CESI No. 57986(Ra) - 57991 (Tx)

OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8106/NI-PXI 5122;


- CESI No 056227- 056228 (on channel No.1)

SOFTWARE SYSTEM:

SW - S.A.D. Surge arrester version 2.0



A01210



Impulse generator circuit for injection of Qs

No. of stages 2

Cg 2,91 μF


Lc 12 μH

S - spark-gap

to circuit A0020



A01230



Impulse generator circuit A0123

Impulsive current measuring system

Sh₂ - Current shunt CESI No.6042; R= 2 m Ω

- Electro optical system HBM CESI No. 57986(Ra) - 57991 (Tx)

OSC_{2,3} - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8106/NI-PXI 5122;

- CESI No 056227- 056228 (on channel No.2)

Power frequency circuit A0131

Voltage measuring system

D - Voltage divider SAGI; CESI No.11120

- Electro optical system HBM CESI No. 57986(Ra) - 57991 (Tx)

OSC_{2,3} - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8106/NI-PXI 5122;

- CESI No 056227- 056228 (on channel No.2)

Current measuring system

Sh₂ (TOV - MCOV) - Current shunt type CESI n. 058315 R= 500 Ω

- Electro optical system CESI No. 57986(Ra) - 58234 (Tx)

OSC_{2,3} - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8106/NI-PXI 5122;


- CESI No 056227- 056228 (on channel No.1)

SOFTWARE SYSTEM:

SW - S.A.D. Surge arrester version 2.0



A00200



Power-frequency circuit

from 350V ac power supply


R₁ single-phase voltage regulator CORMES; power 10 kVA; voltage 350/0-420 V ac

R₂ single-phase voltage regulator CORMES; power 10 kVA; voltage 350/0-420 V ac


T₁ voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200-400 V/15-30 kV




041




CESI B7619962 Oscillogram n. 1



CESI B7619962 Oscillogram n. 2





CESI B7619962 Oscillogram n. 3




CESI B7619962 Oscillogram n. 4

ВЯРНО С
ОРИГИНАЛА







CESI B7019562 Oscillogram n. 5



CESI B7019562 Oscillogram n. 6





CESI B7019562 Oscillogram n. 7




CESI B7019562 Oscillogram n. 8

ВЕРНО
ОРИГИНАЛ







CESI B7019962 Oscillogram n. 9



CESI B7019962 Oscillogram n. 10





CESI B7019962 Oscillogram n. 11




CESI B7019962 Oscillogram n. 12

ВЯРНО С
ОРИГИНАЛА







CESI B7015562 Oscillogram n. 13



CESI B7015562 Oscillogram n. 14




CESI B7015562 Oscillogram n. 15




CESI B7015562 Oscillogram n. 16




ВЯРНО
СЪДЪРЖАНАТА




CESI B7019962 Oscillogram n. 17




CESI B7019962 Oscillogram n. 18




CESI B7019962 Oscillogram n. 19




CESI B7019962 Oscillogram n. 20




OPREDELJENJE
 OPREDELJENJE
 OPREDELJENJE




CESI B7019962 Oscillogram n. 21



CESI B7019962 Oscillogram n. 22




CESI B7019962 Oscillogram n. 23




CESI B7019962 Oscillogram n. 24

[Handwritten signature]




**ВЯРНО
ОРИГИНАЛ**


[Handwritten signature]




CESI B7015562 Oscillogram n. 25




CESI B7015562 Oscillogram n. 26




CESI B7015562 Oscillogram n. 27




CESI B7015562 Oscillogram n. 28




CESI B7619562 Oscillogram n. 29



CESI B7619562 Oscillogram n. 30




CESI B7619562 Oscillogram n. 31




CESI B7619562 Oscillogram n. 32


ВЕРНО
 СЕРТИФИКАТ
 "ЕМИ ЭЛЕКТРИК"
 "EM ELECTRIC"
 2




CESI B7019962 Oscillogram n. 33



CESI B7019962 Oscillogram n. 34




CESI B7019962 Oscillogram n. 35




CESI B7019962 Oscillogram n. 36


ВЯРНА
ОРИГОНАЛ
"ЕМ ТЕХНИК" ТОО
"ЕМ ТЕХНИК" ТОО
"ЕМ ТЕХНИК" ТОО




CESI B701962 Oscillogram n. 37




CESI B701962 Oscillogram n. 38



CESI B701962 Oscillogram n. 39



PA.VAR.0400.30



ČESKÝ
87 120 837-001

- 1. Miniposuvný kapacitný kondenzátor (mini capacitor)
- 2. Montážne pokyny alebo skéma (assembly instructions or schematic)
- 3. Záručný list (warranty card)
- 4. Záručný list (warranty card)

PA.VAR.0400.30	
Varistor	BSM/50
Typ	BSM 1
Ust. n. (V)	340
Ust. pr. (mA)	1,1
Ust. str. (A)	0,177
Ust. str. (kA)	0,777
Ust. str. (kA)	0,177
Ust. str. (kA)	0,177
Ust. str. (kA)	0,177

Kód výrobku	PA.VAR.0400.30
Podpis a číslo	
M.č. N° 1/24	
M.č. N° 2/24	
M.č. N° 3/24	
M.č. N° 4/24	



Test Report

Document No.	87020147	Copy No.	1	Number of pages	56
Apparatus	Polymer-housed surge arrester section type PA-DM section ST with additional thermal insulation				
Designation	---				
Serial Number	---				
Manufacturer	Joint-Stock Company "Polymer-Apparat"				
Client	Joint-Stock Company "Polymer-Apparat" Al. Kostantinova str., 1 195427 Saint-Petersburg - Russia Federation				
Tested for	---				
Date(s) of tests	October 4 - December 4, 2017				
Tested by	CESI S.p.A. Via Rubattino, 54 20134 Milano - Italy				
Test performed	Power-frequency voltage-versus-time				

PAID UNIVERSITY COMMERCIAL - CONFIDENTIAL USE

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with IEC 60099-4 - Edition 3.0 (2014-06)

The results shown in the record of proving test, and the envelope attached thereto, the reports assigned by the manufacturer as based on the IEC 60099-4, the documents applicable to the apparatus tested, the responsibility for conformity of any apparatus having the same design must be determined with the manufacturer.

December 12, 2017

Date: **Roberto Marco** Test Engineer in charge / **The Manager - Accidia Lorenzo** Approved By document digitally signed

Partial reproduction of this document is permitted in print or by any means provided that the CESI Group, the responsibility of CESI is maintained and the CESI logo is included.



The laboratory meets the requirements of the Standard of the IEC 61010 "Safety" defined requirements for the Construction of Testing and Calibration Laboratories". The technical status of the laboratory is in full compliance with the requirements of the IEC 61010-1:2010.



CESI

Trust the Power of Experience

Notes

STL-Member

CESI Group members are founder members of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in 1969. STL is a forum for voluntary international cooperation of testing organizations.

CESI Group Test Documents description

Type Test Certificate of

Issued for type tests of high voltage products (> 1 kV_u; < 1,5 kV_u), which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. The Type Test Certificate consists of documents unequivocally identifying the test object and describes all conditions under which the tests were conducted. It gives evidence of the unobjectionable behavior of the test object during the tests in line with the normative documents applied as well as of the results of successful testing.

Test Certificate of (complete / selected) Type Tests

Issued if type tests of low voltage products (< 1 kV_u; < 1,5 kV_u) requested by the relevant product standard were passed. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Certificate of Design Verification

Issued for passed design verification tests according to IEC 61439. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Type Test Report

Issued for high and low voltage products if parts of selected type tests have been passed; those shall be carried out in full compliance with the relevant standards but (for high voltage products) do not fulfill all STL requirements for issuing a Type Test Certificate. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Test Report

Issued for all other tests on high and low voltage products which have been carried out according to specifications, standards and/or client instructions

On-Site Test Record

Issued as a record of results acquired during the on-site tests / measurements

Test Award

Can be additionally issued for all named types of test documents above if the tests to be referenced were passed

Tests witnessed by:

Identification of the object: Effect test

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object. These drawings, identified by CESI and numbered 870204364 No. 1, is annexed to this document.

Test evaluation

With reference to the Standards/Specifications listed in the first page and the characteristics of the tested sample assigned by manufacturer, the carried out tests passed SUCCESSFULLY.

The data necessary to permit repetition of the tests are contained in the document marked: ---

The reported expanded uncertainties are determined in accordance with the Publication JCGM 100 "Evaluation of measurement data - Guide to the expression of uncertainty in measurement" and are based on a standard uncertainty multiplied by a coverage factor k = 2, which for a normal distribution provides a level of confidence of approximately 95 %.

- Voltage a.c. ± 3,0%
- Residual peak voltage (impulse tests) ± 3,0%
- Current a.c. ± 3,0%
- Peak current (impulse tests) ± 3,0%
- Time (impulse tests) ± 10,0%
- Time (a.c. tests) ± 1,5%


Laboratory Information

Receipt date of the sample: September 2017
 Test location: CESI - Via Rubattino 54 - Milan
 CESI testing team: Mr L. Podavite
 Test laboratory: P177
 DDF SAP: 70006781



Page	test date
5	October 4-5, 2017
6	October 5, 2017
7	December 2-4, 2017
7	October 6, 2017
7	December 4, 2017
8	
8	
9	
10 to 11	
12	
13 to 16	
17 to 18	
19 to 20	
21 to 25	

TEST REPORT



Test object characteristics (assigned by the client)

Manufacturer's name	Joint-Stock Company "Polymer-Apparat"
Polymer-housed surge arrester section type	PA-DM section ST
Drawing code	PA-DM001.ST.02
MO-resistor supplier's	Joint-Stock Company "Polymer-Apparat"
Metal-oxide resistor type	B34/30
Arrester class	Distribution
Designation	DH
Number of MO resistor Erod	1
Nominal discharge current - [kA]	10
Rated voltage - U_n [kV]	1,077 x U_{nL}
Continuous operating voltage - U_c [kV]	0,861 x U_{nL}
Repetitive charge transfer rating - Q_n [C]	0,4
Rated thermal charge transfer rating - Q_n [C]	1,1
Flat surface area [cm ²]	10,52
Reference current - I_{ref} [mA]	1,0
Rated frequency - [Hz]	48±1
Year of manufacture	08/2017

geometrical characteristics measured on one MO resistor

Total height [mm]	31,1 mm
Diameter [mm]	35,6 mm



A11293

Photographs of the test object




Photo no. 1




Photo no. 2

Polymer-housed surge arrester section type PA-DM section ST with additional thermal insulation



A125793

Reference Standard

IEC 60099-4 (2014:05) – Edition 3 - Clause 10.8.8.
Metal-oxide surge arresters without gaps for a.c. system

Test carried out	Number of sample tested
Power-frequency voltage-versus-time test	6

Test object identification

Test object name	Identification of test sample (given by CESI)	Identification of test sample (given by JSC "Polymer-Apparat")
Polymer-housed surge arrester section type PA-DH section ST with additional thermal insulation	TOV1	00102
	TOV2	00103
	TOV3	00104
	TOV4	00005
	TOV5	00009
	TOV6	00010



A11293

Test procedure

The test procedure consisted of the following sequence:

1. Test performed on Polymer-housed metal-oxide surge arrester section in open air initial test
 - a) Measurement of the lightning impulse residual voltage at the nominal discharge current
 - b) Measurement of the power frequency reference voltage at the reference current

2. Test performed on Polymer-housed metal-oxide surge arrester section assembled in thermal model

Test with energy input (prior duty test)

- c) The surge arrester sections were kept in an oven at the temperature of 66 °C (±1 thermal equilibrium (not more than twenty hours)
- d) Injection of two lightning current impulses 8/20 μs at the rated thermal charge transfer Q_n . A time shorter than 120 ms after the application of the second second lightning current impulses 8/20 μs energization at U_{100V} (declared by the manufacturer) for a time t_{100V} (declared by the manufacturer) and then at U_1 for 30 min. to verify the thermal stability.

Note:

- intervals between lightning current impulses: 60 seconds
- nominal test frequency: 50 Hz

Four samples were tested as specified below:

Sample	U_{100V}	Duration	Note
TOV1	1,080 x U_1	1 sec	prior duty test
TOV2	1,040 x U_1	10 sec	
TOV3	1,000 x U_1	100 sec	
TOV4	0,960 x U_1	1000 sec	

Test without energy input (no-prior duty test)

- e) The surge arrester sections were kept in an oven at the temperature of 66 °C (±1 thermal equilibrium (not more than twenty hours)
- f) Application of the overvoltage U_{100V} (declared by the manufacturer) for a time t_{100V} (declared by the manufacturer) and then at U_1 for 30 min. to verify the thermal stability.

Note:

- nominal test frequency: 50 Hz

Two samples were tested as specified below:

Sample	U_{100V}	Duration	Note
TOV5	1,130 x U_1	10 sec	no-prior duty test
TOV6	1,040 x U_1	1000 sec	

3. Test performed on Polymer-housed metal-oxide surge arrester section in assembly

- g) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value
- h) After that the sample has cooled to ambient temperature and two lightning impulses 8/20 at 0,4 kA/cm² have been applied to check the integrity of the internal parts. The interval between impulses was 50-60 seconds.

Test result

The visual inspection of the sample after the test has revealed no sign of physical damage. The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%). During the two test impulses the oscillograms did not reveal any breakdown. The thermal stability was achieved.

The acceptance criteria are fulfilled. The test result is positive.

ВЯРНО
ОРИГИНАЛНА



A11293



25

Summary of test results

Variation of lightning impulse residual voltage at I_0

sample	before test		after test		Variation %
	discharge current kA	residual voltage kV	discharge current kA	residual voltage kV	
TOV1	10,15	14,04	10,18	14,26	+1,57
TOV2	10,10	14,06	10,14	14,24	+1,28
TOV3	10,07	14,16	10,10	14,38	+1,55
TOV4	10,15	14,30	10,07	14,35	+0,41
TOV5	10,14	14,17	10,04	14,00	+1,20
TOV6	10,08	14,35	10,05	14,25	-0,70

Power frequency voltage versus time test.

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: October 4, 2017

Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current kA	Residual Voltage kV
TOV1	I ₀	24,8	1	8,6/18,2	10,15	14,04
TOV2		24,8	2		10,10	14,06
TOV3		24,8	3		10,07	14,16
TOV4		24,8	4		10,15	14,30
TOV5		24,6	5		10,14	14,17
TOV6		24,6	6		10,08	14,35

Notes:

A117603



A117603



Power frequency voltage versus time test.

Reference voltage test.

Test circuit: A0019

Date: October 5, 2017

Sample No. TOV1						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	3rd harmonic amplitude μ A
7	5,47	0,884	1,000	0,562	1,41	---

Sample No. TOV2						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	3rd harmonic amplitude μ A
8	5,37	0,939	1,000	0,570	1,45	---

Sample No. TOV3						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	3rd harmonic amplitude μ A
9	5,45	0,922	1,00	0,571	1,43	---

Sample No. TOV4						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	3rd harmonic amplitude μ A
10	5,39	0,887	1,000	0,564	1,42	---

Sample No. TOV5						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	3rd harmonic amplitude μ A
11	5,38	0,860	1,000	0,560	1,37	---

Sample No. TOV6						
oscillogram No.	voltage kV	current + mA _{ref}	current - mA _{ref}	current mA _{max}	power W	3rd harmonic amplitude μ A
12	5,40	0,884	1,000	0,563	1,39	---

Power frequency voltage versus time test.

Voltage correction factor and thermal energy calculations

Date: October 5, 2017

Sample No.	U _{ref} [1] kV	KU ₁ [2]	KU ₂ [3]	U ₁ ' [4] kV	U ₁ ' [5] kV
TOV1	5,47	1,077	0,861	5,891	5,710
TOV2	5,37			5,783	5,624
TOV3	5,45			5,870	5,692
TOV4	5,39			5,805	5,641
TOV5	5,38			5,794	5,632
TOV6	5,40			5,816	5,654

- [1] U_{ref} : measured reference voltage
- [2] KU₁ : maximum guaranteed factor for calculation of U₁' = U₁/U_{ref,max}
- [3] KU₂ : maximum guaranteed factor for calculation of U₁' = U₁/U_{ref,min}
- [4] U₁' : corrected rated voltage [4] = [1] × [2]
- [5] U₁' : corrected continuous operating voltage [5] = [1] × [3]

Sample No.	U ₁ ' kV	Requested thermal charge transfer, Q _{th} C	Requested Q _{th} per impulse C
TOV1	5,891	1,1	0,55 (+10%)
TOV2	5,783		0,55 (+10%)
TOV3	5,870		0,55 (+10%)
TOV4	5,805		0,55 (+10%)

[Handwritten signature]

A117603



ВЯРНО С ОРЪГИНАЛА



Power frequency voltage versus time test.

Application of two lightning current impulses 8/20µs, corrected rated voltage U₁ and corrected continuous operating U₂ for evaluation of the thermal stability.

Test circuit: A0124-A0030-A0130

Sample No.: TOV1

Ambient temperature: 20 °C
Preheating temperature: 65 °C

Date: December 2, 2017

Lightning current impulses 8/20 µs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q ₈ C	Applicable range for Q ₈ C
13	1	65.0 x 2	---	38.14	0.55	0,495+0,605
14	2	65.0 x 2	---	38.07	0.55	0,495+0,605

Current impulse waveshape (µs)	
8.8/18.2	

Temporary overvoltage application

Amplitude claimed by the manufacturer U₁' x 1,050 = 5,891 x 1,050 = 6,186 kV
Duration claimed by the manufacturer 1 sec.

Oscillogram No.	Time s	U ₁ ' kV	Current +mA ₉₀	Current -mA ₉₀
15	0	6,352	145.0	221.0
16	1		132.0	164.0

Corrected continuous operating voltage U₂' application to evaluate the thermal stability

Oscillogram No.	Time min	U ₂ ' kV	Current +mA ₉₀	Current -mA ₉₀	Power W	Temperature °C
17	0	4,710	0.58	0.59	1.10	---
	5		0.91	0.94	0.76	---
	10		0.90	0.93	0.64	---
18	15		0.88	0.91	0.59	---
	20		0.87	0.90	0.54	---
	25		0.86	0.89	0.50	---
19	30	0.85	0.88	0.48	---	

Note 1 Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 5211 thermometer CESI no.30889

continued



A11920

Continued

Sample No.: TOV2

Ambient temperature: 20 °C
Preheating temperature: 65 °C

Date: December 2, 2017

Lightning current impulses 8/20 µs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q ₈ C	Applicable range for Q ₈ C
20	1	65.0 x 2	---	37.80	0.55	0,495+0,605
21	2	65.0 x 2	---	37.80	0.55	0,495+0,605

Current impulse waveshape (µs)	
8.8/18.2	

Temporary overvoltage application

Amplitude claimed by the manufacturer U₁' x 1,040 = 5,783 x 1,040 = 6,014 kV
Duration claimed by the manufacturer 10 sec.

Oscillogram No.	Time s	U ₁ ' kV	Current +mA ₉₀	Current -mA ₉₀
22	0	6,014	80.0	118.0
23	10		51.0	67.0

Corrected continuous operating voltage U₂' application to evaluate the thermal stability

Oscillogram No.	Time min	U ₂ ' kV	Current +mA ₉₀	Current -mA ₉₀	Power W	Temperature °C
24	0	4,624	0.58	1.20	1.70	---
	5		0.90	0.93	0.76	---
	10		0.89	0.91	0.65	---
25	15		0.88	0.90	0.58	---
	20		0.87	0.88	0.53	---
	25		0.86	0.87	0.50	---
26	30	0.85	0.87	0.48	---	

Note 1 Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 5211 thermometer CESI no.30889

continued



A11920

Continued

Sample No.: TOV3

Ambient temperature: 20 °C
Preheating temperature: 65 °C

Date: December 2, 2017

Lightning current impulses 8/20 µs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q ₈ C	Applicable range for Q ₈ C
27	1	65.0 x 2	---	37.83	0.55	0,495+0,605
28	2	65.0 x 2	---	37.90	0.55	0,495+0,605

Current impulse waveshape (µs)	
8.8/18.2	

Temporary overvoltage application

Amplitude claimed by the manufacturer U₁' x 1,000 = 5,870 x 1,000 = 5,870 kV
Duration claimed by the manufacturer 100 sec.

Oscillogram No.	Time s	U ₁ ' kV	Current +mA ₉₀	Current -mA ₉₀
29	0	5,870	43.0	85.0
30	100		87.0	17.0

Corrected continuous operating voltage U₂' application to evaluate the thermal stability

Oscillogram No.	Time min	U ₂ ' kV	Current +mA ₉₀	Current -mA ₉₀	Power W	Temperature °C
31	0	4,692	0.92	0.93	0.70	---
	5		0.89	0.91	0.57	---
	10		0.88	0.90	0.52	---
32	15		0.88	0.89	0.48	---
	20		0.87	0.88	0.42	---
	25		0.86	0.87	0.40	---
33	30	0.85	0.86	0.37	---	

Note 1 Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 5211 thermometer CESI no.30889

continued



A11920

Continued

Sample No.: TOV4

Ambient temperature: 20 °C
Preheating temperature: 65 °C

Date: December 4, 2017

Lightning current impulses 8/20 µs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q ₈ C	Applicable range for Q ₈ C
34	1	65.0 x 2	---	38.06	0.56	0,495+0,605
35	2	65.0 x 2	---	37.90	0.55	0,495+0,605

Current impulse waveshape (µs)	
8.8/18.2	

Temporary overvoltage application

Amplitude claimed by the manufacturer U₁' x 0,960 = 5,608 x 0,960 = 5,373 kV
Duration claimed by the manufacturer 1000 sec.

Oscillogram No.	Time s	U ₁ ' kV	Current +mA ₉₀	Current -mA ₉₀
36	0	5,573	30.0	55.0
37	1000		2.30	3.60

Corrected continuous operating voltage U₂' application to evaluate the thermal stability

Oscillogram No.	Time min	U ₂ ' kV	Current +mA ₉₀	Current -mA ₉₀	Power W	Temperature °C
38	0	4,641	0.87	0.88	0.60	---
	5		0.86	0.88	0.56	---
	10		0.85	0.87	0.52	---
39	15		0.84	0.86	0.47	---
	20		0.83	0.85	0.44	---
	25		0.82	0.84	0.41	---
40	30	0.81	0.83	0.40	---	

Note 1 Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 5211 thermometer CESI no.30889

ВЯРНО С
ОРИГИНАЛА



261

Power frequency voltage versus time test.

Application of the temporary overvoltage U_{TOV} and evaluation of thermal stability (WITHOUT PRIOR DUTY TEST)

Test circuit: A0123-A0130-A0020

Sample No.: TOV5

Preheating temperature: 65 °C

Date: October 6, 2017

Temporary overvoltage application

Amplitude claimed by the manufacturer $U_r \times 1,130 = 5,794 \times 1,130 = 6,547$ kV
Duration claimed by the manufacturer 10 sec.

Oscillogram No.	Time s	Voltage kV	Current + mA _{gr}	Current - mA _{gr}	Power W
41	0	6,547	193,0	260,0	---
42	10		167,0	176,0	

Corrected continuous operating voltage U_r application to evaluate the thermal stability

Oscillogram No.	Time min	U_r kV	Current + mA _{gr}	Current - mA _{gr}	Power W	Temperature °C
43	0,5	4,632	0,74	0,76	0,47	---
	5		0,73	0,75	0,45	---
	10		0,72	0,74	0,43	---
44	15		0,71	0,74	0,40	---
	20		0,71	0,73	0,36	---
	25		0,70	0,72	0,35	---
45	31		0,69	0,71	0,33	---

Note: Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 52II thermometer CESI no 30889

A11250



Sample No.: TOV5

Preheating temperature: 65 °C

Date: October 6, 2017

Temporary overvoltage application

Amplitude claimed by the manufacturer $U_r \times 1,040 = 5,816 \times 1,040 = 6,049$ kV
Duration claimed by the manufacturer 1000 sec.

Oscillogram No.	Time s	Voltage kV	Current + mA _{gr}	Current - mA _{gr}	Power W
45	0	6,049	42,0	56,0	---
47	1000		33,0	38,0	

Corrected continuous operating voltage U_r application to evaluate the thermal stability

Oscillogram No.	Time min	U_r kV	Current + mA _{gr}	Current - mA _{gr}	Power W	Temperature °C
48	0	4,694	0,80	0,81	0,84	---
	5		0,78	0,81	0,69	---
	10		0,77	0,79	0,62	---
49	15		0,75	0,77	0,55	---
	20		0,74	0,76	0,50	---
	25		0,73	0,75	0,47	---
50	30		0,72	0,75	0,45	---

Note: Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 52II thermometer CESI no 30889

A11250



Power frequency voltage versus time test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: December 4, 2017

Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current kA	Residual Voltage kV
TOV1	I ₁	24,8	51	8,6/18,3	10,18	14,26
TOV2		24,8	51		10,14	14,24
TOV3		24,8	53		10,10	14,38
TOV4		24,8	54		10,07	14,36
TOV5		24,6	55		10,04	14,00
TOV6		24,7	56		10,05	14,25

Notes:

[Handwritten signature]

A11250



ВЯРНО С
ОРЪЖИНАТА

Power frequency voltage versus time test.

Additional two lightning impulses residual voltage measurement for check no damage occurred during the test

Test circuit: A0120

Date: December 4, 2017


Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current kA	Residual voltage kV
TOV1	5,26(*)	19,4	57	7,8/20,0	5,44	13,22
			58		5,56	13,26
			59		5,46	13,21
TOV2			60		5,42	13,24
			67		5,33	13,33
			68		5,28	13,30
TOV3			61		5,27	13,31
			62		5,27	13,34
			63		5,48	13,12
TOV4			64		5,45	13,10
			65		5,31	13,26
			66		5,28	13,29

Notes:
Requested current = 0,5 kA/cm² x 10,52 cm² = 5,26 kA
- where 0,5 kA/cm² is peak current density
- where 10,52 cm² is surface area on the metal-oxide resistor used for this test declared by the manufacturer



002

Circuit A0019



Power frequency supply

- RE - programmable supply type PACIFIC A.C. Power Source 140 ASX; CESI no. 0560408
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI No.31120; R= 940,5 Ω
- Electro optical system HBM CESI No. 57586(Ra) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.1)

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system type HBM CESI No. 57986(Ra) - 57991 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.2)


SOFTWARE SYSTEM:

- SW - S.A.D. Surge arrester version 2.0

A0019/0



Circuit A0120



Impulse generator

- No. of stages - 1
- Cg - 6,64 μF
- Lc - 6 μH
- S - Spark-gap

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system type HBM CESI No. 57586(Ra) - 57991 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 mΩ; peak current= 250 kA
- Electro optical system HBM CESI No. 57986(Ra) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.1)


SOFTWARE SYSTEM:

- SW - S.A.D. Surge arrester version 2.0

A0120/0




Circuit A0123



Impulse generator circuit for injection of Qa

- No. of stages - 2
- Cg - 2,91 μF
- Lc - 12 μH
- S - spark-gap

Circuit A0020



Impulse generator circuit A0123

- Impulsive current measuring system
- Sh₁ - Current shunt CESI n. 6042; R= 2 m Ω
- Electro optical system HBM CESI No. 57986(Ra) - 57987 (Tx)
- OSC_{2,3} - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.2)
- I - Circuit-breaker

Power frequency circuit A0131

- Voltage measuring system
- D - Voltage divider SAGI; CESI No.11120
- Electro optical system HBM CESI No. 57586(Ra) - 57991 (Tx)
- OSC_{2,3} - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.2)


Current measuring system

- Sh₂ (TOV - MCOV) - Current shunt type CESI n. 608315 R= 500 Ω
- Electro optical system CESI No. 57986(Ra) - 58294 (Tx)
- OSC_{2,3} - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227-056226 (on channel No.2)

SOFTWARE SYSTEM:


- SW - S.A.D. Surge arrester version 2.0

A0123/0



263


Circuit A0131



Power-frequency circuit


from 380V ac power supply

- R₁ single-phase voltage regulator CORMES; power 20 kVA; voltage 380V±120 Vac
- R₂ single-phase voltage regulator CORMES; power 10 kVA; voltage 380V±120 Vac
- T₁ voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200-400 V/15-30 kV





CESI B7020147 Oscillogram n. 1

A117930



CESI B7020147 Oscillogram n. 2




ВЕРНО С
ОРИГИНАЛА


CESI B7020147 Oscillogram n. 3

[Handwritten signature]


120




СЭСІ В7020147 Осцилограм n. 4



СЭСІ В7020147 Осцилограм n. 5





СЭСІ В7020147 Осцилограм n. 6




СЭСІ В7020147 Осцилограм n. 7

ВЕРНО С
ОРИГИНАЛА






CESI B7026147 Oscilogram n. 8




CESI B7026147 Oscilogram n. 9

[Handwritten signature]




CESI B7026147 Oscilogram n. 10




CESI B7026147 Oscilogram n. 11


[Handwritten signature]

**ВЕРНО С
ОРИГИНАЛОМ**






CESI B7020147 Oscillogram n. 12




CESI B7020147 Oscillogram n. 13

[Handwritten signature]



CESI B7020147 Oscillogram n. 14




CESI B7020147 Oscillogram n. 15


[Handwritten signature]

**ВЯРНО С
ОРИГИНАЛА**


EMERSON ELECTRIC LTD.
Тестов център
[Handwritten signature]




CESI B7020147 Oscillogram n. 16



CESI B7020147 Oscillogram n. 17





CESI B7020147 Oscillogram n. 18




CESI B7020147 Oscillogram n. 19

ВЯРНО С
ОРИГИНАЛА







CESI B7020147 Oscillogram n. 20



CESI B7020147 Oscillogram n. 21





CESI B7020147 Oscillogram n. 22




CESI B7020147 Oscillogram n. 23

ВЯРНО С
ОРИГИНАЛА.







CESI B7020147 Oscilogram n. 24



CESI B7020147 Oscilogram n. 25




CESI B7020147 Oscilogram n. 26




CESI B7020147 Oscilogram n. 27

[Handwritten signature]


ВЕРНО С
ОРИГИНАЛА




022




CESI B7020147 Oscilogram n. 28



CESI B7020147 Oscilogram n. 29





CESI B7020147 Oscilogram n. 30




CESI B7020147 Oscilogram n. 31

ВЯРНО С
ОРУДИНАТА







CESI B7020147 Oscillogram n. 32



CESI B7020147 Oscillogram n. 33



CESI B7020147 Oscillogram n. 34



CESI B7020147 Oscillogram n. 35


Handwritten signature

**ВЯРНО С
ОРИГИНАЛА**

ТЕХНИЧЕСКАЯ КОПИЯ
ИЗДАНИЕ 2010
ИЗДАНИЕ 2010
Handwritten signature




CESI B7020147 Oscillogram n. 35




CESI B7020147 Oscillogram n. 37

Handwritten signature




CESI B7020147 Oscillogram n. 38




CESI B7020147 Oscillogram n. 39


**ВЕРНО С
ОРИГИНАЛА**




Handwritten initials




CESI B7020147 Oscilogram n. 40



CESI B7020147 Oscilogram n. 41



CESI B7020147 Oscilogram n. 42




CESI B7020147 Oscilogram n. 43


[Handwritten signature]

**ВЯРНО С
СЕРТИФИКАТА**







CESI B7020147 Oscilogram n. 44



CESI B7020147 Oscilogram n. 45





CESI B7020147 Oscilogram n. 46




CESI B7020147 Oscilogram n. 47

ВЯРНО С
ОРИГИНАЛА







CESI B7020147 Oscillogram n. 48



CESI B7020147 Oscillogram n. 49




CESI B7020147 Oscillogram n. 51




CESI B7020147 Oscillogram n. 52

ВЕРНО С
ОРИГИНАЛОМ


746




CESI B7020147 Oscillogram n. 53



CESI B7020147 Oscillogram n. 54




CESI B7020147 Oscillogram n. 55




CESI B7020147 Oscillogram n. 56


ВЯРНО С
ОРИГИНАЛА




277



CESI B7020147 Oscillogram n. 57




CESI B7020147 Oscillogram n. 58



CESI B7020147 Oscillogram n. 59


Handwritten signature




CESI B7020147 Oscillogram n. 59

**ВЯРНО С
ОРИГИНАЛА**







CESI B7020147 Oscillogram n. 60



CESI B7020147 Oscillogram n. 61




CESI B7020147 Oscillogram n. 62




CESI B7020147 Oscillogram n. 63


[Handwritten signature]

**ВЕРНО С
ОРИГИНАЛА**






CESI B7020147 Oscillogram n. 64




CESI B7020147 Oscillogram n. 65



CESI B7020147 Oscillogram n. 66


Handwritten signature



ВЕРНО
ОРИГИНАЛ
CESI B7020147 Oscillogram n. 67

“ЭМЭЛЭГЧИЙН” ТӨД
“ЭМЭЛЭГЧИЙН” ТӨД
“ЭМЭЛЭГЧИЙН” ТӨД

Handwritten signature



CESI B702147 Oscillogram n. 68

n. n.	name	note
n.1	varistor B34/30	000
n.2	Housing	000
n.3	External insulation	000
n.4	Metal Ranges and spacers	000
n.5	Additional thermal insulation	000

1. * - Dimensions for reference
2. ** - Typical diameter B34 / 30

PA-DM.001.ST.02		dim	pieces	pieces
Section 1	section in thermal model.			4-1
Section 2	Surge Arrester PA-DM			
Section 3				3A0
Section 4				(Thermop-Arrester)

1. Монтажные размеры (тип 340)
2. Измерения корпуса сепаратора (класс изолирующей обмотки)
3. Измерения корпуса сепаратора (тип изолирующей обмотки)
4. Монтажные размеры (тип - электрода)

PA.VAR.04.00.30		dim	pieces	pieces
Section 1	Varistor B34/30	0.77	1.1	
Section 2				3A0
Section 3				Толщина-толщина
Section 4				Корпуса

The TOV characteristics of PA-DM surge arresters.

The TOV characteristics (in p.u. Ur) of PA-DM surge arresters with prior duty and without prior duty as per IEC 60099-4 Ed. 3.0 are presented in the Fig 2 below.





Figure 2. The TOV characteristics of PA-DM surge arresters.


The TOV values in per unit of Ur for times 0,1 s, 1 s, 10 s, 100 s, 1000 s and 3500 s are presented in the table 4.

v Time, s	The TOV values in p.u. Ur	
	with prior duty	without prior duty
0,1	1,130	1,230
1	1,080	1,180
10	1,040	1,130
100	1,000	1,090
1000	0,960	1,040
3500	0,940	1,020

ВЕРНО С
ОРГАНИЗАЦИЯ



Приложение
6



JSC "POLYMER-APPARAT"
St. Petersburg, Russian Federation



МЕТАЛО-ОКСИДНИ ВЕНТИЛНИ ОТВОДИ

РА-DM-093-27-22/22


ТЕХНИЧЕСКО РЪКОВОДСТВО

TM 3414-E323-15207362-2018



ВЯРНО С
ОРИГИНАЛА





Това ръководство съдържа технически данни за метало-оксидни предпазители от свръхнапрежения в полимерни обвивки тип PA-DM-093-27-22/22

1. Приложение

1.1. Метало-оксидни вентилни отводи от пренапрежения без въздушна междина от тип PA-DM-093, по нататък наричани „отводи”, са предназначени за предпазване на електрическо оборудване АС с $48 \div 62$ Hz честота от пренапрежение при комутации и мълнии.

1.2. Класификация на вентилни отводи съгласно IEC 60099-4:2014 – Високо разпределение

2. Дизайн и работна информация

2.1. Вентилните отводи са направени като пакет от метало-оксидни варистори (MOV), затворени в полимерна обвивка с метални фланци.

2.2. Цялостни и монтажни размери са дадени в Приложение А.

2.3. Принципът на работа на ВО се базира на нелинейността на волт-амперната диаграма на цинк-оксидните варистори. При работно напрежение стойността на активните токове през варисторите е по-малка от милиампер, но при свръхнапрежение тези стойности се повишават до стотици и хиляди амperi.

3. Система за маркиране на породукта:

Пример за продуктов номер: PA-DM-093-27-22/22

PA - Търговска марка на производител - "Polymer-Apparat";

DM - Високо разпределение (класификация на предпазителя съгласно JSC "Polymer-Apparat");

093 - Тип обвивка;

27 - Номинално напрежение (rated voltage), kV;

22 - Високо-волтов вход (M12 type 2);


22 - Заземителна клема (M12 type 2).

4. Условия на работната среда

Работата на ВО се осигурява при следните условия на обслужване:

- На открито;
- Минимална работна температура на околната среда е -60°C ;
- Минимална работна температура на околната среда е $+50^{\circ}\text{C}$;


ВЯРНО С
ОРИГИНАЛА



- Надморска височина до 1000 m.

5. Основни характеристики и параметри

5.1. Вентилните отводи отговарят на спецификация: IEC 60099-4:2014. Основните характеристики и параметри са дадени в Таблица 1 по-долу.

Таблица 1

Параметри	Номинална стойност
1. Номинално напрежение, kV	27
2. Трайно напрежение на предпазител (MCOV), kV (rms)	21.6
3. Номинален разряден ток, A	10000
4. Остатъчно напрежение при мълниев импулс на тока с амплитуда 8/20 μ s (kV, не повече от):	
5 kA	65.0
10 kA	69.1
20 kA	77.4
5. Остатъчно напрежение при превключващ импулс на ток с амплитуда 30/60 μ s (kV, не повече от):	
125 A	50.5
500 A	52.7
6. Остатъчно напрежение при стръмен 1/10 μ s токов импулс с амплитуда 10000 A (kV, не повече от)	75.3
7. Траен рейтинг за пренос на заряд Q_{rs} , C	0.4
8. Степен на пренос на топлинна енергия Q_{th} , C	1.1
9. Висок токов импулс 4/10 μ s, kA	100
10. Продължителност на текущия импулс, A	300
11. Референтно напрежение (при референтен ток $I_{ref} = 1.5$ mA), kV, не по-малко от	25.1


5.2. Външни параметри на изолация:

- Обявено издържано мълниев импулсно напрежение 1.2/50 μ s, не по-малко от 144 kV
- Обявено издържано мълниев импулсно напрежение 60 Hz, не по-малко от 90 kV
- Разстояние на утечка, не по-малко от 938mm

5.1.5.3. Изолацията на ВО е устойчива на ерозия и проникване на влага.

5.4. Сеизмична стабилност, MSK-64 номер 9.

ВЯРНО С
ОРИГИНАЛА



5.5. Ниво на частично разреждане в предпазителя при напрежение $1.05 \times U_{cont}$ – не повече от 10 pC.

5.6. TOV характеристики (отнесени към MCOV) представени в Таблица 3 по-долу

Продължителност на завишено напрежение	0.1 с	0.15 с	1.0 с	3.5 с	10 с	20 с	20 min	50 min	2 h	6 h
Допустимо съотношение на повишено напрежение на предпазителя по отношение на U_{cont}	1.48/ 1.56	1.47/ 1.55	1.43/ 1.50	1.40/ 1.47	1.37/ 1.45	1.36/ 1.43	1.26/ 1.33	1.23/ 1.30	1.22/ 1.29	1.19/ 1.26

Забележка:

- Числителят отговаря на тест при предварително загрят предпазител до 60°C изпитан чрез два правоъгълни импулса равни на рейтинга на устройството;
- Стойността на знаменателя съответства на тест при загрят до 60°C предпазител без допълнителни импулси.

6. Безопасност

6.1. Вентилните отводи са устойчиви на експлозия и издържат на следните токове на късо съединение без да експлодират:

- 20 kA (rms) за 0,2 с (не по-малко);
- 600 A (rms) за 2 с (не по-малко)

6.2. Вентилните отводи отговарят на IEC 60099-4:2014.

7. Експлоатационен живот

Очакван експлоатационен живот на Вентилните отводи (с 0.98 вероятност за безпроблемност) е 30+ години.

8. Стандартен набор и опции

Комплектът за доставка се състои от:

- Предпазител;
- QC сертификат за тест;
- Техническо упътване (3 копия за вид предпазител).

Вентилните отводи се състои от:

- Метало-оксиден предпазител от пренапрежение без пролуки, тип PA-DM-93

**ВЯРНО С
ОРИГИНАЛА**



– Високо волтов вход тип 02 - пин M12×50 - 1 бр., шайба Ø12 - 2 бр., пружинна шайба Ø12 - 1 бр;

– Заземителна клема тип 02 - пин M10×25 - 1 бр., шайба Ø12 - 2 бр., пружинна шайба Ø12 - 1 бр.

9.Обозначения

На долният фланец на предпазителя е отбелязано:

- Име на производителя;
- Тип на предпазител;
- MCOV, kV;
- Заводски номер;
- Дата на производство.

10.Транспортиране

Транспортирането се извършва в оригиналната опаковка с етикети:

- Чупливо;
- Да не се мокри;
- Нагоре

11.Съхранение

Вентилните отводи трябва да се съхраняват в оригиналната опаковка. Да се съхраняват на закрито. Няма необходимост от затопляне/охлаждане в диапазона от -60° C до +50° C.

При съхранение и транспорт Вентилните отводи не трябва да излагат на влага, маслени продукти, киселини, алкални, газове и други агресивни субстанции, които могат да навредят на полимерната обвивка.

Приемането на продукта трябва да включва проверка на цялостта на опаковката и съответствие с поръчката.

12.Инсталация

12.1. Само квалифициран персонал, запознат с това техническо ръководство и правила за безопасност може да борави с тези вентилни отводи.

ВНИМАНИЕ: За да избегнете щети, **ВО не трябва да се докосват до абразивни повърхности, остри ръбове или режещи инструменти.**

ВЯРНО С
ОРИГИНАЛА



12.1. Извадете ВО от опаковката и се уверете, че няма видими повреди, които да са се появили при транспортирането.

12.2. Инсталирайте ВО, като следвате диаграмата в Приложение А.

12.3. Заземяването на предпазителя се извършва чрез гъвкав меден проводник със сечение не по-малко от 6 mm^2 .

13. Изисквания за поддръжка

Поддръжка на Вентилните отводи не е предвидена.


Вентилните отводи не подлежат на ремонт. Няма инструкция за ремонт.

14. Гаранция


Производителя ще замени повредени Вентилни отводи в срок от 5 години от датата на пускане в експлоатация, но не по-късно от 7 години от датата на експедиция от производителя, при условие, че повреденият ВО е бил транспортиран, съхраняван, инсталиран и експлоатиран стриктно спазвайки това техническо ръководство.

15. Рециклиране

Вентилните отводи не съдържат опасни или агресивни материали, които могат да навредят на хора или животни, които имат контакт с тях. Рециклирайте в съответствие с местните разпоредби за индустриални отпадъци от метал и пластмаса.




ВЯРНО С
ОРИГИНАЛА



ПРИЛОЖЕНИЕ А

Външни и инсталационни размери и тегло на вентилни отводи тип РА-DM-093



Височина на ВО (H) – 275 ± 1 mm.

Тегло на ВО – 2.8 ± 0.1 kg

ВЯРНО С
ОРИГИНАЛА



Test Report

Document No.	B6020612	Copy No.	1	Number of pages	24
Apparatus	Polymeric housing surge arresters				
Designation	PA-DH				
Serial Number	3508-3509-3510-3511				
Manufacturer	JSC "Polymer-Apparat"				
Client	JSC "Polymer-Apparat" Ak. Konstantinova Str., 1 195427 Saint-Petersburg - Russia Federation.				
Tested for					
Date(s) of test	September 16, 2016				
Tested by	CESI S.p.A. Via Rubattino, 54 20134 Milano - Italy				
Test performed	Short circuit tests				

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with:
IEEE Std C62.11-2012

The results are shown in the record of proving tests and the evaluations indicated herein. The general performance is considered as mentioned above. The settings assigned by the manufacturer are listed on the ratings page. The document applies only to the apparatus tested. The responsibility for conformity of the test results with the manufacturer's specifications is assumed by the manufacturer.

September 16, 2016

Ghezzi Giuseppe
Test Engineer in charge

The laboratory meets the requirements of the Standard EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing and Calibration Laboratories". The in force status of the accreditation and the list of accredited tests may be checked in the file: <http://www.italian.it>

ACCREDIAS
LABORATORIO ACCREDITATO

LAB N° 8320

CESI


Trust the Power of Experience

Notes

- STL-Member.** CESI Group members are founder members of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in 1969. STL is a forum for voluntary international cooperation of testing organizations.
- CESI Group Test Documents description**
- Type Test Certificate of** Issued for type tests of high voltage products ($> 1 \text{ kV}_{\text{eff}}$ $> 1,5 \text{ kV}_{\text{eff}}$), which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. The Type Test Certificate consists of documents unequivocally identifying the test object and describes all conditions under which the tests were conducted. It gives evidence of the unobjectionable behavior of the test object during the tests in line with the normative documents applied as well as of the results of successful testing.
- Test Certificate of (complete / selected) Type Tests** Issued if type tests of low voltage products ($< 1 \text{ kV}_{\text{eff}}$; $< 1,5 \text{ kV}_{\text{eff}}$) requested by the relevant product standard were passed. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.
- Certificate of Design Verification** Issued for passed design verification tests according to IEC 61439. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.
- Type Test Report** Issued for high and low voltage products if parts of selected type tests have been passed; those shall be carried out in full compliance with the relevant standards but (for high voltage products) do not fulfill all STL requirements for issuing a Type Test Certificate. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.
- Test Report** Issued for all other tests on high and low voltage products which have been carried out according to specifications, standards and/or client instructions
- On-Site Test Record** Issued as a record of results acquired during the on-site tests / measurements
- Test Award** Can be additionally issued for all named types of test documents above if the tests to be referenced were passed

Приложение 7


ВНЕШНЕ-ОРИЕНТИРОВАННОЕ
PAP 06020612 (2016.11) - CONFIDENTIAL USE



Tests witnessed by

Mr. Kolychev Alexandr

Joint-Stock Company Polymer-Apparat



Identification of the object Effected.
 The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.
 These drawings identified by CESI and numbered B6019250 No. 1 are annexed to this document.

Test evaluation
 With reference to the Standards/Specifications listed in the first page and the characteristics of the tested sample assigned by manufacturer, the carried out tests passed **SUCCESSFULLY**

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked B6018837 and in the following revisions:

Revision No.	Date	Reference

The reported expanded uncertainties are determined in accordance with the Publication JCGM 100 "Evaluation of measurement data - Guide to the expression of uncertainty in measurement" and are based on a standard uncertainty multiplied by a coverage factor $k = 2$, which for a normal distribution provides a level of confidence of approximately 95 %.

- Voltage a.c. $\pm 3,0 \%$
- Current a.c. $\pm 3,0 \%$
- Transient Recovery Voltage $\pm 5,0 \%$
- Resistance d.c. $\pm 1,5 \%$
- Inductance $\pm 1,5 \%$

Receipt date of the sample September 2016





**ВЯРНО С
ОРИГИНАЛА**

Test date	Page	Contents
September 16, 2016	5	Rated characteristics of the tested object assigned by the Client
September 16, 2016	6	Test arrangement
September 16, 2016	7	Drawing
September 16, 2016	8	Tests carried out
September 16, 2016	9	High-current short-circuit tests with 20,2 kA for 0,23 s
September 16, 2016	10	High-current short-circuit tests with 6,06 kA for 0,22 s
September 16, 2016	11	Low-current short-circuit tests with 602 A for 1,01 s
September 16, 2016	12	Test circuits
	13 to 17	Photos Pages annexed Oscillograms B6018837 (No. 7 pages)



Manufacturer	Joint-Sveek Company, Polymer-Apparnt PA-DH
Type	
Drawing	
Rated voltage (U _n)	54,0 kV
Maximum continuous operating voltage (U _c)	43,2 kV
Rated frequency	50/60 Hz
Nominal discharge current (8/20 μs impulse shape)	10 kA
Arrestor classification	DH
Rated short circuit current	
High current	for 0,20 s : 20,0 kA
Low current	for 1,00 s : 0,6 kA


[Handwritten signature]



**ВЯРНО С
ОРИГИНАЛА**



D8858 - Test arrangement






- 1: Surge arrester
 - 2: Flexible conductor
 - 3: Flexible conductor
 - 4: Not metallic pole
 - 5: Enclosure
- A: 1,00 m
B: 0,4 m
C: 1,80 m

The arrester to be tested was installed by means of a crossarm on a not metallic pole at 0,4 m to ground in the middle of a square enclosure of 1,80 m in side.
The live side of the supply was connected to the upper end of the arrester while the return circuit, earthed, was connected to the lower end.
The live conductor was directed to the opposite direction as the earth conductor

[Handwritten signature]



D12321G



№	№	№
1	104 079 105 002 07 8	
2	104 079 105 002 01 7	
3	104 079 105 002 03 6	

1. Все работы выполнены. Все документы на объекте.

№	№	№
1	104 079 105 002 07 8	
2	104 079 105 002 01 7	
3	104 079 105 002 03 6	

Test Report



B6020612

Approved

Page 7

D12321G



High-current short-circuit tests with 12,1 kA for 0,22 s

Test circuit: Sec D0046 Power factor: <0,15 Frequency: 50 Hz

No.	Sheets	Prospective test current	
		rms value	Peak value
6	1	12,6	33,7

Under test surge arrester PA-DH Type

Test arrangement: Sec D0058

A photo detector was used to determine the venting time. In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.

The short-circuit current of the auxiliary low power source has been set at about 10 A. The voltage applied to the arrester was 63 kV and kept at this value or slightly adjusted till arrester failure. The pre-failure process duration was 3 minutes and 12 seconds. The short-circuit test was performed 5 minutes and 40 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new

Date: September 16, 2016

Test	Oscillogram	Arrester under test	Duration	Test voltage	Test current		Time to flame extinction after the test	Venting time	Notes
					Peak value	rms value			
2	10	No. 3509	0,22	36,0	28,3	12,1	5,7		

Condition of the apparatus after the tests:

- there was not violent shattering
- the arrester was found broken in two parts
- the arrester remained connected to the supply and return circuit
- some blocks fragment were found inside the enclosure. Polymer fragments found inside and outside the enclosure
- no flame was noted

Acceptance criteria according to clause 8.7.6: Satisfied

Test result: Positive

Test Report



B6020612

Approved

Page 9

298

D12321G

High-current short-circuit tests with 6,06 kA for 0,22 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz



Oscillogram		Prospective test current	
No.	Sheets	rms value kA	Peak value kA
11	1	6,23	16,5

Under test Surge arrester PA-DH Type

Test arrangement : See D8058

A photo detector was used to determine the venting time
In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.

The short-circuit current of the auxiliary low power source has been set at about 10 A.
The voltage applied to the arrester was 63 kV and kept at this value or slightly adjusted till arrester failure.
The pre-failure process duration was 4 minutes and 05 seconds
The short-circuit test was performed 4 minutes and 55 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new

Date: September 16, 2016

Test	Oscillogram		Arrester under test	Duration	Test voltage	Test current		Time to flame extinction after the test	Venting time	Notes
	No.	Sheets				Peak value kA	rms value kA			
3	13	1	3510	0,22	36,0	13,8	6,06	-	6,1	-

Condition of the apparatus after the tests:

- there was not violent shattering
 - the arrester structure remained intact
 - the arrester remained connected to the supply and return circuit
 - no fragment were found inside or outside the enclosure
 - no flame was noted
- Acceptance criteria according to clause 8.7.6: Satisfied
Test result: Positive

Test Report

CESI

Approved

B6020612

Page 10

D12321G

Low-current short-circuit tests with 602 A for 1,01 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz



Oscillogram		Prospective test current	
No.	Sheets	rms value kA	Peak value kA
-	-	-	-

Under test surge arrester PA-DH Type

Test arrangement : See D8058

A photo detector was used to determine the venting time
In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.

The short-circuit current of the auxiliary low power source has been set at about 10 A.
The voltage applied to the arrester was 63 kV and kept at this value or slightly adjusted till arrester failure.
The pre-failure process duration was 5 minutes and 30 seconds
The short-circuit test was performed 5 minutes and 25 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new

Date: September 16, 2016

Test	Oscillogram		Arrester under test	Duration	Test voltage	Test current		Time to flame extinction after the test	Venting time	Notes
	No.	Sheets				Peak value kA	rms value A			
4	15	1	3511	1,01	36,0	1,19	602	25	8,30	-

Condition of the apparatus after the tests:

- there was not violent shattering
 - the arrester structure remained intact
 - the arrester remained connected to the supply and return circuit
 - no fragment were found inside or outside the enclosure
 - the flame self-extinguished after 25 seconds
- Acceptance criteria according to clause 8.7.6: Satisfied
Test result: Positive

Test Report

CESI


Approved

B6020612

Page 11


295

Test circuit D0046



Symbols used in this diagram are the same as those on the oscillograms.

ВРЪНО С
ОПТИКАЛА



D0046G




Photo No.1
Before test No.1



CESI

Test Report

Approved




Photo No.4
After the test No.2




Photo No.5
After the test No. 2



ACCREDITED
BY THE NATIONAL ACCREDITED
LAB IN GERMANY

D1091IG

CESI

Test Report

Approved




Photo No.2
After test No. 1





Photo No.3
After the test No.1



ACCREDITED
BY THE NATIONAL ACCREDITED
LAB IN GERMANY

ВЯРНО С
ОРИГИНАЛА



D1091IG




Photo No.8
After the test No.4




Photo No.9
After the test No.4



ACCREDIA S.p.A.
CONTRATTI PUBBLICI E ACCREDITAMENTO
L. 14/11/2008




Photo No.6
After the test No.3



Photo No.7
After the test No.3



ACCREDIA S.p.A.
CONTRATTI PUBBLICI E ACCREDITAMENTO
L. 14/11/2008


ВЯРНО С
ОРИГИНАЛА



D10911G

D10911G

106




ВЯРНО
ОРИГИНАЛ

I_{peak} = 55,78 kA
I_{rms} = 21,02 kA

U 30 kV


I 35 kA

VENT 5 V



CESI P141 B6018837, Oscill. No. 0003


Seq: 1560 Osc: SCARICATORI Meas: HF1 - 1



I_{peak} = 46,85 kA
dT = 4,2 mSec
dT = 225,8 mSec

CESI P141 B6018837, Oscill. No. 0005

Seq: 1560 Osc: SCARICATORI Meas: HF1 - 1




ВАРНО С
ОРИГИНАЛА

U 30 kV

I 15 kA

VENT 5 V



CESI P141 B6018837, Oscill. No. 0006


Seq: 15EC Osc: SCARCATOR1 Mess: HF1-1

I_{peak} = 28,29 kA
dT = 223,4 mSec
dT = 5,7 mSec

U 30 kV


I 15 kA

VENT 5 V



CESI P141 B6018837, Oscill. No. 0010

Seq: 15ED Osc: SCARCATOR1 Mess: HF1-1




ВЕРНО С
ОРИГИНАЛА

U 30 kV

I 6 kA

VENT 5 V



CESI P141 B6018837, Oscill. No. 0011


2,000 (msec/div.)

Seq: 1SEC Osc: SCARICATORI Meas: HF1 - 1

U 30 kV

I 6 kA

VENT 5 V



I_{peak} = 13,82 kA
dT = 222,6 mSec
dT = 6,1 mSec

CESI P141 B6018837, Oscill. No. 0013

2,000 (msec/div.)



Seq: 1SEC Osc: SCARICATORI Meas: HF1 - 1

ВЕРНО
СЕРТИФИКАТ

Handwritten signature

Seq: 15EC Osc: SCARICATOR! Meas: HF1 - 1

I_{peak} = 1,19 kA
dT = 8,3 mSec
dT = 1,006 Sec



Handwritten signature

U 30 kV

I 0.70 kA

VENT 5V

CESI P141 B6018837, Oscill. No. 0015

Test Report

Document No. B6020613 Copy No. 1 Number of pages 24

Apparatus Polymeric housing surge arresters

Designation PA-DH

Serial Number 3508-3509-3510-3511

Manufacturer JSC "Polymer-Apparat"

Client JSC "Polymer-Apparat"
Ak. Konstantinova Str., 1
195427 Saint-Petersburg - Russia Federation

Tested for -

Date(s) of tests September 16, 2016

Tested by CESI S.p.A.
Via Rubattino, 54
20134 Milano - Italy

Test performed Short circuit tests

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with:
IEC 60099-4 (2014-06)


The results are shown in the record of proving tests and the certificates attached hereto. The general performance is confirmed as mentioned above. The equipment is approved for use in the voltage range assigned by the manufacturer and listed on the rating tags. The equipment applies only to the evaluation test. The responsibility for conformity of any other manufacturer.

September 16, 2016

Giozzi Giuseppe
Test Engineer in charge

The laboratory meets the requirements of the Standard EN ISO/IEC 17025 for the calibration of surge arresters. The in-charge status of the accreditation and the list of accredited tests may be checked in the VFD file: www.cesi.it

ACCREDIA
LAB N° 0030



Trust the Power of Experience

Notes

STL Member
CESI Group members are founder members of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in 1969. STL is a forum for voluntary international cooperation of testing organizations.

CESI Group Test Documents description

Type Test Certificate of ...
Issued for type tests of high voltage products ($> 1 \text{ kV}_{\text{eff}}$ $> 1.5 \text{ kV}_{\text{eff}}$), which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. The Type Test Certificate consists of documents unequivocally identifying the test object and describes all conditions under which the tests were conducted. It gives evidence of the unobjectionable behavior of the test object during the tests in line with the normative documents applied as well as of the results of successful testing.

Type Certificate of (complete / selected) Type Tests
Issued for type tests of low voltage products ($< 1 \text{ kV}_{\text{eff}}$ $< 1.5 \text{ kV}_{\text{eff}}$) requested by the relevant product standard were passed. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Certificate of Design Verification
Issued for passed design verification tests according to IEC 61439. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Type Test Report
Issued for high and low voltage products if parts of selected type tests have been passed; those shall be carried out in full compliance with the relevant standards but (for high voltage products) do not fulfill all STL requirements for issuing a Type Test Certificate. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Test Report
Issued for all other tests on high and low voltage products which have been carried out according to specifications, standards and/or client instructions

On-Site Test Record

Issued as a record of results acquired during the on-site tests / measurements
Test Award
Can be additionally issued for all named types of test documents above if the tests to be referenced were passed

CONFIDENTIAL USE (239/173) - B6020613

Contents	Page	Test date
Rated characteristics of the tested object assigned by the Client	5	
Test arrangement	6	
Drawing	7	
Tests carried out	8	September 16, 2016
High-current short-circuit tests with 20,2 kA for 0,23 s		
High-current short-circuit tests with 12,1 kA for 0,22 s		
High-current short-circuit tests with 6,05 kA for 0,22 s		
Low-current short-circuit tests with 602 A for 1,01 s		
Test circuits	11	September 16, 2016
Photos	12	
Pages annexed	13 to 17	
Oscillograms B6018837 (No.7 pages)		

B6020613

Page 3

CESI

Approved

Test Report

Tests witnessed by

Mr. Kolychev Alexandr

Joint-Stock Company Polymer-Apparat

Identification of the object Effected.
 The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.
 CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.
 These drawings identified by CESI and numbered B6019250 No. 1 are annexed to this document.

Test evaluation
 With reference to the Standards/Specifications listed in the first page and the characteristics of the tested sample assigned by manufacturer, the carried out tests passed **SUCCESSFULLY**

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked B6018837 and in the following revisions:

Revision No.	Date	Reference

The reported expanded uncertainties are determined in accordance with the Publication JCGM 100 "Evaluation of measurement data - Guide to the expression of uncertainty in measurement" and are based on a standard uncertainty multiplied by a coverage factor $k = 2$, which for a normal distribution provides a level of confidence of approximately 95 %.


- Voltage a.c. $\pm 3,0 \%$
- Current a.c. $\pm 3,0 \%$
- Transient Recovery Volting $\pm 3,0 \%$
- Resistance d.c. $\pm 1,5 \%$

September 2016

Receipt of the sample



D8058 - Test arrangement



- A : 1,00 m
- B : 0,4 m
- C : 1,80 m

- 1 : Surge arrester
- 2 : Flexible conductor
- 3 : Flexible conductor
- 4 : Not metallic pole
- 5 : Enclosure

The arrester to be tested was installed by means of a crossarm on a not-metallic pole at 0,4 m to ground in the middle of a square enclosure of 1,80 m in side.
 The live side of the supply was connected to the upper end of the arrester while the return circuit, earthed, was connected to the lower end.
 The live conductor was directed to the opposite direction as the earth conductor



Manufacturer	Joint-Stock Company Polymer-Apparat PA-DH
Type	
Drawing	
Rated voltage (Ur)	54,0 kV
Maximum continuous operating voltage (Uc)	43,2 kV
Rated frequency	50/60 Hz
Nominal discharge current (S/20 is impulse shape)	10 kA
Arrester classification	DH
Rated short circuit current	
High current	for 0,20 s : 20,0 kA
Low current	for 1,00 s : 0,6 kA

ВЯРНО С
ОРИГИНАЛА



[Handwritten signature]

Condition of the apparatus after the tests:

- there was not violent shattering
- the arrester structure remained intact
- the arrester remained connected to the supply and return circuit
- no fragments were found inside or outside the enclosure
- no flame was noted

Acceptance criteria according to clause 8.7.5: Satisfied

Test result: Positive

Test	Oscillogram	Arrester under test	Duration	Test voltage	Peak value	Test current rms value	Time to flame extinction after the test	Veiling time	Notes
1	5	1	3508	0.23	36.0	46.9	20.3	ms	4.2
No.	Sheets	No.	s	kV	kA	kA	ms		

Date: September 16, 2016

Condition of the apparatus before the tests: rev

The short-circuit test was performed 6 minutes and 10 sec after the completion of the pre-failure process. The pre-failure process duration was 7 minutes and 45 seconds. The voltage applied to the arrester was 63 kV and kept at this value or slightly adjusted till arrester failure. The short-circuit current of the auxiliary low power source has been set at about 10 A.

A photo detector was used to determine the veiling time. In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.

Under test surge arrester PA-DH Type

Prospective test current	Oscillogram	No. Sheets	No.
kA	kA	1	3
Peak value	rms value		
55.8	21.0		

Test circuit: See D0046 Power factor: <0.15 Frequency: 50 Hz

High-current short-circuit tests with 20.2 kA for 0.23 s



D123210



№ п/п	Наименование	Материал	Масса	Объем	Длина	Ширина	Толщина
1	Полоса стальная	Сталь	0.020	0.001	0.001	0.001	0.001
2	Полоса стальная	Сталь	0.020	0.001	0.001	0.001	0.001
3	Полоса стальная	Сталь	0.020	0.001	0.001	0.001	0.001
4	Полоса стальная	Сталь	0.020	0.001	0.001	0.001	0.001

Всего просуммировано: 4

№ п/п	Наименование	Материал	Масса	Объем	Длина	Ширина	Толщина
1	Полоса стальная	Сталь	0.020	0.001	0.001	0.001	0.001
2	Полоса стальная	Сталь	0.020	0.001	0.001	0.001	0.001
3	Полоса стальная	Сталь	0.020	0.001	0.001	0.001	0.001
4	Полоса стальная	Сталь	0.020	0.001	0.001	0.001	0.001



D123210


ВЕРНО С
ОРИГИНАЛОМ



[Handwritten signature]


408

D12321G



High-current short-circuit tests with 12,1 kA for 0,22 s

Test circuit: See D0046 Power factor: <0,15 Frequency: 50 Hz



Prospective test current			
Oscillogram		rms value	Peak value
No.	Sheets	kA	kA
6	1	12,6	33,7

Under test surge arrester PA-DH Type

Test arrangement: See D8058

A photo detector was used to determine the venting time in order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.

The short-circuit current of the auxiliary low power source has been set at about 10 A. The voltage applied to the arrester was 63 kV and kept at this value or slightly adjusted till arrester failure. The pre-failure process duration was 3 minutes and 12 seconds. The short-circuit test was performed 5 minutes and 40 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new

Date: September 16, 2016

Test	Oscillogram		Arrester under test	Duration	Test voltage	Test current		Time to flame extinction after the test	Venting time	Notes
	No.	Sheets				Peak value	rms value			
			No.	s	kV	kA	kA	s	ms	No.
2	10	1	3509	0,22	36,0	28,3	12,1	-	5,7	-

Condition of the apparatus after the tests:

- there was not violent shattering
 - the arrester was found broken in two parts
 - the arrester remained connected to the supply and return circuit
 - some blocks fragment were found inside the enclosure. Polymer fragments found inside and outside the enclosure
 - no flame was noted
- Acceptance criteria according to clause 8.7.6: Satisfied
Test result: Positive

Test Report

CESI

Approved

B6020613

Page 9

D12321G



High-current short-circuit tests with 6,06 kA for 0,22 s

Test circuit: See D0046 Power factor: <0,15 Frequency: 50 Hz

Prospective test current			
Oscillogram		rms value	Peak value
No.	Sheets	kA	kA
11	1	6,23	16,5

Under test Surge arrester PA-DH Type

Test arrangement: See D8058

A photo detector was used to determine the venting time in order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.

The short-circuit current of the auxiliary low power source has been set at about 10 A. The voltage applied to the arrester was 63 kV and kept at this value or slightly adjusted till arrester failure. The pre-failure process duration was 4 minutes and 05 seconds. The short-circuit test was performed 4 minutes and 55 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new

Date: September 16, 2016

Test	Oscillogram		Arrester under test	Duration	Test voltage	Test current		Time to flame extinction after the test	Venting time	Notes
	No.	Sheets				Peak value	rms value			
			No.	s	kV	kA	kA	s	ms	No.
3	13	1	3510	0,22	36,0	13,8	6,06	-	6,1	-

Condition of the apparatus after the tests:

- there was not violent shattering
 - the arrester structure remained intact
 - the arrester remained connected to the supply and return circuit
 - no fragment were found inside or outside the enclosure
 - no flame was noted
- Acceptance criteria according to clause 8.7.6: Satisfied
Test result: Positive

Test Report

CESI

Approved

B6020613


Page 10

305

D1232IG

Low-current short-circuit tests with 602 A for 1,01 s

Test circuit : See D0046 Power factor : $\lt;0,15$ Frequency : 50 Hz



Oscillogram		Prospective test current	
No.	Sheets	rms value kA	Peak value kA
-	-	-	-

Handwritten signature or scribble.

Under test surge arrester PA-DII-150

Test arrangement : See D8058

A photo detector was used to determine the venting time

In order to achieve the internal discharge the surge arrester has been electrically pre-filled by means of a power frequency over-voltage application using an auxiliary low power source.

The short-circuit current of the auxiliary low power source has been set at about 10 A.

The voltage applied to the arrester was 63 kV and kept at this value or slightly adjusted till arrester failure.

The pre-failure process duration was 5 minutes and 30 seconds

The short-circuit test was performed 5 minutes and 25 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new

Date: September 16, 2016

Test	Oscillogram		Arrester under test	Duration	Test voltage	Test current		Time to flame extinction after the test	Venting time	Notes
	No.	Sheets				Peak value	rms value			
4	15	1	3511	1,01	36,0	1,19	602	25	8,30	-

Condition of the apparatus after the tests:

- there was not violent shattering
- the arrester structure remained intact
- the arrester remained connected to the supply and return circuit
- no fragment were found inside or outside the enclosure
- the flame self-extinguished after 25 seconds

Acceptance criteria according to clause 8.7.6: Satisfied

Test result: Positive

Test Report

CESI


B6020613

Approved

Page 11

D0046IG

Symbols used in this diagram are the same as those on the oscillograms.



Test circuit D0046

Test Report

CESI

Approved

B6020613
Page 12



Handwritten signature.




Photo No. 2
After test No. 1




Photo No. 3
After the test No. 1



D10911G

[Handwritten signature]




Photo No. 1
Before test No. 1

**ВЯРНО С
ОРИГИНАЛА**



D10921G

307




Photo No. 6
After the test No.3




Photo No. 7
After the test No.3





Photo No. 4
After the test No. 2



Photo No. 5
After the test No. 2



[Handwritten signature]



ВЯРНО С
ОРИГИНАЛА

D10910

D10910

208

[Handwritten signature]




Photo No. 8
After the test No. 4






Photo No. 9
After the test No. 6



ВЯРНО С
ОРИГИНАЛА



ACCREDIA S.p.A.
CONFORME ALLA NORMA UNI EN ISO 9001

I_{peak} = 59,79 kA
I_{rms} = 21,03 kA






[Handwritten signature]




ВЯРНО С ОРИГИНАЛА

25437 40.000 60.000 80.000 100.000 120.000 140.000 160.000 180.000 200.000 220.000 240.000 260.000 280.000 293.333



Handwritten signature


26413 40.000 60.000 80.000 100.000 120.000 140.000 160.000 180.000 200.000 220.000 240.000 260.000 280.000 293.150






Handwritten signature

Handwritten signature

ВЕРНО С
ОРИГИНАЛОМ





ВЯРНО
ОРИГОНАЛ

Test Report

Document No.	B7024813	Copy No.	1	Number of pages	96
Apparatus	Polymer-housed surge arrester section type PA-DH section 5T with additional thermal insulation				
Designation	---				
Serial Number	---				
Manufacturer	Joint-Stock Company "Polymer-Apparat"				
Client	Joint-Stock Company "Polymer-Apparat" Ak. Kostantynova str.,1 195427 Saint-Petersburg - Russia Federation				
Tested for	---				
Date(s) of tests	December 4 - 14, 2017				
Tested by	CESI S.p.A. Via Rubattino, 54 20134 Milano - Italy				
Test performed	Power-frequency voltage-versus-time test				

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with IEC 60099-4 - Edition 3.0 (2014-06)

The results are shown in the record of proving tests and the oscillograms attached hereto. The ratings assigned by the Manufacturer are listed on the ratings paper. The document applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the Manufacturer.

December 21, 2017

Date: _____
 Test Engineer in charge: **Gregorio Marro**
 The Manager - **Ardiasco Lorenzo**
 Approved By: **Document Digitally Signed**

Partial reproduction of this document is permitted only with the written permission from CESI Group. The authenticity of this document is guaranteed by the integrity of the signature.

The laboratory meets the requirements of the Standard EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing and Calibration Laboratories". The full text of the Standard may be checked in the WEB site: www.accredia.it




CESI

Trust the Power of Experience

Notes

- STL-Member**
CESI Group members are founder members of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in 1969. STL is a forum for voluntary international cooperation of testing organizations.
- CESI Group Test Documents description**
Type Test Certificate of
Issued for type tests of high voltage products ($\geq 1 \text{ kV}_{ac}$ > 1.5 kV_{ac}), which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. The Type Test Certificate consists of documents unequivocally identifying the test object and describes all conditions under which the tests were conducted. It gives evidence of the unobjectionable behavior of the test object during the tests in line with the normative documents applied as well as of the results of successful testing.
- Test Certificate of (complete / selected) Type Tests**
Issued for type tests of low voltage products ($< 1 \text{ kV}_{ac}$ < 1.5 kV_{ac}) requested by the relevant product standard were passed. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.
- Certificate of Design Verification**
Issued for passed design verification tests according to IEC 61439. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.
- Type Test Report**
Issued for high and low voltage products if parts of selected type tests have been passed; those shall be carried out in full compliance with the relevant standards but (for high voltage products) do not fulfill all STL requirements for issuing a Type Test Certificate. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.
- Test Report**
Issued for all other tests on high and low voltage products which have been carried out according to specifications, standards and/or client instructions
- On-Site Test Report**
Issued as a record of results acquired during the on-site tests / measurements
- Test Award**
Can be additionally issued for all named types of test documents above if the tests to be referenced were passed

CONFIDENTIAL USE
 PAB B7024813 (24/139)
 ОРИГИНАЛ



Test Report

Tests witnessed by:

Identification of the object: Effected

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawing, identified by CESI and numbered B7026212 No. 1, is annexed to this document.

Test evaluation

With reference to the Standards/Specifications listed in the first page and the characteristics of the tested sample assigned by manufacturer, the carried out tests passed **SUCCESSFULLY**.

The data necessary to permit repetition of the tests are contained in the document marked: —


The reported expanded uncertainties are determined in accordance with the Publication JCGM 100 "Evaluation of measurement data - Guide to the expression of uncertainty in measurement" and are based on a standard uncertainty multiplied by a coverage factor k = 2, which for a normal distribution provides a level of confidence of approximately 95 %.

- Voltage a.c. : ± 3,0 %
- Residual peak voltage (impulse tests) : ± 3,0 %
- Current a.c. : ± 3,0 %
- Peak current (impulse tests) : ± 3,0 %
- Time (impulse tests) : ± 10,0 %
- Time (a.c. tests) : ± 1,5 %

Laboratory information

Receipt date of the sample September 2017

Test location CESI - Via Rubattino 54 - Milan
 Test laboratory Mr L. Podavizze
 P177
 70006781



A1001G rev.2

Test object characteristics	Page	test date
Photograph of the test object	5	
Reference standard	6	
Test carried out	7	
Test object identification	7	
Test procedure	7	
Summary of test results	8	
Initial test	9	
Voltage correction factor and thermal energy calculations	10 to 11	December 4, 2017
With prior duty test	12	December 12, 2017
Without prior duty test	13 to 16	December 12, 2017
Test evaluation	17 to 18	December 13, 2017
Technical data of the test circuit	19 to 20	December 13-14, 2017
Pages annexed:	21 to 25	

Client's drawing (Polymer-housed metal-oxide surge arrester section) - CESI no. B7026212 - no. 1 page
 Client's drawing (MFO resistor) - CESI no. B7024038 - no. 1 page
 Technical document (TOV curve) CESI No. B7026211 - n.1 page

Handwritten signature



A1002IG rev.1

**ВАРНО С
ОРИГИНАЛА**

Photographs of the test object




Photo no. 1




Photo no. 2

Polymer-housed surge arrester section type PA-DH section ST with additional thermal insulation




Test object characteristics (assigned by the client)

Manufacturer's name	Joint-Stock Company "Polymer-Apparat"
Polymer-housed surge arrester section type	PA-DH section ST
MO-resistor supplier's	Joint-Stock Company "Polymer-Apparat"
Metal-oxide resistor type	B41/30
Arrester class	Distribution
Designation	DH
Number of MO resistor fitted	1
Nominal discharge current - [kA]	10
Rated voltage - U _r [kV]	1,011 x U _{ref}
Continuous operating voltage - U _c [kV]	0,809 x U _{ref}
Repetitive charge transfer rating - Q _a [C]	0,5
Rated thermal charge transfer rating - Q _{th} [C]	1,1
Reference current - I _{ref} [mA]	1,5
Rated frequency - [Hz]	48-62
Year of manufacture	08/2017

geometrical characteristics on the MO resistor

Total height [mm]	29,50 mm
Diameter [mm]	41,80 mm

ВАРЖЕНО С ОПРАТНАТА



A11761G

A1267G



Reference Standard


IEC 60099-4 (2014/06) - Edition 3 - Clause 10.8.8. "Metal-oxide surge arresters without gaps for a.c. system"

Test carried out	Number of sample tested
Power-frequency voltage-versus-time test	6

Test object identification

Test object name	Identification of test sample (given by CESI)	Identification of test sample (given by JSC "Polymer Apparatus")
Polymer-housed surge arrester section type PA-DH section ST with additional thermal insulation	TOV1	00016
	TOV2	00037
	TOV3	00040
	TOV4	00057
	TOV5	00082
	TOV6	00089

ВЪРНО С ОПИТНАТА



Handwritten signature and date 21.6



ACCREDITIA S
LAW 14/2003

Test procedure

1. Test performed on Polymer-housed metal-oxide surge arrester section in open air

The test procedure consisted of the following sequence:
Initial test

- a) Measurement of the lightning impulse residual voltage at the nominal discharge current
- b) Measurement of the power frequency reference voltage at the reference current

2. Test performed on Polymer-housed metal-oxide surge arrester section assembled in thermal model

Test with energy input (prior duty test)

- e) The surge arrester sections were kept in an oven at the temperature of 65 °C till thermal equilibrium (not more than twenty hours)
- d) Injection of two lightning current impulses 8/20 μs at the rated thermal charge transfer Q_{th} . A time shorter than 100 ms after the application of the second second lightning current impulses 8/20 μs energization at U_{rov} (declared by the manufacturer) for a time t_{rov} (declared by the manufacturer) and then at U_r for 30 min. to verify the thermal stability.

Four samples were tested as specified below:

Sample	U_{rov}	Duration	Note
TOV1	$1,080 \times U_r$	1 sec	prior duty test
TOV2	$1,040 \times U_r$	10 sec	
TOV3	$1,000 \times U_r$	100 sec	
TOV4	$0,960 \times U_r$	1000 sec	

Test without energy input (no-prior duty test)

- e) The surge arrester sections were kept in an oven at the temperature of 65 °C till thermal equilibrium (not more than twenty hours)
- f) Application of the overvoltage U_{rov} (declared by the manufacturer) for a time t_{rov} (declared by the manufacturer) and then at U_r for 30 min. to verify the thermal stability.

Two samples were tested as specified below:

Sample	U_{rov}	Duration	Note
TOV5	$1,130 \times U_r$	10 sec	no-prior duty test
TOV6	$1,040 \times U_r$	1000 sec	

3. Test performed on Polymer-housed metal-oxide surge arrester section in open air

- b) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value
- f) After that the sample has cooled to ambient temperature and two current impulses 8/20 at 0.5 kA/cm² have been applied to check the integrity of the internal parts. The interval between impulses was 50-60 seconds.

Test result

The visual inspection of the sample after the test has revealed no sign of physical damage. The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%). During the two last impulses the oscillograms not reveal any breakdown. The thermal stability was achieved.

Handwritten signature

The acceptance criteria are fulfilled. The test result is positive.



ACCREDITIA S
LAW 14/2003

Power frequency voltage versus time test.

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: December 4, 2017

sample	before test		after test		Variation %
	discharge current kA	residual voltage kV	discharge current kA	residual voltage kV	
TOV1	10,11	13,37	10,09	13,56	+1,42
TOV2	10,12	13,37	10,20	13,54	+1,27
TOV3	10,15	13,38	10,11	13,61	+1,72
TOV4	10,18	13,28	10,19	13,43	+1,13
TOV5	10,06	13,24	10,08	13,32	+0,60
TOV6	10,09	13,49	10,08	13,50	+0,10

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА



ACCREDIA S
L'UNO TRUOVO D'AZZERAMENTO
L&E H. 0020

A1176G

317

Power frequency voltage versus time test.

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: December 4, 2017

Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current kA	Residual Voltage kV
TOV1	I _b	25,1	1	8,6/18,2	10,11	13,37
TOV2		25,1	2		10,12	13,37
TOV3		25,1	3		10,15	13,58
TOV4		25,1	4		10,18	13,28
TOV5		25,0	5		10,06	13,24
TOV6		25,1	6		10,09	13,49

Notes:

[Handwritten signature]



ACCREDIA S
L'UNO TRUOVO D'AZZERAMENTO
L&E H. 0020

A1176G

Test Report


Power frequency voltage versus time test.

Reference voltage test.

Test circuit: A0019

Date: December 4, 2017

Sample No. TOV1						
oscillogram No.	voltage kV	current + mA _{ar}	current - mA _{ar}	power W	3rd harmonic amplitude μA	
7	5.37	1.28	1.50	0.771	2.02	—
Sample No. TOV2						
oscillogram No.	voltage kV	current + mA _{ar}	current - mA _{ar}	power W	3rd harmonic amplitude μA	
8	5.38	1.31	1.50	0.775	2.05	—
Sample No. TOV3						
oscillogram No.	voltage kV	current + mA _{ar}	current - mA _{ar}	power W	3rd harmonic amplitude μA	
9	5.35	1.37	1.50	0.788	2.13	—
Sample No. TOV4						
oscillogram No.	voltage kV	current + mA _{ar}	current - mA _{ar}	power W	3rd harmonic amplitude μA	
10	5.31	1.32	1.50	0.779	2.07	—
Sample No. TOV5						
oscillogram No.	voltage kV	current + mA _{ar}	current - mA _{ar}	power W	3rd harmonic amplitude μA	
11	5.29	1.34	1.50	0.782	2.09	—
Sample No. TOV6						
oscillogram No.	voltage kV	current + mA _{ar}	current - mA _{ar}	power W	3rd harmonic amplitude μA	
12	5.41	1.37	1.50	0.780	2.11	—



ACCREDIA S.p.A.
SISTEMI DI CERTIFICAZIONE
Via V. Veneto

Test Report

Power frequency voltage versus time test.

Voltage correction factor and thermal energy calculations

Date: December 12, 2017

Sample No.	U _{ar} [1] kV	KU, [2]	KU _c [3]	U _i [4] kV	U _i [5] kV
TOV1	5.37			5.429	4.344
TOV2	5.38			5.439	4.352
TOV3	5.35	1.011	0.809	5.409	4.328
TOV4	5.31			5.368	4.296
TOV5	5.29			5.348	4.280
TOV6	5.41			5.470	4.377

- [1] U_{ar} : measured reference voltage
- [2] KU : maximum guaranteed factor for calculation of U_i - U_i/U_{ar,min}
- [3] KU_c : maximum guaranteed factor for calculation of U_c - U_c/U_{ar,min}
- [4] U_i : corrected rated voltage [4] = [1] × [2]
- [5] U_c : corrected continuous operating voltage [5] = [1] × [3]

Sample No.	U _i kV	Requested thermal charge transfer, Q _{th} C	Requested Q _{th} per impulse C
TOV1	5.429		0.55 (±10%)
TOV2	5.439	1.1	0.55 (±10%)
TOV3	5.409		0.55 (±10%)
TOV4	5.368		0.55 (±10%)

[Handwritten signature]



ACCREDIA S.p.A.
SISTEMI DI CERTIFICAZIONE
Via V. Veneto

ВЯРЛО С ОРЪЖИ

Test Report

Power frequency voltage versus time test.

Application of two lightning current impulses 8/20µs, corrected rated voltage U_r and corrected continuous operating U_c for evaluation of the thermal stability.

Test circuit: A0123-A0070-A0131

Sample No.: TOV 1

Ambient temperature: 20 °C
Preheating temperature: 65 °C

Date: December 12, 2017

Lightning current impulses 8/20 µs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q_h C	Applicable range for Q_h C
13	1	65.0 x 2	—	38,60	0,56	0,495±0,605
14	2	65.0 x 2	—	38,46	0,56	0,495±0,605

Current impulse waveshape

8,8/18,2

Temporary overvoltage application

Amplitude claimed by the manufacturer $U_r \times 1,080 = 5,429 \times 1,080 = 5,863$ kV
Duration claimed by the manufacturer 1 sec.

Oscillogram No.	Time s	U_c kV	Current +mA _{cr}	Current -mA _{cr}	Temperature °C
15	0	5,863	78,0	115,0	—
16	1	—	68,0	84,0	—

Corrected continuous operating voltage U_c application to evaluate the thermal stability

Oscillogram No.	Time min	U_c kV	Current +mA _{cr}	Current -mA _{cr}	Power W	Temperature °C
17	0	—	0,98	0,97	0,61	—
	5	—	0,96	0,96	0,48	—
	10	—	0,94	0,96	0,43	—
18	15	4,344	0,93	0,95	0,40	—
	20	—	0,92	0,94	0,38	—
19	25	—	0,91	0,93	0,36	—
20	30	—	0,90	0,92	0,34	—

Note: Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 52II thermometer CESI no.30889

continued



Test Report

Continued

Sample No.: TOV2

Ambient temperature: 20 °C
Preheating temperature: 65 °C

Date: December 12, 2017

Lightning current impulses 8/20 µs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q_h C	Applicable range for Q_h C
20	1	65.0 x 2	—	38,18	0,55	0,495±0,605
21	2	65.0 x 2	—	38,30	0,56	0,495±0,605

Current impulse waveshape

8,8/18,2

Temporary overvoltage application

Amplitude claimed by the manufacturer $U_r \times 1,040 = 5,439 \times 1,040 = 5,656$ kV
Duration claimed by the manufacturer 10 sec.

Oscillogram No.	Time s	U_c kV	Current +mA _{cr}	Current -mA _{cr}	Temperature °C
22	0	5,656	24,6	51,0	—
23	10	—	10,0	17,0	—

Corrected continuous operating voltage U_c application to evaluate the thermal stability

Oscillogram No.	Time min	U_c kV	Current +mA _{cr}	Current -mA _{cr}	Power W	Temperature °C
24	0	—	1,05	1,04	0,70	—
	5	—	0,99	0,99	0,49	—
	10	—	0,92	0,98	0,45	—
25	15	4,352	0,97	0,97	0,41	—
	20	—	0,96	0,96	0,38	—
	25	—	0,95	0,95	0,36	—
26	30	—	0,94	0,94	0,35	—

Note: Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 52II thermometer CESI no.30889

continued



Continued
 Sample No.: TOV4
 Ambient temperature: 20 °C
 Preheating temperature: 65 °C
 Date: December 13, 2017

Lightning current impulses 8/20 μs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q _{th} C	Applicable range for Q _{th} C
34	1	65.0 x 2	---	38.74	0.56	0.495-0.605
35	2	65.0 x 2	---	38.20	0.56	0.495-0.605

Current impulse waveshape (μs)	8.8/18.2
--------------------------------	----------

Temporary overvoltage application


Amplitude claimed by the manufacturer U_r x 0.960 = 5,368 x 0.960 = 5,153 kV
 Duration claimed by the manufacturer 1000 sec.

Oscillogram No.	Time s	U _r kV	Current + mA _{cr}	Current - mA _{cr}	Power W	Temperature °C
36	0	5,153	7.5	17.0	1.8	---
37	1000	5,153	1.3	---	---	---

Corrected continuous operating voltage U_c application to evaluate the thermal stability

Oscillogram No.	Time min	U _c kV	Current + mA _{cr}	Current - mA _{cr}	Power W	Temperature °C
38	0	---	0.99	1.01	0.46	---
	5	---	0.98	0.99	0.41	---
	10	---	0.97	0.98	0.38	---
39	15	4,296	0.96	0.97	0.35	---
	20	---	0.95	0.96	0.33	---
	25	---	0.94	0.94	0.31	---
40	30	---	0.93	0.93	0.29	---

Note: Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 52II thermometer CESI no.30889



Continued
 Sample No.: TOV3
 Ambient temperature: 20 °C
 Preheating temperature: 65 °C
 Date: December 12, 2017

Lightning current impulses 8/20 μs application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Q _{th} C	Applicable range for Q _{th} C
27	1	65.0 x 2	---	38.05	0.55	0.495-0.605
28	2	65.0 x 2	---	38.15	0.56	0.495-0.605

Current impulse waveshape (μs)	8.8/18.2
--------------------------------	----------

Temporary overvoltage application


Amplitude claimed by the manufacturer U_r x 1,000 = 5,409 x 1,000 = 5,409 kV
 Duration claimed by the manufacturer 100 sec.

Oscillogram No.	Time s	U _r kV	Current + mA _{cr}	Current - mA _{cr}	Power W	Temperature °C
29	0	5,409	19.0	36.0	6.8	---
30	100	5,409	4.5	---	---	---

Corrected continuous operating voltage U_c application to evaluate the thermal stability

Oscillogram No.	Time min	U _c kV	Current + mA _{cr}	Current - mA _{cr}	Power W	Temperature °C
31	0	---	1.02	1.04	0.58	---
	5	---	0.99	1.01	0.51	---
	10	---	0.98	1.00	0.46	---
32	15	4,328	0.97	0.99	0.44	---
	20	---	0.96	0.98	0.40	---
	25	---	0.95	0.97	0.37	---
33	30	---	0.94	0.96	0.35	---

Note: Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 52II thermometer CESI no.30889



Power frequency voltage versus time test.

Application of the temporary overvoltage U_{rov} and evaluation of thermal stability
(WITHOUT PRIOR DUTY TEST)

Test circuit: A0131-A0020

Sample No.: TOV5

Preheating temperature: 65 °C

Date: December 13, 2017

Temporary overvoltage application


Amplitude claimed by the manufacturer $U_r \times 1,130 = 5,248 \times 1,130 = 6,043$ kV
Duration claimed by the manufacturer 10 sec.

Oscillogram No.	Time s	Voltage kV	Current +mA _{cr}	Current -mA _{cr}	Power W
41	0	6,043	77,0	87,0	---
42	10		65,0	66,0	

Corrected continuous operating voltage U_c application to evaluate the thermal stability

Oscillogram No.	Time min	U_c kV	Current +mA _{cr}	Current -mA _{cr}	Power W	Temperature °C
43	0	4,280	0,84	0,86	0,40	---
44	10		0,83	0,85	0,37	
45	20		0,82	0,83	0,33	

Note: Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 52II thermometer CESI no.30889



A1176G

A1176G

821

continued

Sample No.: TOV6

Preheating temperature: 65 °C

Date: December 13, 2017

Temporary overvoltage application

Amplitude claimed by the manufacturer $U_r \times 1,040 = 5,470 \times 1,040 = 5,689$ kV
Duration claimed by the manufacturer 1000 sec.


Oscillogram No.	Time s	Voltage kV	Current +mA _{cr}	Current -mA _{cr}	Power W
46	0	5,689	13,0	13,5	---
47	1000		7,0	7,5	

Corrected continuous operating voltage U_c application to evaluate the thermal stability

Oscillogram No.	Time min	U_c kV	Current +mA _{cr}	Current -mA _{cr}	Power W	Temperature °C
48	0	4,370	0,84	0,85	0,25	---
49	10		0,81	0,82	0,20	
50	15		0,80	0,81	0,28	

Note: Before the injection of the energy, the temperature of the test sample has been checked with instrument type FLUKE 52II thermometer CESI no.30889

continued



A1176G

A1176G


Power frequency voltage versus time test.

Additional two lightning impulses residual voltage measurement for check no damage occurred during the test

Test circuit: A0120
Date: December 14, 2017

Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μs	Discharge current kA	Residual voltage kV
TOV1	6,86 (*)	20,0	57	8,6/18,3	7,25	13,07
TOV2		20,0	58		7,20	13,08
TOV3		20,0	59		7,29	13,08
TOV4		20,0	60		7,21	13,02
TOV5		20,0	61		7,28	13,07
TOV6		20,0	62		7,21	12,97
		20,0	63		7,33	12,95
		20,0	64		7,34	12,82
		20,0	65		7,40	12,84
		20,0	66		7,42	12,85
		20,0	67		7,22	13,02
		20,0	68		7,24	13,01

Notes:
Requested current = 0,5 kA/cm² x 13,72 cm² = 6,86 kA
- where 0,5 kA/cm² is peak current density
- where 10,52 cm² is surface area on the metal-oxide resistor used for this test declared by the manufacturer



Power frequency voltage versus time test.



Lightning impulse residual voltage measurement after the test

Test circuit: A0120
Date: December 14, 2017


Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μs	Discharge current kA	Residual Voltage kV
TOV1	I _g	25,0	51	8,6/18,1	10,09	13,56
TOV2		25,0	52		10,20	13,54
TOV3		25,0	53		10,11	13,61
TOV4		25,0	54		10,19	13,43
TOV5		25,0	55		10,08	13,32
TOV6		25,0	56		10,08	13,50

Notes:

ВАРНО С
ОРГАНИЗАЦИЯ



Circuit A0019



Power frequency supply

- RE - programmable supply type PACIFIC A.C. Power Source 140 ASX.; CESI no. 0560408
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system


- R - Current shunt CESI No.51120; R= 941,4 Ω
- OSC - Electro optical system HBM CESI No. 57986(Rx) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.1)

Voltage measuring system


- D - Voltage divider SAGI; CESI No.11120
- OSC - Electro optical system type HBM CESI No. 57986(Rx) - 57991 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.2)

SOFTWARE SYSTEM:

- SW - S.A.D. Surge arrester version 2.0



Circuit A0120



Impulse generator

- No. of stages - 1
- Cg - 6,64 μF
- Lc - 6 μH
- S - Spark-gap

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- OSC - Electro optical system type HBM CESI No. 57986(Rx) - 57991 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 mΩ; peak current= 250 kA
- OSC - Electro optical system HBM CESI No. 57986(Rx) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.1)


SOFTWARE SYSTEM:

- SW - S.A.D. Surge arrester version 2.0



ВЯРННО С
ОПРЕДЕЛЕНИЕ


Circuit A0123



Impulse generator circuit for injection of Q_{in}

- No. of stages 2
- C_g 2,91 μF
- L_c 12 μH
- S - spark-gap

ВЕРНИМАТО
ОПРЕДЕЛЕНИЕ




ACCREDITIA S
www.italianmetro.com
L. 10.10.2008

A0123G

A1176G

Circuit A0020



Impulse generator circuit A0123

Impulsive current measuring system

- Sh_1 - Current shunt CESI No.6042; $R = 2 \text{ m } \Omega$
- Electro optical system HBM CESI No. 57986(Rx) - 57987 (Tx)
- OSC_{2,3} - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122
- CESI No 056227- 056226 (on channel No.2)
- I - Circuit-breaker

Power frequency circuit A0131

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system HBM CESI No. 57986(Rx) - 57991 (Tx)
- OSC_{2,3} - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122
- CESI No 056227- 056226 (on channel No.2)

Current measuring system

- Sh_2 (TOV - MCOV) - Current shunt type CESI n. 058315 $R = 500 \Omega$
- Electro optical system CESI No. 57986(Rx) - 58294 (Tx)
- OSC_{2,3} - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122
- CESI No 056227- 056226 (on channel No.1)

SOFTWARE SYSTEM:

- SW - S.A.D. Surge arrester version 2.0


[Handwritten signature]




ACCREDITIA S
www.italianmetro.com
L. 10.10.2008

Test Report

Circuit A0131


CESI E7024813 Oscillogram n. 1


Power-frequency circuit

- from 380V ac power supply
- R₁ single-phase voltage regulator CORMES; power 20 kVA; voltage 380/0/4220 Vac
- R₂ single-phase voltage regulator CORMES; power 10 kVA; voltage 380/0/4220 Vac
- T₁ voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200-400 V/15-30 kV


BARRINO C
CONTRATTI S.p.A.



ACCREDIA S.p.A.
S.p.A. - Via S. Felice 10 - 00100 Roma





CESI B7024813 Oscillogram n. 3



CESI B7024813 Oscillogram n. 2


ВЯРНО С
ОРИГИНАЛА





Handwritten signature

CESI B7024813 Oscillogram n. 5





Handwritten signature

CESI B7024813 Oscillogram n. 4

Handwritten signature


ВЯРНО С
ОРЪЖИЯТА





[Handwritten signature]

CESI B7024813 Oscillogram n. 7





[Handwritten signature]

[Handwritten signature]

CESI B7024813 Oscillogram n. 6


ВЪРНО С
ОРИГИНАЛА





[Handwritten signature]


CESI B7024813 Oscillogram n. 9




CESI B7024813 Oscillogram n. 8

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛО





CESI B7024813 Oscillogram n. 11

[Handwritten signature]





CESI B7024813 Oscillogram n. 10

[Handwritten signature]

[Handwritten signature]


**ВАРНО С
ОРДИНАЛА**





[Handwritten signature]

CESI B7024813 Oscillogram n. 13





CESI B7024813 Oscillogram n. 12

[Handwritten signature]

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА





[Handwritten signature]

CESI B7024813 Oscillogram n. 15





[Handwritten signature]

CESI B7024813 Oscillogram n. 14

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА





[Handwritten signature]

CESI B7024813 Oscillogram n. 17





[Handwritten signature]

CESI B7024813 Oscillogram n. 16

[Handwritten signature]


ВЕРНО С
ОРИГИНАЛ





[Handwritten signature]

CESI B7024813 Oscillogram n. 19





CESI B7024813 Oscillogram n. 18

[Handwritten signature]

[Handwritten signature]


REPUBBLICA ITALIANA
 Ministero delle Infrastrutture e dei Trasporti
 Direzione Generale delle Ferrovie dello Stato
 Direzione Regionale
 Roma





CESI B7024813 Oscillogram n. 21

[Handwritten signature]





CESI B7024813 Oscillogram n. 20

[Handwritten signature]

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛОМ





Handwritten signature

CESI B7024813 Oscillogram n. 23





Handwritten signature

CESI B7024813 Oscillogram n. 22

Handwritten signature


ВЯРНО С
ОРИГИНАЛЕ





Handwritten signature


CESI B7024813 Oscillogram n. 25




CESI B7024813 Oscillogram n. 24


Handwritten signature

**ВЯРНО С
ОРИГИНАЛА**







CESI B7024813 Oscillogram n. 27



CESI B7024813 Oscillogram n. 26


ВЯРНО С
ОРИГИНАЛА





Handwritten signature

CESI B7024813 Oscillogram n. 29





Handwritten signature

CESI B7024813 Oscillogram n. 28

Handwritten signature


**ВЯРНО С
ОРИГИНАЛО**





[Handwritten signature]


СЭС1 В7024813 Осциллограмм n. 31




СЭС1 В7024813 Осциллограмм n. 30

ВЕРНО С
ДАТА


[Handwritten signature]





[Handwritten signature]

CESI B7024813 Oscillogram n. 33




[Handwritten signature]

CESI B7024813 Oscillogram n. 32

[Handwritten signature]




**ВЯРНО С
ОРИГИНАЛА**




[Handwritten signature]

СЭСІ В7024813 Осциллограмм n. 31




СЭСІ В7024813 Осциллограмм n. 30

ВЕРНО С
ПРОВЕРКА




[Handwritten signature]

[Handwritten signature]



Handwritten signature

CESI B7024813 Oscillogram n. 37





Handwritten signature

CESI B7024813 Oscillogram n. 36

Handwritten signature


ВЕРНО
ОРИГИНАЛ





CESI B7024813 Oscillogram n. 39

[Handwritten signature]





CESI B7024813 Oscillogram n. 38

[Handwritten signature]

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА





CESI B7024813 Oscillogram n. 41

[Handwritten signature]





CESI B7024813 Oscillogram n. 40

[Handwritten signature]

[Handwritten signature]


ВАЖНО С
СВИДЕТЕЛЬСТВОМ





Handwritten signature

CESI B7024813 Oscillogram n. 43





Handwritten signature

CESI B7024813 Oscillogram n. 42

Handwritten signature


ВЕРНО С
ОТРАЖАЕТСЯ





[Handwritten signature]

CESI B7024813 Oscillogram n. 45





[Handwritten signature]

CESI B7024813 Oscillogram n. 44


[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА






CESI B7024813 Oscillogram n. 47




CESI B7024813 Oscillogram n. 46

Handwritten signature


**ВЯРНО С
СРЪЖНАТА**





CESI B7024813 Oscillogram n. 49

[Handwritten signature]





CESI B7024813 Oscillogram n. 48

[Handwritten signature]

[Handwritten signature]


**ВЯРНО С
СРЪТНАНАТА**





CESI B702-4813 Oscillogram n. 51

[Handwritten signature]





CESI B702-4813 Oscillogram n. 50

[Handwritten signature]

[Handwritten signature]


ВЯРНО С
ОБЪЕКТАТА





Handwritten signature

CESI B7024813 Oscillogram n. 53





Handwritten signature

CESI B7024813 Oscillogram n. 52

Handwritten signature


**ВЯРНО С
СРИГНАЛА**





CESI B7024813 Oscillogram n. 55

[Handwritten signature]






CESI B7024813 Oscillogram n. 54

[Handwritten signature]


[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА






ВЯРНО С
ОРИГИНАЛА






CESI B7024813 Oscillogram n. 59




CESI B7024813 Oscillogram n. 58


Handwritten signature

ВАРНО С
ОБЩИНА







CESI 67024813 Oscillogram n. 61




CESI 67024813 Oscillogram n. 60

ВЯРНО С
ОРИГИНАЛА







CESI B7024813 Oscillogram n. 63



CESI B7024813 Oscillogram n. 62


ВЯРНО Е
ОРИГИНАЛЪТ





CESI B7024813 Oscillogram n. 65


[Handwritten signature]




CESI B7024813 Oscillogram n. 64

[Handwritten signature]


ВЯРНО С
ОРГАНИЗАТА



[Handwritten signature]





CESI E7024813 Oscillogram n. 67



CESI E7024813 Oscillogram n. 66

ВЯРНО С
ОРИГИНАЛА






N° n.d.	name	note
n.1	varistor B41/30	000
n.2	Housing	000
n.3	External insulation	000
n.4	Metal flanges and spacers	000
n.5	Additional thermal insulation	000




PA-DH.001.ST.02		
АВТ.	НАЧ. РАБОТ	ПРОГ.
2.15	1:1	1
3.10	3.10	3.10
section in thermal model.		
Surge Arrester PA-OH		
ТИПОВЫЙ-АННОЦИД		



CESI 87024813 Oscillogram n. 63

[Handwritten signature]

**ВЕРНО С
ОРИГИНАЛА**



The TOV characteristics of PA-DH surge arresters.

The TOV characteristics (in p.u. Ur) of PA-DH surge arresters "with prior duty" and "without prior duty" as per IEC 60099-4 Ed. 3.0 are presented in the Fig.2 below.




Figure 2. The TOV characteristics of PA-DH surge arresters.

The TOV values in per unit of Ur for times 0,1 s, 1 s, 10 s, 100 s, 1000 s, 10000 s are presented in the table 4.

Time, s	The TOV values in p.u. Ur	
	"with prior duty"	"without prior duty"
0,1	1,120	1,230
1	1,080	1,180
10	1,040	1,130
100	1,000	1,090
1000	0,960	1,040
3600	0,940	1,020

Table 4.

Forma AK

"Полупер-Андром"		3A0	
Автом. 1	Автом. 2	0,227	1:1

Varistor B4/30

PA.VAR.0500.30

Имя	Имя	Имя	Имя
Фамилия	Фамилия	Фамилия	Фамилия
Адрес	Адрес	Адрес	Адрес
Телефон	Телефон	Телефон	Телефон

1. Несомкнутый барьер (NOV disk)
2. Изоляционное покрытие полупером (PU insulating collar)
3. Изоляционное покрытие стержня (glass insulating collar)
4. Активный электрод (Al - electrode)

Тун d

Тун b

ВЕРНО С PA.VAR.0500.30

ЭЛЕКТРОН

СЕРТИФИКАТ

№ 001

87020211001

Test Report

Document No.	B7023423	Copy No.	1	Number of pages	17
Apparatus	Polymer-housed surge arrester unit type PA-DH and polymer-housed surge arrester section type PA-DH assembled in thermal model				
Designation	—				
Serial Number	—				
Manufacturer	Joint-Stock Company " Polymer-Apparat "				
Client	Joint-Stock Company " Polymer-Apparat " Ak. Kostantinaova str., 1 195427 Saint-Petersburg - Russia Federation				
Tested for	—				
Date(s) of tests	November 16, 2017				
Tested by	CESI, S.p.A. Via Rubattino, 54 20134 Milano - Italy				
Test performed	Heat dissipation behaviour of test sample : Test to verify thermal equivalency between complete arrester and arrester section				

Notes

STL-Member

CESI Group members are founder members of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in 1969. STL is a forum for voluntary international cooperation of testing organizations.

CESI Group Test Documents description

Type Test Certificate of

Issued for type tests of high voltage products ($> 1 \text{ kV}_{\text{eff}} > 1,5 \text{ kV}_{\text{eff}}$), which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. The Type Test Certificate consists of documents unequivocally identifying the test object and describes all conditions under which the tests were conducted. It gives evidence of the unobjectionable behavior of the test object during the tests in line with the normative documents applied as well as of the results of successful testing.

Test Certificate of (complete / selected) Type Tests

Issued if type tests of low voltage products ($< 1 \text{ kV}_{\text{eff}} < 1,5 \text{ kV}_{\text{eff}}$) requested by the relevant product standard were passed. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Certificate of Design Verification

Issued for passed design verification tests according to IEC 61439. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Type Test Report

Issued for high and low voltage products if parts of selected type tests have been passed; those shall be carried out in full compliance with the relevant standards but (for high voltage products) do not fulfill all STL requirements for issuing a Type Test Certificate. For these tests the equipment under test must be clearly identified by technical description, drawings, and additional specifications.

Test Report

Issued for all other tests on high and low voltage products which have been carried out according to specifications, standards and/or client instructions

On-Site Test Record

Issued as a record of results acquired during the on-site tests / measurements

Test Award

Can be additionally issued for all named types of test documents above if the tests to be referenced were passed

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with: IEC 60099-4 – Edition 3.0 (2014-06)

The results are shown in the record of proving tests and the oscillograms attached hereto. The ratings assigned by the Manufacturer are listed on the rating page.
The document applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the Manufacturer.

December 22, 2017


Date: **Gregorio Marco**
Test Engineer in charge
The Manager - Arcidives Lorenzo
Approved By Document Digitally Signed

Partial reproduction of this document is permitted only with the written permissions from CESI Group.
The authenticity of this document is guaranteed by the integrity of hologram.


The laboratory meets the requirements of the Standards EN ISO/IEC 17025:2005 General Requirements for the Competence of Testing and Calibration Laboratories. The In-Use status of the accreditation and the list of accredited tests may be checked in the VEEB with the manufacturer.



LAB N° 0030



Trust the Power of Experience



Tests witnessed by:




The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.
These drawings, identified by CESI and numbered B7026756 n.1 & 2, are annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked: _____

The reported expanded uncertainties are determined in accordance with the Publication JCGM 100 "Evaluation of measurement data - Guide to the expression of uncertainty in measurement" and are based on a standard uncertainty multiplied by a coverage factor K=2, which, for a normal distribution provides a level of confidence of approximately 95%

- Voltage a.c. : ± 3,0%
- Residual peak voltage (impulse tests) : ± 3,0%
- Current a.c. : ± 3,0%
- Peak current (impulse tests) : ± 3,0%
- Time (impulse tests) : ± 10,0%
- Time (a.c. tests) : ± 1,5%



November 2017

CESI - Via Rubattino 54 - Milan



Mr. L. Podavite, Mr. I. Guacci

P177 (Surge Arrester laboratory)


70006781



content	page	test date	
Test object characteristics	5	November 16, 2017	
Reference standard	6		
Test carried out and identification of the test object	6		
Test setting for the test	7 to 8		
Test procedure	9		
Summary of test result	10 to 12		
Instrument used for the test	13		
Technical data	14		
Pages annexed:			
Client's drawing (arrestor section assembled in thermal model) : CESI n. B70026756-1 - n.1 page			
Client's drawing (complete arrestor) : CESI n. B70026756-2 - n.1 page			
Client's drawing (MCO resistor) : CESI n. B7024038 - n.1 page			



ВЪРНО С
ОРГАНИЗАЦИЯ



Test Report

Rated characteristics of the tested objects assigned by the Client


Polymer-housed surge arrester

Manufacturer	Joint-Stock Company "Polymer-Apparat"
Type	PA-DH-54
MO resistors supplier	Joint-Stock Company "Polymer-Apparat"
Serial no.	00204
Drawing code	PA-OPN.035.002.056.01
Arrester class	Distribution
Designation	DH
Design	B
Rated voltage - U_r	54 kV
Continuous operating voltage - U_c	43.2 kV
Rated frequency	48-62 Hz
Nominal discharge current (8/20 μ s impulse shape)	10 kA
Reference current - I_{ref}	1 mA
Year of manufacturer	10/2017

Polymer-housed surge arrester section assembled in thermal model

Manufacturer	Joint-Stock Company "Polymer-Apparat"
Type	PA-DH
MO resistors supplier	Joint-Stock Company "Polymer-Apparat"
Serial no.	00077
Drawing code	PA-DH.001.ST-01
Arrester class	Distribution
Designation	DH
Design	B
Rated voltage - U_r	1,25 x U_c
Continuous operating voltage - U_c	4,0 kV
Rated frequency	48-62 Hz
Normal discharge current (8/20 μ s impulse shape)	10 kA
Reference current - I_{ref}	1 mA
Year of manufacturer	10/2017

ВЕРНО
ОПРАВДАНО



Test Report

Reference Standard

IEC 60099-4 – Edition 3.0 (2014-06) – clause 8.6 & Annex B
 * Metal-Oxide Surge Arresters without gaps for AC systems

Test carried out and identification of the test objects

Test carried out	Number of test objects	Test object identification
Heat dissipation behaviour of test sample	1	PA-DH-54 (s/n. 00204)
	1	PA-DH Section ST (s/n. 00077)

(Handwritten signature)



Test setting for the test







Photo no. 1
Complete arrester



A1257G



ACCREDIA S.p.A.
UNITS: MILANO (VA) - ACCREDITATION NO. 0123
L.A. N. 04320

A1257G






Photo no. 2
Arrester section with thermal insulation



ACCREDIA S.p.A.
UNITS: MILANO (VA) - ACCREDITATION NO. 0123
L.A. N. 04320



Test procedure on complete arrester

The complete arrester was placed in the testing laboratory (see photograph no.1 on page 7) at still air ambient temperature of 19 °C. The ambient temperature was held at 19 °C ±3K during the test.

The complete arrester was supplied by the manufacturer fitted with a optical thermal sensors attached to the MO resistors (see drawing attached on this test report).

The surge arrester was heated to a temperature of approximately 140 °C by the application of a power frequency overvoltage with an amplitude above the reference voltage. The heating time was 46 min. (the maximum time according to the reference standard is 60 min.).

When the specified temperature of about 140 °C was reached the voltage source was disconnected and the cooling time curve was determined over a period of not less than 2 hours.

Test procedure on arrester section

The arrester section was placed in the testing laboratory (see photograph no.2 on page 8) at still air ambient temperature of 17,7 °C.

The ambient temperature was held at 17,7 °C ±3K during the test.


The arrester section was supplied by the manufacturer and one optical thermal sensor has been used (see drawing attached on this test report).

The MO resistor was heated to a temperature of approximately 140 °C by the application of a power frequency overvoltage with an amplitude above the reference voltage.

The heating time has been of 51 min. (the maximum time according to the reference standard is 60 min.).


When the specified temperature of about 140 °C was reached the voltage source was disconnected and the cooling time curve was determined over a period of not less than 2 hours.

ВРНО С
ОПРАТОВА



A1264K0

A1265TG



Test result and the calculation of the temperature compensation

The cooling curve (see pag.10) of the arrester section hasn't been for all instants equal or higher than the cooling curve of the arrester. The compensation may be made adding a ΔT to the start temperature S_{max} of the prorated section during the preheating (thermal recovery part) for Operating duty test and Power-frequency voltage versus time test.

Sample	T	T _A	T ₀	T ₀ - T _A	Heating time	Date
Complete arrester	is the measured temperature during cooling every minute	19,0 °C	144 °C	125 °C	46 min	November 16, 2017
Arrester section	is the measured temperature during cooling every minute	17,7 °C	143 °C	125,3 °C	51 min	November 16, 2017

Legend:
 T is the measured temperature instant by instant
 T_A is the average ambient temperature during test
 T₀ is the maximum heating temperature
 T_{rel} (T-T_A) / (T₀-T_A)
 ΔT temperature compensation

The two relative temperatures T_{rel,arrester} and T_{rel,arrester section} have been plotted (see page 12) for the cooling time (≥7200s).
 During the cooling time the difference T_{rel,arrester} - T_{rel,arrester section} has been calculated and the max value has to be considered.


$$K = \max(T_{rel,arrester} - T_{rel,arrester section}) = 0,034101197$$

$$\Delta T = K \cdot (T_0 - T_A)_{max} = 0,034101197 \cdot 125,3 = 4,27 \text{ °C}$$

The compensation temperature ΔT resulting from the test is 4,27 °C.

$$S_{max} = 60 \text{ °C} + 4,27 \text{ °C} = 64,27 \text{ °C}$$


Therefore the S_{max} for thermal recovery test in the Operating duty test and Power-frequency voltage versus time test is equal to 65,50 °C.



Instruments used for temperature measurement

Instrument type	CESI no.	Note:
ASKVIANA	022469 - Rx 022468 - Tx	used surge arrester unit and surge arrester section temperature
FLUKE thermometer	030889	used for ambient temperature

Circuit A0019



ВРП
ОПРЕДЕЛЕНИЕ

Power frequency supply

- RE - programmable supply type PACIFIC A.C. Power Source 140 ASX; CESI no. 0560408
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV (used for arrester section)
- T - voltage transformer type SPECIALTRASFO; power 60 kVA; voltage 220 V/200 kV (used for complete arrester)

Current measuring system

- R - Current shunt CESI No.31120; R= 941,4 Ω
- Electro optical system HEM CESI No. 57986(Rx) - 57987 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NIPX-1031/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 056226 (on channel No.1)

Voltage measuring system


- D - Voltage divider SAGI; CESI No.11120 (used for arrester section)
- Voltage divider HAEFELY; CESI No 13455 (used for complete arrester)
- Electro optical system type HEM CESI No. 57986(Rx) - 57991 (Tx)
- OSC - Oscilloscope type NATIONAL INSTRUMENT NIPX-1031/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 056226 (on channel No.2)

SOFTWARE SYSTEM:

- SW - S.A.D. Surges arrester version 2.0

[Handwritten signature]

[Handwritten signature]





Исполнитель	Имя и фамилия	Подпись	Дата
Материал	Получено	Исполнено	Сдано
№ детали	№ документа	№ чертежа	№ спецификации
1	2	3	4
5	6	7	8
9	10	11	12

№ п/п	Наименование детали/узла	Материал	Код материала
1	Нержавеющая фланец/металл flange	Нержавеющая сталь	12Х18Н10Т
2	Нержавеющая трубка/металлическая трубка	Нержавеющая сталь	12Х18Н10Т
3	Защитная трубка/защитная трубка	Резина/резина	ЭПД
4	Вкладыш/металлическая вставка	Металл	12Х18Н10Т
5	Нержавеющая трубка/металлическая трубка	Нержавеющая сталь	12Х18Н10Т




1. The pressure relief window. All dimensions for reference.



PA-DH.035.002.056.01 SB

1001 2.01-08

PA-DH.001.5T.01




ЛЭТИ ИМ. В. В. ВОЙТОВА
B7020756-001

№ п.п.	наименование	материал
n.1	варистор B41/30	000
n.2	housing	000
n.3	external insulation	000
n.4	metal flanges and spacers	000
n.5	additional thermal insulation	000
n.6	aperture for a thermocouple	000

1. - Dimensions for reference

Исполнитель	Имя и фамилия	Подпись	Дата
Материал	Получено	Исполнено	Сдано
№ детали	№ документа	№ чертежа	№ спецификации
1	2	3	4
5	6	7	8
9	10	11	12

Имя	Фамилия	Инициалы
Имя	Фамилия	Инициалы
Имя	Фамилия	Инициалы
Имя	Фамилия	Инициалы
Имя	Фамилия	Инициалы






ВАРИАНТ С
ОРИГИНАЛ


PA.VAR.0500.30

Тип а

Тип б




1. Металлооксидный варистор (MOV disk)
2. Изоляционное покрытие стекла (Glass insulating collar)
3. Изоляционное покрытие полимером (PI insulating collar)
4. Алюминиевый диэлектрик (Al - electrode)




Изм.		Лист		№ докум.		Подп.		Дата	
Разработ.		Литовод А.В.		Проб.		Петухов А.Л.		Т.контр.	
И.контр.		Шевцов И.В.		Упр.		Зав		Лист 1 / Листов 1	
Материал		Varistor B41/30		Масса		0.227		1:1	
Лит.		PA.VAR.0500.30		Лит.		Лист 1		Листов 1	
Покрытие		Оксид цинка		Производитель		"Полимер-Аппарат"		Формат А4	

Инд. № подл.	Подп. и дата	Инд. № дудл.	Подп. и дата
--------------	--------------	--------------	--------------



Приложение В



JSC "POLYMER-APPARAT"
St. Petersburg, Russian Federation



МЕТАЛО-ОКСИДНИ ВЕНТИЛНИ ОТВОДИ


РА-ДН-204-27-22/22

ТЕХНИЧЕСКО РЪКОВОДСТВО

TM 3414-E419-15207362-2018

%year%

ВЯРНО С
ОРИГИНАЛА



Това ръководство съдържа технически данни за метало-оксидни Вентилни Отводи (ВО) от свръхнапрежения в полимерни обвивки тип PA-DH-204-27-22 / 22

1. Приложение

1.1. Метало-оксидни ВО от свръхнапрежения без въздушна междина от тип PA-DH-204, по нататък наричани „Отводи”, са предназначени за предпазване на електрическо оборудване АС с 48÷62 Hz честота от свръхнапрежение при превключване и мълнии.

1.2. Класификация на ВО съгласно IEC 60099-4:2014 - **Distribution High**.

2. Дизайн и работна информация

2.1. ВО са направени като пакет от метало-оксидни варистори (MOV), затворени в полимерна обвивка с метални фланци.

2.2. Цялостни и монтажни размери са дадени в Приложение А.

2.3. Принципът на работа на ВО се базира на нелинейността на волт-амперната диаграма на цинк-оксидните варистори. При работно напрежение стойността на активните токове през варисторите е по-малка от милиампер, но при свръхнапрежение тези стойности се повишават до стотици и хиляди амperi.

3. Система за маркиране на продукта:

Пример за продуктов номер: PA-DH-204-27-22/22

PA - Търговска марка на производител - "Polymer-Apparat";

DH - Distribution High (класификация на предпазителя съгласно JSC "Polymer-Apparat");


204 - Тип обвивка;

27 - Номинално напрежение, kV;

22 - Високо-волтов вход (M12 type 2);

22 - Заземителна клема (M12 type 2).

ВЯРНО С
ОРИГИНАЛА



4. Условия на работната среда

Оперативност на предпазителите е гарантиране при следните условия :

- На открито;
- Минимална работна температура на околната среда е -60°C ;
- Минимална работна температура на околната среда е $+50^{\circ}\text{C}$;
- Надморска височина до 1000 m.


5. Основни характеристики и параметри

5.1. ВО отговарят на спецификация: IEC 60099-4:2014. Основните характеристики и параметри са дадени в Таблица 1 по-долу.

Таблица 1

Parameter	Rated value
1. Номинално напрежение, kV	27
2. Трайно напрежение на ВО (MCOV), kV (rms)	21.6
3. Номинален разряден ток, A	10000
4. Остатъчно напрежение при мълниев импулс на тока с амплитуда 8/20 μs (kV, не повече от):	
5 kA	63.6
10 kA	67.0
20 kA	72.3
5. Остатъчно напрежение при превключващ импулс на ток с амплитуда 30/60 μs (kV, не повече от):	
125 A	48.9
500 A	50.9
6. Остатъчно напрежение при стръмен 1/10 μs токов импулс с амплитуда 10000 A (kV, не повече от)	73.0
7. Траен рейтинг за пренос на заряд Q_{rs} , C	0.5
8. Степен на пренос на топлинна енергия Q_{th} , C	1.1
9. Висок токов импулс 4/10 μs , kA	100
10. Продължителност на токовия импулс, A	450
11. Референтно напрежение (при референтен ток $I_{ref} = 1.5\text{ mA}$), kV, не по-малко от	26.8

**ВЯРНО С
ОРИГИНАЛА**



5.2. Външни параметри на изолацията:

- Обявено издържано мълниеве импулсно напрежение 1.2/50 μ s , не по-малко от 150 kV
- Обявено издържано мълниеве импулсно напрежение 60 Hz, не по-малко от 50 kV
- Разстояние на утечка, не по-малко от 807 mm

5.3. Изолацията на ВО е устойчива на ерозия и проникване на влага.

5.4. Сеизмична стабилност, MSK-64 номер 9.

5.5. Ниво на частичните разряди във ВО при напрежение $1.05 \times U_{cont}$ – не повече от 10 pC.

5.6. TOV характеристики (отнесени към MCOV) представени в Таблица 3 по-долу.

Таблица 3

Продължителност на увеличеното напрежение	0.1 с	0.15 с	1.0 с	3.5 с	10 с	20 с	20 min	50 min	2 h	6 h
Допустимо съотношение на повишено напрежение на ВО по отношение на U_{cont}	1.48/ 1.56	1.47/ 1.55	1.43/ 1.50	1.40/ 1.47	1.37/ 1.45	1.36/ 1.43	1.26/ 1.33	1.23/ 1.30	1.22/ 1.29	1.19/ 1.26

Забележка:

- Числителя отговаря на тест при предварително загрят ВО до 60⁰C изпитан чрез два правоъгълни импулса равни на рейтинга на устройството;
- Стойността на знаменателя съответства на тест при загрят до 60⁰C предпазител без допълнителни импулси.

6. Безопасност

6.1. ВО са устойчиви на експлозия и издържат на следните токове на късо съединие без да експлодират:


- 20 kA (rms) за 0,2 с (не по-малко);
- 600 A (rms) за 2 с (не по-малко)

6.2. Вентилните отводи отговарят на IEC 60099-4:2014.

7. Експлоатационен живот

Очакваната продължителност на работа на Вентилния Отвод (с вероятност от 0.98 възможност за повреди) е над 30 години.

**ВЯРНО С
ОРИГИНАЛА**



8. Стандартен комплект и опции

Комплекта за доставка се състои от:

- Вентилен Отвод;
- QC сертификат за тест;
- Техническо упътване (3 копия за всеки тип отвод).

Вентилния отвод се състои от:

- метало-оксидни вентилни отводи без въздушна междина тип PA-DH-204 ;
- Високо волтов вход тип 02 - пин M12×50 - 1 бр., шайба Ø12 - 2 бр., пружинна шайба Ø12 - 1 бр;
- Заземителна клемма тип 02 - пин M10×25 - 1 бр., шайба Ø12 - 2 бр., пружинна шайба Ø12 - 1 бр.

9. Обозначения

На долният фланец на предпазителя е отбелязано:

- Име на производителя;
- Тип на предпазител;
- MCOV, kV;
- Заводски номер;
- Дата на производство.

10. Транспортиране

Транспортирането се извършва в оригиналната опаковка с етикети:

- Чупливо;
- да не се мокри;
- нагоре .


11. Съхранение

Вентилните отводи трябва да се съхраняват в оригиналната опаковка. Да се съхраняват на закрито. Няма необходимост от затопляне/охлаждане в диапазона от -60°C до $+50^{\circ}\text{C}$.

При съхранение и транспорт ВО не трябва да излагат на влага, маслени продукти, киселини, алкални, газове и други агресивни субстанции, които могат да навредят на полимерната обвивка.

Приемането на продукта трябва да включва проверка на цялостта на опаковката и съответствие с поръчката.

ВЯРНО С
ОРИГИНАЛА



12. Монтаж

12.1. Само квалифициран персонал, запознат с това техническо ръководство и правила за безопасност може да борави с Вентилните Отводи.

ВНИМАНИЕ: За да избегнете щети, ВО не трябва да се докосват до абразивни повърхности, остри ръбове или режещи инструменти.

12.2. Извадете отвода от опаковката и се уверете, че няма видими повреди, които да са се появили при транспортирането.

12.3. Монтирайте отвода, като следвате диаграмата в Приложение А.

12.4. Заземяването на отвода се извършва чрез гъвкав меден проводник със сечение не по-малко от 6 mm².

13. Изисквания за поддръжка

Поддръжка на Вентилните Отводи не е предвидена.

Отводите не подлежат на ремонт. Няма инструкция за ремонт.

14. Гаранция


Производителя ще замени повредени ВО в срок от 5 години от датата на пускане в експлоатация, но не по-късно от 7 години от датата на експедиция от производителя, при условие, че повреденият отвод е бил транспортиран, съхраняван, монтиран и експлоатиран стриктно спазвайки това техническо ръководство.

15. Рециклиране

Вентилните Отводи не съдържат опасни или агресивни материали, които могат да навредят на хора или животни, които имат контакт с тях. Рециклирайте в съответствие с местните разпоредби за индустриални отпадъци от метал и пластмаса.




ВЪРНО С
ОРИГИНАЛА



ПРИЛОЖЕНИЕ А


Външни и инсталационни размери и тегло на Вентилните Отводи тип РА- ДН -204



Височина на ВО (H) -- 290 ± 1 mm.

Тегло на ВО -- 3.5 ± 0.1 kg

ВЯРНО С
КОПИЯТА



СРОКОВЕ ЗА ДОСТАВКА

№	Наименование	Мярка	Количество със срок на доставка до 7 кал. дни	Количество със срок на доставка до 30 кал. дни
1	2	3	4	5
1	Вентилен отвод метало - оксиден тип без искрови разрядници, 10 kV, 10kA, клас 2	бр.	3	5
2	Вентилен отвод метало - оксиден тип без искрови разрядници, 20 kV, 10kA, клас 1	бр.	20	50
3	Вентилен отвод метало - оксиден тип без искрови разрядници, 20 kV, 10kA, клас 2	бр.	20	50

Забелџки:

- 1/ Срокът на доставките започва да тече от датата на изпращане на поръчката.
- 2/ Количествата в колона 4, със срок на доставка до 7 /седем/ календарни дни, се доставят след SAP поръчка до посочените в обявлението складове на Възложителя за покриване на спешни нужди на Възложителя.
- Възложителят може да поръчва посоченото спешно количество веднъж месечно.
- 3/ В случай, че крайният срок на доставката съвпада с празничен или неработен ден, то доставката се извършва не по-късно от първия работен ден след изтичането на срока.
- 4/ При поръчки на Възложителя на количества в рамките на потвърдените от Изпълнителя и недоставени в посочените срокове, ще бъдат налагани неустойки, съгласно условията на договора.
- 5/ Възложителят може да поръчва количества по-малки от посочените в колони 4 и 5.
- 6/ Възложителят може да поръчва количества по-високи от посочените в колони 4 и 5, като това обстоятелство ще бъде посочено текстово в съответната поръчка изпратена към Изпълнителя. С потвърждението на поръчката, Изпълнителят вписва в същата очаквана дата за доставка на количествата надвишаващи посочените в колони 4 и 5.
- 7/ Количествата за доставка в колони 4 и 5 са отделни и независими едно от друго.
- 8/ Количествата за доставка в колона 5 не включват в себе си количествата за доставка в колона 4.
- 9/ Възложителят има право да направи едновременно поръчки за доставка на количества от колони 4 и 5.

Дата 13.03.2018 г.

ПОДПИС И ПЕЧАТ:

на основание чл. 2 от
ЗЗЛД

(длъжност на представляващия участника)

ДЕКЛАРАЦИЯ

за приемане на условията в проекта на рамково споразумение и проекта на конкретен договор,
неразделна част от рамковото споразумение


Долуподписаният/-ната/ Алексей Николаевич Родин, в качеството ми на представляващ „ЕМИ
ЕЛЕКТРИК“ ЕООД, участник в процедура за възлагане на обществена поръчка с реф. № PPD17-158 и
предмет: „Доставка на вентилни отводи средно напрежение (СрН)“,

ДЕКЛАРИРАМ, ЧЕ:

1. Приемам условията в проекта на рамково споразумение, приложен в документацията за участие.
2. Приемам условията в проекта на конкретен договор, неразделна част от рамковото споразумение,
приложен в документацията за участие.

Дата 13.03.2018 г.

ПОДПИС И ПЕЧАТ:



Референтен № PPD 17-158



ДЕКЛАРАЦИЯ
за срока на валидност на офертата

Долуподписаният/ -ата Алексей Николаевич Родин,
(посочете фамилия, бащино, феминно име)

на основание чл. 2 от ЗЗЛД



(посочете се длъжността)

на „ЕМИ ЕЛЕКТРИК“ ЕООД,

(посочете наименованието на участника)

участник в процедура за възлагане на обществена поръчка с реф. № PPD17-158 и предмет:
„Доставка на вентилни отводи средно напрежение (СрН)“,


ДЕКЛАРИРАМ, ЧЕ:

С подаване на настоящата оферта, направените от нас предложения и поети ангажименти са валидни за срока, посочен в обявлението, считано от крайния срок за подаване на офертите.

на основание
чл. 2 от ЗЗЛД

Дата 20.03.2018 г.

ПОДПИС И ПЕЧАТ:





Забележка:

Декларацията се подписва от законния представител на участника или от надлежно упълномощено лице, което подава офертата.



Референтен № PPD 17-158

СИСТЕМА СЕРТИФИКАЦИИ ГОСТ Р
ФЕДЕРАЛЬНОЕ АГЕНТСТВО ПО ТЕХНИЧЕСКОМУ РЕГУЛИРОВАНИЮ И МЕТРОЛОГИИ



СЕРТИФИКАТ СООТВЕТСТВИЯ

№ РОСС RU.ME05.H00313

Срок действия с 11.12.2015 по 10.12.2018

№ 0060370

ОРГАН ПО СЕРТИФИКАЦИИ

АВТОНОМНАЯ НЕКОММЕРЧЕСКАЯ ОРГАНИЗАЦИЯ «НАУЧНО-ТЕХНИЧЕСКИЙ ЦЕНТР «ОРГАН ПО СЕРТИФИКАЦИИ
ЭЛЕКТРИЧЕСКИХ МАШИН, ТРАНСФОРМАТОРОВ, ЭЛЕКТРООБОРУДОВАНИЯ И ПРИБОРОВ»
196105, Санкт-Петербург, ул.Благодатная, д.2, тел.+7(812)369-91-67, факс +7(812)369-68-27, elmatep@mail.vplus.net,
Аттестат аккредитации № RA.RU.11ME05 от 27.01.2015г., выдан Федеральной службой по аккредитации

ПРОДУКЦИЯ

Ограничители перенапряжений нелинейные серии ОПНп для электрических сетей переменного тока классов напряжения 3, 6 и 10 кВ, категории размещения 2, ток взрывобезопасности 40кА
ТУ 3414-009-15207362-2006
Серийный выпуск

код ОК 005 (ОКП):

341400

СООТВЕТСТВУЕТ ТРЕБОВАНИЯМ НОРМАТИВНЫХ ДОКУМЕНТОВ

ГОСТ Р 52725-2007; ГОСТ 12.2.007.0-75 п.п. 3.3.1, 3.3.3, ГОСТ 12.2.007.3-75;
ТУ 3414-009-15207362-2006

код ТН ВЭД России:

8535400000

ИЗГОТОВИТЕЛЬ

Закрытое акционерное общество "Полимер-Аппарат", Адрес: 190068, СПб, ул.Большая Подъяческая д.1/3, литер А., Фактический адрес: 190068, СПб, ул.Большая Подъяческая д.1/3, литер А.

СЕРТИФИКАТ ВЫДАН

Закрытое акционерное общество "Полимер-Аппарат", Адрес: 190068, СПб, ул.Большая Подъяческая д.1/3, литер А., Фактический адрес: 190068, СПб, ул.Большая Подъяческая д.1/3, литер А., телефон: (812)33140402, факс: (812)3314040, E-mail: orn@polimer-apparat.ru

НА ОСНОВАНИИ

Протокол испытаний № ПИ 923 от 27.11.2015г., № РОСС RU.0001.21MB01. Испытательный центр высоковольтной аппаратуры Акционерного общества «Научно-исследовательский и проектно-конструкторский институт высоковольтного аппаратостроения». Сертификат системы менеджмента качества ГОСТ ISO 9001-2011 (ISO 9001:2008) № СТ/СМК/ОС01 RU № 02/13-00360 от 14.11.2013.

ДОПОЛНИТЕЛЬНАЯ ИНФОРМАЦИЯ

Маркирование продукции производится знаком соответствия по ГОСТ Р 50460-92 с надписью "Добровольная сертификация" на изделии и в сопроводительной документации. Схема сертификации

на
основание
чл. 2 от
ЗЗЛД


на
основание
чл. 2 от
ЗЗЛД



Руководитель органа

Эксперт

Сертификат не применяется при применении другой системы сертификации



ДЕКЛАРАЦИЯ О СООТВЕТСТВИИ

Закрытое акционерное общество "Полимер-Аппарат"

(наименование организации или фамилия, имя, отчество индивидуального предпринимателя, принявших декларацию о соответствии)

Зарегистрирован(а) Межрайонная инспекция РФ по налогам и сборам № 7, дата регистрации 13.08.2003, ОГРН: 1037861005401

(сведения о регистрации организации или индивидуального предпринимателя (наименование регистрирующего органа, дата регистрации, регистрационный номер)

Адрес: 190068, РОССИЯ, город Санкт-Петербург, ул. Большая Подъяческая, д. 1/3, лит. А,
Фактический адрес: 190068, РОССИЯ, город Санкт-Петербург, ул. Большая Подъяческая, д. 1/3, лит. А, телефон: (812)3314040, факс: (812)3314040, E-mail: orn@polimer-apparat.ru
(адрес, телефон, факс)

в лице Генерального директора Шевцова Ильи Владимировича

(должность, фамилия, имя, отчество руководителя организации, от имени которой принимается декларация) заявляет, что Ограничители перенапряжений нелинейные серии ОПНп для электрических сетей переменного тока классов напряжения 3, 6 и 10 кВ, категории размещения 2, ток взрывобезопасности 40кА, ТУ 3414-009-15207362-2006

(наименование, тип, марка продукции, на которую распространяется декларация)

Серийный выпуск, Код ОКП 341400, Код ТН ВЭД 8535400000

(сведения о серийном выпуске или партии (номер партии, номера изделий, реквизиты договора (контракта), накладная, код ОК 005-93 и (или) ТН ВЭД ТС или ОК 002-93 (ОКУН))

Изготовитель: Закрытое акционерное общество "Полимер-Аппарат", Адрес: 190068, РОССИЯ, город Санкт-Петербург, ул. Большая Подъяческая, д. 1/3, лит. А, Фактический адрес: 190068, РОССИЯ, город Санкт-Петербург, ул. Большая Подъяческая, д. 1/3, лит. А

(наименование изготовителя, страны и т.п.)

соответствует требованиям ГОСТ Р 52725-2007 п.п. 6.4.10, 6.5; ГОСТ 12.2.007.0-75 п.п. 3.3.1, 3.3.3

(обозначение нормативных документов, соответствие которым подтверждено данной декларацией, с указанием пунктов этих нормативных документов, содержащих требования для данной продукции)

Декларация принята на основании: Протокол испытаний № ПИ 923 от 27.11.2015г. Испытательный центр высоковольтной аппаратуры Акционерного общества «Научно-исследовательский и проектно-конструкторский институт высоковольтного аппаратостроения». Аттестат аккредитации № РОСС RU.0001.21MB01 от 06.06.2012 до 06.06.2017. Сертификат системы менеджмента качества ГОСТ ISO 9001-2011 (ISO 9001:2008) № СТ/СМК/ОС01 RU № 02/13-00360 от 14.11.2013

(информация о документах, являющихся основанием для принятия декларации)

Дата принятия декларации 11.12.2015

Декларация о соответствии на основании чл. 2 от 33ЛД действительна до 10.12.2018

на основании чл. 2 от 33ЛД

И (инициалы)

Сведения о регистрации и о соответствии: 05, Орган по сертификации электрических машин, трансформаторов, электрооборудования и приборов АНО "Научно-Технический Центр "Орган по сертификации электрических машин, трансформаторов, электрооборудования и приборов"


(наименование и адрес органа по сертификации, зарегистрировавшего декларацию)

Адрес: 196105, Россия, город Санкт-Петербург, Лагодатная, дом 10 на основании чл. 2 от 33ЛД
Регистрационный номер декларации РОСС RU.0001.21MB01 на основании чл. 2 от 33ЛД

т 11.12.2015

(дата регистрации декларации)
(подпись, инициалы руководителя организации)

ва (подпись, инициалы руководителя организации по сертификации)



СИСТЕМА ЗА ДОБРОВОЛНА СЕРТИФИКАЦИЯ
“ СЕРТИФИКА-ТЕСТ ”

Въведени в единния регистър на доброволната система за сертифициране
ФЕДЕРАЛНА АГЕНЦИЯ ЗА ТЕХНИЧЕСКИ РЕГЛАМЕНТИ И МЕТРОЛОГИЯ
Регистрационен номер: № РОСС RU.3285.04A.100



ISO 9000

Organization establishing the certification system "Sertifika-Test"
"Center of Certification and Elaborations on Quality"

CERTIFICATION BODY
"CSRK-Management"

Elektrodnyi proezd, 6, building 1, office 28, Moscow, 11123
Tel: +7 (495) 223-22-18

СЕРТИФИКАТ ЗА СЪОТВЕТСТВИЕ

СТ/СМК/ОС01 RU № 02/16-00521

CJSC "Polimer-Appart"

Bol'shaya Podyacheskaya street, 1/13, lit.A, St. Petersburg, 190068

INN 7838002312

ТОЗИ СЕРТИФИКАТ УДОСТОВЕРЯВА, ЧЕ
СИСТЕМА ЗА УПРАВЛЕНИЕ НА КАЧЕСТВОТО

Във връзка с проектиране, инженеринг, производство и сглобяване на
ограничители на пренапрежение и електрически уреди при при
строително-монтажни работи по проектиране на електротехническо
оборудване за сгради, енергетика и железопътни обекти

Съответства на изискванията на
GOST R ISO 9001-2015 (ISO 9001:2015)

Сертификатът е издаден: 22.10.2016

Валиден до: 22.10.2019

на основание чл. 2 от
ЗЗЛД

на
основание
чл. 2 от
ЗЗЛД

С
ЛА

Romanenko M.A.
Head of the Organization

The certificate obliges the organization to render services in compliance with the aforesaid standard, which
will be under control of the organization of certification within the "Sertifika-Test" Certification System
and shall be reconfirmed by annual inspection.

№ 013159



SYSTEM OF VOLUNTARY CERTIFICATION "SERTIFIKA-TEST"

Introduced in the unified register of voluntary systems of certification of the
FEDERAL AGENCY ON TECHNICAL REGULATION AND METROLOGY
Registration number: № POCC RU.3285.04A400

ISO 9000



OC01

Organization establishing the certification system "Sertifika-Test"
"Center of Certification and Elaborations on Quality"

CERTIFICATION BODY
"CSRK-Management"

Elektroodnyi proezd, 6, building 1, office 28, Moscow, 11123
Tel. +7 (495) 223-22-18

CERTIFICATE OF CONFORMITY

CT/CMK/OC01/RU № 02/16-00521

CJSC "Polimer-Appart"

Bol'shaya Podyacheskaya street, 1/13, lit. A, St. Petersburg, 190068
INN 7838002312

THIS CERTIFICATE CERTIFIES THAT: QUALITY MANAGEMENT SYSTEM

With reference to designing, engineering, production and assembling of
excess-voltage suppressors and electrical devices, to construction building
works, to designing of electrotechnical equipment for building, energy and
railway objects


COMPLIES WITH THE REQUIREMENTS OF
GOST R ISO 9001-2015 (ISO 9001:2015)

на основании чл. 2 от
Серт 33ЛД

22, 2016

Valid until November 22, 2019

Head of the Organization



Вна
ОП
основание
чл. 2 от
33ЛД

The certificate obliges the organization to render services in compliance with the aforesaid standard, which
will be under control of the organization of certification within the "Sertifika-Test" Certification System
and shall be reconfirmed by annual inspection.



Закрытое акционерное общество "Полимер-Аппарат"

ИНН/КПП 7838002312/783801001, р/с 40702810505000000096 в Филиале АО АКБ
"НОВИКОМБАНК" в г. Санкт-Петербурге, к/с 30101810400000000902, БИК044030902,
Юридический адрес: 190068, г. Санкт-Петербург, ул.Б. Подъячская, 1/3 литер А,
Почтовый адрес: 191144, г. Санкт-Петербург, а/я 1
Тел/факс.(812)331-40-40, <http://www.polymer-apparat.ru>


Исх.№ 288/17 от «29» августа 2017 г.

Информационное письмо

Ограничители перенапряжений, предлагаемые для поставки в Болгарию, имеют маркировку "О" и предназначены для эксплуатации на территории Евросоюза. Данные ограничители отличаются от ограничителей перенапряжений, применяемых в России.


Генеральный директор

на
основание
чл. 2 от
ЗЗЛД



Шевцов И.В.

ВЯРНО С
ОРИГИНАЛА



ACCREDIA

L'ENTE ITALIANO DI ACCREDITAMENTO

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and RAC Mutual Recognition Agreements**CERTIFICATO Di ACCREDITAMENTO**
Акредитационен сертификатAccreditamento n°
Акредитация n°**0030**Rev. **2**Si dichiara che
Ние декларираме, че**CESI S.p.A.**Sede/Headquarters:
Via Rubattino 54 - 20134 Milano MIconforme ai requisiti
della normaотговаря на
изискванията на
стандартаUNI CEI EN ISO/IEC 17025:2005 "Requisiti generali per la competenza dei
Laboratori di prova e taratura"EN ISO/IEC 17025:2005 "Общи изисквания за компетентност на
лабораториите за изпитване и калибриране"

quale

Laboratorio di Prova

като

Изпитвателна лаборатория

L'accreditamento attesta la competenza tecnica del Laboratorio relativamente allo scopo riportato nelle schede allegate al presente certificato. Le schede possono variare nel tempo. I requisiti gestionali della ISO/IEC 17025:2005 (sezione 4) sono scritti in un linguaggio idoneo all'attività dei Laboratori di Prova, sono conformi ai principi della ISO 9001:2008 ed allineati con i suoi requisiti applicabili.

Il presente certificato non è da ritenersi valido se non accompagnato dalle schede allegate e può essere sospeso o revocato in qualsiasi momento nel caso di inadempienza accertata da parte di ACCREDIA.

La validità dell'accreditamento può essere verificata sul sito WEB (www.accredia.it) o richiesta direttamente ai singoli Dipartimenti

Акредитацията удостоверява техническата компетентност на лабораторията, ограничена до обхвата, описан в приложеното Приложение. Обхватът може да варира във времето. Изискванията на системата за управление в ISO / IEC 17025: 2005 (раздел 4) са написани на език, съответстващ на операциите на лабораториите за изпитване и отговарят на принципите на ISO 9001: 2008 и са съобразени с нейните съответни изисквания.

Настоящият сертификат е валиден само ако е свързан с приложения график и може да бъде спряна или отнет по всяко време в случай на неизпълнение, както е установено от ACCREDIA.

Статусът на акредитацията в сила може да се провери на WEB сайта (www.accredia.it) или директно заявление до назначения отдел.

Data di 1a emissione
Първа дата на издаване
1992.02.27

на основание чл. 2 от ЗЗЛД

Data di modifica
Дата на модификация
2016.04.14

на основание чл. 2 от ЗЗЛД

основание
чл. 2 от
ЗЗЛД


(In

scadenza
валиден до
20.03.09
(Rossi)Gen. Dir.
Генерален директор
(Dr. Filippo Trifiletti)Dir. del Dipartimento
директор на отдела
(Dr.ssa Silvia Tramontin)

Mod. CA-

01 rev. 01

Акредитация





Handwritten signature

CERTIFICATO DI ACCREDITAMENTO

Accreditation Certificate

Accreditamento n°
Accreditation n°

0030

Rev. **2**

Si dichiara che
We declare that

CESI S.p.A.

Sede/Headquarters:
Via Rubattino 54 - 20134 Milano MI

è conforme ai requisiti
della norma

meets the requirements
of the standard

UNI CEI EN ISO/IEC 17025:2005 "Requisiti generali per la competenza del
Laboratori di prova e taratura"

EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing
and Calibration Laboratories" standard

quale

Laboratorio di Prova

as

Testing Laboratory

L'accreditamento attesta la competenza tecnica del Laboratorio relativamente allo scopo riportato nelle schede allegate al presente certificato. Le schede possono variare nel tempo. I requisiti gestionali della ISO/IEC 17025:2005 (sezione 4) sono scritti in un linguaggio idoneo all'attività dei Laboratori di Prova, sono conformi ai principi della ISO 9001:2008 ed allineati con i suoi requisiti applicabili.

Il presente certificato non è da ritenersi valido se non accompagnato dalle schede allegate e può essere sospeso o revocato in qualsiasi momento nel caso di inadempienza accertata da parte di ACCREDIA.

La vigenza dell'accreditamento può essere verificata sul sito WEB (www.accredia.it) o richiesta direttamente ai singoli Dipartimenti.

The accreditation certifies the technical competence of the laboratory limited to the scope detailed in the attached Enclosure. The scope may vary in the time. The management system requirements in ISO/IEC 17025:2005 (Section 4) are written in a language relevant to Testing Laboratories operations and meet the principles of ISO 9001:2008 and are aligned with its pertinent requirements.

The present certificate is valid only if associated to the annexed schedule, and can be suspended or withdrawn at any time in the event of non fulfilment as ascertained by ACCREDIA.

The in force status of the accreditation may be checked in the WEB site (www.accredia.it) or on direct request to appointed Department.

Data di 1ª emissione
1st issue date
1992-02-27

на основание чл. 2 от 33ЛД

Data di modifica
Modification date

на основание чл. 2 от 33ЛД


Data di scadenza
Expiring date

на основание чл. 2 от 33ЛД

(Dr. Filippo Trifiletti)

Department Director
(Dr.ssa Silvia Tramontin)

The President
(Ing. Giuseppe Rossi)





CERTIFICATO DI ACCREDITAMENTO *Accreditation Certificate*

Accreditamento n°
Accreditation n°

0030

Rev. **2**


Si dichiara che
We declare that

Sedi operative:

CESI S.p.A.
Via Rubattino 54
20134 Milano MI
CESI S.p.A. - Sede di Piacenza
Via Nino Bixio 39
29100 Piacenza PC
CESI S.p.A. - Sede di Seriate
Via Pastrengo 9
24068 Seriate BG

Mod. CA-01 rev. 01

ВЯРНО С



ACCREDIA

CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 1 di 10 PA35AR33.pdf

ELENCO PROVE ACCREDITATE - CATEGORIA: 0

AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Capacitor switching current tests	IEEE Std C37.09: 1999 R2007 / C37.09a (A1): 2005 / C37.04: 1999
Control voltage	IEEE Std C37.09: 1999 R2007
Dielectric withstand tests	IEEE Std C37.09: 1999 R2007 / C37.06: 2009
Interrupting time tests	IEEE Std C37.09: 1999 R2007 / C37.04: 1999
Line closing switching surge factor	IEEE Std C37.09: 1999 R2007 / C37.06: 2009
Load current	IEEE Std C37.09: 1999 R2007 / C37.06: 2009
Maximum voltage tests	IEEE Std C37.09: 1999 R2007 / C37.04: 1999 / C37.06: 2009
Out-of-phase switching current tests	IEEE Std C37.09: 1999 R2007 / C37.09b (A2): 2010
Short-circuit current interrupting tests	IEEE Std C37.09: 1999 R2007 / C37.09b (A2): 2010 / C37.04: 1999 / C37.06: 2009 / C37.081: 1981 / C37.081a: 1997
Standard operating duty tests	IEEE Std C37.09: 1999 R2007 / C37.04: 1999 / C37.06: 2009
Synthetic fault testing	IEEE C37.081: 1981 / C37.081a: 1997
TRV tests	IEEE Std C37.09: 1999 R2007 / C37.09b (A2): 2010 / C37.06: 2009

Apparati e sistemi elettronici per applicazioni civili ed industriali

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Immunità ai disturbi condotti, indotti da campi a radiofrequenza (Solo su porte di alimentazione con CDN tipo M)	CEI EN 61000-4-6: 2014
Prova di immunità a transitori/treni elettrici veloci	CEI EN 61000-4-4: 2013
Prova di immunità agli impulsi (Solo impulsi 1,2/50 µs su porte di alimentazione)	CEI EN 61000-4-5: 2015
Prova di immunità alle onde oscillatorie smorzate (Solo 100 KHz e 1 MHz)	CEI EN 61000-4-18: 2007 / A1: 2011
Prova di immunità a scariche di elettricità statica	CEI EN 61000-4-2: 2011

Apparati e sistemi elettronici per applicazioni civili ed industriali - Apparecchi per la tecnologia dell'informazione

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Limiti dei disturbi irradiati (Limiti al di sotto di 1 GHz)	CEI EN 55022: 2014
Metodo di misura dei disturbi condotti ai morsetti di alimentazione e alle porte di telecomunicazione (Solo morsetti di alimentazione)	CEI EN 55022: 2014

Apparati per la misura dell'energia elettrica (a.c.) - Apparato di misura


<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Prova ai transitori/treni elettrici veloci	CEI EN 62052-11: 2003
Prova di immunità agli impulsi (Solo impulsi 1,2/50 µs su porte di alimentazione)	CEI EN 62052-11: 2003
Prova di immunità alle onde oscillatorie smorzate	CEI EN 62052-11: 2003
Prova di immunità alle scariche elettrostatiche	CEI EN 62052-11: 2003

Apparati per la misura dell'energia elettrica (a.c.) - Apparato di misura (indici di classe A, B, C)

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Immunità agli impulsi (Solo impulsi 1,2/50 µs su porte di alimentazione)	CEI EN 50470-1: 2007

[Handwritten signature]

**ВЪРНО С
ОРИГИНАЛА**




CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 2 di 10 PA35AR33.pdf

Immunità ai disturbi condotti, indotti da campi a radiofrequenza (Solo su porte di alimentazione con CDN tipo M)	CEI EN 50470-1: 2007
Immunità ai transitori/treni elettrici veloci	CEI EN 50470-1: 2007
Immunità alle scariche elettrostatiche	CEI EN 50470-1: 2007
Soppressione dei radiodisturbi	CEI EN 50470-1: 2007
Apparati per la misura dell'energia elettrica (a.c.) - Contatori statici di energia attiva (classe 1 e 2)	
<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Costante del contatore	CEI EN 62053-21: 2003
Influenza del riscaldamento proprio	CEI EN 62053-21: 2003
Limiti di errore dovuti alla variazione della corrente	CEI EN 62053-21: 2003
Limiti di errore dovuti alle grandezze di influenza	CEI EN 62053-21: 2003
Prova di avviamento e marcia a vuoto	CEI EN 62053-21: 2003
Apparati per la misura dell'energia elettrica (a.c.) - Contatori statici per energia attiva (indici di classe A, B, C)	
<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Autoriscaldamento	CEI EN 50470-3: 2007
Costante del contatore	CEI EN 50470-3: 2007
Errore massimo tollerato (MPE)	CEI EN 50470-3: 2007
Limiti di errore percentuale addizionale dovuti alle grandezze di influenza	CEI EN 50470-3: 2007
Limiti di errore percentuale dovuti alla variazione del carico	CEI EN 50470-3: 2007
Prova di avviamento e marcia a vuoto	CEI EN 50470-3: 2007
Ripetibilità	CEI EN 50470-3: 2007
Sovracorrenti di breve durata	CEI EN 50470-3: 2007
Apparati per la misura dell'energia elettrica (a.c.) - Contatori statici per energia reattiva (classi 2 e 3)	
<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Costante del contatore	CEI EN 62053-23: 2003
Influenza del riscaldamento proprio	CEI EN 62053-23: 2003
Limiti di errore dovuti alla variazione della corrente	CEI EN 62053-23: 2003
Limiti di errore dovuti alle grandezze di influenza	CEI EN 62053-23: 2003
Prova di avviamento e marcia a vuoto	CEI EN 62053-23: 2003
Apparecchiatura ad alta tensione - Apparecchiatura di manovra con involucro metallico con isolamento in gas per tensioni nominali superiori a 52 kV, High-voltage switchgear and controlgear - Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	
<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Misura della resistenza dei circuiti, Measurement of the resistance of circuits	CEI EN 62271-203: 2013, IEC 62271-203: 2011
Prove di isolamento, Dielectric tests	CEI EN 62271-203: 2013, IEC 62271-203: 2011
Prove di riscaldamento, Temperature-rise tests	CEI EN 62271-203: 2013, IEC 62271-203: 2011
Prove di tenuta alla corrente di breve durata e alla corrente di picco, Short-time withstand current and peak withstand current tests	CEI EN 62271-203: 2013, IEC 62271-203: 2011
Verifica dei poteri di stabilimento e di interruzione, Verification of making and breaking capacities	CEI EN 62271-203: 2013, IEC 62271-203: 2011

[Handwritten signature]

ВЯРНО С ОРГАНИЗАЦИЯ



CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 3 di 10 PA35AR33.pdf

Apparecchiatura ad alta tensione - Apparecchiatura prefabbricata con involucro metallico per tensioni da 1 kV a 52 kV
High-voltage switchgear and controlgear - AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Prove di isolamento, Dielectric tests	CEI EN 62271-200: 2013 / EC: 2015, IEC 62271-200: 2011 / EC: 2015

Apparecchiatura ad alta tensione - Apparecchiatura prefabbricata con involucro metallico per tensioni da 1 kV a 52 kV
High-voltage switchgear and controlgear - AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Misura della resistenza dei circuiti, Measurement of the resistance of circuits	CEI EN 62271-200: 2013, IEC 62271-200: 2011
Prova d'arco interno, Internal arc fault - Method to verify the internal arc classification (IAC)	CEI EN 62271-200: 2013, IEC 62271-200: 2011
Prove di riscaldamento, Temperature-rise tests	CEI EN 62271-200: 2013, IEC 62271-200: 2011
Prove di tenuta alla corrente di breve durata e alla corrente di picco, Short-time withstand current and peak withstand current tests	CEI EN 62271-200: 2013, IEC 62271-200: 2011
Verifica dei poteri di stabilimento e di interruzione, Verification of making and breaking capacities	CEI EN 62271-200: 2013, IEC 62271-200: 2011


Apparecchiatura ad alta tensione - Interruttori a corrente alternata
High-voltage switchgear and controlgear - Alternating-current circuit-breakers

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Cicli di prova fondamentali di cortocircuito, Basic short-circuit test-duties	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012
Misura della resistenza del circuito principale, Measurement of the resistance of the main circuit	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012
Prove di guasto in linea, Short-line fault tests	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012
Prove di guasto monofase e bifase a terra, Single-phase and double-earth fault tests	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012
Prove di manovra di correnti capacitive, Capacitive current switching tests	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012
Prove di sovratemperatura, Temperature-rise tests	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012
Prove di stabilimento e di interruzione, Making and breaking tests	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012
Prove di stabilimento e interruzione in discordanza di fase, Out-of-phase making and breaking tests	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012
Prove di tenuta alla corrente di breve durata e alla corrente di picco, Short-time withstand current and peak withstand current tests	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012
Prove dielettriche, Dielectric tests	CEI EN 62271-100: 2013 / A1: 2014, IEC 62271-100: 2012

Apparecchiatura ad alta tensione - Interruttori di manovra e Interruttori di manovra sezionatori per tensioni nominali superiori a 1 kV fino a 52 kV compreso
High-voltage switchgear and controlgear - Switches for rated voltages above 1 kV up to and including 52 kV

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Misura della resistenza dei circuiti, Measurement of the resistance of circuits	CEI EN 62271-103: 2012, IEC 62271-103: 2011
Prove di isolamento, Dielectric tests	CEI EN 62271-103: 2012, IEC 62271-103: 2011
Prove di riscaldamento, Temperature-rise tests	CEI EN 62271-103: 2012, IEC 62271-103: 2011

**ВЯРНО С
ОПРЕДЕЛЕНИЕ**




[Handwritten signature]

CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 4 di 10 PA35AR33.pdf

Prove di stabilimento e di interruzione, Making and breaking tests	CEI EN 62271-103: 2012 / EC 2014, IEC 62271-103: 2011
Prove di tenuta alla corrente di breve durata e alla corrente di picco, Short-time withstand current and peak withstand current tests	CEI EN 62271-103: 2012, IEC 62271-103: 2011
Apparecchiatura ad alta tensione - Manovra di carichi Induttivi High-voltage switchgear and controlgear - Inductive load switching <i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Prove di manovra della corrente del reattore in derivazione, Shunt reactor current switching tests	CEI EN 62271-110: 2014, IEC 62271-110: 2012
Apparecchiatura ad alta tensione - Prove sintetiche, High-voltage switchgear and controlgear - Synthetic testing <i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Specific requirements for synthetic tests for making and breaking performance related to the requirements of 6.102 through 6.111 of IEC 62271-100: 2008	CEI EN 62271-101: 2013, IEC 62271-101: 2012
Synthetic testing techniques and methods for short-circuit breaking tests	CEI EN 62271-101: 2013, IEC 62271-101: 2012
Synthetic testing techniques and methods for short-circuit making tests	CEI EN 62271-101: 2013, IEC 62271-101: 2012
Apparecchiatura ad alta tensione - Sezionatori e sezionatori di terra a corrente alternata per alta tensione, High-voltage switchgear and controlgear - Alternating current disconnectors and earthing switches <i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Misura della resistenza dei circuiti, Measurement of the resistance of circuits	CEI EN 62271-102: 2003 / EC: 2008 / A1: 2012, IEC 62271-102: 2013
Prova per dimostrare la prestazione di stabilimento di corrente di cortocircuito dei sezionatori di terra, Test to prove the short-circuit making performance of earthing switches	CEI EN 62271-102: 2003 / EC: 2008 / A1: 2012 / A2: 2014, IEC 62271-102: 2013
Prove di isolamento, Dielectric tests	CEI EN 62271-102: 2003 / EC: 2008 / A1: 2012 / A2: 2014, IEC 62271-102: 2013
Prove di manovra di corrente indotta, Induced current switching tests	CEI EN 62271-102: 2003 / EC: 2008 / A1: 2012 / A2: 2014, IEC 62271-102: 2013
Prove di manovra su corrente di commutazione di sbarra, Bus transfer current switching tests	CEI EN 62271-102: 2003 / EC: 2008 / A1: 2012 / A2: 2014, IEC 62271-102: 2013
Prove di sovratemperatura, Temperature-rise tests	CEI EN 62271-102: 2003 / EC: 2008 / A1: 2012, IEC 62271-102: 2013
Prove di tenuta alla corrente di breve durata e alla corrente di picco, Short-time withstand current and peak withstand current tests	CEI EN 62271-102: 2003 / EC: 2008 / A1: 2012 / A2: 2014, IEC 62271-102: 2013
Apparecchiatura di manovra e di comando ad alta tensione, High-voltage switchgear and controlgear <i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Misura della resistenza dei circuiti, Measurement of the resistance of circuits	CEI EN 62271-1: 2010 / A1: 2012, IEC 62271-1: 2011
Prove di riscaldamento, Temperature-rise tests	CEI EN 62271-1: 2010 / A1: 2012, IEC 62271-1: 2011
Prove di tenuta alla corrente di breve durata e alla corrente di picco, Short-time withstand current and peak withstand current tests	CEI EN 62271-1: 2010 / A1: 2012, IEC 62271-1: 2011
Prove dielettriche, Dielectric tests	CEI EN 62271-1: 2010 / A1: 2012, IEC 62271-1: 2011

[Handwritten signature]

**ВАРНО С
ОРИГИНАЛА**



CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 5 di 10 PA35AR33.pdf

Applicazioni ferroviarie, tranviarie, filoviarie e metropolitane - Impianti fissi - Apparecchiatura a corrente continua - Interruttori a corrente continua, Railway applications - Fixed Installations - D.C. switchgear - Circuit breakers

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Prova di durata elettrica, Electrical endurance test	CEI EN 50123-2: 2003, EN 50123-2: 2003
Ricerca delle correnti critiche ed esecuzione dei cicli di prova I) ed Ir), Search for critical currents and performing test duty I) and Ir)	CEI EN 50123-2: 2003, EN 50123-2: 2003
Verifica del comportamento con corrente di tenuta di breve per il ciclo di prova s, Verification of behaviour under short-time withstand current for test duty s	CEI EN 50123-2: 2003, EN 50123-2: 2003
Verifica del potere di chiusura e di interruzione in cortocircuito e delle caratteristiche H, V o S, Verification of the making and breaking capacity in short-circuit conditions and of the H, V or S characteristic	CEI EN 50123-2: 2003, EN 50123-2: 2003

Applicazioni ferroviarie, tranviarie, filoviarie e metropolitane - Impianti fissi - Apparecchiatura a corrente continua - Sezionatori, interruttori di manovra-sezionatori e sezionatori di terra a corrente continua per interno, Railway applications - Fixed Installations - Indoor d.c. disconnectors, switch-disconnectors and earthing switches


<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Prova di durata elettrica, Electrical endurance test	CEI EN 50123-3: 2003, EN 50123-3: 2003
Ricerca delle correnti critiche ed esecuzione delle prove di tipo a bassa corrente, Search for critical currents and performing the low current type test	CEI EN 50123-3: 2003, EN 50123-3: 2003
Verifica del comportamento sotto corrente ammissibile di breve durata, Verification of the behaviour during short-time withstand current test	CEI EN 50123-3: 2003, EN 50123-3: 2003
Verifica del potere di chiusura e di interruzione di targa, Verification of the rated making and breaking capacities	CEI EN 50123-3: 2003, EN 50123-3: 2003

Atmosfere esplosive - Parte 0: Apparecchi e sistemi di protezione destinati a essere utilizzati in atmosfera potenzialmente esplosiva

<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
§ 26.13 Prova di resistenza superficiale di parti di custodie in materiale non metallico / Surface resistance tests of parts of enclosures of non-metallic materials	EN 60079-0: 2012, IEC 60079-0: 2011
§ 26.14 Prove di carica / Measurement of capacitance	EN 60079-0: 2012, IEC 60079-0: 2011
§ 26.4.2 Resistenza all'urto / resistance to impact	EN 60079-0: 2012, IEC 60079-0: 2011
§ 26.4.3 Prova di resistenza alla caduta / drop test	EN 60079-0: 2012, IEC 60079-0: 2011
§ 26.4.5 grado di protezione (IP) fornito dalle custodie / degree of protection (IP) by enclosures	EN 60079-0: 2012, IEC 60079-0: 2011
§ 26.5.1 misura della temperatura / temperature measurements	EN 60079-0: 2012, IEC 60079-0: 2011
§ 26.5.2 prova agli sbalzi termici / thermal shock test	EN 60079-0: 2012, IEC 60079-0: 2011
§ 26.6 Prova di rotazione dei passanti / Torque test for bushing	EN 60079-0: 2012, IEC 60079-0: 2011
§ 26.8 resistenza termica al calore / thermal endurance to heat	EN 60079-0: 2012, IEC 60079-0: 2011
§ 26.9 resistenza termica al freddo / thermal resistance to cold	EN 60079-0: 2012, IEC 60079-0: 2011
A.3.1.4 Prove di trazione / Tensile Tests	EN 60079-0: 2012, IEC 60079-0: 2011

[Handwritten signature]

Stampa:
EN 60079-0: 2012, IEC 60079-0: 2011



CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 6 di 10 PA35AR33.pdf

A.3.1.5 Resistenza meccanica EN 60079-0: 2012, IEC 60079-0: 2011

Atmosfere esplosive - Parte 1: Apparecchiature protette mediante custodia a prova di esplosione 'd'
Denominazione della prova / Campi di prova *Metodo di prova*

§ 15.1.2 Determinazione della pressione di esplosione / Determination of explosion pressure (reference pressure) (Prove con Metano, Etilene Acetilene, Idrogeno.
Test with Methane, Ethylene, acetylene, Hydrogen) EN 60079-1:2007, IEC 60079-1:2007

§ 15.1.3.1 Prove di sovrappressione (Metodo statico) / Overpressure test (Static method) EN 60079-1:2007, IEC 60079-1:2007

Atmosfere esplosive - Parte 1: Apparecchiature protette mediante custodia a prova di esplosione 'd'
Denominazione della prova / Campi di prova *Metodo di prova*

§ 15.1.3.2 Prove di sovrappressione (Metodo dinamico) / Overpressure test (dynamic method) EN 60079-1:2007, IEC 60079-1:2007

§ 15.2 Prove di tenuta alla fiamma / Test for non-transmission of an internal ignition (Prove con Metano, Etilene Acetilene, Idrogeno.
Test with Methane, Ethylene, acetylene, Hydrogen) EN 60079-1:2007, IEC 60079-1:2007

§ 15.4.1 Prova di tenuta alla pressione della custodia / Tests of ability of the enclosure to withstand pressure (Prove con Metano, Etilene Acetilene, Idrogeno.
Test with Methane, Ethylene, acetylene, Hydrogen) EN 60079-1:2007, IEC 60079-1:2007

Atmosfere esplosive - Parte 7: Apparecchiature con modo di protezione a sicurezza aumentata 'e'
Denominazione della prova / Campi di prova *Metodo di prova*

§ 4.4 distanze di isolamento superficiali (limitatamente alla verifica dell'indice di resistenza alla traccia) / creepage distances (only verify for comparative tracking index) IEC 60079-7: 2006 / IEC 60079-7: 2007

§ 4.9 gradi di protezione delle custodie / degree of protection provided by enclosures IEC 60079-7: 2006 / IEC 60079-7: 2007

§ 6.1 Prova di rigidità dielettrica / dielectric strength IEC 60079-7: 2006 / IEC 60079-7: 2007

Atmosfere esplosive Parte 11: apparecchiature con modo di protezione a sicurezza intrinseca 'i'
Denominazione della prova / Campi di prova *Metodo di prova*

§ 11.2 prove di temperatura / temperatures EN 60079-11: 2012, IEC 60079-11: 2011

Atmosfere esplosive Parte 15: apparecchiature con modo di protezione 'n'
Denominazione della prova / Campi di prova *Metodo di prova*

§ 22.13 Prove di innesco per grandi macchine o macchine ad alta tensione / Ignition tests for large or high-voltage machines EN 60079-15: 2010, IEC 60079-15: 2010


§ 22.6 Type tests on restricted-breathing enclosures EN 60079-15: 2010, IEC 60079-15: 2010

Atmosfere esplosive Parte 18: Protezione mediante incapsulamento 'm'
Denominazione della prova / Campi di prova *Metodo di prova*

§ 8.1.1 Prova assorbimento di acqua / water absorption test EN 60079-15: 2010, IEC 60079-15: 2010

§ 8.2.4 Prova di rigidità dielettrica / Dielectich strengh test EN 60079-15: 2010, IEC 60079-15: 2010

ВЯРНУ С ОРГАНИЗАЦИЯ



CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 7 di 10 PA35AR33.pdf

§ 8.2.5 Prova di trazione del cavo / Cable pull test EN 60079-15: 2010,
IEC 60079-15: 2010

Atmosfere esplosive Parte 2: apparecchiature con modo di protezione a sovrappressione 'p'
Denominazione della prova / Campi di prova *Metodo di prova*

§ 16.1 Prova di sovrappressione massima / Maximum overpressure test; EN 60079-2: 2007,
IEC 60079-2: 2007

Atmosfere esplosive Parte 31: apparecchi con modo di protezione mediante custodie 't' destinati ad essere utilizzati in presenza di polveri combustibili
Denominazione della prova / Campi di prova *Metodo di prova*

§ 16.2 Prove di tenuta Leakage test; EN 60079-2: 2007,
IEC 60079-2: 2007

§ 16.3 Prove di lavaggio / Purging test; EN 60079-2: 2007,
IEC 60079-2: 2007

§ 6.1.1.3 prova di pressione / pressure test EN 60079-31: 2014,
IEC 60079-31: 2013

§ 6.1.2 prove termiche / thermal test EN 60079-31: 2014,
IEC 60079-31: 2013

Batterie / Cells and Batteries
Denominazione della prova / Campi di prova *Metodo di prova*

§ 10.5 prove su batterie / Test for cells and batteries EN 60079-11: 2012,
IEC 60079-11: 2011

Custodie a prova di esplosione con dispositivi di respirazione e drenaggio
Denominazione della prova / Campi di prova *Metodo di prova*

1^F 4.2 Thermal tests (Prove con Metano, Etilene Acetilene, Idrogeno.
with Methane, Ethylene, acetylene, Hydrogen) EN 60079-1:2007,
IEC 60079-1:2007

15.4.3 / Prove di tenuta alla fiamma per i dispositivi di respirazione e drenaggio / Test for non-transmission of an internal ignition of breathing and ignition devices (Prove con Metano, Etilene Acetilene, Idrogeno.
Test with Methane, Ethylene, acetylene, Hydrogen) EN 60079-1:2007,
IEC 60079-1:2007

Dispositivi ed unità riscaldanti a resistenza / resistance heating devices and resistance heating units
Denominazione della prova / Campi di prova *Metodo di prova*

§ 6.8.3 - Verifica isolamento elettrico / Electrical insulation test IEC 60079-7: 2006 / IEC 60079-7: 2007

§ 6.8.4 - Stabilità termica / Thermal stability test IEC 60079-7: 2006 / IEC 60079-7: 2007

§ 6.8.6 - Prova corrente di avviamento a freddo/ Cold start current IEC 60079-7: 2006 / IEC 60079-7: 2007

Flameproof cable glands, Ex blanking elements, Ex thread adaptors
Denominazione della prova / Campi di prova *Metodo di prova*


C.3.1 Sealing test EN 60079-1:2007,
IEC 60079-1:2007 - ANNEX C

C.3.2 Test of mechanical test strength EN 60079-1:2007,
IEC 60079-1:2007 - ANNEX C

C.3.3 Type test for Ex blanking elements EN 60079-1:2007,
IEC 60079-1:2007 - ANNEX C

[Handwritten signature]

**ВЯРНО С
ОРИГИНАЛА**



CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 8 di 10 PA35AR33.pdf

C.3.4 Type test for Ex thread adapters EN 60079-1:2007,
IEC 60079-1:2007 - ANNEX C

Fusibili ad alta tensione - Fusibili limitatori di corrente, High-voltage fuses - Current-limiting fuses
Denominazione della prova / Campi di prova Metodo di prova

Breaking tests CEI EN 60282-1: 2011,
IEC 60282-1: 2009

Isolatori di materiale ceramico o di vetro per linee aeree con tensione nominale superiore a 1000 V, Insulators of ceramic material or glass for overhead lines with a nominal voltage greater than 1000 V
Denominazione della prova / Campi di prova Metodo di prova

Impulse voltage puncture test on insulators in air CEI EN 61211: 2005,
IEC 61211: 2004

Isolatori passanti per tensioni alternate oltre 1000 V, Insulated bushings for alternating voltages above 1000 V
Denominazione della prova / Campi di prova Metodo di prova

Prova di tenuta a secco con tensione a impulso atmosferico (BIL), Dry lightning impulse voltage withstand test (BIL) CEI EN 60137: 2009,
IEC 60137: 2008

Prova di tenuta a secco o sotto pioggia con tensione a frequenza industriale, Dry or wet power-frequency voltage withstand test CEI EN 60137: 2009,
IEC 60137: 2008

Isolatori per linee aeree con tensione nominale superiore a 1000 V - Isolatori in materiale ceramico o in vetro per sistemi in corrente alternata, Insulators for overhead lines with a nominal voltage above 1000 V - Ceramic or glass insulator units for a.c. systems
Denominazione della prova / Campi di prova Metodo di prova

Prova di tenuta alla frequenza di esercizio sotto pioggia, Wet power-frequency voltage tests CEI EN 60383-1: 1998,
IEC 60383-1: 1993

Isolatori portanti per interno ed esterno di ceramica o di vetro, per impianti con tensione nominale superiore a 1000 V, Indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltages greater than 1000 V
Denominazione della prova / Campi di prova Metodo di prova

Prova di tensione di tenuta a impulso di manovra sotto pioggia o a secco, Dry or wet switching-impulse withstand voltage tests CEI EN 60168: 1996 / A1: 1998,
IEC 60168: 2001

Prova di tenuta a frequenza di esercizio a secco, Dry power-frequency withstand voltage test CEI EN 60168: 1996 / A1: 1998,
IEC 60168: 2001

Prova di tenuta a frequenza di esercizio sotto pioggia, Wet power-frequency withstand voltage test CEI EN 60168: 1996 / A1: 1998,
IEC 60168: 2001

Prova di tenuta a impulso atmosferico a secco, Dry lightning-impulse withstand voltage test CEI EN 60168: 1996 / A1: 1998,
IEC 60168: 2001

Line traps for a.c. power systems
Denominazione della prova / Campi di prova Metodo di prova

Short-time current tests IEC 60353: 1989

Morsetti / Terminals
Denominazione della prova / Campi di prova Metodo di prova

§ 6.9 prove sui materiali isolanti (trazione) / insulating test (tensile test) IEC 60079-7: 2006 / IEC 60079-7: 2007

Non-electrical equipment for use in potentially explosive atmospheres - Part 5: Protection by constructional safety 'c'
Denominazione della prova / Campi di prova Metodo di prova

B.1 'Dry run' test for lubricated sealing arrangements UNI EN 13463-5: 2011


B.2 Type test for determining the maximum engaging time of clutch assembly UNI EN 13463-5: 2011

B.3 Conductivity criteria for transmission belts UNI EN 13463-5: 2011

Rotating electrical machines - Part 5: Degrees of protection provided by the integral design of rotating electrical machines (IP code) - Classification
Denominazione della prova / Campi di prova Metodo di prova

[Handwritten signature]

OPRINTA




CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 9 di 10 PA35AR33.pdf

Test for first characteristic numeral;	IEC 60034-5:2006
Test for second characteristic numeral (Only IPX3, IPX4, IPX5, IPX6, IPX8 and IPX9)	IEC 60034-5:2006
Scaricatori - Scaricatori a resistori non lineari con spinterometri per sistemi a corrente alternata, Surge arresters - Non-linear resistor type gapped surge arresters for a.c. systems	
<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Insulation withstand tests	CEI EN 60099-4: 2015, IEC 60099-4: 2014
Operating duty tests	CEI EN 60099-4: 2015, IEC 60099-4: 2014
Power-frequency voltage-versus-time test	CEI EN 60099-4: 2015, IEC 60099-4: 2014
Partial discharge voltage tests	CEI EN 60099-4: 2015, IEC 60099-4: 2014
Short-circuit tests	CEI EN 60099-4: 2015, IEC 60099-4: 2014
Test to verify the repetitive charge transfer rating, Qrs	CEI EN 60099-4: 2015, IEC 60099-4: 2014
Trasformatori / Transformers	
<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
§ 10.10 Prove su trasformatori / Transformer test	EN 60079-11: 2012, IEC 60079-11: 2011
Trasformatori di potenza - Capacità di tenuta al cortocircuito, Power transformers - Ability to withstand short circuit	
<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Capacità di resistenza al cortocircuito dal punto di vista dinamico, Ability to withstand the dynamic effects of short circuit	CEI EN 60076-5: 2007, IEC 60076-5: 2006
Trasformatori di potenza - Livelli di isolamento, prove dielettriche e distanze isolanti in aria, Power transformers - Insulation levels, dielectric tests and external clearances in air	
<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Prova ad impulso atmosferico (LI), Lightning impulse tests (LI)	CEI EN 60076-3: 2015, IEC 60076-3: 2013
Prova di tensione applicata (AV), Applied voltage test (AV)	CEI EN 60076-3: 2015, IEC 60076-3: 2013
Prove a tensione indotta (IVW), Induced voltage tests (IVW)	CEI EN 60076-3: 2015, IEC 60076-3: 2013
Trasformatori di potenza - Trasformatori di tipo a secco, Power transformers - Dry-type transformers	
<i>Denominazione della prova / Campi di prova</i>	<i>Metodo di prova</i>
Misura del livello di rumore, Measurement of sound level	CEI EN 60076-11: 2006, IEC 60076-11: 2004
Misura del rapporto di tensione e controllo dello spostamento angolare, Measurement of voltage ratio and check of phase displacement	CEI EN 60076-11: 2006, IEC 60076-11: 2004
Misura della resistenza degli avvolgimenti, Measurement of winding resistance	CEI EN 60076-11: 2006, IEC 60076-11: 2004
Misura della tensione di corto circuito e delle perdite a carico, Measurement of short-circuit impedance and load loss	CEI EN 60076-11: 2006, IEC 60076-11: 2004
Misura delle perdite e della corrente a vuoto, Measurement of no-load loss and current	CEI EN 60076-11: 2006, IEC 60076-11: 2004

[Handwritten signature]

**ВАРНО С
ОРИГИНАЛА**



CESI S.p.A. Via Rubattino 54 20134 Milano MI	Numero di accreditamento: 0030 Sede A
	Revisione: 33 Data: 23/05/2016
	Scheda 10 di 10 PA35AR33.pdf

Prova ad impulso atmosferico,
Lightning impulse test

CEI EN 60076-11: 2006,
IEC 60076-11: 2004

Prova di cortocircuito,
Short-circuit test

CEI EN 60076-11: 2006,
IEC 60076-11: 2004

Prova di sovratemperatura,
Temperature-rise test

CEI EN 60076-11: 2006,
IEC 60076-11: 2004

Prova di tenuta a tensione applicata in c.a.,
Separate-source AC withstand voltage test

CEI EN 60076-11: 2006,
IEC 60076-11: 2004

Prova di tenuta a tensione indotta in c.a.,
Induced AC withstand voltage test

CEI EN 60076-11: 2006,
IEC 60076-11: 2004

**Trasformatori di potenza,
Power transformers**

Eliminazione della prova / Campi di prova

Metodo di prova

Determinazione dei livelli di rumore (Metodo per la misura della pressione
statica),
Determination of sound levels (Sound pressure method)

CEI EN 60076-10: 2002,
IEC 60076-10: 2001

Misura del rapporto di trasformazione e verifica dello sfasamento,
Measurement of voltage ratio and check of phase displacement

CEI EN 60076-1: 2015,
IEC 60076-1: 2011

Misura dell'impedenza di cortocircuito e delle perdite dovute al carico,
Measurement of short-circuit impedance and load loss

CEI EN 60076-1: 2015,
IEC 60076-1: 2011

Misura della resistenza degli avvolgimenti,
Measurement of winding resistance

CEI EN 60076-1: 2015,
IEC 60076-1: 2011

Misura delle perdite e della corrente a vuoto,
Measurement of no-load loss and current

CEI EN 60076-1: 2015,
IEC 60076-1: 2011

Prove di riscaldamento,
Temperature rise tests


CEI EN 60076-2: 2015,
IEC 60076-2: 2011

Legenda

ACCREDIA
Il Direttore del Dipartimento
(Dr.ssa Silvia Tramontin)




**ВЯРНО С
ОРИГИНАЛА**



ИЗПИТАТЕЛЕН ПРОТОКОЛ

Ускорено изпитване на атмосферни влияния на **POWERSIL® XLR® 630**
(Хепоп- дъга изпитване съгласно ISO 4892-2 *)


*) тест, проведен в Wacker-Chemie AG през август 2012 г. Времето на цикъла е 120 минути с дъжд от 18 минути и 102 мин сухолъчение. Черната стандартна температура на повърхността на пробите беше 65°C.

Свойства	Стандарт	Единици	Преди теста	След 3000 часа
Твърдост	DIN 53505	ShoreA	34	36
Издръжливост на опън	ISO 37	N/mm ²	5,6	4,2
Устойчивост на разкъсване	ASTM D 624 B	N/mm	23	20
Удължаване	ISO 37	%	353	196
Съпротивление на дъгата	IEC 61621	S	380	375
Диелектрична константа	IEC 60250		2,7	2,7
Хидрофобност	STRI Class	HC	1	1

След продължителност на теста от 3000 часа не са наблюдавани повърхностни разгради като пукнатини и повърхностни стъци.

Вурич, 17 март 2018

ВАРНО С
ОРГАНИЗАЦИЯ



Wacker Chemie AG
Hanns-Seidel-Platz 4
81737 München, Germany
silicones@wacker.com
www.wacker.com

TEST REPORT


Accelerated weathering test of POWERSIL® XLR® 630
 (Xenon-arc test according ISO 4892-2 *)

*) test carried out at Wacker-Chemie AG in August 2012. The cycle time was 120min with 18min rain and 102min dry radiation. The black-standard-temperature on the surface of the samples was 65°C.

Property	Standard	Unit	Virgin	After 3000h
Hardness	DIN 53505	ShoreA	34	36
Tensile strength	ISO 37	N/mm ²	5,6	4,2
Tear resistance	ASTM D 624 B	N/mm	23	20
Elongation	ISO 37	%	353	196
Arc resistance	IEC 61621	S	380	375
Dielectric Constant	IEC 60250		2,7	2,7
Hydrophobicity	STRI Class	HC	1	1

After accelerated weathering no surface degradations such as cracks and raised areas have been observed.

на основании чл. 2 от 33ЛД
 March 2018



[Handwritten signature]

Wacker Chemie AG
 Hanns-Seidel-Platz 4
 81737 München, Germany
 silicones@wacker.com
 www.wacker.com

[Handwritten signature]

ВАРНО С
 ОБЩИНА ВАРНА

()

(