




Attachment No. 2

KRAC 50/17	E12KA-01010301300	M12	✓	9,8	16,0	42	62	25	70	50	16	3	5
KRAC 50/14	E12KA-01010301400	M14	-	9,8	16,0	42	62	25	70	50	16	3	5
KRAC 70/8	E12KA-01010301500	M8	✓	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/10	E12KA-01010301600	M10	✓	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/12	E12KA-01010301700	M12	✓	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/14	E12KA-01010301800	M14	-	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/16	E12KA-01010301900	M16	-	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 95/10	E12KA-01010302000	M10	✓	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 95/12	E12KA-01010302100	M12	✓	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 95/14	E12KA-01010302200	M14	-	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 95/16	E12KA-01010302300	M16	-	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 120/10	E12KA-01010302400	M10	✓	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 120/12	E12KA-01010302500	M12	✓	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 120/14	E12KA-01010302600	M14	-	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 120/16	E12KA-01010302700	M16	✓	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 150/10	E12KA-01010302800	M10	✓	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/12	E12KA-01010302900	M12	✓	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/14	E12KA-01010303000	M14	-	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/16	E12KA-01010303100	M16	✓	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/20	E12KA-01010303200	M20	-	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 185/10	E12KA-01010303300	M10	✓	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/12	E12KA-01010303400	M12	✓	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/14	E12KA-01010303500	M14	-	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/16	E12KA-01010303600	M16	✓	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/20	E12KA-01010303700	M20	-	18,3	28,5	60	91	30	240	185	28	3	6

Product data sheet (continued):

I-POB-07/01-Z3w9



ВЕРНО С ОРИГИНАЛОМ
Подпись:



Attachment No. 2

KRAC 240/10	E12KA- 01010303800	M10	..	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/12	E12KA- 01010303900	M12	√	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/14	E12KA- 01010304000	M14	-	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/16	E12KA- 01010304100	M16	√	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/20	E12KA- 01010304200	M20	-	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 300/12	E12KA- 01010304400	M12	√	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 300/14	E12KA- 01010304500	M14	-	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 300/16	E12KA- 01010304600	M16	√	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 300/20	E12KA- 01010304700	M20	√	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 500/16	E12KA- 01010305201	M16	√	29,0	44,0	80	122	44	-	500	44	4	-

I-POB-07/01-Z3w9
 ВЯРНО С ОФИЦИАЛ
 Подпис:



since 1933

ASSOCIATION of POLISH ELECTRICIANS
QUALITY TESTING OFFICE
ul. M. Pożaryskiego 28, 04-703 Warszawa, Poland

tel./fax: +48 22 815 65 80

TESTING LABORATORY



AB 044




TEST REPORT
PN-EN 61238-1

Compression and mechanical connectors for power cables for rated voltages up 36 kV ($U_m = 42$ kV)
Part 1: Test methods and requirements (IEC 61238-1:2003, modified)

Report Reference No.	LA-17.062/17.045/3/E
Data of issue	2017-12-29
Total number of pages	19
Tested by (name + position + signature)	Krzysztof Podgórnjak Specialist
Authorized by (name + position + signature)	Dariusz Szczepanowski Manager of LA
Testing application number	C-A-17-062/17.045
Test item reference	S-A-17-045
Scope of test	<input checked="" type="checkbox"/> - type test <input type="checkbox"/> - partial test
Test specification:	
Standard/procedure	<input checked="" type="checkbox"/> PN-EN 61238-1:2004, EN 61238-1:2003, IEC 61238-1:2003 (Second Edition)
Non-standard test methods	N/A
Non-accredited test methods	N/A
Applicant's name	Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o.
Address	ul. Nowe Sady 10, 94-102 Łódź

на основании чл. 36а, ал. 3
от ЗОП

The BBJ test report form is not permitted for commercial purposes
without written approval of the BBJ Testing Laboratory



ВЕРНО С ОСТАВА
Подпись:



Test item description: Aluminium terminals longitudinally sealed

Trade Mark: **ER2 ERGOM®**

Manufacturer: Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o.
ul. Nowe Sady 10, 94-102 Łódź

Model/Typ reference: KRAC 16 + 300 / This report covers test of KRAC 120/12

Ratings: Nominal cross-sectional area: 16 mm² + 300 mm² / This report covers test of 120 mm²

List of Attachments:

Attachment No.	Attachment No.	Attachment No.
1	Summary of the test result	1
2	Product information and photos of samples	6

Summary of testing:

Test performer (in the case of partial tests): N/A	Testing location/address (if different from page 1) : Stowarzyszenie Elektryków Polskich, Biuro Badawcze ds. Jakości Association of Polish Electrician, Quality Testing Office ul. M. Rapackiego 13, 20-150 Lublin, POLAND
Number of tests with F (Fail) verdict:	0
Summary conformity/non-conformity with standardization document (if apply):	N/A
Summary of compliance with National Differences (if apply): Provide list of standards.	N/A
Opinion and interpretation if needed:	N/A
Other additional information (as requested by the applicant):	N/A

Copy of marking plate:



Al 12-120rm/srn 150se ERGOM 22

KRAC 120/12



ВЯРМО С ОРЪДИНА
Подпис: ПОВ-07/01-Z3w9



Test item particular:	
Classification of installation and use	: N/A
Supply Connection	: N/A
Date (s) of receipt of test item	: 2017-06-23 (Sample No. 1.1...1.7, 4.1...4.7) 2017-07-20 (Sample No. 2.1...2.21) 2017-09-11 (Sample No. 3.1...3.21) 2017-10-06 (Sample No. 4.8...4.19) 2017-10-13 (Sample No. 1.8...1.21)
Date (s) of performance of tests	: 2017-06-28...2017-12-29
Possible test case verdicts:	
- test case does not apply to the test object	: N/A
- test object does meet the requirement	: P (Pass)
- test object does not meet the requirement	: F (Fail)
Test report general remarks:	
1. The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.	
2. "(See Enclosure #)" refers to additional information appended to the report..	
3. "(See appended table)" refers to a table appended to the report	
4. Throughout this report a comma is used as the decimal separator.	
5. Test Report Form is based on TRF No.: IEC61238_1A, copyrighted by IECCE.	
Production place(s)	: Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o. ul. Nowe Sady 10, 94-102 Łódź

TRF No. IEC61238_1A

ВЯРНО С ОРИГИНАЛА
Подпис:



General product information:

Tests were carried out on samples of aluminium terminals longitudinally sealed type KRAC, nominal cross sectional area 16 mm² + 300 mm².

According to the standard and as agreed with the manufacturer for the tests were prepared four loops: 16 mm², 70 mm², 120 mm² and 300 mm² cross sectional area.

This report covers test of 120 mm², KRAC 120/12.

Electro-hydraulic presses HKP 22 EL with hexagonal die KP22-W120 was used to crimp testing terminals KRAC 120. Hexagonal die KP22-W120 is dedicated to aluminium terminals with a DIN-conforming tubular part (size DIN 22) for crimping cables RMC/RMV.

Cable YAKY 1x120 mm² RMV 0,6/1kV, manufacturer NKT was used to electrical and mechanical tests of terminals KRAC 120.

Torque for screw of terminal lugs was 27,7 Nm ± 29,1 Nm.

Samples were marked for the tests as S-A-17-045/1.1...1.21, S-A-17-045/2.1...2.21, S-A-17-045/3.1...3.21 and S-A-17-045/4.1...4.19. In the Test Report abbreviated marking of the samples, as the samples No. 1.1...1.21, 2.1...2.21, 3.1...3.21, 4.1...4.19 is used.

Type:	No.:
KRAC 16/10	1.1...1.21
KRAC 70/12	2.1...2.21
KRAC 120/12	3.1...3.21
KRAC 300/12	4.1...4.19

TRF No. IEC61238-1A
ВАРНО С СЕРТИФИКАТ
Подпис:




PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
Identification			—
	Connector		—
	Type of connector	<input type="checkbox"/> through connector <input type="checkbox"/> branch connector <input checked="" type="checkbox"/> terminal lug	—
	Nominal cross-sectional area	120 mm ²	—
	Class of connector	<input checked="" type="checkbox"/> Class A <input type="checkbox"/> Class B	—
5.1	Conductor		—
	conductor material.....	Al	—
	nominal cross-sectional area.....	120 mm ² RMV	—
	actual conductor area	120 mm ² RMV	—
	leading dimensions and shape.....	Unprepared cable	—
	type of conductor (solid or stranded)	120 mm ² - stranded	—
	details of conductor construction (in the case of stranded conductors)	120 mm ² – stranded cable, round, 23 wires	—
	compacted / non-compacted	Compacted	—
	flexible	No	—
	number of wires	23 wires	—
	direction of lay	Right	—
	plating.....	No plating	—
	type of impregnation, if any	—	—
	approximate indication of hardness (annealed, half-hard, hard).....	Hard	—
	type of insulation (in case of insulation-piercing connectors)	—	—
5.2	Connectors and tooling		—
	assembly technique	Crimp connection	—
	tooling and necessary settings	Electro-hydraulic presses HKP 22 EL with hexagonal die KP22-W120. Hexagonal die KP22-W120 is dedicated to aluminium terminals with a DIN-conforming tubular part for crimping cables RMC/RMV. Size DIN 22; torque wrench	—
	preparation of contact surfaces	Terminal lug filled with contact grease	—

TRF No. IEC61238_1A

ВЯНО С ОПИЗНАВА
 Подпис:





PN-EN 61238-1			
Clause	Requirement – Test	Result - Remark	Verdict

	type, reference number and other identification of the connector	KRAC 120: surface: tin-plated; material: Al	—
--	--	---	---

6	Electrical tests		P
----------	-------------------------	--	----------

6.1	Installation		P
------------	---------------------	--	----------

	six connectors fitted in accordance with the manufacturer's instructions		P
--	--	--	----------

	welded equalizers used	Yes	P
--	------------------------	-----	----------

	in case of insulation-piercing connectors, the insulation retained on the conductor under the connector, and for a distance of at least 100 mm outside the connector		N/A
--	--	--	------------

	ambient temperature of the test location (between 15 °C and 30 °C)	18 °C...24 °C	P
--	--	---------------	----------

	the test loop is dismantlable for short-circuit test (class A connectors only)	Short-circuit test performed without dismantling, loop divided on two sections for test	N/A
--	--	---	------------

	the technology of the sectioning joints do not influence the measurements		N/A
--	---	--	------------

	bolts or screws of the connectors were not retightened under test		P
--	---	--	----------

6.1.1	Through connectors and terminal lugs		—
--------------	---	--	----------

	test loop and dimensions according to Figure 1	See Attachment No. 2	P
--	--	----------------------	----------

	linking bars used (in case of terminal lugs)	Without use of linking bars	N/A
--	--	-----------------------------	------------

	the palms bolted to the linking bars in accordance with the manufacturer's instructions		N/A
--	---	--	------------

	linking bars have the same dimensions and material as the palm		N/A
--	--	--	------------

	palm connected direct to palm	Direct connected (see Attachment No. 2)	P
--	-------------------------------	---	----------

6.1.2	Branch connectors		—
--------------	--------------------------	--	----------

	branch connector is treated as a through connector between the main and the branch (size of branch cable equal to the main, or immediately above or below the main)		N/A
--	---	--	------------

	In other cases, test loop and dimensions according to Figure 2		N/A
--	--	--	------------


6.2	Measurements		P
------------	---------------------	--	----------

6.2.1	Electrical resistance measurements		P
--------------	---	--	----------

	measurements made at stages throughout the test as specified in 6.3		P
--	---	--	----------

TRF No. IEC61238_1A

ВЕРНО С ОФОРМЛЕНИЕМ
Подпись:





PN-EN 61238-1			
Clause	Requirement – Test	Result - Remark	Verdict
	method used	<input checked="" type="checkbox"/> indirect <input type="checkbox"/> direct	—
	indirect method: measuring current is 10 % of the heat cycling current	KRAC 120: 36 A + 38 A	P
	potential points as indicated in Figure 3 and annex B		P
	Precision of resistance measurements, indirect method		—
	voltage: max. $\pm 0,5$ % or ± 10 μ V, actual precision	$\pm 0,5$ %	P
	current: max. $\pm 0,5$ % or $\pm 0,1$ A, actual precision	$\pm 0,5$ %	P
	Precision of resistance measurements, direct method: better than ± 1 % or $\pm 0,5$ μ Ω , actual precision	—	N/A
6.2.2	Temperature measurements		P
	stages as specified in 6.3		P
	the temperature of connectors and reference conductor measured at the points as indicated in Figure 3	Figure 3a, 3e, 3f	P
	thermocouples used as reference method	Yes	P
	total accuracy of temperature measurements: ± 2 °C or better, actual accuracy	$\pm 2,0$ °C	P
6.3	Heat cycle test		P
	power frequency current used	AC 50 Hz	P
6.3.1	First heat cycle		—
6.3.1 a)	Non insulation-piercing through connectors and terminal lugs	Sample No. 3.1...3.6	P
	current is circulated in the test loop, bringing the reference conductor to 120 °C at equilibrium		P
	measured temperature of the median connector ..	Sample No. 3.3: 103,3 °C	—
	reference conductor temperature (120 °C \leq Θ_R \leq 140 °C)	126,2 °C	—
	equilibrium current I_N	425 A	—
6.3.1 b)	Non insulation-piercing branch connectors		N/A
	test circuit according to	<input type="checkbox"/> Figure 1 <input type="checkbox"/> Figure 2	—
	current is circulated in the test loop, bringing the reference conductor to 120 °C at equilibrium		N/A


TRF No. IEC61238_1A

ВЕРНО С ОБОИХ СТОРОН
Подпись:



PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
	current in all individual branch adjusted so that each branch reference temperature is the same as the main reference temperature		N/A
	measured temperature of the median connector ...:		—
	reference conductor temperature (120 °C ≤ Θ _R ≤ 140 °C)		—
	equilibrium current I _N		—
6.3.1 c)	Insulation-piercing connectors (IPC)		N/A
	test circuit according to	<input type="checkbox"/> Figure 1 <input type="checkbox"/> Figure 2	—
	isolated reference conductor used		N/A
	permitted temperature of the cable		—
	temperature of the median connector is set 10 K above permitted temperature of the cable		N/A
	measured temperature of the median connector ...:		—
	temperature of the reference conductor(s) is(are) set max.15 K above permitted temperature of the cable		N/A
	temperature of the isolated reference conductor(s) at equilibrium		N/A
	equilibrium current I _N		—
6.3.2	Second heat cycle	Sample No. 3.1...3.6	—
	current is circulated in the loop until the main reference conductor temperature reaches the value Θ _R determined in 6.3.1 with a tolerance of +6 °C	126 °C ± 132 °C	P
	the median connector temperature is stable within 2 °C over a 10 min period		P
	current flow time (t ₁)	49 min	—
	accelerated heating used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	—
	accelerated heating time	17 min	—
	accelerated heating time according to Table 1	10 min	P
	cooling time (t ₂)	15 min	—
	After cooling, the temperature of all connectors and the reference conductor ≤ 35 °C		P
	accelerated cooling used with ambient air	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	—
6.3.3	Subsequent heat cycles	Sample No. 3.1...3.6	—
	a total of 1000 heat cycles performed		P
	Measurements performed at the following cycles:		
	Class A: 0, 200 (before and after short-circuit test), 250, then every 75		P



TRF No. IEC61238-1A

ВАРИАНТ С ОПРЕДЕЛЕНИЕМ
Подпись:



PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
	Class B: 0, 250, then every 75		N/A
	cold resistance and temperature of each connector and reference conductor/conductors measured	See TABLE 1/1 and TABLE 1/2	P
	maximum temperature of each connector measured	See TABLE 2	P
6.3.4	Short-circuit tests (for Class A connectors only)	Sample No. 3.1...3.6	P
	six short circuits applied after the 200th heat cycle	Short-circuit test performed without dismantling, loop divided on two sections for test	P
	short-circuit current	I half: 11,71 kA + 11,78 kA, II half: 11,61 kA + 11,68 kA	—
	short-circuit current raises the reference conductors from a temperature of ≤ 35 °C to a temperature between 250 °C and 270 °C		P
	measured temperature of the reference conductor:	I half: 254,6 °C + 256,4 °C, II half: 252,2 °C + 259,2 °C	P
	duration of the short-circuit current (1 s below 25 kA, ≤ 5 s above 25 kA)	I half: 1,37 s + 1,40 s, II half: 1,39 s + 1,44 s	P
	the test loop cooled to a temperature ≤ 35 °C after each short circuit		P
6.4	Assessment of results		P
	Calculated parameters:		—
	connector resistance factor k , calculated according to annex E, clause E.2	See TABLE 3/1 and TABLE 3/2	—
	initial scatter δ , between the six initial values of k measured prior to heat cycling, calculated according to annex E, clause E.3	See TABLE 4/1 and TABLE 4/2	P
	mean scatter β , between the six values of k averaged over the last 11 measurement intervals, calculated according to annex E, clause E.4	See TABLE 5/1 and TABLE 5/2	P
	change in resistance factor D for each of the six connectors, calculated according to annex E, clause E.5	See TABLE 6/1 and TABLE 6/2	P
	resistance factor ratio λ calculated according to annex E, clause E.6	See TABLE 7/1 and TABLE 7/2	P
	maximum temperature θ_{max} on each connector, recorded according to annex E, clause E.7	See TABLE 2	P
6.5	Requirements		P
	more than four connectors satisfy the requirements shown in table 2		N/A
	one full re-test performed	<input type="checkbox"/> Yes <input type="checkbox"/> No	


TRF No. IEC61238_1A

ВЕРНО С СРЕДСТВОМ
Подпись:



PN-EN 61238-1			
Clause	Requirement – Test	Result - Remark	Verdict
	six connectors satisfy the requirements shown in table 2		P
	values of δ do not exceed 0,3	See TABLE 4/1 and TABLE 4/2	P
	values of β do not exceed 0,3	See TABLE 5/1 and TABLE 5/2	P
	values of D do not exceed 0,15	See TABLE 6/1 and TABLE 6/2	P
	values of λ do not exceed 2,0	See TABLE 7/1 and TABLE 7/2	P
	values of e_{max} do not exceed e_{ref}	See TABLE 2	P

7	Mechanical tests		P
7.1	Test method		—
	the test is made on three connectors different from those used for the electrical test	Sample No. 3.7...3.9	P
	connectors are fitted as for the electrical test of 6.1		P
	the conductor lengths, between connectors or between connector and tensile test machine jaws, are more than 500 mm		P
	the rate of application of the load do not exceed 10 N/mm ² of cross-section per second		P
7.2	Requirements		P
	tensile force applied during one minute	Conductor of 120 mm ² Al; 1 min	P
	force for aluminium, (40×A [mm ²], max. 20 000) ...:	40 x 120 = 4800 N	P
	force for copper, (60×A [mm ²], max. 20 000)		N/A
	in case the connector is electrically tested for conductors with difference cross-sectional area, the different joints tested individually to the above requirements		N/A
	no slipping during the tensile test		P



TRF No. IEC61238_1A
 ВЯРНО С СИГНАМ
 Подпис:




PN-EN 61238-1

6.3.3		TABLE 1/1: cold resistance and temperature of the connectors						—
cycle		connectors						reference conductor
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	R [mΩ]	0,0515	0,0523	0,0514	0,0511	0,0511	0,0511	0,0704
	θ [°C]	19,9	20,5	20,4	20,5	20,3	20,2	20,1
200.*	R [mΩ]	0,0519	0,0528	0,0518	0,0514	0,0516	0,0511	0,0708
	θ [°C]	21,0	21,3	21,3	21,5	21,5	21,6	20,9
200.*	R [mΩ]	0,0537	0,0554	0,0536	0,0530	0,0533	0,0532	0,0708
	θ [°C]	23,0	23,4	23,7	23,5	23,5	23,6	23,1
250.	R [mΩ]	0,0538	0,0559	0,0537	0,0528	0,0532	0,0533	0,0708
	θ [°C]	21,7	21,8	22,1	22,2	22,2	21,9	21,9
325.	R [mΩ]	0,0540	0,0560	0,0541	0,0533	0,0535	0,0537	0,0709
	θ [°C]	21,7	22,3	22,3	22,4	22,5	22,7	21,8
400.	R [mΩ]	0,0539	0,0558	0,0539	0,0530	0,0535	0,0537	0,0708
	θ [°C]	19,3	19,6	19,9	20,0	20,1	20,0	19,3
475.	R [mΩ]	0,0538	0,0559	0,0540	0,0532	0,0534	0,0537	0,0707
	θ [°C]	20,2	20,6	20,7	20,8	20,7	20,8	20,3
550.	R [mΩ]	0,0538	0,0561	0,0541	0,0533	0,0535	0,0534	0,0709
	θ [°C]	21,0	21,5	21,7	21,8	21,8	21,7	21,0
625.	R [mΩ]	0,0539	0,0560	0,0540	0,0532	0,0535	0,0536	0,0706
	θ [°C]	21,2	21,5	21,8	21,8	21,8	21,8	21,4
700.	R [mΩ]	0,0539	0,0558	0,0540	0,0531	0,0534	0,0536	0,0707
	θ [°C]	22,9	23,2	23,6	23,6	23,5	23,4	22,8
775.	R [mΩ]	0,0539	0,0559	0,0540	0,0532	0,0535	0,0536	0,0705
	θ [°C]	23,6	24,0	24,3	24,3	24,2	24,2	23,6
850.	R [mΩ]	0,0539	0,0560	0,0540	0,0532	0,0534	0,0538	0,0706
	θ [°C]	21,4	21,7	22,0	22,0	21,9	22,0	21,5
925.	R [mΩ]	0,0540	0,0560	0,0539	0,0534	0,0534	0,0537	0,0706
	θ [°C]	20,9	21,2	21,4	21,5	21,5	21,5	21,0
1000.	R [mΩ]	0,0538	0,0557	0,0538	0,0533	0,0534	0,0537	0,0705
	θ [°C]	18,6	19,2	19,3	19,5	19,3	19,1	18,8

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 3.1...3.6 (conductor of 120 mm²)






PN-EN 61238-1

6.3.3 TABLE 1/2: cold resistance and temperature of the connectors								
cycle		connectors						reference conductor
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	R [mΩ]	0,0035	0,0035	0,0036	0,0038	0,0037	0,0037	0,0704
	θ [°C]	20,0	20,6	20,5	20,6	20,4	20,4	20,1
200.*	R [mΩ]	0,0039	0,0036	0,0036	0,0037	0,0036	0,0038	0,0708
	θ [°C]	21,1	21,5	21,5	21,6	21,6	21,8	20,9
200.*	R [mΩ]	0,0035	0,0035	0,0037	0,0037	0,0037	0,0035	0,0708
	θ [°C]	23,1	23,5	23,7	23,6	23,6	23,6	23,1
250.	R [mΩ]	0,0035	0,0036	0,0037	0,0038	0,0035	0,0035	0,0708
	θ [°C]	21,8	22,0	22,3	22,5	22,4	22,1	21,9
325.	R [mΩ]	0,0035	0,0036	0,0037	0,0038	0,0035	0,0035	0,0709
	θ [°C]	22,0	22,4	22,5	22,5	22,6	22,8	21,8
400.	R [mΩ]	0,0036	0,0036	0,0037	0,0038	0,0035	0,0035	0,0708
	θ [°C]	19,4	19,7	20,0	20,0	20,3	20,0	19,3
475.	R [mΩ]	0,0035	0,0035	0,0036	0,0038	0,0034	0,0036	0,0707
	θ [°C]	20,3	20,7	20,8	20,9	20,8	21,0	20,3
550.	R [mΩ]	0,0035	0,0035	0,0036	0,0038	0,0034	0,0035	0,0709
	θ [°C]	21,1	21,6	21,9	21,9	21,9	21,9	21,0
625.	R [mΩ]	0,0035	0,0034	0,0036	0,0038	0,0037	0,0035	0,0706
	θ [°C]	21,2	21,6	21,9	21,9	21,9	21,9	21,4
700.	R [mΩ]	0,0035	0,0035	0,0036	0,0038	0,0035	0,0035	0,0707
	θ [°C]	22,9	23,3	23,8	23,8	23,7	23,7	22,8
775.	R [mΩ]	0,0035	0,0035	0,0037	0,0037	0,0035	0,0036	0,0705
	θ [°C]	23,7	24,1	24,4	24,3	24,4	24,3	23,6
850.	R [mΩ]	0,0035	0,0035	0,0037	0,0037	0,0035	0,0035	0,0706
	θ [°C]	21,5	21,8	22,1	22,2	22,1	22,2	21,5
925.	R [mΩ]	0,0035	0,0035	0,0037	0,0037	0,0037	0,0035	0,0706
	θ [°C]	21,0	21,3	21,4	21,6	21,7	21,7	21,0
1000.	R [mΩ]	0,0035	0,0035	0,0036	0,0037	0,0035	0,0035	0,0705
	θ [°C]	18,6	19,2	19,4	19,4	19,3	19,1	18,8

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 3.1...3.6 – pair of terminal lug (conductor of 120 mm²)



ВЕРНО (TRF No. IEC61238_1A)
Подпись:



PN-EN 61238-1

6.3.3		TABLE 2: maximum temperature of each connector measured						P
cycle		connectors						reference conductor
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	Θ_{max} [°C]	101,4	102,4	103,3	104,0	100,7	104,4	126,2
200.*	Θ_{max} [°C]	96,0	101,1	104,3	104,4	100,5	107,0	129,1
200.*	Θ_{max} [°C]	103,0	109,9	111,8	111,4	108,7	113,8	129,1
250.	Θ_{max} [°C]	103,4	110,5	111,5	110,9	107,7	112,7	129,4
325.	Θ_{max} [°C]	102,0	109,5	110,0	111,2	109,0	112,7	130,6
400.	Θ_{max} [°C]	103,0	111,4	109,5	111,7	109,1	112,7	129,7
475.	Θ_{max} [°C]	100,1	108,6	107,7	109,8	106,9	111,6	126,8
550.	Θ_{max} [°C]	101,4	108,4	108,2	109,8	107,1	113,2	127,5
625.	Θ_{max} [°C]	102,4	110,6	108,3	110,8	108,0	112,1	129,0
700.	Θ_{max} [°C]	101,2	109,4	106,2	108,6	106,1	111,1	129,7
775.	Θ_{max} [°C]	98,2	105,4	101,5	102,5	101,4	107,0	128,1
850.	Θ_{max} [°C]	100,0	106,0	104,0	104,1	103,0	107,7	131,3
925.	Θ_{max} [°C]	98,3	105,8	101,7	103,5	101,6	107,4	127,3
1000.	Θ_{max} [°C]	98,2	105,3	101,4	103,0	101,6	107,3	127,3

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 3.1...3.6 (conductor of 120 mm²)

TRF No. IEC61238_1A

ВЕРНО С СРЕДСТВОМ
Подпись:



PN-EN 61238-1

6.4		TABLE 3/1: connector resistance factor k, calculated according to annex E, clause E.2						P	
Parameters:		L _a =	165 mm	L _b =	— mm	L _r =	290 mm	L _{jl} =	60 mm
cycle		connectors							
		j=1	j=2	j=3	j=4	j=5	j=6		
0.		0,7827	0,8376	0,7758	0,7552	0,7552	0,7552		
200.*		0,7919	0,8533	0,7851	0,7578	0,7714	0,7373		
200.*		0,9148	1,0308	0,9080	0,8670	0,8875	0,8806		
250.		0,9216	1,0650	0,9148	0,8533	0,8806	0,8875		
325.		0,9339	1,0703	0,9408	0,8862	0,8999	0,9135		
400.		0,9284	1,0581	0,9284	0,8670	0,9011	0,9148		
475.		0,9298	1,0733	0,9434	0,8887	0,9024	0,9229		
550.		0,9203	1,0771	0,9408	0,8862	0,8999	0,8930		
625.		0,9379	1,0817	0,9448	0,8900	0,9105	0,9174		
700.		0,9366	1,0665	0,9434	0,8819	0,9024	0,9161		
775.		0,9461	1,0832	0,9530	0,8981	0,9187	0,9255		
850.		0,9379	1,0817	0,9448	0,8900	0,9037	0,9311		
925.		0,9448	1,0817	0,9379	0,9037	0,9037	0,9242		
1000.		0,9392	1,0695	0,9392	0,9050	0,9118	0,9324		

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 3.1...3.6 (conductor of 120 mm²)

TRF No. IEC61238_1A

ВЕРНО С ОПИСАНИЕМ
Подпись:



PN-EN 61238-1

6.4		TABLE 3/2: connector resistance factor k , calculated according to annex E, clause E.2						P	
Parameters:		$L_a=$	165 mm	$L_b=$	— mm	$L_r=$	290 mm	$L_{jp}=$	35 mm
cycle		connectors							
		j=1	j=2	j=3	j=4	j=5	j=6		
0.		0,4176	0,4166	0,4260	0,4429	0,4339	0,4310		
200.*		0,4519	0,4197	0,4206	0,4384	0,4165	0,4401		
200.*		0,4062	0,4118	0,4272	0,4336	0,4319	0,4138		
250.		0,4057	0,4157	0,4367	0,4417	0,4140	0,4059		
325.		0,4099	0,4156	0,4272	0,4405	0,4147	0,4116		
400.		0,4236	0,4198	0,4283	0,4480	0,4056	0,4090		
475.		0,4139	0,4131	0,4258	0,4444	0,4037	0,4188		
550.		0,4055	0,4142	0,4170	0,4429	0,3978	0,4104		
625.		0,4145	0,4010	0,4262	0,4414	0,4326	0,4138		
700.		0,4052	0,4115	0,4166	0,4444	0,4080	0,4078		
775.		0,4121	0,4149	0,4301	0,4335	0,4146	0,4179		
850.		0,4156	0,4063	0,4309	0,4326	0,4114	0,4112		
925.		0,4159	0,4089	0,4335	0,4300	0,4394	0,4142		
1000.		0,4126	0,4135	0,4241	0,4392	0,4113	0,4101		

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 3.1...3.6 – palm of terminal lug (conductor of 120 mm²)

6.4		TABLE 4/1: initial scatter δ , between the six initial values of k measured prior to heat cycling, calculated according to annex E, clause E.3						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	K_0	0,7770	0,7770	0,7770	0,7770	0,7770	0,7770	
	s_0	0,0320	0,0320	0,0320	0,0320	0,0320	0,0320	
	δ	0,0680	0,0680	0,0680	0,0680	0,0680	0,0680	

Supplementary information: Sample No. 3.1...3.6 (conductor of 120 mm²)



PN-EN 61238-1

6.4		TABLE 4/2: initial scatter δ , between the six initial values of k measured prior to heat cycling, calculated according to annex E, clause E.3						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	K_0	0,4280	0,4280	0,4280	0,4280	0,4280	0,4280	
	s_0	0,0101	0,0101	0,0101	0,0101	0,0101	0,0101	
	δ	0,0389	0,0389	0,0389	0,0389	0,0389	0,0389	

Supplementary information: Sample No. 3.1...3.6 – palm of terminal lug (conductor of 120 mm²)

6.4		TABLE 5/1: mean scatter β , between the six values of k averaged over the last 11 measurement intervals, calculated according to annex E, clause E.4						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	k	0,9342	1,0735	0,9392	0,8864	0,9032	0,9162	
	K	0,9421	0,9421	0,9421	0,9421	0,9421	0,9421	
	s	0,0673	0,0673	0,0673	0,0673	0,0673	0,0673	
	β	0,1179	0,1179	0,1179	0,1179	0,1179	0,1179	

Supplementary information: Sample No. 3.1...3.6 (conductor of 120 mm²)

6.4		TABLE 5/2: mean scatter β , between the six values of k averaged over the last 11 measurement intervals, calculated according to annex E, clause E.4						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	k	0,4122	0,4122	0,4269	0,4399	0,4139	0,4119	
	K	0,4195	0,4195	0,4195	0,4195	0,4195	0,4195	
	s	0,0115	0,0115	0,0115	0,0115	0,0115	0,0115	
	β	0,0452	0,0452	0,0452	0,0452	0,0452	0,0452	

Supplementary information: Sample No. 3.1...3.6 – palm of terminal lug (conductor of 120 mm²)

TRF No. IEC61238_1A
 ВЯРНО С ОРЖИНАЛА
 Подпис:



PN-EN 61238-1

6.4		TABLE 6/1: change in resistance factor D for each of the six connectors, calculated according to annex E, clause E.5						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	b	-0,0019	-0,0013	-0,0016	-0,0037	-0,0019	-0,0031	
	k	0,9342	1,0735	0,9392	0,8864	0,9032	0,9162	
	IM	0,0203	0,0121	0,0170	0,0417	0,0210	0,0338	
	s_j	0,0060	0,0074	0,0089	0,0092	0,0074	0,0104	
	S	0,0133	0,0143	0,0196	0,0215	0,0170	0,0235	
	D	0,0336	0,0264	0,0366	0,0632	0,0380	0,0573	
Supplementary information: Sample No. 3.1...3.6 (conductor of 120 mm ²)								

6.4		TABLE 6/2: change in resistance factor D for each of the six connectors, calculated according to annex E, clause E.5						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	b	-0,0003	0,0007	0,0002	0,0011	-0,0012	-0,0003	
	k	0,4122	0,4122	0,4269	0,4399	0,4139	0,4119	
	IM	0,0073	0,0170	0,0047	0,0250	0,0290	0,0073	
	s_j	0,0057	0,0049	0,0065	0,0045	0,0121	0,0041	
	S	0,0286	0,0246	0,0315	0,0212	0,0605	0,0206	
	D	0,0359	0,0416	0,0362	0,0462	0,0895	0,0279	
Supplementary information: Sample No. 3.1...3.6 – palm of terminal lug (conductor of 120 mm ²)								





PN-EN 61238-1

6.4		TABLE 7/1: resistance factor ratio λ , calculated according to annex E, clause E.6						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	k_0	0,7827	0,8376	0,7758	0,7552	0,7552	0,7552	
200.*	$\lambda=$	1,0118	1,0187	1,0120	1,0034	1,0215	0,9763	
200.*	$\lambda=$	1,1688	1,2307	1,1704	1,1480	1,1752	1,1660	
250.	$\lambda=$	1,1775	1,2715	1,1792	1,1299	1,1660	1,1752	
325.	$\lambda=$	1,1932	1,2778	1,2127	1,1735	1,1916	1,2096	
400.	$\lambda=$	1,1862	1,2633	1,1967	1,1480	1,1932	1,2113	
475.	$\lambda=$	1,1879	1,2814	1,2160	1,1768	1,1949	1,2221	
550.	$\lambda=$	1,1758	1,2859	1,2127	1,1735	1,1916	1,1825	
625.	$\lambda=$	1,1983	1,2914	1,2178	1,1785	1,2056	1,2148	
700.	$\lambda=$	1,1966	1,2733	1,2160	1,1678	1,1949	1,2131	
775.	$\lambda=$	1,2088	1,2932	1,2284	1,1892	1,2165	1,2255	
850.	$\lambda=$	1,1983	1,2914	1,2178	1,1785	1,1966	1,2329	
925.	$\lambda=$	1,2071	1,2914	1,2089	1,1966	1,1966	1,2238	
1000.	$\lambda=$	1,1999	1,2769	1,2106	1,1984	1,2074	1,2346	

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 3.1...3.6 (conductor of 120 mm²)

ТРФ No. IEC61238_1A
 ВЯРНО С ОРИГИНАЛА
 Подпис:




PN-EN 61238-1

6.4		TABLE 7/2: resistance factor ratio λ , calculated according to annex E, clause E.6						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	k_0	0,4176	0,4166	0,4260	0,4429	0,4339	0,4310	
200.*	$\lambda=$	1,0821	1,0074	0,9873	0,9898	0,9599	1,0211	
200.*	$\lambda=$	0,9727	0,9885	1,0028	0,9790	0,9954	0,9601	
250.	$\lambda=$	0,9715	0,9978	1,0251	0,9973	0,9541	0,9418	
325.	$\lambda=$	0,9816	0,9976	1,0028	0,9946	0,9558	0,9550	
400.	$\lambda=$	1,0144	1,0077	1,0054	1,0115	0,9348	0,9490	
475.	$\lambda=$	0,9911	0,9916	0,9995	1,0034	0,9304	0,9717	
550.	$\lambda=$	0,9710	0,9942	0,9789	1,0000	0,9168	0,9522	
625.	$\lambda=$	0,9926	0,9626	1,0005	0,9966	0,9970	0,9601	
700.	$\lambda=$	0,9703	0,9878	0,9779	1,0034	0,9403	0,9462	
775.	$\lambda=$	0,9868	0,9959	1,0096	0,9788	0,9555	0,9696	
850.	$\lambda=$	0,9952	0,9753	1,0115	0,9767	0,9481	0,9541	
925.	$\lambda=$	0,9959	0,9815	1,0176	0,9709	1,0127	0,9610	
1000.	$\lambda=$	0,9880	0,9926	0,9955	0,9916	0,9479	0,9515	

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 3.1...3.6 – palm of terminal lug (conductor of 120 mm²)

TRF No. IEC61238_1A



ВЯРНО С ОРИГИНАЛА
Подпис:



Attachment No. 1




Summary of the test results according to PN-EN 61238-1:

Clause	Tests	Sample No.	Verdict
6	Electrical tests	3.1...3.6	P
7	Mechanical tests	3.7...3.9	P

ВЯРНО С ОРИГИНАЛА
Подпис:




Photos of the samples:




Terminal lug KRAC 120/12


I-POB-07/01-Z3w9

ВЕРНО С ОРИГИНАЛОМ
Подпись:






Photos of the samples (continued):




Test circuit of KRAC 120/12

Handwritten signature or scribble.





Attachment No. 2



The configuration and dimensions of the test circuit of KRAC 120/12



I-POB-07/01-Z3w9


ВЕРНО С ОРИГИНАЛОМ
Год выд.:



Attachment No. 2

Product data sheet:

Aluminium terminals longitudinally sealed KRAC type



Product name Aluminium terminals longitudinally sealed KRAC type

Category Tubular Al

Material Al.

Surface tin-plated

Note: - terminals are filled with special contact grease and packed in foil; - sector shaped conductors must be rounded with special dies.



mechanical details

Material


Al.

Surface

tin-plated

Name	SKU	Size of bolt dia	DIN	d	D	a min	E	W	Cross section re [mm ²]	Cross section rm/sm [mm ²]	Die code No.	No. of crimping wide	No. of crimping narrow
KRAC 16/8	E12KA-01010300100	M8	-	5,4	12,0	30	50	25	25	16	12	2	4
KRAC 16/10	E12KA-01010300200	M10	-	5,4	12,0	30	50	25	25	16	12	2	4
KRAC 16/12	E12KA-01010300300	M12	-	5,4	12,0	30	50	25	25	16	12	2	4
KRAC 25/8	E12KA-01010300400	M8	√	6,8	12,0	30	50	25	35	25	12	2	4
KRAC 25/10	E12KA-01010300500	M10	√	6,8	12,0	30	50	25	35	25	12	2	4
KRAC 25/12	E12KA-01010300600	M12	√	6,8	12,0	30	50	25	35	25	12	2	4
KRAC 35/8	E12KA-01010300700	M8	√	6,0	14,0	42	62	25	50	35	14	3	5
KRAC 35/10	E12KA-01010300800	M10	√	8,0	14,0	42	62	25	50	35	14	3	5
KRAC 35/12	E12KA-01010300900	M12	√	8,0	14,0	42	62	25	50	35	14	3	5
KRAC 35/14	E12KA-01010301000	M14	-	8,0	14,0	42	62	25	50	35	14	3	5
KRAC 50/8	E12KA-01010301100	M8	√	9,8	16,0	42	62	25	70	50	16	3	5
KRAC 50/10	E12KA-01010301200	M10	√	9,8	16,0	42	62	25	70	50	16	3	5

Handwritten signature



I-POB-07/01-Z3w9

ВЕРНО С ОРГАНИЗАЦИЕЙ
Подпись:



Attachment No. 2


Product data sheet (continued):

KRAC 50/12	E12KA-01010301300	M12	√	9,8	16,0	42	62	25	70	50	16	3	5
KRAC 50/14	E12KA-01010301400	M14	-	9,8	16,0	42	62	25	70	50	16	3	5
KRAC 70/8	E12KA-01010301500	M8	√	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/10	E12KA-01010301600	M10	√	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/12	E12KA-01010301700	M12	√	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/14	E12KA-01010301800	M14	-	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/16	E12KA-01010301900	M16	-	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 95/10	E12KA-01010302000	M10	√	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 95/12	E12KA-01010302100	M12	√	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 95/14	E12KA-01010302200	M14	-	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 95/16	E12KA-01010302300	M16	-	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 120/10	E12KA-01010302400	M10	√	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 120/12	E12KA-01010302500	M12	√	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 120/14	E12KA-01010302600	M14	-	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 120/16	E12KA-01010302700	M16	√	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 150/10	E12KA-01010302800	M10	√	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/12	E12KA-01010302900	M12	√	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/14	E12KA-01010303000	M14	-	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/16	E12KA-01010303100	M16	√	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/20	E12KA-01010303200	M20	-	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 185/10	E12KA-01010303300	M10	√	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/12	E12KA-01010303400	M12	√	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/14	E12KA-01010303500	M14	-	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/16	E12KA-01010303600	M16	√	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/20	E12KA-01010303700	M20	-	18,3	28,5	60	91	30	240	185	28	3	6

I-POB-07/01-Z3w9

ВЯРНО С ОРНИ
Подпис:





Attachment No. 2

Product data sheet (continued):

KRAC 240/10	E12KA- 01010303800	M10	-	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/12	E12KA- 01010303900	M12	√	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/14	E12KA- 01010304000	M14	-	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/16	E12KA- 01010304100	M16	√	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/20	E12KA- 01010304200	M20	-	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 300/12	E12KA- 01010304400	M12	√	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 300/14	E12KA- 01010304500	M14	-	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 300/16	E12KA- 01010304600	M16	√	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 300/20	E12KA- 01010304700	M20	√	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 500/16	E12KA- 01010305201	M16	√	29,0	44,0	80	122	44	-	500	44	4	-

I-POB-07/01-Z3w9

ВЯРНО С ОРВИ НАМА

Подпис:



since 1933

ASSOCIATION of POLISH ELECTRICIANS
QUALITY TESTING OFFICE
ul. M. Pożaryskiego 28, 04-703 Warszawa, Poland

tel./fax: +48 22 815 65 80

TESTING LABORATORY



AB 044



TEST REPORT

1. PN-EN 61238-1

Compression and mechanical connectors for power cables for rated
voltages up to 36 kV ($U_m = 42$ kV)
Part 1: Test methods and requirements (IEC 61238-1:2003, modified)

Report Reference No. : LA-17.062/17.045/4/E

Data of issue : 2017-12-29

Total number of pages : 20

Tested by : Krzysztof Podgórnjak
(name + position + signature) Specialist

на основании чл. 36а, ал. 3
от ЗОП

Authorized by : Dariusz Szczepanowski
(name + position + signature) Manager of LA

Testing application number : C-A-17-062/17.045

Test item reference : S-A-17-045

Scope of test : - type test

- partial test

Test specification:

Standard/procedure : PN-EN 61238-1:2004,
EN 61238-1:2003,
IEC 61238-1:2003 (Second Edition)


Non-standard test methods : N/A

Non-accredited test methods : N/A

Applicant's name : Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o.

Address : ul. Nowe Sady 10, 94-102 Łódź

The BBJ test report form is not permitted for commercial purposes
without written approval of the BBJ Testing Laboratory



ВЯРНО С ОРИГИНАЛА
Подпис:



Test item description: Aluminium terminals longitudinally sealed

Trade Mark: 

Manufacturer: Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o.
ul. Nowe Sady 10, 94-102 Łódź

Model/Typ reference: KRAC 16 + 300 / This report covers test of KRAC 300/16

Ratings: Nominal cross-sectional area: 16 mm² + 300 mm² / This report covers test of 300 mm²


List of Attachments:

Attachment No.	Attachment No.	Attachment No.
1	Summary of the test result	1
2	Product information and photos of samples	6

Summary of testing:

Test performer (in the case of partial tests): N/A	Testing location/address (if different from page 1) : Stowarzyszenie Elektryków Polskich, Biuro Badawcze ds. Jakości Association of Polish Electrician, Quality Testing Office ul. M. Rapackiego 13, 20-150 Lublin, POLAND
Number of tests with F (Fail) verdict:	0
Summary conformity/non-conformity with standardization document (if apply):	N/A
Summary of compliance with National Differences (if apply): Provide list of standards.	N/A
Opinion and interpretation if needed:	N/A
Other additional information (as requested by the applicant):	N/A

Copy of marking plate:



KRAC 300/12



I-POB-07/01-Z3w9





Test item particular:	
Classification of installation and use	: N/A
Supply Connection	: N/A
Date (s) of receipt of test item	: 2017-06-23 (Sample No. 1.1...1.7, 4.1...4.7) 2017-07-20 (Sample No. 2.1...2.21) 2017-09-11 (Sample No. 3.1...3.21) 2017-10-06 (Sample No. 4.8...4.19) 2017-10-13 (Sample No. 1.8...1.21)
Date (s) of performance of tests	: 2017-06-28...2017-12-29
Possible test case verdicts:	
- test case does not apply to the test object	: N/A
- test object does meet the requirement	: P (Pass)
- test object does not meet the requirement	: F (Fail)
Test report general remarks:	
1. The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.	
2. "(See Enclosure #)" refers to additional information appended to the report..	
3. "(See appended table)" refers to a table appended to the report	
4. Throughout this report a comma is used as the decimal separator.	
5. Test Report Form is based on TRF No.: IEC61238_1A, copyrighted by IECCE.	
Production place(s)	: Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o. ul. Nowe Sady 10, 94-102 Łódź

TRF No. IEC61238_1A



ВЕРНО С ОРИГИНАЛОМ
Подпись:



General product information:

Tests were carried out on samples of aluminium terminals longitudinally sealed type KRAC, nominal cross sectional area 16 mm² + 300 mm².

According to the standard and as agreed with the manufacturer for the tests were prepared four loops: 16 mm², 70 mm², 120 mm² and 300 mm² cross sectional area.

This report covers test of 300 mm², KRAC 300/12.

Electro-hydraulic presses HKP 22 EL with hexagonal die KP22-W300 was used to crimp testing terminals KRAC 300. Hexagonal die KP22-W300 is dedicated to aluminium terminals with a DIN-conforming tubular part (size DIN 34) for crimping cables RMC/RMV.

Cable YAKXS 1x300 mm² RMC 0,6/1kV, manufacturer ELPAR was used to electrical and mechanical tests of terminal KRAC 300.

Torque for screw of terminal lugs was 27,7 Nm + 29,6 Nm.

Samples were marked for the tests as S-A-17-045/1.1...1.21, S-A-17-045/2.1...2.21, S-A-17-045/3.1...3.21 and S-A-17-045/4.1...4.19. In the Test Report abbreviated marking of the samples, as the samples No. 1.1...1.21, 2.1...2.21, 3.1...3.21, 4.1...4.19 is used.

Type:	No.:
KRAC 16/10	1.1...1.21
KRAC 70/12	2.1...2.21
KRAC 120/12	3.1...3.21
KRAC 300/12	4.1...4.19

TRF No. IEC61238_1A

ВЕРНО С СЕРТИФИКАТОМ

Подпись:



PN-EN 61238-1			
Clause	Requirement – Test	Result - Remark	Verdict
Identification			—
	Connector		—
	Type of connector	<input type="checkbox"/> through connector <input type="checkbox"/> branch connector <input checked="" type="checkbox"/> terminal lug	—
	Nominal cross-sectional area	300 mm ²	—
	Class of connector	<input checked="" type="checkbox"/> Class A <input type="checkbox"/> Class B	—
5.1	Conductor		—
	conductor material.....	Al	—
	nominal cross-sectional area.....	300 mm ² RMC	—
	actual conductor area	300 mm ² RMC	—
	leading dimensions and shape.....	Unprepared cable	—
	type of conductor (solid or stranded)	300 mm ² - stranded	—
	details of conductor construction (in the case of stranded conductors)	300 mm ² – stranded cable, round, 37 wires	—
	compacted / non-compacted	Compacted	—
	flexible	No	—
	number of wires	37 wires	—
	direction of lay	Right	—
	plating.....	No plating	—
	type of impregnation, if any	—	—
	approximate indication of hardness (annealed, half-hard, hard).....	Half-hard	—
	type of insulation (in case of insulation-piercing connectors).....	—	—
5.2	Connectors and tooling		—
	assembly technique	Crimp connection	—
	tooling and necessary settings	Electro-hydraulic presses HKP 22 EL with hexagonal die KP22-W300. Hexagonal die KP22-W300 is dedicated to aluminium terminals with a DIN-conforming tubular part for crimping cables RMC/RMV. Size DIN 34; torque wrench	—
	preparation of contact surfaces	Terminal lug filled with contact grease	—

TRF No. IEC61238_1A

ВЯРНО С СЪДЪРЖАНИЕТО
 Подпис:



PN-EN 61238-1			
Clause	Requirement – Test	Result - Remark	Verdict

	type, reference number and other identification of the connector	KDA 300: surface: tin-plated; material: Al	—
--	--	--	---

6	Electrical tests		P
6.1	Installation		P
	six connectors fitted in accordance with the manufacturer's instructions		P
	welded equalizers used	Yes	P
	in case of insulation-piercing connectors, the insulation retained on the conductor under the connector, and for a distance of at least 100 mm outside the connector		N/A
	ambient temperature of the test location (between 15 °C and 30 °C)	16 °C...21 °C	P
	the test loop is dismantlable for short-circuit test (class A connectors only)	Short-circuit test performed without dismantling, loop divided on six sections for test	N/A
	the technology of the sectioning joints do not influence the measurements		N/A
	bolts or screws of the connectors were not retightened under test		P
6.1.1	Through connectors and terminal lugs		—
	test loop and dimensions according to Figure 1	See Attachment No. 2	P
	linking bars used (in case of terminal lugs)	Without use of linking bars	N/A
	the palms bolted to the linking bars in accordance with the manufacturer's instructions		N/A
	linking bars have the same dimensions and material as the palm		N/A
	palm connected direct to palm	Direct connected (see Attachment No. 2)	P
6.1.2	Branch connectors		—
	branch connector is treated as a through connector between the main and the branch (size of branch cable equal to the main, or immediately above or below the main)		N/A
	in other cases, test loop and dimensions according to Figure 2		N/A

6.2	Measurements		P
6.2.1	Electrical resistance measurements		P
	measurements made at stages throughout the test as specified in 6.3		P

TRF.No. IEC61238-1A

ВЕРНО С ОРИГИНАЛОМ

Подпись:



PN-EN 61238-1			
Clause	Requirement – Test	Result - Remark	Verdict
	method used	<input checked="" type="checkbox"/> indirect <input type="checkbox"/> direct	—
	indirect method: measuring current is 10 % of the heat cycling current	KRAC 300: 66 A + 71 A	P
	potential points as indicated in Figure 3 and annex B		P
	Precision of resistance measurements, indirect method		—
	voltage: max. $\pm 0,5\%$ or $\pm 10\ \mu\text{V}$, actual precision	$\pm 0,5\%$	P
	current: max. $\pm 0,5\%$ or $\pm 0,1\ \text{A}$, actual precision	$\pm 0,5\%$	P
	Precision of resistance measurements, direct method: better than $\pm 1\%$ or $\pm 0,5\ \mu\Omega$, actual precision	—	N/A
6.2.2	Temperature measurements		P
	stages as specified in 6.3		P
	the temperature of connectors and reference conductor measured at the points as indicated in Figure 3	Figure 3a, 3e, 3f	P
	thermocouples used as reference method	Yes	P
	total accuracy of temperature measurements: $\pm 2\ ^\circ\text{C}$ or better, actual accuracy	$\pm 2,0\ ^\circ\text{C}$	P
6.3	Heat cycle test		P
	power frequency current used	AC 50 Hz	P
6.3.1	First heat cycle		—
6.3.1 a)	Non insulation-piercing through connectors and terminal lugs	Sample No. 4.8...4.13	P
	current is circulated in the test loop, bringing the reference conductor to $120\ ^\circ\text{C}$ at equilibrium		N/A
	measured temperature of the median connector ..	Sample No. 4.10: $101,3\ ^\circ\text{C}$	—
	reference conductor temperature ($120\ ^\circ\text{C} \leq \Theta_R \leq 140\ ^\circ\text{C}$)	$128,3\ ^\circ\text{C}$	—
	equilibrium current I_N	730 A	—
6.3.1 b)	Non insulation-piercing branch connectors		N/A
	test circuit according to	<input type="checkbox"/> Figure 1 <input type="checkbox"/> Figure 2	—
	current is circulated in the test loop, bringing the reference conductor to $120\ ^\circ\text{C}$ at equilibrium		N/A

TRF No. IEC61238_1A

ВРАНО С ОРИГИНАЛ
Подпис:



PN-EN 61238-1


Clause	Requirement – Test	Result - Remark	Verdict
	current in all individual branch adjusted so that each branch reference temperature is the same as the main reference temperature		N/A
	measured temperature of the median connector ...:		—
	reference conductor temperature (120 °C ≤ Θ _R ≤ 140 °C)		—
	equilibrium current I _N		—
6.3.1 c)	Insulation-piercing connectors (IPC)		N/A
	test circuit according to	<input type="checkbox"/> Figure 1 <input type="checkbox"/> Figure 2	—
	isolated reference conductor used		N/A
	permitted temperature of the cable		—
	temperature of the median connector is set 10 K above permitted temperature of the cable		N/A
	measured temperature of the median connector ...:		—
	temperature of the reference conductor(s) is(are) set max.15 K above permitted temperature of the cable		N/A
	temperature of the isolated reference conductor(s) at equilibrium		N/A
	equilibrium current I _N		—
6.3.2	Second heat cycle	Sample No. 4.8...4.13	—
	current is circulated in the loop until the main reference conductor temperature reaches the value Θ _R determined in 6.3.1 with a tolerance of +6 °C	128 °C + 134 °C	P
	the median connector temperature is stable within 2 °C over a 10 min period		P
	current flow time (t ₁)	54 min	—
	accelerated heating used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	—
	accelerated heating time	17 min	—
	accelerated heating time according to Table 1	15 min	P
	cooling time (t ₂)	19 min	—
	After cooling, the temperature of all connectors and the reference conductor ≤ 35 °C		P
	accelerated cooling used with ambient air	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	—
6.3.3	Subsequent heat cycles	Sample No. 4.8...4.13	—
	a total of 1000 heat cycles performed		P
	Measurements performed at the following cycles:		P
	Class A: 0, 200 (before and after short-circuit test), 250, then every 75		P

[Handwritten signature]

[Handwritten signature]

TRF No. IEC61238 1A


ВЕРИО С ОБИМАН
Подпис:






PN-EN 61238-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Class B: 0, 250, then every 75		N/A
	cold resistance and temperature of each connector and reference conductor/conductors measured	See TABLE 1/1 and TABLE 1/2	P
	maximum temperature of each connector measured	See TABLE 2	P
6.3.4	Short-circuit tests (for Class A connectors only)	Sample No. 4.8...4.13	P
	six short circuits applied after the 200th heat cycle	Short-circuit test performed without dismantling, loop divided on six sections for test	P
	short-circuit current	I section: 27,39 kA + 27,64 kA, II section: 27,45 kA + 27,65 kA, III section: 27,48 kA + 27,84 kA, IV section: 28,05 kA + 28,19 kA, V section: 27,08 kA + 27,23 kA, VI section: 30,08 kA + 30,14 kA	—
	short-circuit current raises the reference conductors from a temperature of ≤ 35 °C to a temperature between 250 °C and 270 °C		P
	measured temperature of the reference conductor:	I section: 256,9 °C + 262,3 °C, II section: 251,1 °C + 255,9 °C, III section: 251,4 °C + 260,3 °C, IV section: 252,8 °C + 259,6 °C, V section: 262,4 °C + 268,0 °C, VI section: 255,2 °C + 267,8 °C	P
	duration of the short-circuit current (1 s below 25 kA, ≤ 5 s above 25 kA)	I section: 1,45 s + 1,46 s, II section: 1,40 s + 1,43 s, III section: 1,38 s + 1,43 s, IV section: 1,36 s + 1,38 s, V section: 1,54 s + 1,55 s, VI section: 1,19 s + 1,20 s	P
	the test loop cooled to a temperature ≤ 35 °C after each short circuit		P

TRF No. IEC61238_1A





PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
6.4	Assessment of results		P
	Calculated parameters:		—
	connector resistance factor k , calculated according to annex E, clause E.2	See TABLE 3/1 and TABLE 3/2	—
	initial scatter δ , between the six initial values of k measured prior to heat cycling, calculated according to annex E, clause E.3	See TABLE 4/1 and TABLE 4/2	P
	mean scatter β , between the six values of k averaged over the last 11 measurement intervals, calculated according to annex E, clause E.4	See TABLE 5/1 and TABLE 5/2	P
	change in resistance factor D for each of the six connectors, calculated according to annex E, clause E.5	See TABLE 6/1 and TABLE 6/2	P
	resistance factor ratio λ calculated according to annex E, clause E.6	See TABLE 7/1 and TABLE 7/2	P
	maximum temperature θ_{max} on each connector, recorded according to annex E, clause E.7	See TABLE 2	P

6.5	Requirements		P
	more than four connectors satisfy the requirements shown in table 2		N/A
	one full re-test performed	<input type="checkbox"/> Yes <input type="checkbox"/> No	—
	six connectors satisfy the requirements shown in table 2		P
	values of δ do not exceed 0,3	See TABLE 4/1 and TABLE 4/2	P
	values of β do not exceed 0,3	See TABLE 5/1 and TABLE 5/2	P
	values of D do not exceed 0,15	See TABLE 6/1 and TABLE 6/2	P
	values of λ do not exceed 2,0	See TABLE 7/1 and TABLE 7/2	P
	values of θ_{max} do not exceed θ_{ref}	See TABLE 2	P


7	Mechanical tests		P
7.1	Test method		—
	the test is made on three connectors different from those used for the electrical test	Sample No. 4.1...4.3	P
	connectors are fitted as for the electrical test of 6.1		P
	the conductor lengths, between connectors or between connector and tensile test machine jaws, are more than 500 mm		P

TRF No. IEC61238-1A
 ВАРЮ С СР
 Подпись:



PN-EN 61238-1			
Clause	Requirement – Test	Result - Remark	Verdict
	the rate of application of the load do not exceed 10 N/mm ² of cross-section per second		P
7.2	Requirements		P
	tensile force applied during one minute	Conductor of 300 mm ² Al; 1 min	P
	force for aluminium, (40×A [mm ²], max. 20 000) .. :	40 x 300 = 12 000 N	P
	force for copper, (60×A [mm ²], max. 20 000)		N/A
	in case the connector is electrically tested for conductors with difference cross-sectional area, the different joints tested individually to the above requirements		N/A
	no slipping during the tensile test		P

TRF No. IEC61238_1A






PN-EN 61238-1

6.3.3		TABLE 1/1: cold resistance and temperature of the connectors							
cycle		connectors						reference conductor	
		j=1	j=2	j=3	j=4	j=5	j=6		
0.	R [mΩ]	0,0324	0,0327	0,0322	0,0318	0,0325	0,0325	0,0451	
	θ [°C]	19,7	19,6	20,1	20,2	20,1	20,2	20,0	
200.*	R [mΩ]	0,0324	0,0329	0,0324	0,0319	0,0326	0,0327	0,0452	
	θ [°C]	18,1	18,1	18,3	18,3	18,3	18,3	18,3	
200.*	R [mΩ]	0,0340	0,0346	0,0358	0,0342	0,0344	0,0357	0,0451	
	θ [°C]	17,3	17,2	17,7	17,6	17,4	17,5	17,7	
250.	R [mΩ]	0,0341	0,0345	0,0359	0,0344	0,0344	0,0359	0,0450	
	θ [°C]	17,9	17,9	18,5	18,3	18,0	18,0	18,3	
325.	R [mΩ]	0,0342	0,0347	0,0361	0,0345	0,0344	0,0360	0,0451	
	θ [°C]	18,5	18,3	18,8	18,7	18,5	18,6	19,1	
400.	R [mΩ]	0,0342	0,0348	0,0360	0,0344	0,0345	0,0360	0,0451	
	θ [°C]	19,0	18,8	19,6	19,4	19,0	19,1	19,4	
475.	R [mΩ]	0,0342	0,0348	0,0362	0,0344	0,0345	0,0360	0,0451	
	θ [°C]	19,6	19,5	20,3	20,1	19,6	20,0	19,8	
550.	R [mΩ]	0,0343	0,0348	0,0362	0,0345	0,0346	0,0361	0,0452	
	θ [°C]	19,6	19,5	20,3	20,0	19,6	19,8	19,8	
625.	R [mΩ]	0,0342	0,0346	0,0360	0,0344	0,0344	0,0360	0,0451	
	θ [°C]	16,6	16,5	17,1	17,1	16,8	17,0	17,0	
700.	R [mΩ]	0,0342	0,0347	0,0361	0,0344	0,0345	0,0360	0,0451	
	θ [°C]	18,7	18,5	19,2	18,9	18,6	18,8	18,8	
775.	R [mΩ]	0,0342	0,0347	0,0363	0,0345	0,0345	0,0360	0,0451	
	θ [°C]	17,5	17,4	17,6	17,6	17,5	17,7	17,6	
850.	R [mΩ]	0,0342	0,0348	0,0361	0,0345	0,0345	0,0360	0,0451	
	θ [°C]	18,7	18,5	19,1	18,9	18,5	18,7	18,6	
925.	R [mΩ]	0,0343	0,0347	0,0360	0,0344	0,0344	0,0360	0,0450	
	θ [°C]	16,1	15,9	16,7	16,4	16,0	16,2	16,3	
1000.	R [mΩ]	0,0344	0,0347	0,0361	0,0345	0,0346	0,0360	0,0451	
	θ [°C]	18,2	18,1	18,5	18,5	18,3	18,5	18,2	

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 4.8...4.13 (conductor of 300 mm²)



TRF No. IEC61238_1A

ВІДНО С ОРИГІНАЛОМ
 Підпис:




PN-EN 61238-1

6.3.3		TABLE 1/2: cold resistance and temperature of the connectors							reference conductor
cycle		connectors							
		j=1	j=2	j=3	j=4	j=5	j=6		
0.	R [mΩ]	0,0017	0,0018	0,0017	0,0018	0,0017	0,0018	0,0451	
	θ [°C]	19,8	19,8	20,2	20,2	20,1	20,3	20,0	
200.*	R [mΩ]	0,0017	0,0017	0,0018	0,0018	0,0017	0,0018	0,0452	
	θ [°C]	18,1	18,1	18,4	18,5	18,5	18,4	18,3	
200.*	R [mΩ]	0,0017	0,0018	0,0018	0,0018	0,0017	0,0017	0,0451	
	θ [°C]	17,4	17,2	17,7	17,7	17,5	17,6	17,7	
250.	R [mΩ]	0,0017	0,0018	0,0018	0,0018	0,0017	0,0017	0,0450	
	θ [°C]	17,9	17,8	18,5	18,3	18,1	18,0	18,3	
325.	R [mΩ]	0,0017	0,0019	0,0017	0,0018	0,0017	0,0017	0,0451	
	θ [°C]	18,5	18,4	18,9	18,8	18,5	18,7	19,1	
400.	R [mΩ]	0,0017	0,0018	0,0017	0,0018	0,0018	0,0017	0,0451	
	θ [°C]	19,1	18,9	19,7	19,5	19,0	19,2	19,4	
475.	R [mΩ]	0,0017	0,0019	0,0017	0,0017	0,0017	0,0018	0,0451	
	θ [°C]	19,7	19,5	20,4	20,2	19,7	20,1	19,8	
550.	R [mΩ]	0,0017	0,0019	0,0017	0,0018	0,0017	0,0017	0,0452	
	θ [°C]	19,6	19,5	20,4	20,1	19,6	19,9	19,8	
625.	R [mΩ]	0,0017	0,0018	0,0018	0,0018	0,0017	0,0017	0,0451	
	θ [°C]	16,7	16,5	17,2	17,2	16,9	17,1	17,0	
700.	R [mΩ]	0,0017	0,0018	0,0017	0,0018	0,0017	0,0017	0,0451	
	θ [°C]	18,7	18,5	19,3	18,9	18,6	18,8	18,8	
775.	R [mΩ]	0,0017	0,0018	0,0017	0,0017	0,0017	0,0017	0,0451	
	θ [°C]	17,5	17,4	17,7	17,7	17,5	17,7	17,6	
850.	R [mΩ]	0,0017	0,0019	0,0017	0,0017	0,0017	0,0017	0,0451	
	θ [°C]	18,7	18,5	19,1	18,9	18,5	18,8	18,6	
925.	R [mΩ]	0,0017	0,0018	0,0017	0,0017	0,0017	0,0017	0,0450	
	θ [°C]	16,1	15,9	16,7	16,4	16,1	16,2	16,3	
1000.	R [mΩ]	0,0017	0,0018	0,0017	0,0017	0,0018	0,0017	0,0451	
	θ [°C]	18,2	18,1	18,6	18,5	18,4	18,6	18,2	

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 4.8...4.13 – palm of terminal lug (conductor of 300 mm²)





PN-EN 61238-1

6.3.3		TABLE 2: maximum temperature of each connector measured						P
cycle		connectors						reference conductor
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	Θ_{max} [°C]	96,6	98,2	101,3	99,9	101,6	103,2	128,3
200.*	Θ_{max} [°C]	94,3	97,2	99,7	97,0	100,9	102,1	132,0
200.*	Θ_{max} [°C]	106,0	104,5	109,9	108,2	113,0	109,7	133,2
250.	Θ_{max} [°C]	103,0	101,8	107,9	107,6	109,6	109,9	131,6
325.	Θ_{max} [°C]	104,1	103,5	110,6	109,6	110,4	112,6	131,9
400.	Θ_{max} [°C]	103,3	103,6	111,8	109,1	110,3	113,2	131,2
475.	Θ_{max} [°C]	106,5	107,2	112,8	111,1	110,6	113,6	133,4
550.	Θ_{max} [°C]	102,1	104,5	109,8	107,6	108,8	110,1	130,0
625.	Θ_{max} [°C]	103,1	101,7	108,9	105,8	107,8	110,0	130,2
700.	Θ_{max} [°C]	104,9	104,1	110,4	108,8	111,4	111,1	129,8
775.	Θ_{max} [°C]	106,2	103,5	109,3	107,1	109,1	110,9	131,9
850.	Θ_{max} [°C]	106,9	105,5	110,9	108,1	111,1	111,2	129,1
925.	Θ_{max} [°C]	104,7	103,2	108,7	106,3	110,4	109,6	129,3
1000.	Θ_{max} [°C]	104,1	103,9	108,2	106,8	110,1	110,2	129,3

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 4.8...4.13 (conductor of 300 mm²)

TRF No. IEC61238-1A

ВЕРНО С ОРИГИНАЛОМ
Подпись:




PN-EN 61238-1

6.4		TABLE 3/1: connector resistance factor k, calculated according to annex E, clause E.2						P	
Parameters:		L _a =	260 mm	L _b =	— mm	L _r =	445 mm	L _{fl} =	73 mm
cycle		connectors							
		j=1	j=2	j=3	j=4	j=5	j=6		
0.		0,8110	0,8515	0,7840	0,7299	0,8245	0,8245		
200.*		0,8092	0,8766	0,8092	0,7418	0,8362	0,8496		
200.*		1,0272	1,1083	1,2705	1,0543	1,0813	1,2570		
250.		1,0566	1,1108	1,3005	1,0973	1,0973	1,3005		
325.		1,0543	1,1219	1,3111	1,0948	1,0813	1,2976		
400.		1,0543	1,1354	1,2976	1,0813	1,0948	1,2976		
475.		1,0543	1,1354	1,3246	1,0813	1,0948	1,2976		
550.		1,0654	1,1329	1,3217	1,0924	1,1059	1,3082		
625.		1,0543	1,1083	1,2976	1,0813	1,0813	1,2976		
700.		1,0543	1,1219	1,3111	1,0813	1,0948	1,2976		
775.		1,0543	1,1219	1,3381	1,0948	1,0948	1,2976		
850.		1,0543	1,1354	1,3111	1,0948	1,0948	1,2976		
925.		1,0837	1,1379	1,3140	1,0973	1,0973	1,3140		
1000.		1,0813	1,1219	1,3111	1,0948	1,1083	1,2976		
(*) rows marked with asterisk can be omitted in case of connectors type "B"									
Supplementary information: Sample No. 4.8...4.13 (conductor of 300 mm ²)									

TRF No. IEC61238_1A





PN-EN 61238-1

6.4		TABLE 3/2: connector resistance factor k , calculated according to annex E, clause E.2							P
Parameters:		$L_a=$	260 mm	$L_b=$	— mm	$L_r=$	445 mm	$L_{jp}=$	49 mm
cycle		connectors							
		j=1	j=2	j=3	j=4	j=5	j=6		
0.		0,3460	0,3663	0,3371	0,3634	0,3488	0,3547		
200.*		0,3479	0,3507	0,3643	0,3611	0,3499	0,3530		
200.*		0,3386	0,3714	0,3551	0,3587	0,3469	0,3522		
250.		0,3484	0,3719	0,3562	0,3544	0,3481	0,3466		
325.		0,3416	0,3787	0,3488	0,3544	0,3454	0,3409		
400.		0,3415	0,3566	0,3470	0,3594	0,3648	0,3501		
475.		0,3403	0,3817	0,3447	0,3422	0,3516	0,3660		
550.		0,3472	0,3738	0,3400	0,3677	0,3480	0,3439		
625.		0,3351	0,3606	0,3536	0,3566	0,3427	0,3424		
700.		0,3460	0,3659	0,3501	0,3599	0,3487	0,3419		
775.		0,3460	0,3705	0,3492	0,3522	0,3502	0,3465		
850.		0,3417	0,3778	0,3444	0,3444	0,3501	0,3446		
925.		0,3468	0,3695	0,3477	0,3454	0,3458	0,3407		
1000.		0,3465	0,3639	0,3484	0,3461	0,3543	0,3391		

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 4.8...4.13 – palm of terminal lug (conductor of 300 mm²)

6.4		TABLE 4/1: initial scatter δ , between the six initial values of k measured prior to heat cycling, calculated according to annex E, clause E.3						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	K_0	0,8042	0,8042	0,8042	0,8042	0,8042	0,8042	
	s_0	0,0425	0,0425	0,0425	0,0425	0,0425	0,0425	
	δ	0,0872	0,0872	0,0872	0,0872	0,0872	0,0872	

Supplementary information: Sample No. 4.8...4.13 (conductor of 300 mm²)

TRF No. IEC61238-1A




PN-EN 61238-1

6.4		TABLE 4/2: initial scatter δ , between the six initial values of k measured prior to heat cycling, calculated according to annex E, clause E.3						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	K_0	0,3527	0,3527	0,3527	0,3527	0,3527	0,3527	
	s_0	0,0110	0,0110	0,0110	0,0110	0,0110	0,0110	
	δ	0,0515	0,0515	0,0515	0,0515	0,0515	0,0515	
Supplementary information: Sample No. 4.8...4.13 – palm of terminal lug (conductor of 300 mm ²)								

6.4		TABLE 5/1: mean scatter β , between the six values of k averaged over the last 11 measurement intervals, calculated according to annex E, clause E.4						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	k	1,0606	1,1258	1,3126	1,0901	1,0950	1,3003	
	K	1,1641	1,1641	1,1641	1,1641	1,1641	1,1641	
	s	0,1123	0,1123	0,1123	0,1123	0,1123	0,1123	
	β	0,1592	0,1592	0,1592	0,1592	0,1592	0,1592	
Supplementary information: Sample No. 4.8...4.13 (conductor of 300 mm ²)								

6.4		TABLE 5/2: mean scatter β , between the six values of k averaged over the last 11 measurement intervals, calculated according to annex E, clause E.4						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	k	0,3437	0,3701	0,3482	0,3530	0,3500	0,3457	
	K	0,3518	0,3518	0,3518	0,3518	0,3518	0,3518	
	s	0,0095	0,0095	0,0095	0,0095	0,0095	0,0095	
	β	0,0446	0,0446	0,0446	0,0446	0,0446	0,0446	
Supplementary information: Sample No. 4.8...4.13 – palm of terminal lug (conductor of 300 mm ²)								

TRF No. IEC61238_1A





PN-EN 61238-1

6.4		TABLE 6/1: change in resistance factor <i>D</i> for each of the six connectors, calculated according to annex E, clause E.5						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	<i>b</i>	-0,0021	-0,0007	-0,0011	-0,0005	-0,0010	-0,0004	
	<i>k</i>	1,0606	1,1258	1,3126	1,0901	1,0950	1,3003	
	<i>IM</i>	0,0198	0,0062	0,0084	0,0046	0,0091	0,0031	
	<i>s_j</i>	0,0094	0,0106	0,0122	0,0073	0,0080	0,0057	
	<i>S</i>	0,0183	0,0195	0,0192	0,0139	0,0151	0,0091	
	<i>D</i>	0,0381	0,0257	0,0276	0,0185	0,0242	0,0122	
Supplementary information: Sample No. 4.8...4.13 (conductor of 300 mm ²)								

6.4		TABLE 6/2: change in resistance factor <i>D</i> for each of the six connectors, calculated according to annex E, clause E.5						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	<i>b</i>	-0,0002	0,0004	0,0003	0,0010	0,0001	0,0009	
	<i>k</i>	0,3437	0,3701	0,3482	0,3530	0,3500	0,3457	
	<i>IM</i>	0,0058	0,0108	0,0086	0,0283	0,0029	0,0260	
	<i>s_j</i>	0,0042	0,0081	0,0045	0,0075	0,0061	0,0072	
	<i>S</i>	0,0253	0,0453	0,0268	0,0440	0,0361	0,0431	
	<i>D</i>	0,0311	0,0561	0,0354	0,0723	0,0390	0,0691	
Supplementary information: Sample No. 4.8...4.13 – palm of terminal lug (conductor of 300 mm ²)								

TRF No. IEC61238_1A

ВЕРНО С СЕРТИФИКАТОМ

Подпись:



PN-EN 61238-1

6.4		TABLE 7/1: resistance factor ratio λ , calculated according to annex E, clause E.6							P
cycle		connectors							
		j=1	j=2	j=3	j=4	j=5	j=6		
0.	k_0	0,8110	0,8515	0,7840	0,7299	0,8245	0,8245		
200.*	$\lambda=$	0,9978	1,0295	1,0321	1,0163	1,0142	1,0304		
200.*	$\lambda=$	1,2666	1,3016	1,6205	1,4444	1,3115	1,5246		
250.	$\lambda=$	1,3028	1,3045	1,6588	1,5034	1,3309	1,5773		
325.	$\lambda=$	1,3000	1,3176	1,6723	1,4999	1,3115	1,5738		
400.	$\lambda=$	1,3000	1,3334	1,6551	1,4814	1,3278	1,5738		
475.	$\lambda=$	1,3000	1,3334	1,6895	1,4814	1,3278	1,5738		
550.	$\lambda=$	1,3137	1,3305	1,6858	1,4966	1,3413	1,5867		
625.	$\lambda=$	1,3000	1,3016	1,6551	1,4814	1,3115	1,5738		
700.	$\lambda=$	1,3000	1,3176	1,6723	1,4814	1,3278	1,5738		
775.	$\lambda=$	1,3000	1,3176	1,7068	1,4999	1,3278	1,5738		
850.	$\lambda=$	1,3000	1,3334	1,6723	1,4999	1,3278	1,5738		
925.	$\lambda=$	1,3363	1,3363	1,6760	1,5034	1,3309	1,5937		
1000.	$\lambda=$	1,3333	1,3176	1,6723	1,4999	1,3442	1,5738		

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 4.8...4.13 (conductor of 300 mm²)



PN-EN 61238-1

6.4		TABLE 7/2: resistance factor ratio λ , calculated according to annex E, clause E.6						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	k_0	0,3460	0,3663	0,3371	0,3634	0,3488	0,3547	
200.*	$\lambda=$	1,0055	0,9574	1,0807	0,9937	1,0032	0,9952	
200.*	$\lambda=$	0,9786	1,0139	1,0534	0,9871	0,9946	0,9930	
250.	$\lambda=$	1,0069	1,0153	1,0567	0,9752	0,9980	0,9772	
325.	$\lambda=$	0,9873	1,0339	1,0347	0,9752	0,9903	0,9611	
400.	$\lambda=$	0,9870	0,9735	1,0294	0,9890	1,0459	0,9870	
475.	$\lambda=$	0,9835	1,0420	1,0225	0,9417	1,0080	1,0319	
550.	$\lambda=$	1,0035	1,0205	1,0086	1,0118	0,9977	0,9696	
625.	$\lambda=$	0,9685	0,9844	1,0489	0,9813	0,9825	0,9653	
700.	$\lambda=$	1,0000	0,9989	1,0386	0,9904	0,9997	0,9639	
775.	$\lambda=$	1,0000	1,0115	1,0359	0,9692	1,0040	0,9769	
850.	$\lambda=$	0,9876	1,0314	1,0217	0,9477	1,0037	0,9715	
925.	$\lambda=$	1,0023	1,0087	1,0314	0,9505	0,9914	0,9605	
1000.	$\lambda=$	1,0014	0,9934	1,0335	0,9524	1,0158	0,9560	

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 4.8...4.13 – palm of terminal lug (conductor of 300 mm²)

TRF No. IEC61238_1A

ВЯРНО С ОРИГИНАЛА


Подпис:



Attachment No. 1

Summary of the test results according to PN-EN 61238-1:

Clause	Tests	Sample No.	Verdict
6	Electrical tests	4.8...4.13	P
7	Mechanical tests	4.1...4.3	P






ВАРНО С ОРЪЖИЕМ
Подпис:

I-POB-07/01-Z3w9




Photos of the samples:



Terminal lug KRAC 300/12


I-POB-07/01-Z3w9




ВІДНО С ОРИГІНАЛА
Підпис:



Photos of the samples (continued):




Test circuit of KRAC 300/12



I-POB-07/01-Z3w9

ВЯНО С ОБЪЕКТОМ
Подпись:



The configuration and dimensions of the test circuit of KRAC 300/12


Product data sheet:

I-POB-07/01-Z3w9

ВЛННО С СЕРИЯ
Подпись:



Aluminium terminals longitudinally sealed KRAC type



Product name Aluminium terminals longitudinally sealed KRAC type

Category Tubular Al

Material Al.

Surface tin-plated

Note! - terminals are filled with special contact grease and packed in foil; - sector shaped conductors must be rounded with special dies.



mechanical details

Material

Al.

Surface

tin-plated

Name	SKU	Size of bolt dia	DIN	d	Ø	a min	E	W	Cross section re [mm ²]	Cross section rm/sm [mm ²]	Die code No.	No. of crimping wide	No. of crimping narrow
KRAC 16/8	E12KA-01010300100	M8	-	5,4	12,0	30	50	25	25	16	12	2	4
KRAC 16/10	E12KA-01010300200	M10	-	5,4	12,0	30	50	25	25	16	12	2	4
KRAC 16/12	E12KA-01010300300	M12	-	5,4	12,0	30	50	25	25	16	12	2	4
KRAC 25/8	E12KA-01010300400	M8	√	6,8	12,0	30	50	25	35	25	12	2	4
KRAC 25/10	E12KA-01010300500	M10	√	6,6	12,0	30	50	25	35	25	12	2	4
KRAC 25/12	E12KA-01010300600	M12	√	6,8	12,0	30	50	25	35	25	12	2	4
KRAC 35/8	E12KA-01010300700	M8	√	8,0	14,0	42	62	25	50	35	14	3	5
KRAC 35/10	E12KA-01010300800	M10	√	8,0	14,0	42	62	25	50	35	14	3	5
KRAC 35/12	E12KA-01010300900	M12	√	8,0	14,0	42	62	25	50	35	14	3	5
KRAC 35/14	E12KA-01010301000	M14	-	8,0	14,0	42	62	25	50	35	14	3	5
KRAC 50/8	E12KA-01010301100	M8	√	9,8	16,0	42	62	25	70	50	16	3	5
KRAC 50/10	E12KA-01010301200	M10	√	9,8	16,0	42	62	25	70	50	16	3	5

Product data sheet (continued):

I-POB-07/01-Z3w9

ВЕРНО С ОРИГИНАЛОМ
Подпись: _____




Attachment No. 2


KRAC 50/12	E12KA- 01010301300	M12	✓	9,8	16,0	42	62	25	70	50	16	3	5
KRAC 50/14	E12KA- 01010301400	M14	-	9,8	16,0	42	62	25	70	50	16	3	5
KRAC 70/8	E12KA- 01010301500	M8	✓	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/10	E12KA- 01010301600	M10	✓	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/12	E12KA- 01010301700	M12	✓	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/14	E12KA- 01010301800	M14	-	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 70/16	E12KA- 01010301900	M16	-	11,2	18,5	52	72	25	95	70	18	3	6
KRAC 95/10	E12KA- 01010302000	M10	✓	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 95/12	E12KA- 01010302100	M12	✓	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 95/14	E12KA- 01010302200	M14	-	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 95/16	E12KA- 01010302300	M16	-	13,2	22,0	56	75	25	120	95	22	3	6
KRAC 120/10	E12KA- 01010302400	M10	✓	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 120/12	E12KA- 01010302500	M12	✓	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 120/14	E12KA- 01010302600	M14	-	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 120/16	E12KA- 01010302700	M16	✓	14,7	23,0	56	80	30	150	120	22	3	6
KRAC 150/10	E12KA- 01010302800	M10	✓	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/12	E12KA- 01010302900	M12	✓	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/14	E12KA- 01010303000	M14	-	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/16	E12KA- 01010303100	M16	✓	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 150/20	E12KA- 01010303200	M20	-	16,3	25,0	60	90	30	185	150	25	3	6
KRAC 185/10	E12KA- 01010303300	M10	✓	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/12	E12KA- 01010303400	M12	✓	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/14	E12KA- 01010303500	M14	-	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/16	E12KA- 01010303600	M16	✓	18,3	28,5	60	91	30	240	185	28	3	6
KRAC 185/20	E12KA- 01010303700	M20	-	18,3	28,5	60	91	30	240	185	28	3	6

Product data sheet (continued):

I-POB-07/01-Z3w9



ВІСНО С СЕРВІСА
Підпис:







Attachment No. 2

KRAC 240/10	E12KA- 01010303800	M10	-	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/12	E12KA- 01010303900	M12	√	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/14	E12KA- 01010304000	M14	-	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/16	E12KA- 01010304100	M16	√	21,0	32,0	70	103	38	300	240	32	3	8
KRAC 240/20	E12KA- 01010304200	M20		21,0	32,0	70	103	38	300	240	32	3	8
KRAC 300/12	E12KA- 01010304400	M12	√	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 300/14	E12KA- 01010304500	M14	-	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 300/16	E12KA- 01010304600	M16	√	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 300/20	E12KA- 01010304700	M20	√	23,3	34,0	70	103	38	-	300	34	3	-
KRAC 500/16	E12KA- 01010305201	M16	√	29,0	44,0	80	122	44	-	500	44	4	-

[Handwritten signature]

I-POB-07/01-Z3w9
 ВАРНО С
 Подпис:

Приложение 2 към Техническо предложение**За обособена позиция № 2:****„Доставка на арматура за проводници (кабелни обувки, съединители и накрайници)“**ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ**Приложение 3**

Превод от английски език

ИНСТИТУТ ПО ЕНЕРГЕТИКА
И з с л е д о в а т е л с к и и н с т и т у т
О т д е л с е р т и ф и ц и р а н е



ul. Mory 8, 01-330 Варшава, Полша
Тел.: +48 22 34 51 299
Факс: +48 22 836 63 63
www.ienn.cofn.pl

ДОКАЗАТЕЛСТВО ЗА ОДОБРЯВАНЕ НА ПОДИЗПЪЛНИТЕЛ НА ОТДЕЛ СЕРТИФИЦИРАНЕ НА ИНСТИТУТ ПО ЕНЕРГЕТИКА

в обхвата на лабораторните тестове
№ LBU-001/2016
(Издание 01)

Потвърждава се, че:

- 1. Стенд за тестови цикъл № 1, 2, 3**
- 2. Механична изпитателна стойка за якост**
- 3. Изпитвателен стенд за измерване на съпротивлението**

намиращи се в
ZAE ERGOM Sp. z o.o.,
10 Nowe Sady Str., 94-102 Лодз, Полша

отговаря на критериите за техническите изисквания, посочени в точки 4 и 5 от PN-EN ISO / IEC 17025: 2005 (EN ISO / I EC 17025: 2005) и е получил признание на отдел по сертификация на IEn в рамките на извършването на лабораторни тестове и измервания за собствено ползване на фирмата и за отдел по сертификация на IEn.

Отдел за сертифициране на IEn потвърждава валидността на процедурите за изпитване и измервания, прилагани за измервателните и изследователските станции в ZAE ERGOM Sp. z o.o. в Лодз за тестване според следните стандарти:

PN-EN 61238-1: 2004

Компресионни и механични свързващи устройства за силови кабели с номинално напрежение до 36 kV ($U_m = 42 \text{ kV}$) - Част 1: методи за изпитване и изисквания

Признатите методи за изпитване са дадени в Приложение № 1.

Това доказателство за одобрение е валидно от 01.12.2016 до 01.12.2020

Варшава, 01.12.2016

Ръководител отдел
сертифициране на IEn
/подпис – не се чете/

mgr inż. Grażyna Wiczołek

ВЯРНО С ОРИГИНАЛА
Подпис:




**ПРИЛОЖЕНИЕ № 1 КЪМ ДОКАЗАТЕЛСТВА
ЗА ОДОБРЯВАНЕ НА ПОДИЗПЪЛНИТЕЛ НА ОТДЕЛ
СЕРТИФИЦИРАНЕ НА ИНСТИТУТ ПО ЕНЕРГЕТИКА
№ LBU- 001/2016
(Издание 01)**



Признати методи за изпитване в обхвата:

1. Измерване на температурата чрез многоканален рекордер тип KD7, произведен от LUMEL.
2. Измерване на механичната якост чрез изпитателна машина за статични изпитвания на опън тип ZDM-5 2213, произведена от RAUNSTEIN.
3. Измерване на съпротивление с цифров инструмент малък тип съпротивление DLR010HD, произведен от MEGGER.

ВЪРНО
Подпис:



**EVIDENCE OF APPROVAL
FOR SUBCONTRACTORS
OF CERTIFICATION DEPARTMENT
OF INSTITUTE OF POWER ENGINEERING
IN THE RANGE OF LABORATORY TESTING**

No. LBU – 001/2016
(Issue 01)

It is confirmed that:

- 1. Heat cycle test stand No. 1, 2, 3*
- 2. Strength mechanical test stand*
- 3. Resistance measurement test stand*

*located in the
ZAE ERGOM Sp. z o.o.,
10 Nowe Sady Str., 94-102 Łódź, Poland*

meets the criteria for the technical requirements specified
in point 4 and 5 of PN-EN ISO / IEC 17025:2005 (EN ISO/IEC 17025:2005) and obtained
recognition of Certification Department of IEn in the scope of performing laboratory tests and
measurements for company own use and for Certification Department of IEn.

Certification Department of IEn confirms the validity of test and measurements procedures applied
for the measurement and research stations at ZAE ERGOM Sp. z o.o. in Łódź for testing according
to the following standards:

PN-EN 61238-1:2004

*Compression and mechanical connectrors for power cables rated voltages up to 36
kV (Um= 42 kV) – Part 1: test methods and requirements*


Recognized test methods are given in Appendix No. 1

This evidence of approval is valid from 01.12.2016 until 01.12.2020


Head of Certification
Department of IEn

на основании чл. 36а, ал. 3
от ЗОП

mgr inż. Grażyna Włoczorek



Warsaw, 01.12.2016







**APPENDIX No. 1 TO EVIDENCE OF APPROVAL
FOR SUBCONTRACTORS
OF CERTIFICATION DEPARTMENT
OF INSTITUTE OF POWER ENGINEERING
No. LBU - 001/2016**

(Issue 01)

Recognized test methods in the range:


1. Temperature measurement by means of multichannel screen recorder type KD7 manufactured by LUMEL.
2. Mechanical strength measurement by means of testing machine for static tensile tests type ZDM-5 2213 manufactured by RAUNSTEIN.
3. Resistance Measurement with digital instrument small resistance type DLRO10HD manufactured by MEGGER.




Приложение 2 към Техническо предложение**За обособена позиция № 2:****„Доставка на арматура за проводници (кабелни обувки, съединители и накрайници)“****ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 4**



ERGOM Z.A.E. Sp. z o. o.
Nowe Sady 10 Str., 94-102 Lodz, Poland
(+48)42 689 33 86
export@ergom.com



Декларация за съответствие 58/2015

- 1. **Производител:** ZAE ERGOM Sp. z o. o
94-102 Lodz ul. Nowe Sady 10
- 2. **Продукт:** Алуминиева кабелна обувка **KRAC**
- 3. **Класификация:** PKWiU 31.20.27-70.00
- 4. **Употреба и обхват на използване:** използва се за свързване на алуминиеви проводници.
- 5. **Техническа спецификация:** Обувките отговарят на условията PN-E-06401-02:1990 и DIN 46329.
- 6. **Партида, която е обхваната от декларация:** продукти закупени от клиента.

С настоящото декларирам с пълна отговорност, че продуктът съответства с техническите спецификации по т. 4 и т. 5.

Dział Kontroli Jakości
Specialist / w/s Jakości


на основание чл. 36а, ал. 3
от ЗОП

Ръководител на качеството


WIRING ACCESSORIES
CABLE TCABLE TERMINALS
TOOLS FOR ELECTRICIANS
ENCLOSURES AND SWITCHGEARS



VAT: PL7260129071, Regan: 473076927, KRS: 0000132427
Sgd Rejonowy dla todzi - Srodmiestia w todzi, XX Wydzial Krajowego Rejestru Sqdowego
Initial Capital ERGOM Z.A.E. : 1 0.400.000,00 PLN
Bank Zachodni WBK SA II/O Lodz, BIC: WBK PPLPP, IBAN: PL 16 1090 1304 00000000 3034 8970



ВЪРНО С ОПРАВНО
Подпис:



DECLARATION OF CONFORMITY 58/2015

- 1. Product manufacturer:** ZAE ERGOM Sp. z o. o
94-102 Łódź ul. Nowe Sady 10
 - 2. Product name:** Aluminum cable terminals type KRAC
 - 3. Product classification:** PKWiU 31.20.27-70.00
 - 4. Product application and the range of usage:** used for termination of aluminum conductors of energetics wires.
- 1. Technical specification:** Terminals are compliant with norm PN-E-06401-02:1990 and DIN 46329.
 - 2. Batch covered by the declaration:** products purchased by the customer.

I hereby declare with full responsibility, that the product is compliant with the technical specification as per point 4 and 5.


Dział Kontroli Jakości

на основании чл. 36а, ал. 3
от ЗОП

Quality control dept. manager



WIRING ACCESSORIES
CABLE TERMINALS
TOOLS FOR ELECTRICIANS
ENCLOSURES AND SWITCHGEARS




VAT: PL7260129071, Regon: 473076927, KRS: 0000132427
Sąd Rejonowy dla Łodzi – Śródmieście w Łodzi, XX Wydział Krajowego Rejestru Sądowego
Initial Capital: ERGOM Z.A.E. / 10.400.000,00 PLN
Bank Zachodni WBK SA II/O Łódź, BIC: WBK PPLPP, IBAN: PL 16 1090 1304 0000 0000 8034 8970



ERGOM Z.A.E. Sp. z o. o.
Nowe Sady 10 Str., 94-102 Lodz, Poland
(+48)42 689 33 86
export@ergom.com

Превод от английски език



Лодз, 2016-03-02

Сертификат за качество 55/2016

Декларираме, че предлаганите от Ergom алуминиеви кабелни обувки тип KRAC се изработват суровини съгласно посочените по-долу стандарти:

- 1) PN-EN 754-3: 2009 Алуминиеви и алуминиеви сплави – пръти и тръби студено изтеглени - част 3. Допустими отклонения в размерите и формите на кръгли пръти.
- 2) PN-EN 573 - 3: 2013 Алуминиев и алуминиеви сплави - химичен състав и видове изделия - част 3. Химичен състав и видове продукти.

Dzial Kontroli Jakości

на основание чл. 36а, ал. 3
от ЗОП

Ръководител отдел Контрол на качеството


WIRING ACCESSORIES
CABLE TERMINALS
TOOLS FOR ELECTRICIANS
ENCLOSURES AND SWITCHGEARS




VAT: PL7260129071, Regan: 473076927, KRS: 0000132427

Sgd Rejonowy dla łodzi - Srodmiescia w łodzi, XX Wydział Krajowego Rejestru Sądowego
Initial Capital ERGOM Z.A.E. : 1 0.400.000,00 PLN

Bank Zachodni WBK SA II/O Lodz, BIC: WBK PPLPP, IBAN: PL 16 1090 1304 00000000 3034 8970





Łódź dn. 2016-03-02

Quality certificate nr 55/2016



We hereby declare that offered by Ergom aluminium cable terminals type KRAC are made of raw materials according to below standards:

- 1) PN-EN 754-3: 2009 Aluminum and aluminium's alloy – rods and pipes cold drawn – part 3. Tolerances in dimensions and shapes of round rods.
- 2) PN-EN 573 – 3: 2013 Aluminium i stopy aluminium – chemical composition and product types wrought – part 3. Chemical composition and product types.

Dział Kontroli Jakości

на основании чл. 36а, ап. 3
от ЗОП

Quality control dept. manager



STOWARZYSZENIE ELEKTRYKOW POLSKICH
BIURO BADAWCZE DS. JAKOSCI
 04-703 Варшава, ul. Mieczystawa Pozaryskiego 28
 Тел.: +48 22 81 2 69 38; факс: +48 22 81 5 65 80; e-mail: bbj@bbj.pl

СЕРТИФИКАТ ЗА СЪОТВЕТВИЕ Z nr Z/12/060/17

Доставчик:
(Име и адрес) **Zaklad Aparatury Elektrycznej ERGOM Sp. z o.o.**
ul. Nowe Sady 10
94-102 Лодз, Полша

Производител:
(Име и адрес) **Zaklad Aparatury Elektrycznej ERGOM Sp. z o.o.**
ul. Nowe Sady 10
94-102 Лодз, Полша

Име на продукта: алуминиеви херметични покалаени кабелни обувки

Тип (модел) **KRAC**
(списък с варианти от другата страна на сертификата)

Техническа информация **номинално сечение 16 mm² – 300 mm²**
Клас A

Вид сертификационна схема **1a в съответствие с PN-EN ISO/IEC 17067**


Мостра от горепосочения продукт е изпитана и е установено, че е в съответствие с изискванията на стандарта (ите) и / или нормативния документ:

Стандарт(и)/нормативни документи	Изпитателни протоколи №	Издаден от
PN-EN 61238-1:2004	LA-17.062/17.045/1	SEP - BBJ
EN 61238-1:2003)	LA-17.062/17.045/2	
(IEC 61238-1:2003)	LA-17.062/17.045/3	
	LA-17.062/17.045/4	

Изпитателния протокол е неразделна част от този сертификат
Варшава, 2017-12-29



Ръководител сертифициращ орган
(подпис – не се чете)
Zbigniew Brzozowski



Допълнителна информация

Списък на варианти:

Тип	Номинално сечение [mm ²]
KRAC 16/8; KRAC 16/10; KRAC 16/12	16
KRAC 25/8; KRAC 25/10; KRAC 25/12	25
KRAC 35/8; KRAC 35/10; KRAC 35/12; KRAC 35/14	35
KRAC 50/8; KRAC 50/10; KRAC 50/12; KRAC 50/14	50
KRAC 70/8; KRAC 70/10; KRAC 70/12; KRAC 70/14; KRAC 70/16	70
KRAC 95/10; KRAC 95/12; KRAC 95/14; KRAC 95/16	95
KRAC 120/10; KRAC 120/12; KRAC 120/14; KRAC 120/16	120
KRAC 150/10; KRAC 150/12; KRAC 150/14; KRAC 150/16; KRAC 150/20	150
KRAC 185/10; KRAC 185/12; KRAC 185/14; KRAC 185/16; KRAC 185/20	185
KRAC 240/10; KRAC 240/12; KRAC 240/14; KRAC 240/16; KRAC 240/20	240
KRAC 300/12; KRAC 300/14; KRAC 300/16; KRAC 300/20	300

NC-A 17.400

Per. № S-A-17-045


Копие до:

1. Zakład Aparatury Elektrycznej ERGOM S., z o.o.

ul. Nowe Sady 10

94-102 Лодз, Полша

2. NC





STOWARZYSZENIE ELEKTRYKÓW POLSKICH
BIURO BADAWCZE DS. JAKOŚCI

04-703 Warszawa, ul. Mieczysława Pożaryskiego 28
tel.: +48 22 812 69 38; fax: +48 22 815 65 80; e-mail: bbj@bbj.pl

CERTYFIKAT ZGODNOŚCI Z

CERTIFICATE OF CONFORMITY Z

nr Z/12/060/17

No. Z/12/060/17

Firma nagrodzona Złotą Odznaką Honorową SEP
Company granted with SEP Gold Honour Award

Dostawca: Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
(Nazwa i adres) ul. Nowe Sady 10
Supplier: 94-102 Łódź, Poland
(Name and address)

Producent: Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
(Nazwa i adres) ul. Nowe Sady 10
Manufacturer: 94-102 Łódź, Poland
(Name and address)

Nazwa wyrobu: Końcówki aluminiowe szczelne cynowane.
Name of the product: Aluminium terminals longitudinally sealed tin-plated.

Typ (model): KRAC
Type (model):
(wykaz wykonań na drugiej stronie certyfikatu)
(list of variations on the other side of the certificate)

Dane techniczne: Przekrój znamionowy: 16 mm² ÷ 300 mm²;
Technical data: Klasa A.
Rated cross-section: 16 mm² ÷ 300 mm²;
Class A.

Typ programu certyfikacji: 1a według PN-EN ISO/IEC 17067
Type of certification scheme: 1a according to PN-EN ISO/IEC 17067

Próbka wymienionego wyżej wyrobu została zbadana i uznana, jako spełniająca wymagania norm(-y) i/lub dokumentów normatywnych:

A sample of the aforesaid product was tested and found to be in conformity with the requirement of the standard(s) and/or normative document:


Norma(-y)/ dokumenty normatywne Standard(s)/normative documents	Raport(-y) z badań nr Test report(s) No.	Wydany(-e) przez Issued by
PN-EN 61238-1:2004 (EN 61238-1:2003) (IEC 61238-1:2003)	LA-17.062/17.045/1 LA-17.062/17.045/2 LA-17.062/17.045/3 LA-17.062/17.045/4	SEP - BBJ

Raport z badań stanowi integralną część niniejszego certyfikatu
Test Report forms integral part of this Certificate



AC 012

Warszawa, 2017-12-29



Kierownik Jednostki Certyfikującej
Certification Body Manager

на основании чл. 36а, ал. 3
от ЗОП

Zbigniew Brzozowski

Podpis:

Informacje dodatkowe:
Additional information:

Wykaz odmian:
List of variations:

Typ Type	Przekrój znamionowy Rated cross-section [mm ²]
KRAC 16/8; KRAC 16/10; KRAC 16/12	16
KRAC 25/8; KRAC 25/10; KRAC 25/12	25
KRAC 35/8; KRAC 35/10; KRAC 35/12; KRAC 35/14	35
KRAC 50/8; KRAC 50/10; KRAC 50/12; KRAC 50/14	50
KRAC 70/8; KRAC 70/10; KRAC 70/12; KRAC 70/14; KRAC 70/16	70
KRAC 95/10; KRAC 95/12; KRAC 95/14; KRAC 95/16	95
KRAC 120/10; KRAC 120/12; KRAC 120/14; KRAC 120/16	120
KRAC 150/10; KRAC 150/12; KRAC 150/14; KRAC 150/16; KRAC 150/20	150
KRAC 185/10; KRAC 185/12; KRAC 185/14; KRAC 185/16; KRAC 185/20	185
KRAC 240/10; KRAC 240/12; KRAC 240/14; KRAC 240/16; KRAC 240/20	240
KRAC 300/12; KRAC 300/14; KRAC 300/16; KRAC 300/20	300

NC-A 17.400
Nr rej. S-A-17-045
Reg. No. S-A-17-045

Rozdzielnik:
Copy to:



- Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
ul. Nowe Sady 10
94-102 Łódź, Poland
- NC



ВЕРНО С ОЗНАЧЕННЫМ
Подпись:

Приложение 2 към Техническо предложениеЗа обособена позиция № 2:

„Доставка на арматура за проводници (кабелни обувки, съединители и накрайници)“

ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ**Приложение 5**

Handwritten signature and circular stamp. The stamp contains the text: "РЕПУБЛИКА БЪЛГАРИЯ" (Republic of Bulgaria) at the top, "ФИЛКАБ АД" (FIKAB AD) in the center, and "4004 ПЛОВДИВ" (4004 PLOVDIV) at the bottom.

2 ERGOM

Технология за кримпване на алуминиеви кабелни обувки

Изработени като: пръстеновидни обувки, прави, стегнати (тип KRA съгласно Ergom) съгласно DIN 46329; гилзи. При останалите обувки (с изключение на KLA, 2KAm, 2ZA, KLAN) DIN размерите се отнасят само за тръбната част на обувката. Те са изработени като : изправени, пръстовидни обувки (KRA; KRAS; KDA; KDA../2X; 2KAm; тип KA съгласно Ergom); гилзи (LA; LAS; LAD; LAP; LAW; LAWП; KLAN; ZLA; 2ZA тип съгласно Ergom); редуциращи конектори (LA../...; LAP../...; LAWП../...; LAW../... тип съгласно Ergom); кабелен накрайник (BAW; BAK).

Материали: всеки видове - E-Al алуминиева тръба съгласно с DIN 40501 Teil 3 or DIN 1712 Teil 2.


Покритие: без покритие или поцинковани (по заявка).

Приложение:

Изправените, пръстовидни обувки се използват за свързване на кабелна връзка на винтово съединение към шина, комутационна апаратура и др. Гилзите се използват за свързване на два алуминиеви проводника с еднакво напречно сечение (LA, LAS, LAP, LAWП, KLAN, ZLA, KLA, 2ZA) или за свързване на два алуминиеви проводника с различно напречно сечение (LA../...; LAP../...; LAWП../...; LAW../...). Гилзите направени с тези конектри (с изключение на 2ZA, KLA, KLAN, ZLA) не могат да бъдат механично свързани. Алуминиевите кабелни накрайници (BAW, BAK) се използват за свързване на жица с гилзата.

Технология за кримпване:


Обувките се навиват с инструменти, които са неречни "шестоъгълни" кримпващи клещи.




много гилзи

Благодарение на компресираща форма на гилзата се постига връзка с високи механични и електрически параметри. Въпреки това, такива се нуждаят от компресиране на обувката. Колкото повече е броят на компресиите, толкова по-добре е за гилзата.

Много важно в случай на силови връзки, при които се изисква предаване на големи мощности и ток. "Шестоъгълната" компресия се нуждае от още по-голяма сила, за да се навива обувката, така че при такава компресия (дори при малка напречна секция) ZAE ERGOM препоръчва използването на хидравлични инструменти или ръчни инструменти с по-високо механично съотношение. За да се постигне гилзата необходимото качество, се препоръчва да се компресират обувките на "шестоъгълника" по следния начин:




Правилната посока и последователност на притискане на обувката са маркирани със стрелки.




1. Първи натиск (вътрешен)



2. Втори натиск (отвътре навън)




3. Първи натиск от другата страна (вътрешен)



4. Втори натиск от другата страна (отвътре навън)




1. First compression (inside)



2. Втори натиск (отвътре навън)

Всяка обувка е означена с маркировка и е напечатана:


- напречно сечение или диаметър на отвора на винта (в случай на пръстовидни обувки)
- трябва да се постави номер на седалката преди да се навие обувката
- графичен код за броя и позицията на необходимите компресии направени с тесни удари (ръчни инструменти) или широки удар (хидравлични инструменти).



Пример за подобен код е даден по-долу.

1. Търговска марка,
2. Номер.
3. Маркиране на мястото и броя повторения на натиск.
- 3а. Механично: тясно.
- 3б. Хидравлично: широко.
4. Код на кабелите (напречно сечение и профил).

[Handwritten signature]



Всичко маркирано е препоръчително да бъде кримпнато. Моля, обърнете внимание, че трябва да използвате правилната матрица за напречното сечение, за която е проектирана.


Types of cable wires



Кръгъл многожичен кабел (rm)



Кръгъл проводник (re)



Разделен многожичен (sm)



Разделен проводник

Секторните проводници трябва да бъдат заоблени със специални матрици.
www.ergom.com

НАЦИОНАЛЕН ЦЕНТЪР ЗА КАЧЕСТВО
СЪИЗДАВ
Подпис:

Crimping technology for tubular terminals AI

Made as: ring terminals, straight, tight (KRA type acc. to Ergom) in accordance with DIN 46329; butt connectors. In remaining terminals (excepting KLA; 2KAm; 2ZA; KLAN) the DIN dimensions refer only to tubular part of terminal. They are made as: straight ring terminals (KRA; KRAS; KDA; KDA./2X; ZKam; KA type acc. to Ergom); butt connectors (LA; LAS; LAD; LAP; LAW; LAWP; KLAN; ZLA; 2ZA type acc. to Ergom); reduction connectors (LA.../...; LAP.../...; LAWP.../...; LAW.../... type acc. to Ergom); pin terminals (BAW; BAK).

Materials: all types – E-Al aluminium tube acc. to DIN 40501 Teil 3 or DIN 1712 Teil 2.


Surface: without coating or tin-plated (on request).

Application:

Straight ring terminals are used for connecting wire by use of a screw joint to a bus-bar, switchgear, etc. Butt connectors are used to join two aluminum wires of the same cross-section to so called "butt" (LA, LAS, LAP, LAWP, KLAN, ZLA, KLA, 2ZA) or to join two aluminum wire of different cross-section (LA.../...; LAP.../...; LAWP.../...; LAW.../...). The joint made with these connectors (excepting 2ZA, KLA, KLAN, ZLA) cannot be stressed mechanically. Aluminium pin terminals (BAW, BAK) are used for connecting wire with screw joint.


Crimping technology:

Terminals are crimped using tools with so called "hexagon" Crimping dies.




Thanks to such compressing shape joint with very high mechanical and electrical parameters is achieved. However, such joints need several compressions of terminal. The higher compression number the better the joint is.


It is very important in case of power joints where transmission of large power and currents is required. The "hexagon" compression needs still considerable force to crimp a terminal so in case of such compression (even small wire cross-section) ZAE ERGOM recommends use of hydraulic tools or hand-tools with higher mechanical ratio (operated with both hands). In order to achieve joint of required quality it is recommended to compress terminals to "hexagon" in the following way:




Correct direction and sequence of terminal compressions are marked with arrows.



1. First compression (inside)




2. Further compression (from inside to outside)




3. First compression on the other side (inside)



4. Further compressions on the other side (from inside to outside)




1. First compression (inside)



2. Further compression (from inside to outside)

There is marking stamped or overprinted on every terminal to indicate:

- terminal cross-section or screw hole diameter (in case of ring terminals)
- die seat No. to crimp a terminal
- graphic code of number and position of compressions required, made with narrow dies (hand tools) or wide dies (hydraulic tools).



An example of such code is given below.

1. Trade mark.
2. Die seat No.
3. Marking of place and number of compressions.
 - 3a. Mechanic: narrow die.
 - 3b. Hydraulic: wide die.
4. Code of cable types (cross-section and profile).

All marked (recommended) crimping must be made. Please pay attention to use proper die for cross-section to which it is designed.


Types of cable wires




round multiwire
(rm)



round one-wire
(re)




sectored multiwire
(sm)




sectored one-wire
(se)

Sector shaped conductors must be rounded with special dies.



Ręczne i hydrauliczne praski zaciskowe / Crimping



Narzędzia patrz: katalog ŚWIAT NARZĘDZI ERGOM / Tools: see in catalogue ERGOM'S


Narzędzie / Tool / Инструмент


Przekrój / Cross section / Сечение

[mm²]
[mm²]




	KO 6/6 KT Al-C**)	KO 6/6 KT Al-g***)	KO 6F/6 KT Al-C**)	KD 6/6 KT Al	EK 18	EK 19	EK 22	HK 4	HK 5	HK 22	UH 60	PBM 6	PHK-300
10				•	•	•	•	•	•	•	•	•	•
16	•	•		•	•	•	•	•	•	•	•	•	•
25	•	•	•	•	•	•	•	•	•	•	•	•	•
35	•	•	•	•	•	•	•	•	•	•	•	•	•
50	•	•	•	•	•	•	•	•	•	•	•	•	•
70	•	•	•	•	•	•	•	•	•	•	•	•	•
95	•	•	•	•	•	•	•	•	•	•	•	•	•*
120	•	•	•	•	•	•	•	•	•	•	•	•	•*
150			•	•	•	•	•	•	•	•	•	•	•*
185				•	•	•	•	•	•	•	•	•	•*
240										•	•	•	
300												•	
400													
500													
625													
800													
1000													

* z dodatkowym zestawem matryc PHK-R / with additional die set PHK-R type / с дополнительным набором матриц PHK-R
 ***) tylko do końcówek i łączników cienkościennych / only for thin walled terminals and joints / только к терминалам и разъемы тонкий
 ***) tylko do końcówek i łączników grubościennych / only for thick walled terminals and joints / только концы и толстых опор




Приложение 2 към Техническо предложение**За обособена позиция № 2:****„Доставка на арматура за проводници (кабелни обувки, съединители и накрайници)“****ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 6**


Tubular terminals KDR and KDM types



Material Cu.
Surface KDR – tin-plated;
 KDM – uncoated.
Design DIN 46235.

Note! sector shaped conductors must be rounded with special dies.

tin-plated		uncoated		Cross section [mm ²]	Dimension [mm]						Terminal	Crimping			[kg]	
Type	Item No.	Type	Item No.		d	D	s	a	E	W		Die code No.	Nc/w	Nc/n		
KDR 10/5	E11KM-02020100100	KDM 10/5	E11KM-02010100100													0,40
KDR 10/6	E11KM-02020100200	KDM 10/6	E11KM-02010100200	10	4,5	6,0	1,5	12	27	9	M5					0,45
KDR 10/8 ¹⁾	E11KM-02020100300	KDM 10/8 ¹⁾	E11KM-02010100300				1,0			13	M8	6	-	1	100	0,40
KDR 16/6	E11KM-02020100400	KDM 16/6	E11KM-02010100400							13	M6					1,30
KDR 16/8	E11KM-02020100500	KDM 16/8	E11KM-02010100500	16	5,5	8,5	2,5	20	36	17	M8	9	1	2	100	1,40
KDR 16/10	E11KM-02020100600	KDM 16/10	E11KM-02010100600							17	M10					
KDR 16/12 ¹⁾	E11KM-02020100700	KDM 16/12 ¹⁾	E11KM-02010100700				2,0			19	M12					
KDR 25/6	E11KM-02020100800	KDM 25/6	E11KM-02010100800							14	M6					
KDR 25/8	E11KM-02020100900	KDM 25/8	E11KM-02010100900				3,0			16	M8					1,65
KDR 25/10	E11KM-02020101000	KDM 25/10	E11KM-02010101000	25	7,0	10,0		20		17	M10	10	1	2	100	
KDR 25/12	E11KM-02020101100	KDM 25/12	E11KM-02010101100							19	M12					1,90
KDR 25/14 ¹⁾	E11KM-02020101200	KDM 25/14 ¹⁾	E11KM-02010101200				2,0			21	M14					1,80
KDR 25/16	E11KM-02020101300	KDM 25/16	E11KM-02010101300				1,0			25	M16					1,80
KDR 35/6 ¹⁾	E11KM-02020101400	KDM 35/6 ¹⁾	E11KM-02010101400				4,0			17	M6					3,00
KDR 35/8	E11KM-02020101500	KDM 35/8	E11KM-02010101500							42	M8					
KDR 35/10	E11KM-02020101600	KDM 35/10	E11KM-02010101600	35	8,2	12,5		20		19	M10	12	1	2	100	3,10
KDR 35/12	E11KM-02020101700	KDM 35/12	E11KM-02010101700				3,0			21	M12					
KDR 35/14	E11KM-02020101800	KDM 35/14	E11KM-02010101800							44	M14					3,30
KDR 35/16	E11KM-02020101900	KDM 35/16	E11KM-02010101900				2,5			45	M16					4,380
KDR 50/8	E11KM-02020102000	KDM 50/8	E11KM-02010102000							20	M8					4,70
KDR 50/10	E11KM-02020102100	KDM 50/10	E11KM-02010102100							22	M10					4,75
KDR 50/12	E11KM-02020102200	KDM 50/12	E11KM-02010102200	50	10,0	14,5	4,0	28	52	24	M12	14	2	3	100	4,70
KDR 50/14	E11KM-02020102300	KDM 50/14	E11KM-02010102300							26	M14					4,60
KDR 50/16	E11KM-02020102400	KDM 50/16	E11KM-02010102400							28	M16					6,00
KDR 70/8	E11KM-02020102500	KDM 70/8	E11KM-02010102500							24	M10					6,30
KDR 70/10	E11KM-02020102600	KDM 70/10	E11KM-02010102600				4,5			24	M10					6,40
KDR 70/12	E11KM-02020102700	KDM 70/12	E11KM-02010102700	70	11,5	16,5		28	55	26	M12	16	2	3	100	6,55
KDR 70/14	E11KM-02020102800	KDM 70/14	E11KM-02010102800							30	M14					6,20
KDR 70/16	E11KM-02020102900	KDM 70/16	E11KM-02010102900				4,0			30	M16					6,65
KDR 70/20	E11KM-02020103000	KDM 70/20	E11KM-02010103000				3,0			34	M20					4,80
KDR 95/10	E11KM-02020103200	KDM 95/10	E11KM-02010103200							28	M10					4,70
KDR 95/12	E11KM-02020103300	KDM 95/12	E11KM-02010103300							28	M12					4,80
KDR 95/14	E11KM-02020103400	KDM 95/14	E11KM-02010103400	95	13,5	19,0	5,0	35	65	30	M14	19	2	4	50	4,75
KDR 95/16	E11KM-02020103500	KDM 95/16	E11KM-02010103500							32	M16					5,70
KDR 95/20 ¹⁾	E11KM-02020103600	KDM 95/20 ¹⁾	E11KM-02010103600				4,0			69	M20					5,65
KDR 120/10	E11KM-02020103700	KDM 120/10	E11KM-02010103700							32	M10					5,75
KDR 120/12	E11KM-02020103800	KDM 120/12	E11KM-02010103800							32	M12					5,60
KDR 120/14	E11KM-02020103900	KDM 120/14	E11KM-02010103900	120	15,5	21,0	5,0	35	70	34	M14	20	2	4	50	8,10
KDR 120/16	E11KM-02020104000	KDM 120/16	E11KM-02010104000							38	M16					8,20
KDR 120/20	E11KM-02020104100	KDM 120/20	E11KM-02010104100							38	M20					8,30
KDR 150/10	E11KM-02020104200	KDM 150/10	E11KM-02010104200							34	M10					8,20
KDR 150/12	E11KM-02020104300	KDM 150/12	E11KM-02010104300							34	M12					8,00
KDR 150/14	E11KM-02020104400	KDM 150/14	E11KM-02010104400	150	17,0	23,5	6,0	40	78	40	M14	22	2	4	50	8,20
KDR 150/16	E11KM-02020104500	KDM 150/16	E11KM-02010104500							40	M16					9,30
KDR 150/20	E11KM-02020104600	KDM 150/20	E11KM-02010104600							40	M20					9,30
KDR 185/10	E11KM-02020104700	KDM 185/10	E11KM-02010104700							37	M10					9,30
KDR 185/12	E11KM-02020104800	KDM 185/12	E11KM-02010104800							37	M12					9,30
KDR 185/14	E11KM-02020104900	KDM 185/14	E11KM-02010104900	185	19,0	25,5	6,0	42	82	40	M14	25	2	5	50	13,70
KDR 185/16	E11KM-02020105000	KDM 185/16	E11KM-02010105000							40	M16					13,50
KDR 185/20	E11KM-02020105100	KDM 185/20	E11KM-02010105100							42	M20					13,60
KDR 240/12	E11KM-02020105300	KDM 240/12	E11KM-02010105300							42	M12					13,80
KDR 240/14	E11KM-02020105400	KDM 240/14	E11KM-02010105400	240	21,5	29,0	6,5	42	92	45	M14	28	2			8,30
KDR 240/16	E11KM-02020105500	KDM 240/16	E11KM-02010105500							45	M16					8,50
KDR 240/20	E11KM-02020105600	KDM 240/20	E11KM-02010105600							45	M20					8,55
KDR 300/12 ¹⁾	E11KM-02020105700	KDM 300/12 ¹⁾	E11KM-02010105700							48	M12					8,50
KDR 300/14	E11KM-02020105800	KDM 300/14	E11KM-02010105800							48	M14					8,55
KDR 300/16	E11KM-02020105900	KDM 300/16	E11KM-02010105900							48	M16					8,50
KDR 300/20	E11KM-02020106000	KDM 300/20	E11KM-02010106000							48	M20					




Handwritten signature and a circular stamp with text: "ВЕРНО С ОБРАТНОМ СВЯЗЕМ" and "Подпись: ...".

tin-plated		uncoated		Cross section [mm ²]	Dimension [mm]						Terminal	Crimping			Die code No.	Nc/w	Nc/n	Die code No.	Nc/w	Nc/n	Weight [kg]
Type	Item No.	Type	Item No.		d	D	s	a	E	W		Die code No.	Nc/w	Nc/n							
KDR 400/14	E11KM-02020106200	KDM 400/14	E11KM-02010106000	400	27,5	38,5	10,0	70	115	55	M14	38	3	-	25	16,40	38	3	-	19,9	
KDR 400/16	E11KM-02020106300	KDM 400/16	E11KM-02010106100								M16										17,00
KDR 400/20	E11KM-02020106400	KDM 400/20	E11KM-02010106200								M20										
KDR 500/14	E11KM-02020106600	KDM 500/14	E11KM-02010106300	500	31,0	42,0	10,0	70	125	60	M14	42	3	-	25	19,80	42	3	-	20,50	
KDR 500/16 ¹⁾	E11KM-02020106700	KDM 500/16 ¹⁾	E11KM-02010106400								M16										20,20
KDR 500/20	E11KM-02020106800	KDM 500/20	E11KM-02010106500								M20										
KDR 625/14	E11KM-02020107000	KDM 625/14	E11KM-02010106600	625	34,5	44,0	10,0	81	135	63	M14	44	3	-	10	8,20	44	3	-	8,10	
KDR 625/16 ¹⁾	E11KM-02020107100	KDM 625/16 ¹⁾	E11KM-02010106700								M16										
KDR 625/20	E11KM-02020107200	KDM 625/20	E11KM-02010106800								M20										
KDR 800/16	E11KM-02020107401	KDM 800/16	E11KM-02010106900	800	40,0	52,0	24	100	165	75	M16	52	3	-	10	14,80	52	3	-	14,70	
KDR 800/20	E11KM-02020107501	KDM 800/20	E11KM-02010107000								M20										
KDR 1000/16	E11KM-02020107701	KDM 1000/16	E11KM-02010107100								M16										19,30
KDR 1000/20	E11KM-02020107801	KDM 1000/20	E11KM-02010107200	M20	19,10																

¹⁾ Nc/w = No. of crimping wide | Nc/n = No. of crimping narrow
¹⁾ Sizes out of DIN standard.




Technologia zaciskania końcówek i łączników rurowych Cu wg DIN  %s

Dedykowane praszk ręczne i hydrauliczne  %s





www.ergom.com


Приложение 2 към Техническо предложение**За обособена позиция № 2:****„Доставка на арматура за проводници (кабелни обувки, съединители и накрайници)“****ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 7**



INSTITUTE OF POWER ENGINEERING
ЛАБОРАТОРИЯ ВИСОКО НАПРЕЖЕНИЕ
HIGH CURRENT LABORATORY



AB 323

ПРОТОКОЛ ОТ ИЗПИТВАНЕ
EWP/31/E/2016

ИЗСЛЕДОВАТЕЛСКИ СЪОРЪЖЕНИЯ: Кабелни обувки за кербоване KDR 35/10, KOR 35/10;
Кабелни гилзи за кербоване KLD 35, KL 35;
Тестовите бяха проведени върху кабел: Cu 35mm²,
клас 2

ПРОИЗВОДИТЕЛ: Z.A.E. ERGOM Sp. z o.o.
94-102 Лодз
ул. Nowe Sady 10

ИЗПИТАНИЯТА БЯХА ИЗВЪРШЕНИ: Z.A.E. ERGOM Sp. z o. o.
94-102 Лодз
ул. Nowe Sady 10

ВИД НА ИЗПИТВАНИЯТА: Тестови изпитвания за компоненти от клас А:
електрически и механични изпитвания

ПРОЦЕДУРА НА ИЗПИТВАНЕ: PN-EN 61238-1: 2004

ДАТА НА ПОЛУЧАВАНЕ: Август 2016

ДАТА НА ПРОВЕЖДАНЕ НА ИЗПИТВАНЕТО: Август 2016 - Октомври 2016

РЕЗУЛТАТ ОТ ИЗПИТВАНЕТО: Положителен

УЧАСТНИЦИ В ИЗСЛЕДВАНЕТО: Marcin Lis – представител на производителя

Упълномощен мениджър на изпитванията:

Одобрил Мениджър на лабораторията:

mgr inz. Grzegorz Zaboklicki

mgr inz. Maciej Owsinski

подпис: не се чете

подпис: не се чете

Варшава, 03.02.2017r.


Резултатите от изпитването се отнасят само за тествания обект. Лабораторията не разрешава без писменото съгласие на лабораторията публикуването или възпроизвеждането на протокола в различна форма от пълно копие.

ВЪРНО С ОРГАНИЗАЦИЯТА
Подпис:



INSTYTUT ENERGETYKI
INSTITUTE OF POWER ENGINEERING
LABORATORIUM WIELKOPRĄDOWE
HIGH CURRENT LABORATORY

01-330-Warszawa
ul. Mory 8
tel./fax 22 836-80-16
e-mail: ewp@ien.com.pl
www.ien.com.pl/ewp



AB 323



RAPORT Z BADAŃ EWP/31/E/2016

OBIEKT BADAŃ: Końcówki oczkowe: końcówki rurowe typu KDR 35/10, KOR 35/10;
Złączki: łączniki typu KLD 35, KL 35;
Badania przeprowadzono na przewodzie: rmc Cu 35mm², klasa 2

PRODUCENT: Z.A.E. ERGOM Sp. z o.o.
94-102 Łódź
ul. Nowe Sady 10

BADANIA WYKONANO NA ZAMÓWIENIE: Z.A.E. ERGOM Sp. z o.o.
94-102 Łódź
ul. Nowe Sady 10

RODZAJ BADAŃ: Badania typu dla elementów klasy A:
badania elektryczne i mechaniczne

PROCEDURA BADAŃ: PN-EN 61238-1: 2004

DATA OTRZYMANIA OBIEKTU: Sierpień 2016

DATA WYKONANIA BADAŃ: Sierpień 2016 - Październik 2016

WYNIK BADAŃ: Pozytywny

W BADANIACH UCZESTNICZYŁ: Marcin Lis – przedstawiciel producenta

**AUTORYZOWAŁ
KIEROWNIK BADAŃ:**

mgr inż. Grzegorz Zaboklicki


на основании чл. 36а, ал. 3
от ЗОП

Warszawa, 03.02.2017r.


**ZATWIERDZIŁ
KIEROWNIK LABORATORIUM**

mgr inż. Maciej Owsiański

на основании чл. 36а, ал. 3
от ЗОП



Wyniki badań odnoszą się wyłącznie do badanego obiektu. Bez pisemnej zgody laboratorium nie zezwala się na publikowanie lub reprodukcję raportu w innej postaci niż dokładna i kompletna jego kopia.





Приложение 2 към Техническо предложение

За обособена позиция № 2:

„Доставка на арматура за проводници (кабелни обувки, съединители и накрайници)“


ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ

Приложение 8





ERGOM Z.A.E. Sp. z o. o.
Nowe Sady 10 Str., 94-102 Lodz, Poland
(+48)42 689 33 86
export@ergom.com



Лодз, 2015-07-27

Декларация за съответствие 71/2015

1. **Производител:** ZAE ERGOM Sp. z o. o
94-102 Lodz ul. Nowe Sady 10
2. **Продукт:** Медни кабелни обувки KDR, KDM
3. **Класификация:** PKWiU 31.20.27-70.00
4. **Употреба и обхват на използване:** използва се за свързване на медни проводници.
5. **Техническа спецификация:** Обувките отговарят на условията DIN 46235
6. **Партида, която е обхваната от декларация:** продукти закупени от клиента.

С настоящото декларирам с пълна отговорност, че продуктът съответства с техническите спецификации по т.4 и т.5.


Dział Kontroli Jakości
Секция за Изпитания
на основание чл. 36а, ал. 3
от ЗОП


Ръководител отдел Контрол на качеството

WIRING ACCESSORIES
CABLE TERMINALS
TOOLS FOR ELECTRICIANS
ENCLOSURES AND SWITCHGEARS



VAT: PL7260129071, Regan: 473076927, KRS: 0000132427
Sgd Rejonowy dla todzi - Srodmiestia w todzi, XX Wydzial Krajowego Rejestru Sqdowego
Initial Capital ERGOM Z.A.E. : 1 0.400.000,00 PLN
Bank Zachodni WBK SA II/O Lodz, BIC: WBK PPLPP, IBAN: PL 16 1090 1304 00000000 3034 8970





Łódź 27.07.2015

Declaration of conformity 71/2015

1. **Product manufacturer:** ZAE ERGOM Sp. z o. o
94-102 Łódź ul. Nowe Sady 10
2. **Product name :** Copper tubular cable terminals type KDR, KDM
3. **Product classification:** PKWiU 31.20.27-70.00
4. **Product application and the range of usage:** used for termination of copper conductors of energetics wires.
5. **Technical specification:** Terminals are compliant with norm DIN 46235
6. **Batch covered by the declaration:** products purchased by the customer.

I hereby declare with full responsibility, that the product is compliant with the technical specification as per point 4 and 5.

Dział Kontroli Jakości

на основании чл. 36а, ал. 3
от ЗОП

Quality control dept. manager




WIRING ACCESSORIES
CABLE TERMINALS
TOOLS FOR ELECTRICIANS
ENCLOSURES AND SWITCHGEARS

ISO
9001

VAT: PL7260129071, Regon: 470076927, KRS: 0000132427
Sąd Rejonowy dla Łodzi – Śródmieście w Łodzi, XX Wydział Krajowego Rejestru Sądowego
Initial Capital ERGOM Z.A.E.: 10.400.000,00 PLN
Bank Zachodni WBK SA II/O Łódź, BIC: WBK PPLP, IBAN: PL 16 1090 1304 0000 0000 3034 8970



ERGOM Z.A.E. Sp. z o. o.
Nowe Sady 10 Str., 94-102 Lodz, Poland
(+48)42 689 33 86
export@ergom.com



Лодз, 04.10.2017

Декларация за съответствие 81/2017

1. **Производител на продукта:** ZAE ERGOM Sp. z o. o
94-102 Лодз ул. Новото Сади 10
2. **Наименование на продукта:** Кабелни обувки: KOR, KDR
3. **Класификация на продукта:** PKWU 27.33.13.0
4. **Приложение на продукта и обхват на употреба:** използва се за свързване на медни проводници
5. **Техническа спецификация:** продукти, произведени от безшевни медни тръби за електрически цели в съответствие с норма EN 13600 (Мед и медни сплави)

1. **Партида, обхваната от декларацията:** продукти, закупени от клиента.

Декларирам с пълна отговорност, че продуктът отговаря на техническата спецификация съгласно точка 5.

Dział Kontroli Jakości
на основание чл. 36а, ал. 3
от ЗОП


Ръководител отдел Контрол на качеството



WIRING ACCESSORIES
CABLE TCABLE TERMINALS
TOOLS FOR ELECTRICIANS
ENCLOSURES AND SWITCHGEARS



VAT: PL7260129071, Regan: 473076927, KRS: 0000132427
Sgd Rejonowy dla todzi - Srodmiescia w todzi, XX Wydzial Krajowego Rejestru Sqdowego
Initial Capital ERGOM Z.A.E. : 1 0.400.000,00 PLN
Bank Zachodni WBK SA II/O Lodz, BIC: WBK PPLPP, IBAN: PL 16 1090 1304 00000000 3034 8970



Łódź, 04.10.2017



Declaration of conformity 81/2017

- 1. Product manufacturer:** ZAE ERGOM Sp. z o.o.
94-102 Łódź ul. Nowe Sady 10
 - 2. Product name:** Cable terminals: KOR, KDR
 - 3. Product classification:** PKWiU 27.33.13.0
 - 4. Product application and the range of usage:** used for termination of copper conductors of energetics wires
 - 5. Technical specification:** products made from seamless copper pipes for electrical purposes compliant with norm EN 13600 (Copper and copper alloys)
-
- 1. Batch covered by the declaration:** products purchased by the customer.

I hereby declare with full responsibility, that the product is compliant with the technical specification as per point 5.

Dział Kontroli Jakości
Specjalista: Wiesława
на основании чл. 36а, ал. 3
от ЗОП

Quality control dept. manager



ИНСТИТУТ ПО ЕНЕРГЕТИКА
Изследователски институт
01-330 Варшава, ул. Мору 8
тел. +48 22 34 51 299, факс. +48 22 836 63 63
instytut.energetyki@ien.com.pl

СВРТИФИКАТ ІЕп
NR 007/2015
(ПОТВЪРЖДЕНИЕ)

Име и адрес
Притежателят на сертификата: Отдел Електрическо Оборудване ERGOM Sp. z o. o.
ул. Nowe Sady 10
94-102 Лодз

Име на продукта: Кабелни обувки и конектори

Тип (варианти): КО, КW, КОІ, КWІ, КОР, КL, КDR, КRM, КLD, КRA, КDA, КLA, LA, КСА

Производител: Отдел Електрическо Оборудване ERGOM Sp. z o. o.
ул. Nowe Sady 10
94-102 Лодз

Основни параметри
и приложение: Според прикачения файл
Кабелни обувки и конектори за свързване на медни или алуминиеви
кабели

Продуктът отговаря на
изискванията, съдържащи се в: DIN 46234, DIN 46237, DIN 46235, DIN 46329, DIN 46267-1, DIN 46267-2
и PN-90/E-06401/02⁴ в областта на проверка на размерите и електрическите
изпитвания

Според докладите
направени от: Лаборатория Високо напрежение на Институт по енергетика

Номер на доклада за
оценка на продукта: EWP/52/E/99 - I
EWP/52/E/99
EWP/S2/E/2000 - III
EWP/52/E/2000- IV
EWP/52/E/2000 - V

Срок на валидност: от 12 юни 2015 г. до 12 юни 2020 г.

Правото за използване на сертификата за съответствие по време на неговата валидност се отнася само за

- онези образци, които отговарят на горепосочените изисквания и имат идентични свойства (параметри) като проби / проби от продукти, представени за изпитване,
- собственика на сертификата или негов упълномощен представител.

Спецификацията на характеристиките на продукта се съдържа в приложението към този сертификат. Брой прикачени файлове: 1

Моделът за сертифициране включва:
- проучване и оценка на качеството на проекта.
- оценка на системата за качество на доставчика

Варшава, дата 12.06.2015 г.

z up. ДИРЕКТОР
НА ИНСТИТУТА ПО ЕНЕРГЕТИКА
подпис: не се чете
dr hab. in/ Jerzy Przybysz prof. ІЕп

ВЪРНО С СРМ
Подпис:

**УДОСТОВЕРЕНИЕ ЗА СЕРТИФИКАТ IEd
NR 007/2015
НАСТРОЙКА НА ДИАГРАМАТА НА ИЗБРАНИТЕ ПАРАМЕТРИ**


Обхват на сечения	Съответствие на размерите с нормите
KO / 0,5 ÷ 95 mm ²	DIN 46234
KW / 0,5 ÷ 16 mm ²	DIN 46234 ²⁾
KOI / 0,5 ÷ 95 mm ²	DIN 46237
KWI / 0,5 ÷ 16 mm ²	DIN 46237 ²⁾
KOR / 0,75 ÷ 625 mm ²	съвместимост с каталога
KL / 4 ÷ 625 mm ²	съвместимост с каталога
KDR / 10 ÷ 1000 mm ²	DIN 46235
KRM / 16 ÷ 500 mm ²	DIN 46235 ²⁾
KLD / 10 ÷ 1000 mm ²	DIN 46267-1
KRA / 16 ÷ 500 mm ²	DIN 46329
KDA / 16 ÷ 625 mm ²	DIN 46329 ²⁾
KLA / 16 ÷ 240 mm ²	съвместимост с каталога
LA / 10 ÷ 1000 mm ²	DIN 46267-2
KCA / 16 ÷ 300 mm ²	DIN 46329 ²⁾


БЕЛЕЖКИ:

¹⁾ Съответствие със стандартните изисквания PN-90/E-06401/02 в областта на електрическите изследвания това се отнася за конектори от тип: ICO (за 95 mm²), KW, KOI (за 95 mm²), KWI, KOR, KL, KRA, KDA, KLA, LA, KCA.

Съответствието с изискванията на стандарта PN-90 / E-06401/02 в областта на електрическите изпитвания се прилага за кабелни обувки и конектори от типа: ICO (до 95 mm²), KW, KOI (до 95 mm²), KWI, KOR, KL, KRA, KDA, KLA, LA, KCA

²⁾ Прилага се само към тръбната част



INSTYTUT ENERGETYKI
Instytut Badawczy
01-330 Warszawa, ul. Mory 8
tel. +48 22 34 51 299, fax. +48 22 836 63 63,
instytut.energetyki@ien.com.pl

CERTYFIKAT IEn

NR 007/2015
(POŚWIADCZENIE)

**Nazwa i adres
posiadacza certyfikatu:**

Zakład Aparatury Elektrycznej ERGOM Sp. z o. o.
ul. Nowe Sady 10
94-102 Łódź

Nazwa wyrobu:

Końcówki i złączki kablowe

Typ (odmiany):

KO, KW, KOI, KWI, KOR, KL, KDR, KRM, KLD, KRA, KDA, KLA, LA, KCA

Producent:

Zakład Aparatury Elektrycznej ERGOM Sp. z o. o.
ul. Nowe Sady 10
94-102 Łódź

**Podstawowe parametry
i zastosowanie:**

Według załącznika
Końcówki i złączki do zakończeń i połączeń miedzianych lub aluminiowych
żył roboczych kabli energetycznych

**Wyrób spełnia wymagania
zawarte w:**

DIN 46234, DIN 46237, DIN 46235, DIN 46329, DIN 46267-1, DIN 46267-2,
oraz PN-90/E-06401/02¹⁾ w zakresie sprawdzenia wymiarów i badań
elektrycznych

**Zgodnie z raportami
wykonanymi przez:**

Laboratorium Wielkopiędowe Instytutu Energetyki

Nr raportu z oceny wyrobu:

EWP/52/E/99 – I
EWP/52/E/99
EWP/52/E/2000 – III
EWP/52/E/2000 – IV
EWP/52/E/2000 – V

Okres ważności:

od 12 czerwca 2015 do 12 czerwca 2020

Prawo do posługiwania się certyfikatem zgodności w okresie jego ważności dotyczy wyłącznie:

- tych egzemplarzy, które spełniają wyżej określone wymagania i posiadają identyczne właściwości (parametry) jak wzory/próbki wyrobów przedstawione do badań,
- właściciela certyfikatu lub jego upoważnionego przedstawiciela.


Zestawienie przypisanych parametrów wyrobu zawiera załącznik do niniejszego certyfikatu.

Liczba załączników: I

Model certyfikacji obejmuje:

- badania i ocenę jakości projektowej,
- ocenę systemu jakości dostawcy.

Warszawa, dnia 12.06.2015 r.



z up. DYREKTORA
INSTYTUTU ENERGETYKI
на основании чл. 36а, ал. 3
от ЗОП
dr hab. inż. Jerzy Przybysz prof. IEn





ZALĄCZNIK CERTYFIKATU IEN
NR 007/2015
ZESTAWIENIE PRZYPISANYCH PARAMETRÓW WYROBU

TYP KOŃCÓWKI / Zakres przekrojów	Zgodność wymiarów z normą
KO / 0.5 ÷ 95 mm ²	DIN 46234
KW / 0.5 ÷ 16 mm ²	DIN 46234 ²⁾
KOI / 0.5 ÷ 95 mm ²	DIN 46237
KWI / 0.5 ÷ 16 mm ²	DIN 46237 ²⁾
KOR / 0.75 ÷ 625 mm ²	zgodność z katalogiem
KL / 4 ÷ 625 mm ²	zgodność z katalogiem
KDR / 10 ÷ 1000 mm ²	DIN 46235
KRM / 16 ÷ 500 mm ²	DIN 46235 ²⁾
KLD / 10 ÷ 1000 mm ²	DIN 46267-1
KRA / 16 ÷ 500 mm ²	DIN 46329
KDA / 16 ÷ 625 mm ²	DIN 46329 ²⁾
KLA / 16 ÷ 240 mm ²	zgodność z katalogiem
LA / 10 ÷ 1000 mm ²	DIN 46267-2
KCA / 16 ÷ 300 mm ²	DIN 46329 ²⁾

UWAGI:

- 1) Spełnienie wymagań normy PN-90/E-06401/02 w zakresie badań elektrycznych dotyczy końcówek i złączek typu: KO (do 95 mm²), KW, KOI (do 95 mm²), KWI, KOR, KL, KRA, KDA, KLA, LA, KCA.
- 2) Dotyczy tylko części rurkowej





ИНСТИТУТ ПО ЕНЕРГЕТИКА

Исследователски институт

01-330 Warszawa, ul. Mory 8

тел. +48 22 34 51 299

факс: +48 22 836 63 63

instytut.energetyki@ien.com.pl

СЕРТИФИКАТ ЗА СЪОТВЕТСТВИЕ

№ 071/2018

Издание № 1 от 2018.07.23

Име и адрес на

притежателя на сертификата:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.

ul. Nowe Sady 10.

94-102 Лодз

Име на продукта:

Медни тръбни кабелни обувки / съединителни гилзи в съответствие с DIN

Тип:

KDR 25-240/ KLD 25-240

Производител:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.

ul. Nowe Sady 10.

94-102 Лодз

Параметри и

приложение на продукта:

Съгласно приложението

Свързване на медни кабели с жила клас 2 с параметри

съгласно приложението

Продукта е в съответствие с изискванията на:

IEC 61238-1:2003 (ed. 2.0)

Съгласно изпитванията направени от:

Instytut Energetyki, ZAE ERGOM

Номер на изпитвания за оценка на продукта:

DZC/186c/E/2016-5

Номер на изпитателни протоколи:

EWP/35/E/2016-6, EWP/35/E/2016-7, EWP/35/E/2017-11, EWP/35/E/2018-15, EWP/57/E/2018-3, ERGOM/08/01/2018, ERGOM/06/12/2017, ERGOM/07/12/2017, ERGOM/09/04/2018

Период на валидност:

от 23 юли 2017 до 22 юли 2021

Правото за използване на сертификата за съответствие в срока му на валидност се прилага само за:

- тези образци, които отговарят на посочените по-горе изисквания и имат същите характеристики (параметри) като образците на модела / продукта, представени за изпитване,
- собственик на сертификат или негов упълномощен представител.

Списъкът на доказаните параметри е включен в приложенията към сертификата за съответствие.

Брой приложения: 1

**СИСТЕМАТА НА СЕРТИФИЦИРАНЕ НА ПРОДУКТА Ia (PN-EN ISO / IEC 17067: 2014-01)
(параметри на продукта, потвърдени от типово изпитване)**


Варшава, 2018.07.23

ДИРЕКТОР НА
ИНСТИТУТ ПО ЕНЕРГЕТИКА

на основание чл. 36а, ал. 3
от ЗОП

на основание чл. 36а, ал. 3
от ЗОП

dr hab. inż. Jerzy Przybysz prof. PŁ



**ПРИЛОЖЕНИЕ КЪМ СЕРТИФИКАТ ЗА СЪОТВЕТСТВИЕ
No. 071/2018
Издание № 1 от 2018.07.23**

СПИСКЪН НА ДОКАЗАНИТЕ ПАРАМЕТРИ

Параметър	KDR 25-240	KLD 25-240
Клас	A	A
Форма на медните кабели / проводници [mm ²]	rmv, rmc, rm / 25 ÷ 240	rmv, rmc, rm sm/ 25 ÷ 240
Първоначално разпръскване δ ¹⁾	≤ 0,30	≤ 0,30
Средно разпръскване β ²⁾	≤ 0,30	≤ 0,30
Коефициент на съпротивление λ ³⁾	≤ 2,0	≤ 2,0
Коефициент промяна на съпротивлението D ⁴⁾	≤ 0,15	≤ 0,15
Максимална температура θ _{max} ⁵⁾	≤ θ _{ref}	≤ θ _{ref}
Допустима сила на опън [N]	≤ 60xA ⁶⁾ Cu	≤ 60xA ⁶⁾ Cu

БЕЛЕЖКИ

- 1) ¹⁾ Средната стойност на коефициентите на съпротивление на шест съединителя (накрайници) преди първия топлинен цикъл.
- 2) ²⁾ Средната стойност на коефициентите на съпротивление на шест съединителя (накрайници), изчислени от последните 11 измервания. Определя дали всички конектори (накрайници) от даден тип се характеризират с подобни промени в съпротивлението по време на топлинните цикли.
- 3) ³⁾ Коефициент на съпротивление на изпитвания съединител (накрайник) по време на топлинния цикъл към началния коефициент на съпротивлението.
- 4) ⁴⁾ Стойността определя размера на промяната на коефициента на съпротивление въз основа на последните 11 измервания.
- 5) ⁵⁾ Температура на съединителя (накрайника), съпоставена към референтната температура.
- 6) ⁶⁾ Номинална площ на напречното сечение

ВЪРНО С СЕРТИФИКАТ
Подпис:



AC 117

INSTYTUT ENERGETYKI

Research Institute

01-330 Warszawa, ul. Mory 8

tel. +48 22 34 51 299

fax. +48 22 836 63 63

instytut.energetyki@ien.com.pl

CERTIFICATE OF CONFORMITY

No. 071/2018

Issue No. 01 of 2018.07.23

Name and address of the Certificate Holder:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
ul. Nowe Sady 10,
94-102 Łódź

Name of the product:

Copper tubular cable lugs / butt connectors according to DIN

Type:

KDR 25-240/ KLD 25-240

Manufacturer:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
ul. Nowe Sady 10,
94-102 Łódź

Parameters and application of the product:

According to appendix
Connection and termination of copper cables with class 2
conductors with parameters according to appendix

The product meets requirements of:

IEC 61238-1:2003 (ed. 2.0)

According to the reports made by:

Instytut Energetyki, ZAE ERGOM

Number of the product evaluation reports:

DZC/186c/E/2016-5

Number of the test reports:

EWP/35/E/2016-6, EWP/35/E/2016-7, EWP/35/E/2017-11,
EWP/35/E/2018-15, EWP/57/E/2018-3, ERGOM/08/01/2018,
ERGOM/06/12/2017, ERGOM/07/12/2017, ERGOM/09/04/2018

Period of validity:

from 23rd of July 2017 until 22nd of July 2021

The right to use the certificate of conformity within its validity period applies only to:

- these copies that meet the requirements specified above and have the same characteristics (parameters) as the model / product samples submitted for testing,
- certificate owner or his authorized representative.

The list of evidenced parameters is included in the appendices to the certificate of conformity.

Number of appendices: 1

THE SYSTEM OF PRODUCT CERTIFICATION 1a (PN-EN ISO/IEC 17067:2014-01)

(product parameters confirmed by type test)

на основании чл. 36а, ал. 3
от ЗОП

pp of the DIRECTOR OF
INSTYTUT ENERGETYKI

на основании чл. 36а, ал. 3
от ЗОП

Warsaw, 2018.07.23

dr hab. inż. Jerzy Przybysz prof. IEn



APPENDIX TO CERTIFICATE OF CONFORMITY
No. 071/2018
Issue No. 01 of 2018.07.23


LIST OF EVIDENCED PARAMETERS

Element type	KDR 25-240	KLD 25-240
Class	A	A
Shape of Cu cables /conductors [mm ²]	rmv, rmc, rm, sm / 25 ÷ 240	rmv, rmc, rm, sm / 25 ÷ 240
Initial scatter δ^1	$\leq 0,30$	$\leq 0,30$
Mean scatter β^2	$\leq 0,30$	$\leq 0,30$
Resistance factor ratio λ^3	$\leq 2,0$	$\leq 2,0$
Change in resistance factor D ⁴	$\leq 0,15$	$\leq 0,15$
Maximum temperature θ_{max}^5	$\leq \theta_{ref}$	$\leq \theta_{ref}$
Permissible tensile force [N]	$\leq 60xA^6$ Cu	$\leq 60xA^6$ Cu

NOTES:

- 1) ¹⁾ The average value of the resistance factors of six connectors (lugs) before the first heating cycle.
- 2) ²⁾ The average value of the resistance factors of six connectors (lugs) calculated from last 11 measurements readings. It specifies if all connectors (lugs) of given type are characterized by similar changes in resistance during the heat cycles.
- 3) ³⁾ Resistance factor ratio of tested connector (lug) during the heat cycle test in relation to the initial resistance factor.
- 4) ⁴⁾ The value specifies the size of the resistance factor change based on last 11 measurements readings.
- 5) ⁵⁾ Temperature of the connector (lug) referenced to the temperature of the reference section.
- 6) ⁶⁾ Nominal cross-sectional area





ИНСТИТУТ ПО ЕНЕРГЕТИКА

Исследователски институт

01-330 Warszawa, ul. Mory 8

тел. +48 22 34 51 299

факс: +48 22 836 63 63

instytut.energetyki@ien.com.pl

СЕРТИФИКАТ ЗА СЪОТВЕТСТВИЕ

№ 071/2018

Издание № 3 от 2019.02.18

Име и адрес на

притежателя на сертификата:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
ul. Nowe Sady 10.
94-102 Лодз

Име на продукта:

Медни гръбни кабелни обувки / съединителни гилзи в
съответствие с DIN

Тип:

KDR 10-240/ KLD 10-240

Производител:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
ul. Nowe Sady 10.
94-102 Лодз

Параметри и

приложение на продукта:

Съгласно приложението
Свързване на медни кабели с жила клас 2 с параметри
съгласно приложението

Продукта е в съответствие
с изискванията на:

IEC 61238-1:2003 (ed. 2.0)

Съгласно изпитванията
направени от:

Instytut Energetyki, ZAE ERGOM, SEP-BBJ

Номер на изпитвания за
оценка на продуктам:

DZC/186c/E/2016-5

Номер на изпитателни
протоколи:

EWP/35/E/2016-6, EWP/35/E/2016-7, EWP/35/E/2017-11, LA-
18.042/1, EWP/35/E/2018-15, EWP/57/E/2018-3,
ERGOM/08/01/2018, LA-18.042/2, ERGOM/06/12/2017,
ERGOM/07/12/2017, ERGOM/09/04/2018

Период на валидност:

от 18 февруари 2019 до 22 юли 2021

Правото за използване на сертификата за съответствие в срока му на валидност се прилага само за:

- тези образци, които отговарят на посочените по-горе изисквания и имат същите характеристики (параметри) като образците на модела / продукта, представени за изпитване,
- собственик на сертификат или негов упълномощен представител.

Списъкът на доказаните параметри е включен в приложенията към сертификата за съответствие.
Брой приложения: 1

**СИСТЕМАТА НА СЕРТИФИЦИРАНЕ НА ПРОДУКТА PC 1a (Програма 1a съгласно PN-EN ISO / IEC 17067: 2014-01)
(параметри на продукта, потвърдени от типово изпитване)**


Варшава, 2019.02.18

ДИРЕКТОР НА
ИНСТИТУТ ПО ЕНЕРГЕТИКА

на основание чл. 36а, ал. 3
от ЗОП

на основание чл. 36а, ал. 3
от ЗОП

dr hab. inż. Jerzy Przybylski prof. IEn



Handwritten mark resembling a stylized 'S' or '3'.

**ПРИЛОЖЕНИЕ КЪМ СЕРТИФИКАТ ЗА СЪОТВЕТСТВИЕ
 No. 071/2018
 Издание No 3 от 2019.02.18**

СПИСЪК НА ДОКАЗАНИТЕ ПАРАМЕТРИ

Параметър	KDR 10-240	KLD 10-240
Клас	A	A
Форма на медните кабели / проводници [mm ²]	rmv, rmc, rm / 10 ÷ 240	rmv, rmc, rm sm/ 10 ÷ 240
Първоначално разпръскване δ ¹⁾	≤ 0,30	≤ 0,30
Средно разпръскване β ²⁾	≤ 0,30	≤ 0,30
Коефициент на съпротивление λ ³⁾	≤ 2,0	≤ 2,0
Коефициент промяна на съпротивлението D ⁴⁾	≤ 0,15	≤ 0,15
Максимална температура θ _{max} ⁵⁾	≤ θ _{ref}	≤ θ _{ref}
Допустима сила на опън [N]	≤ 60xA ⁶⁾ Cu	≤ 60xA ⁶⁾ Cu

БЕЛЕЖКИ

- 1) ¹⁾ Средната стойност на коефициентите на съпротивление на шест съединителя (накрайници) преди първия топлинен цикъл.
- 2) ²⁾ Средната стойност на коефициентите на съпротивление на шест съединителя (накрайници), изчислени от последните 11 измервания. Определя дали всички конектори (накрайници) от даден тип се характеризират с подобни промени в съпротивлението по време на топлинните цикли.
- 3) ³⁾ Коефициент на съпротивление на изпитвания съединител (накрайник) по време на топлинния цикъл към началния коефициент на съпротивлението.
- 4) ⁴⁾ Стойността определя размера на промяната на коефициента на съпротивление въз основа на последните 11 измервания.
- 5) ⁵⁾ Температура на съединителя (накрайника), съпоставена към референтната температура.
- 6) ⁶⁾ Номинална площ на напречното сечение

Handwritten signature.

Official stamp of the Bureau of Technical Inspection (Бюрото за Технически Контрол) and a signature over it.

Валидно с оригинала
 Подпис:



AC 117

INSTYTUT ENERGETYKI

Research Institute

01-330 Warszawa, ul. Mory 8

tel. +48 22 34 51 299

fax. +48 22-836-63 63

instytut.energctyki@icn.com.pl

CERTIFICATE OF CONFORMITY

No. 071/2018

Issue No. 03 of 2019.02.18

Name and address of the Certificate Holder:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
10 Nowe Sady Str.,
94-102 Łódź, Poland

Name of the product:

Copper tubular cable lugs / butt connectors

Type:

KDR 10-240/ KLD 10-240

Manufacturer:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
10 Nowe Sady Str.,
94-102 Łódź, Poland

Parameters and application of the product:

According to appendix
Connection and termination of copper cables with class 2
conductors with parameters according to appendix

The product meets requirements of:

IEC 61238-1:2003 (ed. 2.0)

According to the reports made by:

Instytut Energetyki, ZAE ERGOM, SEP-BBJ

Number of the product evaluation reports:

DZC/186c/E/2016-5

Number of the test reports:

EWP/35/E/2016-6, EWP/35/E/2016-7, EWP/35/E/2017-11, LA-18.042/1,
EWP/35/E/2018-15, EWP/57/E/2018-3, ERGOM/08/01/2018, LA-18.042/2,
ERGOM/06/12/2017, ERGOM/07/12/2017, ERGOM/09/04/2018,

Period of validity:

from 18th of February 2019 until 22nd of July 2021

The right to use the certificate of conformity within its validity period applies only to:

- these copies that meet the requirements specified above and have the same characteristics (parameters) as the model / product samples submitted for testing,
- certificate owner or his authorized representative.

The list of evidenced parameters is included in the appendices to the certificate of conformity.

Number of appendices: 1

THE SYSTEM OF PRODUCT CERTIFICATION PC_1a (Program 1a acc. to PN-EN ISO/IEC 17067:2014-01)
(product parameters confirmed by type test)


на основании чл. 36а, ал. 3
от ЗОП

DIRECTOR OF
INSTYTUT ENERGETYKI

на основании чл. 36а, ал. 3
от ЗОП

dr hab. inż. Tomasz Gałka prof. IEn

Warsaw, 2019.02.18



AC 117

APPENDIX TO CERTIFICATE OF CONFORMITY**No. 071/2018****Issue No. 03 of 2019.02.18****LIST OF EVIDENCED PARAMETERS**

Element type	KDR 10-240	KLD 10-240
Class	A	A
Shape of Cu cables /conductors [mm ²]	rmv, rmc, rm, sm / 10 ÷ 240	rmv, rmc, rm, sm / 10 ÷ 240
Initial scatter $\delta^1)$	$\leq 0,30$	$\leq 0,30$
Mean scatter $\beta^2)$	$\leq 0,30$	$\leq 0,30$
Resistance factor ratio $\lambda^3)$	$\leq 2,0$	$\leq 2,0$
Change in resistance factor $D^4)$	$\leq 0,15$	$\leq 0,15$
Maximum temperature $\theta_{max}^5)$	$\leq \theta_{ref}$	$\leq \theta_{ref}$
Permissible tensile force [N]	$\leq 60xA^6) Cu$	$\leq 60xA^6) Cu$

NOTES:

- 1) The average value of the resistance factors of six connectors (lugs) before the first heating cycle.
- 2) The average value of the resistance factors of six connectors (lugs) calculated from last 11 measurements readings. It specifies if all connectors (lugs) of given type are characterized by similar changes in resistance during the heat cycles.
- 3) Resistance factor ratio of tested connector (lug) during the heat cycle test in relation to the initial resistance factor.
- 4) The value specifies the size of the resistance factor change based on last 11 measurements readings.
- 5) Temperature of the connector (lug) referenced to the temperature of the reference section.
- 6) Nominal cross-sectional area

СЕРТИФИКАТ ЗА СЪОТВЕТСТВИЕ

Номер на сертификата 20180822-E475284
Референтен номер на доклада E475284-20160920
Дата на издаване 2018-Август-22

Издаден на: Zaklad Aparatury Elektrycznej Ergom Sp. z o. o.
Nowe Sady 10
94-102 Лодз Полша

С настоящото се удостоверява, че представителни мостри от

КАБЕЛНИ КОНЕКТОРИ И ЩАНЦОВАНИ КАБЕЛНИ ОБУВКИ
Виж допълнителната страница

Бяха изследвани от UL в съответствие със Стандарт (и)
посочени в този Сертификат.

Стандарт (и) за безопасност:
Допълнителна информация:

UL 486A-486B, CSA C22.2 No. 65-13 - Wire Connectors
Вижте UL Директория за Онлайн Сертифициране на
www.ul.com/database за допълнителна информация


Само тези продукти, които носят UL сертификационната марка, трябва да се считат обхванати от UL Сертифициране и последващо обслужване.

Потърсете UL сертификационната марка на продукта.

Подпис: не се чете

Bruce Mahrenholz, Директор Северноамериканска програма за сертифициране
UL LLC

Всяка информация и документация, свързана с услугите на UL Mark, се предоставят от името на UL LLC (UL) или от лицензиант на UL. За въпроси, моля свържете се с местния представител на UL за обслужване на клиенти на адрес <http://ul.com/aboutul/locations/>



СЕРТИФИКАТ ЗА СЪОТВЕТВИЕ

Номер на сертификата 20180822-E475284
Референтен номер на доклада E475284-20160920
Дата на издаване 2018-Август-22

С настоящето се удостоверява, че представителните мостри от продукта както е посочено в настоящия сертификат са тествани съгласно настоящите изисквания на UL.

USL, CNL както следва, Неизолирани кабелни обувки за кербоване, Сери: K45R, K90R, KO, KW, CKOR, KL, KLD, KOR, KDR and CKL.

USL, CNL както следва, Неизолирани кабелни обувки за кербоване серии K45R (накрайници 45 °) включват следните модели №:

Кат. №: K45R 16/5, K45R 16/6, K45R 16/8, K45R 16/10, K45R 16/12, K45R 25/5, K45R 25/6, K45R 25/8, K45R 25/10, K45R 25/12, K45R 25/14, K45R 35/6, K45R 35/8, K45R 35/10, K45R 35/12, K45R 35/14, K45R 35/16, K45R 50/6, K45R 50/8, K45R 50/10, K45R 50/12, K45R 50/14, K45R 50/16, K45R 50/20, K45R 70/6, K45R 70/8, K45R 70/10, K45R 70/12, K45R 70/14, K45R 70/16, K45R 70/20, K45R 95/8, K45R 95/10, K45R 95/12, K45R 95/14, K45R 95/16, K45R 95/20, K45R 120/8, K45R 120/10, K45R 120/12, K45R 120/14, K45R 120/16, K45R 120/20, K45R 150/8, K45R 150/10, K45R 150/12, K45R 150/14, K45R 150/16, K45R 150/20, K45R 185/10, K45R 185/12, K45R 185/14, K45R 185/16, K45R 185/20, K45R 240/10, K45R 240/12, K45R 240/14, K45R 240/16, K45R 240/20.

USL, CNL както следва, Неизолирани кабелни обувки за кербоване серии K90R (накрайници 90 °) включват следните модели №:

Кат. №.: K90R 16/5, K90R 16/6, K90R 16/8, K90R 16/10, K90R 16/12, K90R 25/5, K90R 25/6, K90R 25/8, K90R 25/10, K90R 25/12, K90R 25/14, K90R 35/6, K90R 35/8, K90R 35/10, K90R 35/12, K90R 35/14, K90R 50/6, K90R 50/8, K90R 50/10, K90R 50/12, K90R 50/14, K90R 50/16, K90R 50/20, K90R 70/6, K90R 70/8, K90R 70/10, K90R 70/12, K90R 70/14, K90R 70/16, K90R 95/8, K90R 95/10, K90R 95/12, K90R 95/14, K90R 95/16, K90R 95/20, K90R 120/8, K90R 120/10, K90R 120/12, K90R 120/16, K90R 120/20, K90R 150/10, K90R 150/12, K90R 150/14, K90R 150/16, K90R 150/20, K90R 185/10, K90R 185/12, K90R 185/14, K90R 185/16, K90R 185/20, K90R 240/10, K90R 240/12, K90R 240/14, K90R 240/16, K90R 240/20.

USL, CNL както следва, Неизолирани кабелни обувки (щанцовани) серии KO включват следните модели №:

Кат. №: KO 1/2.5, KO 1/3, KO 1/3.5, KO 1/4, KO 1/5, KO 1/6, KO 1/8, KO 1/10, KO 16/5, KO 16/6, KO 16/8, KO 16/10, KO 25/5, KO 25/6, KO 25/8, KO 25/10, KO 35/6, KO 35/8, KO 35/10, KO 50/6, KO 50/8, KO 50/10, KO 70/6, KO 70/8, KO 70/10, KO 70/12, KO 95/8, KO 95/10, KO 95/12.

USL, CNL както следва, Неизолирани кабелни обувки серии KW (вилкови) включват следните модели №:

Кат. №: KW 1/2.5, KW 1/3, KW 1/3.5, KW 1/4, KW 1/4 W, KW 1/5, KW 1/6, KW 1/8, KW 1/10, KW 2.5/3, KW 2.5/3.5, KW 2.5/4, KW 2.5/4 W, KW 2.5/5, KW 2.5/6, KW 2.5/8, KW 2.5/10, KW 2.5/12, KW 6/3.5, KW 6/4, KW 6/5, KW 6/6, KW 6/8, KW 6/10, KW 10/5, KW 10/6, KW 10/8, KW 10/10, KW 16/5, KW 16/6, KW 16/8, KW 16/10.



USL, CNL както следва, Неизолирани кабелни обувки серии CKOR (прави) включват следните модели №:

Подпис: не се чете
Bruce Mahrenholz, Директор Северноамериканска програма за сертифициране
UL LLC

Всяка информация и документация, свързана с услугите на UL Mark, се предоставят от името на UL LLC (UL) или от лицензиант на UL. За въпроси, моля свържете се с местния представител на UL за обслужване на клиенти на адрес <http://ul.com/aboutul/locations/>.

ВАЖНО С ОРИГИНАЛА
Подпис:

СЕРТИФИКАТ ЗА СЪОТВЕТСТВИЕ

Номер на сертификата 20180822-E475284
Референтен номер на доклада E475284-20160920
Дата на издаване 2018-Август-22

Кат. №: CKOR 35/8, CKOR 35/10, CKOR 35/12, CKOR 50/8, CKOR 50/10, CKOR 50/12, CKOR 70/8, CKOR 70/10, CKOR 70/12, CKOR 70/16, CKOR 95/10, CKOR 95/12, CKOR 95/16, CKOR 120/10, CKOR 120/12, CKOR 120/16, CKOR 150/10, CKOR 150/12, CKOR 150/16, CKOR 150/20, CKOR 185/10, CKOR 185/12, CKOR 185/16, CKOR 185/20, CKOR 240/12, CKOR 240/16, CKOR 240/20.

USL, CNL както следва, Неизолирани кабелни гилзи серии CKL (Гилзи за свързване на кабели) включват следните модели №:

Кат. №: CKL 35, CKL 50, CKL 70, CKL 95, CKL 120, CKL 150, CKL 185, CKL 240.

USL, CNL както следва, Неизолирани кабелни гилзи серии CKL (Гилзи за свързване на кабели) включват следните модели №:

Кат. №: KL10, KL16, KL25, KL35, KL50, KL70, KL95, KL120, KL150, KL185, KL240.

USL, CNL както следва, Неизолирани кабелни обувки за кербоване серии KOR (Прави) включват следните модели №:

Кат. №: KOR0.75/3, KOR0.75/4, KOR0.75/5, KOR1.5/3, KOR1.5/4, KOR1.5/5, KOR1.5/6, KOR2.5/3, KOR2.5/4, KOR2.5/5, KOR2.5/6, KOR2.5/8, KOR4/4, KOR4/5, KOR4/6, KOR4/8, KOR6/4, KOR6/5, KOR6/6, KOR6/8, KOR6/10, KOR6/12, KOR10/5, KOR10/6, KOR10/8, KOR10/10, KOR10/12, KOR16/5, KOR16/6, KOR16/8, KOR16/10, KOR16/12, KOR25/5, KOR25/6, KOR25/8, KOR25/10, KOR25/12, KOR25/14, KOR35/5, KOR35/6, KOR35/8, KOR35/10, KOR35/12, KOR35/14, KOR35/16, KOR50/6, KOR50/8, KOR50/10, KOR50/12, KOR50/14, KOR50/16, KOR50/20, KOR70/6, KOR70/8, KOR70/10, KOR70/12, KOR70/14, KOR70/16, KOR70/20, KOR95/8, KOR95/10, KOR95/12, KOR95/14, KOR95/16, KOR95/20, KOR120/8, KOR120/10, KOR120/12, KOR120/14, KOR120/16, KOR120/20, KOR150/8, KOR150/10, KOR150/12, KOR150/14, KOR150/16, KOR150/20, KOR185/8, KOR185/10, KOR185/12, KOR185/14, KOR185/16, KOR185/20, KOR240/10, KOR240/12, KOR240/14, KOR240/16, KOR240/20.

Неизолирани кабелни гилзи за кербоване серии KLD (Гилзи за свързване на кабели) включват следните модели №:

Кат. №: KLD10, KLD16, KLD25, KLD35, KLD50, KLD70, KLD95, KLD120, KLD150, KLD185, KLD240.

Неизолирани кабелни обувки за кербоване серии KDR (Прави) включват следните модели №:

Кат. №: KDR10/5, KDR10/6, KDR10/8, KDR16/6, KDR16/8, KDR16/10, KDR16/12, KDR25/6, KDR25/8, KDR25/10, KDR25/12, KDR25/14, KDR25/16, KDR35/6, KDR35/8, KDR35/10, KDR35/12, KDR35/14, KDR35/16, KDR50/8, KDR50/10, KDR50/12, KDR50/14, KDR50/16, KDR70/8, KDR70/10, KDR70/12, KDR70/14, KDR70/16, KDR70/20, KDR95/8, KDR95/10, KDR95/12, KDR95/14, KDR95/16, KDR95/20, KDR120/10, KDR120/12, KDR120/14, KDR120/16, KDR120/20, KDR150/10, KDR150/12, KDR150/14, KDR150/16, KDR150/20, KDR185/10, KDR185/12, KDR185/14, KDR185/16, KDR185/20, KDR240/10, KDR240/12, KDR240/14, KDR240/16, KDR240/20.



Подпис: не се чете

Bruce Mahrenholz, Директор Северноамериканска програма за сертифициране
UL LLC

Всяка информация и документация, свързана с услугите на UL Mark, се предоставят от името на UL LLC (UL) или от лицензиант на UL. За въпроси, моля свържете се с местния представител на UL за обслужване на клиенти на адрес <http://ul.com/aboutul/locations/>

ВЪПРОС С ОРИГИНАЛ
Подпис:

CERTIFICATE OF COMPLIANCE

Certificate Number 20180822-E475284
Report Reference E475284-20160920
Issue Date 2018-August-22

Issued to: Zaklad Aparatury Elektrycznej Ergom Sp. z o. o.
Nowe Sady 10
94-102 Lodz POLAND

This is to certify that WIRE CONNECTORS AND SOLDERING LUGS
representative samples of See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 486A-486B, CSA C22.2 No. 65-13 - Wire Connectors
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.


Look for the UL Certification Mark on the product.

на основании чл. 36а, ал. 3
от ЗОП

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



ВЕРНО С СЕРТИФИКАТОМ
Подпись:

CERTIFICATE OF COMPLIANCE

Certificate Number 20180822-E475284
Report Reference E475284-20160920
Issue Date 2018-August-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL Listed, Non-insulated Crimp type Wire Connectors, Series: K45R, K90R, KO, KW, CKOR, KL, KLD, KOR, KDR and CKL.

USL, CNL Listed, Non-insulated crimp type wire connector series K45R (Angled-45 degree wire connectors) includes the following model no(s):

Cat. Nos.: K45R 16/5, K45R 16/6, K45R 16/8, K45R 16/10, K45R 16/12, K45R 25/5, K45R 25/6, K45R 25/8, K45R 25/10, K45R 25/12, K45R 25/14, K45R 35/6, K45R 35/8, K45R 35/10, K45R 35/12, K45R 35/14, K45R 35/16, K45R 50/6, K45R 50/8, K45R 50/10, K45R 50/12, K45R 50/14, K45R 50/16, K45R 50/20, K45R 70/6, K45R 70/8, K45R 70/10, K45R 70/12, K45R 70/14, K45R 70/16, K45R 70/20, K45R 95/8, K45R 95/10, K45R 95/12, K45R 95/14, K45R 95/16, K45R 95/20, K45R 120/8, K45R 120/10, K45R 120/12, K45R 120/14, K45R 120/16, K45R 120/20, K45R 150/8, K45R 150/10, K45R 150/12, K45R 150/14, K45R 150/16, K45R 150/20, K45R 185/10, K45R 185/12, K45R 185/14, K45R 185/16, K45R 185/20, K45R 240/10, K45R 240/12, K45R 240/14, K45R 240/16, K45R 240/20.

USL, CNL Listed, Non-insulated crimp type wire connector series K90R (Angled-90 degree wire connectors) includes the following model no(s):

Cat. Nos.: K90R 16/5, K90R 16/6, K90R 16/8, K90R 16/10, K90R 16/12, K90R 25/5, K90R 25/6, K90R 25/8, K90R 25/10, K90R 25/12, K90R 25/14, K90R 35/6, K90R 35/8, K90R 35/10, K90R 35/12, K90R 35/14, K90R 50/6, K90R 50/8, K90R 50/10, K90R 50/12, K90R 50/14, K90R 50/16, K90R 50/20, K90R 70/6, K90R 70/8, K90R 70/10, K90R 70/12, K90R 70/14, K90R 70/16, K90R 95/8, K90R 95/10, K90R 95/12, K90R 95/14, K90R 95/16, K90R 95/20, K90R 120/8, K90R 120/10, K90R 120/12, K90R 120/16, K90R 120/20, K90R 150/10, K90R 150/12, K90R 150/14, K90R 150/16, K90R 150/20, K90R 185/10, K90R 185/12, K90R 185/14, K90R 185/16, K90R 185/20, K90R 240/10, K90R 240/12, K90R 240/14, K90R 240/16, K90R 240/20.

USL, CNL Listed, Non-insulated crimp type wire connector series KO (Straight/Ring wire connectors) includes the following model no(s):

Cat. Nos.: KO 1/2.5, KO 1/3, KO 1/3.5, KO 1/4, KO 1/5, KO 1/6, KO 1/8, KO 1/10, KO 16/5, KO 16/6, KO 16/8, KO 16/10, KO 25/5, KO 25/6, KO 25/8, KO 25/10, KO 35/6, KO 35/8, KO 35/10, KO 50/6, KO 50/8, KO 50/10, KO 70/6, KO 70/8, KO 70/10, KO 70/12, KO 95/8, KO 95/10, KO 95/12.

USL, CNL Listed, Non-insulated crimp type wire connector series KW (Fork wire connectors) includes the following model no(s):

Cat. Nos.: KW 1/2.5, KW 1/3, KW 1/3.5, KW 1/4, KW 1/4 W, KW 1/5, KW 1/6, KW 1/8, KW 1/10, KW 2.5/3, KW 2.5/3.5, KW 2.5/4, KW 2.5/4 W, KW 2.5/5, KW 2.5/6, KW 2.5/8, KW 2.5/10, KW 2.5/12, KW 6/3.5, KW 6/4, KW 6/5, KW 6/6, KW 6/8, KW 6/10, KW 10/5, KW 10/6, KW 10/8, KW 10/10, KW 16/5, KW 16/6, KW 16/8, KW 16/10.


USL, CNL Listed, Non-insulated crimp type wire connector series CKOR (Straight wire connectors) includes the following model no(s):

На основании чл. 36а, ал. 3
от ЗОП

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) for any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180822-E475284
Report Reference E475284-20160920
Issue Date 2018-August-22

Cat. Nos.: CKOR 35/8, CKOR 35/10, CKOR 35/12, CKOR 50/8, CKOR 50/10, CKOR 50/12, CKOR 70/8, CKOR 70/10, CKOR 70/12, CKOR 70/16, CKOR 95/10, CKOR 95/12, CKOR 95/16, CKOR 120/10, CKOR 120/12, CKOR 120/16, CKOR 150/10, CKOR 150/12, CKOR 150/16, CKOR 150/20, CKOR 185/10, CKOR 185/12, CKOR 185/16, CKOR 185/20, CKOR 240/12, CKOR 240/16, CKOR 240/20.

USL, CNL Listed, Non-insulated crimp type wire connector series CKL (Splicing wire connector) includes the following model no(s):

Cat. Nos.: CKL 35, CKL 50, CKL 70, CKL 95, CKL 120, CKL 150, CKL 185, CKL 240.

USL, CNL Listed, Non-insulated crimp type wire connector series KL (Splicing wire connector) includes the following model no(s):

Cat. Nos.: KL10, KL16, KL25, KL35, KL50, KL70, KL95, KL120, KL150, KL185, KL240.

USL, CNL Listed, Non-insulated crimp type wire connector series KOR (Straight wire connectors) includes the following model no(s):

Cat. Nos.: KOR0.75/3, KOR0.75/4, KOR0.75/5, KOR1.5/3, KOR1.5/4, KOR1.5/5, KOR1.5/6, KOR2.5/3, KOR2.5/4, KOR2.5/5, KOR2.5/6, KOR2.5/8, KOR4/4, KOR4/5, KOR4/6, KOR4/8, KOR6/4, KOR6/5, KOR6/6, KOR6/8, KOR6/10, KOR6/12, KOR10/5, KOR10/6, KOR10/8, KOR10/10, KOR10/12, KOR16/5, KOR16/6, KOR16/8, KOR16/10, KOR16/12, KOR25/5, KOR25/6, KOR25/8, KOR25/10, KOR25/12, KOR25/14, KOR35/5, KOR35/6, KOR35/8, KOR35/10, KOR35/12, KOR35/14, KOR35/16, KOR50/6, KOR50/8, KOR50/10, KOR50/12, KOR50/14, KOR50/16, KOR50/20, KOR70/6, KOR70/8, KOR70/10, KOR70/12, KOR70/14, KOR70/16, KOR70/20, KOR95/8, KOR95/10, KOR95/12, KOR95/14, KOR95/16, KOR95/20, KOR120/8, KOR120/10, KOR120/12, KOR120/14, KOR120/16, KOR120/20, KOR150/8, KOR150/10, KOR150/12, KOR150/14, KOR150/16, KOR150/20, KOR185/8, KOR185/10, KOR185/12, KOR185/14, KOR185/16, KOR185/20, KOR240/10, KOR240/12, KOR240/14, KOR240/16, KOR240/20.

Non-insulated crimp type wire connector series KLD (Splicing wire connector) includes the following model no(s):

Cat. Nos.: KLD10, KLD16, KLD25, KLD35, KLD50, KLD70, KLD95, KLD120, KLD150, KLD185, KLD240.

Non-insulated crimp type wire connector series KDR (Straight wire connectors) includes the following model no(s):


Cat. Nos.: KDR10/5, KDR10/6, KDR10/8, KDR16/6, KDR16/8, KDR16/10, KDR16/12, KDR25/6, KDR25/8, KDR25/10, KDR25/12, KDR25/14, KDR25/16, KDR35/6, KDR35/8, KDR35/10, KDR35/12, KDR35/14, KDR35/16, KDR50/8, KDR50/10, KDR50/12, KDR50/14, KDR50/16, KDR70/8, KDR70/10, KDR70/12, KDR70/14, KDR70/16, KDR70/20, KDR95/8, KDR95/10, KDR95/12, KDR95/14, KDR95/16, KDR95/20, KDR120/10, KDR120/12, KDR120/14, KDR120/16, KDR120/20, KDR150/10, KDR150/12, KDR150/14, KDR150/16, KDR150/20, KDR185/10, KDR185/12, KDR185/14, KDR185/16, KDR185/20, KDR240/10, KDR240/12, KDR240/14, KDR240/16, KDR240/20.

На основании чл. 36а, ал. 3
от ЗОП

Bruce Mehrenholz, Director North American Certification Program

UL LLC


Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>





ERGOM Z.A.E. Sp. z o. o.
Nowe Sady 10 Str., 94-102 Lodz, Poland
(+48)42 689 33 86
export@ergom.com

Превод от английски език



Лодз, 2018-01-12

Сертификат за качество № 03/2018

Отнася се до: Якост на опън на кабелни обувки

С настоящото декларираме, че предлаганите от Ergom медни кабелни обувки се произвеждат в съответствие с изискванията на норма EN61238-1 и притежават следната якост на опън:

1. Напречено сечение 150 мм² – 900 daN
2. Напречено сечение 185 мм² - 1100 daN
3. Напречено сечение 240 мм² - 1440 daN
4. Напречено сечение 300 мм² - 1800 daN
5. Напречено сечение 400 мм² - 2400 daN

Dział Kontroli Jakości
Specjalistyczny Zakład

на основание чл. 36а, ал. 3
от ЗОП

Ръководител отдел Контрол на качеството

WIRING ACCESSORIES
CABLE TCABLE TERMINALS
TOOLS FOR ELECTRICIANS
ENCLOSURES AND SWITCHGEARS



VAT: PL7260129071, Regan: 473076927, KRS: 0000132427
Sąd Rejonowy dla m. st. Łodzi - Sąd Gospodarczy, XX Wydział Krajowego Rejestru Sądowego
Initial Capital ERGOM Z.A.E. : 1 0.400.000,00 PLN
Bank Zachodni WBK SA II/O Lodz, BIC: WBK PPLPP, IBAN: PL 16 1090 1304 0000 0000 3034 8970

ВЯНО С ОРИ
Подпис:



Łódź 2018-01-12

Quality certificate no. 03/2018

Refers to: Tensile breaking strength of cable terminals

We hereby declare, that the offered by Ergom copper cable terminals are produced in compliant with requirements of norm EN61238-1 and have the following breaking forces:

1. Cross section 150 mm² – 900 daN
2. Cross section 185 mm² – 1100 daN
3. Cross section 240 mm² – 1440 daN
4. Cross section 300 mm² – 1800 daN
5. Cross section 400 mm² – 2400 daN

Quality control dept. manager.

Dział Kontroli Jakości




на основании чл. 36а, ал. 3
от ЗОП



AKCESORIA DO OKABLOWANIA
KOŃCÓWKI KABLOWE
NARZĘDZIA DLA ELEKTRYKÓW
ROZDZIELNICE I OBUDOWY



BRONIA S. C. SP. z o.o.
NIP: 726 01-29-071, Regon: 173076927, KRS: 0000132427
Sąd Rejonowy dla Łodzi - Śródmieście w Łodzi, XX Wydział Krajowego Rejestru Sądowego
Kapitał Zakładowy ZAE ERGOM: 10.400.000,00 zł
Konto bankowe: Bank Zachodni WBK S.A. II O/Łódź 39 1090 1904 0000 0000 3000 5564


Приложение 2 към Техническо предложение**За обособена позиция № 2:****„Доставка на арматура за проводници (кабелни обувки, съединители и накрайници)“****ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 9**

2 ERGOM

Технология за кримпване на алуминиеви кабелни обувки

Изработени като: пръстеновидни обувки, прави, стегнати (тип KRA съгласно Ergom) съгласно DIN 46329; гилзи. При останалите обувки (с изключение на KLA, 2KAm, 2ZA, KLAN) DIN размерите се отнасят само за тръбната част на обувката. Те са изработени като: изправени, пръстовидни обувки (KRA; KRAS; KDA; KDA../2X; 2KAm; тип KA съгласно Ergom); гилзи (LA; LAS; LAD; LAP; LAW; LAWП; KLAN; ZLA; 2ZA тип съгласно Ergom); редуциращи конектори (LA../...; LAP../...; LAWП../...; LAW../... тип съгласно Ergom); кабелен накрайник (BAW; BAK).

Материали: всеки видове - E-Al алуминиева тръба съгласно с DIN 40501 Teil 3 or DIN 1712 Teil 2.

Покритие: без покритие или поцинковани (по заявка).


Приложение:

Изправените, пръстовидни обувки се използват за свързване на кабелна връзка на винтово съединение към шина, комутационна апаратура и др. Гилзите се използват за свързване на два алуминиеви проводника с еднакво напречно сечение (LA, LAS, LAP, LAWП, KLAN, ZLA, KLA, 2ZA) или за свързване на два алуминиеви проводника с различно напречно сечение (LA../...; LAP../...; LAWП../...; LAW../...). Гилзите направени с тези конектри (с изключение на 2ZA, KLA, KLAN, ZLA) не могат да бъдат механично свързани. Алуминиевите кабелни накрайници (BAW, BAK) се използват за свързване на жица с гилзата.

Технология за кримпване:

Обувките се навиват с инструменти, които са неречни "шестоъгълни" кримпващи клещи.

Благодарение на компресираща форма на гилзата се постига връзка с високи механични и електрически параметри. Въпреки това, такива се нуждаят от компресиране на обувката. Колкото повече е броят на компресиите, толкова по-добре е за гилзата. Много важно в случай на силови връзки, при които се изисква предаване на големи мощности и ток. "Шестоъгълната" компресия се нуждае от още по-голяма сила, за да се навива обувката. Така че при такава компресия (дори при малка напречна секция) ZAE ERGOM препоръчва използването на хидравлични инструменти или ръчни инструменти с по-високо механично съотношение. За да се постигне гилзата необходимото качество, се препоръчва да се компресират обувките на "шестоъгълника" по следния начин:




много гилзи

Благодарение на компресираща форма на гилзата се постига връзка с високи механични и електрически параметри. Въпреки това, такива се нуждаят от компресиране на обувката. Колкото повече е броят на компресиите, толкова по-добре е за гилзата.

Много важно в случай на силови връзки, при които се изисква предаване на големи мощности и ток. "Шестоъгълната" компресия се нуждае от още по-голяма сила, за да се навива обувката. Така че при такава компресия (дори при малка напречна секция) ZAE ERGOM препоръчва използването на хидравлични инструменти или ръчни инструменти с по-високо механично съотношение. За да се постигне гилзата необходимото качество, се препоръчва да се компресират обувките на "шестоъгълника" по следния начин:




Правилната посока и последователност на притискане на обувката са маркирани със стрелки.




1. Първи натиск (вътрешен)



2. Втори натиск (отвътре навън)




3. Първи натиск от другата страна (вътрешен)



4. Втори натиск от другата страна (отвътре навън)




1. First compression (inside)



2. Втори натиск (отвътре навън)

Всяка обувка е означена с маркировка и е напечатана:

- напречно сечение или диаметър на отвора на винта (в случай на пръстовидни обувки)
- трябва да се постави номер на седалката преди да се навие обувката
- графичен код за броя и позицията на необходимите компресии направени с тесни удари (ръчни инструменти) или широки удар (хидравлични инструменти).



Пример за подобен код е даден по-долу.

1. Търговска марка.
2. Номер.
3. Маркиране на мястото и броя повторения на натиск.
- 3а. Механично: тясно.
- 3б. Хидравлично: широко.
4. Код на кабелите (напречно сечение и профил).

[Handwritten signature]

[Handwritten signature]



ВЕРНО С ОРЪЖИЯТА
Подпис:

Всичко маркирано е препоръчително да бъде кримпнато. Моля, обърнете внимание, че трябва да използвате правилната матрица за напречното сечение, за която е проектирана.


Types of cable wires




Кръгъл многожичен кабел (rm)



Кръгъл проводник (re)




Разделен многожичен (sm)



Разделен проводник

Секторните проводници трябва да бъдат заоблени със специални матрици.
www.ergom.com



ВЕРНО С ОРИГИНАЛ
 Подпис:

Crimping technology for tubular terminals and butt connectors

Made as: straight ring terminals (KDR type acc. to Ergom) in accordance with DIN 46235 and connecting terminals (KLD acc. to Ergom type), in accordance with DIN 46267. In remaining terminals the DIN dimensions refer only to the tubular part of terminal. They are made as: straight ring terminals (KDR.../2X; KRM type acc. to Ergom) and angle ring terminals (K90D; KPD type acc. to Ergom); butt connectors (KLD; LMP; LMW; LMWP type acc. to Ergom); reduction connectors (LMP.../...; LMWP.../... type acc. to Ergom); pin terminals (BMW; BMK type acc. to Ergom).

Materials: all types – E-Cu copper tube acc. to DIN 40500 Teil 2, 3 or DIN 1787.


Surface: KDR; KDR .../x2; K90D; K45D; KRM; KLD; LMWP – tin-plated.
KPD; LMP; LMP.../...; LMW; LMWP; HMR; BMW; BMK – not tin-plated.

Application:

Straight and angle ring terminals are used for connecting wire by use of screw joint to bus-bar, switchgear, etc. Tubular connectors are used to join two wires of the same cross-section to contact (KLD, LMP, LMW, LMWP) or to joint two wires of different cross-section (LMP.../...; LMWP.../...). This join (except KLD) cannot be stressed mechanically. Copper pin terminals (BMW, BMK) are used for connecting wire with screw joint.


Crimping technology:

Terminals are crimped using tools with so called "hexagon" Crimping dies.




Thanks to such compressing shape joint with very high mechanical and electrical parameters is achieved. However, such joints need several compressions of terminal. The higher compression number the better the joint is.

It is very important in case of power joints where transmission of large power and currents is required. The "hexagon" compression needs still considerable force to crimp a terminal, so in case of such compression (even small wire cross-section) ZAE ERGOM recommends use of hydraulic tools or hand-tools with higher mechanical ratio (operated with both hands). In order to achieve joint of required quality it is recommended to compress terminals to "hexagon" in the following way:



Correct direction and sequence of terminal compressions are marked with arrows.




1. First compression (inside)




2. Further compression (from inside to outside)



3. First compression on the other side (inside)




4. Further compressions on the other side (from inside to outside)



1. First compression (inside)



2. Further compression (from inside to outside)



There is marking stamped or overprinted on every terminal to indicate:
 – terminal cross-section or screw hole diameter (In case of ring terminals)
 – die seat No. to crimp a terminal
 – graphic code of number and position of compressions required, made with narrow dies (hand tools) or wide dies (hydraulic tools).

An example of such code is given below.

1. Trade mark.
2. Die seat No.
3. Marking of place and number of compressions.
 - 3a. Mechanic: narrow die.
 - 3b. Hydraulic: wide die.
4. Code of cable types (cross-section and profile).

All marked (recommended) crimping must be made. Please pay attention to use proper die for cross-section to which it is designed.


Types of cable wires




round multiwire
(rm)



round one-wire
(re)







sectored multiwire
(sm)



sectored one-wire
(se)


Sector shaped conductors must be rounded with special dies.



Приложение 2 към Техническо предложение**За обособена позиция № 2:****„Доставка на арматура за проводници (кабелни обувки, съединители и накрайници)“****ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 10**

Handwritten signature and circular stamp. The stamp contains the text "ФИЛКАБ АД" and "ПЛОДДИВ" and is partially obscured by a signature.

Non-tension compression joints LA ... type



Material Al.
Surface uncoated.
Design DIN 46267/2 refers only to tubular part of terminal.
Napięcie 1÷10 kV.

Note!
 - L A terminals are filled with special contact grease and packed in foil;
 - L A...BS - without contact grease;
 - sector shaped conductors must be rounded with special dies.

contact grease		without contact grease		Cross section [mm ²]		Dimension [mm]			Crimping			Pkg	kg
Type	Item No.	Type	Item No.	mm /sm	re / se	L	d	D	Die code No.	Nc/w	Nc/n		
LA 10	E12KA-01100100100	LA 10 BS	E12KA-01100200100	10	16	55	5,0	10,0	10	1-1	3-3	100	1,06
LA 16	E12KA-01100100200	LA 16 BS	E12KA-01100200200	16	25	55	5,6	12,0	12	1-1	3-3	100	1,50
LA 25	E12KA-01100100300	LA 25 BS	E12KA-01100200300	25	35	70	6,8	12,0	12	2-2	4-4	100	1,63
LA 35	E12KA-01100100400	LA 35 BS	E12KA-01100200400	35	50	85	8,0	14,0	14	2-2	5-5	100	2,63
LA 50	E12KA-01100100500	LA 50 BS	E12KA-01100200500	50	70	85	9,8	16,0	16	2-2	5-5	100	3,35
LA 70	E12KA-01100100600	LA 70 BS	E12KA-01100200600	70	95	105	11,2	18,5	18	3-3	6-6	100	5,20
LA 95	E12KA-01100100750	LA 95 BS	E12KA-01100200750	95	120	105	13,2	22,0	22	3-3	6-6	50	3,70
LA 120	E12KA-01100100850	LA 120 BS	E12KA-01100200850	120	150	105	14,7	23,0	22	3-3	6-6	50	3,90
LA 150	E12KA-01100100900	LA 150 BS	E12KA-01100200900	150	185	125	16,3	25,0	25	3-3	7-7	50	4,75
LA 185	E12KA-01100101000	LA 185 BS	E12KA-01100201000	185	240	125	18,3	28,5	28	3-3	7-7	50	7,90
LA 240	E12KA-01100101100	LA 240 BS	E12KA-01100201100	240	300	145	21,0	32,0	32	3-3	8-8	50	9,30
LA 300	E12KA-01100101200	LA 300 BS	E12KA-01100201200	300	-	145	23,3	34,0	34	3-3	-	25	5,00
LA 400	E12KA-01100101300	LA 400 BS	E12KA-01100201300	400	-	210	26,0	38,5	38	4-4	-	25	9,30
LA 500	E12KA-01100101400	LA 500 BS	E12KA-01100201400	500	-	210	29,0	44,0	44	4-4	-	25	12,50
LA 625	E12KA-01100101501	LA 625 BS	E12KA-01100201501	625	-	330	35,0	52,0	52	5-5	-	25	12,27
LA 800	E12KA-01100101601	LA 800 BS	E12KA-01100201601	800	-	350	40,0	58,0	58	5-5	-	25	15,00
LA 1000	E12KA-01100101701	LA 1000 BS	E12KA-01100201701	1000	-	350	44,0	60,0	60	5-5	-	25	14,20


Nc/w = No. of crimping wide | Nc/n = No. of crimping narrow


Technologia zaciskania końcówek i łączników rurowych Al %s

Dedykowane praski ręczne i hydrauliczne %s

Приложение 2 към Техническо предложениеЗа обособена позиция № 2:

„Доставка на арматура за проводници (кабелни обвивки, съединители и накрайници)“

ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ**Приложение 11**





since 1933

ASSOCIATION of POLISH ELECTRICIANS
QUALITY TESTING OFFICE
ul. M. Pożaryskiego 28, 04-703 Warszawa, Poland

tel./fax: +48 22 815 65 80

TESTING LABORATORY



AB 044



TEST REPORT


PN-EN 61238-1

Compression and mechanical connectors for power cables for rated
voltages up 36 kV ($U_m = 42$ kV)


Part 1: Test methods and requirements (IEC 61238-1:2003, modified)

Report Reference No.	LA-18.012/2/E	
Data of issue	2018-03-30	
Total number of pages	14	
Tested by	Krzysztof Podgórnjak (name + position + signature) Specialist	на основании чл. 36а, ал. 3 от ЗОП
Authorized by	Dariusz Szczepanowski (name + position + signature) Manager of LA	
Testing application number	B-A-18-012	
Test item reference	B-A-18-012	
Scope of test	<input checked="" type="checkbox"/> - type test	<input type="checkbox"/> - partial test
Test specification:		
Standard/procedure	<input checked="" type="checkbox"/> PN-EN 61238-1:2004, EN 61238-1:2003, IEC 61238-1:2003 (Second Edition)	
Non-standard test methods	N/A	
Non-accredited test methods	N/A	
Applicant's name	Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o.	
Address	ul. Nowe Sady 10, 94-102 Łódź	

The BBJ test report form is not permitted for commercial purposes
without written approval of the BBJ Testing Laboratory



ВЕРНО О СМЕРТНА
Подпис:



Test item description		Aluminium through connector
Trade Mark		
Manufacturer		Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o. ul. Nowe Sady 10, 94-102 Łódź
Model/Typ reference		LAC 16
Ratings		Nominal cross-sectional area: 16 mm ²
List of Attachments:		
Attachment No.	Attachment No.	Attachment No.
1	Summary of the test result	1
2	Product information and photos of samples	4
3	List of the equipment used for the test	1
Summary of testing:		
Test performer (in the case of partial tests): N/A		Testing location/address (if different from page 1) : Stowarzyszenie Elektryków Polskich, Biuro Badawcze ds. Jakości Association of Polish Electrician, Quality Testing Office ul. M. Rapackiego 13, 20-150 Lublin, POLAND
Number of tests with F (Fail) verdict:		0
Summary conformity/non-conformity with standardization document (if apply):		N/A
Summary of compliance with National Differences (if apply): Provide list of standards.		N/A
Opinion and interpretation if needed:		N/A
Other additional information (as requested by the applicant):		N/A
Copy of marking plate:		
 LAC 16		

Handwritten signature

Handwritten signature



I-POB-07/01-Z3w9

ВЕРНО С СЧЕТА
Подпись:

Handwritten signature



Test item particular:	
Classification of installation and use	: N/A
Supply Connection	: N/A
Date (s) of receipt of test item	: 2018-01-29 (Sample No. 1.1...1.19, 11.1...11.10)
Date (s) of performance of tests	: 2018-02-01...2018-03-29
Possible test case verdicts:	
- test case does not apply to the test object	: N/A
- test object does meet the requirement	: P (Pass)
- test object does not meet the requirement	: F (Fail)
Test report general remarks:	
1. The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.	
2. "(See Enclosure #)" refers to additional information appended to the report..	
3. "(See appended table)" refers to a table appended to the report	
4. Throughout this report a comma is used as the decimal separator.	
5. Test Report Form is based on TRF No.: IEC61238_1A, copyrighted by IECCE.	
Production place(s)	Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o. ul. Nowe Sady 10, 94-102 Łódź
General product information:	
Tests were carried out on samples of aluminium through connectors type LAC, nominal cross sectional area 16 mm ² .	
Manual hydraulic presses HK 22 C with hexagonal die KP22-12 was used to crimp testing through connectors LAC 16. Hexagonal die KP22-12 is dedicated to aluminium terminals with a DIN-conforming tubular part (size DIN 12) for crimping cables RMC/RMV.	
Cable AsXSn 2x16 mm ² RMC 0,6/1kV, manufacturer NKT Cables was used to electrical and mechanical tests of through connectors LAC 16.	
Samples were marked for the tests as B-A-18-012/1.1...1.19 and B-A-18-012/11.1...11.10. In the Test Report abbreviated marking of the samples, as the samples No. 1.1...1.19, 11.1...11.10 were used.	
Type:	No.:
KDAC 16/8	1.1...1.19
LAC 16	11.1...11.10

TRF No. IEC61238_1A



ВЕРНО С ОФИЦИАЛЬНОЙ ПОДПИСЬЮ
Подпись:



PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Identification			—
	Connector		—
	Type of connector	<input checked="" type="checkbox"/> through connector <input type="checkbox"/> branch connector <input type="checkbox"/> terminal lug	—
	Nominal cross-sectional area	16 mm ²	—
	Class of connector	<input checked="" type="checkbox"/> Class A <input type="checkbox"/> Class B	—
5.1	Conductor		—
	conductor material	Al	—
	nominal cross-sectional area	16 mm ² RMC	—
	actual conductor area	16 mm ² RMC	—
	leading dimensions and shape	Unprepared cable	—
	type of conductor (solid or stranded).....	16 mm ² - stranded	—
	details of conductor construction (in the case of stranded conductors).....	16 mm ² – stranded cable, round, 7 wires	—
	compacted / non-compacted	Compacted	—
	flexible	No	—
	number of wires	7 wires	—
	direction of lay	Right	—
	plating	No plating	—
	type of impregnation, if any	—	—
	approximate indication of hardness (annealed, half-hard, hard)	Hard	—
	type of insulation (in case of insulation-piercing connectors)	—	—
5.2	Connectors and tooling		—
	assembly technique	Crimp connection	—
	tooling and necessary settings	Manual hydraulic presses HK 22 C with hexagonal die KP22-12. Hexagonal die KP22-12 is dedicated to aluminium terminals with a DIN-conforming tubular part for crimping cables RMC/RMV. Size DIN 12	—
	preparation of contact surfaces	Through connector filled with contact grease	—


TRF No. IEC61238_1A



Подпись:



PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
	type, reference number and other identification of the connector	LAC 16: surface: tin-plated; material: Al	—
6	Electrical tests		P
6.1	Installation		P
	six connectors fitted in accordance with the manufacturer's instructions		P
	welded equalizers used	Yes	P
	in case of insulation-piercing connectors, the insulation retained on the conductor under the connector, and for a distance of at least 100 mm outside the connector		N/A
	ambient temperature of the test location (between 15 °C and 30 °C)	19 °C...23 °C	P
	the test loop is dismantlable for short-circuit test (class A connectors only)		N/A
	the technology of the sectioning joints do not influence the measurements		N/A
	bolts or screws of the connectors were not retightened under test		N/A
6.1.1	Through connectors and terminal lugs		—
	test loop and dimensions according to Figure 1	See Attachment No. 2	P
	linking bars used (in case of terminal lugs)		N/A
	the palms bolted to the linking bars in accordance with the manufacturer's instructions		N/A
	linking bars have the same dimensions and material as the palm		N/A
	palm connected direct to palm		N/A
6.1.2	Branch connectors		—
	branch connector is treated as a through connector between the main and the branch (size of branch cable equal to the main, or immediately above or below the main)		N/A
	In other cases, test loop and dimensions according to Figure 2		N/A
6.2	Measurements		P
6.2.1	Electrical resistance measurements		P
	measurements made at stages throughout the test as specified in 6.3		P






PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
	method used	<input checked="" type="checkbox"/> indirect <input type="checkbox"/> direct	—
	indirect method: measuring current is 10 % of the heat cycling current	LAC 16: 10 A + 11 A	P
	potential points as indicated in Figure 3 and annex B		P
	Precision of resistance measurements, indirect method		—
	voltage: max. $\pm 0,5\%$ or $\pm 10\ \mu\text{V}$, actual precision	$\pm 0,5\%$	P
	current: max. $\pm 0,5\%$ or $\pm 0,1\ \text{A}$, actual precision	$\pm 0,5\%$	P
	Precision of resistance measurements, direct method: better than $\pm 1\%$ or $\pm 0,5\ \mu\Omega$, actual precision	—	N/A
6.2.2	Temperature measurements		P
	stages as specified in 6.3		P
	the temperature of connectors and reference conductor measured at the points as indicated in Figure 3	Figure 3a, 3b	P
	thermocouples used as reference method	Yes	P
	total accuracy of temperature measurements: $\pm 2\ \text{°C}$ or better, actual accuracy	$\pm 2,0\ \text{°C}$	P

6.3	Heat cycle test		P
	power frequency current used	AC 50 Hz	P
6.3.1	First heat cycle		—
6.3.1 a)	Non insulation-piercing through connectors and terminal lugs	Sample No. 11.1...11.6	P
	current is circulated in the test loop, bringing the reference conductor to $120\ \text{°C}$ at equilibrium		N/A
	measured temperature of the median connector ...:	Sample No. 11.1: $102,2\ \text{°C}$	—
	reference conductor temperature ($120\ \text{°C} \leq \Theta_R \leq 140\ \text{°C}$)	$138,6\ \text{°C}$	—
	equilibrium current I_N	122 A	—
6.3.1 b)	Non insulation-piercing branch connectors		N/A
	test circuit according to	<input type="checkbox"/> Figure 1 <input type="checkbox"/> Figure 2	—
	current is circulated in the test loop, bringing the reference conductor to $120\ \text{°C}$ at equilibrium		N/A

TRF No. IEC61238_1A



ВЕРНО С ОПТИМАЛ
Подпис:



PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
	current in all individual branch adjusted so that each branch reference temperature is the same as the main reference temperature		N/A
	measured temperature of the median connector :		—
	reference conductor temperature (120 °C ≤ Θ_R ≤ 140 °C)..... :		—
	equilibrium current I_N :		—
6.3.1 c)	Insulation-piercing connectors (IPC)		N/A
	test circuit according to	<input type="checkbox"/> Figure 1 <input type="checkbox"/> Figure 2	—
	isolated reference conductor used		N/A
	permitted temperature of the cable :		—
	temperature of the median connector is set 10 K above permitted temperature of the cable		N/A
	measured temperature of the median connector :		—
	temperature of the reference conductor(s) is(are) set max.15 K above permitted temperature of the cable		N/A
	temperature of the isolated reference conductor(s) at equilibrium :		N/A
	equilibrium current I_N :		—
6.3.2	Second heat cycle	Sample No. 11.1...11.6	—
	current is circulated in the loop until the main reference conductor temperature reaches the value Θ_R determined in 6.3.1 with a tolerance of +6 °C	138 °C + 144 °C	P
	the median connector temperature is stable within 2 °C over a 10 min period		P
	current flow time (t_1) :	33 min	—
	accelerated heating used	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	—
	accelerated heating time :	—	—
	accelerated heating time according to Table 1		N/A
	cooling time (t_2) :	6 min	—
	After cooling, the temperature of all connectors and the reference conductor ≤ 35 °C		P
	accelerated cooling used with ambient air	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	—
6.3.3	Subsequent heat cycles	Sample No. 11.1...11.6	—
	a total of 1000 heat cycles performed		P
	Measurements performed at the following cycles:		P
	Class A: 0, 200 (before and after short-circuit test), 250, then every 75		P

TRF No. IEC61238_1A




PN-EN 61238-1			
Clause	Requirement – Test	Result - Remark	Verdict

	Class B: 0, 250, then every 75		N/A
	cold resistance and temperature of each connector and reference conductor/conductors measured	See TABLE 1	P
	maximum temperature of each connector measured	See TABLE 2	P
6.3.4	Short-circuit tests (for Class A connectors only)	Sample No. 11.1...11.6	P
	six short circuits applied after the 200th heat cycle		P
	short-circuit current	1,59 kA + 1,60 kA	—
	short-circuit current raises the reference conductors from a temperature of ≤ 35 °C to a temperature between 250 °C and 270 °C		P
	measured temperature of the reference conductor:	251,5 °C + 255,0 °C	P
	duration of the short-circuit current (1 s below 25 kA, ≤ 5 s above 25 kA)	1,39 s + 1,40 s	P
	the test loop cooled to a temperature ≤ 35 °C after each short circuit		P

6.4	Assessment of results		P
	Calculated parameters:		—
	connector resistance factor k , calculated according to annex E, clause E.2	See TABLE 3	—
	initial scatter δ , between the six initial values of k measured prior to heat cycling, calculated according to annex E, clause E.3	See TABLE 4	P
	mean scatter β , between the six values of k averaged over the last 11 measurement intervals, calculated according to annex E, clause E.4	See TABLE 5	P
	change in resistance factor D for each of the six connectors, calculated according to annex E, clause E.5	See TABLE 6	P
	resistance factor ratio λ calculated according to annex E, clause E.6	See TABLE 7	P
	maximum temperature θ_{max} on each connector, recorded according to annex E, clause E.7	See TABLE 2	P

6.5	Requirements		P
	more than four connectors satisfy the requirements shown in table 2		N/A
	one full re-test performed	<input type="checkbox"/> Yes <input type="checkbox"/> No	—
	six connectors satisfy the requirements shown in table 2		P
	values of δ do not exceed 0,3	See TABLE 4	P

TRF No. IEC61238_1A





PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
	values of β do not exceed 0,3	See TABLE 5	P
	values of D do not exceed 0,15	See TABLE 6	P
	values of λ do not exceed 2,0	See TABLE 7	P
	values of σ_{max} do not exceed σ_{ref}	See TABLE 2	P
7	Mechanical tests		P
7.1	Test method		—
	the test is made on three connectors different from those used for the electrical test	Sample No. 11.7...11.9	P
	connectors are fitted as for the electrical test of 6.1		P
	the conductor lengths, between connectors or between connector and tensile test machine jaws, are more than 500 mm		P
	the rate of application of the load do not exceed 10 N/mm ² of cross-section per second		P
7.2	Requirements		P
	tensile force applied during one minute	Conductor of 16 mm ² Al; 1 min	P
	force for aluminium, (40×A [mm ²], max. 20 000) .. :	40 x 16 = 640 N	P
	force for copper, (60×A [mm ²], max. 20 000) .. :		N/A
	in case the connector is electrically tested for conductors with difference cross-sectional area, the different joints tested individually to the above requirements		N/A
	no slipping during the tensile test		P





PN-EN 61238-1

6.3.3		TABLE 1: cold resistance and temperature of the connectors							—
cycle		connectors						reference conductor	
		j=1	j=2	j=3	j=4	j=5	j=6		
0.	R [mΩ]	0,6031	0,6032	0,6071	0,6047	0,6032	0,6071	0,6716	
	θ [°C]	19,4	19,5	19,5	19,8	20,0	19,9	19,7	
200.*	R [mΩ]	0,6039	0,6056	0,6094	0,6059	0,6037	0,6160	0,6719	
	θ [°C]	18,4	18,7	18,6	18,8	18,9	18,9	18,3	
200.*	R [mΩ]	0,6047	0,6095	0,6213	0,6070	0,6049	0,6134	0,6754	
	θ [°C]	19,7	19,9	20,0	20,2	20,4	20,3	19,6	
250.	R [mΩ]	0,6047	0,6096	0,6212	0,6064	0,6051	0,6143	0,6757	
	θ [°C]	21,1	21,4	21,4	21,7	21,7	21,5	21,1	
325.	R [mΩ]	0,6045	0,6089	0,6218	0,6067	0,6042	0,6143	0,6753	
	θ [°C]	21,4	21,6	21,7	21,9	21,9	21,8	21,8	
400.	R [mΩ]	0,6033	0,6074	0,6207	0,6059	0,6030	0,6134	0,6742	
	θ [°C]	22,1	22,4	22,4	22,6	22,8	22,7	22,7	
475.	R [mΩ]	0,6035	0,6073	0,6208	0,6058	0,6035	0,6132	0,6740	
	θ [°C]	21,0	21,3	21,3	21,5	21,5	21,5	21,0	
550.	R [mΩ]	0,6046	0,6092	0,6223	0,6075	0,6052	0,6148	0,6746	
	θ [°C]	21,6	21,7	21,8	21,9	22,0	22,0	21,7	
625.	R [mΩ]	0,6053	0,6096	0,6224	0,6071	0,6046	0,6141	0,6757	
	θ [°C]	24,0	24,2	24,2	24,3	24,4	24,3	23,8	
700.	R [mΩ]	0,6033	0,6077	0,6210	0,6053	0,6030	0,6124	0,6730	
	θ [°C]	22,4	22,5	22,4	22,7	22,7	22,7	22,9	
775.	R [mΩ]	0,6033	0,6079	0,6216	0,6058	0,6035	0,6131	0,6731	
	θ [°C]	19,5	19,7	19,7	19,9	19,9	19,8	19,6	
850.	R [mΩ]	0,6039	0,6073	0,6210	0,6055	0,6031	0,6124	0,6738	
	θ [°C]	20,3	20,6	20,6	20,9	21,0	20,9	20,4	
925.	R [mΩ]	0,6035	0,6086	0,6218	0,6066	0,6035	0,6130	0,6734	
	θ [°C]	22,9	23,1	23,1	23,4	23,6	23,3	22,9	
1000.	R [mΩ]	0,6029	0,6090	0,6213	0,6053	0,6023	0,6107	0,6731	
	θ [°C]	19,6	19,7	19,7	19,7	19,8	19,9	20,2	

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 11.1...11.6 (conductor of 16 mm²)

TRF No. IEC61238_1A

ВАРНО С ОБИТЕЛНА

Подпис:



PN-EN 61238-1

6.3.3		TABLE 2: maximum temperature of each connector measured						P
cycle		connectors						reference conductor
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	ϑ_{max} [°C]	102,2	104,3	92,9	96,6	105,1	97,7	138,6
200.*	ϑ_{max} [°C]	107,2	111,0	98,4	105,5	109,3	103,2	141,7
200.*	ϑ_{max} [°C]	101,7	110,3	102,2	104,0	109,4	100,1	140,3
250.	ϑ_{max} [°C]	104,3	114,4	102,4	106,1	111,8	103,5	143,5
325.	ϑ_{max} [°C]	105,0	112,7	103,5	106,4	110,9	102,3	143,6
400.	ϑ_{max} [°C]	104,4	113,4	104,2	105,4	111,1	102,8	143,4
475.	ϑ_{max} [°C]	104,4	112,8	103,3	106,3	111,7	105,2	142,6
550.	ϑ_{max} [°C]	104,6	113,6	99,6	105,8	110,8	105,3	140,9
625.	ϑ_{max} [°C]	105,3	114,8	100,9	107,9	112,1	106,6	140,9
700.	ϑ_{max} [°C]	103,9	112,4	98,8	106,1	111,5	106,5	142,0
775.	ϑ_{max} [°C]	101,4	110,5	99,3	105,2	108,2	101,3	140,6
850.	ϑ_{max} [°C]	102,4	111,7	97,6	103,9	109,2	105,5	142,0
925.	ϑ_{max} [°C]	103,4	111,3	99,6	104,8	110,0	105,2	140,3
1000.	ϑ_{max} [°C]	103,3	110,9	101,6	105,0	110,2	104,1	140,3

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 11.1...11.6 (conductor of 16 mm²)

TRF No. IEC61238_1A

ВАРНО С ОПРИГНАЛА

Подпис:



PN-EN 61238-1

6.4		TABLE 3: connector resistance factor k, calculated according to annex E, clause E.2						P	
Parameters:		L _a =	150 mm	L _b =	150 mm	L _r =	365 mm	L _j =	55 mm
cycle		connectors							
		j=1	j=2	j=3	j=4	j=5	j=6		
0.		0,5049	0,5059	0,5445	0,5208	0,5059	0,5445		
200.*		0,5106	0,5274	0,5650	0,5304	0,5087	0,6302		
200.*		0,4874	0,5345	0,6505	0,5100	0,4893	0,5728		
250.		0,4842	0,5323	0,6463	0,5009	0,4881	0,5785		
325.		0,4865	0,5297	0,6565	0,5081	0,4835	0,5828		
400.		0,4843	0,5246	0,6556	0,5099	0,4813	0,5837		
475.		0,4874	0,5248	0,6577	0,5100	0,4874	0,5829		
550.		0,4929	0,5381	0,6670	0,5214	0,4988	0,5932		
625.		0,4901	0,5323	0,6580	0,5078	0,4832	0,5765		
700.		0,4940	0,5374	0,6686	0,5138	0,4911	0,5838		
775.		0,4940	0,5393	0,6744	0,5186	0,4959	0,5906		
850.		0,4934	0,5269	0,6619	0,5092	0,4856	0,5772		
925.		0,4928	0,5430	0,6731	0,5233	0,4928	0,5864		
1000.		0,4900	0,5502	0,6714	0,5137	0,4841	0,5669		

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 11.1...11.6 (conductor of 16 mm²)



TRF No. IEC61238_1A

ДАНО С ОРВИГИНАЛ
Подпис:




PN-EN 61238-1

6.4		TABLE 4: initial scatter δ , between the six initial values of k measured prior to heat cycling, calculated according to annex E, clause E.3						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	K_0	0,5211	0,5211	0,5211	0,5211	0,5211	0,5211	
	s_0	0,0191	0,0191	0,0191	0,0191	0,0191	0,0191	
	δ	0,0605	0,0605	0,0605	0,0605	0,0605	0,0605	
Supplementary information: Sample No. 11.1...11.6 (conductor of 16 mm ²)								

6.4		TABLE 5: mean scatter β , between the six values of k averaged over the last 11 measurement intervals, calculated according to annex E, clause E.4						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	k	0,4900	0,5344	0,6628	0,5124	0,4883	0,5820	
	K	0,5450	0,5450	0,5450	0,5450	0,5450	0,5450	
	s	0,0673	0,0673	0,0673	0,0673	0,0673	0,0673	
	β	0,2038	0,2038	0,2038	0,2038	0,2038	0,2038	
Supplementary information: Sample No. 11.1...11.6 (conductor of 16 mm ²)								

6.4		TABLE 6/1: change in resistance factor D for each of the six connectors, calculated according to annex E, clause E.5						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
250...1000	b	-0,0009	-0,0016	-0,0022	-0,0012	-0,0004	0,0005	
	k	0,4900	0,5344	0,6628	0,5124	0,4883	0,5820	
	IM	0,0184	0,0299	0,0332	0,0234	0,0082	0,0086	
	s_j	0,0026	0,0063	0,0051	0,0055	0,0058	0,0074	
	S	0,0110	0,0244	0,0159	0,0222	0,0246	0,0263	
	D	0,0294	0,0543	0,0491	0,0456	0,0328	0,0349	
Supplementary information: Sample No. 11.1...11.6 (conductor of 16 mm ²)								



ВЕРНО С ОПИШАННЯ
 Подпис:



PN-EN 61238-1

6.4		TABLE 7/1: resistance factor ratio λ , calculated according to annex E, clause E.6						P
cycle		connectors						
		j=1	j=2	j=3	j=4	j=5	j=6	
0.	k_0	0,5049	0,5059	0,5445	0,5208	0,5059	0,5445	
200.*	$\lambda=$	1,0113	1,0425	1,0376	1,0184	1,0055	1,1574	
200.*	$\lambda=$	0,9653	1,0565	1,1947	0,9793	0,9672	1,0520	
250.	$\lambda=$	0,95 90	1,0522	1,1870	0,9618	0,9648	1,0624	
325.	$\lambda=$	0,9636	1,0470	1,2057	0,9756	0,9557	1,0703	
400.	$\lambda=$	0,9592	1,0370	1,2040	0,9791	0,9514	1,0720	
475.	$\lambda=$	0,9653	1,0374	1,2079	0,9793	0,9634	1,0705	
550.	$\lambda=$	0,9762	1,0636	1,2250	1,0012	0,9860	1,0894	
625.	$\lambda=$	0,9707	1,0522	1,2084	0,9750	0,9551	1,0588	
700.	$\lambda=$	0,9784	1,0623	1,2279	0,9866	0,9707	1,0722	
775.	$\lambda=$	0,9784	1,0660	1,2386	0,9958	0,9802	1,0847	
850.	$\lambda=$	0,9772	1,0415	1,2156	0,9777	0,9599	1,0601	
925.	$\lambda=$	0,9760	1,0733	1,2362	1,0048	0,9741	1,0770	
1000.	$\lambda=$	0,9705	1,0876	1,2331	0,9864	0,9569	1,0411	

(*) rows marked with asterisk can be omitted in case of connectors type "B"

Supplementary information: Sample No. 11.1... 11.6 (conductor of 16 mm²)

TRF No. IEC61238 1A

ВЕРИЛИ С ОПРЕДЕЛЕНА
Подпис:



Attachment No. 1

Summary of the test results according to PN-EN 61238-1:2004

Clause	Tests	Sample No.	Verdict
6	Electrical tests	11.1... 11.6	P
7	Mechanical tests	11.7... 11.9	P




I-POB-07/01-Z3w9



ВАРНО С ОБЩИНА
Подпис:



Photos of the samples:




Aluminium tin-plated through connector LAC 16

I-POB-07/01-Z3w9

Подпис: 
[Circular official stamp of the State Forensic Laboratory of the Ministry of Internal Affairs of the Republic of Latvia]




Photos of the samples (continued):




Test circuit of LAC 16

Handwritten signature


Handwritten signature





The configuration and dimensions of the test circuit of LAC 16

I-POB-07/01-Z3w9



ВАНІО С ОРГАНІЗАЦІЇ
Підпис:



Product data sheet:

Non-tension compression joints LAC... - LAC 16

EN60046-01x E12KA-01100100200

Unit of measure 100 pcs.
Minimal quantity 0.5 UOH



logistics details

Product title:	Non-tension compression joints LAC ...type
Type:	LAC 16 (100 SZT./PCS)
EN60046 index:	E12KA-01100100200
EAN:	5900003219483
Weight netto:	- 1,416 kg

mechanical details

Material:	Al.
Surface:	tin plated
Grease:	contact grease

Certificates

Design:	DRN 46267/2 - concern only the tubular part of terminal
---------	---

Electrical data


Voltage [kV]:	1-10
---------------	------

Sections

Cross section se [mm ²]:	25
Cross section sm [mm ²]:	16

crimping

Die code No:	12
No. of crimping wide:	1-2
No. of crimping narrow:	2-2



Sizes

d:	5,6
D:	12,0
L:	55

Characteristics

Note:
 - L A terminals are filled with special contact grease and packed in foil;
 - L A...BS - without contact grease;
 - sector shaped conductors must be rounded with special dies.

I-POB-07/01-Z3w0

ВАРНО С ОРИГИНАЛА
 Подпис:




Attachment No. 3

List of test equipment used:

Clause	Measurement / testing	Testing / measuring equipment / material used	Range used	Calibration date
6	Electrical tests	Temperature and humidity meter (W-02512)	Auto	2017-08-07
		KRP arrangement (801/50681)	—	2017-06-14
		Shunts 25 kA RST (801/50064-2C)	25 kA	2016-08-16
		Measuring tape 3 m (W-52157)	(0 ... 3) m	2014-01-14
		Stopwatch (W-52182)	s, min	2017-02-24
		Temperature meter TMP (801/02707)	(0 ... 300) °C	2017-07-20
		Current transformer JL-4 (W-51323)	400/5 A	2016-03-22
		Ammeter LE-3P (801/02824)	6 A	2017-06-21
		Multimeter FLUKE (8/02480)	mV DC	2017-05-15
7	Mechanical tests	Ammeter ML20 (W-51678)	15 A	2017-04-20
		Temperature and humidity meter (W-02506)	Auto	2017-08-07
		Dynamometer FB50K (801/02722)	640 N	2018-01-19
		Measuring tape 3 m (W-52157)	(0 ... 3) m	2014-01-14
		Stopwatch (W-50018)	(0 ... 60) s	2018-02-12

I-POB-07/01-Z3w9





od 1933 r.

ASSOCIATION of POLISH ELECTRICIANS
QUALITY TESTING OFFICE
ul. M. Pożaryskiego 28, 04-703 Warszawa, Poland

tel./fax: +48 22 815 65 80

TESTING LABORATORY



AB 044



TEST REPORT
EN 61238-1

Compression and mechanical connectors for power cables for rated
voltages up 36 kV ($U_m = 42$ kV)
Part 1: Test methods and requirements (IEC 61238-1:2003, modified)

Report Reference No. : LA-16.081/16.069/1/E

Data of issue : 2017-01-20

Total number of pages : 14

Tested by : Krzysztof Podgórnjak
(name + position + signature) Specialist

на основании чл. 36а, ал. 3
от ЗОП

Authorized by : Dariusz Szczepanowski
(name + position + signature) Manager of LA

Testing application number : C-A-16-081/16.069

Test item reference : S-A-16-069

Scope of test : - type test - partial test

Test specification:

Standard/procedure : EN 61238-1:2003,
IEC 61238-1:2003 (Second Edition)

Non-standard test methods : N/A


Non-accredited test methods : N/A

Applicant's name : Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o.

Address : ul. Nowe Sady 10, 94-102 Łódź



ВЕРНО С ОРИГИНАЛА
Подпись:



Test item description: Aluminium through connector

Trade Mark: 

Manufacturer: Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o.
ul. Nowe Sady 10, 94-102 Łódź

Model/Typ reference: LAC 25 + 300 / This report covers test of LAC 25

Ratings: Nominal cross-sectional area: 25 mm² + 300 mm² /
This report covers test of 25 mm²


List of Attachments:

Attachment No.	Attachment No.	Attachment No.
1	Summary of the test result	1
2	Product information and photos of samples	4
3	List of the equipment used for the test	1

Summary of testing:

Test performer (in the case of partial tests): N/A	Testing location/address (if different from page 1) : Stowarzyszenie Elektryków Polskich, Biuro Badawcze ds. Jakości Association of Polish Electrician, Quality Testing Office ul. M. Rapackiego 13, 20-150 Lublin, POLAND
Number of tests with F (Fail) verdict:	0
Summary conformity/non-conformity with standardization document (if apply):	N/A
Summary of compliance with National Differences (if apply): Provide list of standards.	N/A
Opinion and interpretation if needed:	N/A
Other additional information (as requested by the applicant):	N/A

Copy of marking plate:



LAC 25

[Handwritten signature]

[Handwritten signature]

И-РОБ-07/01-23w9


ВАРНО С ОУНОВАНА

Подпис:



Test item particular:	
Classification of installation and use	: N/A
Supply Connection	: N/A
Date (s) of receipt of test item	: 2016-09-02 (Sample No 1.1...1.9, 2.7...2.9) 2016-10-12 (Sample No 1.10, 2.10, 3.1...3.10, 4.10) 2016-10-21 (Sample No 4.1...4.9) 2016-10-26 (Sample No 2.1...2.6)
Date (s) of performance of tests	: 2016-09-02...2017-01-20
Possible test case verdicts:	
- test case does not apply to the test object	: N/A
- test object does meet the requirement	: P (Pass)
- test object does not meet the requirement	: F (Fail)
Test report general remarks:	
1. The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.	
2. "(See Enclosure #)" refers to additional information appended to the report..	
3. "(See appended table)" refers to a table appended to the report	
4. Throughout this report a comma is used as the decimal separator.	
5. Test Report Form is based on TRF No.: IEC61238_1A, copyrighted by IECCE.	
Production place(s)	: Zakłady Aparatury Elektrycznej ERGOM Sp. z o.o. ul. Nowe Sady 10, 94-102 Łódź
General product information:	
Tests were carried out on samples of aluminium tin-plated through connectors type LAC, nominal cross sectional area 25 mm ² + 300 mm ² . According to the standard and as agreed with the manufacturer for the tests were prepared four loops: 25 mm ² , 70 mm ² , 120 mm ² and 300 mm ² cross sectional area. This report covers test of 25 mm ² , LAC 25.	
Manual hydraulic presses HK 22 C with die KP22-W16/25 was used to crimp testing samples LAC 25. Die KP22-W16/25 with fangs is dedicated for cables of RMC construction. Size DIN12. Cable AsXSn 4x25 mm ² RMC 0,6/1kV, manufacturer NKT Cables was used to electrical and mechanical tests of through connectors LAC 25.	
Samples were marked for the tests as S-A-16-069/1.1...1.10, S-A-16-069/2.1...2.10, S-A-16-069/3.1...3.10 and S-A-16-069/4.1...4.10. In the Test Report abbreviated marking of the samples, as the samples No. 1.1...1.10, 2.1...2.10, 3.1...3.10, 4.1...4.10 is used.	
Type:	No.:
LAC 25	1.1...1.10
LAC 70	2.1...2.10
LAC 120	3.1...3.10
LAC 300	4.1...4.10

I-POB-07/01-Z3w9






PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Identification			—
	Connector		—
	Type of connector	<input checked="" type="checkbox"/> through connector <input type="checkbox"/> branch connector <input type="checkbox"/> terminal lug	—
	Nominal cross-sectional area	25 mm ²	—
	Class of connector	<input checked="" type="checkbox"/> Class A <input type="checkbox"/> Class B	—
5.1	Conductor		—
	conductor material	Al	—
	nominal cross-sectional area	25 mm ² RMC	—
	actual conductor area	25 mm ² RMC	—
	leading dimensions and shape	Unprepared cable	—
	type of conductor (solid or stranded).....	25 mm ² - stranded	—
	details of conductor construction (in the case of stranded conductors).....	25 mm ² – stranded cable, round, 7 wires	—
	compacted / non-compacted	Compacted	—
	flexible	No	—
	number of wires	7 wires	—
	direction of lay.....	Right	—
	plating	No plating	—
	type of impregnation, if any.....	—	—
	approximate indication of hardness (annealed, half-hard, hard)	Hard	—
	type of insulation (in case of insulation-piercing connectors)	—	—
5.2	Connectors and tooling		—
	assembly technique	Crimp connection	—
	tooling and necessary settings	Manual hydraulic presses HK 22 C with die KP22-W16/25. Die KP22-W16/25 with fangs is dedicated for cables of RMC construction. Size DIN12	—
	preparation of contact surfaces	Through connector filled with contact grease	—
	type, reference number and other identification of the connector	LAC 25: surface: tin-plated; material: Al	—

TRF No. IEC61238_1A

ВАЖНО С ОРИГИНАЛОМ
Подпись:






PN-EN 61238-1

Clause	Requirement – Test	Result - Remark	Verdict
6	Electrical tests		P
6.1	Installation		P
	six connectors fitted in accordance with the manufacturer's instructions		P
	welded equalizers used	Yes	P
	in case of insulation-piercing connectors, the insulation retained on the conductor under the connector, and for a distance of at least 100 mm outside the connector		N/A
	ambient temperature of the test location (between 15 °C and 30 °C) : 19 °C + 24 °C		P
	the test loop is dismantlable for short-circuit test (class A connectors only)		N/A
	the technology of the sectioning joints do not influence the measurements		N/A
	bolts or screws of the connectors were not retightened under test		N/A
6.1.1	Through connectors and terminal lugs		—
	test loop and dimensions according to Figure 1	See Attachment No. 2	P
	linking bars used (in case of terminal lugs)		N/A
	the palms bolted to the linking bars in accordance with the manufacturer's instructions		N/A
	linking bars have the same dimensions and material as the palm		N/A
	palm connected direct to palm		N/A
6.1.2	Branch connectors		—
	branch connector is treated as a through connector between the main and the branch (size of branch cable equal to the main, or immediately above or below the main)		N/A
	In other cases, test loop and dimensions according to Figure 2		N/A

6.2	Measurements		P
6.2.1	Electrical resistance measurements		P
	measurements made at stages throughout the test as specified in 6.3		P
	method used	<input checked="" type="checkbox"/> indirect <input type="checkbox"/> direct	—
	indirect method: measuring current is 10 % of the heat cycling current	LAC 25: 10,5 A + 13 A	P

TRF No. IEC61238_1A


 ВАРНО С ОРГАНУ
 Подпис: