


Reg.-Nr.
DAT-P-032/93

TEST REPORT No. HZ 236 E 06

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 12





Deutscher
Akkreditierungs
Rat

Reg.-Nr.
DAT-P-032/93


ABB Calor Emag Laboratories

[Signature]
ABB


TEST REPORT No. HZ 236 E 06

Issued by an Accredited Laboratory
corresponding to EN 45001


Sheet 13




Test Arrangement and Measurement Points for Temperatures and Resistances on the Busbars




ВЯРНО С ОРИГИНАЛА




Measurement Points for Temperatures and Resistances of Panel 1




ВЯРНО С ОРИГИНАЛА



Measurement Points for Temperatures and Resistances of Panel 2



ВЯРНО С ОРИГИНАЛА





Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories




TEST REPORT No. HZ 236 E 06


Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 17

Measurement Points for Temperatures of Circuit-Breaker Poles Panel 1



ВЯРНО С ОРИГИНАЛА




Reg.-Nr.
DAT-P-032/93

TEST REPORT No. HZ 236 E 06


Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 18

Measurement Points for Temperatures of Circuit-Breaker Poles Panel 2



ВЯРНО С ОРИГИНАЛА



Mey



Deutscher
Akreditierungs
Rat

ABB Calor Emag Laboratories

Reg.-Nr.
DAT-P-032/93

TEST REPORT No. HZ 236 E 06

Sheet 19

Issued by an Accredited Laboratory
corresponding to EN 45001

Measurement of the Resistance of the Main Circuit

Date of test: 11th November 2000 - before temperature rise test
12th November 2000 - after temperature rise test

Condition of test object before test: factory new panels

Ambient air temperature: before temperature rise test 22 °C
after temperature rise test 24 °C

Measurement between points (see sheet 14 - 16)	Resistance of the main circuit µΩ		
	L1 before/after ¹⁾	L2 before/after ¹⁾	L3 before/after ¹⁾
2 - 14 (panel 1)	56.3 / 56.4	53.5 / 53.6	51.6 / 51.5
13 - 25 (panel 2)	95.0 / 94.4	90.4 / 89.1	83.3 / 81.9

Remarks: ¹⁾ Before: before temperature rise test
After: after temperature rise test

Resistance measurement at direct current of: 50 A

The measurement of the resistances are carried out by using the thermocouples at the named measurement points.

ВЯРНО С ОРИГИНАЛА





Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 236 E 06

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 20

Temperature Rise Test

Date of test: 11th and 12th November 2000

Condition of test object before test: factory new panels

Connections to test object: feeder:

two bars 100x10 mm² Cu, length about 2 m outside the panel and
four bars 80x8 mm² Cu, length about 0.8 m outside and inside the
panel

neutral points:

1. busbar outside feeder panel 2 with two bars 80x10 mm² Cu
2. extended cable connection bars of panel 2 with one bar 80x10 mm² Cu

Duration of test: 9 h

Ambient air temperature: 26.1 °C

Test current: see sheet 14

Test frequency 50 Hz


Distribution of the currents of the panels:

panel or busbar	current in A			
	phase L1	phase L2	phase L3	average value
panel 1, incoming 2000 A	2002	2004	2013	2006
busbar panel 1 - 2	2002	2004	2013	2006
panel 2, outgoing 1250 A	1251	1250	1252	1251

Remarks:

1. The distribution of the currents at the busbar connections of the feeder panel 2 was done by using of iron cores over the extended busbars.
2. The side walls of the panels and the extended busbars were covered by expanded polystyrene sheets of 30 mm thickness.
3. The temperatures were measured by thermocouples type T. For the measurement points of the main circuit the thermocouples were inserted into holes and fixed. The measurement system determines the average value of the ambient temperatures, calculates the differences to the temperatures of all measuring points and records the temperature rises directly.

ВЯРНО С ОРИГИНАЛА





Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories

TEST REPORT No. HZ 236 E 06

Sheet 21

Issued by an Accredited Laboratory
corresponding to EN 45001


Permitted Temperature Rise of the Main Circuit according IEC 60694 table 3

Kind of measuring point	Maximum value temperature rise at ambient air temperature not exceeding 40 °C	Measuring point (see sheet 14 to 18)
cable terminal	50	3, 24
Connection, bolted, Cu silver coated in air	75	13, 14, 18, 26, 27, 28
Connection, bolted, Cu silver coated in air in contact with insulation material class A	65	8, 10, 17, 19
Connection, bolted, Cu silver coated in air in contact with insulation material class E	75	4, 5, 22, 23
Contact, Cu silver-coated in air	65	6, 7, 9, 11, 12, 15, 16, 20, 21

Continuation from sheet 20

Measuring point (see sheets 15 and 16)	Panel	Description of measuring point	Kind of measuring point	Final temperature rise K	Permitted temperature rise K
29	1	Front door top cable compartment	Access. part expected to be touched in normal operation	4.7	30
30	1	Front door top c.b. compartment	Access. part expected to be touched in normal operation	5.0	30
31	1	Front door top low voltage compartment	Access. part expected to be touched in normal operation	7.6	30
32	1	Rear wall top	Accessible part which need not to be touched in normal op.	14.4	40
33	2	Front door top cable compartment	Access. part expected to be touched in normal operation	3.8	30
34	2	Front door top c.b. compartment	Access. part expected to be touched in normal operation	6.3	30
35	2	Front door top low voltage compartment	Access. part expected to be touched in normal operation	8.1	30
36	2	Rear wall top	Accessible part which need not to be touched in normal op.	11.0	40

ВЯРНО С ОРИГИНАЛА



Ноя



Reg.-Nr.
DAT-P-032/93


ABB Calor Emag Laboratories

TEST REPORT No. HZ 236 E 06

Sheet 22

Issued by an Accredited Laboratory
corresponding to EN 45001

Temperature rises and Permitted Temperature rises of the Incoming Panel 1 and the Busbar – right side



**Temperature rises and Permitted Temperature rises of the Feeder Panel 2
and the Busbar – left side**


12.11.2000

ABB Calor Emag Laboratories Test report HZ236E06

Temperature-rise of switchgear Z31.2 - 24 kV with UNI 2406-25 with UG4-S.

No.	Name	Temperature rise in K			Test current : 1251 A	Ambient temperature : 26.1 °C	Permit. temp. rise
		P1	P2	P3			
28	end of busbar panel 1	24.9	23.3	34.9			
13	busbar/jumper bar panel 1	55.7	53.7	58.7			
14	busbar/jumper bar panel 2	61.9	60.4	54.6			
15	upper disconn. contact pan	64.1	64.9	59.6			
16	upper disconn. cont. c.b.	59.8	61.2	58.1			
17	upper pole terminal	57.0	58.7	57.3			
18	current lead interrr. stem	59.0	61.1	61.2			
19	lower pole terminal	55.2	57.7	57.1			
20	lower disconn. cont. c.b.	52.9	56.3	55.5			
21	lower disconn. contact pan	50.4	53.5	54.4			
22	upper c.t. terminal	50.3	51.6	50.4			
23	lower c.t. terminal	43.7	45.4	44.5			
24	cable terminal	36.7	40.0	39.7			
25	neutral point cable term.	36.5	38.3	36.3			

BEST OF COPIES MADE BY
BROTHO COPYSERVICE LTD





Reg.-Nr.

DAT-P-032/93

ABB Calor Emag Laboratories




TEST REPORT No. HZ 236 E 06


Sheet 24

Issued by an Accredited Laboratory
corresponding to EN 45001

Temperature rise of upper Disconnecting Contacts Panel Side - Phase L2



ВЯРНО С ОРИГИНАЛА



PEHLA

GESELLSCHAFT FÜR ELEKTRISCHE HOCHLEISTUNGSPRÜFUNGEN
Member of the SHORT-CIRCUIT TESTING LIAISON (STL)

Test Document

Report No.: 0511Ra

Copy No.: 1

Contents: 72 Sheets

Test object: Vacuum circuit-breaker type VD4/P 24.06.20 p275 in metal-enclosed air-insulated switchgear type UniGear ZS1, 1000 mm width

Designation: VD4/P 24.06.20 p275 in UniGear ZS1 (1000 mm width)

Rated voltage: 24 kV Rated normal current: 630 A
Rated short-circuit breaking current: 20 kA

Rated frequency: 50 / 60 Hz

Manufacturer: ABB P.T. S.p.A.

Client: ABB P.T. S.p.A.

Testing station: PEHLA-Testing Laboratory Ratingen

Date of test: 10th February, 09th and 10th March 2005

Applied test specifications:

The tests have been carried out in full compliance with the below mentioned standards.

Test procedure and test parameters were strictly according to:

IEC 62271-200 / 1st Ed. / 2003-11, Clauses 6.6 and 6.101

IEC 60694 / Ed. 2.2 / 2002-01, Clause 6.6

IEC 62271-100 / Ed. 1.1 / 2003-05, Clause 6.106

According to STL Objectives and Operating Principles PEHLA issues a Test Document following exclusively the above mentioned test specifications and the STL Guides wherever applicable.

Tests performed:

Three-phase short-time withstand current and peak withstand current test of the main circuit.

Three-phase making and breaking capacity test based on 20.0 kA at 24 kV comprising the basic test duties T10, T30, T60, T100s and T100a (dc-component of 35 %).

No-load operations and measurement of the resistance of the main circuit before and after the tests.

Power frequency withstand voltage test at 50.0 kV – 1 min before and after the tests as a condition check.

Test results:

The above mentioned vacuum circuit-breaker in metal-enclosed air-insulated switchgear passed the short-time withstand current and peak withstand current test and the three-phase making and breaking capacity test successfully.

GESELLSCHAFT FÜR ELEKTRISCHE
HOCHLEISTUNGSPRÜFUNGEN

Management Committee

Technical Committee




Mannheim, 20th July 2005

The test results relate only to the items tested.

The authenticity of this document is guaranteed by the integrity of the seal label and seal ribbon.
Without a written permission of PEHLA it is not allowed to make reproduction in extracts of this document. Copying the cover sheet accompanied by sheet 2 and the sheets mentioned here is an exception.

03PE0402



297

Notes

Accreditation

The PEHLA-Testing Laboratory Ratingen has been approved by the DATech (German accreditation body for technology) according to EN ISO/IEC 17025 for tests in the field of high-voltage switchgear and controlgear and power engineering equipment (Registration-No. DAT-P032/93).

STL-Member

PEHLA is founder member of the SHORT-CIRCUIT TESTING LIAISON (STL) which has been established in March 1969. STL is a forum for the international cooperation of the testing organisations with the further full members ASTA (UK), CESI (IT), ESEF (FR), KEMA (NL), SATS (NO; SE, FI), STLNA (US, CA) and JSTC (JP). In the framework of EC, STL (EU) has been recognised in 1992 by EOTC as agreement group.

PEHLA-Documents

A Type Test Certificate

is issued for type tests which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. For these tests the test object must be clearly identified by technical description, drawings and additional specifications.

A Test Document

is issued for parts of type tests which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of test. For these tests the test object must be clearly identified by technical description, drawings and additional specifications.

A Test Report

is issued for all other tests which have been carried out according to specifications, standards or "PEHLA-Richtlinien" (PEHLA Guides) and/or clients' instructions. Similarly, this test report contains all test results, details of the conditions under which the tests were carried out, also details relating to the behaviour of the test object, and its condition after the tests.

A Test Confirmation

is issued immediately after the tests. It confirms that the tests have been conducted and is valid only until publishing the detailed results in an entire document.

Uncertainty of the measurement systems

The PEHLA - Testing Laboratories apply the PEHLA Guide No. 12 for determining the uncertainties of measurement, based on ENV 13005 (Guide to the expression of uncertainty in measurement). As long as no explicit statements are made, the uncertainties required by the relevant standards have been complied with.

Addresses

Office: PEHLA-Geschäftsstelle
Hallenweg 40
68219 Mannheim
Germany
Internet: www.pehla.com

Testing Station: PEHLA-Testing Laboratory Ratingen
Oberhausener Str. 33
40472 Ratingen
Germany

Manufacturer: ABB P.T. S.p.A.
Via Friuli, 4
24044 Dalmine (BG)
Italy

Client: ABB P.T. S.p.A.
Via Friuli, 4
24044 Dalmine (BG)
Italy

My
03PEH09741
DODHO C OPIWIIWA
298





Table of Contents

Cover Sheet.....	1
Notes	2
Table of Contents	3
List of Test Participants	4
Technical Data of Test Object Switchgear.....	5
Technical Data of Test Object Circuit-Breaker.....	6
List of Identified Drawings	7
Drawings.....	8
Technical Data of Test Circuits Short-Time Withstand Current and Peak Withstand Current Tests.....	10
Circuit Diagram Test Circuit for Three-Phase Tests Peak Withstand Current and Short-Time Withstand Current Tests.....	11
Technical Data of Test Circuit Short-Circuit Direct Test.....	12
Circuit Diagram Test Circuit for Three-Phase Tests Basic Short-Circuit Making and Breaking Tests	13
Test Results Three-phase short-time withstand current and peak withstand current tests	14
Oscillograms.....	15
Test Results Basic Short-Circuit Making and Breaking Tests.....	17
Oscillograms.....	18
Test Results Basic Short-Circuit Making and Breaking Tests.....	23
Oscillograms.....	24
Test Results Basic Short-Circuit Making and Breaking Tests.....	29
Oscillograms.....	30
Test Results Basic Short-Circuit Making and Breaking Tests.....	35
Oscillograms.....	36
Test Results Basic Short-Circuit Making and Breaking Tests.....	42
Oscillograms.....	43
Test Results Basic Short-Circuit Making and Breaking Tests.....	55
Oscillograms.....	56
Test Results No-load Operations	61
Oscillograms.....	62
Test Results Voltage Test as a Condition Check.....	68
Measurement of the Resistance of the Main Circuit	69
Measurement of the Resistance of the Main Circuit Measurement points	70
Photos	71

БРАНО С ОРНAMENTАМ





List of Test Participants

Representatives of Technical Committee:

Mr. Klaus Niemeyer PEHLA-Testing Laboratory Berlin-Siemensstadt, Germany
Mr. Joachim Oemisch PEHLA-Testing Laboratory Berlin-Siemensstadt, Germany
Dr. Thomas Ebke PEHLA-Testing Laboratory Ratingen, Germany

Test Engineer / Test Operator:

Mr. Joachim Köhler PEHLA-Testing Laboratory Ratingen, Germany
Dr. Thomas Ebke PEHLA-Testing Laboratory Ratingen, Germany

Representatives of Client:


Mr. Stefano Magoni ABB P.T. S.p.A., Dalmine, Italy

Further Participants:

Mr. Frank Idaszek PEHLA-Testing Laboratory Ratingen, Germany

БАРНО С ОРИГИНАЛА

51PE0402



Technical Data of Test Object Switchgear

Test object: Metal-enclosed air-insulated switchgear.
Designation: UniGear ZS1
Manufacturer: ABB P.T. S.p.A., Via Friuli, 4, 24044 Dalmine (BG), Italy
Serial No.: -
Year of manufacture: 2004
Drawing No.: See sheet 7

Ratings assigned by the manufacturer:


Rated voltage	24 kV
Rated normal current	630 A
Rated frequency	50/60 Hz
Rated lightning impulse withstand voltage	125 kV
Rated switching impulse withstand voltage	- kV
Rated power-frequency withstand voltage	50 kV
Rated peak withstand current	63/65 kA
Rated short-time withstand current	25 kA
Rated duration of short-circuit	3 s
Insulating medium	-
Rated filling pressure for insulation	- MPa abs. at 20 °C
Minimum functional pressure for insulation	- MPa abs. at 20 °C

Permissible values for internal arc faults:

Peak current	63/65 kA
Short-circuit current	25 kA
Duration of short-circuit	1 s

Further data: -**Essential characteristics and installed devices:** -

ВАРНО С ОРИГИНАЛА



Technical Data of Test Object

Circuit-Breaker

Test object: Vacuum circuit-breaker
Designation: VD4/P 24.06.20
Manufacturer: ABB P.T. S.p.A., Via Friuli, 4, 24044 Dalmine (BG), Italy
Serial No.: 1VC1AE00038562
Year of manufacture: 2004
Serial No. of drive: -
Drawing No.: See sheet 7



Ratings assigned by the manufacturer:

Rated voltage	24	kV
Rated normal current	630	A
Rated frequency	50/60	Hz
Rated lightning impulse withstand voltage	125	kV
Rated switching impulse withstand voltage	-	kV
Rated power-frequency withstand voltage	50	kV
Rated peak withstand current	50/52	kA
Rated short-time withstand current	20	kA
Rated duration of short-circuit	3	s
Rated short-circuit breaking current	20	kA
DC component of the rated short-circuit breaking current	35	%
Rated short-circuit making current	50/52	kA
Rated transient recovery voltage	41	kV
Rate of rise of transient recovery voltage	0.47	kV/μs
First-pole-to-clear factor	1.5	
Rated operating sequence	O - 0.3 s - CO - 15 s - CO	
Arc extinguishing medium	vacuum	
Rated filling pressure for operation	- MPa	abs. at 20 °C
Minimum functional pressure for operation	- MPa	abs. at 20 °C
Insulating medium	-	
Rated filling pressure for insulation	- MPa	abs. at 20 °C
Minimum functional pressure for insulation	- MPa	abs. at 20 °C
Driving mechanism (type)	spring charged by motor	
Number of poles	3	
Number of units per pole	1	
Rated opening time	30 – 60	ms
Rated closing time	50 – 80	ms
Rated supply voltage of opening device	110	V d.c.
Rated supply voltage of closing device	110	V d.c.
Rated supply voltage of auxiliary circuits	110	V d.c.
Rated frequency of supply voltage	-	Hz

Further data:

Type and Serial No. of Poles: P4 with VG4, L1: EP00013111, L2: EP00013094, L3: EP00013173

Essential characteristics:



List of Identified Drawings

The manufacturer has submitted to the testing laboratory drawings and other data containing sufficient information to unambiguously identify by type the essential details and parts of the test object presented for test.

The drawings have been stamped and signed by the manufacturer in order to guarantee that the drawings or data schedules truly represent the test object to be tested.

Further these drawings have been stamped and signed by PEHLA representatives and are kept

at the client.

with the test documents at the test laboratory.

The testing laboratory has checked that drawings and data schedules adequately represent the essential details and parts of the test object to be tested, but is not responsible for the accuracy of the detailed information.


The drawing(s) contained in this document are identical with the checked, stamped and signed drawings.

Drawing No.	Rev.	P/D ^{*)}	Title	Additional remarks
GCE8010459 R0103	01	D	Abzweigfeld 24kV, TLG.1000 Feeder panel 24kV, PW.1000	Included in the Test Report
TN 7414	--	D	Interruttore in Vuoto Tipo Vacuum Circuit Breaker Type VD4/P 24kV 630-1250A	Included in the Test Report
GCE8012502 R0103	01	D	MONTAGEPLATTE H=310, KONTAKT 35 Mounting plate H=310, contact 35	-
GCE8685778 P0121	03	D	Kontaktstift	-
N 510509 Gr. 810	--	P	Tabella Materiali N 510509	-
510509 Gr. 810	--	D	Completamento Interruttore C.B. Completion	-
N 1VCR003288 G0015	--	P	Tabella Materiali N 1VCR003288G	-
1VCR003288 G0015	--	D	Struttura con poli Frame with Poles	-
N 1VCR003324 G0015	--	P	Tabella Materiali N 1VCR003324G	-
1VCR003324 G0015	--	D	Interuttore Base Base Breaker	-
N 1VCR003321 G0003	--	P	Tabella Materiali N 1VCR003321G	-
1VCR003321 G0003	--	D	Commando con Albero Operating Mechanism with Shaft	-
N 510508 Gr. 802	--	P	Tabella Materiali N 510508	-
510508 Gr. 802	--	D	Montaggio Passanti e Tulipani Bushing and Tulip Mounting	-
GCE7004730 R0104	11	D	Pol, vst. 24kV 1250A Pole complet 24kV 1250A	-


*) P: Parts list, D: Drawing

Remarks: -

ВЪРНО С ОРИГИНАЛА




Drawing
GCE8010459R0103



ВЯРНО С ОРИГИНАЛА

Drawing
TN.7414



БЯРНО С ОРИГИНАЛА

[Signature]

Technical Data of Test Circuits


Short-Time Withstand Current and Peak Withstand Current Tests

Test performed	STC	-	-	-
Test No. PEHLA 0511Ra	03 - 04	-	-	-
Circuit diagram	Sheet No.	11	-	-
Current circuit		-	-	-
Number of phases		3	-	-
Power frequency	Hz	50	-	-
Power factor		< 0.15	-	-
Earthing conditions		-	-	-
Generator / System		earthed via 5 kΩ	-	-
Transformer		not earthed	-	-
Short-circuit point		earthed	-	-
Test object		earthed	-	-
Test object (test values)		-	-	-
Number of phases		3	-	-
Measurement		-	-	-
Voltage measurement		Dividers 80 kΩ / 1.1 kΩ	-	-
Current measurement		Transf. 50 kA / 5 A	-	-


Remarks: -

[Signature]


ВЯРНО С ОРИГИНАЛА



Circuit Diagram
Test Circuit for Three-Phase Tests
Peak Withstand Current and Short-Time Withstand Current Tests



ВЯРНО С ОРИГИНАЛА
44PE0402



Technical Data of Test Circuit


Short-Circuit Direct Test

Test performed	T30		T60		T100		T10	
Test No. PEHLA 0511Ra	07-08		09-12		13-28		29-30	
Circuit diagram (test circuit) see sheet	13		13		13		13	
Test object								
Rated voltage	kV	24		24		24		24
Rated frequency	Hz	50		50		50		50
Short-circuit breaking current	kA	6.00		12.0		20.0		2.00
Units under test		-		-		-		-
Voltage distribution	%	-		-		-		-
Number of phases (test circuit)		3		3		3		3
Power factor (test circuit)		≤ 0.15		≤ 0.15		≤ 0.15		≤ 0.15
Frequency (test circuit)	Hz	50		50		50		50
Earthing conditions								
Generator		earthed via 5 kΩ		earthed via 5 kΩ		earthed via 5 kΩ		earthed via 5 kΩ
Transformer		not earthed		not earthed		not earthed		not earthed
Short-circuit point		earthed		earthed		earthed		earthed
Prospective transient recovery voltage		Required values	Tested values	Required values	Tested values	Required values	Tested values	Required values
Evaluation of oscillogram	No.	-	prosp.	-	prosp.	-	prosp.	-
Crest value u_c	kV	44.0	44.5	44.0	44.0	41.0	41.0	44.0
Time t_3	μs	19	38 ¹⁾	38	38	87	80	19
Time delay t_d	μs	-	-	-	-	-	-	-
Rate of rise u_1/t_1 or u_c/t_3	kV/μs	2.32	1.17	1.16	1.16	0.47	0.51	2.32
u_1	kV	-	-	-	-	-	-	-
t_1	μs	-	-	-	-	-	-	-


Remarks: ¹⁾ Due to limitations of the test plant the time coordinate t_3 is higher than the required values.

ВЪРНО С ОРИГИНАЛА


12PE0402



Circuit Diagram
Test Circuit for Three-Phase Tests
Basic Short-Circuit Making and Breaking Tests



ВЯРНО С ОРИГИНАЛА



Test Results

Three-phase short-time withstand current and peak withstand current tests

Test performed: Three-Phase Peak and Short-Time Withstand Current Tests,
52 kA / 20 kA – 3s

Date of test: 10th February 2005

Condition of test object before test: Factory new.

Test arrangement: Direct test circuit, circuit-breaker in air-insulated switchgear

Connections to test object: Infeed via copper bars to the busbar connection of the
switchgear, short-circuited via copper bar at the cable terminals,
short-circuit point earthed via cable.

Test No. PEHLA 0511Ra			03	04	-	-	-	-
Short-circuit current - peak	L1	kA	52.3	36.6	-	-	-	-
	L2	kA	40.6	29.8	-	-	-	-
	L3	kA	46.1	37.1	-	-	-	-
Short-circuit current - rms	First cycle	L1	kA	22.0	20.4	-	-	-
		L2	kA	22.7	19.9	-	-	-
		L3	kA	22.5	21.4	-	-	-
	Last cycle	L1	kA	21.0	21.1	-	-	-
		L2	kA	22.0	22.2	-	-	-
		L3	kA	21.4	21.5	-	-	-
	Equivalent current	L1	kA	21.0	20.6	-	-	-
		L2	kA	22.1	21.6	-	-	-
		L3	kA	21.4	21.0	-	-	-
	Average value		kA	21.5	21.0	-	-	-
Duration of short circuit			s	0.317	3.02	-	-	-
Short-time current	L1	kA	-	20.6	-	-	-	-
	L2	kA	-	21.7	-	-	-	-
	L3	kA	-	21.0	-	-	-	-
	Average value		kA	21.1	-	-	-	-
Duration			s	-	3.00	-	-	-
Emission of flame/gas/oil			no	no	-	-	-	-
Test result (P/N)			P	P	-	-	-	-

Resistance of the main circuit

Before test		L1	μΩ	26.5	-	-	-	-	-
		L2	μΩ	28.4	-	-	-	-	-
		L3	μΩ	26.9	-	-	-	-	-
After test		L1	μΩ	-	26.2	-	-	-	-
		L2	μΩ	-	27.1	-	-	-	-
		L3	μΩ	-	26.2	-	-	-	-


Legend: P: Passed in terms of the applied standard N: Not passed in terms of the applied standard


Remarks: PEHLA 0511Ra / 01: Current calibration

PEHLA 0511Ra / 02: No-load operation


Condition of test object after test: Vacuum circuit-breaker type VD4/P 24.06.20 p275 in metal-enclosed air-insulated switchgear type UniGear ZS1, 1000 mm width without visible or functional change or damage. It opened by its own mechanism energized at rated auxiliary voltage at the first attempt.


ВЯРНО С ОРИГИНАЛА



**Oscillogram
PEHLA 0511Ra / 03**


ВЯРНО С ОРИГИНАЛА



**Oscillogram
PEHLA 0511Ra / 04**

ВЯРНО С ОРИГИНАЛА

18PE0402



Test Results

Basic Short-Circuit Making and Breaking Tests

Test performed: Basic short-circuit making and breaking tests (T30)
Date of test: 09th March 2005
Condition of test object before test: As after PEHLA 0511Ra / 04.
Test arrangement: Direct test circuit, circuit-breaker in gas insulated switchgear
Connections to test object: Infeed via copper bars to the busbar connection of the switchgear, short-circuited via copper bar at the cable terminals, short-circuit point earthed via cable.


Test No. PEHLA 0511Ra			07	08	-	-	-
Operating sequence and time intervals			O-0.3s-CO-15s-CO		-	-	-
Applied voltage	kV	-	24.5	24.2	-	-	-
Making current (peak)	L1	kA	-	10.4	11.2	-	-
	L2	kA	-	15.1	15.5	-	-
	L3	kA	-	14.9	13.2	-	-
Breaking current (r.m.s.)	L1	kA	6.58	6.67	6.58	-	-
	L2	kA	6.68	6.77	6.81	-	-
	L3	kA	6.54	6.73	6.66	-	-
	Average value	kA	6.60	6.72	6.69	-	-
Recovery voltage (r.m.s.)	L1	kV	13.8	14.2	14.0	-	-
	L2	kV	14.1	14.2	14.0	-	-
	L3	kV	14.1	14.4	14.3	-	-
Transient recovery voltage	Voltage u_1	kV	-	-	-	-	-
	Time t_1	μs	-	-	-	-	-
	TRV peak value u_c	kV	44.5	43.0	44.5	-	-
	Time t_3	μs	-	-	-	-	-
	Time delay t_d	μs	-	-	-	-	-
	Rate of rise u_c/t_3	kV/μs	-	-	-	-	-
C-Operation	Voltage of closing device	V	-	94	94	-	-
	Closing time	ms	-	63.4	62.6	-	-
	Pre-arcning time	ms	-	-	-	-	-
	Make time	ms	-	63.4	62.6	-	-
O-Operation	Voltage of opening device	V	77	77	77	-	-
	Opening time	ms	59.8	60.7	59.0	-	-
	Arcing time L1	ms	4.6	8.2	8.2	-	-
	L2	ms	9.6	7.8	3.0	-	-
	L3	ms	9.4	2.8	8.2	-	-
	Break time	ms	69.4	68.9	67.2	-	-
Emission of flame/gas/oil, occurrence of NSDD		no	no	no	-	-	-
Number of valid test		-	-	-	-	-	-
Test result		P	P	P	-	-	-


Legend: P: Passed in terms of the applied standard N: Not passed in terms of the applied standard

Remarks: PEHLA 0511Ra / 05 and 06: No-load operations

Condition of test object after test: Switchgear and circuit-breaker were not inspected.

ВЯРНО С ОРИГИНАЛА





**Oscillogram
PEHLA 0511Ra / 07**

ВЯРНО С ОРИГИНАЛА

18PE0402




**Oscillogram
PEHLA 0511Ra / 07****ВЯРНО С ОРИГИНАЛА**


**Oscillogram
PEHLA 0511Ra / 07**

БЛАНК С ОРИГИНАЛА
0511Ra




**Oscillogram
PEHLA 0511Ra / 08**

МУ
БЯРНО С ОРИГИНАЛА
18PE0402




Oscillogram PEHLA 0511Ra / 08



ВЯРНО С ОРИГИНАЛА

18PE0402



Test Results

Basic Short-Circuit Making and Breaking Tests

Test performed: Basic short-circuit making and breaking tests (T60)
Date of test: 09th March 2005
Condition of test object before test: As after Test Pehla 0511Ra / 08
Test arrangement: Direct test circuit, circuit-breaker in air-insulated switchgear
Connections to test object: Infeed via copper bars to the busbar connection of the switchgear, short-circuited via copper bar at the cable terminals, short-circuit point earthed via cable.


Test No. PEHLA 0511Ra			11	12	-	-	-
Operating sequence and time intervals			O-0.3s-CO-15s-CO		-	-	-
Applied voltage	kV	-	25.0	24.1	-	-	-
Making current (peak)	L1	kA	-	20.1	25.5	-	-
	L2	kA	-	32.5	32.9	-	-
	L3	kA	-	29.8	25.7	-	-
Breaking current (r.m.s.)	L1	kA	12.5	13.0	12.5	-	-
	L2	kA	12.8	13.5	12.8	-	-
	L3	kA	12.6	13.1	13.1	-	-
	Average value	kA	12.6	13.2	12.8	-	-
Recovery voltage (r.m.s.)	L1	kV	14.1	14.2	13.6	-	-
	L2	kV	14.2	14.5	13.8	-	-
	L3	kV	14.2	14.8	14.4	-	-
Transient recovery voltage	Voltage u_1	kV	-	-	-	-	-
	Time t_1	μ s	-	-	-	-	-
	TRV peak value u_c	kV	41.6	42.0	42.5	-	-
	Time t_3	μ s	-	-	-	-	-
	Time delay t_d	μ s	-	-	-	-	-
	Rate of rise u_c/t_3	kV/ μ s	-	-	-	-	-
C-Operation	Voltage of closing device	V	-	94	94	-	-
	Closing time	ms	-	62.8	63.5	-	-
	Pre-arcning time	ms	-	-	-	-	-
	Make time	ms	-	62.8	63.5	-	-
O-Operation	Voltage of opening device	V	77	77	77	-	-
	Opening time	ms	58.6	56.5	59.4	-	-
	Arcing time L1	ms	7.8	7.6	8.2	-	-
	L2	ms	3.4	7.6	3.8	-	-
	L3	ms	9.0	2.6	8.8	-	-
	Break time	ms	67.6	64.1	68.2	-	-
Emission of flame/gas/oil, occurrence of NSDD		no	no	no	-	-	-
Number of valid test		-	-	-	-	-	-
Test result		P	P	P	-	-	-


Legend: P: Passed in terms of the applied standard N: Not passed in terms of the applied standard

Remarks: PEHLA 0511Ra / 09 and 10: Tests with reduced values


Condition of test object after test: Switchgear and circuit-breaker were not inspected.


BADHO C OPIJINHADIA
B755432




**Oscillogram
PEHLA 0511Ra / 11**

ВЯРНО С ОРИГИНАЛА
48860402





**Oscillogram
PEHLA 0511Ra / 11**

ВЯРНО С ОРИГИНАЛА
18PE0402

**Oscillogram
PEHLA 0511Ra / 11**


БРАФО С ОРГАНІВАДІЯ
19752402




**Oscillogram
PEHLA 0511Ra / 12**

ВЯРНО С ОРИГИНАЛА

18PE0402



**Oscillogram
PEHLA 0511Ra / 12**

Test Results

Basic Short-Circuit Making and Breaking Tests



Test performed: Basic short-circuit making and breaking tests (T100s)
Date of test: 09th March 2005
Condition of test object before test: As after PEHLA 0511Ra / 12.
Test arrangement: Direct test circuit, circuit-breaker in gas insulated switchgear
Connections to test object: Infeed via copper bars to the busbar connection of the switchgear, short-circuited via copper bar at the cable terminals, short-circuit point earthed via cable.


Test No. PEHLA 0511Ra			15	16	-	-	-
Operating sequence and time intervals			O-0.3s-CO-15s-CO			-	-
Applied voltage	kV	-	25.3	24.3	-	-	-
Making current (peak)	L1	KA	-	40.3	47.5	-	-
	L2	KA	-	49.7	49.7	-	-
	L3	KA	-	48.0	38.5	-	-
Breaking current (r.m.s.)	L1	KA	20.4	20.3	19.8	-	-
	L2	KA	20.5	20.0	21.1	-	-
	L3	KA	19.6	19.8	20.1	-	-
	Average value	KA	20.2	20.0	20.4	-	-
Recovery voltage (r.m.s.)	L1	kV	13.7	14.1	14.0	-	-
	L2	kV	14.2	14.7	14.0	-	-
	L3	kV	14.0	14.5	14.1	-	-
Transient recovery voltage	Voltage u_1	kV	-	-	-	-	-
	Time t_1	μs	-	-	-	-	-
	TRV peak value u_c	kV	41.0	40.0	40.0	-	-
	Time t_3	μs	-	-	-	-	-
	Time delay t_d	μs	-	-	-	-	-
	Rate of rise u_c/t_3	kV/μs	-	-	-	-	-
C-Operation	Voltage of closing device	V	-	94	94	-	-
	Closing time	ms	-	62.9	63.0	-	-
	Pre-arc time	ms	-	-	-	-	-
	Make time	ms	-	62.9	63.0	-	-
O-Operation	Voltage of opening device	V	77	77	77	-	-
	Opening time	ms	61.0	61.3	61.6	-	-
	Arcing time L1	ms	3.8	7.4	6.6	-	-
	L2	ms	8.6	8.4	2.6	-	-
	L3	ms	8.8	3.2	6.8	-	-
	Break time	ms	69.8	69.7	68.4	-	-
Emission of flame/gas/oil, occurrence of NSDD			no	no	no	-	-
Number of valid test			-	-	-	-	-
Test result			P	P	P	-	-

Legend: P: Passed in terms of the applied standard N: Not passed in terms of the applied standard

Remarks: PEHLA 0511Ra / 13 and 14: Tests with reduced values


Condition of test object after test: Switchgear and circuit-breaker were not inspected.




**Oscillogram
PEHLA 0511Ra / 15**

ВЯРНО С ОРИГИНАЛА

6PPE0402




**Oscillogram
PEHLA 0511Ra / 15****ВЯРНО С ОРИГИНАЛА**

18PE0402

327




**Oscillogram
PEHLA 0511Ra / 15**

ВЯРНО С ОРИГИНАЛА

18PE0402




Oscillogram PEHLA 0511Ra / 16




ВЯРНО С ОРИГИНАЛА

16PE0402




329

**Oscillogram
PEHLA 0511Ra / 16**

ВЯРНО С ОРИГИНАЛА

18PE0402



Test Results

Basic Short-Circuit Making and Breaking Tests

Test performed: Basic short-circuit making and breaking tests (T100a)
Date of test: 09th March 2005
Condition of test object before test: As after PEHLA 0511Ra / 16.
Test arrangement: Direct test circuit, circuit-breaker in gas insulated switchgear
Connections to test object: Infeed via copper bars to the cable terminals of the switchgear, short-circuited via copper bars at the busbar connection, short-circuit point earthed via cable.

Test No. PEHLA 0511Ra			19	20	21	-	-	-
Operating sequence and time intervals			O-3min-O-3min-O			-	-	-
Applied voltage	kV		-	-	-	-	-	-
Breaking current (r.m.s.)	L1	kA	18.7	18.6	17.9	-	-	-
	L2	kA	18.2	19.0	18.7	-	-	-
	L3	kA	18.7	18.0	18.8	-	-	-
	Average value	kA	18.5	18.5	18.5	-	-	-
Breaking current - last current loop (peak)	L1	kA	-	-	-	-	-	-
	L2	kA	-	-	-	-	-	-
	L3	kA	-	-	-	-	-	-
Duration of the last current loop	L1	ms	-	-	-	-	-	-
	L2	ms	-	-	-	-	-	-
	L3	ms	-	-	-	-	-	-
DC-component	L1	%	< 20	< 20	< 20	-	-	-
	L2	%	< 20	< 20	< 20	-	-	-
	L3	%	< 20	< 20	< 20	-	-	-
Recovery voltage (r.m.s)	L1	kV	13.6	13.4	13.7	-	-	-
	L2	kV	13.9	13.5	13.9	-	-	-
	L3	kV	13.7	13.8	13.8	-	-	-
Transient recovery voltage	Voltage u_1	kV	-	-	-	-	-	-
	Time t_1	μs	-	-	-	-	-	-
	TRV peak value u_c	kV	39.9	38.9	38.4	-	-	-
	Time t_3	μs	-	-	-	-	-	-
	Time delay t_d	μs	-	-	-	-	-	-
	Rate of rise u_c/t_3	kV/μs	-	-	-	-	-	-
O-Operation	Voltage of opening device	V	121	121	121	-	-	-
	Opening time	ms	46.6	46.9	47.7	-	-	-
	Arcing time L1	ms	5.2	8.4	8.6	-	-	-
	L2	ms	5.2	3.6	8.6	-	-	-
	L3	ms	0.8	8.4	3.8	-	-	-
	Break time	ms	51.8	55.3	56.3	-	-	-
Emission of flame/gas/oil, occurrence of NSDD			no	no	no	A	-	-
Number of valid test			-	-	-	M	-	-
Test result			P	P	P	-	-	-

Legend: P: Passed in terms of the applied standard N: Not passed in terms of the applied standard


Remarks: Before PEHLA 0511Ra / 17: Infeed direction inverted


PEHLA 0511Ra / 17 and 18: Test with reduced values

PEHLA 0511Ra / 19 to 21: Tests for determination of DC-component




Condition of test object after test: Switchgear and circuit-breaker were not inspected.




**Oscillogram
PEHLA 0511Ra / 19**

ВЯРНО С ОРИГИНАЛА


18PE0402




**Oscillogram
PEHLA 0511Ra / 19**

ВЯРНО С ОРИГИНАЛА

16PE0402




**Oscillogram
PEHLA 0511Ra / 20**

ВЯРНО С ОРИГИНАЛА


16PE0402




**Oscillogram
PEHLA 0511Ra / 20**


ВЯРНО С ОРИГИНАЛА


48PE0492



**Oscillogram
PEHLA 0511Ra / 21**


ВАРНО С ОРИГИНАЛА
18PE0402



**Oscillogram
PEHLA 0511Ra / 21**

ВЯРНО С ОРИГИНАЛА

18PE0402



Test Results

Basic Short-Circuit Making and Breaking Tests


Test performed: Basic short-circuit making and breaking tests (T100a)
Date of test: 09th March 2005
Condition of test object before test: As after PEHLA 0511Ra / 21.
Test arrangement: Direct test circuit, circuit-breaker in gas insulated switchgear
Connections to test object: Infeed via copper bars to the cable terminals of the switchgear,
short-circuited via copper bars at the busbar connection, short-circuit point earthed via cable.

Test No. PEHLA 0511Ra			23	24	25	26	27	28
Operating sequence and time intervals		O-3min-O-3min-O-3min-O-3min-O-3min-O-						
Applied voltage	kV	-	-	-	-	-	-	-
Breaking current (r.m.s.)	L1	kA	20.7	20.5	20.6	20.6	20.5	20.5
	L2	kA	20.1	19.8	19.9	20.9	20.5	20.6
	L3	kA	20.7	20.1	20.0	20.5	19.7	19.8
	Average value	kA	20.5	20.1	20.2	20.7	20.2	20.3
Breaking current - last current loop (peak)	L1	kA	36.9	-	-	-	-	-
	L2	kA	-	37.3	37.3	37.3	-	-
	L3	kA	-	-	-	-	36.0	36.0
Duration of the last current loop	L1	ms	12.8	-	-	-	-	-
	L2	ms	-	12.6	12.6	12.6	-	-
	L3	ms	-	-	-	-	12.2	12.2
DC-component	L1	%	32.2	< 20	< 20	< 20	35.7	35.7
	L2	%	< 20	37.8	39.9	37.8	< 20	< 20
	L3	%	< 20	28.3	29.7	28.0	33.7	34.0
Recovery voltage (r.m.s.)	L1	kV	13.9	13.7	13.7	13.7	13.7	13.8
	L2	kV	13.9	13.6	14.1	13.7	14.1	14.0
	L3	kV	14.2	13.5	14.1	14.1	14.0	14.1
Transient recovery voltage	Voltage u_1	kV	-	-	-	-	-	-
	Time t_1	μs	-	-	-	-	-	-
	TRV peak value u_c	kV	40.8	39.6	37.4	41.4	37.4	37.4
	Time t_3	μs	-	-	-	-	-	-
	Time delay t_d	μs	-	-	-	-	-	-
	Rate of rise u_c/t_3	kV/μs	-	-	-	-	-	-
O-Operation	Voltage of opening device	V	121	121	121	121	121	121
	Opening time	ms	47.0	47.3	45.8	44.6	47.0	46.0
	Arcing time L1	ms	3.8	6.6	6.4	6.0	0.8	0.8
	L2	ms	7.8	6.4	8.0	10.2	6.6	6.6
	L3	ms	8.0	0.8	1.8	10.4	6.4	6.6
	Break time	ms	55.0	53.7	53.8	55.0	53.6	52.6
Emission of flame/gas/oil, occurrence of NSDD		no	no	no	no	no	no	no
Number of valid test		-	-	-	-	-	-	-
Test result		P	P	P	P	P	P	P

Legend: P: Passed in terms of the applied standard N: Not passed in terms of the applied standard


Remarks: PEHLA 0511Ra / 22: Test with reduced values.

Condition of test object after test: Switchgear and circuit-breaker were not inspected.


**Oscillogram
PEHLA 0511Ra / 23**

ВЯРНО С ОРИГИНАЛА

18PE0402





339

**Oscillogram
PEHLA 0511Ra / 23**

ВЯРНО С ОРИГИНАЛА

18P20402



**Oscillogram
PEHLA 0511Ra / 24**

ВЯРНО С ОРИГИНАЛА


18PE0402




341




Oscillogram PEHLA 0511Ra / 24




БЯРНО С ОРИГИНАЛА
18P-E9402




**Oscillogram
PEHLA 0511Ra / 25**


ВЯРНО С ОРИГИНАЛА


18PE0402



**Oscillogram
PEHLA 0511Ra / 25**


ВАРИАНТ С ОРИГИНАЛА
БРЕНДОК




**Oscillogram
PEHLA 0511Ra / 26**

ВЯРНО С ОРИГИНАЛА
188E0402




**Oscillogram
PEHLA 0511Ra / 26**


ВЯРНО С ОРИГИНАЛА

**Oscillogram
PEHLA 0511Ra / 27**


ВЯРНО С ОРИГИНАЛА

**Oscillogram
PEHLA 0511Ra / 27**

ВЯРНО С ОРИГИНАЛА


**Oscillogram
PEHLA 0511Ra / 28**

ВЯРНО С ОРИГИНАЛА

**Oscillogram
PEHLA 0511Ra / 28**

ВЯРНО С ОРИГИНАЛА

18PE0402



Test Results

Basic Short-Circuit Making and Breaking Tests

Test performed: Basic short-circuit making and breaking tests (T10)
Date of test: 10th March 2005
Condition of test object before test: As after PEHLA 0511Ra / 28.
Test arrangement: Direct test circuit, circuit-breaker in gas insulated switchgear
Connections to test object: Infeed via copper bars to the busbar connection of the switchgear, short-circuited via copper bar at the cable terminals, short-circuit point earthed via cable.

Test No. PEHLA 0511Ra			29	30	-	-	-
Operating sequence and time intervals		O-0.3s-CO-15s-CO			-	-	-
Applied voltage	kV	-	24.5	24.2	-	-	-
Making current (peak)	L1 kA	-	4.02	3.6	-	-	-
	L2 kA	-	4.85	5.2	-	-	-
	L3 kA	-	5.48	5.3	-	-	-
Breaking current (r.m.s.)	L1 kA	2.21	2.31	2.30	-	-	-
	L2 kA	2.28	2.34	2.28	-	-	-
	L3 kA	2.24	2.31	2.25	-	-	-
	Average value kA	2.24	2.32	2.28	-	-	-
Recovery voltage (r.m.s.)	L1 kV	13.8	14.5	14.3	-	-	-
	L2 kV	14.0	14.6	14.2	-	-	-
	L3 kV	13.7	14.6	14.5	-	-	-
Transient recovery voltage	Voltage u_1 kV	-	-	-	-	-	-
	Time t_1 μs	-	-	-	-	-	-
	TRV peak value u_c kV	46.5	48.5	44.0	-	-	-
	Time t_3 μs	65.0	65.0	65.0	-	-	-
	Time delay t_d μs	-	-	-	-	-	-
	Rate of rise u_c/t_3 kV/ μs	0.715	0.746	0.677	-	-	-
C-Operation	Voltage of closing device V	-	94	94	-	-	-
	Closing time ms	-	63.4	64.4	-	-	-
	Pre-arcning time ms	-	-	-	-	-	-
	Make time ms	-	63.4	64.4	-	-	-
O-Operation	Voltage of opening device V	77	77	77	-	-	-
	Opening time ms	61.3	63.1	60.4	-	-	-
	Arcing time L1 ms	3.8	2.2	9.4	-	-	-
	L2 ms	9.0	7.0	9.4	-	-	-
	L3 ms	9.0	7.0	4.0	-	-	-
	Break time ms	70.3	70.1	69.8	-	-	-
Emission of flame/gas/oil, occurrence of NSDD		no	no	no	-	-	-
Number of valid test		-	-	-	-	-	-
Test result		P	P	P	-	-	-


Legend: P: Passed in terms of the applied standard

N: Not passed in terms of the applied standard

Remarks: PEHLA 0511Ra / 31: No-load operation


Condition of test object after test: The condition of the circuit-breaker after the test series corresponds to the conditions given in clause 6.102.9.4 of IEC 62271-100 / Ed. 1.1 / 2003-05. Visual inspection, no-load measurements before and after the test series, measurements of the resistance of the main circuit before and after the test series as well as a power frequency voltage check according to clause 6.2.11 of IEC 62271-100 / Ed. 1.1 / 2003-05 (with 80% and 100% of the rated power frequency withstand voltage), after the test series are carried out to prove the condition of the circuit-breaker.




**Oscillogram
PEHLA 0511Ra / 29**


ВЯРНО С ОРИГИНАЛА


18PE0402




**Oscillogram
PEHLA 0511Ra / 29****ВЯРНО С ОРИГИНАЛА**

18PE0402




**Oscillogram
PEHLA 0511Ra / 29**

**Oscillogram
PEHLA 0511Ra / 30**

ВЯРНО С ОРИГИНАЛА



**Oscillogram
PEHLA 0511Ra / 30****ВЯРНО С ОРИГИНАЛА**

Test Results

No-load Operations

Test performed: No-load operation

Date of test: 09th March 2005

Condition of test object before test: As after Test PEHLA 0511Ra / 05.

Test No. PEHLA 0511Ra			06		06A		06B	
Operating sequence			O – 0.3s – CO		O – 0.3s – CO		O – 0.3s – CO	
C-Operation	Voltage of closing device	V	-	110	-	121	-	94
	Closing time	L1	ms	-	59.6	-	57.6	-
		L2	ms	-	59.8	-	57.8	-
		L3	ms	-	59.6	-	57.4	-
O-Operation	Voltage of opening device	V	110	110	121	121	77	77
	Opening time	L1	ms	46.0	45.6	43.2	43.8	61.0
		L2	ms	45.8	45.4	43.0	43.6	60.8
		L3	ms	46.0	45.6	43.2	43.8	60.8

Remarks: The voltage values correspond to 100% of the rated supply voltage in Test PEHLA 0511Ra / 06, 110% in Test PEHLA 0511Ra / 06A and 70% (O) resp. 85% (C) in Test PEHLA 0511Ra / 06B.

Test performed: No-load operation


Date of test: 10th March 2005

Condition of test object before test: As after Test PEHLA 0511Ra / 30.

Test No. PEHLA 0511Ra			31		31A		31B	
Operating sequence			O – 0.3s – CO		O – 0.3s – CO		O – 0.3s – CO	
C-Operation	Voltage of closing device	V	-	110	-	121	-	94
	Closing time	L1	ms	-	60.6	-	58.6	-
		L2	ms	-	60.6	-	58.6	-
		L3	ms	-	60.0	-	58.0	-
O-Operation	Voltage of opening device	V	110	110	121	121	77	77
	Opening time	L1	ms	46.2	46.0	43.6	43.0	58.8
		L2	ms	45.8	45.6	43.2	42.6	58.4
		L3	ms	46.4	46.2	43.8	43.4	59.0


Remarks: The voltage values correspond to 100% of the rated supply voltage in Test PEHLA 0511Ra / 31, 110% in Test PEHLA 0511Ra / 31A and 70% (O) resp. 85% (C) in Test PEHLA 0511Ra / 31B.


ВЯРНО С ОРИГИНАЛА

**Oscillogram
PEHLA 0511Ra / 06**

ВЯРНО С ОРИГИНАЛА


18PE0402




**Oscillogram
PEHLA 0511Ra / 06A**

ВЯРНО С ОРИГИНАЛА


18PE0402




**Oscillogram
PEHLA 0511Ra / 06B**


ВЯРНО С ОРИГИНАЛА

T8PE0402



Key


**Oscillogram
PEHLA 0511Ra / 31****ВЯРНО С ОРИГИНАЛА**

**Oscillogram
PEHLA 0511Ra / 31A**

ВЯРНО С ОРИГИНАЛА

18PE0402



**Oscillogram
PEHLA 0511Ra / 31B**

ВЯРНО С ОРИГИНАЛА

Test Results

Voltage Test as a Condition Check

Test performed: Voltage test as a condition check according to IEC 62271-100
Subcl. 6.2.11

Date of test: 10th March 2005

Condition of test object before test: As after test PEHLA 0511Ra / 31

Test arrangement: High voltage test transformer connected to the contact arms of the circuit-breaker

Connections to test object: Connection of high voltage to one contact arm of the open poles via copper wire Ø 0.5 mm, the other contact arm earthed via copper wire Ø 0.5 mm

Test arrangement			Test voltage kV	Result
Condition	Voltage applied to	Earthed		
-	-	-	40.0 – 1 min	ok
-	-	-	50.0 – 1 min	ok

Remarks: -

Condition of test object after test: No visible or functional change or damage.

ВЯРНО С ОРИГИНАЛА

Measurement of the Resistance of the Main Circuit

Test performed: Measurement of the Resistance of the Main Circuit

Date of test: 09th March 2005

Condition of test object: As after Test PEHLA 0511Ra / 06.

Measurement before test No. PEHLA 0511Ra / 07			
Ambient air temperature:		21.0 °C	
Resistance measurement at direct current of:		100 A (d.c.)	
Measurement between points (see sheet 70)		Resistance of the main circuit μΩ	
L1		L2	L3
1 - 2	26.2	27.1	26.2
-	-	-	-
-	-	-	-

Remarks: -

Date of test: 10th March 2005

Condition of test object: As after Test PEHLA 0511Ra / 30.


Measurement after test No. PEHLA 0511Ra / 31			
Ambient air temperature:		21.0 °C	
Resistance measurement at direct current of:		100 A (d.c.)	
Measurement between points (see sheet 70)		Resistance of the main circuit μΩ	
L1		L2	L3
1 - 2	32.2	36.8	29.7
-	-	-	-
-	-	-	-

Remarks: -

ВЯРНО С ОРИГИНАЛА

Measurement of the Resistance of the Main Circuit

Measurement points



ВЯРНО С ОРИГИНАЛА

33PE0402

366

Photos

Photo No. 01
Before Test no. PEHLA 0511Ra / 03




Photo No. 02
After Test no. PEHLA 0511Ra / 05

ВЯРНО С ОРИГИНАЛА


Photos

Photo No. 03
After Test no. PEHLA 0511Ra / 31





Photo No. 04
After Test no. PEHLA 0511Ra / 31

ВЯРНО С ОРИГИНАЛА

16PE0402





Deutscher
Akkreditierungs
Rat

Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. MZ 235 A 01

Sheet 1

Issued by an Accredited Laboratory
corresponding to EN 45001

Copy-No. 02e

Test Object	Metal-clad air-insulated switchgear panel from a 24 kV switchgear type ZS1.2 ($T = 1000$ mm), drawing-no. GCE 8010459 R0101, with withdrawable vacuum circuit-breaker type VD4 2420-25 and with earthing switch type EK6-2406-275	
	Ratings of the panel:	
Rated voltage	U	24 kV
Rated normal current (tee-off)	I _n	1600 A
Rated frequency	f	50/60 Hz
Rated short-time withstand current	I _{th}	25 kA
Rated peak withstand current	I _p	63 kA
Rated duration of short-circuit current	t _{th}	3 s
Rated short-circuit breaking capacity at 24 kV	I _{sc}	25 kA
Manufacturer	ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen / Germany	
Tests performed	Mechanical operation test comprising 50 operations of the vacuum circuit-breaker, 50 operations of the earthing switch, 50 manual operations of the withdrawable part and 25 insertions and 25 removals of the removable part. The interlocks of the circuit-breaker, the earthing switch, the withdrawable part and the removable part were tested in the respective position. Test procedure and test parameters were based on IEC 60298/3rd. Ed./1990/Clause 6.102	
Test Specification	IEC 60298/3rd. Ed./1990	
Test Results	All switching devices, the withdrawable part, the removable part and the mechanical interlocks passed the mechanical operation test successfully. They were in proper working order and the effort to operate them was practically the same before and after the test.	
Test Date	07 th September 2000	
Client	ABB Calor Emag Mittelspannung GmbH 40472 Ratingen / Germany	

18th October 2000
Date of Issue

Laboratory Manager

Test Engineer


Total Number of Sheets: 10 Sheets

This test report refers exclusively to the object tested.
ABB Calor Emag Mittelspannung GmbH is certified according
to DIN ISO 9001 by DQS under Reg. No. 373-03

ABB Calor Emag Laboratories Ratingen are accredited according to
EN 45001 by DATech under Reg.No. DAT - P - 032/93

With the exception of the cover sheet and any subsequent sheets mentioned thereon, this document may not be partly copied without written consent of ABB
Calor Emag Mittelspannung GmbH Ratingen.

ABB Calor Emag Mittelspannung GmbH Ratingen
Mechanical Testing Laboratory



Oberhausener Str.33
D - 40472 Ratingen

Phone: +49 (0) 21 02 121371
Fax: +49 (0) 21 02 121713



Deutscher
Akkreditierungs
Rat

Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. MZ 235 A 01

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 2

Contents

Sheet

Test Report - Cover Sheet	1
Test Results - Comments on Test Object	1
Contents	2
1. Technical Data of Test Objects	3
Drawings: GCE 8010459 R0101 (ZS1.2 panel)	6
GCE 7000162 R1104 (Withdrawable vacuum circuit-breaker) ..	7
GCE 7169312 R0118 (Earthing switch)	8
2. Test Location and Set-up	9
3. Mechanical Operation Test	10

ВЯРНО С ОРИГИНАЛА





Deutscher
Akkreditierungs
Rat

Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories

Sheet 3

TEST REPORT No. MZ 235 A 01

Issued by an Accredited Laboratory
corresponding to EN 45001

1. Technical Data of Test Object

(Ratings assigned by the manufacturer)

Switchgear

Test Object: Metal-clad air-insulated switchgear panel from a 24 kV switchgear

Type: ZS1.2

Manufacturer: ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen/ Germany

Serial-No.: 7550027/2015/00 **Year of manufacture:** 2000

Drawing Nos.: GCE 8010459 R0101

Rated voltage	24	kV
Rated lightning impulse withstand voltage	125	kV
Rated power frequency withstand voltage	50	kV

Rated frequency	50/60	Hz
Rated normal current busbar	2500	A
Rated normal current circuit	1600	A


Rated peak withstand current	63	kA
Rated short-time withstand current	25	kA
Rated duration of short-circuit	3	s

Prospected values under internal-arc conditions:

Peak withstand current	63	kA
Short-time withstand current	25	kA
Short-circuit duration	3	s

Date of receipt of test object: 24th August 2000

ВЯРНО С ОРИГИНАЛА





Deutscher
Akkreditierungs
Rat

Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. MZ 235 A 01

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 4

1. Technical Data of Test Object

(Ratings assigned by the manufacturer)

Switching Device

Test Object: Withdrawable vacuum circuit-breaker

Type: VD4 2420-25

Vacuum interrupter: VG4S

Manufacturer: ABB Calor Emag Mittelspannung GmbH

Serial-No.: 7008269/4002/00 **Year of manufacture:** 2000

Drawing Nos.:	Withdrawable breaker:	GCE 7000162 R1104
	Operating mechanism:	GCE 7179610 R0104
	Pole part:	GCE 7005757 R0122
	Interrupters:	GCE 7005535 R0102
	Pole Centres:	275 mm

Rated voltage	24	kV
Rated lightning impulse withstand voltage	125	kV
Rated power frequency withstand voltage	50	kV


Rated frequency	50/60	Hz
Rated normal current	2000	A
Rated short-circuit breaking current	25	kA
Rated short-circuit making current	63	kA
DC-component	30	%
Pole factor	1.5	--

Rated peak withstand current	63	kA
Rated short-time withstand current	25	kA
Rated duration of short-circuit	3	s
Rated operating sequence	O-0,3s-CO-3min-CO	
Rated times of circuit-breaker:		
- opening time	≤ 45	ms
- closing time	approx. 60	ms

Number of poles	3
Number of units per pole	1

Date of receipt of test object: 24th August 2000

ВЪРНО С ОРИГИНАЛА





Deutscher
Akkreditierungs
Rat

Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. MZ 235 A 01

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 5

1. Technical Data of Test Object

(Ratings assigned by the manufacturer)

Switching Device

Test Object: Earthing switch

Type: EK6-2406-275

Manufacturer: ABB Calor Emag Mittelspannung GmbH

Serial-No.: 06/052/00 **Year of manufacture:** 2000

Drawing Nos.: Earthing switch: GCE 7169312 R0118
Pole Centres: 275 mm

Rated voltage	24	kV
Rated lightning impulse withstand voltage	125	kV
Rated power frequency withstand voltage	50	kV
Rated short-circuit making current	63	KA
Rated peak withstand current	63	KA
Rated short-time withstand current	25	KA
Rated duration of short-circuit	3	s

Date of receipt of test object: 24th August 2000

БЯРНО С ОРИГИНАЛА



Deutscher
Akkreditierungs
Rat

ABB Calor Emag Laboratories

ABB


Reg.-Nr.

DAT-P-032/93

TEST REPORT No. MZ 235 A 01

Sheet 6

Issued by an Accredited Laboratory
corresponding to EN 45001




БЯРНО С ОРИГИНАЛА

MZ 235 A 01



Deutscher
Akkreditierungs
Rat

ABB Calor Emag Laboratories



ABB

Reg.-Nr.
DAT-P-032/93

TEST REPORT No. MZ 235 A 01

Sheet 7

Issued by an Accredited Laboratory
corresponding to EN 45001





Deutscher
Akreditierungs
Rat


ABB Calor Emag Labs

Reg.-Nr.
DAT-P-032/93

TEST REPORT No. MZ 235 A 01

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 8





Deutscher
Akkreditierungs
Rat

Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. MZ 235 A 01

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 9

2. Test Locations and Set-up



The test was performed in the Mechanical Testing Laboratory

of ABB Calor Emag Mittelspannung GmbH
Dept. LM in Ratingen

at an ambient temperature of approx. 20°C.

Test job no.: 7550027_024A

Test engineer: Koal





Deutscher
Akkreditierungs
Rat

Reg.-Nr.
DAT-P-032/93

ABB Calor Emag Laboratories

ABB

TEST REPORT No. MZ 235 A 01

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 10


3. Mechanical Operation Test

List of interlocks:

1. Withdrawable part in test-position
 - Circuit-breaker ON: prevented to move the withdrawable part in service-position
2. Withdrawable part in service-position
 - Circuit-breaker ON: prevented to move the withdrawable part in test-position
3. Withdrawable part between service and test position:
 - prevented to switch ON the circuit-breaker
4. Withdrawable part in test-position
 - Circuit-breaker OFF and earthing switch ON: prevented to move the withdrawable part in service-position
5. Withdrawable part in test-position
 - circuit-breaker ON and earthing switch ON: prevented to move the withdrawable part in service-position
6. Withdrawable part not in test-position
 - prevented to switch ON the earthing switch
7. Withdrawable part not in test-position
 - prevented to remove the removable part

All the above mentioned interlocks were checked. For this the circuit-breaker, the earthing switch and the withdrawable part were operated 50 times and the removable part was removed and inserted 25 times.

ВЯРНО С ОРИГИНАЛА



PEHLA
GESELLSCHAFT FÜR ELEKTRISCHE HOCHLEISTUNGSPRÜFUNGEN
Member of the Short-Circuit-Testing Liaison (STL)

Test Report

Report No.: 0311 Ra Copy No.: 1 Contents: 24 Sheets

Equipment under test: Vacuum circuit-breaker type VD4 24.12.20

Manufacturer:

Circuit-breaker: ABB SACE T.M.S. S.p.A., 4 – 24044 Dalmine (BG), Italy

Pole parts inclusive
vacuum interrupters: ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen, Germany

Client: ABB T&D SpA, Divisione Sace T.M.S, 4 – 24044 Dalmine (BG), Italy

Testing station: PEHLA - Testing Laboratory Ratingen

Date of test: 03rd February 2003 – 24th February 2003

Applied test specifications:

IEC 62271-100, 1st Ed, 2001-05, clause 6.101.1 and 6.101.2

IEC 60694, Ed.2.2, 2002-01

Tests performed:

In accordance with the requirements of class M2, 10 000 mechanical operating cycles without voltage on or current in the main circuit were carried out with the vacuum circuit-breaker of type VD4 24.12.20 to demonstrate the mechanical reliability.

Test results:

No changes impairing the function of the circuit-breaker were noted after the endurance test.
The vacuum circuit-breaker type VD4 24.12.20 passed the mechanical type test successfully.



GESELLSCHAFT FÜR ELEKTRISCHE
HOCHLEISTUNGSPRÜFUNGEN

Technical Committee


Mannheim, 24th February 2003

The test results relate only to the items tested.

Without a written permission of PEHLA it is not allowed to make reproduction in extracts of this document. Copying the cover sheet accompanied by sheet 2 and the sheets mentioned here is an exception.

D3PE0001

BAPRO C OPTIMAIA



DAT-P-032/03

Accreditation

The PEHLA-Testing Laboratory Ratingen has been approved by the DATech (German accreditation body for technology) according to DIN EN ISO/IEC 17025 for tests in the field of high-voltage switchgear and controlgear and power engineering equipment (Registration-No. DAT-P-032/93).

Under reference to DIN EN ISO/IEC 17025 PEHLA states the following:

- The accreditation of the PEHLA-Testing Laboratory or any of its test reports by themselves in no way constitute or imply product approval by DATech or any other body.
- If someone refers to a test in an accredited PEHLA-Testing Laboratory this reference shall include the accreditation body, i.e. DATech, the relevant scope of the accreditation and the appropriate registration number.

STL-Member

PEHLA is foundation-member of the Short-Circuit Testing Liaison (STL) which has been founded in March 1969. STL is a forum for the international co-operation of the testing organisations with the further full members ASTA (GB), CESI (I), ESEF (F), KEMA (NL), SATS (N, S, AIR) and STLNA (USA). In the Framework of EC, STL has been recognised in 1992 by EOTC as agreement group.

PEHLA-Documents**A Certificate**

Is issued for type tests which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test.

For these tests the equipment under test must be clearly identified by technical description, drawings and additional specifications.

A Test Document

Is issued for parts of type tests which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of test.

For these tests the equipment under test must be clearly identified by technical description, drawings and additional specifications.

A Test Report

Is issued for all other tests which have been carried out according to specifications, standards or "PEHLA-Richtlinien" (PEHLA Guides) and/or clients instructions.

Similarly, this test report contains all test results, details of the conditions under which the tests were carried out, also details relating to the behaviour of the equipment during test, and its condition after the tests.

Addresses:

Office: PEHLA-Geschäftsstelle
Hallenweg 40
68219 Mannheim; Germany

Testing Station: PEHLA-Testing Laboratory Ratingen
Oberhausener Str. 33
40472 Ratingen; Germany

Manufacturer: ABB SACE T.M.S. S.p.A.
Via Friuli
4 - 24044 Dalmine (BG), Italy

ABB Calor Emag Mittelspannung GmbH
Oberhausener Str. 33
40472 Ratingen, Germany

Client: ABB SACE T.M.S. S.p.A.
Via Friuli
4 - 24044 Dalmine (BG), Italy

ВЯРНО С ОРИГИНАЛА




Table of Contents

	<u>Sheet No.</u>
Cover sheet	1
Accreditation	2
Table of Contents	3
List of Test Participants	4
Technical Data of Test Object	5
List of Drawings	6
Drawing No. TN. 7410	7
Drawing No. 510507	8
Drawing No. GCE7004730	9
Details on Performance of the Test	10
Results of Measurements before the Mechanical Endurance Test	11 to 15
Results of Measurements during the Mechanical Endurance Test	16
Results of Measurements after the Mechanical Endurance Test	17 to 21
Evaluation of the measurements before and after the test program	22
Measuring Instrument Record	23
Photo of the Test Object	24

ВЯРНО С ОРИГИНАЛА

List of Test Participants

Representatives of the Test Committee:

Mr. G. Heit PEHLA-Testing Laboratory Mannheim
Mr. U. Köster PEHLA-Testing Laboratory Ratingen

Test Operator:

Mr. M. Schöttler PEHLA-Testing Laboratory Ratingen
Mr. J. Mendorf PEHLA-Testing Laboratory Ratingen
Mr. A. Piglas PEHLA-Testing Laboratory Ratingen

Representatives of the Client:

Mr. S. Magoni ABB SACE T.M.S. S.p.A., Italy

ВЯРНО С ОРИГИНАЛА



Kleef

Technical Data of Test Object**Switching Device – Circuit-Breaker**

Ratings assigned by the manufacturer

Test Object:	Vacuum circuit-breaker
Type:	VD4 24.12.20
Manufacturer:	
Circuit-breaker:	ABB SACE T.M.S. S.p.A., 4 – 24044 Dalmine (BG), Italy
Pole parts including vacuum Interrupters:	ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen, Germany
Serial-No.:	AD00003052
Drawing No.:	TN. 7410 (circuit-breaker)
Vacuum interrupter:	Type: VG4, L1: No. 1154/3, GCE 7004730R0105 (pole part)
	Year of manufacture: 2003
Drawing No.:	L2: No. 1135/3, L3: No. 0288/3
Rated voltage	24 kV
Rated lightning impulse withstand voltage	125 kV
Rated switching impulse withstand voltage	- kV
Rated power frequency withstand voltage	50 kV
Rated frequency	50 Hz
Rated normal current	1250 A
Rated peak withstand current	50 kA
Rated short-time withstand current	20 kA
Rated duration of short-circuit	3 s
Rated short-circuit breaking current at 12 kV	20 kA
D.C. component	30 %
Rated short-circuit making current at 12 kV	50 kA
Rated transient recovery voltage:	
Peak value	20.6 kV
Rate of rise	0.34 kV/μs
First-pole-to-clear-factor	1.5
Rated operating sequence	O-0.3s-CO-3min-CO
Arc extinguishing medium	vacuum
Number of poles	3
Number of units per pole	1
Rated opening time	≤ 45 ms
Rated closing time	approx. 60 ms
Rated voltage of trip coil	110 V-DC
Rated voltage of closing coil	110 V-DC
Rated supply voltage	220 V-DC
Rated frequency of supply voltage	- Hz

Essential characteristics and installed devices:

The circuit-breaker was not equipped with the auxiliary switch BS2 for the spring-charged signal.
Motor Drive Type 701 921/803, Serial No. CA2 7GL 02 C (EL1).

Date of receipt of test object: 3rd February 2003

ВЯРНО С ОРИГИНАЛА



List of Drawings


The manufacturer has guaranteed, that the equipment submitted for test has been manufactured in full accordance with the following drawings. PEHLA has verified that these drawings adequately represent the equipment tested. These drawings have been stamped and signed by PEHLA representatives and are kept


- with the test documents at the test laboratory.
 at the client.

The drawings contained in this document are identical with the checked, stamped and signed drawings.

Drawing-No.	Revision	Title	Additional remarks
TN.7410	M5234 02-10-10	Vaccum Circuit Breaker Type VD4 24kV 630-1250A	Included in test report
510507	50538 02-12-13	Assieme Comando Operating Mechanism Assembly	Included in test report
GCE7004730	09	Pol vst. VD4P 24kV 1250A Pole complete VD4P 24kV 1250A	Included in test report
Parts list			
510564		Ass. molle di ch. com. EL1	—
510507		Assieme comando EL1	—
GCE7004730R0104		Pol vst. 40,7 2400N H310 2412-20 VG4	—


БЛЯНО С ОРИГИНАЛА






БАРХО С ОРИГИНАЛА

Марка



Report No.: 0311-Ra



ВЪРНО С ОРИГИНАЛА

Details on Performance of the Test

Prior to the endurance test, the following electrical and mechanical data were determined by measurements on the circuit-breaker and its auxiliary systems:

- a) closing time (5 times *)
 - b) opening time (5 times *)
 - c) time spread between units of one pole - not applicable
 - d) time spread between poles (5 times *)
 - e) charging time of the motorized operating mechanism (5 times *)
 - f) consumption of the motorized operating mechanism (5 times *)
 - g) consumption of the tripping devices (5 times *)
 - h) duration of opening and closing command impulse
 - i) tightness
 - j) gas densities or pressures - not applicable
 - k) resistance of the main circuit (5 times *)
 - l) time-travel chart (5 times *)
 - m) other important characteristics
 - contact travel
 - check of vacuum of interrupters
 - verification of the rated operating sequence (refer to clause 6.101.2.5 a))
 - ambient atmospheric conditions
- *) 5 times at rated, minimum and maximum supply voltage.

The subsequent endurance test comprising 10 000 mechanical operating cycles was structured as follows and carried out five times:

500 operating cycles with operating sequence C - 90 s - O - 90 s at the minimum supply voltage of closing and opening devices and motorized operating mechanism and the minimum pressure for operation

500 operating cycles with operating sequence C - 90 s - O - 90 s at the rated supply voltage of closing and opening devices and motorized operating mechanism and the rated pressure for operation

500 operating cycles with operating sequence C - 90 s - O - 90 s at the maximum supply voltage of closing and opening devices and motorized operating mechanism and at the maximum pressure for operation

250 operating cycles with operating sequence C - 90 s - O - 300 ms - CO - 270 s at the rated supply voltage of closing and opening devices and motorized operating mechanism and at the rated pressure for operation

After each series of 2 000 operating sequences the operating characteristics: a), b), d), e), f) and l) as listed above have been recorded.

Following the endurance test, the measurements carried out before the mechanical endurance test were measured again for comparison. Check, whether the travel characteristics fell within the envelope curves, taken before the endurance test.

ДОДУЧО С ПОВІДОМАНЯМ

Results of measurements before the mechanical endurance test

Number of operations: counter: 00035

e/b) Opening and closing time:

Rated supply voltage of closing and opening devices: $U_a = 110 \text{ V DC}$

Operating time [ms]

measured during the 5 x CO operations

- at the minimum supply voltage

- at the rated supply voltage

- at the maximum supply voltage

U [V]	t _o (opening)			t _c (closing)		
	0.7 x U _a	1.0 x U _a	1.1 x U _a	0.85 x U _a	1.0 x U _a	1.1 x U _a
t [ms]	80.4	53.1	50.4	72.3	66.0	63.3
	79.8	53.4	50.1	72.3	66.3	63.3
	79.8	53.4	50.1	72.3	66.0	63.3
	79.8	53.4	50.1	72.3	66.0	63.6
	80.4	53.4	50.1	72.3	66.0	63.3

e/d) Time spread between the breaker poles:

The time spread between the breaker poles on closing and on opening of the circuit-breaker was measured to < 2 ms.

e/f) Charging time and power consumption of the motorized operating mechanism:

Rated supply voltage of motor charging: $U_a = 220 \text{ V DC}$

Measured values:

Measured during the 5 x CO operations


- at the minimum supply voltage

- at the rated supply voltage

- at the maximum supply voltage

motor voltage	charging time after O-C operation [s]					current consumption [A]					power consumption [W]				
	U = 0.85 x U _a = 187 V DC	U = 1.0 x U _a = 220 V DC	U = 1.1 x U _a = 242 V DC	U = 0.85 x U _a = 187 V DC	U = 1.0 x U _a = 220 V DC	U = 1.1 x U _a = 242 V DC	U = 0.85 x U _a = 187 V DC	U = 1.0 x U _a = 220 V DC	U = 1.1 x U _a = 242 V DC	U = 0.85 x U _a = 187 V DC	U = 1.0 x U _a = 220 V DC	U = 1.1 x U _a = 242 V DC	U = 0.85 x U _a = 187 V DC	U = 1.0 x U _a = 220 V DC	
U = 0.85 x U _a = 187 V DC	3.57	3.71	3.71	3.78	3.71	0.95	0.97	0.98	0.98	0.97	178	181	183	183	181
U = 1.0 x U _a = 220 V DC	2.94	3.00	2.94	2.96	2.97	0.99	0.98	0.96	0.99	0.98	218	216	211	218	216
U = 1.1 x U _a = 242 V DC	2.59	2.54	2.53	2.53	2.50	1.00	0.99	0.99	0.98	0.97	242	240	240	237	234

BRPHO С ОРИГИНАЛА



Alley

(g) Consumption of the tripping devices:

Measured during the 5 x CO operations

at the minimum supply voltage

at the rated supply voltage

at the maximum supply voltage

	Shunt-release ON YC					Shunt-release OFF YO1				
Rated operating voltage, U _r	110 V DC					110 V DC				
Current at minimum supply voltage [A]	1.24	1.24	1.24	1.24	1.24	0.90	0.92	0.92	0.92	0.92
Current at rated supply voltage [A]	1.52	1.56	1.52	1.52	1.52	1.24	1.20	1.20	1.24	1.20
Current at maximum supply voltage [A]	1.68	1.72	1.72	1.72	1.68	1.36	1.36	1.36	1.36	1.36

(h) Duration of opening and closing command impulse:

Measured during the 5 x CO operations

at the minimum supply voltage



at the rated supply voltage

at the maximum supply voltage

	Shunt-release ON YC					Shunt-release OFF YO1				
Duration of command impulse at minimum supply voltage [ms]	74.6	75.0	74.7	74.7	74.7	80.7	80.1	80.4	84.9	80.4
Duration of command impulse at rated supply voltage [ms]	70.5	69.6	69.3	69.3	69.3	54.9	54.9	54.9	54.9	54.9
Duration of command impulse at maximum supply voltage [ms]	67.2	67.2	67.5	67.5	67.5	52.5	52.2	52.2	51.9	52.2

(k) Resistance of the main conductors:

Measuring points:



БЯРНО С ОРИГИНАЛА

Uleg

Contact resistance measured during the 5 x CO operations at the minimum supply voltage of the coils:

Measuring points	L1 $\mu\Omega$					L2 $\mu\Omega$					L3 $\mu\Omega$				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1-2	16.9	16.9	16.9	17.0	17.0	16.6	16.6	16.6	16.6	17.1	17.2	17.2	17.2	17.2	17.2

Contact resistance measured during the 5 x CO operations at the rated supply voltage of the coils:

Measuring points	L1 $\mu\Omega$					L2 $\mu\Omega$					L3 $\mu\Omega$				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1-2	16.9	16.9	16.9	16.9	16.9	16.6	16.6	16.6	16.6	17.2	17.2	17.2	17.2	17.2	17.2

Contact resistance measured during the 5 x CO operations at the maximum supply voltage of the coils:

Measuring points	L1 $\mu\Omega$					L2 $\mu\Omega$					L3 $\mu\Omega$				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1-2	17.0	16.9	17.0	17.0	17.0	16.6	16.6	16.6	16.6	16.7	17.2	17.2	17.2	17.2	17.2

i) Time-travel chart with opening and closing speed: See diagram 1.1 and 1.2

Speed in [m/s]: $U_a = 110 \text{ V DC}$
at $U = 1.0 \times U_a$

	V_{O1}	V_c
L2	1.18	1.35

The deviations from the measured mechanical time travel charts are in the allowable limits of the reference mechanical travel characteristics.

m) Other important characteristics:

- Contact travel:

	L1	L2	L3
Total Travel [mm]	15.0	15.0	15.1
Cont.-travel [mm]	11.3	11.3	11.2
Contact-spring travel [mm]	3.7	3.7	3.9

Check of vacuum of interrupters:

60 KV DC ok

- Verification of the rated operating sequence:


O-0.3s-CO-3min-CO at rated voltage ok

- Ambient atmospheric conditions:

Date: 04th February 2003, ambient air temperature: approx. 22°C

БЯРДО С ОРИГИНАЛА




Diagram 1.1: Measurement of the operating speed before the mechanical endurance test


Measuring point: Insulated coupling rod in phase L2

Operating speed measured: $V_c = 0.97 \text{ m/s}$ at $U = 1.0 \times U_a$

БЯРНО С ОРИГИНАЛА




№1

Diagram 1.2: Measurement of the operating speed before the mechanical endurance test

Measuring point: Insulated coupling rod in phase L2

Operating speed measured: $V_{01} = 1.18 \text{ m/s}$ $V_{02} = 1.35 \text{ m/s}$ at $U = 1.0 \times U_a$

БАРХО С ОРИГИНАЛА



Results of measurements during the mechanical endurance test

a/b) Opening and closing time:

Operating time [ms] $U_a = 110 \text{ V DC}$	U [V]	t_{o1} (opening)			t_c (closing)		
		$0.7 \times U_a$	$1.0 \times U_a$	$1.1 \times U_a$	$0.85 \times U_a$	$1.0 \times U_a$	$1.1 \times U_a$
Number of operations: 2 000	t [ms]	82.2	53.7	50.4	72.0	66.0	63.0
Number of operations: 4 000	t [ms]	79.5	53.7	50.4	72.9	66.3	63.3
Number of operations: 6 000	t [ms]	78.0	53.4	50.4	72.9	66.6	64.2
Number of operations: 8 000	t [ms]	78.6	53.7	50.7	72.9	66.6	64.0

d) Time spread between the breaker poles:

The time spread between the breaker poles on closing and on opening of the circuit-breaker was measured to < 2 ms.

e) Charging time of the motorized operating mechanism:

	charging time for O1-C [s]		
Motor voltage: $U_a = 220 \text{ V DC}$	$U = 0.85 \times U_a$ $= 187 \text{ V DC}$	$U = 1.0 \times U_a$ $= 220 \text{ V DC}$	$U = 1.1 \times U_a$ $= 242 \text{ V DC}$
Number of operations: 2 000	3.64	2.99	2.47
Number of operations: 4 000	3.87	3.12	2.68
Number of operations: 6 000	3.80	3.06	2.69
Number of operations: 8 000	3.81	3.03	2.65

m) Other important characteristics - contact travel:

Contact travel in L2	Total Travel [mm]
Number of operations: 2 000	14.8
Number of operations: 4 000	14.7
Number of operations: 6 000	14.7
Number of operations: 8 000	14.7

l) Time travel chart with opening and closing speed:

Speed in [m/s]; at $U_a = 110 \text{ V DC}$ L2	V_{o1}		V_c
	8.25	6.6 mm	
Number of operations: 2 000	1.12	1.29	0.91
Number of operations: 4 000	1.11	1.29	0.91
Number of operations: 6 000	1.08	1.24	0.91
Number of operations: 8 000	1.13	1.32	0.93

The deviations from the measured mechanical time travel charts are in the allowable limits of the reference mechanical travel characteristics.

BRPHOC OPITWHAJA



Results of measurements after the mechanical endurance test

Number of operations: counter: 10 199

(b) Opening and closing time:

Rated supply voltage of closing and opening devices: $U_a = 110 \text{ V DC}$

Operating time [ms]

measured during the 5 x CO operations
at the minimum supply voltage
at the rated supply voltage
at the maximum supply voltage

U [V]	t_o (opening)			t_c (closing)		
	$0.7 \times U_a$	$1.0 \times U_a$	$1.1 \times U_a$	$0.85 \times U_a$	$1.0 \times U_a$	$1.1 \times U_a$
	80.1	55.5	50.7	73.5	67.5	63.3
	79.8	54.0	51.0	73.5	67.5	63.3
t [ms]	80.1	55.2	51.6	73.5	66.3	63.9
	79.8	54.0	51.0	74.1	66.6	63.9
	79.2	53.4	50.7	72.9	67.5	64.2

(d) Time spread between the breaker poles:

The time spread between the breaker poles on closing and on opening of the circuit-breaker was measured to < 2 ms.

(e/f) Charging time and power consumption of the motorized operating mechanism:

Rated supply voltage of motor charging: $U_a = 220 \text{ V DC}$

Measured values:

Measured during the 5 x CO operations


at the minimum supply voltage

at the rated supply voltage

at the maximum supply voltage

motor voltage	charging time after O-C operation [s]					current consumption [A]					power consumption [W]				
	$U = 0.85 \times U_a$ $= 187 \text{ V DC}$	3.60	3.78	3.80	3.86	3.83	0.93	0.92	0.95	0.94	0.93	174	172	178	176
$U = 1.0 \times U_a$ $= 220 \text{ V DC}$	3.03	2.86	2.83	2.90	2.93	0.94	0.93	0.92	0.94	0.95	207	205	202	207	209
$U = 1.1 \times U_a$ $= 242 \text{ V DC}$	2.59	2.71	2.69	2.65	2.68	0.90	0.96	0.96	0.95	0.96	218	232	232	230	232

BRUNNEN OPWIRKAMA



g) Consumption of the tripping devices:

Measured during the 5 x CO operations

at the minimum supply voltage

at the rated supply voltage

at the maximum supply voltage

Rated operating voltage U _r	Shunt-release ON YC					Shunt-release OFF YO1				
	110 V DC					110 V DC				
Current at minimum supply voltage [A]	1.24	1.28	1.28	1.28	1.28	0.92	0.92	0.92	0.92	0.92
Current at rated supply voltage [A]	1.56	1.52	1.52	1.52	1.52	1.20	1.20	1.20	1.20	1.20
Current at maximum supply voltage [A]	1.72	1.72	1.72	1.72	1.72	1.36	1.36	1.36	1.32	1.32

h) Duration of opening and closing command impulse:

Measured during the 5 x CO operations

at the minimum supply voltage

at the rated supply voltage

at the maximum supply voltage

	Shunt-release ON YC					Shunt-release OFF YO1				
	75.9	76.2	76.2	76.8	75.3	79.8	79.8	80.1	79.8	79.2
Duration of command impulse at minimum supply voltage [ms]	75.9	76.2	76.2	76.8	75.3	79.8	79.8	80.1	79.8	79.2
Duration of command impulse at rated supply voltage [ms]	71.4	71.4	69.9	70.5	71.1	56.7	55.5	57.0	55.5	54.6
Duration of command impulse at maximum supply voltage [ms]	67.8	67.8	68.4	68.4	68.7	52.5	52.8	53.4	52.5	52.8

k) Resistance of the main conductors:

Measuring points:







Diagram 2/1: Measurement of the operating speed after the mechanical endurance test



Measuring point: Insulated coupling rod in phase L2

Operating speed measured: $V_c = 0.93 \text{ m/s}$ at $U = 1.0 \times U_a$

БЯРХО С ОРИГИНАЛА

Report No.: 0311/Ra

Contact resistance measured during the 5 x CO operations at the minimum supply voltage of the coils:

Measuring points	L1 μΩ					L2 μΩ					L3 μΩ				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1-2	17.1	17.1	17.2	17.1	17.1	16.9	16.9	16.9	16.9	16.8	17.7	17.7	17.7	17.7	17.8

Contact resistance measured during the 5 x CO operations at the rated supply voltage of the coils:

Measuring points	L1 μΩ					L2 μΩ					L3 μΩ				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1-2	17.3	17.2	17.2	17.2	17.2	16.9	17.0	16.9	16.9	16.9	17.7	17.7	17.7	17.8	17.8

Contact resistance measured during the 5 x CO operations at the maximum supply voltage of the coils:

Measuring points	L1 μΩ					L2 μΩ					L3 μΩ				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1-2	17.1	17.1	17.1	17.1	17.1	16.9	17.0	17.0	17.0	17.0	17.7	17.7	17.7	17.7	17.7

i) Time-travel chart with opening and closing speed: See diagram 2.1 and 2.2

Speed in [m/s]: $U_a = 110 \text{ V DC}$
at $U = 1.0 \times U_a$

	V_o	V_c
L2	1.12	1.25
	0.93	

The deviations from the measured mechanical time travel charts are in the allowable limits of the reference mechanical travel characteristics.

m) Other important characteristics:

- Contact travel:

	L1	L2	L3
Total Travel [mm]	14.6	14.6	14.7
Cont.-travel [mm]	11.2	11.1	11.2
Contact-spring travel [mm]	3.4	3.5	3.5

- Check of vacuum of interrupters:

60 KV DC ok


- Verification of the rated operating sequence:

O-0.3s-CO-3min-CO at rated voltage ok

- Ambient atmospheric conditions:

Date: 24th February 2003, ambient air temperature: approx. 22°C


BAPMO GÖTTINGEN

Diagram 2.2. Measurement of the operating speed after the mechanical endurance test

Measuring point: Insulated coupling rod in phase L2

Operating speed measured: $V_{01} = 1.12 \text{ m/s}$ $V_{02} = 1.25 \text{ m/s}$ at $U = 1.0 \times U_a$

ВЯРНО С ОРИГИНАЛА



Evaluation of the measurements before and after the test program

The reference mechanical travel characteristic was recorded at the rated supply voltage before the endurance test. All measured travel-curves fall within the limits of the two envelope curves which characterize the allowable deviations from the reference curve.

All characteristics measured before and after the test program do not show unacceptable variations.

The circuit-breaker operated only on command and did not operate without command.

ВЯРНО С ОРИГИНАЛА



Measuring Instrument Record

Test job no.: 8002374_M06
Test object: VD4 24.12.20
Date of test: 03rd Feb. – 24th Feb. 2003
Test report No: 0311Ra
Test operator: Mendorf / Schöttler

Instrument	Ident.-no.	Measuring	Remarks
Microohmmeter MO2A 50	ELK 001111	20 $\mu\Omega$ / 200 $\mu\Omega$	Resistance measurement
resistive travel pick-up type lino pot Ts 50 502	ELK 001024	5 k Ω	Travel time measurement
DM 7100 Transient memory	ELK 000466	± 2 V / full scale 50 μ s/word, channel 4 (12 bit)	
YEW-3063 Multi-pen	ELK 000464	0.25 V/cm-vernier 10 cm/min, channel 4	
Slide caliper rule	LAE 002162	0 - 300 mm	
Shunt 1.5A/150mV DM 7100 Transient memory	ELK 001044 ELK 000466	1.5A/150mV $\pm 20/0.2$ V/full scale 50 μ sec/word/10ms/word channel 1, 2, 3, 8 (8 bit)	Current measurement (y2/y3) Operating time measurement,
YEW-3063 Multi-pen	ELK 000464	Channel 1, 2, 3, 8, 0.25/1 V/cm-cal/vernier 10 cm/min	
Electronic time clock Jor 6E	ELK 001231 ELK 000389	0-100s 1 A	Charging time measurement Motor current measurement
Vidar-Vacuum- Checker-Test device	DRU 000026	40/60kV DC	Vacuum-Checker-Test
BBC M2110	ELK 000359	300 V DC	Voltage measurement
Hygrometer Hygronom	FEU 000022	-30°C - +50°C	temperature measurement

БРАНО С ОРИГИНАЛА






Photo 1: Test object

ВЯРНО С ОРИГИНАЛА



АББ Трансмисионе & Дистрибузионе С.п.А.
Унита Оператива Саче Т.М.С.



Виа Фриули 4
124044 – Далмине(BG)
Италия

тел.: 0039.035.395111
факс: 0039.035.395874
E-mail: sacetms.tipm@it.abb.com
интернет://www.abb.com

ПРОТОКОЛ ЗА ТИПОВИ ИЗПИТАНИЯ №. 100089_С СТРАНЦИ 1/1

Apparatus: КРУ тип ZS1 изд. 1.2 с вакуумен прекъсвач тип VD4/P
24.12.20 p=275

Идентификация: 1VCP0000138-Rev.-,en-Технически каталог-2003-04

Параметри:	Номинално напрежение:	24	kV
	Ном. Издържано импулсно напрежение:	125	kV
	Ном. Издържано напрежение с 50Hz:	75	kV
	Номинална честота:	50-60	Hz
	Номинален ток на шината:	1250	A
	Номинален ток на ошиновката:	1250	A
	Ном. Издържан ток, пикова стойност:	63	kA
	Ном. Издържан кратковременен ток на к.с.:	20	kA
	Ном. Продължителност на к.с.:	3	s

Test reports verifying rating assigned by the manufacturer:

Изпитания	Тест съгласно стандарт	Тестов протокол	
		No.	Издаден от
Диелектричени изпитания	IEC 60298 Subclause 6.1	0045 Ra	ПЕХЛА Високо-мощностни лаборатории
Тест с повишаване на температурата	IEC 60298 Subclause 6.3/6.4	HZ 236 E06	АББ Калор Емаг Лаборатории
Тест за кратковременен т.к.с. и пиков т.к.с.	IEC 60298 Subclause 6.5	HZ 235 F01	АББ Калор Емаг Лаборатории в лаборатория CESI Лаб.
Механична работа и тест за блокировки	IEC 60298 Subclause 6.102	MZ 235 A01	АББ Калор Емаг Лаборатории
Тест за вътрешна дъга	IEC 60298 Annex AA	HZ 235 L02	АББ Калор Емаг Лаборатории
Тест за механична работа	IEC 62271-100 subclause 6.101.2	0311 Ra	ПЕХЛА Високо-мощностни лаборатории
Тест за способност за изкл. на т.к.с. и вкл. върху т.к.с.	IEC 62271-100 subclause 6.106	0511 Ra	ПЕХЛА Високо-мощностни лаборатории

Лабораторията на АББ ТиД Унита Оператива САЧЕ Т.М.С. в гр. Далмине е акредитирана съгласно UNI CEI EN ISO/IEC 17025 от SINAL с регистрационен номер Reg. No. 0253

Лабораторията на АББ Калор Емаг в гр. Ратинген, Германия е акредитирана съгласно UNI CEI EN ISO/IEC 17025 от DATech под регистрационен номер No. DAT-P-032/93

Високо-мощностните лаборатории ПЕХЛА са акредитирани съгласно UNI CEI EN ISO/IEC 17025 от DATech с регистрационен номер No. DAT-P-032/93 и сертификат Д-ПЛ-12072-06-01

ЧЕЗИ Лаборатории Милано са акредитирани съгласно UNI CEI EN ISO/IEC 17025 от SINAL с регистрационен номер Reg. No. 0030

Дата на издаване:

04/09/16
ВЪРНО С ОРИГИНАЛА

Отдел за Развойна дейност

Г.М. Граванзала

Test Report

Report No.: 0045 Ra Copy No.: 0 Contents: 19 Sheets

Equipment under test: Metal-clad air-insulated switchgear panel type ZS1.2, rated voltage 24 kV, drawing-no. GCE 8010459 R0104, with vacuum circuit-breaker type VD4P 2420-25.

Manufacturer: ABB Calor Emag Mittelspannung GmbH, D-40472 Ratingen, Germany

Client: ABB Calor Emag Mittelspannung GmbH, D-40472 Ratingen, Germany

Testing station: PEHLA - Testing Station Ratingen

Date of test: 28th November 2000

Applied test specifications: IEC 60298: 1990-12, clauses 6.1.1, 6.1.3 - 6.1.7,
IEC 60694: 1996-05, clauses 6.2.1, 6.2.3 - 6.2.6.

Tests performed: Dielectric type test.
Standard lightning impulse withstand voltage test at 125 kV and power-frequency withstand voltage test at 50 kV to earth, between phases and across open switching device.

Test results: The ZS1.2-type panel passed the dielectric type test successfully.
The respective requirements are met.



Mannheim, 07th December 2000

GESELLSCHAFT FÜR ELEKTRISCHE
HOCHLEISTUNGSPRÜFUNGEN

Technical Committee

The test results relate only to the items tested.

Without a written permission of PEHLA it is not allowed to make reproduction in extracts of this document. Copying the cover sheet accompanied by sheet 2 and the sheets mentioned here is an exception.



Accreditation

The PEHLA-Testing Station Ratingen has been approved by the DATech (German accreditation body for technology) according to DIN EN 45001 for tests in the field of high-voltage switchgear and controlgear and power engineering equipment (Registration-No. DAT-P-032/93).

Under reference to DIN EN 45001 PEHLA states the following:

- The accreditation of the PEHLA-Testing Station or any of its test reports by themselves in no way constitute or imply product approval by DATech or any other body.
- If someone refers to a test in an accredited PEHLA-Testing Station this reference shall include the accreditation body, i.e. DATech, the relevant scope of the accreditation and the appropriate registration number.

STL-Member

PEHLA is foundation-member of the Short-Circuit Testing Liaison (STL) which has been founded in March 1969. STL is a forum for the international cooperation of the testing organisations with the further full members ASTA (GB), CESI (I), ESEF (F), KEMA (NL), SATS (N; S, SF) and STLNA (USA). In the framework of EC, STL has been recognised in 1992 by EOTC as agreement group.

PEHLA-Documents**A Certificate**

is issued for type tests which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test.
For these tests the equipment under test must be clearly identified by technical description, drawings and additional specifications.

A Test Document

is issued for parts of type tests which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of test.
For these tests the equipment under test must be clearly identified by technical description, drawings and additional specifications.

A Test Report

is issued for all other tests which have been carried out according to specifications, standards or "PEHLA-Richtlinien" (PEHLA Guides) and/or clients instructions.
Similarly, this test report contains all test results, details of the conditions under which the tests were carried out, also details relating to the behaviour of the equipment during test, and its condition after the tests.

Addresses:

Office: PEHLA-Geschäftsstelle
Hallenweg 40
D-68219 Mannheim

Testing Station: PEHLA-Testing Station Ratingen
Oberhausener Str. 33
D-40472 Ratingen

Manufacturer: ABB Calor Emag Mittelspannung GmbH
Oberhausener Str. 33
D-40472 Ratingen

Client: ABB Calor Emag Mittelspannung GmbH
Oberhausener Str. 33
D-40472 Ratingen



Table of Contents

	<u>Sheet-No.</u>
Test Report - cover sheet	1
Accreditation	2
Table of Contents	3
List of Test Participants	4
Technical Data of Test Object Switchgear	5
Technical Data of Test Object Switching Device	6
List of Drawings	7
Drawing No. GCE 8010459 R0104 Sheet 30, Index 00	8
Drawing No. GCE 8012050 R0101 Sheet 1 Index 01	9
Drawing No. GCE 7000162 R1104 Sheet 5 Index 00	10
Technical Data of Test Circuit Power Frequency Voltage	11
Technical Data of Test Circuit Lightning Impulse Voltage	12
Lightning Impulse wave	13
Atmospheric Conditions during Tests	14
Test Results	15 - 17
Fig. 1: ZS1.2-panel	18
Fig. 2: Vacuum circuit-breaker type VD4P 2420-25	19
Fig. 3: Cable compartment	19

ВЯРНО С ОРИГИНАЛА



List of Test Participants

Representatives of the Test Committee:

Mr. A. Meier PEHLA- Testing Station Ratingen


Mr. W. Stolz PEHLA- Testing Station Mannheim

Test Engineer:

Mr. U. Lisseck PEHLA- Testing Station Ratingen

Other Participants:

ВЯРНО С ОРИГИНАЛА



Technical Data of Test Object

Switchgear

Ratings assigned by the manufacturer

Test Object: Metal-clad air-insulated switchgear panel
Type: ZS1.2
Manufacturer: ABB Calor Emag Mittelspannung GmbH, D-40472 Ratingen, Germany
Serial-No.: 07550027/2017/00
Drawing No.: GCE8010459 R0104 index 00 **Year of manufacture:** 2000

Rated voltage	24 kV
Rated lightning impulse withstand voltage	125 kV
Rated switching impulse withstand voltage	- kV
Rated power frequency withstand voltage	50 kV
Rated frequency	50/60 Hz
Rated normal current of busbar	2500 A
Rated normal current of tee-off	2500 A
Rated peak withstand current	63 kA
Rated short-time withstand current	25 kA
Rated duration of short-circuit	3 s
Insulating medium	air
Rated operating pressure (abs./20 °C)	- kPa
Minimum operating pressure (abs./20 °C)	- kPa
Permissible values for internal arc faults:	
Peak current	63 kA
Short-time current	25 kA
Duration of short-circuit	1 s
Max. ambient air temperature	40 °C

The above switchgear panel is fully described in the mentioned drawings.

Essential characteristics and installed devices:

- busbar 2 x 80 mm x 10 mm / R 5 mm, Cu, insulated, with bushing plate (left and right).
- busbar tee-off conductor 2 x 100 mm x 10 mm / R 5 mm, Cu, insulated.
- tulip insulator with contact pin Ø = 79 mm.
- current transformer type TPU 65.11, manufacturer: ABB,
 serial-no. L1: 058 246; L2: 058 247; L3: 058 248.
- earthing switch type EK6 2406-275, serial-no. 06/050/00.
- cable conductor 2 x 100 mm x 10 mm / R 5 mm, Cu, bare.

Date of receipt of test object: 27th November 2000

ВЯРНО С ОРИГИНАЛА



Technical Data of Test Object

Switching Device - Circuit-Breaker

Ratings assigned by the manufacturer


Test Object:	Vacuum circuit-breaker
Type:	VD4P 2420-25
Manufacturer:	ABB Calor Emag Mittelspannung GmbH, D-40472 Ratingen, Germany
Serial-No.:	7008269/4002/00
Drawing No.:	GCE 7000162 R1104 index 00 (circuit-breaker)
Vacuum Interrupter:	Type VG4S, L1: No. 00G4S01196, L2: No. 00G4S01192, L3: No. 00G4S01194
Drawing No.:	GCE 7005535 R0102 index 02 (interrupter)

Rated voltage	24 kV
Rated lightning impulse withstand voltage	125 kV
Rated switching impulse withstand voltage	- kV
Rated power frequency withstand voltage	50 kV
Rated frequency	50/60 Hz
Rated normal current	2000 A
Rated peak withstand current	63 kA
Rated short-time withstand current	25 kA
Rated duration of short-circuit	3 s
Rated short-circuit breaking current D.C. component	25 kA
Rated short-circuit making current	30 %
Rated transient recovery voltage: Peak value	41 kV
Rate of rise	0.47 kV/μs
First-pole-to-clear-factor	1.5
Rated operating sequence	O-0.3 s -CO-3 min-CO
Arc extinguishing medium	Vacuum
Number of poles	3
Number of units per pole	1
Rated opening time	≤ 45 ms
Rated closing time	approx. 60 ms
Rated voltage of trip coil	220 V-DC
Rated voltage of closing coil	220 V-DC
Rated supply voltage	220 V-DC
Rated frequency of supply voltage	- Hz
Max. ambient air temperature	-
Further specifications:	40 °C

Essential characteristics: -

Date of receipt of test object: 27th November 2000

ВЯРНО С ОРИГИНАЛА



List of Drawings

The manufacturer has guaranteed, that the equipment submitted for test has been manufactured in full accordance with the following drawings. PEHLA has verified that these drawings adequately represented the equipment tested. These drawings have been stamped and signed by PEHLA representatives and are kept


with the test documents at the test laboratory.
 at the client.

A copy of the following drawings is part of this Test Report.


Drawing-No.	Index	Title	Additional remarks
GCE 8010459 R0104	00	SwitchGear 24kV; PW.1000	-
GCE 8012050 R0101	01	Cable connecting bar system 2500A	-
GCE 7000162 R1104	00	Einschub für ZS1.2 24kV VD4P 2420.25	-


ВЯРНО С ОРИГИНАЛА






ВЯРНО С ОРИГИНАЛА

**ВЯРНО С ОРИГИНАЛА**



ВЯРНО С ОРИГИНАЛА

Technical Data of Test Circuit Power Frequency Voltage



Technical Data

HVT - High Voltage Test Transformer: Type TEO 250/20, serial-no. 268 734,
manufacturer: Meßwandler-Bau, Bamberg

Rated Voltage 260 kV

Rated Capacity 50 kVA

Short Circuit Impedance 14.6 %


TO - Test Object: ZS1.2/24 KV-type panel, 2500 A

M - Voltage Measurement: Capacitive Divider Type CM 300 (Ident-No. ELK-000994) in
connection with a Peak Voltmeter Type DMI 551/Haefely
(Ident-No. ELK-000989)

Verification of Calibration:


- Capacitive Divider (Ident-No. ELK-000994, ELK-000990, ELK-000992);
calibrated on April 1998 at DEACE/LH,
Calibration Report-No. 9800086.
- Peak Voltmeter Typ DMI 551 (Ident-No. ELK-000989);
calibrated on April 2000 at DECMS/LK,
Calibration Report No. 2000353.

ВЯРНО С ОРИГИНАЛА



Technical Data of Test Circuit

Lightning Impulse Voltage 1.2/50



Technical Data

Impulse Generator Type SGS-200/6, WO: 513809, manufacturer: Haefely

Maximum Charging Voltage	U_{Σ}	=	200 kV
Number of Stages	n	=	2
Surge Capacity per Stage	C_S	=	600 nF
Load Capacitance	C_B	=	1000 pF
Damping Resistance	R_D	=	$R_{SI} + R_{SE}$
Internal Front Resistance per Stage	R_{SI}	=	20 Ω
External Front Resistance	R_{SE}	=	300 Ω
Discharge Resistance	R_E	=	$2 R_P$
Tail Resistance per Stage	R_P	=	115 Ω

TO - Test Object: ZS1.2/24 kV-type panel, 2500 A


M - Voltage Measurement: Capacitive Divider Type CS 200 SPZ (Ident-No. ELK-000893, ELK-000894) in connection with a Peak Voltmeter Type DMI 551/ Haefely (Ident-No. ELK-000989) and Oscilloscope Type TDS520 (Ident-No. ELK-000545).




Verification of Calibration:

- Capacitive Divider (Ident-No. ELK-000893, ELK-000894, ELK-000922, ELK-001074): Calibrated in February 1998 at FGH Mannheim, FGH-Calibration-Report-No. 050 DKD-K-15901 98-02.
- Peak Voltmeter Type DMI 551 (Ident-No. ELK-000989): Calibrated in Mai 2000 at FGH Mannheim, FGH-Calibration-Report-No. 073 DKD-K-15901 00-05.
- Oscilloscope Type TDS520 (Ident-No. ELK-000545): calibrated in March 2000 at DECMS/LK, Calibration-Report-No. 2000297.



БЯРНО С ОРИГИНАЛА




Lightning Impulse Voltage with the Test Object connected(Standard Value: $1.2 \pm 30\% / 50 \pm 20\% / \text{peak} \pm 3\%$)**ВАРИО С ОРИГИНАЛА**

Atmospheric Conditions during Tests

Date of test: 28th November 2000

IEC17A/567/Q: Corrigendum to subclause 6.2.1 of IEC60694, 2000-01 (Indices: ~ power frequency voltage; + positive lightning impulse voltage; - negative lightning impulse voltage)						
Input data		Correction factors		calculated	applied	
air temperature t:	19.5 °C	air density correction factors	$k_{t\sim}$:	1.006	-	
air pressure b:	1017 hPa		k_{t+} :	1.006	-	
air humidity h:	7.212 g/m³		k_{t-} :	1.006	-	
50% disruptive-discharge voltages	$U_{B\sim}$: KV	air humidity correction factors	$k_{2\sim}$:	0.954	-	
	U_{B+} : KV		k_{2+} :	0.962	-	
	U_{B-} : KV		k_{2-} :	0.962	-	
minimum discharge path L:		atmospheric correction factors	$K_{t\sim}$:	0.960	0.960	
			K_{t+} :	0.967	0.967	
			K_{t-} :	0.967	0.967	

ВЯРНО С ОРИГИНАЛА



Lightning Impulse Voltage Test Power Frequency Voltage Test

Test performed: Test of insulation phase-to-phase, phase-to-ground and against shutter.

Date of test: 28th November 2000

Condition of test object before test: Factory new, clean and dry.

Connections to test object: For further details see the entry in column 'Condition'

Front time T₁: 1.26 µs

Time to half-value T₂: 51.0 µs

Test frequency f: 50 Hz

All voltage values are corrected with the applied atmospheric correction factor.

The applied test voltages refer to the standard atmosphere of 20 °C, 1013 hPa and 11 g/m³.

Test Arrangement 1:			Applied power frequency voltage ~ kV	Result
Condition	Voltage applied to	Earthed		
Vacuum circuit-breaker in test position, shutters closed. Infeed of the test voltage at the led-out busbar right hand.	A	BCabcF	50 +125 -125	1 minute/0 15/0 15/0
	B	ACabcF	50 +125 -125	1 minute/0 15/0 15/0
	C	ABabcF	50 +125 -125	1 minute/0 15/0 15/0
Vacuum circuit-breaker in test position, shutters closed. Infeed at the cable connecting bar in the cable compartment.	a	ABCbcF	50 +125 -125	1 minute/0 15/0 15/0
	b	ABCacF	50 +125 -125	1 minute/0 15/0 15/0
	c	ABCabF	50 +125 -125	1 minute/0 15/0 15/0

Remarks: A,a = Phase L1, B,b = Phase L2, C,c = Phase L3, F = Frame

БРАНО С ОРИГИНАЛА

Lightning Impulse Voltage Test Power Frequency Voltage Test

Test performed: Test of insulation phase-to-phase, phase-to-ground and across open switching device.

Date of test: 28th November 2000

Condition of test object before test: Factory new, clean and dry.

Connections to test object: For further details see the entry in column 'Condition'

Front time T_1 : 1.26 μ s

Time to half-value T_2 : 51.0 μ s

Test frequency f: 50 Hz

All voltage values are corrected with the applied atmospheric correction factor.

The applied test voltages refer to the standard atmosphere of 20 °C, 1013 hPa and 11 g/m³.

Test arrangement 2:			Applied power frequency voltage ~ kV	Result
Condition	Voltage applied to	Earthed		
Vacuum circuit-breaker in service position and open. Infeed of the test voltage at the fed-out busbar right hand.	A	BCabcF	50 +125 -125	1 minute/0 15/0 15/0
	B	ACabcF	50 +125 -125	1 minute/0 15/0 15/0
	C	ABabcF	50 +125 -125	1 minute/0 15/0 15/0
Vacuum circuit-breaker in service position and open. Infeed of the test voltage at the cable connecting bar in the cable compartment.	a	ABCbcF	50 +125 -125	1 minute/0 15/0 15/0
	b	ABCacF	50 +125 -125	1 minute/0 15/0 15/0
	c	ABCabF	50 +125 -125	1 minute/0 15/0 15/0

Remarks: A,a = Phase L1, B,b = Phase L2, C,c = Phase L3, F = Frame

БЯРНО С ОРИГИНАЛА



Lightning Impulse Voltage Test Power Frequency Voltage Test

Test performed: Test of insulation phase-to-phase and phase-to-ground.

Date of test: 28th November 2000

Condition of test object before test: Factory new, clean and dry.

Connections to test object: Infeed of the test voltage at the led-out busbar right hand.

Front time T_1 : 1.26 μ s

Time to half-value T_2 : 51.0 μ s

Test frequency f: 50 Hz

All voltage values are corrected with the applied atmospheric correction factor.

The applied test voltages refer to the standard atmosphere of 20 °C, 1013 hPa and 11 g/m³.

Test Arrangement 3:			Applied power frequency voltage ~ kV	Result
Condition	Voltage applied to	Earthed		
Vacuum circuit-breaker in service position and closed	Aa	BCbcF	50 +125 -125	1 minute/0 15/0 15/1
	Bb	ACacF	50 +125 -125	1 minute/0 15/0 15/0
	Cc	ABabF	50 +125 -125	1 minute/0 15/0 15/0

Remarks: A,a = Phase L1, B,b = Phase L2, C,c = Phase L3, F = Frame

ВЯРНО С ОРИГИНАЛА

РЕХЛА

Report No.: 0045Ra

GESELLSCHAFT FÜR ELEKTRISCHE HOCHLEISTUNGSPRÜFUNGEN

Sheet: 18




Fig. 1: ZS1.2 / 24 kV-type panel

ВЯРНО С ОРИГИНАЛА

PEHLA

GESELLSCHAFT FÜR ELEKTRISCHE HOCHLEISTUNGSPRÜFUNGEN

Report No.: 0045Ra

Sheet: 19




Fig. 2: Vacuum circuit-breaker type VD4P 2420-25




Fig. 3: Cable-compartment

ВЯРНО С ОРИГИНАЛА



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 1

Issued by an Accredited Laboratory
corresponding to EN 45001

Copy-No. 1

Test Object

Three-panel arrangement of metal-clad, air insulated switchgear
type ZS1.2 (1000 mm, 1000 mm, 800 mm width) equipped with
bushing plates

Rated voltage	U_r	24	kV
Rated normal current	I_r	1600/1600/1000	A
Rated frequency	f_r	50/60	Hz
Rated short-time withstand current	I_k	25	kA
Rated peak withstand current	I_p	63	kA
Rated duration of short-circuit current	t_k	3	s

Manufacturer

ABB Calor Emag Mittelspannung GmbH, Oberhausener Str. 33,
40472 Ratingen, Deutschland

Tests performed

Testing of the behaviour of the metal-clad switchgear under conditions of
arching due to internal faults with 25 kA - 1.0 s in different compartments of
the three panels. For further details see sheet-no. 2 to 5.

Test Specification

The test has been carried out in accordance with the client's
instructions. Test procedure and test parameters were based on
IEC 60298/3rd Ed/1990-12, Clause 6.108, Annex AA in conjunction with
PEHLA-Recommendation No. 4 / 3.1995.
(Accessibility Type A: Metal-enclosed switchgear and controlgear
with accessibility restricted to authorized personnel only).

Test Results

The assessment of the test was carried out in accordance with
criteria 1 to 6 of the above mentioned test specifications.
For further details see sheet-no. 2 to 5 and 16 to 20.

Test Date

12th and 14th December 2000

Client

ABB Calor Emag Mittelspannung GmbH, Oberhausener Str. 33,
40472 Ratingen, Deutschland



19th February 2002
Date of Issue

Göttlich
Dr. S. Göttlich
Laboratory Manager

Brandt
Andreas Brandt
Test Engineer

Total Number of Sheets: 30 Sheets

11 Oszillograms

This test report refers exclusively to the object tested.
ABB Calor Emag Mittelspannung GmbH is certified according
to DIN ISO 9001 by DQS under Reg. No. 373-02

ABB Calor Emag Laboratories Ratingen are accredited according to
EN 45001 by DATech under Reg.No. DAT-P-032/93

With the exception of the cover sheet and any subsequent sheets mentioned thereon, this document may not be partly copied without written consent of
ABB Calor Emag Mittelspannung GmbH Ratingen.

ABB Calor Emag Mittelspannung GmbH Ratingen
High-Power Testing Laboratory

Oberhausener Straße 33
40472 Ratingen, Deutschland

Phone +49 (0) 21 02 12-1352
Fax +49 (0) 21 02 12-1713



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

TEST REPORT No. HZ 235 L 02

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 2

Comments on Test Arrangement and on the Test

The test object was a three-panel arrangement of a metal-clad, air insulated switchgear type ZS1.2 for 24 kV, consisting of a 1000 mm width outgoing panel left-handed, of a 1000 mm width incoming panel in centre and a 800 mm width outgoing panel right-handed. The switchgear was installed in a room mock up with a ceiling height of approximately 3 m. The distance between the rear wall of the switchgear and the room mock up was approximately 0.2 m. The pressure relief took place by a top mounted pressure relief duct overcoming 1800 mm at the side wall of the left-handed panel.

Each panel was equipped with a VD4 vacuum circuit-breaker dummy and a common earthing bar of copper 30 x 8 mm².

Infeed of current was made three-phase by means of a three core cable 1 x 3 x 185 mm² through the closed bottom of the centre panel.

For all tests black cretonne indicators (cotton fabric approximately 150 g/m²) were placed in front of and on one side of the switchgear as stated in the relevant test regulations.

During the tests the pressure gauge in the compartment under test was measured and recorded. The tests were filmed with a high-speed video camera with a frequency of 500 frames/s.

The evaluation of the RMS-value of the short-circuit current was made according to the Simpson-Formula.

ВЯРНО С ОРИГИНАЛА





Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

TEST REPORT No. HZ 235 L 02

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 3

Test Results

Test-no.: HZ 235 L 02 / 03 Internal arcing test in the cable compartment of the right-handed panel (800 mm width), ignition of arc three-phase by means of a copper wire Ø 0.5 mm at the cable terminals.

Peak short-circuit current: 59.7 kA

Short-circuit current: 24.7 kA - 1.03 s equivalent to 25.0 kA - 1.02 s

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

Test-no.: HZ 235 L 02 / 04 Internal arcing test in the cable compartment of the left-handed panel (1000 mm width), ignition of arc three-phase by means of a copper wire Ø 0.5 mm at the cable terminals.

Peak short-circuit current: 59.7 kA

Short-circuit current: 24.9 kA - 1.04 s equivalent to 25.0 kA - 1.03 s

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

ВАРНО С ОРИГИНАЛА



Test Results

Test-no.: HZ 235 L 02 / 05 Internal arcing test in the circuit-breaker compartment of the right-handed panel (800 mm width), ignition of arc three-phase by means of a copper wire Ø 0.5 mm across the lower contact arms of the circuit-breaker.

Peak short-circuit current: 58.8 kA

Short-circuit current: 24.7 kA - 1.04 s equivalent to 25.0 kA - 1.02 s

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

Test-no.: HZ 235 L 02 / 06 Internal arcing test in the busbar compartment of the left-handed panel (1000 mm width), ignition of arc three-phase by means of a copper wire Ø 0.5 mm across the busbars.

Peak short-circuit current: 56.8 kA

Short-circuit current: 24.7 kA - 1.04 s equivalent to 25.0 kA - 1.03 s

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

ВЯРНО С ОРИГИНАЛА





Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

TEST REPORT No. HZ 235 L 02

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 5

Test Results

Test-no.: HZ 235 L 02 / 07 Internal arcing test in the circuit-breaker compartment of the centre panel (1000 mm width), ignition of arc three-phase by means of a copper wire Ø 0.5 mm across the upper contact arms of the circuit-breaker.

Peak short-circuit current: 59.6 kA

Short-circuit current: 24.7 kA - 1.04 s equivalent to 25.0 kA - 1.03 s

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

ВЯРНО С ОРИГИНАЛА





Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02


Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 6

Contents

	Sheet
Test Report - Cover Sheet	1
Comments on Test Arrangement	2
Test Results	3 - 5
Contents	6
Assessment of the Test	7
Participants of the Test	8
Technical Data of Test Objects	9 - 10
Table of Drawings of Test Objects	11
Drawings	12 - 14
Technical Data of Test Circuit	15
Principle Diagram of Test Circuit	16
Determination of the Prospective Short-Circuit Current	17
Internal Arcing Tests	18 - 22
Photos	23 - 30
Oscillograms	

БЯРНО С ОРИГИНАЛА





Reg. No.

DAT-P-032/93

ABB Calor Emag Laboratories

TEST REPORT No. HZ 235 L 02

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 7

Assessment of the Test

Extraction of IEC 60298/3rd Ed/1990-12, Annex AA

The following criteria allow for the arcing effects.
It is to be observed:

Criterion No. 1

Whether correctly secured doors, covers, etc., do not open.

Criterion No. 2

Whether parts (of the metal-enclosed switchgear and controlgear), which may cause a hazard, do not fly off. This includes large parts or those with sharp edges, for example, inspection windows, pressure relief flaps, cover plates, etc.

Criterion No. 3

Whether arcing does not cause holes to develop in the freely accessible parts of the enclosure as a result of burning or other effects.

Criterion No. 4

Whether the indicators arranged vertically do not ignite. Indicators ignited as a result of paint or stickers burning are excluded from this assessment.

Criterion No. 5

Whether the indicators arranged horizontally do not ignite. Should they start to burn during the test, the assessment criterion may be regarded as having been met, if proof is established of the fact that the ignition was caused by glowing particles rather than hot gases. Pictures taken by high-speed cameras should be produced in evidence.


Criterion No. 6

Whether all earthing connections are still effective.

Remark:

When the PEHLA-Recommendation No. 4 is stated under *Test Specification* in the *Test Report*, the results of each test were assessed by all six criteria.

БАРНО С ОРИГИНАЛА





Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Issued by an Accredited Laboratory
corresponding to EN 45001

Sheet 8

Participants of the Tests

Client: ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen,
Deutschland

Representatives of the client:

Mr. Aufermann ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen,
Deutschland
Dept. EA

Mr. Groll ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen,
Deutschland
Dept. EA


Representatives of the laboratory:

Mr. Dr. Göttlich ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen,
Deutschland
Dept. LL

Test Engineer:

Mr. Brandt ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen,
Deutschland
Dept. LL

ВЪРНО С ОПИГИНАТА





Deutscher
Akkreditierungs
Rat

Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 9

Issued by an Accredited Laboratory
corresponding to EN 45001

Technical Data of Test Object

(Ratings assigned by the manufacturer)

Switchgear (left-handed and centre)

Test Object: Metal-clad, air insulated switchgear

Type: ZS1.2, 1000 mm width

Manufacturer: ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen, Deutschland

Serial-No.: 7550027/2027/00

7550027/2025/00

Year of manufacture: 2000

Drawing Nos.: See sheet-no. 10

Rated voltage	24	kV
Rated lightning impulse withstand voltage	125	kV
Rated power frequency withstand voltage	50	kV
Rated frequency	50/60	Hz
Rated current (busbar)	2000	A
Rated current (tee-off)	1600	A
Rated short-circuit peak withstand current	63	kA
Rated short-time withstand current	25	kA
Rated short-circuit duration	3	s
Insulating medium	air	
Rated filling pressure (abs., 20 ° C)	-	kPa

Prospective values under internal-arc conditions:


Peak withstand current	63	kA
Short-time withstand current	25	kA
Short-circuit duration	1	s

Additional specifications and data:

- busbars 2 x 80 mm x 10 mm / R 5 mm, Cu, insulated
- tee-off bars 2 x 80 mm x 10 mm / R 5 mm, Cu, insulated

Date of receipt of test object: 11th December 2000

ВЯРНО С ОРИГИНАЛА





Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 10

Issued by an Accredited Laboratory
corresponding to EN 45001

Technical Data of Test Object (Ratings assigned by the manufacturer) Switchgear (right-handed)

Test Object: Metal-clad, air insulated switchgear

Type: ZS1.2, 800 mm width

Manufacturer: ABB Calor Emag Mittelspannung GmbH, 40472 Ratingen, Deutschland

Serial-No.: 7550027/2022/00

Year of manufacture: 2000

Drawing Nos.: See sheet-no. 10

Rated voltage	24	kV
Rated lightning impulse withstand voltage	125	kV
Rated power frequency withstand voltage	50	kV
Rated frequency	50/60	Hz
Rated current (busbar)	2000	A
Rated current (tee-off)	1000	A
Rated short-circuit peak withstand current	63	kA
Rated short-time withstand current	25	kA
Rated short-circuit duration	3	s
Insulating medium	air	
Rated filling pressure (abs., 20 ° C)	-	kPa

Prospective values under internal-arc conditions:


Peak withstand current	63	kA
Short-time withstand current	25	kA
Short-circuit duration	1	s

Additional specifications and data:

- busbars 2 x 80 mm x 10 mm / R 5 mm, Cu, insulated
- tee-off bars 1 x 60 mm x 10 mm / R 5 mm, Cu, insulated

Date of receipt of test object: 11th December 2000

БЯРHO C ОРИГИНАЛА





Deutscher
Akreditierungs
Rat

Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

ABB

TEST REPORT No. HZ 235 L 02

Sheet 11

Issued by an Accredited Laboratory
corresponding to EN 45001

Table of Drawings of Test Objects

The drawings submitted for identification of the test object were stamped and signed by the test engineer.

The manufacturer/client has guaranteed by signature on the drawings that the equipment submitted for tests has been manufactured in accordance with the given drawings.


A copy of the following drawing is part of this Test Report:

ZS 1.2, feeder panel 24 kV, PW.1000 GCE8010459R0101, sheet 1, index 01,

ZS 1.2, feeder panel 24 kV, PW.800 GCE8010457R0101, sheet 1, index 01,

Type Test Arrangement (internal fault) GCEP800240 sheet 1, index 00
ZS1.2 – Panel 24kV

БЯРНО С ОРИГИНАЛА





Deutscher
Akkreditierungs
Rat

Reg. No.

DAT-P-032/93


ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 12

Issued by an Accredited Laboratory
corresponding to EN 45001



ВЪРХО С ОРИГИНАЛА


ABB Calor Emag Laboratories

ABB

TEST REPORT No. HZ 235 L 02

Sheet 13

Issued by an Accredited Laboratory
corresponding to EN 45001



Reg. No.
DAT-P-032/93

TEST REPORT No. HZ 235 L 02

Sheet 14

Issued by an Accredited Laboratory
corresponding to EN 45001

Panel 1	Feld 15 DECMS 7550027_075A GCEB010439R0101	Panel 2	Feld 16 DECMS 7550027_025A GCEB010459R0101	Panel 3	Feld 14 DECMS 7550027_022A GCEB010457R0101
Incoming line					
<p>① cable terminal ② cable terminal ③ circuit breaker VD4 lower contact ④ busbar system ⑤ circuit breaker VD4 upper contact</p>					
<p>Date: <u>11.12.00</u> Dispersed</p>					
<p>Signature: <u>E.A.</u></p>					
<p>This document / drawing has not been checked in detail by the testing authority</p>					
<p>ABB Calor Emag Laboratories Rating E</p>					
<p>Table: Type Test Arrangement (internal fault)</p>					
<p>2S1.2 - Panel 24kV</p>					
<p>Manufacturing Order: GCEP800240</p>					
<p>Firm: DECMS Name: A.Emag Dir.: EA The test object corresponds to this drawing Date: 11.12.00</p>					
<p>Statement: All rights in this document and in the information contained herein are reserved. Reproduction, in whole or in part, without written permission of the manufacturer is prohibited. © ABB Calor Emag Netzteilspannung GmbH</p>					
<p>Statement: All rights in this document and in the information contained herein are reserved. Reproduction, in whole or in part, without written permission of the manufacturer is prohibited. © ABB Calor Emag Netzteilspannung GmbH</p>					

ВЯРНО С ОРИГИНАЛА



Deutscher
Akreditierungs
Rat

Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 15

Issued by an Accredited Laboratory
corresponding to EN 45001


Technical Data of Test Circuit

Test	Internal fault	-	-	-
Oscillogram-No. HZ 235 L 02	02 - 07	-	-	-
Number of phases (circuit)	3	-	-	-
Number of poles/phases (test object)	3	-	-	-
Power frequency Hz	50	-	-	-
Power factor $\cos \varphi$	≤ 0.15	-	-	-
Earthing	Generator	earthed via 5 kΩ	-	-
	Transformer	not earthed	-	-
	Short-circuit point	not earthed	-	-
Circuit diagram	Sheet no.:	16	-	-
Circuit impedance	$m\Omega$	≈ 170	-	-
TRV control elements		-	-	-
Capacitance in parallel	μF	-	-	-
Resistance in series	Ω	-	-	-
	-	-	-	-
	-	-	-	-
Prospective TRV	-	-	-	-
TRV peak value U_c	kV	-	-	-
Time co-ordinate t_3	μs	-	-	-
Time delay t_d	μs	-	-	-
Based on	kV	-	-	-
Rate-of-rise	$kV/\mu s$	-	-	-
	-	-	-	-
	-	-	-	-
Voltage measurements	Divider 375 kΩ / 2 kΩ	-	-	-
Current measurements	Transformer 50 kA / 5 A	-	-	-



Remarks:

HZ 235 L 02 / 01: Current calibration

ВЯРНО С ОРИГИНАЛА



TEST REPORT No. HZ 235 L 02

Issued by an Accredited Laboratory
corresponding to EN 45001**Principle Diagram of Test Circuit**
ВЯРНО С ОРИГИНАЛА



Reg. No.

DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 17

Issued by an Accredited Laboratory
corresponding to EN 45001

Determination of the Prospective Short-Circuit Current

Condition of test object before test:

Arrangement: See sheet-no. 2

Connection: Infeed of current was made three-phase by means of a three core cable $1 \times 3 \times 185 \text{ mm}^2$ through the closed bottom of the centre panel.

For the determination of the prospective short-circuit current the infeeding busbars of the test plant were short-circuited and earthed outside the switchgear under test.

Test-No.: HZ 235 L 02 / 02		Applied voltage (phase-to-phase) 7.30 kV		Duration of short-circuit current 1.03 s
	Peak short-circuit current kA	Short-circuit current: first cycle kA		Arithmetic mean value kA
L1	65.8	27.2	25.8	25.0
L2	19.6	26.9	25.9	25.1
L3	51.3	26.9	25.5	24.8
Average value		27.0	25.7	25.0
Equivalent duration of short-circuit current		corresponding to a short-circuit current of 25.0 kA		
1.03 s				

Remarks: -

БДРУС С ОРУГИНАЛА



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

TEST REPORT No. HZ 235 L 02

Sheet 18

Issued by an Accredited Laboratory
corresponding to EN 45001

Internal Arcing Test

Condition of test object before test: Switchgear factory-new.

Arrangement: See sheet-no.: 2

Connection: Infeed of current was made three-phase by means of a three core cable
 $1 \times 3 \times 185 \text{ mm}^2$ through the closed bottom of the centre panel.

Ignition: Internal arcing test in the cable compartment of the right-handed panel
(800 mm width), ignition of arc three-phase by means of a copper wire
 $\varnothing 0.5 \text{ mm}$ at the cable terminals.

Test-No.: HZ 235 L 02 / 03		Applied voltage (phase-to-phase) 7.45 kV		Duration of short-circuit current 1.03 s
	Peak short-circuit current kA	Short-circuit current: first cycle kA	last cycle kA	Arithmetic mean value kA
L1	59.7	26.9	25.6	24.8
L2	18.3	26.3	25.7	24.9
L3	45.4	26.4	25.2	24.4
Average value		26.5	25.5	24.7
Equivalent duration of short-circuit current 1.02 s		corresponding to a short-circuit current of 25.0 kA		

Remarks and condition of test object after test:

The condition of the switchgear before and after test is shown on the photos on sheet-no.

23 to 29: The measured pressure gauge was about 42 kPa.

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

БРНФО С ОРИГИНАЛА



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 19

Issued by an Accredited Laboratory
corresponding to EN 45001

Internal Arcing Test

Condition of test object before test: as after test HZ 235 L 02 / 03.

Arrangement: See sheet-no.: 2

Connection: Infeed of current was made three-phase by means of a three core cable
1 x 3 x 185 mm² through the closed bottom of the centre panel.

Ignition: Internal arcing test in the cable compartment of the left-handed panel
(1000 mm width), ignition of arc three-phase by means of a copper wire
Ø 0.5 across the cable terminals.

Test-No.: HZ 235 L 02 / 04		Applied voltage (phase-to-phase) 7.45 kV		Duration of short-circuit current 1.04 s
	Peak short-circuit current kA	Short-circuit current: first cycle kA	last cycle kA	Arithmetic mean value kA
L1	59.7	27.1	25.8	25.1
L2	20.5	26.0	25.7	25.0
L3	47.5	26.6	25.4	24.6
Average value		26.6	25.7	24.9
Equivalent duration of short-circuit current 1.03 s		corresponding to a short-circuit current of 25.0 kA		

Remarks and condition of test object after test:

The condition of the switchgear before and after test is shown on the photos on sheet-no.
23 to 29. The measured pressure gauge was about 45 kPa.

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

ВЪРНО С ОРИГИНАЛА



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

TEST REPORT No. HZ 235 L 02

Sheet 20

Issued by an Accredited Laboratory
corresponding to EN 45001

Internal Arcing Test

Condition of test object before test: as after test HZ 235 L 02 / 04.

Arrangement: See sheet-no.: 2

Connection: Infeed of current was made three-phase by means of a three core cable
 $1 \times 3 \times 185 \text{ mm}^2$ through the closed bottom of the centre panel.

Ignition: Internal arcing test in the circuit-breaker compartment of the right-handed panel (800 mm width), ignition of arc three-phase by means of a copper wire $\varnothing 0.5 \text{ mm}$ across the lower contact arms of the circuit-breaker.

Test-No.: HZ 235 L 02 / 05		Applied voltage (phase-to-phase) 7.45 kV		Duration of short-circuit current 1.04 s
	Peak short-circuit current kA	Short-circuit current: first cycle kA	last cycle kA	Arithmetic mean value kA
L1	58.8	26.8	25.3	24.5
L2	19.4	26.3	25.7	24.8
L3	46.4	27.0	25.6	24.7
Average value		26.7	25.5	24.7
Equivalent duration of short-circuit current 1.02 s		corresponding to a short-circuit current of 25.0 kA		

Remarks and condition of test object after test:

The condition of the switchgear before and after test is shown on the photos on sheet-no. 23 to 29. The measured pressure gauge was about 31 kPa.

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

БЯРНО С ОПРЕДИЛНАЈА



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 21

Issued by an Accredited Laboratory
corresponding to EN 45001

Internal Arcing Test

Condition of test object before test: as after test HZ 235 L 02 / 05.

Arrangement: See sheet-no.: 2

Connection: Infeed of current was made three-phase by means of a three core cable
 $1 \times 3 \times 185 \text{ mm}^2$ through the closed bottom of the centre panel.

Ignition: Internal arcing test in the busbar compartment of the left-handed panel
(1000 mm width), ignition of arc three-phase by means of a copper wire
 $\varnothing 0.5 \text{ mm}$ across the busbars.

Test-No.: HZ 235 L 02 / 06		Applied voltage (phase-to-phase) 7.45 kV		Duration of short-circuit current 1.04 s
	Peak short-circuit current kA	Short-circuit current: first cycle kA	last cycle kA	Arithmetic mean value kA
L1	56.8	26.6	25.5	24.7
L2	19.3	25.3	26.5	25.0
L3	44.1	26.9	24.7	24.2
	Average value	26.3	25.6	24.7
Equivalent duration of short-circuit current 1.03 s		corresponding to a short-circuit current of 25.0 kA		

Remarks and condition of test object after test:

The condition of the switchgear before and after test is shown on the photos on sheet-no.
23 to 29. The measured pressure gauge was about 60 kPa.

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

БЯРНО С ОРИГИНАЛА



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

Sheet 22

TEST REPORT No. HZ 235 L 02

Issued by an Accredited Laboratory
corresponding to EN 45001

Internal Arcing Test

Condition of test object before test: as after test HZ 235 L 02 / 06.

Arrangement: See sheet-no.: 2

Connection: Infeed of current was made three-phase by means of a three core cable
 $1 \times 3 \times 185 \text{ mm}^2$ through the closed bottom of the centre panel.

Ignition: Internal arcing test in the circuit-breaker compartment of the centre panel
(1000 mm width), ignition of arc three-phase by means of a copper wire
 $\varnothing 0.5 \text{ mm}$ across the upper contact arms of the circuit-breaker.

Test-No.: HZ 235 L 02 / 07		Applied voltage (phase-to-phase) 7.45 kV		Duration of short-circuit current 1.04 s
	Peak short-circuit current kA	Short-circuit current: first cycle kA	last cycle kA	Arithmetic mean value kA
L1	59.6	26.7	25.2	24.6
L2	18.7	26.7	25.8	25.0
L3	45.9	27.0	25.3	24.7
Average value		26.8	25.5	24.7
Equivalent duration of short-circuit current		1.03 s	corresponding to a short-circuit current of 25.0 kA	

Remarks and condition of test object after test:

The condition of the switchgear before and after test is shown on the photos on sheet-no.
23 to 29. The measured pressure gauge was about 28 kPa.

Assessment of the test:

- Correctly secured doors, covers, etc. did not open (Criterion No. 1).
- Parts of the switchgear, which may cause injury to persons, did not fly off (Criterion No. 2).
- Arc did not cause holes to develop in the outer, freely accessible parts of the enclosure as a result of burning or other effects (Criterion No. 3).
- The indicators arranged vertically did not ignite (Criterion No. 4).
- The indicators arranged horizontally did not ignite (Criterion No. 5).
- All earthing connections were still effective (Criterion No. 6).

БЯРНО С ОПРЕДЕЛЯЮЩАЯ



Deutscher
Akkreditierungs
Rat

Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 23

Issued by an Accredited Laboratory
corresponding to EN 45001




Photo No. 01
Before Test HZ 235 L 02 / 03




Photo No. 02
After Test HZ 235 L 02 / 03

БЯРНО С ОРИГИНАЛА



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

ABB

TEST REPORT No. HZ 235 L 02

Sheet 24

Issued by an Accredited Laboratory
corresponding to EN 45001




Photo No. 03
After Test HZ 235 L 02 / 03




Photo No. 04
Before Test HZ 235 L 02 / 04

ВЯРНО С ОРИГИНАЛА



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

ABB

TEST REPORT No. HZ 235 L 02

Sheet 25

Issued by an Accredited Laboratory
corresponding to EN 45001




Photo No. 05
After Test HZ 235 L 02 / 04




Photo No. 06
After Test HZ 235 L 02 / 04

ВЯРНО С ОРИГИНАЛА



Deutscher
Akreditierungs
Rat

Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

ABB

TEST REPORT No. HZ 235 L 02

Sheet 26

Issued by an Accredited Laboratory
corresponding to EN 45001




Photo No. 07
Before Test HZ 235 L 02 / 05





Photo No. 08
After Test HZ 235 L 02 / 05

ВЪРНО С ОРИГИНАЛА





Deutscher
Akkreditierungs
Rat

Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

ABB

TEST REPORT No. HZ 235 L 02

Sheet 27

Issued by an Accredited Laboratory
corresponding to EN 45001




Photo No. 09
After Test HZ 235 L 02 / 05




Photo No. 10
Before Test HZ 235 L 02 / 06

БАРНО С ОРИГИНАЛА



Deutscher
Akreditierungs
Rat

Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

ABB

Sheet 28

TEST REPORT No. HZ 235 L 02

Issued by an Accredited Laboratory
corresponding to EN 45001




Photo No. 11
After Test HZ 235 L 02 / 06




Photo No. 12
After Test HZ 235 L 02 / 06

БИФО С ОРИГИНАЛА



Deutscher
Akreditierungs
Rat

Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories



TEST REPORT No. HZ 235 L 02

Sheet 29

Issued by an Accredited Laboratory
corresponding to EN 45001




Photo No. 13
Before Test HZ 235 L 02 / 07




Photo No. 14
After Test HZ 235 L 02 / 07

ВЯРНО С ОРИГИНАЛА



Reg. No.
DAT-P-032/93

ABB Calor Emag Laboratories

ABB

TEST REPORT No. HZ 235 L 02

Sheet 30

Issued by an Accredited Laboratory
corresponding to EN 45001






Photo No. 15
After Test HZ 235 L 02 / 07



ВАРНО С ОРИГИНАЛА






14






12.12.2000
БАРНО С ОРИГИНАЛА






H2235E02-002






16






HZ235L02.003



HZ235L02.004







HZ235L02.004





H2235L-02E005

Л2











14.12.2600
ВАРНО С ОРИГИНАЛА



H2235L02.006






HZ2335-L02.006



HZ235LE02.007

Yur



HZ235L02.007

12.12.2000

ВЯРНО С ОРИГИНАЛА

ABB Trasmissione & Distribuzione S.p.A.

Unità operativa Sace T.M.S.



Via Friuli 4
I 24044 – Dalmine (BG)
Italy

Tel.: 0039.035.395111
Fax: 0039.035.395874
E-mail: sacetms.tipm@it.abb.com
Internet: <http://www.abb.com>

TYPE TEST DOCUMENTATION No. 100089_C Page 1/1

Apparatus: Metal-clad switchgear type ZS1 rel 1.2 with vacuum circuit-breaker type VD4/P 24.12.20 p=275

Identification: 1VCP0000138-Rev.-,en-Technical catalogue-2003-04

Performances:	Rated voltage :	24	kV
	Rated lightning impulse withstand voltage :	125	kV
	Rated power-frequency withstand voltage :	50	kV
	Rated frequency :	50-60	Hz
	Rated normal current (busbar) :	1250	A
	Rated normal current (tee-off) :	1250	A
	Rated peak withstand current :	63	kA
	Rated short-time withstand current :	20	kA
	Rated duration of short circuit :	3	s

Test reports verifying rating assigned by the manufacturer:

Performances	Test according to	Test reports	
		No.	Issued by
Dielectric test	IEC 60298 Subclausole 6.1	0045 Ra	PEHLA High-power Laboratories
Temperature-rise test	IEC 60298 Subclausole 6.3/6.4	HZ 236 E06	Calor Emag Laboratories
Short-time and peak withstand current test	IEC 60298 Subclausole 6.5	HZ 235 F01	Calor Emag Laboratories
Mechanical operation and interlock test	IEC 60298 Subclausole 6.102	MZ 235 A01	Calor Emag Laboratories
Internal arc test	IEC 60298 Annex AA	HZ 235 L02	Calor Emag Laboratories
Mechanical operation test	IEC 62271-100 subclause 6.101.2	0311 Ra	PEHLA High-power Laboratories
Making and breaking capacity test	IEC 62271-100 subclause 6.106	0511 Ra	PEHLA High-power Laboratories

ABB T&D Unità operativa SACE T.M.S. Laboratories Dalmine are accredited according UNI CEI EN ISO/IEC 17025 by SINAL under Reg. No 0233
ABB Calor Emag Laboratories Ratingen are accredited according UNI CEI EN ISO/IEC 17025 by DATech under Reg. No. DAT-P-032/93
PEHLA High-power Laboratories are accredited according UNI CEI EN ISO/IEC 17025 by DATech under Reg. No. DAT-P-032/93 and certificate D-PL-12072-08-01

CESI Laboratories Milano are accredited according UNI CEI EN ISO/IEC 17025 by SINAL under Reg. No. 030

Date of issue:

04/09/16

Development Dept.

G.M. Cravanzola



ABB-T&D-Unità operativa Sace T.M.S. is accredited by DET NORSKE VERITAS QUALITY CERTIFICATE Quacer Certificate
No. CERT-07978-2001-AQ-MIL-SINCERT/B according to ISO 9001.




Приложение 1.3 - Акредитация

(

(

ВЕРНО С ОРИГИНАЛА





L'ENTE ITALIANO DI ACCREDITAMENTO

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e IAC
Signatory of EA, IAF and IAC Mutual Recognition Agreements



CERTIFICATO DI ACCREDITAMENTO Accreditation Certificate

Accreditamento n°
Accreditation n°

0253

Rev. 1

Si dichiara che
We declare that

ABB S.p.A. Power Products Division

Sede/Headquarters:
Via Friuli 4 - 24044 Dalmine BG

è conforme ai requisiti
della norma
*meets the requirements
of the standard*

UNI CEI EN ISO/IEC 17025:2005 "Requisiti generali per la competenza dei
Laboratori di prova e taratura"

*EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing
and Calibration Laboratories" standard*

quale **Laboratorio di Prova**
as **Testing Laboratory**

L'accreditamento attesta la competenza tecnica del Laboratorio relativamente allo scopo riportato nelle schede indicate al presente certificato. Le schede possono variare nel tempo. I requisiti gestionali della ISO/IEC 17025:2005 (sezione 4) sono scritti in un linguaggio idoneo all'attività del Laboratorio di Prova, sono conformi ai principi della ISO 9001:2008 ed allineati con i suoi requisiti applicabili.
Il presente certificato non è da ritenersi valido se non accompagnato dalle schede indicate e può essere sospeso o revocato in qualsiasi momento nel caso di inadempimento accertato da parte di ACCREDIA.
La validità dell'accreditamento può essere verificata sul sito WEB (www.accredia.it) o richiesta direttamente ai singoli Dipartimenti.

The accreditation certifies the technical competence of the laboratory limited to the scope detailed in the attached Enclosure. The scope may vary in the time. The management system requirements in ISO/IEC 17025:2005 (Section 4) are written in a language relevant to Testing Laboratories operations and meet the principles of ISO 9001:2008 and are aligned with its pertinent requirements.

The present certificate is valid only if associated to the annexed schedule, and can be suspended or withdrawn at any time in the event of non fulfilment as ascertained by ACCREDIA.

The in force status of the accreditation may be checked in the WEB site (www.accredia.it) or on direct request to appointed Department.

Data di 1ª emissione
1st issue date
1999-07-08


Data di modifica
Modification date
2015-07-16

Data di scadenza
Expiring date
2019-07-11

Il Direttore Generale
The General Director
(Dr. Filippo Trifiletti)

Il Direttore di Dipartimento
Department Director
(Dr.ssa Silvia Tramontin)

Il Presidente
The President
(Ing. Giuseppe Rossi)



Mod. CA-01 rev. 01
Sede operativa e legale: via Guglielmo Saliceto, 7/9 | 00161 Roma - Italy | Tel. +39 06 8440991 | Fax +39 06 8841199
info@accredia.it | www.accredia.it | Partita IVA - Codice Fiscale 10566361001

Pag. 1 di 1



Deutsche
Akkreditierungsstelle

Deutsche Akkreditierungsstelle GmbH German Accreditation Body

Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1
subsection 1 AkkStelleGBV
Signatory to the Multilateral Agreements of
EA, ILAC and IAF for Mutual Recognition

Accreditation



The Deutsche Akkreditierungsstelle GmbH (German Accreditation Body) attests that the testing laboratory

PEHLA GbR
PEHLA-Prüffeld Ratingen
Oberhausener Straße 33, 40472 Ratingen

is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out tests in the following fields:


**High-Voltage Switchgear and Controlgear,
Low-Voltage Switchgear and Controlgear Assemblies,
Current and Voltage Transformers,
Power transformers and Busbar Systems**

The accreditation certificate shall only apply in connection with the notice of accreditation of 2012-05-08 with the accreditation number D-PL-12072-06 and is valid until 2017-05-08. It comprises the cover sheet, the reverse side of the cover sheet and the following annex with a total of 5 pages.


Registration number of the certificate: D-PL-12072-06-01

Frankfurt am Main, 2012-05-09

Dipl.-Ing. (FH) Berl Egner
Head of Division 2



This document is a draft for communication. The definitive version is the original German accreditation certificate.
See notes section.





Deutsche Akkreditierungsstelle GmbH

Office Berlin
Spittelmarkt 10
10117 Berlin

Office Frankfurt am Main
Gartenstraße 6
60594 Frankfurt am Main

Office Braunschweig
Bundesallee 100
38116 Braunschweig

The publication of extracts of the accreditation certificate is subject to the prior written approval by Deutsche Akkreditierungsstelle GmbH (DAkkS). Exempted is the unchanged form of separate disseminations of the cover sheet by the conformity assessment body mentioned overleaf.

No impression shall be made that the accreditation also extends to fields beyond the scope of accreditation attested by DAkkS.


The accreditation was granted pursuant to the Act on the Accreditation Body (AkkStelleG) of 31 July 2009 (Federal Law Gazette I p. 2625) and the Regulation (EC) No 765/2008 of the European Parliament and of the Council of 9 July 2008 setting out the requirements for accreditation and market surveillance relating to the marketing of products (Official Journal of the European Union L 218 of 9 July 2008, p. 30). DAkkS is a signatory to the Multilateral Agreements for Mutual Recognition of the European co-operation for Accreditation (EA), International Accreditation Forum (IAF) and International Laboratory Accreditation Cooperation (ILAC). The signatories to these agreements recognise each other's accreditations.

The up-to-date state of membership can be retrieved from the following websites:

EA: www.european-accreditation.org

ILAC: www.ilac.org

IAF: www.iaf.nu



CERTIFICATO DI ACCREDITAMENTO Accreditation Certificate

Accreditamento n°
Accreditation n°

0030

Rev. **2**

Si dichiara che
We declare that

CESI S.p.A.

Sede/Headquarters:

Via Rubattino 54 - 20134 Milano MI

è conforme ai requisiti
della norma
*meets the requirements
of the standard*

UNI CEI EN ISO/IEC 17025:2005 "Requisiti generali per la competenza dei Laboratori di prova e taratura"

EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing and Calibration Laboratories" standard

quale **Laboratorio di Prova**
as **Testing Laboratory**

L'accreditamento attesta la competenza tecnica del Laboratorio relativamente allo scopo riportato nelle schede indicate al presente certificato. Le schede possono variare nel tempo. I requisiti gestionali della ISO/IEC 17025:2005 (sezione 4) sono scritti in un linguaggio idoneo all'attività dei Laboratori di Prova, sono conformi ai principi della ISO 9001:2008 ed allineati con i suoi requisiti applicabili.
Il presente certificato non è da ritenersi valido se non accompagnato dalle schede indicate e può essere sospeso o revocato in qualsiasi momento nel caso di inadempimento accertato da parte di ACCREDIA.
La validità dell'accreditamento può essere verificata sul sito WEB (www.accredia.it) o richiesta direttamente ai singoli Dipartimenti.

*The accreditation certifies the technical competence of the laboratory limited to the scope detailed in the attached Enclosure. The scope may vary in the time. The management system requirements in ISO/IEC 17025:2005 (Section 4) are written in a language relevant to Testing Laboratories operations and meet the principles of ISO 9001:2008 and are aligned with its pertinent requirements.
The present certificate is valid only if associated to the annexed schedule, and can be suspended or withdrawn at any time in the event of non fulfilment as ascertained by ACCREDIA.
The in force status of the accreditation may be checked in the WEB site (www.accredia.it) or on direct request to appointed Department.*

Data di 1ª emissione
1st issue date
1992-02-27

Data di modifica
Modification date
2016-04-14

Data di scadenza
Expiring date
2020-03-09

Il Direttore Generale
The General Director
(Dr. Filippo Trifiletti)

Il Direttore di Dipartimento
Department Director
(Dr.ssa Silvia Tramontin)

Il Presidente
The President
(Ing. Giuseppe Rossi)

CERTIFICATO DI ACCREDITAMENTO *Accreditation Certificate*

Accreditamento n°
Accreditation n°

0030

Rev. **2**

Si dichiara che
We declare that

Sedi operative:
CESI S.p.A.
Via Rubattino 54
20134 Milano MI
CESI S.p.A. - Sede di Piacenza
Via Nino Bixio 39
29100 Piacenza PC
CESI S.p.A. - Sede di Seriate
Via Pastrengo 9
24068 Seriate BG




ABB Laboratories, Ratingen, Germany
PEHLA Testing Laboratories, Ratingen,
Germany

БЯРНО С ОРИГИНАЛА

Power and productivity
for a better world™

ABB

Introducing Laboratories Ratingen

W

Since 1954, the laboratories of ABB AG – Calor Emag Medium Voltage Products have performed tests on medium voltage equipment. Our laboratories, which are located in Ratingen, Germany, contain all the facilities necessary for tests in the medium voltage range.

The ABB Laboratories Ratingen and PEHLA Testing Laboratories Ratingen are accredited by the German Accreditation Authority (DAkkS). As a shareholder of PEHLA GbR we are also a member laboratory of the Short-circuit Testing Liaison. We provide our customers with high performance and independent testing carried out in accordance with customer requirements or national and international standards.

<p>DAkkS Deutsche Akkreditierungsstelle</p> <p>Deutsche Akkreditierungsstelle GmbH German Accreditation Body</p> <p>Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1 subsection 1 AkkStelleGBV Signatory to the Multilateral Agreements of EA, ILAC and IAF for Mutual Recognition</p> <p>Accreditation</p> <p>The Deutsche Akkreditierungsstelle GmbH (German Accreditation Body) attests that the testing laboratory</p> <p>ABB AG Calor Emag Mittelspannungsprodukte Oberhausener Straße 33, 40472 Ratingen</p> <p>is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out tests in the following fields:</p> <p>High-Voltage Switchgear and Controlgear, Low-Voltage Switchgear and Controlgear Assemblies, Current and Voltage Transformers, Power Transformers and Busbar Systems</p> <p>The accreditation certificate shall only apply in connection with the notice of accreditation number D-PL-12115-01 and is valid until 2037-05-05 with the reverse side of the cover sheet and the following annex with a total of 5 pages. Registration number of the certificate: D-PL-12115-01-01</p> <p>BRPHOCOPRINTDATA</p>	<p>DAkkS Deutsche Akkreditierungsstelle</p> <p>Deutsche Akkreditierungsstelle GmbH German Accreditation Body</p> <p>Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1 subsection 1 AkkStelleGBV Signatory to the Multilateral Agreements of EA, ILAC and IAF for Mutual Recognition</p> <p>Accreditation</p> <p>The Deutsche Akkreditierungsstelle GmbH (German Accreditation Body) attests that the testing laboratory</p> <p>PEHLA GbR PEHLA-Prüfstand Ratingen Oberhausener Straße 33, 40472 Ratingen</p> <p>is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out tests in the following fields:</p> <p>High-Voltage Switchgear and Controlgear, Low-Voltage Switchgear and Controlgear Assemblies, Current and Voltage Transformers, Power Transformers and Busbar Systems</p> <p>The accreditation certificate shall only apply in connection with the notice of accreditation number D-PL-12072-06 and is valid until 2012-05-05 with the reverse side of the cover sheet and the following annex with a total of 5 pages. Registration number of the certificate: D-PL-12072-06-01</p> <p>EAK</p>
--	--


Why testing at Laboratories Ratingen?

With 60 years of experience we know how to perform tests professionally. Starting with the planning and preparation phase we cooperate closely with our customers in order to ensure an optimal testing. Our organization provides flexible planning which ensures short-term reservation.

When testing at the Laboratories Ratingen our customers may choose to either prepare the test objects on their own or make use of our assembly and installation service. By request an on-site testing can be performed in the customer's facilities. All test results will be evaluated by our team of highly qualified and experienced experts in close cooperation with the customers. Our laboratories are equipped with a SF₆ module to handle and recycle the gas for environmental safety. The accreditation as ABB Laboratories Ratingen and as PEHLA Testing Laboratories Ratingen ensures that all tests are fully independent.

Services we provide:

- On-site testing and diagnostics with mobile test equipment
- Independent witnessing of tests
- Inspections, examinations and diagnostics
- Manufacturing of prototypes and individual parts
- Assembly of prototypes and test objects
- Assembly and installation work
- Calibration of electrical and mechanical measuring equipment



Our documentation to the customers

2

When testing at Laboratories Ratingen different types of documentation can be issued.

Type test certificate

A type test certificate is issued for type tests which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of the test. For these tests the test object must be clearly identified by technical description, drawings and additional specifications.

Test document


A test document is issued for parts of type tests which have successfully been carried out in full compliance with the relevant specifications or standards and STL Guides valid at the time of test. For these tests the test object must be clearly identified by technical description, drawings and additional specifications.

Test report

A test report is issued for all other tests which have been carried out according to specifications, standards or "PEHLA-Richtlinien" (PEHLA Guides) and/or clients' instructions. Similarly, this test report contains all test results, details of the conditions under which the tests were carried out, also details relating to the behaviour of the test object, and its condition after the tests.

Test confirmation

A test confirmation is issued immediately after the tests. It confirms that the tests have been conducted and is valid only until publishing the detailed results in an entire document.



Development tests, type tests or acceptance tests

W

Laboratories Ratingen are able to offer any kind of test your company needs.

The laboratories are fully equipped to perform complete type tests on medium voltage equipment with state-of-the-art technology. All tests can be carried out as ABB tests or as PEHLA tests.

Tests we provide

- Type tests
- Development tests
- Acceptance tests (also in other test laboratories)
- Certification tests

Our test portfolio:

Tests	Products	MV circuit-breaker	Metal enclosed switchgear	Power transformer	Disconnect & earthing switch	Switch fuse unit	Earthing facility	Bushing	Instrument transformer	Fuse	Cable accessory	Auxiliary circuit	Substation
Making and Breaking test		●	●		●	●				●		●	●
STC test		●	●	●	●		●	●	●		●	●	●
Internal arc test			●										●
Capacitive switching test		●			●								
Temperature rise test		●	●		●	●	●	●	●	●	●	●	●
Climatic test		●	●	●	●	●	●	●	●	●	●	●	●
Dielectric test		●	●		●	●	●	●	●	●	●	●	●
IP/IK-coding test		●	●										●
Partial discharge test		●	●		●	●	●	●	●		●		●
Mechanical operation test		●	●		●	●						●	
Mechanical endurance test		●			●	●						●	
High and low temperature test		●	●		●			●		●			
Tightness test		●	●		●			●					
Pressure test		●	●		●								



Tests at Ratingen possible




Tests not applicable to this product

БРФНО С ОРГАНІЗАЦІєю

Overview of standards

High-voltage switchgear and controlgear	IEC 62271-1 IEC 62271-103 IEC 62271-106 IEC 62271-200 IEC 62271-203	IEC 62271-100 IEC 62271-104 IEC 62271-110 IEC 62271-201 IEC 62271-304	IEC 62271-102 IEC 62271-105 IEC 62271-111 IEC 62271-202 IEC 60529
High-voltage test techniques		IEC 60060-1	IEC 60060-2 IEC 60270
Power transformers		IEC 60076-5	IEC 60076-11
High-voltage fuses		IEC 60282-1	IEC 60282-2
Bushings		IEC 60137	
Insulators		IEC 60660	
Instrument transformers		IEC 61869-1	IEC 61869-2 IEC 61869-3
Live working		IEC 60832-1	IEC 60832-2 IEC 61230
Low-voltage switchgear and controlgear		IEC 60947-1	IEC 60947-2 IEC 60947-3
ANSI / IEEE	IEEE C37.04 ANSI C37.54	ANSI C37.06 IEEE C37.60	IEEE C37.09

Other standards on request

Testing facilities

The Laboratories Ratingen are coordinating tests very well even if different kind of tests in more than one laboratory are required. Customers, who need various tests, can therefore rely on well-organized test procedures – quickly and at fair conditions.

High-power testing laboratory


The high power testing laboratory is equipped with a 2800 MVA short-circuit test generator and oil-insulated power transformers and is therefore able to perform making and breaking tests at several voltage- and short-circuit current levels.

A special dry-type power transformer is available to perform peak-withstand current- and short-time withstand current test up to 250 kA and 100 kA r.m.s for three seconds.

Inside the room simulation of the arcing test bay, internal arcing tests can be performed for switchgear, containers or even substations.

A capacitor bank allows to perform different capacitive tests (e.g. line- or cable-charging current switching tests, back-to-back- and single-capacitor-bank current switching tests).

With the miscellaneous equipment like different reactors and resistors, measurement equipment etc., it is possible to perform a wide range of load current switching tests as well.





Laboratories Ratingen | 7

Testing facilities

The tests, which can be performed at our high power testing laboratory, are:

- Short-circuit making and breaking capacity test up to
 - 50 kA at 12 kV
 - 31.5 kA at 17.5 kV
 - 25 kA at 24 kV
 - 16 kA at 40.5 kV
- Switching capacity test Load currents
 - Capacitive
 - Inductive
 - Ohmic
 - Inductive-ohmic
- Peak withstand current test
 - Up to 250 kA
- Short-time withstand current test
 - Up to 100 kA and up to 3s (4s)
- Internal arc fault test
 - Up to 50 kA
- Different tests
 - beyond the standards according to client's instructions





Temperature-rise testing laboratory

The temperature-rise testing laboratory is suited to perform tests with a continuous current up to 5000 A on switchgear and switching devices. Through automated and computer controlled tests we use our resources in the most efficient and effective way. Therefore we can offer precise, reliable and quick tests during day and night-time to our customers.

During the test, currents and temperatures are checked every 10 minutes. Shorter measurement intervals for currents and temperatures are possible. A control circuit guarantees a constant three-phase current through the entire test. The test is automatically stopped if a temperature limit is exceeded or the test duration is over.

Temperature-rise tests

- Up to 180 measuring points can be connected
- Single-phase and three-phase
 - Up to 5000 A at 50 Hz
 - Up to 4000 A at 60 Hz
- Additionally we can offer
 - Magnetic field measurement
 - Thermal imaging



Testing facilities



High-voltage testing laboratory

With the test facilities in our high voltage testing laboratory all dielectric and partial discharge tests for medium voltage equipment can be carried out. For sensitive partial discharge tests a special test chamber is available with a background level < 1 pC.

In order to offer on-site testing the high-voltage laboratory has mobile test equipment.

The high-voltage testing laboratory performs the following tests:

- Standard lightning impulse voltage tests
 - Up to 800 kV
- Power-frequency voltage tests
 - Stationary up to 260 kV
 - Mobile up to 230 kV
- Partial discharge tests
 - Stationary up to 150 kV
 - Mobile up to 230 kV
- Degree of protection tests
- Tests on auxiliary and control circuits



W

Mechanical testing laboratory

The mechanical testing laboratory offers different functional, environmental and material tests especially on medium and low voltage equipment and their components.

The functional tests include endurance tests on switching devices, kinematic chain tests and function tests on any kind of interlocking or control system. For long-duration tests automatic control and monitoring systems are available to supervise various signals for diagnostics.



A wide range of measurement equipment is able to record via special sensors many additional data for detailed investigation of the test objects characteristics, like travels, rotation angles, forces, torques, pressures, temperatures, binary signal states and gas densities.

For gas-filled equipment we offer additionally gas-tightness and pressure withstand tests.

The environmental tests combine the above mentioned measurements and functional tests with special conditions during storage and/or operation like extreme temperatures, humidity, vibrations, inclination and other impacts.

Material testing concentrates on load tests like tensile, compression, mechanical impact IK-coding, torsion and bending tests.

High-speed video recording can be used for visual examination of very fast processes (up to 10,000 pic./s).



Testing facilities

[Handwritten signature]

Material testing laboratory

In this laboratory various climatic tests on materials, components and complete medium voltage switchgear panels can be carried out.

The testing facilities include two accessible climatic / thermo chambers. The main tests offered by the material testing laboratory are:

- Temperature tests
 - Range: -70 °C to +150 °C
 - Test voltage: 95 kV (1-phase)
- Climatic tests
 - Temperature range: +20 °C to +90 °C
 - Humidity range: 10 - 98 %
 - Test voltage: 95 kV (1-phase)
- Corrosion tests
 - Salt fog tests
 - Fog tests with sulfur dioxide
 - Tests with condensed water containing climate

Calibration service

At the calibration laboratory we are able to calibrate electrical measurement instruments, force measurement instruments, length measurement equipment, torque wrenches and pressure gas equipment.




Initial sampling inspection

Objects with different size can be digitized with top-quality by 3D-scanning.

The 3D scanner will also be used for

- Quality checks
 - Comparison of nominal/actual measurement data
 - according to CAD data set
 - Measurement of form and position tolerances without complex construction
 - Measurement of free formed surfaces
 - Serial measurement for quality checks, process safety
- Toolroom
 - Generation of drawings for CAD system derives from scan process
 - Check of initial batches





Workshop of the Laboratories

The workshop manufactures prototypes and test arrangements as well as provides complete assembly and installation service in connection with tests.

If defects occur during tests our workshop offers immediate repair service and manufacturing of spare parts.

In order to offer optimal service the workshop is fully equipped for all kind of metal processing.



14 | Laboratories Ratingen



Contacts at the Laboratories Ratingen

If you need more information on Laboratories Ratingen or if you would like to make reservations for a test please contact:

General manager
Dr. Stefan Göttlich
Phone: +49 2102 12-1736
Fax: +49 2102 12-1713
E-Mail: stefan.goettlich@de.abb.com

Manager of high-power testing laboratory
Dr. Martin Wember
Phone: +49 2102 12-1353
Fax: +49 2102 12-1713
E-Mail: martin.wember@de.abb.com

Manager of temperature-rise, material testing and calibration laboratory
Claus Loquingen
Phone: +49 2102 12-1372
Fax: +49 2102 12-1713
E-Mail: claus.loquingen@de.abb.com

Manager of high-voltage testing laboratory
Ralf Hutmacher
Phone: +49 2102 12-1968
Fax: +49 2102 12-1713
E-Mail: ralf.hutmacher@de.abb.com

Manager of mechanical testing and electronic laboratory
Michael Schöttler
Phone: +49 2102 12-1703
Fax: +49 2102 12-1713
E-Mail: michael.schoettler@de.abb.com

Manager of workshop
Reiner Huhle
Phone: +49 2102 12-1277
Fax: +49 2102 12-1713
E-Mail: reiner.huhle@de.abb.com

ВЯРНО С ОРИГИНАЛА

Contact

U

ABB AG
Calor Emag Medium Voltage Products
Oberhausener Strasse 33
40472 Ratingen, Germany
Phone: +49 2102 12-0
Fax: +49 2102 12-17 77
E-Mail: powertech@de.abb.com

www.abb.com/laboratories-ratingen

Note:

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. ABB AG does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights in this document and in the subject matter and illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts -- is forbidden without prior written consent of ABB AG.

Copyright© 2013 ABB
All rights reserved

DEABB 2497 13 gb Printed in Germany (05.13-1000-AMC)

U

ВЯРНО С ОРИГИНАЛА

Power and productivity
for a better world

ABB

U

Deutsche Akkreditierungsstelle GmbH

Anlage zur Akkreditierungsurkunde D-PL-12115-01-00 nach DIN EN ISO/IEC 17025:2005

Gültigkeitsdauer: 20.04.2017 bis 19.04.2022 Ausstellungsdatum: 20.04.2017

Urkundeninhaber:

ABB AG
Kallstater Str. 1, 68309 Mannheim

Standort:
ABB AG
Calor Emag Mittelspannungsprodukte
Oberhausener Straße 33, 40472 Ratingen

Prüfungen in den Bereichen:

Geräte und Anlagen der Nieder-, Mittel- und Hochspannung

Dem Prüflaboratorium ist, ohne dass es einer vorherigen Information und Zustimmung der DAkkS bedarf, die Anwendung der hier aufgeführten genormten oder ihnen gleichzusetzenden Prüfverfahren mit unterschiedlichen Ausgabeständen gestattet.

Das Prüflaboratorium verfügt über eine aktuelle Liste aller Prüfverfahren im flexiblen Akkreditierungsbereich.

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 61869-1 VDE 0414-9-1: April 2010 IEC 61869-1 Edition 1.0, 2007-10	Messwandler – Teil 1: Allgemeine Anforderungen (IEC 61869-1:2007, modifiziert); Deutsche Fassung EN 61869-1:2009 Instrument transformers – Part 1: General requirements (IEC 61869-1:2007, modified); German version EN 61869-1:2009	OK

Seite 1 von 18


БЯРНО С ОРИГИНАЛА



Deutsche
Akkreditierungsstelle

Anlage zur Akkreditierungsurkunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 61869-2 VDE 0414-9-2: 2013-07 + DIN EN 61869-2 Berichtigung 1: 2014- 06; VDE 0414-9-2 Berichtigung 1: 2014-06 IEC 61869-2 Edition 1.0, 2012-09	Messwandler – Teil 2: Zusätzliche Anforderungen für Stromwandler (IEC 61869-2:2012); Deutsche Fassung EN 61869-2:2012 Instrument transformers – Part 2: Additional requirements for current transformers (IEC 61869-2:2012); German version EN 61869-2:2012	
Elektrotechnik	DIN EN 61869-3 (VDE 0414-9-3): Mai 2012 IEC 61869-3 Edition 1.0, 2011-07	Messwandler – Teil 3: Zusätzliche Anforderungen für induktive Spannungswandler (IEC 61869-3:2011); Deutsche Fassung EN 61869-3:2011 Instrument transformers – Part 3: Additional requirements for inductive voltage transformers (IEC 61869-3:2011); German version EN 61869-3:2011	
Elektrotechnik	DIN EN 61869-4 VDE 0414-9-4: April 2015 IEC 61869-4 Edition 1.0, 2013-11	Messwandler - Teil 4: Zusätzliche Anforderungen für kombinierte Wandler (IEC 61869-4:2013) Deutsche Fassung EN 61869-4:2014 Instrument transformers - Part 4: Additional requirements for combined transformers German version EN 61869-4:2014	
Elektrotechnik	DIN EN 61869-5 (VDE 0414-9-5) Mai 2012 IEC 61869-5 Edition 1.0, 2011-07	Messwandler - Teil 5: Zusätzliche Anforderungen für kapazitive Spannungswandler (IEC 61869-5:2011); Deutsche Fassung EN 61869-5:2011 Instrument transformers – Part 5: Additional requirements for capacitor voltage transformers (IEC 61869-5:2011); German version EN 61869-5:2011	



Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

Ausstellungsdatum: 20.04.2017

Seite 2 von 18

Anlage zur Akkreditierungsurkunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 60060-1 (VDE 0432-1) Oktober 2011	Hochspannungs-Prüftechnik – Teil 1: Allgemeine Begriffe und Prüfbedingungen (IEC 60060-1:2010); Deutsche Fassung EN 60060-1:2010	
	IEC 60060-1 Edition 3.0, 2010-09	High-voltage test techniques – Part 1: General definitions and test requirements (IEC 60060-1:2010); German version EN 60060-1:2010	
Elektrotechnik	DIN EN 60060-2 (VDE 0432-2) Oktober 2011	Hochspannungs-Prüftechnik – Teil 2: Messsysteme (IEC 60060-2:2010); Deutsche Fassung EN 60060-2:2011	(without annex A) (ohne Anhang A)
	IEC 60060-2 Edition 3.0, 2010-11	High-voltage test techniques – Part 2: Measuring systems (IEC 60060-2:2010); German version EN 60060-2:2011	
Elektrotechnik	DIN EN 60076-5 (VDE 0532-76-5) Januar 2007	Leistungstransformatoren – Teil 5: Kurzschlussfestigkeit (IEC 60076-5:2006); Deutsche Fassung EN 60076-5:2006	
	IEC 60076-5 Third Edition, 2006-02	Power transformers – Part 5: Ability to withstand short-circuit (IEC 60076-5:2006); German version EN 60076-5:2006	
Elektrotechnik	DIN EN 60076-11 (VDE 0532-76-11) April 2005	Leistungstransformatoren – Teil 11: Trockentransformatoren (IEC 60076-11:2004); Deutsche Fassung EN 60076-11:2004	
	IEC 60076-11 First Edition, 2004-05	Power transformers – Part 11: Dry-type transformers (IEC 60076-11:2004); German version EN 60076-11:2004	
Elektrotechnik	DIN EN 60137 (VDE 0674-5) Juli 2009	Isolierte Durchführungen für Wechselspannungen über 1 000 V (IEC 60137:2008); Deutsche Fassung EN 60137:2008	
	IEC 60137	Insulated bushings for alternating voltages above	





Deutsche
Akkreditierungsstelle

Anlage zur Akkreditierungskunde D-PL-12115-01-00


Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
	Edition 6.0, 2008-07	1000 V (IEC 60137:2008); German version EN 60137:2008	
Elektrotechnik	DIN EN 62271-103 (VDE 0671-103) April 2012 IEC 62271-103 Edition 1.0, 2011-06	Hochspannungs-Schaltgeräte und -Schaltanlagen – Teil 103: Lastschalter für Bemessungsspannungen über 1 kV bis einschließlich 52 kV (IEC 62271-103:2011); Deutsche Fassung EN 62271-103:2011 High-voltage switchgear and controlgear – Part 103: Switches for rated voltages above 1 kV up to and including 52 kV (IEC 62271-103:2011); German version EN 62271-103:2011	
Elektrotechnik	DIN EN 62271-104 (VDE 0671-104) November 2015 IEC 62271-104 Edition 2.0, 2015-02	Hochspannungs-Schaltgeräte und -Schaltanlagen – Teil 104: Wechselstrom-Lastschalter für Bemessungsspannungen über 52 kV (IEC 62271-104:2015); Deutsche Fassung EN 62271-104:2015 High-voltage switchgear and controlgear – Part 104: Alternating current switches for rated voltages higher than 52 kV (IEC 62271-104:2015); German version EN 62271-104:2015	

Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

BRPHOC UPNINIA

Ausstellungsdatum: 20.04.2017

Seite 4 von 18

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 60270 (VDE 0434) August 2001 + DIN EN 60270 Berichtigung 1: November 2002; VDE 0414-9-2 Berichtigung 1: November 2002 IEC 60270 Third edition, 2000-12 + Amendment 1 Third edition, 2015-11	Hochspannungs-Prüftechnik Teilentladungsmessungen (IEC 60270:2000) Deutsche Fassung EN 60270:2001 High-voltage test techniques – Partial discharge measurement (IEC 60270:2000); German version EN 60270:2001	
Elektrotechnik	DIN EN 60282-1 (VDE 0670-4) August 2010 IEC 60282-1 Edition 7.1, 2014-07	Hochspannungssicherungen Teil 1: Strombegrenzende Sicherungen (IEC 60282-1:2009) Deutsche Fassung EN 60282-1:2009 High-voltage fuses – Part 1: Current-limiting fuses (IEC 60282-1:2009); German version EN 60282-1:2009	
Elektrotechnik	IEC 60282-2 Edition 3.0, 2008-04	High-voltage fuses – Part 2: Expulsion fuses	
Elektrotechnik	DIN EN 62271-106 (VDE 0671-106) Juni 2011 IEC 62271-106 Edition 1.0, 2011-08	Hochspannungs-Schaltgeräte und -Schaltanlagen – Teil 106: Wechselstrom-Schütze, Kombinationsstarter und Motorstarter mit Schützen (IEC 62271-106:2011); Deutsche Fassung EN 62271-106:2011 High-voltage switchgear and controlgear – Part 106: Alternating current contactors, contactor-based controllers and motor-starters (IEC 62271-106:2011); German version EN 62271-106:2011	



Deutsche
Akkreditierungsstelle

Anlage zur Akkreditierungskunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 60529 (VDE 0470-1) September 2014	Schutzarten durch Gehäuse (IP-Code) (IEC 60529:1989 + A1:1999 + A2:2013) Deutsche Fassung EN 60529:1991 + A1: 2000 + A2:2013	
	IEC 60529 Edition 2.2, 2013-08	Degree of protection provided by enclosures (IP Code) (IEC 60529:1989 + A1:1999 + A2:2013) German version EN 60529:1991 + A1: 2000 + A2:2013	
Elektrotechnik	DIN EN 60660 (VDE 0441-3) Dezember 2000	Isolatoren Prüfungen an Innenraum-Stützern aus organischem Werkstoff für Netze mit Nennspannungen über 1 kV bis kleiner 300 kV (IEC 60660:1999) Deutsche Fassung EN 60660:1999	
	IEC 60660 Edition 2.0, 1999-10	Insulators – Tests on indoor post insulators of organic material for systems with nominal voltages greater than 1 kV up to but not including 300 kV (IEC 60660:1999); German version EN 60660:1999	
Elektrotechnik	DIN EN 60832-1 (VDE 0682-211) Dezember 2010	Arbeiten unter Spannung – Isolierende Stangen und auswechselbare Arbeitsköpfe – Teil 1: Isolierende Stangen (IEC 60832-1:2010) Deutsche Fassung EN 60832-1:2010 + Cor.:2010	
	IEC 60832-1 Edition 1.0, 2010-02	Live working - Insulating sticks and attachable devices - Part 1: Insulating sticks (IEC 60832-1:2010) German version EN 60832-1:2010 + Cor.:2010	
Elektrotechnik	DIN EN 60832-2 (VDE 0682-212) Dezember 2010	Arbeiten unter Spannung – Isolierende Stangen und auswechselbare Arbeitsköpfe Teil 2: Auswechselbare Arbeitsköpfe (IEC 60832-2:2010); Deutsche Fassung EN 60832-2:2010 + Cor.:2010	
	IEC 60832-2 Edition 1.0, 2010-02	Live working - Insulating sticks and attachable devices - Part 2: Attachables devices (IEC 60832-2:2010); German version EN 60832-2:2010 + Cor.:2010	

Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

Ausstellungsdatum: 20.04.2017

Seite 6 von 18

Anlage zur Akkreditierungskunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 60947-1: (VDE 0660-100) Oktober 2011	Niederspannungsschaltgeräte – Teil 1: Allgemeine Festlegungen (IEC 60947-1:2007 + A1:2010); Deutsche Fassung EN 60947-1:2007 + A1:2011	
	DIN EN 60947-1/A2 (VDE 0660-100/A2) Mai 2014	Niederspannungsschaltgeräte – Teil 1: Allgemeine Festlegungen (IEC 17B/1806/CDV:2013); Deutsche Fassung EN 60947-1:2007/FprA2:2013	
	IEC 60947-1 Edition 5.2 2014-09 + Amendement 1 + 2	Low-voltage switchgear and controlgear - Part 1: General rules (IEC 60947-1:2007 + A1:2010); German version EN 60947-1:2007 + A1:2011	
Elektrotechnik	DIN EN 60947-2: VDE 0660-101 Januar 2014	Niederspannungsschaltgeräte – Teil 2: Leistungsschalter (IEC 60947-2:2006 + A1:2009 + A2:2013); Deutsche Fassung EN 60947-2:2006 + A1:2009 + A2:2013	
	DIN EN 60947-2 (VDE 0660-101) März 2015	Niederspannungsschaltgeräte – Teil 2: Leistungsschalter (IEC 121A/26/CDV:2014); Deutsche Fassung FprEN 60947-2:2014	
	IEC 60947-2 Edition 5.0 2016-06	Low-voltage switchgear and controlgear – Part 2: Circuit-breakers (IEC 60947-2: 2016); German version EN 60947-2:2006 + A1:2009 + A2:2013	

Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

Ausstellungsdatum: 20.04.2017

Seite 7 von 18

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 60947-3: VDE 0660-10 Dezember 2012	Niederspannungsschaltgeräte - Teil 3: Lastschalter, Trennschalter, Lasttrennschalter und Schalter-Sicherungs-Einheiten (IEC 60947- 3:2008 + A1:2012); Deutsche Fassung EN 60947- 3:2009 + A1:2012	
	DIN EN 60947-3 Berichtigung 1 (VDE 0660-107 Berichtigung 1) März 2015	Niederspannungsschaltgeräte – Teil 3: Lastschalter, Trennschalter, Lasttrennschalter und Schalter-Sicherungs- Einheiten (IEC 60947-3:2008 + A1:2012); Deutsche Fassung EN 60947-3:2009 + A1:2012, Berichtigung zu DIN EN 60947-3 (VDE 0660- 107):2012-12; (IEC-Cor.:2013 zu IEC 60947- 3:2008/A1:2012)	
	DIN EN 60947- 3/A2:2015-03; VDE 0660-107/A2:2015-03	Niederspannungsschaltgeräte – Teil 3: Lastschalter, Trennschalter, Lasttrennschalter und Schalter-Sicherungs- Einheiten (IEC 121A/7/CDV:2014); Deutsche Fassung EN 60947-3:2009/FprA2:2014	
	IEC 60947-3 Edition 3.1 2012-04 + Amendement 1	Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch- disconnectors and fuse-combination units (IEC 60947-3:2008 + A1:2012); German version EN 60947-3:2009 + A1:2012	
Elektrotechnik	DIN EN 61230, (VDE 0683-100) Juli 2009	Ortsveränderliche Geräte zum Erden oder Erden und Kurzschließen (IEC 61230:2008); Deutsche Fassung EN 61230:2008	
	IEC 61230 Edition 2.0, 2008-07	Live working - Portable equipment for earthing or earthing and short-circuiting (IEC 61230:2008); German version EN 61230:2008	



Deutsche
Akkreditierungsstelle

Anlage zur Akkreditierungsurkunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 61869-1 VDE 0414-9-1 April 2010 IEC 61869-1 Edition 1.0, 2007-10	Messwandler Teil 1: Allgemeine Anforderungen (IEC 61869-1:2007, modifiziert); Deutsche Fassung EN 61869-1:2009 Instrument transformers - Part 1: General requirements (IEC 61869-1:2007, modified); German version EN 61869-1:2009	
Elektrotechnik	DIN EN 62271-1 VDE 0671-1 August 2009 + DIN EN 62271-1/A1 VDE 0671-1/A1 April 2012 IEC 62271 Edition 1.1, 2011-08	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 1: Gemeinsame Bestimmungen (IEC 62271-1:2007); Deutsche Fassung EN 62271-1:2008 Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 1: Gemeinsame Bestimmungen (IEC 62271-1:2007/A1:2011); Deutsche Fassung EN 62271-1:2008/A1:2011 High-voltage switchgear and controlgear - Part 1: Common specifications (IEC 62271-1:2007); German version EN 62271-1:2008	
Elektrotechnik	DIN EN 62271-100 VDE 0671-100 August 2013 IEC 62271-100 Edition 2.1, 2012-09	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 100: Wechselstrom-Leistungsschalter (IEC 62271-100:2008 + A1:2012); Deutsche Fassung EN 62271-100:2009 + A1:2012 High-voltage switchgear and controlgear – Part 100: Alternating current circuit-breakers (IEC 62271-100:2008 + A1:2012); German version EN 62271-100:2009 + A1:2012	

Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

БАРХО С ОРИГИНАЛА

Ausstellungsdatum: 20.04.2017

Seite 9 von 18

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 62271-102 VDE 0671-102 August 2013 +	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 102: Wechselstrom-Trennschalter und - Erdungsschalter (IEC 62271-102:2001 + Corrigenda 2002 & 2003 + A1:2011); Deutsche Fassung EN 62271-102:2002 + Cor.:2008 + A1:2011	
	DIN EN 62271-102/A2 VDE 0671-102/A2 Dezember 2013	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 102: Wechselstrom-Trennschalter und - Erdungsschalter (IEC 62271-102:2001/A2:2013); Deutsche Fassung EN 62271-102:2002/A2:2013	
	IEC 62271-102 Edition 1.2, 2013-02	High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches (IEC 62271-102:2001 + Corrigenda 2002 & 2003 + A1:2011 + A2:2013); German version EN 62271-102:2002 + Cor.:2008 + A1:2011 + A2:2013	
Elektrotechnik	DIN EN 62271-105 VDE 0671-105 August 2013	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 105: Wechselstrom-Lastschalter-Sicherungs- Kombinationen für Bemessungsspannungen über 1 kV bis einschließlich 52 kV (IEC 62271-105:2012); Deutsche Fassung EN 62271-105:2012	
	IEC 62271-105 Edition 2.0, 2012-09	High-voltage switchgear and controlgear – Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV (IEC 62271-105:2012); German version EN 62271-105:2012	
Elektrotechnik	DIN EN 62271-110 VDE 0671-110 August 2013	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 110: Schalten induktiver Lasten (IEC 62271-110:2012 + corrigendum Oct. 2012); Deutsche Fassung EN 62271-110:2012	
	IEC 62271-110 Edition 3.0, 2012-09	High-voltage switchgear and controlgear – Part 110: Inductive load switching (IEC 62271-110:2012 + corrigendum Oct. 2012); German version EN 62271-110:2012	


Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	E DIN EN 62271-111 VDE 0671-111 September 2014 IEC 62271-111: 2012(E) IEEE Std C37.60- 2012(E) Edition 2.0 2012-09	Hochspannungs-Schaltgeräte -und Schaltanlagen Teil 111: Automatische Wiedereinschalter und Fehlerunterbrecher für Wechselspannungssysteme bis 38 kV (IEC 17A/1060/CD:2014) High-voltage switchgear and controlgear – Part 111: Automatic circuit reclosers and fault interrupters for alternating current systems up to 38 kV	
Elektrotechnik	DIN EN 62271-200 VDE 0671-200 August 2012 + Berichtigung 1 IEC 62271-200 Edition 2.0, 2011-10 + Corrigendum 1	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 200: Metallgekapselte Wechselstrom- Schaltanlagen für Bemessungsspannungen über 1 kV bis einschließlich 52 kV (IEC 62271-200:2011); Deutsche Fassung EN 62271-200:2012 + Berichtigung 1:2016-01 High-voltage switchgear and controlgear – Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV (IEC 62271-200:2011 + Corrigenda 2015); German version EN 62271-200:2012 + Berichtigung 1:2016-01	
Elektrotechnik	DIN EN 62271-201 VDE 0671-201 Juli 2007 IEC 62271-201 Edition 2.0, 2014-03	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 201: Isolierstoffgekapselte Wechselstrom- Schaltanlagen für Bemessungsspannungen über 1 kV bis einschließlich 52 kV (IEC 62271-201:2006); Deutsche Fassung EN 62271-201:2006 High-voltage switchgear and controlgear - Part 201: AC insulation-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV (IEC 62271-201:2014);	



Deutsche
Akkreditierungsstelle

Anlage zur Akkreditierungsurkunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 62271-202 VDE 0671-202 August 2007	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 202: Fabrikfertige Stationen für Hochspannung/Niederspannung (IEC 62271-202:2006); Deutsche Fassung EN 62271-202:2007	
	IEC 62271-202 Edition 2.0, 2014-03	High-voltage switchgear and controlgear – Part 202: High-voltage/ low-voltage prefabricated substation (IEC 62271-202:2014);	
Elektrotechnik	DIN EN 62271-203 VDE 0671-203 November 2012	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 203: Gasisolierte metallgekapselte Schaltanlagen für Bemessungsspannungen über 52 kV (IEC 62271-203:2011); Deutsche Fassung EN 62271-203:2012	
	IEC 62271-203 Edition 2.0, 2011-09	High-voltage switchgear and controlgear – Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV (IEC 62271-203:2011); German version EN 62271-203:2012	
Elektrotechnik	E DIN EN 62271-304 VDE 0671-304 April 2007	Zusätzliche Anforderungen an gekapselte Schaltgerätekombinationen und Hochspannungsschaltanlagen von 1 kV bis 52 kV für den Einsatz unter erschwerten klimatischen Bedingungen (IEC 17C/373/CD:2006)	
	IEC/TS 62271-304 Edition 1.0, 2008-05	High-voltage switchgear and controlgear – Part 304: Design classes for indoor enclosed switchgear and controlgear for rated voltages above 1 kV up to and including 52 kV to be used in severe climatic conditions (IEC/TS 62271-304:2008)	



Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

Ausstellungsdatum: 20.04.2017

Seite 12 von 18

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	E DIN IEC 62271-37-013 VDE 0671-37-013; 2012-09 IEC/IEEE 62271-37-013 Edition 1.0, 2015-10	Hochspannungs-Schaltgeräte und -Schaltanlagen Teil 37-013: Wechselstrom-Generatorschalter (IEC 17A/993/CD:2011) High-voltage switchgear and controlgear – Part 37-013: Alternating-current generator circuit-breakers	
Elektrotechnik	DIN EN 60068-2-1 VDE 0468-2-1 Januar 2008 IEC 60068-2-1 Edition 6.0, 2007-03	Umgebungseinflüsse - Teil 2-1: Prüfverfahren - Prüfung A: Kälte (IEC 60068-2-1:2007); Deutsche Fassung EN 60068-2-1:2007 Environmental testing – Part 2-1: Tests – Test A: Cold (IEC 60068-2-1:2007); German version EN 60068-2-1:2007	
Elektrotechnik	DIN EN 60068-2-2 VDE 0468-2-2 Mai 2008 IEC 60068-2-2 Edition 5.0, 2007-07	Umgebungseinflüsse - Teil 2-2: Prüfverfahren - Prüfung B: Trockene Wärme (IEC 60068-2-2:2007); Deutsche Fassung EN 60068-2-2:2007 Environmental testing – Part 2-2: Tests – Test B: Dry heat (IEC 60068-2-2:2007) German version EN 60068-2-2:2007	
Elektrotechnik	DIN EN 60068-2-30 Juni 2006 IEC 60068-2-30 Edition 3.0, 2005-08	Umgebungseinflüsse - Teil 2-30: Prüfverfahren - Prüfung Db: Feuchte Wärme, zyklisch (12 + 12 Stunden) (IEC 60068-2-30:2005); Deutsche Fassung EN 60068-2-30:2005 Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle) (IEC 60068-2-30:2005) German version EN 60068-2-30:2005	
Elektrotechnik	IEC 62262 Edition 1.0, 2002-02	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code) German version SN EN 62262:2002	



Deutsche
Akkreditierungsstelle

Anlage zur Akkreditierungsurkunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 60068-2-75 VDE 0468-2-75 2015-08 IEC 60068-2-75 Edition 2.0, 2014-09	Umgebungseinflüsse - Teil 2-75: Prüfungen - Prüfung Eh: Hammerprüfungen (IEC 60068-2-75:2014); Deutsche Fassung EN 60068-2-75:2014 Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests (IEC 60068-2-75:2014) German version EN 60068-2-75:2014	
Elektrotechnik	IEEE Std C37.04- 1999 June 1999	IEEE Standard Rating Structure for AC High-Voltage Circuit Breakers IEEE Std C37.04-1999 (Revision of IEEE Std C37.04-1979)	
Elektrotechnik	IEEE Std C37.06-2009 November 2009	IEEE Standard for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis - Preferred Ratings and Related Required Capabilities for Voltages Above 1000 V IEEE Std C37.06-2009 (Revision of ANSI C37.06-2000)	
Elektrotechnik	IEEE Std C37.09-1999 (R2007) June 1999	IEEE Standard Test Procedure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis IEEE Std C37.09™-1999 (R2007) (Revision of IEEE Std C37.09-1979)	
Elektrotechnik	ANSI C37.54- 2002 March 2003	American National Standard For Indoor Alternating Current High-Voltage Circuit Breakers Applied as Removable Elements in Metal-Enclosed Switchgear— Conformance Test Procedures	
Elektrotechnik	ANSI C37.20.2-2015	IEEE Standard for Metal-Clad Switchgear	
Elektrotechnik	ANSI C37.20.7-2007	IEEE Guide for Testing Metal-Enclosed Switchgear Rated Up to 38 kV for Internal Arcing Faults	
Elektrotechnik	ANSI C37.122.2- 2011	IEEE Guide for the Application of Gas Insulated Substations 1kV to 52kV	
Elektrotechnik	IEEE Std C57.13-2008	IEEE Standard Requirements for Instrument Transformers	

Gültigkeitsdatum 16.04.2017 bis 19.04.2022
DAkkS

Ausstellungsdatum: 20.04.2017

Seite 14 von 18



Deutsche
Akkreditierungsstelle

Anlage zur Akkreditierungsurkunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	E DIN EN 61180 VDE 0432-10 Juli 2013	Hochspannungs-Prüftechnik für Niederspannungsgeräte Begriffe, Prüfung und Prüfbedingungen, Prüfgeräte	
	DIN EN 61180-1 VDE 0432-10 Mai 1995	Hochspannungs-Prüftechnik für Niederspannungsgeräte Begriffe, Prüfung und Prüfbedingungen (IEC 61180-1:1992); Deutsche Fassung EN 61180-1:1994	
	IEC 61180-1 Edition 1.0, 1992-10	High-voltage test techniques for low voltage equipment – Part 1: Definitions, test and procedure requirements (IEC 61180-1:1992); German version EN 61180-1:1994	
	DIN EN 61180-2 VDE 0432-11 Mai 1995	Hochspannungs-Prüftechnik für Niederspannungsgeräte Prüfgeräte (IEC 61180-2:1994); Deutsche Fassung EN 61180-2:1994	
	IEC 61180-2 Edition 1.0, 1994-06	High-voltage test techniques for low-voltage equipment – Part 2: Test equipment (IEC 61180-2:1994); German version EN 61180-2:1994	

Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

Ausstellungsdatum: 20.04.2017

Seite 15 von 18

Anlage zur Akkreditierungsurkunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 61439-1 VDE 0660-600-1 Juni 2012 + DIN EN 61439-1 Bbl 1 VDE 0660-600-1 Bbl 1 Berichtigung 1 Dezember 2014 + DIN EN 61439-1 VDE 0660-600-1 Beiblatt 1: Juni 2014 IEC 61439-1 Edition 2.0, 2011-08 IEC/TR 61439-0 Edition 2.0, 2013-04	Niederspannungs-Schaltgerätekombinationen Teil 1: Allgemeine Festlegungen (IEC 61439-1:2011); Deutsche Fassung EN 61439-1:2011 Berichtigung zu DIN EN 61439-1 Beiblatt 1 (VDE 0660-600-1 Beiblatt 1):2014-06 Niederspannungs-Schaltgerätekombinationen Teil 1: Allgemeine Festlegungen; Beiblatt 1: Leitfaden für die Spezifikation von Schaltgerätekombinationen (IEC/TR 61439-0:2013) Low-voltage switchgear and controlgear assemblies – Part 1: General rules (IEC 61439-1:2011); German version EN 61439-1:2011 Low-voltage switchgear and controlgear assemblies – Part 0: Guidance to specifying assemblies	
Elektrotechnik	DIN EN 61439-2 VDE 0660-600-2 Juni 2012 IEC 61439-1 Edition 2.0, 2011-08	Niederspannungs-Schaltgerätekombinationen Teil 2: Energie-Schaltgerätekombinationen (IEC 61439-2:2011); Deutsche Fassung EN 61439-2:2011 Low-voltage switchgear and controlgear assemblies – Part 2: Power switchgear and controlgear assemblies (IEC 61439-2:2011); German version EN 61439-2:2011	

Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

Ausstellungsdatum: 20.04.2017

Seite 16 von 18



Deutsche
Akkreditierungsstelle

Anlage zur Akkreditierungskunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 61439-3 VDE 0660-600-3 Februar 2013 +	Niederspannungs-Schaltgerätekombinationen Teil 3: Installationsverteiler für die Bedienung durch Laien (DBO) (IEC 61439-3:2012); Deutsche Fassung EN 61439-3:2012	
	DIN EN 61439-3 VDE 0660-600-3 Berichtigung 1 Oktober 2014	Berichtigung zu DIN EN 61439-3 (VDE 0660-600-3):2013-02; (IEC-Cor.:2013 zu IEC 61439-3:2012)	
	IEC 61439-3 Edition 1.0, 2012-02	Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO) (IEC 61439-3:2012); German version EN 61439-3:2012	
Elektrotechnik	DIN EN 61439-4 VDE 0660-600-4 September 2013	Niederspannungs-Schaltgerätekombinationen Teil 4: Besondere Anforderungen für Baustromverteiler (BV) (IEC 61439-4:2012); Deutsche Fassung EN 61439-4:2013	
	IEC 61439-4 Edition 1.0, 2012-11	Low-voltage switchgear and controlgear assemblies – Part 4: Particular requirements for assemblies for construction sites (ACS) (IEC 61439-4:2012); German version EN 61439-4:2013	

Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

BRPRO C OPIWIAJA

Ausstellungsdatum: 20.04.2017

Seite 17 von 18



Deutsche
Akkreditierungsstelle

Anlage zur Akkreditierungsurkunde D-PL-12115-01-00

Fachbereich	Norm / Hausverfahren / Version	Titel der Norm oder des Hausverfahrens (ggf. Abweichungen / Modifizierungen von Normverfahren angeben)	Prüfbereich / Einschränkung
Elektrotechnik	DIN EN 61439-5 VDE 0660-600-5 Oktober 2011	Niederspannungs-Schaltgerätekombinationen Teil 5: Schaltgerätekombinationen in öffentlichen Energieverteilungsnetzen (IEC 61439-5:2010); Deutsche Fassung EN 61439-5:2011	
	E DIN EN 61439-5 VDE 0660-600-5 Juli 2014	Niederspannungs-Schaltgerätekombinationen Teil 5: Schaltgerätekombinationen in öffentlichen Energieverteilungsnetzen (IEC 17D/492/CDV:2013); Deutsche Fassung FprEN 61439-5:2013	
	IEC 61439-5 Edition 2.0, 2014-08	Low-voltage switchgear and controlgear assemblies - Part 5: Assemblies for power distribution in public networks (IEC 61439-5:2014);	
Elektrotechnik	DIN EN 60439-1 VDE 0660-500 Beiblatt 2 Mai 2009	Niederspannungs-Schaltgerätekombinationen Teil 1: Typgeprüfte und partiell typgeprüfte Kombinationen – Technischer Bericht: Verfahren für die Prüfung unter Störlichtbogenbedingungen (IEC/TR 61641:2008)	
	IEC TR 61641 Edition 3.0, 2014-09	Enclosed low-voltage switchgear and controlgear assemblies – Guide for testing under conditions of arcing due to internal fault	

Gültigkeitsdauer: 20.04.2017 bis 19.04.2022

Ausstellungsdatum: 20.04.2017

Seite 18 von 18

БЯРНО С ОРИГИНАЛА

()

Д Е К Л А Р А Ц И Я
за конфиденциалност и извършен оглед на обект по предмета на поръчката

Долуподписаният Георги Николов Табаков в качеството ми на представляващ „Електролукс Табаков и синове“ ООД, участник в процедура за възлагане на обществена поръчка с реф. № PPD 17 – 052 и предмет: „Модернизация (ретрофит) на електрически уредби 110/20 (10) кV и въвеждането им в режим на телемеханика“,

Д Е К Л А Р И Р А М, ЧЕ:

1/ Представител на участника, когото представлявам е извършил оглед на енергийния обект от обхвата на Обособена позиция 5 /ОП 5/- Модернизация (ретрофит) на закрита разпределителна уредба 20 kV в подстанция „Студентски град“, а именно: п/ст „Студентски град“ и съм запознат със съществуващото положение в обекта.

2/ Няма да разпространявам поверителна информация, във връзка с извършения оглед на обекта на Възложителя, като ми е известно, че за поверителна се счита всяка информация, относно пропускателния режим в обекта, организацията на работната сила и работния процес, наличното оборудване и техническите схеми на функционирането му, системите за защита и сигурност в обекта и всичко, което е свързано с наличното оборудване, съоръжения и тяхното функциониране в съответния обект.

3/ Прилагам документ за извършен оглед, съставен на място в подстанцията.

Приложение: съгласно текста

Дата 25.07.2017 г.

Декларатор: 
Георги Табаков-Управител/

ДЕКЛАРАЦИЯ
за конфиденциалност във връзка с посещение на обект

Долуподписанието Стадион Георгиев Каменец
(собствено, бащино и фамилно име)

ЕГН 661211348 притежаващ лична карта № 64038 6823, издадена на 30.06.2010
от МЗР-Предприе с постоянен адрес: г. Пловдив НВ Троян
д. 14 бх 6

Представител на "ЕлектроПроект Градеж и съветуване" ООД
(наименование на юридическото лице/физическото лице и вид на
търговеца)

Със седалище и адрес на управление:

г. Пловдив, ул. "Седем" 9


зainteresовано лице по смисъла на §2, т.14 от Допълнителните разпоредби на Закона за обществените поръчки за открита процедура за възлагане на обществена поръчка с предмет: „Модернизация (ретрофит) на електрически уредби 110/20 (10) кV и въвеждането им в режим на телемеханика”, реф. № РРД 17 - 052, във връзка с посещението на обекта, предмет на обществената поръчка, с цел запознаване със съществуващото му положение, включително с действащите електрически съоръжения и спецификата на ПС.

ДЕКЛАРИРАМ:

- Няма да разгласявам по никакъв начин информацията станала ми известна при запознаване със съществуващото му положение, включително с действащите електрически съоръжения и спецификата на ПС.
- Наясно съм, че разгласяване на информация по смисъла на настоящата декларация представлява всяка към вид устно или писмено изявление, предаване на информация на хартиен, електронен или друг носител, включително по поща, факс или електронна поща, както и всяка към друг начин на разгласяване на информация, в това число чрез средствата за масово осведомяване, печатните издания или интернет.

Известна ми е отговорността по чл.313 от Наказателния кодекс.

Дата 19.07.17 г.



Декларатор:

подпис

трите имена

Име. ид. Възложител: Красимир Димитров 506

ДЕКЛАРАЦИЯ

за приемане на условията в проекта на договор

Долуподписаният Георги Николов Табаков в качеството ми на представляващ „Електролукс Табаков и синове“ ООД, участник в обществена поръчка с реф. № PPD 17 – 052 и предмет: „Модернизация (ретрофит) на електрически уредби 110/20 (10) кV и въвеждането им в режим на телемеханика“, Обособена позиция 5 /ОП 5/ - Модернизация (ретрофит) на закрита разпределителна уредба 20 кV в подстанция „Студентски град“;

Д Е К Л А Р И Р А М, ЧЕ:

Приемам условията в проекта на договор, приложен в документацията за участие.

(
Дата 25.07.2017 г.

Декларатор:
/Георги Табаков-Управител/

Д Е К Л А Р А Ц И Я

за срока на валидност на офертата

Долуподписаният Георги Николов Табаков, притежаващ лична карта №641449027, издадена на 17.11.2010 г. от МВР – гр. Пловдив, адрес с.Белащица, общ.Родопи, обл.Пловдив, ул."Съединение" №2Б в качеството ми на Управител на „Електролукс Табаков и синове“ ООД участник в процедура за възлагане на обществена поръчка с предмет: „Модернизация (ретрофит) на електрически уредби 110/20 (10) kV и въвеждането им в режим на телемеханика“, реф. № PPD 17-052, Обособена позиция 5 /ОП 5/ - Модернизация (ретрофит) на закрита разпределителна уредба 20 kV в подстанция „Студентски град“;

Д Е К Л А Р И Р А М, ЧЕ:

С подаване на офертата за участие в обществената поръчка, направените от нас предложения и поети ангажименти са валидни за срока, посочен в обявленето, считано от крайния срок за подаване на офертите.

Дата 25.07.2017 г.

Декларатор:

Георги Табаков-Управител/

