


CESI TEST A4/509306 oscillogram n° 1

ВЯРНО С ОПРИТНАТА



[Handwritten signature]





[Handwritten signature]

CESI TEST A4/509306 oscillogram n. 2

[Handwritten signature]

ВЯЧНО С ОПРИГНАЛАТА






СЕСИ TEST A4/509306 oscillogram n. 3


ВЯРНО С ОРИГИНАЛА

"БАК - 02" ОРД
[Signature]

oscillogram.no.04



oscillogram no.05




CESI TEST A4/509306

ВЯРНО С ОПРИГНАЛНАТА



oscillogram no.06




CESI TEST A4/509306



ВЪРХО С ОБЕДНАТА



253



[Handwritten signature]


CESI TEST A4/509306 oscillogram n. 7

[Handwritten signature]


ВЯРНО С ОРИГИНАЛА



10. Plans / Drawings



ECHELLE 1:2



PROTOKOLLO DATA
 # 4/500487.1 # 3 10.2004
 Firma: *Walo Grou*

| N° model | R.D. | DESIGNATION | VISA | DATE |
|----------|------|-------------|------|------|
| A | | | | |

| | | | | | | |
|--|--------|-------|-------------|-----------|--------|-------------|
| N° PLAN | Revisé | Int'c | Designation | Reference | Notice | Observation |
| TOLERANCES GENERALES: | | | | | | |
| <input type="checkbox"/> TRAITEMENT: GALVANISATION A CHAUD SELON SA C233 <input type="checkbox"/> AUTRE (voir cote) | | | | | | |

MODULE AZB 36



Indice des POINTS - 42800 ST JOSEPH
 tel : 04.77.75.25.98, fax : 04.77.83.22.90.

| | |
|--------------------------------|---------------|
| DESIGNER PAR : ID | NOUVEAU : AS |
| DATE : 09/09/2004 | ECHELLE : 1:2 |
| VERIFIE PAR : | DATE : |
| PLAN N° - DRAWING N° - PLAN N° | |
| 99B524923A | |



ВАРЖО С ОБЯЗАТЕЛНАТА

client **Dervasil - Saint Joseph (France)**

equipment under test **Polymer housed metal-oxide surge arresters Type AZB 27**

tests performed **Weather ageing test - Test series A**

normative documents **IEC Standard 60099-4 Edition 2.0 (2004-05).**

receipt date of the sample **May 24, 2004**

test date **from July 8, 2004 to August 24, 2004**

no. of pages **22** no. of pages annexed **8**

the test results relate only to the sample tested
this document shall not be reproduced except in full without the written approval of CESI

first issue date **May 12, 2006**

prepared **PeC/TEST - G. Fedeli**

на основание чл. 2 от ЗЗЛД

verified **PeC/TEST - A. Sironi**

approved **PeC/TEST - M. de Nigri**

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prova di Componenti

на основание чл. 2 от ЗЗЛД

CESI
Centro Elettrotecnico
Sperimentale Italiano
Giulio Motte SpA

Via R. Rubattino 63 -
20134 Milano - Italia
Telefono +39 022126.1
Fax +39 022126440
www.cesi.it

Capitale per
interamente
Codice fiscale e numero
iscrizione CCIAA 00793580160

se di Milano
N. R.E.A. 429222
P.I. IT00793580160

ВАРНО С ОПИТИВАНАТА



tests witnessed by: /

identification of the object: Performed

The Manufacturer guarantees that the tested surge arrester is manufactured according to the submitted drawings.

CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawings identified by CESI and numbered A5/021441 no.1 to 10 have been returned to the Client.

The data necessary to permit repetition of the tests are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with impulse current : peak value: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3 \%$
- dielectric tests with direct voltage : voltage: $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.


laboratory information

CESI testing team: G. Fedeli

test laboratory: P188

activity code: 41285B

keywords: 12015R 23801L 31020W 44060J 53001D



Handwritten number 251

| contents | page | test date |
|--|------|----------------------|
| Test object | 4 | |
| Test carried out and test procedure | 8 | |
| Summary of test result | 9 | |
| Initial measurements | 11 | 05/12/04 |
| Weather ageing test. Test circuit | 13 | |
| Weather ageing test. Test arrangement | 14 | |
| Weather ageing test. Pictures after the test | 16 | 07/08/04 to 08/24/04 |
| Final measurements | 21 | 08/30/04 |
| Reference documents annexed: | | |
| Oscillograms (8 pages), CESI no. A4/510342 | | |



CESI
TEST

Test Report

AT-A5/022740

Test object

Type: Two polymer housed metal-oxide surge arrester type AZB 27.
The test objects were identified by Cesi as sample W1 and sample W2.


electrical characteristics (claimed by the client)

| | |
|---|----------------------------------|
| manufacturer's name | DERVASIL - Saint Joseph (France) |
| nominal discharge current - I_N [kA] | 10,0 |
| rated voltage - U_n [kV] | 27,0 |
| continuous operating voltage - U_c [kV] | 22,0 |
| line discharge class | 1 |
| rated frequency - [Hz] | 50 |

Dimensional characteristics of the test objects, claimed by the Client:

| | |
|---------------------|-------|
| total height [mm] | 272,4 |
| sheds diameter [mm] | 119 |
| core diameter [mm] | 59,4 |

ВЯРНО С ОРМЪВНАТА




259

Dimensional characteristics of the test objects measured by Cesi


| | |
|------------------------|------|
| total height [mm] | 270 |
| creepage distance [mm] | 711 |
| arching distance [mm] | 297 |
| number of sheds [n] | 9 |
| sheds diameter [mm] | 116 |
| core diameter [mm] | 59,5 |
| sheds spacing [mm] | 25 |
| sheds projection [mm] | 30 |
| | |

MOD.A117816

ВЯРНО С ОПИТАНАТА



Picture of the test object W1



[Handwritten signature]


[Handwritten signature]

ВЯЖУ С ОРИГИНАЛАТА

"БАК - 02" ООД
САМОКОВ

[Handwritten signature] 261

Picture of the test object W2



ВЯРНО С ОРИГИНАЛАТА

“БАК - 02” ООД
САМОКОВ

Test carried out and test procedure

Test has been carried out according with IEC Standard 60099-4 (2004-05) edition 2.0 "Metal-oxide surge arrester without gaps for a.c. system", at clause 10.8.14 .

Initial measurement

- The reference voltage have been measured at reference current equal to 5 mA_{pk}

- Internal partial discharge have been measured.

The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec.

The voltage has been decreased to 1,05 times the continuous operating voltage (U_o) and the partial discharge level has been measured according to the reference standard.

Weather ageing test. Test series A: 1000 hours

Note: During the weather ageing test, the test objects were tested in parallel with a Dervasil insulator.

The test samples have been assembled in the test room in vertical position spaced each-other and from the chamber walls in order to avoid electrical field disturbance.

Test objects have been cleaned with deionized water before starting the test.

The surge arresters have been energized at $U_{test} = 22 \text{ kV}_{rms}$ and kept for a total duration of 1000 hours in the test room filled with salt fog.

The water flow rate was $0,4 \pm 0,1 \text{ l/h} \cdot \text{m}^3$

At the beginning the salinity of the water solution was 10 Kg/m^3 . Then it has been decreased to 5 Kg/m^3 after 591 hours, and to $2,5 \text{ Kg/m}^3$ after 610 hours (see the paragraph "summary of test result").

The salt fog was not directly sprayed against the test specimens.

A scheme and a view of the test configuration are shown at pages 14 and 15.

The test sample has been visually inspected after about 500 hours and at test completion. Photos were taken at the end of the test.

Final measurement

The initial measurement were repeated.

Summary of test result

Test series A: 1000 hours

The external flashovers occurred during the test are noted in table below. The test salinity had to be changed twice.

| sample W1 | sample W2 | test salinity | salinity change |
|---------------------------------------|---------------------------------------|---------------|-------------------|
| 1 st Flashover after 565 h | | 10 g/l | |
| 2 nd Flashover after 591 h | | 10 g/l | from 10 to 5 g/l |
| 3 rd Flashover after 595 h | | 5 g/l | |
| | 1 st Flashover after 610 h | 5 g/l | from 5 to 2,5 g/l |
| | 2 nd Flashover after 976 h | 2,5 g/l | |
| | 3 rd Flashover after 981 h | 2,5 g/l | |

Visual inspection

Note: Sheds are numbered starting from the live side.

- After 500 hours

No tracking, shed puncture or significant erosions have been evidenced by the visual inspection carried out after 500

- After 1000 hours

Sample W1:

An overall view of the object after 1000 hours is shown in the photo at page 16.

No tracking, significant erosion or puncture was observed.

Shallow and diffuse erosions were visible on all circumference of the core between sheds n.2 and n.3 and, in less diffused way, also on the core between sheds n.3 and n.4 (see photo at page 17).


Sample W2:

An overall view of the object after 1000 hours is shown in the photo at page 18.

No tracking, significant erosion or puncture was observed.

Shallow erosions on the cores between sheds n.2-3, sheds n.4-5 and sheds n.6-7 (see photo at page 19).

Shallow and diffuse erosions were visible on all circumference of core between sheds n.8 and n.9 (see photo at page 20).



[Handwritten signature]

[Handwritten signature]
264

Variation of the reference voltage

| Type | before test | after test | variation % |
|------|-------------|------------|----------------|
| | kV | kV | |
| W1 | 27,26 | 27,9 | + 2,3 |
| W2 | 28,03 | 28,4 | + 1,3 |



Acceptance criteria: satisfied

Partial discharge level

| Type | before test | after test |
|------|-------------|------------|
| | pC | pC |
| W1 | <1 | <1 |
| W2 | <1 | <1 |

Acceptance criteria: satisfied

Conclusion: the acceptance criteria specified by the standard are satisfied. The test result is positive.



Measurement of the reference voltage - initial


test object: Polymer housed metal-oxide surge arresters
test circuit: /

date: May 12, 2004

| sample W1 | | | | | | |
|-----------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscill. | voltage | current | current | current | power | 3rd harmonic amplitude |
| no. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 1 | 27,26 | 4,94 | 4,82 | 1,04 | 25,18 | / |

date: May 12, 2004

| sample W2 | | | | | | |
|-----------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscill. | voltage | current | current | current | power | 3rd harmonic amplitude |
| no. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 2 | 28,03 | 3,95 | 5,04 | 1,37 | 23,80 | / |



[Handwritten signature]

Measurement of partial discharges - initial

test object: Polymer housed metal-oxide surge arresters

test circuit: /

measurement circuit: /

arrangement: ----

| atmospheric conditions | | |
|------------------------|----|--------------------|
| b | t | h |
| kPa | °C | g / m ³ |
| / | 24 | / |


date: May 13, 2004

sample W1

| test condition | applied voltage | duration of voltage application | temperature of the test object | voltage increase | | oscillogram | note |
|----------------|-----------------|---------------------------------|--------------------------------|------------------|-------|-------------|------|
| | | | | Q max | Q max | | |
| rated voltage | 27 | 10 | 24 | / | / | / | / |
| 22 x 1,05 | 23,1 | / | 24 | / | ≤ 1 | / | / |

sample W2

| test condition | applied voltage | duration of voltage application | temperature of the test object | voltage increase | | oscillogram | note |
|----------------|-----------------|---------------------------------|--------------------------------|------------------|-------|-------------|------|
| | | | | Q max | Q max | | |
| rated voltage | 27 | 10 | 24 | / | / | / | / |
| 22 x 1,05 | 23,1 | / | 24 | / | ≤ 1 | / | / |




[Handwritten signature]



Test Report

AT-A5/022740

Weather ageing test.



power frequency test circuit (plant P188)

- R : regulator type M.E.S.A.; power 66 kVA ; output voltage 220 V ; CESI no. 29991
- TA : current reducer ; ratio 150A / 5A
- TV₁: voltage reducer ; ratio 220V / 100V
- V₁ : direct reading voltmeter
- T : booster transformer PIV type TMO/230 ; power 50 kVA ; ratio 220 V / 30 kV ;
primary current 227 A ; secondary current 1,67 A ; CESI no. 38675
- TV₂: voltage reducer CGS type VSO 534 ; CESI no. 287 ; ratio 30/0,1 kV
- V₂ : voltmeter ANALOGIC Type DP100 ; CESI no. 9533

check of the test circuit

date: August 8, 2004


| low voltage | | | | high voltage k = 300 | | k _T V _{AT} / V _I |
|----------------|-----------------|----------------|-----------------|-------------------------|-----------------|--|
| V ₁ | V _{bt} | I ₁ | I _{bt} | V ₂ | V _{AT} | |
| V | V | A | A | V | kV | |
| / | / | / | / | 50,1 | 15,0 | / |
| / | / | / | / | 73,3 | 22,0 | / |
| / | / | / | / | / | / | / |

[Handwritten signature]

ВЯРНО С ОПРИГНАЛАТА



Weather ageing test. Test arrangement
Plant: pollution test room planimetry



Test room volume: 360m³

B: bushing

N: spray nozzles. Number of spray nozzles: 4


W1, W2: test objects

MOD.A8043IG
[Handwritten signature]

ВАРНО С ОРБИГНАЛНАТА

“BAK - 02” ООД
[Handwritten signature]
САМОКОВ 269

Picture of the test arrangement




[Handwritten signature]

ВЯРНО С ОРИГИНАЛА



[Handwritten signature]

Picture of the test sample W1 after the test




Handwritten signature or initials

ВЯРНО С ОРГАНИЗАТА



Handwritten mark or signature

Picture of the test sample W1 after the test



[Handwritten signature]


[Handwritten signature]

ВЯРНО С ОРИГИНАЛАТА

“BAK - 02” ООД
САМОСОВ

[Handwritten signature]
222

Picture of the test sample W2 after the test




[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРМИНАЛАТА

“BAK - 02” ООД
САМОКОВ

Picture of the test sample W2 after the test




[Handwritten signature]

[Handwritten signature]

ВРАЧНО С ОПИТИВАЊАТА



Picture of the test sample W2 after the test



[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРМИНАЛАТА

"ВАК - 02" ООД
САМОКОВ
[Handwritten signature]

Measurement of the reference voltage - Final

test object: Polymer housed metal-oxide surge arresters
test circuit: /

date: August 30, 2004

| sample W1 | | | | | | |
|-----------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscill. | voltage | current | current | current | power | 3rd harmonic amplitude |
| no. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 3 | 27,9 | 4,88 | 5,04 | / | / | / |

date: August 30, 2004

| sample W2 | | | | | | |
|-----------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscill. | voltage | current | current | current | power | 3rd harmonic amplitude |
| no. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 4 | 28,4 | 4,32 | 5,04 | / | / | / |

ВЯРНО С ОРИГИНАЛА



Measurement of partial discharges - Final

test object: Polymer housed metal-oxide surge arresters

test circuit: /

measurement circuit: /

arrangement: ---

| atmospheric conditions | | | |
|------------------------|----|--------------------|---|
| b | t | h | |
| kPa | °C | g / m ³ | |
| / | 25 | / | / |

date: August 30, 2004

Sample W1



| test condition | applied voltage | duration of voltage application | temperature of the test object | voltage increase Q max | voltage decrease Q max | oscillogram | note |
|----------------|-------------------------|---------------------------------|--------------------------------|------------------------|------------------------|-------------|------|
| rated voltage | kV _{rms} 27 | sec 10 | °C 25 | pC / | pC / | no. / | / |
| 22 x 1,05 | 23,1 | / | 25 | / | ≤ 1 | 7 | / |

Sample W2

| test condition | applied voltage | duration of voltage application | temperature of the test object | voltage increase Q max | voltage decrease Q max | oscillogram | note |
|----------------|-------------------------|---------------------------------|--------------------------------|------------------------|------------------------|-------------|------|
| rated voltage | kV _{rms} 27 | sec 10 | °C 25 | pC / | pC / | no. / | / |
| 22 x 1,05 | 23,1 | / | 25 | / | ≤ 1 | 8 | / |



background noise ≤ 1 pC, see oscillogram n.5
direct calibration: 50 pC - see oscillogram n.6

ВАРНО С ОРГАНИЗАТА



211

oscillogram no.01





CESI TEST A4510342

ВЕРНО С ОПИТИМАННЯ



218

oscillogram no.02




CESI TEST A4510342

ВЯРНО С ОПРИТЪЛНАТА



oscillogram no.03




CESI TEST A4510342

ВЯРЧЮ С ОРИГИНАЛА




[Handwritten signature]

oscillogram no.04



CESI TEST A4510342


ВЯРНО С ОПТИМАЛА



A handwritten signature in the bottom left corner.

A handwritten signature in the middle right area.

oscillogram no.05



CESI TEST A4510342


ВЯРНО С ОПРИТИНАЛА



282



oscillogram no.06



CESI TEST A4510342


ВЯРНО С ОПРИТИНАТА



283

[Handwritten signature]

oscillogram no.07




CESI TEST A4510342

ВЯРНО С ОРИГИНАЛА



284

oscillogram no.08



CESI TEST A4510342

ВЯРНО С ОПИТНАТА



СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ВЕНТИЛЕН ОТВОД ТИП AZC
150 И ВЕНТИЛЕН ОТВОД ТИП AZC 270

1. Изпитание на изолационната устойчивост на корпуса на вентилния отвод
2. Изпитание на остатъчно напрежение
3. Изпитание за устойчивост на дълготраен токов импулс
4. Изпитание при работен режим с високо-токов импулс:
 - Изпитание с ускорено стареене
 - Изпитание при режим с високо-токов импулс и комутационно пренапрежение
5. Изпитание на късо съединение
6. Изпитание с вътрешно частично разреждане
7. Изпитание на огъващ момент
8. Изпитание с проникване на влага
9. Изпитание с атмосферно стареене

Съставил:

на основание чл. 2 от ЗЗЛД



| dervasil | | Manufacturer: .DERVASIL..... Surge Arrester Type:.. AZBD..... | | | | | | | | | |
|----------------------------------|-----------------|---|---------------------------|--------------------|------------|-------------|--|--|---|--|--|
| Clauses of IEC 60099-4 (2006-07) | Laboratory | Laboratory accreditation | Validity of accreditation | Test Report Number | Test dates | Report date | Requested Sample to be tested according IEC 60099-4 | Tested Samples | Comments | | |
| 8.2.6 | EGU (Czech Rep) | CAI N°110/2006 | 30.4.2011 | 9422/08 | 13.11.2008 | 20.11.2008 | on Longuest housing i.e AZBD 42 | AZBD 42 Ur = 42 kV Uc = 35 kV | | | |
| 8.2.8 | EGU (Czech Rep) | CAI N°110/2006 | 30.4.2011 | 9422/08 | 13.11.2008 | 20.11.2008 | on Longuest housing i.e AZBD 42 | AZBD 42 Ur = 42 kV Uc = 35 kV | | | |
| 8.3 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A8007148 | 1.4.2008 | 23.9.2008 | As authorized by IEC test has been performed on Metal Oxide Resistor Ur = 6 kV | Metal oxide resistor for arrester type AZBD Ur= 6 IV | | | |
| 10.8.4 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A8018267 | 1.4.2008 | 3.9.2008 | As authorized by IEC test has been performed on Surge Arrester section Ur = 9 kV | AZBD 090 Ur = 9 kV Uc = 8,4 kV | Energy max of choc = 15,98 kJ which corresponds to 1,9 kJ/kv Uc | | |

Handwritten signature

Large handwritten signature



| | | | | | | | | | | |
|--|---------|-----------------|--------------------|-----------|----------|------------|------------|--|--------------------------------------|---|
| HIGH CURRENT IMPULSE OPERATING DUTY TEST | 10.8.5 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A8018272 | 1.4.2008 | 3.9.2008 | As authorized by IEC test has been performed on Surge Arrester section with disconnector and support Ur = 9 kV | AZBD 090 Ur = 9 kV Uc = 8,4 kV | Energy max of choc = 33,1 kJ which corresponds to 3,94 kJ/kv Uc |
| DISCONNECTOR TEST | 8.6.3.1 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A5/8453 | 8.3.2005 | 14.3.2005 | | Disconnector | |
| INTERNAL PARTIAL DISCHARGE TEST | 10.8.8 | EGU (Czech Rep) | CAI N°110/2006 | 30.4.2011 | 9422/08 | 13.10.2008 | 20.11.2008 | on Longuest housing i.e AZBD 42 | AZBD 42 Ur = 42 kV Uc = 35 kV | |
| TEST OF BENDING MOMENT | 10,8,9 | Dervasil Lab | | | N°224 | 28/10/2008 | 28.10.2008 | on Longuest housing i.e AZBD 42 | AZBD 42 Ur = 42 kV Uc = 35 kV | Cantilever load 350 Nm - Torque load 70 Nm |
| MOISTURE INGRESS TEST | 10,8,13 | VNL (Hungaria) | NAT-1-1251/2007 | 8.7.2011 | | | | | | |

СЕРТИФИКАТ



8

0

| | | | | | | | | | | |
|---------------------|-----------------|-----------------|-----------------------|----------|-----------|-----------|-----------|---|--|---|
| WEATHER AGEING TEST | 10.8.14.2. 1 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A5/022740 | 12.5.2005 | 24.8.2004 | Longest with minimum specific creepage distance | Surge Arrester AZB27 Ur=27 kV Uc = 22 kV | AZB and AZBD have same profile housing, same leakage distance and injected silicone rubber housing . This test is also valid for AZBD arresters |
|---------------------|-----------------|-----------------|-----------------------|----------|-----------|-----------|-----------|---|--|---|

ВЪРНО С ОПИТАНА

[Handwritten signature]

St Joseph on
11.08.2013


на основание чл. 2 от 33ЛД

dervasil
 SAS au capital de 907 190 €
 Route de Poponet - 42800 SAINT-JOSEPH
 Tél. 04 77 75 29 98 - Fax 04 77 83 22 80
 RC St-Etienne 423 136 877 - Code NAF 512 A

[Handwritten signature]



| dervasil | | Производител: DERVASIL..... Тип вентилен отвод: AZBD..... | | | | | | | | | |
|---------------------------------|-----------------|---|-----------------------|--------------------|-------------------|-------------------|--|---|-----------|--|--|
| Клаузи от IEC 60099-4 (2006-07) | Лаборатория | Акредитация на лабораторията | Дата на акредитацията | Номер на протокола | Дата на изпитване | Дата на протокола | Изискваните мостри да бъдат изпитани съгласно IEC 600099-4 | Изпитани мостри | Коментари | | |
| 8.2.6 | EGU (Czech Rep) | CAI N°110/2006 | 30.4.2011 | 9422/08 | 13.11.2008 | 20.11.2008 | върху най-дългия корпус - AZBD 42 | AZBD 42 U _g = 42 kV U _c = 35 kV | | | |
| 8.2.8 | EGU (Czech Rep) | CAI N°110/2006 | 30.4.2011 | 9422/08 | 13.11.2008 | 20.11.2008 | върху най-дългия корпус - AZBD 42 | AZBD 42 U _g = 42 kV U _c = 35 kV | | | |
| 8.3 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A8007148 | 1.4.2008 | 23.9.2008 | Като оторизиран от IEC извършено изпитване на метало-окисен ресистор U _g = 6 kV | метало-окисен ресистор за вентилен отвод тип AZBD U _g = 6 kV | | | |




С. Кочарски

| | | | | | | | | | | |
|---|---------|-----------------|--------------------|-----------|----------|------------|------------|---|--------------------------------------|---|
| ИЗПИТАНИЕ ЗА УСТОЙЧИВОСТ НА ДЪЛГОТРАЕН ТОКОВ ИМПУЛС | 10.8.4 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A8018267 | 1.4.2008 | 3.9.2008 | Като оторизиран от IEC извършено изпитване на вентилен отвод раздел Ur = 9 kV | AZBD 090 Ur = 9 kV Uc = 8,4 kV | Максимална енергия = 15,98 kJ което съответства на 1,9 kJ/kV Uc |
| ИЗПИТАНИЕ ПРИ РАБОТЕН РЕЖИМ С ВИСОКО-ТОКОВ ИМПУЛС | 10.8.5 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A8018272 | 1.4.2008 | 3.9.2008 | Като оторизиран от IEC извършено изпитване на вентилен отвод раздел с разединител Ur = 9 kV | AZBD 090 Ur = 9 kV Uc = 8,4 kV | Максимална енергия = 33,1 kJ което съответства на 3,94 kJ/kV Uc |
| ИЗПИТАНИЕ С РАЗЕДИНИТЕЛ | 8.6.3.1 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A5/8453 | 8.3.2005 | 14.3.2005 | разедините | л | |
| ИЗПИТАНИЕ С ВЪТРЕШНО ЧАСТИЧНО РАЗРЕЖДАНЕ | 10.8.8 | EGU (Czech Rep) | CAI N°110/2006 | 30.4.2011 | 9422/08 | 13.10.2008 | 20.11.2008 | върху най-дългия корпус - AZBD 42 | AZBD 42 Ur = 42 kV Uc = 35 kV | |
| ИЗПИТАНИЕ НА ОГЪВАЩ МОМЕНТ | 10.8.9 | Dervasil Lab | | | N°224 | 28/10/2008 | 28.10.2008 | върху най-дългия корпус - AZBD 42 | AZBD 42 Ur = 42 kV Uc = 35 kV | товар на огъване 350 Nm - товар на усукване 70 Nm |
| ИЗПИТАНИЕ С ПРОНИКВАНЕ НА ВЛАГА | 10.8.13 | VNL (Hungary) | NAT-1-1251/2007 | 8.7.2011 | | | | | | |




| | | | | | | | | | | |
|------------------------------------|-----------------|-----------------|-----------------------|----------|-----------|-----------|-----------|--|---|---|
| ИЗПИТАНИЕ С АТМОСФЕРНО СТАРЕЕНЕ | 10.8.14.2. 1 | CESI (Italy) | SINCERT 018B rev04 | 1.6.2010 | A5/022740 | 12.5.2005 | 24.8.2004 | Най-дълъг с минимално разстояние на специфичен път на утечка | Вентилен отвод AZB27 U _f =27 kV U _c = 22 kV | Вентилен отвод тип AZB и AZBD имат същия корпус, същото изолационн о разстояние по повърхността а и обвивка от силиконов каучук. Това изпитание също е валидно за отводи AZBD. |
|------------------------------------|-----------------|-----------------|-----------------------|----------|-----------|-----------|-----------|--|---|---|



St Joseph on
May 28th, 2013


на основание чл. 2 от ЗЗЛД



SAS au capital de 907 190 €
Route de Poppenot - 42800 SAINT-JOSEPH
T 61 04 77 75 29 98 - Fax 04 77 83 22 60
RC St-Etienne 423 136 977 - Code NAF 812A

REÇU
Le 01 DEC. 2008
Répondu le

EGU - HV Laboratory a.s.
High voltage testing laboratory
Podnikatelská 267, 190 11 Praha 9, Běchovice



CUSTOMER:
DERVASIL
Route de Popenot
42800 Saint Joseph
France

ORDER No.:
CG080905 mod 1

DATE OF TEST:
The 13th of October 2008
The 13th of November 2008

TEST No.:
9422/08

TEST REPORT
No.: 9422/08

TEST OBJECT: SURGE ARRESTERS
MANUFACTURER: DERVASIL, FRANCE
TEST STANDARDS: IEC 60060-1:1989, IEC 60099-4:2006-07 Ed. 2.1



TEST PERFORMED BY:
Marek Brosch
на основании чл. 2 от 33ЛД

DIRECTOR OF EGU - HV Laboratory a.s.:
Václav Skle
на основании чл. 2 от 33ЛД

CO

PAGES: 11

Test report is confidential and must not be passed over or transferred to any third party without written approval of the customer. Test results relate only to the tests given in presented report and do not substitute any other documents. The report shall not be reproduced except in full without written approval of the testing laboratory.

In Prague 9 - Běchovice: 2008-11-20

ВЯРНО С ОРИГИНАЛА



TEST OBJECT

SURGE ARRESTERS AZB-D 42

Drawing No.: No. 99B000210B (see Figure 1)

Characteristics of arresters are :

$U_r = 42 \text{ kV}$

$U_c = 35 \text{ kV}$

$I_n = 10 \text{ kA class 1}$

The creepage distance: 1045 mm

The arcing distance: 365 mm

Insulation withstand characteristics are :

190 kV dry lightning impulse withstand voltage

70 kV wet power-frequency voltage

DATE OF DELIVERY

2008-10-10 and 2008-10-22



SCHEDULE OF TESTS

1. Internal partial discharge test
2. Dry lightning impulse withstand voltage test
3. Wet power-frequency voltage test

surge arrester #1 sn 08/0006

surge arrester #2 sn D42 0030

surge arrester #2 sn D42 0030



TEST PROCEDURE


1. Internal partial discharge test

The test was carried out according to IEC 60099-4, clause 10.8.8.

The test voltage was increased to the rated voltage of the arrester, held 2 s to 10 s, and then decreased to 1,05 times the continuous operating voltage of the arrester.

The test arrangement is given on Figure 3.

Testing and measuring equipment:



- IR – induced regulator ČKD Praha, 6/0-3 kV, 50 kVA
- T – test transformer Fischer-Köln, 3-6/250 kV, 250 kVA
- IVT – instrument voltage transformer Škoda, $380/\sqrt{3}$ kV / $100/\sqrt{3}$ V, serial No. 917355
- PD measuring system Tettex, type 2801, serial No. 123989
- universal voltmeter Siemens, type MU 15, serial No. 879953
- digital stop-watch Speedo, type Speedo
- measuring system for atmospheric condition COMET, type D4130, serial No. 04900257

2. Dry lightning impulse withstand voltage test

Test was carried out in compliance with IEC 60099-4, clause 8.2.6 and in compliance with IEC 60060-1, clause 20.1.2.

Fifteen (15) full lightning impulses of positive polarity was applied to the arrester followed by fifteen (15) full lightning impulses of negative polarity.

The impulse withstand voltage of 190 kV was applied to the arrester.


The wave shape of the test lightning impulse is given in Figure 2.

The test arrangement is given on Figure 4.

Handwritten signature



Testing and measuring equipment:



impulse generator TuR Dresden 750 kV, 30 kJ
 R_{d1}/R_{d2} - resistive divider Haefely, type R 800, serial No. 554333
 digital voltmeter Haefely, type 64 M, serial No. 604160
 measuring system Haefely Trench, type HiAS 743, serial No. 080649-01
 measuring system for atmospheric condition COMET, type D4130, serial No. 04900257
 yard stick, type 30-847, serial No. 101


3. Wet power frequency voltage test

Test was carried out in compliance with IEC 60099-4, clause 8.2.8 and in compliance with IEC 60060-1, clause 17.


The one minute wet power-frequency withstand voltage (U_{WAC}) was applied according to IEC 60060-1, clause 17.1.

The test arrangement is given on Figure 5.

Testing and measuring equipment:



G - synchronous generator BEZ Bratislava 6 kV, 1300 kVA, 50 Hz
 T - test transformer Fischer-Köln, 3-6/250 kV, 250 kVA
 IVT - instrument voltage transformer Škoda, $380/\sqrt{3}$ kV / $100/\sqrt{3}$ V, serial No. 917355
 universal voltmeter Siemens, type MU 15, serial No. 879953
 measuring system for atmospheric condition COMET, type D4130, serial No. 04900257
 conductivity meter ino Lab Con Level 1, serial No. 99440007
 yard stick, type 30-847, serial No. 101
 digital stop-watch Speedo, type Speedo



4/11
 ВЕРНО С ОРИГИНАЛОМ




UNCERTAINTY OF MEASUREMENT

| QUANTITY | UNCERTAINTY (k=2) | |
|--|----------------------------------|-------|
| | <i>Lightning impulse voltage</i> | U_m |
| T_1 | | 2,6 % |
| T_2 | | 2,2 % |
| <i>Power-frequency voltage</i> | 1,7 % | |
| <i>Partial discharges</i> | 8,0 % | |
| <i>Air pressure</i> | 0,04 kPa | |
| <i>Temperature</i> | 0,7 °C | |
| <i>Relative humidity</i> | 4 % | |
| <i>Time</i> | 0,2 % | |
| <i>Length (1 – 5 000 mm)</i> | 620 μ m | |
| <i>Conductivity (0,1 μS/cm – 500 mS/cm)</i> | 1,3 % | |


The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a Normal (Gaussian) distribution corresponds to a coverage probability of approximately 95 %.

LIST OF SYMBOLS

- b** air pressure (kPa),
- t** air temperature (°C),
- RH** relative air humidity (%),
- U** test voltage (kV), corresponding to actual atmosphere,
- Q** internal partial discharge (pC),
- U_{WLI}** specified dry lightning impulse withstand voltage (kV),
- ri** average value of rainfall intensity (mm/min):
 - v.c. - vertical component,
 - h.c. - horizontal component,
- ρ** water resistivity (Ω m),
- U_{WAC}** specified wet power-frequency withstand voltage (kV), corresponding to standard reference atmosphere (test duration - 60 s).




ВАРНО С ОРИГИНАЛА



TEST RESULTS

1. Internal partial discharge test

Table 1

| sample | #1 | |
|--------|---------|------|
| | b (kPa) | 99,3 |
| t (°C) | 16,7 | |
| RH (%) | 56,7 | |
| U (kV) | Q (pC) | |
| | ↓ | ↑ |
| 0 | 0,5 | 0,5 |
| 35 | 2 | 2 |
| 36,8 | 3 | 3 |
| 42 | 6 | 6 |

Measured values of partial discharges on arrester are less then 10 pC specified by IEC 60099-4 clause 10.8.8.

Surge arrester #1, drawing No. 99B000210B passed the internal partial discharge test according to IEC 60099-4, clause 10.8.8.



2. Dry lightning impulse withstand voltage test

Table 2

| sample | #2 | |
|-----------------------|----------|------|
| | Polarity | + |
| b (kPa) | 99,2 | 99,2 |
| t (°C) | 16,3 | 16,3 |
| RH (%) | 44,6 | 44,6 |
| U _{WLI} (kV) | 190 | 190 |
| No. of flashovers | 0 | 0 |

No internal and external disruptive discharges were occurred during the test with the specified dry lightning impulse withstand voltage 190 kV (corrected value 179 kV).

Surge arrester #2, drawing No. 99B000210B passed the dry lightning impulse withstand voltage test according to IEC 60099-4, clause 8.2.6.




3. Wet power frequency voltage test




Table 3

| sample | | #2 |
|-----------------------|------|------|
| b (kPa) | | 99,2 |
| t (°C) | | 15,9 |
| RH (%) | | 54,6 |
| ri | v.c. | 1,0 |
| (mm/min) | h.c. | 1,0 |
| ρ (Ωm) | | 103 |
| U _{WAC} (kV) | | 70 |

No flashover and no puncture was occurred during the test with the specified wet power frequency withstand voltage 70 kV.

Surge arrester #2, drawing No. 99B000210B passed the wet power frequency voltage tests according to IEC 60099-4, clause 8.2.8.










Figure 1
Surge arrester, drawing No. 99B000210B



ВЯРНО С ОРИГИНАЛА



LI / SURGE ARRESTER


13/11/2008 08:32:55



LI full
 Upk : 179.340 kV
 T1 : 1.153 us
 T2 : 48.737 us

LI / SURGE ARRESTER

13/11/2008 08:41:42





LI full
 Upk : -179.864 kV
 T1 : 1.188 us
 T2 : 48.730 us

Figure 2
Wave shape of lightning impulse voltage

Handwritten signature

9/11






Figure 3
Surge arrester, drawing No. 99B000210B,
test arrangement under internal partial discharge test





Figure 4
Surge arrester, drawing No. 99B000210B,
test arrangement under the dry lightning impulse voltage test



ВЪРХО С ОРИГИНАЛА








Figure 5
Surge arrester, drawing No. 99B000210B,
test arrangement under the wet power frequency voltage test

[Handwritten signature]

[Handwritten signature]


ВЯРНО С ОРМИНАЛАТА





Handwritten signature

ВЯРНО С ОРМИНАЛА



Client **DERVASIL**

Address of the Client **Route de Popenot F-42800 Saint Joseph (FRANCE)**

Tested samples/items **Metal-oxide resistor block for polymer-housed metal-oxide surge arrester type AZBD**

Tests carried out **Residual voltage test**

Standards/Specifications **IEC 60099-4 – Edition 2.1 (2006-07)**

Tests date **from April 01, 2008 to April 02, 2008**

The results reported in this document relate only to the tested samples/items.
 Partial reproduction of this document is permitted only with the written permission from CESI.

PUBBLICATO A8007148 (PAD - 1098393)

No. of pages **15** No. of pages annexed **19**

Issue date **September 23, 2008**

Prepared **LAP - Gregori Marco**
AS00141.029 AUT

Verified **LAP - Sironi Alberto, LAP - Arneodo Giorgio**
AS00141.029 VCE AS00141.031 VCE

Approved **LAP - Nicolini Roberto**
AS00141.029 AUT

CESI S.p.A.
 Energy Division

на основании чл. 2 от 33ЛД

D:10001G rev 04

CESI
 Centro Elettrotecnico
 Sperimentale Italiano
 Giacinto Motta spa

Via R. Rubattino 54
 20134 Milano - Italia
 Telefono +39 022125.1
 Fax +39 0221255440
 http://www.cesi.it

Capitale sociale 6 550 000 Euro
 interamente versato
 Codice fiscale e numero
 iscrizione CCIAA 00793580150

Registro Imprese di Milano
 Sezione Ordinaria
 N. R.E.A. 429222
 P.I. IT00793580150

ВАРНО С ОПИТНАТА

“BAK - 02” OGD
 CAMKOB

Tests witnessed by:

Identification of the object: Not requested

The data necessary to permit repetition of the tests are contained in the document marked: -----

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3 \%$ time parameters: $\pm 10 \%$
- dielectric tests with impulse current : peak value: $\pm 3 \%$ time parameters: $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3 \%$ time parameters: $\pm 3,5 \%$
- dielectric tests with direct voltage : voltage: $\pm 3 \%$ time parameters: $\pm 3,5 \%$
- partial discharge measurement : up to 10 pC: $\pm 1 \text{ pC}$ above 10 pC: $\pm 10 \%$
- atmospheric conditions : temperature: $\pm 2 \text{ }^\circ\text{C}$ pressure: $\pm 0,133 \text{ kPa}$ humidity: $\pm 10 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory Information

Receipt date of the sample March 05, 2008

Test location CESI – Via Rubattino 54 – Milan

CESI testing team Mr L. Podavitte – Mr I. Guacci

Test laboratory P177

Activity code AE08LAP016

AI001IG



| content | page | test date |
|--|--------------------|----------------|
| Test object characteristics | 4 | |
| Photograph of the test sample | 5 | |
| Reference standard | 6 | |
| Test carried out | 6 | |
| Test object identification | 6 | |
| Test procedure | 7 | |
| Lightning impulse residual voltage test | from page 8 to 9 | April 01, 2008 |
| Switching impulse residual voltage test | 10 | April 01, 2008 |
| Steep current impulse residual voltage test (measurement of inductive error) | 11 | April 02, 2008 |
| Steep current impulse residual voltage test | 12 | April 02, 2008 |
| Technical data | from page 13 to 15 | |

Pages annexed:

oscillograms n. 19 pages

БРИФИНГ ОПИТУВАЊА



Test Report

CESI

Approved

Test object characteristics

type: Metal-oxide resistor block for polymer-housed metal-oxide surge arrester type AZBD

electrical characteristics (assigned by the client)

| | |
|--|----------------------------------|
| Manufacturer's name | DERVASIL – SAINT JOSEPH (FRANCE) |
| Nominal discharge current – I_n [kA] | 10 |
| Rated voltage – U_r [kV] | 6,0 |
| Reference current - I_{ref} [mA] | 5,0 |
| Line discharge class | I |
| Standard rated frequency - [Hz] | 50/60 |
| year of manufacture | 2008 |

ВЪРНО С ОПРИГАНАТА

Picture of the test object




Photo no. 1

Metal-oxide resistor block for polymer-housed metal-oxide surge arrester type AZBD

[Handwritten signature]

[Handwritten signature]

A12671G

ВЯРНО С ОРИГИНАЛАТА



309




Reference Standard

IEC 60099-4 – Edition 2.1 (2006-07) - Clause 8.3
"Metal-oxide surge arresters without gaps for a.c. system"

| Test carried out | Number of sample tested |
|---|-------------------------|
| Lightning impulse residual voltage test | 3 |
| Switching impulse residual voltage test | |
| Steep current impulse residual voltage test | |

Test object identification

| Test object name | Identification of test sample (given by CESI) |
|--|---|
| Metal-oxide resistor block for polymer-housed metal-oxide surge arrester type AZBD | RV1-RV2-RV3 |



Test procedure

The following tests have been carried out on the same three samples

a) Lightning impulse residual voltage test

- wave-shape 8/20 μ s
- peak current $I_n = 10$ kA, 0,5 $I_n = 5$ kA & 2 $I_n = 20$ kA

b) Switching impulse residual voltage test

- wave-shape front time in the range 30 μ s to 100 μ s, tail time twice the virtual time
- peak current 125 A & 500 A (according to table 4 of the reference standard)

c) Steep current impulse residual voltage test

- wave-shape front time equal to 1 μ s, tail time less than 20 μ s
- peak current $I_n = 10$ kA
- note Correction of the inductive error


The inductive error was determined replacing the surge arrester section with a metal part having the same dimensions and measuring the voltage across the metal part in this condition..

Being the inductive error (peak value) in the range 2% to 20% of the measured residual voltage (peak value) the correction was applied by subtracting the impulse voltage shape measured on the surge arrester section and the impulse voltage shape on the metal part.

Test result

See pages 8 & 9

ВЯРНО С ОПРИГНАЛАТА



Residual voltage tests

Lightning impulse residual voltage test.

Test circuit: A0120

Date: April 01, 2008

| Sample | Requested current | Charging voltage | Oscillogram | Current waveshape | Discharge current | Residual voltage | Lightning impulse protection level |
|--------|-------------------|------------------|-------------|-------------------|-------------------|------------------|------------------------------------|
| No. | | kV | No. | μ s | kA | kV | kV |
| RV1 | $0,5 \times I_n$ | 21,8 | 07 | 8,7/18,9 | 5,00 | 15,11 | 16,18 |
| | I_n | 30,0 | 01 | 8,7/18,9 | 10,11 | 16,14 | |
| | $2,0 \times I_n$ | 45,4 | 04 | 8,7/18,9 | 20,15 | 17,68 | |
| RV2 | $0,5 \times I_n$ | 21,8 | 08 | 8,7/18,9 | 5,02 | 15,09 | |
| | I_n | 29,8 | 02 | 8,7/18,9 | 10,04 | 16,18 | |
| | $2,0 \times I_n$ | 45,4 | 05 | 8,7/18,9 | 20,07 | 17,69 | |
| RV3 | $0,5 \times I_n$ | 21,8 | 09 | 8,7/18,9 | 5,02 | 15,08 | |
| | I_n | 29,8 | 03 | 8,7/18,9 | 10,05 | 16,10 | |
| | $2,0 \times I_n$ | 45,4 | 06 | 8,7/18,9 | 20,00 | 17,59 | |

| | Requested current | Oscilloscope settings | | |
|---------|-------------------|-----------------------|-----------|-------------|
| | | sampling division | input | Attenuation |
| | | μ s | V_{div} | |
| Current | $0,5 \times I_n$ | 5 | 0,5 | 20:10 |
| | I_n | | 1,0 | 50:10 |
| | $2 \times I_n$ | | 1,0 | 50:10 |
| Voltage | $0,5 \times I_n$ | 5 | 1,0 | 20:5 |
| | I_n | | 1,0 | 20:5 |
| | $2 \times I_n$ | | 1,0 | 20:5 |

Notes:

[Handwritten signature]


[Handwritten signature]

ВЯРНО С ОПРИГНАЛАТА




A1264IG

Lightning impulse protection level



ВЪРНО С ОПРИЛНАТА



Test Report

CESI

Approved

A8007148

Page 9

Residual voltage tests

Switching impulse residual voltage test.

Test circuit: A0122

Date: April 01, 2008

| Sample | Requested current | Charging Voltage | Oscillogram | Current waveshape | Discharge current | Residual voltage | Switching impulse protection level |
|--------|-------------------|------------------|-------------|-------------------|-------------------|------------------|------------------------------------|
| No. | A | kV | No. | μ s | A | kV | kV |
| RV1 | 125 | 12,4 | 10 | 31/72 | 128 | 11,96 | 12,74 |
| | 500 | 18,3 | 13 | 33/71 | 510 | 12,74 | |
| RV2 | 125 | 12,3 | 11 | 3172 | 130 | 11,97 | |
| | 500 | 18,3 | 14 | 33/71 | 511 | 12,67 | |
| RV3 | 125 | 12,3 | 12 | 3172 | 128 | 12,05 | |
| | 500 | 18,1 | 15 | 33/71 | 497 | 12,52 | |

| Oscilloscope settings | | | |
|-----------------------|-------------------|------------------|-------------|
| | sampling division | Input | attenuation |
| | μ s | V _{div} | |
| 125A Current | 20 | 0,5 | 10:10 |
| Voltage | | 1,0 | 20:5 |
| 250A current | | 0,5 | 50:10 |
| Voltage | | 0,5 | 20:5 |

Notes:

ВАЖНО С ОПИТИМНАТА



Residual voltage tests

Steep current impulse residual voltage test.

Measurement of the inductive error

Test circuit: A0121B


Date: April 02, 2008

| Sample | Charging voltage | Oscillogram | Current waveshape | Discharge current | Peak voltage | Inductive error |
|------------------|------------------|-------------|-------------------|-------------------|--------------|-----------------|
| No. | kV | No. | μ s | kA | V | % |
| aluminium blocks | 34,5 | 16 | 0,98/2,2 | 10,00 | 550 | 2+20 (1) |

| | Oscilloscope settings | | |
|---------|-----------------------|------------------|-------------|
| | sampling division | input | attenuation |
| | μ s | V _{div} | |
| Current | 1 | 2 | x 10 |
| Voltage | | --- | --- |

Notes: (1) correction is required





Residual voltage tests

Steep current impulse residual voltage test.

Test circuit: A0121B

Date: April 02, 2008

| Sample No. | Charging voltage kV | Oscillogram No. | Current waveshape μs | Discharge current kA | Corrected residual voltage kV | Steep current impulse protection level kV |
|------------|---------------------|-----------------|---------------------------|----------------------|-------------------------------|---|
| RV1 | 34,5 | 17 | 0,98/2,2 | 10,10 | 17,21 | 17,21 |
| RV2 | 34,5 | 18 | | 10,01 | 17,15 | |
| RV3 | 34,5 | 19 | | 10,06 | 17,21 | |


| | Oscilloscope settings | | |
|---------|---------------------------|-----------------|-------------|
| | sampling division μs | input V_{div} | attenuation |
| Current | 1 | 2 | x10 |
| Voltage | | 5,0 | --- |

Notes:

Handwritten signature

Handwritten signature

Circuit A0120



Impulse generator

- No. of stages 1
- Cg 4,98 μ F
- Lc 10 μ H
- S - Spark-gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system


- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No.11517/518;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

ВРЪНО С ОПИТИНАТА

“BAK - 02” ООД
 САМОУЧБ

313

Circuit A0122



Impulse generator

- No. of stages 1
- Cg 2,49 μ F
- Lc 120 μ H
- S - Spark-gap

Voltage measuring system.


- D - Voltage divider SAGI; CESI No.13027
- Electro optical system CESI No 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6037; R= 20 m Ω ; peak current= 250 kA
- Electro optical system CESI No11517/518
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)


A014IG

ВЯРНО С ОПРИТИНАЛА



3/8

Circuit A0121B



Impulse generator

No. of stages 1
 Cg 0,500 μ F

S - Spark-gap

Voltage measuring system.

D - Voltage divider SAGI; CESI No.11120
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)





Current measuring system

Sh - Current Pearson CESI No.6042; 0,01 V x A
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

A0121IG

ВЯРНО С ОРИГИНАЛА





[Handwritten signature]

[Handwritten initials]

[Handwritten mark]

ВЯРНО С ОРЪГИНАЛАТ



Client **DERVASIL**

Address of the Client **Route de Popenot F- 42800 Saint Joseph (FRANCE)**


Tested samples/items **Polymer-housed metal-oxide surge arrester type AZBD090**

Tests carried out **Long-duration current impulse withstand test**

Standards/Specifications **IEC 60099-4 – Edition 2.1 (2006-07)**

Tests date **from April 01, 2008 to April 02, 2008**

The results reported in this document relate only to the tested samples/items.
 Partial reproduction of this document is permitted only with the written permission from CESI.



PUBBLICATO A8018267 (PAD - 1093286)

No. of pages **21** No. of pages annexed **28**

Issue date **September 03, 2008**



Prepared **LAP - Gregori Marco**

Verified **LAP - Arneodo Giorgio, LAP - Sironi Alberto**

Approved **LAP - Nicolini Roberto**

CESI S.p.A.
 Energy Division
 Technical Area Components

на основание чл. 2 от ЗЗЛД

D10001G rev 04

CESI
 Centro Elettrotecnico
 Sperimentale Italiano
 Giacinto Motta spa

Via R. Rubattino 54
 20134 Milano - Italia
 Telefono +39 022125.1
 Fax +39 0221255440
 http://www.cesi.it

Capitale sociale 8 550 000 Euro
 interamente versato
 Codice fiscale e numero
 iscrizione CCIAA 00793580150

Registro Imprese di Milano
 Sezione Ordinaria
 N. R.E.A. 429222
 P.I. IT00793580150

ВЪРЖО С ОРИГИНАЛА



Tests witnessed by:

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawings identified by CESI and numbered A8024793 no. 1 to 3 are annexed to this document..

The data necessary to permit repetition of the tests are contained in the document marked: ---

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3 \%$ time parameters: $\pm 10 \%$
- dielectric tests with impulse current : peak value: $\pm 3 \%$ time parameters: $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3 \%$ time parameters: $\pm 3,5 \%$
- dielectric tests with direct voltage : voltage: $\pm 3 \%$ time parameters: $\pm 3,5 \%$
- partial discharge measurement : up to 10 pC: $\pm 1 \text{ pC}$ above 10 pC: $\pm 10 \%$
- atmospheric conditions : temperature: $\pm 2 \text{ }^\circ\text{C}$ pressure: $\pm 0,133 \text{ kPa}$ humidity: $\pm 10 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory information

Receipt date of the sample June 19, 2008

Test location CESI – Via Rubattino 54 – Milan

CESI testing team Mr L. Podavitte – Mr I. Guacci

Test laboratory P177

Activity code AE08LAP012

ВАРЬНО С ОПРИТЕЛНАТА

"BAK - 02" OGD
САМОКОВ

| content | page a | test date |
|--|--------------------|---------------|
| Test object characteristics | 4 | |
| Picture of the test sample | 5 | |
| Reference standard | 6 | |
| Test carried out | 6 | |
| Test object identification | 6 | |
| Test procedure | 7 | |
| Visual inspection and summary of the test result | 8 | |
| Power frequency voltage characteristics | 9 | June 23, 2008 |
| Lightning impulse residual voltage measurement before the test | 10 | June 23, 2008 |
| Switching impulse residual voltage test | 11 | June 24, 2008 |
| Voltage correction factor and energy calculations | 12 | June 24, 2008 |
| Long duration current impulse withstand test | from page 13 to 15 | June 24, 2008 |
| Lightning impulse residual voltage measurement after the test | 16 | June 25, 2008 |
| Additional long duration current impulse | 17 | June 25, 2008 |
| Technical data of the test circuit | from page 18 to 21 | |

Pages annexed:

oscillograms n. 24 pages

- DERVASIL drawing no. 99B000210B; CESI no. A8024793/1 - n.1 page
- DERVASIL drawing no. 99B000224A; CESI no. A8024793/3 - n.1 page
- DERVASIL technical document no. 99B000226A; CESI no. A8024793/2- n.1 page
- DERVASIL technical document no. 99B000224A; CESI no. A8024794 - n.1 page



CESI


Test Report

Test object characteristics

type: Polymer-housed metal-oxide surge arrester type AZBD090

electrical characteristics (assigned by the client)

| | |
|---|----------------------------------|
| Manufacturer's name | DERVASIL – Saint Joseph (France) |
| Nominal discharge current – I_n [kA] | 10 |
| Rated voltage – U_r [kV] | 1,07 x U_{ref} |
| Continuous operating voltage - U_c [kV] | 0,89 x U_{ref} |
| Reference current - I_{ref} [mA] | 5,0 |
| Line discharge class | 1 |
| Standard rated frequency - [Hz] | 50/60 |
| year of manufacture | 2008 |



Picture of the test object




Photo no. 1


polymer housed metal oxide surge arrester

Handwritten signature

A1265IG

Handwritten signature

ВЯРНО С ОПИТАНАТЪ



325


Reference Standard

IEC 60099-4 (2006-07) -- Edition 2.1 - Clause 10.8.4
"Metal-oxide surge arresters without gaps for a.c. system"

| Test carried out | Number of sample tested |
|--|-------------------------|
| Long-duration current impulse withstand test | 3 |

Test object identification

| Test object name | Identification of test sample (given by CESI) |
|--|---|
| Polymer-housed metal-oxide surge arrester type AZBD090 | LD1-LD2-LD3 |



ВЪРНО С ОПРИГНАЛАТА



Test procedure

The test procedure consisted of the following sequence:

- a) Measurement of the power frequency reference voltage at the reference current
- b) Measurement of the lightning impulse residual voltage at nominal discharge current
- c) Measurement of the switching impulse residual voltage at the lowest current peak prescribed by the standard in table 4 that is 125 A
- d) Calculation of the specified energy associated to each long duration current impulse according to clause 8.4.2 of the reference standard
- e) Application of eighteen long duration current impulses with the specified energy and a virtual duration of 2000 μ s in six groups of three operations each.
 - intervals between operations of the same group: 60 seconds
 - interval between different groups: as required to cool down the samples to near ambient temperature
- f) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value
- g) After cooling down to near ambient temperature cooling down to near ambient temperature application of a nineteenth impulse to check the sample integrity

Test result

The visual inspection of the sample after the test has revealed no sign of physical damage. The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%). The oscillographic record of the 19th impulse did not reveal any sign of internal discharge.

The acceptance criteria are fulfilled. The test result is positive



Summary of test results

Variation of lightning impulse residual voltage at I_n


| Sample | before test | | after test | | Variation |
|--------|-------------------|------------------|-------------------|------------------|-----------|
| | discharge current | residual voltage | discharge current | residual voltage | |
| | kA | kV | kA | kV | % |
| LD1 | 10,10 | 31,69 | 10,15 | 31,81 | + 0,38 |
| LD2 | 10,08 | 31,97 | 10,13 | 31,92 | - 0,16 |
| LD3 | 10,05 | 31,72 | 10,09 | 31,78 | + 0,19 |

Visual inspection after the test

The visual inspection of the surge arrester sections after the test has revealed no sign of physical damage



ВЯРНО С ОПРИГНИНАТА



Long-duration current impulse withstand test.

Reference voltage test.

Test circuit: A0019

Date: June 23, 2008

| Sample No. LD1 | | | | | | |
|----------------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| Oscillogram | Voltage | current | current | current | power | 3rd harmonic amplitude |
| No. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 1 | 13,45 | 5,04 | 4,32 | 1,50 | 13,47 | --- |

| Sample No. LD2 | | | | | | |
|----------------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscillogram | Voltage | current | current | current | Power | 3rd harmonic amplitude |
| No. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 2 | 13,57 | 5,02 | 4,06 | 1,49 | 13,50 | --- |

| Sample No. LD3 | | | | | | |
|----------------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscillogram | Voltage | current | current | current | Power | 3rd harmonic amplitude |
| No. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 3 | 13,49 | 5,03 | 4,42 | 1,52 | 12,73 | --- |

[Handwritten signature]

[Handwritten signature]

Long-duration current impulse withstand test.

Lightning impulse residual voltage measurement before the test


Test circuit: A0120


Date: June 23, 2008

| Sample | Requested current | Charging Voltage | Oscillogram | Current waveshape | Discharge current | Residual voltage |
|--------|-------------------|------------------|-------------|-------------------|-------------------|------------------|
| No. | | kV | No. | μ s | kA | kV |
| LD1 | I_n | 45,3 | 4 | 8,7/20,0 | 10,10 | 31,69 |
| LD2 | | 45,4 | 5 | | 10,08 | 31,97 |
| LD3 | | 45,3 | 6 | | 10,05 | 31,72 |

| | Oscilloscope settings | | |
|---------|-----------------------|-----------|-------------|
| | Sampling division | Input | attenuation |
| | μ s | V_{div} | |
| Current | 5 | 1,0 | 50:10 |
| Voltage | 5 | 1,0 | 50:5 |

Notes:





ВЪРНО С ОПИГНАНАТА

"BAK - 02" OOD
САМОКОВ



Long-duration current impulse withstand test.

Switching impulse residual voltage test.

Test circuit: A0122

Date: June 24, 2008

| Sample | Requested current | Charging voltage | Oscillogram | Current waveshape | Discharge current | Residual voltage |
|--------|-------------------|------------------|-------------|-------------------|-------------------|------------------|
| No. | A | kV | No. | μ s | A | kV |
| LD1 | 125 | 24,7 | 7 | 31/79 | 129 | 23,80 |
| LD2 | | 24,8 | 8 | | 128 | 23,88 |
| LD3 | | 24,7 | 9 | | 125 | 23,73 |

| Oscilloscope settings | | | |
|-----------------------|-------------------|------------------|-------------|
| | sampling division | input | attenuation |
| | μ s | V _{div} | |
| Current | 20 | 0,5 | 10:10 |
| Voltage | 20 | 1,0 | 20:5 |

Notes:

Long-duration current impulse withstand test.

Voltage correction factor and energy calculations

Date: June 24, 2008

| Sample | U_{ref} [1] | KU_r [2] | KU_c [3] | U_r' [4] | U_c' [5] |
|--------|------------------|---------------|---------------|---------------|---------------|
| No. | kV | | | kV | kV |
| LD1 | 13,45 | 1,07 | 0,89 | 14,392 | 11,971 |
| LD2 | 13,57 | | | 14,520 | 12,077 |
| LD3 | 13,49 | | | 14,433 | 12,006 |

- [1] U_{ref} : measured reference voltage
- [2] KU_r : maximum guaranteed factor for calculation of U_r
- [3] KU_c : maximum guaranteed factor for calculation of U_c
- [4] U_r' : corrected rated voltage [4] = [1] × [2]
- [5] U_c' : corrected continuous operating voltage [5] = [1] × [3]

| Sample | U_r' | U_L | U_{res} | T | Z | W | W' |
|--------|--------|---------|-----------|---------|----------|--------|-------|
| No. | kV | kV d.c. | kV | μs | Ω | kJ | kJ/kV |
| LD1 | 14,392 | 46,054 | 23,73 | 2000 | 70,521 | 15,024 | 1,044 |
| LD2 | 14,520 | 46,464 | | | 71,148 | 15,165 | 1,044 |
| LD3 | 14,434 | 46,189 | | | 70,727 | 15,071 | 1,044 |

- U_{res} : switching impulse residual voltage
- U_L, T, Z : see table 5 of IEC 60099-4 at clause 8.4.2
- W : = $U_{res} \times (U_L - U_{res}) \times (T / Z)$

[Handwritten signature]

[Large handwritten signature]

Long-duration current impulse withstand test.

Test circuit: A0017

Date: June 24, 2008

| Sample | Impulse | Charging voltage U_c | Oscillogram | Peak current I | Residual voltage U_{res} | Energy E |
|--------|---------|---------------------------|-------------|---------------------|-------------------------------|---------------|
| No. | No. | kV | No. | A | kV | kJ |
| LDI | 1 | 51,4 | | 286 | 24,36 | 15,54 |
| | 2 | 51,4 | | 286 | 24,56 | 15,67 |
| | 3 | 51,4 | 10 | 286 | 24,68 | 15,73 |
| | 4 | 51,4 | | 288 | 24,43 | 15,69 |
| | 5 | 51,4 | | 287 | 24,63 | 15,72 |
| | 6 | 51,4 | | 286 | 24,73 | 15,71 |
| | 7 | 51,4 | | 288 | 24,50 | 15,70 |
| | 8 | 51,4 | | 286 | 24,62 | 15,69 |
| | 9 | 51,4 | 13 | 284 | 24,78 | 15,70 |
| | 10 | 51,4 | | 289 | 24,56 | 15,98 |
| | 11 | 51,4 | | 286 | 24,66 | 15,68 |
| | 12 | 51,4 | | 286 | 24,78 | 15,74 |
| | 13 | 51,4 | | 286 | 24,51 | 15,63 |
| | 14 | 51,4 | | 286 | 24,66 | 15,68 |
| | 15 | 51,4 | | 284 | 24,73 | 15,67 |
| | 16 | 51,4 | | 286 | 24,49 | 15,66 |
| | 17 | 51,4 | | 284 | 24,67 | 15,64 |
| | 18 | 51,4 | 16 | 285 | 24,80 | 15,69 |


Notes:

| Measured waveshape | |
|--------------------|------------------------|
| virtual duration | virtual total duration |
| μs | μs |
| 2000 | 2560 |

| Oscilloscope settings | | | |
|-----------------------|-------------------|-----------|-------------|
| | sampling division | Input | Attenuation |
| | μs | V_{div} | |
| Current | 500 | 0,5 | 10:10 |
| Voltage | 500 | 1,0 | 10:5 |

Continued

A1147IG



Continued

Date: June 24, 2008

| Sample No. | Impulse No. | Charging voltage U_c kV | Oscillogram No. | Peak current I A | Residual voltage U_{res} kV | Energy E kJ |
|------------|-------------|---------------------------|-----------------|------------------|-------------------------------|-------------|
| LD2 | 1 | 51,4 | | 286 | 24,63 | 15,71 |
| | 2 | 51,4 | | 284 | 24,90 | 15,68 |
| | 3 | 51,4 | 11 | 283 | 24,96 | 15,69 |
| | 4 | 51,4 | | 286 | 24,68 | 15,70 |
| | 5 | 51,4 | | 283 | 24,85 | 15,68 |
| | 6 | 51,4 | | 285 | 24,92 | 15,78 |
| | 7 | 51,4 | | 284 | 24,74 | 15,69 |
| | 8 | 51,4 | | 284 | 24,87 | 15,73 |
| | 9 | 51,4 | 14 | 283 | 24,99 | 15,76 |
| | 10 | 51,4 | | 284 | 24,74 | 15,67 |
| | 11 | 51,4 | | 283 | 24,87 | 15,70 |
| | 12 | 51,4 | | 283 | 24,98 | 15,73 |
| | 13 | 51,4 | | 284 | 24,71 | 15,70 |
| | 14 | 51,4 | | 284 | 24,90 | 15,75 |
| | 15 | 51,4 | | 283 | 24,98 | 15,74 |
| | 16 | 51,4 | | 285 | 24,78 | 15,75 |
| | 17 | 51,4 | | 284 | 24,92 | 15,75 |
| | 18 | 51,4 | 17 | 284 | 25,00 | 15,75 |

Notes:

| Measured waveshape | |
|--------------------------|--------------------------------|
| virtual duration μs | virtual total duration μs |
| 2000 | 2560 |

| Oscilloscope settings | | | |
|-----------------------|---------------------------|-----------------|-------------|
| | sampling division μs | input V_{div} | Attenuation |
| Current | 500 | 0,5 | 10:10 |
| Voltage | 500 | 1,0 | 10:5 |

Continued

AI177IG

ВРЪЧНО С ОРЪГИНАЛАТА



Continued

Date: June 24, 2008

| Sample | Impulse | Charging voltage | Oscillogram | Peak current | Residual voltage | Energy |
|--------|---------|------------------|-------------|--------------|------------------|-----------|
| No. | No. | U_c kV | No. | I A | U_{res} kV | E kJ |
| LD3 | 1 | 51,4 | | 287 | 24,54 | 15,67 |
| | 2 | 51,4 | | 286 | 24,68 | 15,68 |
| | 3 | 51,4 | 12 | 286 | 24,83 | 15,70 |
| | 4 | 51,4 | | 286 | 24,56 | 15,67 |
| | 5 | 51,4 | | 287 | 24,73 | 15,78 |
| | 6 | 51,4 | | 286 | 24,83 | 15,82 |
| | 7 | 51,4 | | 286 | 24,61 | 15,66 |
| | 8 | 51,4 | | 286 | 24,72 | 15,78 |
| | 9 | 51,4 | 15 | 284 | 24,85 | 15,71 |
| | 10 | 51,4 | | 287 | 24,62 | 15,76 |
| | 11 | 51,4 | | 284 | 24,77 | 15,68 |
| | 12 | 51,4 | | 283 | 24,86 | 15,71 |
| | 13 | 51,4 | | 286 | 24,58 | 15,70 |
| | 14 | 51,4 | | 284 | 24,73 | 15,66 |
| | 15 | 51,4 | | 284 | 24,88 | 15,71 |
| | 16 | 51,4 | | 286 | 24,64 | 15,71 |
| | 17 | 51,4 | | 284 | 24,77 | 15,71 |
| | 18 | 51,4 | 18 | 285 | 24,91 | 15,81 |

Notes:

| Measured waveshape | |
|--------------------|------------------------|
| Virtual duration | virtual total duration |
| μs | μs |
| 2000 | 2560 |

| Oscilloscope settings | | | |
|-----------------------|-------------------|-----------|-------------|
| | sampling division | input | Attenuation |
| | μs | V_{div} | |
| Current | 500 | 0,5 | 10:10 |
| Voltage | 500 | 1,0 | 10:5 |

Continued

A1177IG

ВЯРНО С ОРИГИНАЛА



335

Long-duration current impulse withstand test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: June 25, 2008

| Sample No. | Requested Current | Charging voltage kV | Oscillogram No. | Current waveshape μ s | Discharge current kA | Residual voltage kV |
|------------|-------------------|---------------------|-----------------|---------------------------|----------------------|---------------------|
| LD1 | I _n | 31,4 | 22 | 8,7/20,0 | 10,15 | 31,81 |
| LD2 | | 31,3 | 23 | | 10,13 | 31,92 |
| LD3 | | 31,4 | 24 | | 10,09 | 31,78 |

| | Oscilloscope settings | | |
|---------|---------------------------|------------------------|-------------|
| | sampling division μ s | input V _{div} | attenuation |
| Current | 5 | 1,0 | 50:10 |
| Voltage | 5 | 1,0 | 20:5 |

Notes:

Handwritten signature

Handwritten signature

Long -duration current impulse withstand test.

check of the integrity of the internal parts with a nineteenth shot at ambient temperature

Test circuit: A0017

Date: June 24, 2008

| Sample | Impulse | Charging voltage V_c | Oscillogram | Peak current I | Residual voltage V_r | Energy E |
|--------|---------|---------------------------|-------------|---------------------|---------------------------|---------------|
| No. | No. | kV | No. | A | kV | kJ |
| LD1 | 19 | 51,4 | 19 | 286 | 24,52 | 15,64 |
| LD2 | 19 | 51,4 | 20 | 285 | 24,80 | 15,64 |
| LD3 | 19 | 51,4 | 21 | 288 | 24,69 | 15,72 |


Notes:

| Measured waveshape | |
|--------------------|------------------------|
| virtual duration | virtual total duration |
| μs | μs |
| 2000 | 2560 |

| Oscilloscope settings | | | |
|-----------------------|-------------------|-----------|-------------|
| | sampling division | input | attenuation |
| | μs | V_{div} | |
| Current | 500 | 0,5 | 10:10 |
| Voltage | 500 | 1,0 | 10:5 |

[Handwritten signature]

Circuit A0019



Power frequency supply

- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI No.31120; $R = 941,4 \Omega$
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522; attenuation 50:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090


Handwritten signature

Handwritten signature

ВАРНО С ОРМОНАМ

BAK-02 OOD
САМОКОВ
Handwritten signature

Circuit A0120



Impulse generator

- No. of stages 1
- Cg 4,98 μ F
- Lc 10 μ H
- S - Spark-gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.13027
- Electro optical system CESI No.11521/522;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No.11517/518;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

Handwritten signature


Handwritten signature

Handwritten signature

ВАРНО С ОПРИГНАЛАТА



Circuit A0122



Impulse generator

- No. of stages 1.
- Cg 2,49 μ F
- Lc 100 μ H
- S - Spark-gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6037; R= 20 m Ω ; peak current= 250 kA
- Electro optical system CESI No 11517/519
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

Handwritten signature

Handwritten signature


A0141G

Handwritten signature

ВЕРНО С ОПРИМНАТА



Circuit A0017



Impulse generator

- C₁ ... C₁₀ - capacitors 37,5 μF
- C₁₂ - capacitors 18,75 μF
- L₁ ... L₁₁ - inductors 666 μH
- L₁₂ - inductor (600+500) μH

S: - spark gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)





Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 m Ω
- Electro optical system CESI No 11521/11522.
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

A0017IG

ВЯРНО С ОПИШВАНАТА





Handwritten signature

Handwritten initials

Handwritten initials

ВЯРНО С ОРНАМЕНТАТЕ



Client **DERVASIL**

Address of the Client **Route de Popenot F-42800 Saint Joseph (FRANCE)**

Tested samples/items **Polymer-housed metal-oxide surge arrester type AZBD092 assembled with additional thermal insulation and fitted with disconnectors**

Tests carried out **High current impulse operating duty test**

Standards/Specifications **IEC 60099-4 – Edition 2.1 (2006-07)**

Tests date **from April 01, 2008 to April 02, 2008**

The results reported in this document relate only to the tested samples/items.
 Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages **25** No. of pages annexed **46**

Issue date **September 03, 2008**

Prepared **LAP - Gregori Marco**

Verified **LAP - Sironi Alberto, LAP - Arneodo Giorgio**

Approved **LAP - Nicolini Roberto**

CESI S.p.A.
 Energy Division
 Technical Area Components

на основании чл. 2 от 33ЛД

D10001G rev.04

CESI
 Centro Elettrotecnico
 Sperimentale Italiano
 Giacinto Motta spa
 Via R. Rubattino 54
 20134 Milano - Italia
 Telefono +39 022125.1
 Fax +39 0221255440
 http://www.cesi.it

Capitale sociale 8 550 000 Euro
 Interamente versato
 Codice fiscale e numero
 Iscrizione CCIAA 00793580150
 Registro Imprese di Milano
 Sezione Ordinaria
 N. R.E.A. 429222
 P.I. 00793580150

ВАРНО С ОПИТАТЕЛНА

“BAK - 02” ОЧА
 САОКОВ

Tests witnessed by:

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawings identified by CESI and numbered A8024793 no. 1 to 2 are annexed to this document..

The data necessary to permit repetition of the tests are contained in the document marked: ----

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with impulse current : peak value: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3 \%$ time: $\pm 3,5 \%$
- dielectric tests with direct voltage : voltage: $\pm 3 \%$ time: $\pm 3,5 \%$
- atmospheric conditions : temperature: $\pm 2 \text{ }^\circ\text{C}$; pressure: $\pm 0,133 \text{ kPa}$; humidity: $\pm 10 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory information


Receipt date of the sample June 19, 2008

Test location CESI - Via Rubattino 54 - Milan

CESI testing team Mr L. Podavitte

Test laboratory P177

Activity code AE08LAP016



| content | page | test date |
|---|--|-------------------------------|
| Test object characteristics Picture of the test object Reference standard Test carried out Test object identification Test procedure Visual inspection and summary of test result High current operating duty test Technical data | 4 5 6 6 6 7 8 from page 9 to 17 from page 18 to 25 | from June 23 to June 30, 2008 |

Pages annexed:

Oscillograms n. 43 pages

DERVASIL drawing no. 99B000210B; CESI no. A8024793/1 - n.1 page

DERVASIL drawing no. 99B000226A; CESI no. A8024793/2 - n.1 page

DERVASIL technical document no. 99B000224A; CESI no. A8024794 - n.1 page



CESI

Test Report

Test object characteristics

type: Polymer-housed metal-oxide surge arrester type AZBD092 assembled with additional thermal insulation and fitted with disconnectors

electrical characteristics (assigned by the client)

| | |
|---|----------------------------------|
| Manufacturer's name | DERVASIL – SAINT JOSEPH (FRANCE) |
| Nominal discharge current – I_n [kA] | 10 |
| Rated voltage – U_r [kV] | 1,03 x U_{ref} |
| Continuous operating voltage - U_c [kV] | 0,83 x U_{ref} |
| Reference current - I_{ref} [mA] | 5,0 |
| Line discharge class | 1 |
| Standard rated frequency - [Hz] | 50/60 |
| year of manufacture | 2008 |

NOTE:

The thermal model was supplied by the manufacturer

The verification of the thermal equivalency according to annexe B was not carried out by CESI

ВАРНО С ОРИГИНАЛА

“BAK - 02” ООД
САМОКОВ

Picture of the test object




Photo no. 1

Polymer-housed metal-oxide surge arrester

ВЯРНО С ОРЪГИНАЛА



A12671G

342

Reference standard

IEC 60099-4 (2006-07) – Edition 2.1 – Clause 10.8.5


“ Metal-oxide surge arresters without gaps for a.c. system “

Test carried out


| test carried out | number of sample tested |
|--|-------------------------|
| High current impulse operating duty test | 3 |

Test object identification

| test object names | identification of test sample (assigned by the CESI) |
|---|--|
| Polymer-housed metal-oxide surge arrester type AZBD092 assembled with additional thermal insulation | OD1-OD2-OD3 |



A1176IG



ВЯРНО С ОРМЪМНАТА



Test procedure

The test procedure consisted of the following sequence:

- a) Measurement of the power frequency reference voltage at the reference current
- b) Measurement of the lightning impulse residual voltage at the nominal discharge current
- c) Calculation of the voltage correction factors according to the reference standard
- d) Conditioning 1: application of twenty impulses $8/20 \mu\text{s}$ at the nominal discharge current superimposed to the power frequency voltage at 1,2 times U_c in four groups of five impulses
 - interval between impulses of the same group: 50-60 seconds
 - interval between groups: 30 minutes
 - polarity of the impulses: same as that of the half cycle of power frequency voltage during which it occurred (positive)
 - synchronization of the impulses: 60 electrical degrees before the peak of the power frequency.
- e) Conditioning 2: application of one high current impulse $4/10 \mu\text{s}$ at 100 kA
- f) Heating in an oven at the temperature of 60°C till thermal equilibrium
- g) Application of a second high current impulse $4/10 \mu\text{s}$ at 100 kA. A time shorter than 100 ms after the application of the second high current shot energization at U_r' for 10 sec. and then at U_c' for 30 min. to verify the thermal stability.
- h) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value with two impulses at 50 sec to 60 sec. time interval in between

TEST RESULT

The visual inspection of the sample after the test has revealed no sign of physical damage.

The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%).

The oscillographic record of the two last lightning impulse at nominal discharge current did not reveal any sign of internal discharge.

The thermal stability was achieved

The disconnectors did not operate

The acceptance criteria are fulfilled. The test result is positive

Variation of lightning impulse residual voltage at I_n

| Sample | before test | | after test | | Variation |
|--------|-------------------|------------------|-------------------|------------------|-----------|
| | discharge current | residual voltage | discharge current | residual voltage | |
| | kA | kV | kA | kV | % |
| OD1 | 10,09 | 32,27 | 10,11 | 33,1 | + 2,57 |
| OD2 | 10,12 | 32,02 | 9,90 | 33,4 | + 4,20 |
| OD3 | 10,02 | 32,00 | 10,08 | 33,1 | + 3,40 |

Visual inspection after the test

The visual inspection of the polymer-housed metal-oxide surge arrester after the test has revealed no sign of physical damage

A1441IG

ВЯРНО С ОПРИГНАЛАТА



High current impulse operating duty test.

Reference voltage test

Test circuit: A0019

Date: June 23, 2008

| Sample No. OD1 | | | | | | |
|----------------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| Oscillogram | voltage | current | current | current | power | 3rd harmonic amplitude |
| No. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 1 | 13,60 | 5,06 | 4,62 | 1,56 | 14,31 | -- |

| Sample No. OD2 | | | | | | |
|----------------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| Oscillogram | voltage | current | current | Current | power | 3rd harmonic amplitude |
| No. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 2 | 13,55 | 5,04 | 4,22 | 1,50 | 13,53 | -- |

| Sample No. OD3 | | | | | | |
|----------------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| Oscillogram | voltage | current | current | Current | power | 3rd harmonic amplitude |
| No. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 3 | 13,50 | 5,08 | 4,38 | 1,53 | 13,76 | -- |

ВЯРНО С ОПРАТНАТА



High current impulse operating duty test.

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: June 23, 2008

| Sample No. | Requested current | Charging voltage kV | Oscillogram No. | Current waveshape μs | Discharge current kA | Residual Voltage kV |
|------------|-------------------|---------------------|-----------------|---------------------------|----------------------|---------------------|
| OD1 | I _n | 45,8 | 4 | 8,7/19,2 | 10,09 | 32,27 |
| OD2 | | 45,8 | 5 | | 10,12 | 32,02 |
| OD3 | | 45,5 | 6 | | 10,02 | 32,00 |

| | Oscilloscope settings | | |
|---------|---------------------------|------------------------|-------------|
| | sampling division μs | input V _{div} | Attenuation |
| Current | 5 | 1,0 | 50:10 |
| Voltage | 5 | 1,0 | 50:5 |

Notes:

Voltage correction factor and energy calculations

Date: June 24, 2008

| Sample | U _{ref} [1] | KU _r [2] | KU _c [3] | U _r ' [4] | U _c ' [5] | U _s ' [6] |
|--------|-------------------------|------------------------|------------------------|-------------------------|-------------------------|-------------------------|
| No. | kV | | | kV | kV | kV |
| OD1 | 13,60 | 1,03 | 0,83 | 14,008 | 11,288 | 13,546 |
| OD2 | 13,55 | | | 13,957 | 11,247 | 13,496 |
| OD3 | 13,50 | | | 13,905 | 11,205 | 13,446 |

- [1] U_{ref} : measured reference voltage
- [2] KU_r : factor claimed by the manufacturer for calculation of U_r'
- [3] KU_c : factor claimed by the manufacturer for calculation of U_c'
- [4] U_r' : corrected rated voltage [4] = [1] × [2]
- [5] U_c' : corrected continuous operating voltage [5] = [1] × [3]
- [6] U_s' : corrected voltage to be applied during the conditioning [6] = 1,2 × [5]

ВЯРНО С ОРИГИНАЛА



353

High current impulse operating duty test.

Conditioning: application of twenty 8/20 μ s current impulses (first part)

Test circuit: A0015

Date: June 26, 2008

| Imp. No. | Osc. No. | Sample No. OD1 | | Osc. No. | Sample No. OD2 | | Osc. No. | Sample No. OD3 | |
|----------|----------|----------------|-----------------|----------|----------------|-----------------|----------|----------------|-----------------|
| | | charging kV | peak current kA | | Charging kV | peak current kA | | charging kV | peak current kA |
| 1 | 7 | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 2 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 3 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 4 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 5 | 8 | 60,4 | 10,0 | 9 | 60,4 | 10,0 | 10 | 60,4 | 10,0 |
| 6 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 7 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 8 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 9 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 10 | 11 | 60,4 | 10,0 | 12 | 60,4 | 10,0 | 13 | 60,4 | 10,0 |
| 11 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 12 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 13 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 14 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 15 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 16 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 17 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 18 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 19 | | 60,4 | 10,0 | | 60,4 | 10,0 | | 60,4 | 10,0 |
| 20 | 14 | 60,4 | 10,0 | 15 | 60,4 | 10,0 | 16 | 60,4 | 10,0 |

| | | | |
|---|----------------|----------------|----------------|
| Power frequency voltage applied to the test sample during current impulse applications [kV] | Sample No. OD1 | Sample No. OD2 | Sample No. OD3 |
| | 13,546 | 13,496 | 13,446 |

| | Oscilloscope settings | | |
|---------|-----------------------|------------------|-------------|
| | sampling division | Input | attenuation |
| | ms | V _{div} | |
| Current | 10 | 1,0 | 50:10 |
| Voltage | 10 | 1,0 | 50:5 |

Notes:

ВАРНО С ОПРИГНАЛАТА



[Handwritten signatures]

High current impulse operating duty test.

Conditioning: Application of the first impulse 100 kA 4/10 μ s high current impulses (second part)


Test circuit: A0121

Date: June 27, 2008

| Sample | Impulse | Charging voltage | Oscillogram | Discharge current | Residual Voltage | current waveshape | Energy |
|--------|---------|------------------|-------------|-------------------|------------------|-------------------|--------|
| No. | No. | kV | No. | kA | kV | μ s | kJ |
| OD1 | 1 | 93,5 x 2 | 17 | 98,0 | 53,1 | 4,5/9,8 | 33,1 |
| OD2 | 1 | 93,5 x 2 | 18 | 98,5 | 52,1 | | 33,0 |
| OD3 | 1 | 93,5 x 2 | 19 | 99,0 | 53,8 | | 33,0 |

| Oscilloscope settings | | | |
|-----------------------|-------------------|------------------|-------------|
| | sampling division | input | attenuation |
| | μ s | V _{div} | |
| Current | 2 | 2,0 | 300:10 |

Notes: opposite polarity 4,6 %



A11531G

ВЕРНО С ОПРИГІНАЛАТА



355

High current impulse operating duty test.

Application of the second high current impulse, of the rated voltage U_r' and evaluation of thermal stability

Test circuit: A0123 – A0020 – A0131

Sample No.: OD1

Preheating temperature: 61 °C

Date: June 30, 2008

Second high current impulse application

| Oscillogram No. | Charging voltage kV | Residual voltage kV | Discharge current kA | Energy kJ | Current waveshape μ s |
|-----------------|---------------------|---------------------|----------------------|-----------|---------------------------|
| 20 | 94,0 x 2 | --- | 99,0 | --- | 4,5/9,8 |

Corrected rated voltage U_r' application

| Oscillogram No. | Time s | Voltage kV | Current + mA _{cr} | Current - mA _{cr} | Power W |
|-----------------|--------|------------|----------------------------|----------------------------|---------|
| 21 | 0 | 14,008 | 96,0 | 130,0 | 327 |
| 22 | 10 | | 61,0 | 96,0 | |

Corrected continuous operating voltage U_c' application to evaluate the thermal stability

| Oscillogram No. | Time min | Voltage kV | Current + mA _{cr} | Current - mA _{cr} | Power W |
|-----------------|----------|------------|----------------------------|----------------------------|---------|
| 23 | 0 | 11,288 | 1,51 | 2,96 | 10,35 |
| | 5 | | 1,20 | 1,12 | 3,03 |
| | 10 | | 1,18 | 1,08 | 2,83 |
| 24 | 15 | | 1,16 | 1,05 | 2,50 |
| | 20 | | 1,12 | 1,03 | 2,21 |
| | 25 | | 1,11 | 1,02 | 2,14 |
| 25 | 30 | | 1,10 | 1,01 | 2,05 |

continued

A1154IG

ВЯРНО С ОРИГИНАЛАТА



continued

Sample No.: OD2

Preheating temperature: 61 °C

Date: June 30, 2008

Second high current impulse application

| Oscillogram No. | Charging voltage kV | Residual voltage kV | Discharge current kA | Energy kJ | Current μ s |
|-----------------|---------------------|---------------------|----------------------|-----------|-----------------|
| 26 | 94,0 x 2 | --- | 99,0 | --- | 4,5/9,8 |

Corrected rated voltage U_r application

| Oscillogram No. | Time s | Voltage kV | Current + mA _{cr} | Current - mA _{cr} | Power W |
|-----------------|--------|------------|----------------------------|----------------------------|---------|
| 27 | 0 | 13,957 | 105,0 | 156,0 | 260 |
| 28 | 10 | | 48,0 | 71,0 | |

Corrected continuous operating voltage U_r application to evaluate the thermal stability

| Oscillogram No. | Time min | Voltage kV | Current + mA _{cr} | Current - mA _{cr} | Power W |
|-----------------|----------|------------|----------------------------|----------------------------|---------|
| 29 | 0 | 11,247 | 2,50 | 3,01 | 10,80 |
| | 5 | | 1,24 | 1,12 | 2,81 |
| | 10 | | 12,0 | 1,07 | 2,40 |
| 30 | 15 | | 1,18 | 1,06 | 2,18 |
| | 20 | | 1,17 | 1,02 | 2,12 |
| | 25 | | 1,15 | 1,01 | 2,00 |
| 31 | 30 | | 1,13 | 0,99 | 1,88 |

continued

A11551G

ВЯРНО С ОПИТИНАТА



353

continued

Sample No.: OD3

Preheating temperature: 61 °C

Date: June 30, 2008

Second high current impulse application

| Oscillogram No. | Charging voltage kV | Residual voltage kV | Discharge current kA | Energy kJ | Current μ s |
|-----------------|---------------------|---------------------|----------------------|-----------|-----------------|
| 32 | 94,0 x 2 | --- | 103,0 | --- | 4,5/9,8 |

Corrected rated voltage U_r application

| Oscillogram No. | Time s | Voltage kV | Current + mA _{cr} | Current - mA _{cr} | Power W |
|-----------------|--------|------------|----------------------------|----------------------------|---------|
| 33 | 0 | 13,905 | 60,0 | 80,0 | 185 |
| 34 | 10 | | 46,0 | 70,0 | |

Corrected continuous operating voltage U_c application to evaluate the thermal stability

| Oscillogram No. | Time min | Voltage kV | Current + mA _{cr} | Current - mA _{cr} | Power W |
|-----------------|----------|------------|----------------------------|----------------------------|---------|
| 35 | 0 | 11,205 | 2,30 | 2,80 | 9,51 |
| | 5 | | 1,30 | 1,18 | 3,51 |
| | 10 | | 1,26 | 1,16 | 3,27 |
| 36 | 15 | | 1,24 | 1,10 | 3,09 |
| | 20 | | 1,22 | 1,06 | 2,72 |
| | 25 | | 1,21 | 1,03 | 2,54 |
| 37 | 30 | | 1,18 | 1,01 | 2,40 |

continued

A11551G

ВРЪЧНО С ОПИГНАНАТА



High current impulse operating duty test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: June 30, 2008

| Sample No. | Requested current | Charging voltage kV | Oscillogram No. | Current waveshape μ s | Discharge current kA | Residual voltage kV |
|------------|-------------------|---------------------|-----------------|---------------------------|----------------------|---------------------|
| OD1 | I_n | 45,8 | 38 | 8,7/19,0 | 9,95 | 33,0 |
| | | 45,9 | 39 | | 10,11 | 33,1 |
| 45,9 | | 40 | 9,90 | | 33,4 | |
| OD2 | | 46,0 | 41 | | 9,90 | 33,4 |
| | | 46,1 | 42 | | 10,16 | 33,4 |
| OD3 | | 46,1 | 43 | | 10,08 | 33,1 |

| | Oscilloscope settings | | |
|---------|---------------------------|-----------------|-------------|
| | sampling division μ s | input V_{div} | attenuation |
| Current | 5 | 1,0 | 50:10 |
| Voltage | 5 | 1,0 | 20:5 |

Notes:


A12451G

ВЯРНО С ОРИГИНАЛАТА



359

Circuit A0019



Power frequency supply

- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI N° 31120; R= 941,4 Ω
- Electro optical system CESI N°.-; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI N°. 6318


Voltage measuring system

- D - Voltage divider SAGI; CESI N°.11120
- Electro optical system CESI N°.11520/11524; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI N°.6318

A0019IG



Circuit A0120



Impulse generator

- No. of stages 1
- Cg 4,98 μ F
- Lc 10 μ H
- S - Spark-gap

Voltage measuring system.


- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No. 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system


- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No. 11517/518
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

A0120IG

ВЯРНО С ОПРИГНАТА



Circuit A0122



Impulse generator

- No. of stages 1
- Cg 4,98 μ F
- Lc 100 μ H
- S - Spark-gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522; attenuation 5:5
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system


- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

A014IG

ВЯРНО С ОРИГИНАЛА



Circuit A0015



Impulse generator

No. of stages: 1

- C_g - Capacitor 4,98 μF
- L - Inductance of the circuit
- L_c - Inductor 10 μH
- S - Spark gap

One resistor block has been added

Power frequency supply

- RE - Regulator type specialtrasfo; power 20 kVA; voltage 380 V/ 220 V
- T - Transformer type Pivi; power 30 kVA; voltage 220 V/ 15 kV
- B - Blocking gap

Current measuring system

- Sh₁ - Current shunt CESI No.6042; R = 0,002 Ω
- Electro optical system CESI No.11517/11518; attenuation 20:5
- OSC - Oscilloscope type Tektonix 540A; CESI No.13217 (on channel No.1)

Voltage measuring system

- D - Voltage divider SAGI ; CESI No.1120; k = 1010
- Electro optical system CESI No.11520/11521; attenuation 50:5
- OSC - Oscilloscope type Tektonix 540A; CESI No.13217 (on channel No.2)


A0015IG

ВРЪЧНО С ОПРИТНАТА



363

Circuit A0121



Impulse generator

No. of stages 2
 Cg 3,32 μ F

S - Spark-gap

Three blocks in series have been added

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No11517/518
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)


A0121IG

ВЯЗНО С ОРИГИНАЛАТА



364

Circuit A0123



to circuit A0020

Impulse generator circuit


No. of stages 2

Cg 3,32 μ F


S - spark-gap

A0123IG

ВЯРНО С ОРИГИНАЛА



Circuit A0020



Impulse generator circuit A0124

I - Circuit-breaker

Impulsive current measuring system

- Sh₁ - Current shunt CESI No.6039; R= 20 m Ω
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC₁ - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

Power frequency circuit A0130

Voltage measuring system.



- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.8009/8015; attenuation 50:5
- OSC₁ - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)
- OSC₂ - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090 (on channel No.2)

Power frequency current measuring system


Sh₂ (TOV) - Current shunt CESI R= 500 Ω - Electro optical system CESI No.8011/8017

OSC₂ - Oscilloscope type TEKTRONIX TDS 744A; CESI No.13937 (on channel No.1)

A0020IG



Circuit A0131



Power-frequency circuit

from 380Vac power supply

- R₁ single-phase voltage regulator CORMES; power 20 kVA; voltage 380/0 + 220 Vac
- R₂ single-phase voltage regulator CORMES; power 10 kVA; voltage 380/0 + 220 Vac
- T₁ voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200-400 V/15-30 kV

A0131IG

ВЯЖНО С ОРИГИНАЛАТА



Client DERVASIL F-42800 Saint Joseph - France

Tested equipment Disconnectors for polymer housed metal-oxide surge arresters

Tests carried out Time-versus current curve

Standards/Specifications Specification ENEL DY1018 (11-2003)

Test date from March 8, 2005 to March 8, 2005

The results reported in this document relate only to the tested equipment. Partial reproduction of this document is permitted only with the written permission from CESI

[Handwritten signature]

No. of pages 15

No. of pages annexed 28

Issue date March 14, 2005

Prepared BU PeC/TEST - M. Levati

на основание чл. 2 от ЗЗЛД

Verified BU PeC/TEST - R. Malgesini

Approved BU PeC/TEST - M. de Nigris

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prova di Componenti
Il Responsabile del Laboratorio

на основание чл. 2 от ЗЗЛД

CESI
Centro Elettrotecnico
Sperimentale Italiano
Giacinto Motta spa

Via R. Rubatino 64
20134 Milano - Italia
Telefono +39 0221251
Fax +39 0221255440
http://www.cesi.it

Capitala societate
interamente s.p.a.
Codice fiscale e
iscr. Zone CGIA/00784550159 - R.T. 110319/0001150

and

[Handwritten signature]

ВЯРНО С ОРИГИНАЛАТА



Tests witnessed by /

Identification of the object requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object. This drawing, identified by CESI and numbered A5/009432 No. 1, is annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: -

The measurement uncertainties of the test results reported in this document comply with the following limits:

voltage : ± 5 % ; current : ± 5 % ; time : ± 5 %

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum estimated values referred to that type of measurement.

Receipt date of the sample March 7, 2005

Test location CESI -- Via Rubattino 54 -- Milan

Activity code 31757A

12001IG

ВАЖНО С ОПРИГНАЛАТА



| Contents | Page | Test date |
|---|---------|---------------|
| Rated characteristics of the surge arrester for which the disconnectors are designed to be used | 4 | --- |
| Disconnector operation test - Arrangements and test modalities | 5 | --- |
| Test results | 5 | --- |
| Single-phase current tests results | 6 4 8 | March 8, 2005 |
| Time current versus curve | 9 | --- |
| Test circuit M0015 | 10 | --- |
| Photographs of test arrangement | 11 | --- |
| Photographs of some samples after the test | 11 4 12 | --- |
| Laboratory informations | 13 + 15 | --- |
| Pages annexed: | | |
| - Oscillogram from test report MP-A5/008453 (total pages: 27) | | |
| - drawing nb. A5/009432 (1 page) | | |

SECRET CONFIDENTIAL



Handwritten signature

Rated characteristics of the surge arrester for witch the disconnectors are designed to be used

| | |
|---------------------------|--|
| Manufacturer | DERVASIL F-42800 Saint Joseph (France) |
| Duty cycle voltage rating | up to 17,5 kV |
| Frequency | 50 Hz |
| Classifying current | 5 kA & 10 kA |
| Classification | distribution normal & heavy duty |

Handwritten signature: *[Signature]*

[Handwritten signature]

ВЯРЧО С ОРНИНАЦИ



Disconnecter operation test

Arrangements and test modalities

The disconnecters were tested with-out the surge arrester and with an insulating bracket also supplied by the manufacturer

The bolted junction from the disconnector and the flexible conductor was performed applying a torque force of 20 Nm for 30s.

The applied voltage was about 16750 V


The test voltage was applied for 400 ms and after 400 ms with-out voltage, the test voltage was reapplied due to verify the effective disconnection

Five samples of disconnecters were tested for each of the four current values stated by the Standard.

Test results

In all the tests the disconnecters operated and the separation was permanent and effective. The operation times (time to first movement) are reported in the table from page 6 to page 8 and in the diagram to page 9. A view of some disconnector after the test is shown in the photos from page 11 to page 12.

The test result is positive



Single-phase current tests results

Test circuit: M0015

Reference number of the oscillograms: MP-A5/008453

| Test | Oscillogram | Prospective current | | Power factor | Supply voltage | Frequency |
|------|-------------|---------------------|------------|--------------|----------------|-----------|
| | | rms value | peak value | | | |
| No. | No./sheet | A | A | - | V | Hz |
| T1 | 3/1 | 613 | 1560 | 0,07 | 16770 | 50 |

Date: March 8, 2005

| Test | Oscillogram | Sample tested | voltage | current | time to first movement | restart of the current | Photo of one sample after the test | Test result |
|------|-------------|---------------|---------|---------|------------------------|------------------------|------------------------------------|-------------|
| No. | No./sheet | No. | V | A | ms | yes / not | no. | |
| 1 | 5/2 | 1 | 16630 | 599 | 14,5 | not | 3 | positive |
| 2 | 6/2 | 2 | 16580 | 603 | 4,9 | not | | positive |
| 3 | 7/2 | 3 | 16620 | 597 | 10,3 | not | | positive |
| 4 | 8/2 | 4 | 16620 | 592 | 15,0 | not | | positive |
| 5 | 9/2 | 5 | 16540 | 594 | 6,6 | not | | positive |

ВЯРНО С ОРИГИНАЛАТА



continued

continued

Test circuit: M0015

Reference number of the oscillograms: MP-A5/008453

| Calibration of the test circuit | | | | | | |
|---------------------------------|-------------|---------------------|------------|--------------|----------------|-----------|
| Test | Oscillogram | Prospective current | | Power factor | Supply voltage | Frequency |
| | | rms value | peak value | | | |
| No. | No./sheet | A | A | - | V | Hz |
| T2 | 11/1 | 200 | 525 | 0,05 | 16530 | 50 |
| | | | | | | |

Date: March 8, 2005

| Test | Oscillogram | Sample tested | voltage | current | time to first movement | restart of the current | Photo of one sample after the test | Test result |
|------|-------------|---------------|---------|---------|------------------------|------------------------|------------------------------------|-------------|
| No. | No./sheet | No. | V | A | ms | yes / not | no. | |
| 6 | 12/2 | 6 | 16530 | 198 | 23,6 | not | 4 | positive |
| 7 | 13/2 | 7 | 16580 | 199 | 29,7 | not | | positive |
| 8 | 14/2 | 8 | 16500 | 196 | 17,1 | not | | positive |
| 9 | 15/2 | 9 | 16510 | 197 | 36,5 | not | | positive |
| 10 | 16/2 | 10 | 16500 | 198 | 28,2 | not | | positive |

continued

Test circuit: M0015



Reference number of the oscillograms: MP-A5/008453

| Calibration of the test circuit | | | | | | |
|---------------------------------|-------------|---------------------|------------|--------------|----------------|-----------|
| Test | Oscillogram | Prospective current | | Power factor | Supply voltage | Frequency |
| | | rms value | peak value | | | |
| No. | No./sheet | A | A | - | V | Hz |
| T3 | 17/1 | 19,72 | 53,0 | 0,03 | 16730 | 50 |
| | | | | | | |


Date: March 8, 2005

| Test | Oscillogram | Sample tested | voltage | current | time to first movement | restart of the current | Photo of one sample after the test | Test result |
|------|-------------|---------------|---------|---------|------------------------|------------------------|------------------------------------|-------------|
| No. | No./sheet | No. | V | A | ms | yes / not | no. | |
| 11 | 18/2 | 11 | 16710 | 19,5 | 82,6 | not | 5 | positive |
| 12 | 20/1 | 12 | 16670 | 19,6 | 387 | not | | positive |
| 13 | 21/* | 13 | 16760 | 19,77 | 147 | not | | positive |
| 14 | 22/* | 14 | 16680 | 19,8 | 230 | not | | positive |
| 15 | 24/1 | 15 | 16680 | 19,8 | 149 | not | | positive |

* manca l'oscillogramma

ВЯРНО С ОРИГИНАЛА




1716
[Handwritten signature]

ВЯРНО С ОПРИГНАЛАТА




the current versus curve



[Handwritten signature]

Test circuit M0015



The symbols used in this diagram are the same as those on the oscillograms.

ВРАНО С ОПИШКАМ



Photographs of test arrangement




Photo no. 1




Photo no. 2

ВАРНО С ОПРИГНАТА



013

Handwritten signature

378

Photographs of some samples after the test




Photo no. 3




Photo no. 4

120091G

Handwritten signature

ВЯРНО С ОРИГИНАЛА



Laboratory information

Test laboratory: P102 / MP1
 CESI testing team: C. Assi
 C. Carniel
 G. Vassallo

Date: March 8, 2005

Characteristics of supply circuit

| Tests | | Supply | OTE MV | | OTE LV | |
|-------|----|----------------|--------|----------|--------|----------|
| from | to | | K | position | K | position |
| T1 | 15 | 23 kV Lambrate | 4,2 | - | | |
| | | | | | | |
| | | | | | | |

Characteristics of measuring system


| Measure | Transducer | | KRENZ | | TRANSISCOPE |
|---------|------------|----------|---------|-------------|-------------|
| | ref. | position | TRC No. | channel No. | channel No. |
| I | G1 | | 1 | 1 | |
| U | N1 - N2 | | 1 | 2 | |
| V | A1 - A3 | | 1 | 3 | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

Symbols assigned in 'ref.' column refer to the measuring equipment listed in page "Laboratory P102 – MP1. Measuring system characteristics."


Other measuring equipment:
 Ohmmeter CESI number: /



ВЕРНО С ОПРАВИЛАТА




$I_p = 1.56 \text{ kA}$
 $I = 613.21 \text{ A}$
 $D_c = 94.96 \text{ ms}$
 $I_{zt} = 53.78 \text{ kA}^2\text{s}$
 $U_b = 16.77 \text{ kV}$
 $C_f = 0.07$
 $F = 50.3 \text{ Hz}$




Handwritten signature

ВЯРНО С ОПРИТАНАТА



CESI MP-A5/008453 п.3

$I_p = 883.92 \text{ A}$
 $I = 599.10 \text{ A}$
 $D_c = 409.68 \text{ ms}$
 $I_{\Sigma t} = 142.80 \text{ kA}^2\text{s}$
 $U_a = 16.39 \text{ kV}$
 $U_b = 16.63 \text{ kV}$
 $C_f = 0.77$
 $F = 49.9 \text{ Hz}$




ВЯРЧО С ОРЪГИНАЛА



CESI MP-A5/008453 n.5

Handwritten marks


ВЯРНО С ОПИРАНЕТО




CESI MP-A5/008453 n.5

Handwritten signature


ВЯРНО С ОПИТАНИЕМ




CESI MP-A5/008453 n.6



CESI MP-A5/008453 n.6



IP=911.39 A
 I=597.34 A
 DC=409.83 ms
 I_{rt}=144.55 kA²s
 U_a=16.39 kV
 U_b=16.62 kV
 Cf=0.68
 F=50.0 Hz



29.2ms/div
 1314ms

[Handwritten signature]

[Handwritten signature]

U
16.7 kV

ВЯРНО С ОРВИНАТА

U
10. kV

I
391. A



292.

584.

876.

1168.

CESI MP-A5/008453 n.7


[Handwritten signature]

[Handwritten signature]


ВЯРНО С ОРИГИНАЛА



CESI MP-A5/008453 n.7



$I_p = 880.10 \text{ A}$
 $I = 592.50 \text{ A}$
 $D_c = 409.68 \text{ ms}$
 $I_{\text{rt}} = 141.73 \text{ kA}^2\text{s}$
 $U_a = 16.35 \text{ kV}$
 $U_b = 16.62 \text{ kV}$
 $C_f = 0.75$
 $F = 49.9 \text{ Hz}$



29.2 ms/div
 1314 ms

1168.

876.

584.


292.

0.

CESI MP-A5/008453 n.8

ВЯРНО С ОРИГИНАЛ





Handwritten signature

Handwritten initials


ВЯРНО С ОРИГИНАЛАТА



CESI MP-A5/008453 n.8

39A


$I_p = 855.26 \text{ A}$
 $I = 594.65 \text{ A}$
 $D_c = 409.82 \text{ ms}$
 $I_{\Sigma t} = 139.96 \text{ kA}^2\text{s}$
 $U_a = 16.30 \text{ kV}$
 $U_b = 16.54 \text{ kV}$
 $C_f = 0.85$
 $F = 49.8 \text{ Hz}$




29.2ms/div
 1314ns

Handwritten signature
 1105

ВЯРНО С ОРГАНИЗАЦИОННО-ТЕХНИЧЕСКИМ
 УТВЕРЖДЕНИЕМ



CESI MP-A5/008453 n.9



Handwritten signature

Handwritten initials

ВЯРНО С ОПРИТИНАЛА



СЕСИ МР-А5/008453 п.9

[Handwritten signature]


[Handwritten signature]

ВЯРНО С ОПРИТКАТА




356

Ip=525.46 A
I=200.60 A
Dc=94.72 ms
Izt=6.56 kA²s
Ub=16.53 kV
Cf=0.05
F=50.0 Hz



CESI MP-A5/008453 n.11

$I_p = 287.17 \text{ A}$
 $I = 198.20 \text{ A}$
 $D_c = 409.51 \text{ ms}$
 $I_{zt} = 15.75 \text{ kA}^2\text{s}$
 $U_a = 16.25 \text{ kV}$
 $U_b = 16.53 \text{ kV}$
 $C_f = 0.82$
 $F = 49.9 \text{ Hz}$



29.2 ms/div
 1314 ms

[Handwritten signature]

U
 16.7 kV
[Handwritten signature]

ВЪРНО С ОРНИРАТА




CESI MP-A5/008453 n.12


Handwritten mark

Handwritten mark

ВЯРНО С ОПРИМНАТА



$\Delta t = 23.65 \text{ms}$



2.2ms/div

141ms

130.

108.


86.

64.

42.

CESI MP-A5/008453 n.12

$I_p = 292.20 \text{ A}$
 $I = 198.69 \text{ A}$
 $D_c = 399.95 \text{ ms}$
 $I_{zt} = 15.83 \text{ kA}^2\text{s}$
 $U_a = 16.35 \text{ kV}$
 $U_{\text{max}} = 16.58 \text{ kV}$
 $C_f = 0.77$
 $F = 50.0 \text{ Hz}$



29.2 ms/div
 1314 ms

U 16.7 kV

I 10. kV

I 156. A

ВЯРНО С ОРЖИНАЛАТА



0. 292. 584. 876. 1168. 1314ms
 МР-А5/008453 п.13

[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРИГИНАЛА



398

Dt=29.7ms

sat

2.2ms/div

136ms

103.

81.

59.

37.

U 16.7 kV

U 1. kV

I 156. A

CESI MP-A5/008453 n.13

Handwritten mark


Handwritten signature

ИРЯВНО С ОРВИИНАТА



399

$I_p = 284.87 \text{ A}$
 $I = 196.47 \text{ A}$
 $D_c = 409.66 \text{ ms}$
 $I_{zt} = 15.67 \text{ kA}^2\text{s}$
 $U_a = 16.17 \text{ kV}$
 $U_b = 16.50 \text{ kV}$
 $C_f = 0.82$
 $F = 50.0 \text{ Hz}$




CESI MP-A5/008453 n.14

Handwritten signature


Handwritten signature

ВЯРНО С ОПРИГНАЛАТА



400

Dt=17.1ms



1.9ms/div

122ms

113.

94.


75.

56.

37.

CESI MP-A5/008453 n.14

$I_p = 288.09 \text{ A}$
 $I = 196.96 \text{ A}$
 $DC = 409.13 \text{ ms}$
 $I_{rt} = 15.42 \text{ kA}^2\text{s}$
 $U_a = 16.26 \text{ kV}$
 $U_b = 16.51 \text{ kV}$
 $C_f = 0.79$
 $F = 49.6 \text{ Hz}$



29.2 ns/div
 1314 ns

U 16.7 kV

U 10. kV

I 156. A

0.

292.

584.

876.

1168.

1314ms

[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОПТИМИЗАЦИЯ



MP-A5/008453 п.15

СЕСИ

[Handwritten mark]

V 16.7 kV

[Handwritten signature]

ВЯРНО С ОРМИНАЛАТА


U 1. kV

I 156. A



CEESI MP-A5/008453 n.15

402



Dt=36.56ms

2.5ms/div

147ms

135.


110.

85.

60.

35.

$I_p = 287.62 \text{ A}$
 $I = 197.71 \text{ A}$
 $D_c = 399.85 \text{ ms}$
 $I_{zt} = 15.58 \text{ kA}^2\text{s}$
 $U_a = 16.29 \text{ kV}$
 $U_b = 16.50 \text{ kV}$
 $C_f = 0.81$
 $F = 50.0 \text{ Hz}$



$U_{16.7 \text{ kV}}$
[Signature]

ВЪРХУ С ОПРИГНАЛАТА



CESI MP-A5/008453 n.16

Dt=28.2ms

2.4ms/div

143ms

131.

107.

83.

59.

35.

U
16.7 kV

U
1 kV


I
156. A

ВЯРНО С ОПРИТНАТА



CESI MP-A5/008453 n.16

$I_p = 52.97 \text{ A}$
 $I = 19.72 \text{ A}$
 $D_c = 94.65 \text{ ms}$
 $I_{\Sigma t} = 70.12 \text{ A}^2\text{s}$
 $U_b = 16.73 \text{ kV}$
 $C_f = 0.03$
 $F = 49.9 \text{ Hz}$



U 16.7 kV

U 10. kV

I 15.6 A


ВЯРНО С ОРНИНАТА



СЕСИ МР-А5/008453 п.17



$I_p = 28.55 \text{ A}$
 $I = 19.48 \text{ A}$
 $D_c = 409.36 \text{ ms}$
 $I_{\Sigma t} = 148.17 \text{ A}^2\text{s}$
 $U_a = 16.50 \text{ kV}$
 $U_b = 16.71 \text{ kV}$
 $C_f = 0.78$
 $F = 49.8 \text{ Hz}$



29.2 ms/div
 1314 ms

0. 292. 584. 876. 1168.

U 16.7 kV


U 10. kV

I 15.6 A

ВЪРХО С ОПТИМАЛНАТА



CESI MP-A5/008453 n.18



[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРИГИНАЛАТА



CESI MP-A5/008453 n.18

for

[Handwritten mark]


[Handwritten signature]

ВЯРНО С ОРИГИНАЛАТА



405

Dt = 387.5ns



U 16.7 kV

I 5.6 A

sat

10. ns/div
1311ns

1261.

1161.

1061.

961.

861.

CESI MP-A5/008453 n.20

[Handwritten mark]

[Handwritten signature]

ВЯРНО С ОРИГИНАЛАТА




409

U 13.3 kV

U 10. kV

I 15.6 A


Ip=32.04 A
I=19.64 A
Dc=439.45 ms
I²t=162.64 A²s
Ua=16.56 kV
U₀=16.71 kV
Cf=0.55
F=50.1 Hz



29.2ms/div
1314ms

CESI MP-A5/008453 n.24

| N° modif. | IND. | DESIGNATION | VISA | DATE |
|-----------|------|----------------------------|------|----------|
| | A | création | | |
| 081 | B | modification embout fileté | LD | 04/03/05 |



CESI
 PROTOCOLLO DATA
 A 5/00 9432 n.1 14 MAR. 2005
 Firma: *Levati*

Fournitures conforme avec la spécification Dervasil SP0809
 Fournisseur LAMCO
 terminal material : brass

| N° PLAN | repère | nbre | Désignation | Référence | Matière | Observation |
|-----------------------|--------|------|--|-----------|---------|-------------|
| TOLERANCES GENERALES: | | | TRAITEMENT : <input type="checkbox"/> GALVANISATION A CHAUD SELON SA 0223 <input type="checkbox"/> AUTRE (voir nota) | | | |

DECONNECTEUR

CE DOCUMENT NE PEUT ETRE REPRODUIT OU COMMUNIQUE SANS ACCORD
 ECRIT DE LA SOCIETE DERVASIL

CODE ARTICLE :



dervasil
groupe SICAME

DESSINE PAR : LD

FORMAT :
A6

DATE : 11/01/2005

ECHELLE :
1:1

VERIFIE PAR : CG

PAGE :
1/1

PLAN N° - DRAWING N° - PLANO N°

route de POPENOT - 42800 ST JOSEPH
 tel : 04.77.75.29.98. fax : 04.77.83.22.80.

99B000053B

Handwritten signatures and marks

ВЯРНО С ОПИМЕНАТА

Stamp: "BAK-02" 904
Handwritten signature
 CAPOVOP



dervasil

TECHNICAL SERVICE

TEST REPORT

N° 224

MC 98 002 IND. A

MAJ : 25/03/98

PRODUCT: Lightning Arrester AZBD 42

TESTS CARRIED OUT: BENDING TEST

STANDARD: IEC 60099-4 - § 10.8.9

N° SAMPLES : 0019, 0020, 0021, 0022, 0023,

TEST DATE: 28/10/2008

TEST PLACE:

- DERVASIL Laboratory


TEST PERFORMED BY: M. DZIRI

на основание чл. 2 от ЗЗЛД

CONCLUSION : Lightning Arrester AZBD 420 passed bending test

TECHNICAL DIRECTOR

на основание чл. 2 от ЗЗЛД



1 - Identification of Samples

Lightning arrestes 0019, 0020, 0021, 0022, 0023 are manufactured with :
ZnO blocks lot 7641 Otowa 5 kV
Moulding : HTV Silicone

Height : 360 mm
Leakage distance : 1045 mm
Arcing distance : 365 mm

2 - Test Equipment:

10 kg weights
Dial Torque Wrench 20-100 Nm

3 - Test Procedure

3.1 Mechanical test

Following strengths were applied successively to sample
Cantilever load : 1000 N, corresponding to 350 Nm
Torque Load : 70 Nm.

| Test | Result |
|----------------------------|-------------------------|
| Cantilever load 1000N 1min | No permanent distorsion |
| Torque load 70 Nm | No permanent distorsion |

3.2 Electrical tests


Levels of Partial Discharges have been measured before and after mechanical tests. No variations occurred.



4 - Breaking tests

Sample 0020 was tested until breaking

| Weight (kg) | Cantilever load (Nm) | |
|-------------|----------------------|--------------------|
| 1200 | 420 | RAS |
| 1300 | 450 | RAS |
| 1400 | 490 | RAS |
| 1500 | 520 | RAS |
| 1600 | 560 | RAS |
| 1700 | 590 | RAS |
| 1800 | 630 | RAS |
| 1900 | 660 | Breaking after 20s |



ВЪРНО С ОПИТАНАТА





dervasil

TECHNICAL SERVICE

TEST REPORT

N° 228

MC 98 002 IND. A

MAJ : 25/03/98

PRODUCT: Lightning Arrester AZBD 42

TESTS CARRIED OUT: MOISTURE INGRESS TEST

STANDARD: IEC 60099-4 - § 10.8.13.

N° SAMPLES : 0023

TEST DATE: 19/01/2009 to 23/01/2009


TEST PLACE:

- DERVASIL Laboratory for themomechanical test
- FERRAZ Laboratory for initial and final verification

TEST PERFORMED BY: M. DZIRI

CONCLUSION : Lightning Arrester AZBD 420 passed moisture ingress test

TECHNICAL DIRECTOR





1 - Identification of Samples

Lightning arrester 0023 is manufactured with :

ZnO blocks lot 7641 Otowa 5 kV

Moulding : HTV Silicone

Height : 360 mm

Leakage distance : 1045 mm

Arcing distance : 365 mm

2 - Test Equipment:

10 kg weights

Dial Torque Wrench 20-100 Nm

HV generator

Oven WEISSTECKNIC for thermal cycle




3 - Test Procedure

3.1 Initial measurement

- Measurement of Watt Loss at $U_c = 35$ kV
- Measurement of Discharge Partial level at $1.05 * U_c = 36.75$ kV
- Measurement of residual voltage at 2500 A (8/20 μ s wave)

3.2 Torque preconditionning





Torque Load at 70 Nm has been applied during 30s to sample





3.3 Thermomechanical preconditioning

Sample has been submitted to two 48 h thermal cycles of heating and cooling under mechanical load of 100 kg. Direction of load was changed every 24 h





ВЯРНО С ОПИТИВАНАТА





3.4 Water immersion

Sample has been immersed in a vessel, in boiling deionized water with 1 kg/ of NaCl, for 42h. After end sample remains in water at 50°C.



3.5 Final measurement

- Visual inspection
- Measurement of Watt Loss at $U_c = 35 \text{ kV}$
- Measurement of Discharge Partial level at $1.05 * U_c = 36.75 \text{ kV}$
- Measurement of residual voltage at 2500 A (8/20 μ s wave)

4 - Test Results

| | Before test | | After test | | Variation |
|-------------------------|-------------|---------|------------|---------|-----------|
| Watt loss | 35 kV | 0.692 W | 35 kV | 0.802 W | 15.9% |
| Residual Voltage | 2500 A | 98 kV | 2500 A | 98 kV | 0% |
| Partial discharge level | | < 6pC | | < 6pc | |

Visual inspection after test: no damages

Handwritten signatures and marks.

ВЯРНО С ОПИШИВАТА



client Dervasil - Saint Joseph (France)

equipment under test Polymer housed metal-oxide surge arresters Type AZB 27

tests performed Weather ageing test - Test series A

normative documents IEC Standard 60099-4 Edition 2.0 (2004-05).

receipt date of the sample May 24, 2004

test date from July 8, 2004 to August 24, 2004

no. of pages 22 no. of pages annexed 8

the test results relate only to the sample tested
 this document shall not be reproduced except in full without the written approval of CESI

first issue date May 12, 2005

prepared PeC/TEST - G. Fedeli

на основание чл. 2 от ЗЗЛД

verified PeC/TEST - A. Sironi

approved PeC/TEST - M. de Nigris

CESI
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
 Business Unit

Prova
 Il Responsabile на основание чл. 2 от ЗЗЛД

CESI
 Centro Elettrotecnico
 Sperimentale Italiano
 Giacinto Motta SpA

Via R. Rubattino 54
 20134 Milano - Italia
 Telefono +39 022125.1
 Fax +39 0221255440
 www.cesi.it


Capitale sociale 8.550
 interamente versato
 Codice fiscale e numero
 iscrizione CCIAA 00793590150

Sezione Ordinaria
 N. R.E.A. 429222
 P.I. IT00793590150

ВАРНО С ОРИГИНАЛА



tests witnessed by: /



Identification of the object: Performed

The Manufacturer guarantees that the tested surge arrester is manufactured according to the submitted drawings.

CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawings identified by CESI and numbered A5/021441 no.1 to 10 have been returned to the Client.

The data necessary to permit repetition of the tests are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with impulse current : peak value: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3 \%$
- dielectric tests with direct voltage : voltage: $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

CESI testing team: G. Fedeli

test laboratory: P188

activity code: 41285B

keywords: 12015R 23801L 31020W 44060J 53001D



[Handwritten signature]

| contents | page | test date |
|--|------|----------------------|
| Test object | 4 | |
| Test carried out and test procedure | 8 | |
| Summary of test result | 9 | |
| Initial measurements | 11 | 05/12/04 |
| Weather ageing test. Test circuit | 13 | |
| Weather ageing test. Test arrangement | 14 | |
| Weather ageing test. Pictures after the test | 16 | 07/08/04 to 08/24/04 |
| Final measurements | 21 | 08/30/04 |
| Reference documents annexed: | | |
| Oscillograms (8 pages), CESI no. A4/510342 | | |

[Handwritten signature]

БЪРНО С ОПИТИНАТА



[Handwritten signature]



Test Report

AT-A5/022740

p.3

420

Test object

Type: Two polymer housed metal-oxide surge arrester type AZB 27.
The test objects were identified by Cesi as sample W1 and sample W2.

electrical characteristics (claimed by the client)

| | |
|---|----------------------------------|
| manufacturer's name | DERVASIL - Saint Joseph (France) |
| nominal discharge current - I_N [kA] | 10,0 |
| rated voltage - U_n [kV] | 27,0 |
| continuous operating voltage - U_c [kV] | 22,0 |
| line discharge class | 1 |
| rated frequency - [Hz] | 50 |

Dimensional characteristics of the test objects, claimed by the Client:

| | |
|---------------------|-------|
| total height [mm] | 272,4 |
| sheds diameter [mm] | 119 |
| core diameter [mm] | 59,4 |

[Handwritten signatures]

ВЪРНО С ОПРИЛНАТА



Dimensional characteristics of the test objects measured by Cesi


| | |
|------------------------|------|
| total height [mm] | 270 |
| creepage distance [mm] | 711 |
| arching distance [mm] | 297 |
| number of sheds [n] | 9 |
| sheds diameter [mm] | 116 |
| core diameter [mm] | 59,5 |
| sheds spacing [mm] | 25 |
| sheds projection [mm] | 30 |
| | |
| | |

[Handwritten signatures]

ВЯРНО С ОРИГИНАЛА



Picture of the test object W1




[Handwritten signature]

ВЯРНО С ОПРИЧИНАТА

"BAK - 02" ООД
САМОКОВ

Picture of the test object W2



[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРМЕТРИЈАТА



424

Test carried out and test procedure

Test has been carried out according with IEC Standard 60099-4 (2004-05) edition 2.0 "Metal-oxide surge arrester without gaps for a.c. system", at clause 10.8.14 .

Initial measurement

- The reference voltage have been measured at reference current equal to 5 mA_{pk}
 - Internal partial discharge have been measured.
- The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec. The voltage has been decreased to 1,05 times the continuous operating voltage (U_c) and the partial discharge level has been measured according to the reference standard.

Weather ageing test. Test series A: 1000 hours

Note: During the weather ageing test, the test objects were tested in parallel with a Dervasil insulator.

The test samples have been assembled in the test room in vertical position spaced each-other and from the chamber walls in order to avoid electrical field disturbance.

Test objects have been cleaned with deionized water before starting the test.

The surge arresters have been energized at $U_{test} = 22 \text{ kV}_{rms}$ and kept for a total duration of 1000 hours in the test room filled with salt fog.

The water flow rate was $0,4 \pm 0,1 \text{ l/h} \cdot \text{m}^3$

At the beginning the salinity of the water solution was 10 Kg/m^3 . Then it has been decreased to 5 Kg/m^3 after 591 hours, and to $2,5 \text{ Kg/m}^3$ after 610 hours (see the paragraph "summary of test result").


The salt fog was not directly sprayed against the test specimens.

A scheme and a view of the test configuration are shown at pages 14 and 15.

The test sample has been visually inspected after about 500 hours and at test completion. Photos were taken at the end of the test.

Final measurement

The initial measurement were repeated.



Summary of test result

Test series A: 1000 hours

The external flashovers occurred during the test are noted in table below. The test salinity had to be changed twice.

| sample W1 | sample W2 | test salinity | salinity change |
|---------------------------------------|---------------------------------------|---------------|-------------------|
| 1 st Flashover after 565 h | | 10 g/l | |
| 2 nd Flashover after 591 h | | 10 g/l | from 10 to 5 g/l |
| 3 rd Flashover after 595 h | | 5 g/l | |
| | 1 st Flashover after 610 h | 5 g/l | from 5 to 2,5 g/l |
| | 2 nd Flashover after 976 h | 2,5 g/l | |
| | 3 rd Flashover after 981 h | 2,5 g/l | |

Visual inspection

Note: Sheds are numbered starting from the live side.

- After 500 hours

No tracking, shed puncture or significant erosions have been evidenced by the visual inspection carried out after 500

- After 1000 hours

Sample W1:

An overall view of the object after 1000 hours is shown in the photo at page 16.

No tracking, significant erosion or puncture was observed.

Shallow and diffuse erosions were visible on all circumference of the core between sheds n.2 and n.3 and, in less diffused way, also on the core between sheds n.3 and n.4 (see photo at page 17).



Sample W2:

An overall view of the object after 1000 hours is shown in the photo at page 18.

No tracking, significant erosion or puncture was observed.

Shallow erosions on the cores between sheds n.2-3, sheds n.4-5 and sheds n.6-7 (see photo at page 19).

Shallow and diffuse erosions were visible on all circumference of core between sheds n.8 and n.9 (see photo at page 20).



Variation of the reference voltage

| Type | before test | after test | variation % |
|------|-------------|------------|----------------|
| | kV | kV | |
| W1 | 27,26 | 27,9 | + 2,3 |
| W2 | 28,03 | 28,4 | + 1,3 |

Acceptance criteria: satisfied

Partial discharge level

| Type | before test | after test |
|------|-------------|------------|
| | pC | pC |
| W1 | <1 | <1 |
| W2 | <1 | <1 |

Acceptance criteria: satisfied

Conclusion: the acceptance criteria specified by the standard are satisfied. The test result is positive.

ВЯРНО С ОПИТАНАТА



Measurement of the reference voltage - initial

test object: Polymer housed metal-oxide surge arresters
test circuit: /

date: May 12, 2004

| sample W1 | | | | | | |
|-----------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscill. | voltage | current | current | current | power | 3rd harmonic amplitude |
| no. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 1 | 27,26 | 4,94 | 4,82 | 1,04 | 25,18 | / |

date: May 12, 2004

| sample W2 | | | | | | |
|-----------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscill. | voltage | current | current | current | power | 3rd harmonic amplitude |
| no. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 2 | 28,03 | 3,95 | 5,04 | 1,37 | 23,80 | / |

[Handwritten signature]

ВЯРНО С ОПРАТНАТА



Measurement of partial discharges - initial

test object: Polymer housed metal-oxide surge arresters

test circuit: /

measurement circuit: /

arrangement: —

| atmospheric conditions | | |
|------------------------|----|--------------------|
| b | t | h |
| kPa | °C | g / m ³ |
| / | 24 | / |

date: May 13, 2004

sample W1

| test condition | applied voltage | duration of voltage application | temperature of the test object | voltage increase Q max | voltage decrease Q max | oscillogram | note |
|----------------|-------------------------|---------------------------------|--------------------------------|------------------------|------------------------|-------------|------|
| rated voltage | kV _{rms} 27 | sec 10 | °C 24 | pC / | pC / | no. / | / |
| 22 x 1,05 | 23,1 | / | 24 | / | ≤ 1 | / | / |

sample W2

| test condition | applied voltage | duration of voltage application | temperature of the test object | voltage increase Q max | voltage decrease Q max | oscillogram | note |
|----------------|-------------------------|---------------------------------|--------------------------------|------------------------|------------------------|-------------|------|
| rated voltage | kV _{rms} 27 | sec 10 | °C 24 | pC / | pC / | no. / | / |
| 22 x 1,05 | 23,1 | / | 24 | / | ≤ 1 | / | / |

ВЯРНО С ОПРАТИКАЛА



[Handwritten signature]


CESI TEST
TESTING SERVICES

AT-A5/022740

p.12

Test Report

Weather ageing test.



power frequency test circuit (plant P188)

- R : regulator type M.E.S.A.; power 66 kVA ; output voltage 220 V ; CESI no. 29991
- TA : current reducer ; ratio 150A / 5A
- TV₁ : voltage reducer ; ratio 220V / 100V
- V₁ : direct reading voltmeter
- T : booster transformer PIVI type TMO/230 ; power 50 kVA ; ratio 220 V / 30 kV ;
primary current 227 A ; secondary current 1,67 A ; CESI no. 38675
- TV₂ : voltage reducer CGS type VSO 534 ; CESI no. 287 ; ratio 30/0,1 kV
- V₂ : voltmeter ANALOGIC Type DP100 ; CESI no. 9533

check of the test circuit

date: August 8, 2004


| low voltage | | | | high voltage k = 300 | | k ₁ |
|----------------|-----------------|----------------|-----------------|-------------------------|-----------------|----------------------------------|
| V ₁ | V _{bt} | I ₁ | I _{bt} | V ₂ | V _{AT} | V _{AT} / V ₁ |
| V | V | A | A | V | kV | |
| / | / | / | / | 50,1 | 15,0 | / |
| / | / | / | / | 73,3 | 22,0 | / |
| / | / | / | / | / | / | / |

Handwritten signature

ВЕРНО С ОПРАГМНАТА



Weather ageing test. Test arrangement
Plant: pollution test room planimetry



Test room volume: 360m³

B: bushing

N: spray nozzles. Number of spray nozzles: 4


W1, W2: test objects

ВАРНО С ОПРЕДЕЛЕНАТА



431

Picture of the test arrangement




[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРЪГИНАЛАТА



Picture of the test sample WI after the test



[Handwritten signature]

[Handwritten mark]

[Handwritten mark]


[Handwritten signature]

ВЯРНО С ОПРИГНАЛА

"БАК - 02" ООД
[Signature]
САМОКОВ


433

Picture of the test sample W1 after the test



[Handwritten signature]


ВЪРНО С ОПРИГНАЛАТА



434

[Handwritten signature]

Picture of the test sample W2 after the test




[Handwritten signature]

ВЯРНО С ОРИГИНАЛАТА

ВКР-02 ООД
САМОКОВ
[Handwritten signature]

435

Picture of the test sample W2 after the test



[Handwritten signature]


[Handwritten marks]

ВЯРНО С ОРЪГИНАЛАТА

“ВАН-02” ООД
САМОКОВ
[Handwritten signature]

436

Picture of the test sample W2 after the test



(3)

(2)

[Handwritten signature]

ВЯРНО С ОРГИНАЛАТА



437

Measurement of the reference voltage - Final

test object: Polymer housed metal-oxide surge arresters
test circuit: /

date: August 30, 2004

| sample W1 | | | | | | |
|-----------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscill. | voltage | current | current | current | power | 3rd harmonic amplitude |
| no. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 3 | 27,9 | 4,88 | 5,04 | / | / | / |

date: August 30, 2004

| sample W2 | | | | | | |
|-----------|---------|--------------------|--------------------|-------------------|-------|------------------------|
| oscill. | voltage | current | current | current | power | 3rd harmonic amplitude |
| no. | kV | + mA _{cr} | - mA _{cr} | mA _{rms} | W | μA |
| 4 | 28,4 | 4,32 | 5,04 | / | / | / |

[Handwritten signatures]

ВЯРНО С ОПРЕДЕЛЕНИЕТО



Measurement of partial discharges - Final

test object: Polymer housed metal-oxide surge arresters

test circuit: /

measurement circuit: /

arrangement: ---

| atmospheric conditions | | |
|------------------------|----|--------------------|
| b | t | h |
| kPa | °C | g / m ³ |
| / | 25 | / |

date: August 30, 2004

Sample W1



| test condition | applied voltage | duration of voltage application | temperature of the test object | voltage increase Q _{max} | voltage decrease Q _{max} | oscillogram | note |
|----------------|-----------------|---------------------------------|--------------------------------|-----------------------------------|-----------------------------------|-------------|------|
| rated voltage | 27 | 10 | 25 | / | / | / | / |
| 22 x 1,05 | 23,1 | / | 25 | / | ≤ 1 | 7 | / |

Sample W2

| test condition | applied voltage | duration of voltage application | temperature of the test object | voltage increase Q _{max} | voltage decrease Q _{max} | oscillogram | note |
|----------------|-----------------|---------------------------------|--------------------------------|-----------------------------------|-----------------------------------|-------------|------|
| rated voltage | 27 | 10 | 25 | / | / | / | / |
| 22 x 1,05 | 23,1 | / | 25 | / | ≤ 1 | 8 | / |

Note: background noise ≤ 1 pC, see oscillogram n.5

"direct" calibration: 50 pC - see oscillogram n.6





Test Report

AT-A5/022740

p.22

439

oscillogram no.01





CESI TEST A4510342

ВЯРНО С ОРИГИНАЛА



oscillogram no.02



[Handwritten signature]

CESI TEST A4510342


ВЯРНО С ОПТИКАТА



[Handwritten signature]

[Handwritten mark]


oscillogram no.03



30 Aug 2004


13:52:48

CESI TEST A4510342



442

oscillogram no.04



30 Aug 2004
13:46:22

Handwritten signature


CESI TEST A4510342

ВЯЧНО С ОРНИТНАСТА



003

oscillogram no.05



Handwritten signature


CESI TEST A4510342

ВЯРНО С ОРИГИНАЛА

“BAK-02” ООД
САМОКОВ
ИИЗ

Handwritten signature

oscillogram no.06



Handwritten signature


CESI TEST A4510342

ВЯРНО С ОРИГИНАЛА



Handwritten signature

oscillogram no.07



Handwritten signature


CESI TEST A4510342

ВЯРНО С ОПРИЛНАТА



Handwritten signature

oscillogram no.08



CESI TEST A4510342

ВЯРНО С ОРМИНАЛАТА




**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ВЕНТИЛЕН ОТВОД
ТИП AZBD 270**

1. Изпитване с вътрешно частично разреждане;
2. Изпитание за устойчивост на импулсно атмосферно пренапрежение в сухо състояние;
3. Изпитание с напрежение с промишлена честота във влажно състояние;
4. Изпитание на остатъчно напрежение;
5. Изпитание за устойчивост на дълготраен токов импулс;
6. Изпитание при работен режим с високо-токов импулс;
7. Изпитание с разединител;
8. Изпитание на огъващ момент;
9. Изпитание с проникване на влага;
10. Изпитание с атмосферно стареене.

Съставил:

на основание чл. 2 от ЗЗЛД

САМОКОВ



ИИТ



CERTIFICATO DI ACCREDITAMENTO

Accreditation Certificate

Accreditamento n° **0030**
Accreditation n°

Rev. **2**

Si dichiara che
We declare that

CESI S.p.A.
Sede/Headquarters:
Via Rubattino 54 - 20134 Milano MI

è conforme ai requisiti della norma
meets the requirements of the standard

UNI CEI EN ISO/IEC 17025:2005 "Requisiti generali per la competenza dei Laboratori di prova e taratura"
EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing and Calibration Laboratories" standard

quale **Laboratorio di Prova**
as **Testing Laboratory**

L'accREDITAMENTO attesta la competenza tecnica del Laboratorio relativamente allo scopo riportato nelle schede allegate al presente certificato. Le schede possono variare nel tempo. I requisiti gestionali della ISO/IEC 17025:2005 (sezione 4) sono scritti in un linguaggio idoneo all'attività dei Laboratori di Prova, sono conformi ai principi della ISO 9001:2008 ed allineati con i suoi requisiti applicabili. Il presente certificato non è da ritenersi valido se non accompagnato dalle schede allegate e può essere sospeso o revocato in qualsiasi momento nel caso di inadempienza accertata da parte di ACCREDIA. La vigenza dell'accREDITAMENTO può essere verificata sul sito WEB (www.accredia.it) o richiesta direttamente ai singoli Dipartimenti.

The accreditation certifies the technical competence of the laboratory limited to the scope detailed in the attached Enclosure. The scope may vary in the time. The management system requirements in ISO/IEC 17025:2005 (Section 4) are written in a language relevant to Testing Laboratories operations and meet the principles of ISO 9001:2008 and are aligned with its pertinent requirements. The present certificate is valid only if associated to the annexed schedule, and can be suspended or withdrawn at any time in the event of non fulfilment as ascertained by ACCREDIA. The in force status of the accreditation may be checked in the WEB site (www.accredia.it) or on direct request to appointed Department.

Data di 1ª emissione
1st issue date
1992-02-27

Data di modifica
Modification date
2016-04-14

Data di scadenza
Expiring date
2020-03-09

на основание чл. 2 от ЗЗЛД


на основание чл. 2 от ЗЗЛД

на основание чл. 2 от ЗЗЛД

The General Director
(Dr. Filippo Trifiletti)

(Dr.ssa Silvia Tramontin)

The President
(Ing. Giuseppe Rossi)





CERTIFICATO DI ACCREDITAMENTO *Accreditation Certificate*

Accreditamento n°
Accreditation n°

0030

Rev. **2**

Si dichiara che
We declare that

Sedi operative:

CESI S.p.A.
Via Rubattino 54
20134 Milano MI
CESI S.p.A. - Sede di Piacenza
Via Nino Bixio 39
29100 Piacenza PC
CESI S.p.A. - Sede di Seriate
Via Pastrengo 9
24068 Seriate BG

Mod CA-01 rev. 01

ВЪРНО С ОПРИЛНАТА

Pag. 2 di 2

ACCREDIA

Sede operativa e legale: Via Guglielmo Saliceto, 7/9 | 00161 Roma - Italy | Tel. +39 06 8440991 | Fax +39 06 8841199
info@accredia.it | www.accredia.it | Partita IVA - Codice Fiscale 10566361001



449

СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ

Регистрационен № 0030 ред. 2

Ние декларираме, че **CESI S.p.A.**
Via Rubattino, 54 20134 - MILANO (MI)

Отговаря на изискванията на стандарта
EN ISO/IEC 17025:2005 Общи изисквания относно компетентността на
лабораториите за изпитване и калибриране

като **Изпитваща лаборатория**

Акредитацията удостоверява техническата компетентност на лабораторията ограничена до данните за обхват в прикачените приложения. Обхватът може да търпи промени във времето. Изискванията на системата за управление съгласно *ISO/IEC 17025:2005* (Секция 4) са написани на език, подходящи за употреба от Изпитващите лаборатории и отговарят на принципите на *ISO 9001:2008* и са приведени в съответствие изисквания му. Настоящото удостоверение е валидно само, ако е придружено с приложените допълнения и може да бъде спряно или оттеглено по всяко време, в случай на неизпълнение, както е установено от ACCREDIA. Статута на акредитацията може да се провери на интернет страницата (www.accredia.it) или с директно запитване към съответния отдел.

1-ва дата на издаване
1992-02-27

Дата на промяна
2016-04-14

Дата на изтичане
2020-03-09

Генерален Директор

Директор
Дирекция

Президент

на основание чл. 2 от ЗЗЛД





NÁRODNÍ AKREDITAČNÍ ORGÁN

EA MLA Signatory
Český institut pro akreditaci, o.p.s.
Olšanská 54/3, 130 00 Praha 3

issues

according to section 16 of Act No. 22/1997 Coll., on technical requirements for products, as amended

CERTIFICATE OF ACCREDITATION

No. 156 / 2016

EGU - HV Laboratory a.s.
with registered office Podnikatelská 267, 190 11 Praha, Běchovice, Company Registration
No. 25634330

to the Testing Laboratory No. 1029
High voltage testing laboratory

Scope of accreditation:

High-voltage tests, measurement of high-frequency interference, voltage and dielectric tests of electric objects and equipment and mechanical tests of insulators to the extent as specified in the appendix to this Certificate.

This Certificate of Accreditation is a proof of Accreditation issued on the basis of assessment of fulfillment of the accreditation criteria in accordance with

ČSN EN ISO/IEC 17025:2005

In its activities performed within the scope and for the period of validity of this Certificate, the Body is entitled to refer to this Certificate, provided that the accreditation is not suspended and the Body meets the specified accreditation requirements in accordance with the relevant regulations applicable to the activity of an accredited Conformity Assessment Body.

This Certificate of Accreditation replaces, to the full extent, Certificate No.: 370/2015 of 26 May 2015, or any administrative acts building upon it.


The Certificate of Accreditation is valid until: **14 March 2021**

Prague: 14 March 2016

на основании чл. 2 от 33ЛД



Jiří Růžička
Director
Czech Accreditation Institute
Public Service Company



**НАЦИОНАЛЕН ОРГАН ПО
АКРЕДИТАЦИЯ**

Подпис EA MLA
Чешки Институт по акредитация
Olšanská 54/3, 130 00 Прага 3

Сертификат за акредитация

Номер 156/2016

EGU – Лаборатория В.Н a.s.
със седалище Podnikatelska 267,190 11 Praha 9, Běchovice, ID No. 25634330

за тестова лаборатория номер. 1029
Лаборатория за изпитвания високо напрежение

Обхват на акредитацията:

Изпитвания високо напрежение, измерване на радио-интерференция, напреженови и диелектрични изпитвания на електрически изделия и оборудване и механични тестове на изолятори до степен, посочена в приложението към този сертификат.

Този сертификат за акредитация е доказателство за акредитация издаден, въз основа на покриване на критериите за акредитация в съответствие с

ČSN EN ISO/IEC 17025:2005

В дейностите си, изпълнявани в рамките на обхвата и за периода на валидност на настоящия сертификат, притежателя на настоящия сертификат има право да се позовава на този сертификат, при условие че акредитацията не е преустановена и притежателя отговаря на специфичните акредитационни условия, в съответствие със съответните регламенти, приложими за дейността на акредитирания орган за оценка на съответствието.

Сертификатът за акредитация заменя, в пълна степен, Сертификат с номер 370/2015 от 26 май 2015 г., или някакви административни актове създадени за него.

Сертификатът е валиден до **14 Март 2021**

Прага, 14 Март 2016

ЗАЩИТЕН ПЕ на основание чл. 2 от ЗЗЛД

И

А

Чешки институт за акредитация, (Czech
Accreditation Institute, p.s.c.)

на основание чл. 2 от ЗЗЛД






Operating, storage and installation instructions Lightning Arresters AZC --0

DERVASIL offers a range of latest generation lightning arresters with silicone rubber housing and metal oxide varistors. :

- 10 kA Lightning arresters Class 2

These arresters do not have internal spark gaps. They exhibit stable characteristics, with practically constant, very short response times (30 to 50 ns).

Direct injection of silicone rubber over the internal varistors ensures both absolute sealing, excellent behaviour without explosion in case of short-circuit. They have been tested in accordance with last version of IEC standard 60099-4.



MOUNTING GUIDE

9950003104

DERVASIL


INSTRUCTION DE MONTAGE AZC . . . 0
MOUNTING GUIDE AZC . . . 0

| | | |
|-----|--|---|
| 5 | High Pressure / stainless steel | 2 |
| 4 | Wash cap / cap with rubber O-ring seal | 2 |
| 3 | Wash cap / Washer | 2 |
| 2 | Wash cap / Washer | 2 |
| 1 | Wash cap / Washer | 2 |
| Exp | Exp. gasket | 2 |

Section de câble avec cap e pour la connexion
25 / 145 mm²
Агрегатная секция с кабелем для соединения
25 / 145 мм²

NEED TO BE TIGHT

DERVASIL - Paris de France - 42000 St-Jouin - FRANCE - Tel. : +33 (0) 77 83 22 11 - Fax. : +33 (0) 77 83 22 80





Operating, storage and installation instructions Lightning Arresters AZC --0

PACKING

Lightning arresters are packed in stable cardboard boxes. Each cardboard box contains:

- 3 lightning arresters fitted with threaded studs.
- 3 plastic bags with nuts and washes
- 1 mounting guide


TRANSPORT AND STORAGE

Secure lightning arresters against crushing, falling or sliding during transport and storage
Respect safety precautions for proper handling during transport and storage
Store lightning arresters in their cardboard box and in clean and ventilated room

INSPECTION

After opening of boxes, check:

- Lightning arrester marking must correspond to the bought product
- Presence of all components according to this guide
- Cleanness of threaded rods to avoid any seizing during installation of lightning arrester
- Cleanness of external silicone housing which must be without cuts or holes.





**Operating, storage and installation instructions
Lightning Arresters AZC --0**

RECOMMENDATIONS AND MAINTENANCE

PERSONNEL IN CHARGE OF INSTALLATION MUST BE PROFESSIONAL AND SAFE WORKING TRAINED.

ONLY PERSONNEL WHO HAVE UNDERSTOOD OPERATING AND INSTALLATION INSTRUCTIONS MAY BE ALLOWED TO MOUNT LIGHTNING ARRESTERS

AVOID ANY USE OF SHARP TOOLS WHICH COULD DAMAGE LIGHTNING ARRESTER HOUSING, NOTABLY DURING BOX OPENING.

MINIMUM CLEARANCE DISTANCE BETWEEN ARRESTERS AND BETWEEN ARRESTERS AND EARTH ARE SPECIFIED ON THE TABLE PAGE 1. THESE DISTANCES MUST BE USED FOR LIGHTNING ARRESTER MOUNTING.

FOR LIGHTNING ARRESTER TYPR AZB _ _ 2, CONNECT ALWAYS DISCONNECTOR TO THE EARTH WITH FLEXIBLE CABLE TO AVOID BLOCKAGE OF DISCONNECTOR OPERATING.

TO CONNECT AND TO MOUNT LIGHTNING ARRESTER, DO NOT EXCEED SPECIFIED TORQUE.

AFTER LIGHTNING ARRESTER INSTALLATION, CLEAN SILICONE HOUSING WITH SOFT AND CLEAN CLOTH.

**LIGHTNING ARRESTERS INSTALLED ACCORDING TO THIS GUIDE DO NOT REQUIRE ANY PREVENTIVE MAINTENANCE.
REPLACE LIGHTNING ARRESTERS IF FAULT INDICATOR OR DISCONNECTOR OPERATE OR AFTER FLASHOVER.**

ENVIRONMENT ASPECT

The lightning arresters DERVASIL do not contain any dangerous material for environment. After use they must be destroyed in an approved center.







Operating, storage and installation instructions Lightning Arresters AZC --0


INSTALLATION EXAMPLE

Always mount lightning arresters as close as possible to the apparatuses to be protected

TRANSFORMER PROTECTION



CABLE PROTECTION



DERVASIL Route de Popenot 42800 Saint Joseph FRANCE
 Téléphone : +33 (0)4 77 83 22 81 – Fax : +33 (0)4 77 83 22 80
 Email : info@dervasil.com
 Web : www.dervasil.com

This documentation is not as per agreement.
 DERVASIL reserves the right to modify without prior notice.
 Non-contractuel pictures and drawings

ВЯРНО С ОПРИГАНАЛТА






Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZC --0

DERVASIL предлага диапазон от най-последно поколение вентилни отводи със силиконов гумен корпус и металооксидни варистори. :

- 10 kA Вентилни отводи Клас 2

Тези вентилни отводи нямат вътрешни искрови междини. Те показват стабилни характеристики с частична константа, много кратки времена за реакция (30 до 50 ns). Пряко инжектиране на силиконова гума над вътрешните варистори гарантира абсолютно уплътняване, отлично поведение без експлозия при късо съединение. Тествани са в съответствие с последната версия на IEC стандарта 60099-4.



РЪКОВОДСТВО ЗА МОНТАЖ

1655003-04 DERVASIL

Composant de protection pour les réseaux d'énergie électrique

INSTRUCTION DE MONTAGE AZC -- 0
MOUNTING GUIDE AZC -- 0

021001 10
25 An plus

| | | |
|---|---|---|
| 5 | câble isolé en PVC (isolé en PVC) | 2 |
| 2 | Support isolant et câble en aluminium (Support isolant) | 2 |
| 3 | Headset à ressort | 2 |
| 2 | Boîte AZC | 1 |
| 1 | Capot, 2 pièces | 2 |
| 4 | Dispositif de montage | 2 |


021001 10
25 An plus

Parti en de câble adhésif à utiliser pour la connexion
25 / 140 mm²
Acceptable section of cable for connection
25 / 140 mm²

021001 10
25 An plus

DERVASIL - Point de contact - C/da de Jozeph - 120000 - Tel. : +359 (0) 71 82 22 81 - Fax. : +359 (0) 71 82 22 80





Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZC --0

ОПАКОВКА

Вентилните отводи са опаковани в стабилни картонени кутии. Всяка картонена кутия съдържа:

- 3 вентилни отвода закрепени с резбовани щифтове.
- 3 пластмасови чувала с гайки и шайби
- 1 ръководство за монтаж

ТРАНСПОРТИРАНЕ И СЪХРАНЕНИЕ НА СКЛАД

Да се защитят вентилните отводи срещу удар, падане или плъзгане по време на транспортиране и съхранение

Спазвайте предпазните мерки за безопасност за подходящи манипулации по време на транспортирането и съхранението

Съхраняване на вентилните отводи в техните картонени кутии и в чисто и проветрено помещение.

ИНСПЕКЦИЯ

След отваряне на кутиите, проверете:

- Маркировката на вентилните отводи трябва да съответства на закупения продукт
- Наличието на всички компоненти съгласно това ръководство
- Почистването на резбованите щанги за избягване на всякакво заяждане по време на монтажа на вентилните отводи
- Почистване на външния силиконов корпус, който трябва да бъде без нарязвания или отвори.





Инструкции за експлоатация, монтаж, обслужване
и съхранение на склад
Вентилни отводи AZC --0

ПРЕПОРЪКИ И ПОДДРЪЖКА

ПЕРСОНАЛЪТ, ОТГОВОРЕН ЗА МОНТАЖА, ТРЯБВА ДА БЪДЕ ПРОФЕСИОНАЛЕН И ОБУЧЕН ЗА БЕЗОПАСНА РАБОТА. САМО ПЕРСОНАЛ, КОЙТО Е РАЗБРАЛ ИНСТРУКЦИИТЕ ЗА ЕКСПЛОАТАЦИЯ И МОНТАЖ, МОЖЕ ДА МОНТИРА ВЕНТИЛНИ ОТВОДИ

ДА СЕ ИЗБЯГВА ИЗПОЛЗВАНЕТО НА ОСТРИ ИНСТРУМЕНТИ, КОИТО МОГАТ ДА ПОВРЕДЯТ КОРПУСА НА ВЕНТИЛНИТЕ ОТВОДИ, ОСОБЕНО ПО ВРЕМЕ НА ОТВАРЯНЕ НА КУТИЯТА.

МИНИМАЛНАТА МЕЖДИНА МЕЖДУ ВЕНТИЛНИТЕ ОТВОДИ И МЕЖДУ ВЕНТИЛНИТЕ ОТВОДИ И ЗАЗЕМЯВАНЕТО Е ОПРЕДЕЛЕНА НА ТАБЛИЦАТА НА СТРАНИЦА 1. ТЕЗИ РАЗСТОЯНИЯ ТРЯБВА ДА СЕ ИЗПОЛЗВАТ ЗА МОНТАЖ НА ВЕНТИЛНИТЕ ОТВОДИ.

ЗА ВЕНТИЛНО ОТВОДИ ТИП AZC __ 2, ВИНАГИ СВЪРЗВАЙТЕ РАЗЕДИНИТЕЛЯ КЪМ ЗЕМЯ С ГЪВКАВ КАБЕЛ, ЗА ДА ИЗБЕГНЕТЕ БЛОКИРАНЕТО НА РАБОТАТА НА РАЗЕДИНИТЕЛЯ.

ЗА СВЪРЗВАНЕ И МОНТАЖ НА ВЕНТИЛНИ ОТВОДИ ДА НЕ СЕ ПРЕВИШАВА ОПРЕДЕЛЕНИЯ ВЪРТЯЩ МОМЕНТ.

СЛЕД МОНТАЖА НА ВЕНТИЛНИТЕ ОТВОДИ, ПОЧИСТЕТЕ СИЛИКОНОВИЯ КОРПУС С МЕКА И ЧИСТА КЪРПА.

ВЕНТИЛНИТЕ ОТВОДИ, КОИТО СА МОНТИРАНИ СЪГЛАСНО ТОВА РЪКОВОДСТВО, НЕ ИЗИСКВАТ НИКАКВО ПРОФИЛАКТИЧНО ТЕХНИЧЕСКО ОБСЛУЖВАНЕ. ЗАМЕНЕТЕ ВЕНТИЛНИТЕ ОТВОДИ, АКО Е ПОВРЕДЕН ИНДИКАТОРЪТ ИЛИ РАЗЕДИНИТЕЛЯТ РАБОТИ ИЛИ СЛЕД ПРЕМОСТВАНЕ

ЕКОЛОГИЧЕН АСПЕКТ

Вентилните отводи DERVASIL не съдържат никакви материали, опасни за околната среда. След използване те трябва да бъдат разрушени в одобрен център.






Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZC --0

ПРИМЕР ЗА МОНТАЖ


Винаги монтирайте вентилните отводи колкото е възможно по-близо до оборудването, за да бъде то защитено

ЗАЩИТА НА ТРАНСФОРМАТОРА

Вертикално положение на казана на трансформатора




Хоризонтално положение



КАБЕЛНА ЗАЩИТА

Хоризонтално положение



DERVASIL Route de Popenot 42800 Saint Joseph FRANCE
Téléphone : +33 (0)4 77 83 22 81 – Fax : +33 (0)4 77 83 22 80
Email : info@dervasil.com
Web : www.dervasil.com

Тази документация не се издава по взаимно съгласие.
DERVASIL си запазва правото на промени без
предварително уведомление.
Не съдържа снимки и чертежи по договор





Operating, storage and installation instructions Lightning Arresters AZBD- - - 0


storage

DERVASIL offers a range of latest generation lightning arresters with silicone rubber housing and metal oxide varistors. :


- 10 kA Lightning arresters Class 1

These arresters do not have internal spark gaps. They exhibit stable characteristics, with practically constant, very short response times (30 to 50 ns).

Direct injection of silicone rubber over the internal varistors ensures both absolute sealing, excellent behaviour without explosion in case of short-circuit. They have been tested in accordance with last version of IEC standard 60099-4.



MOUNTING GUIDE



ВЯРНО С ОПИТИНАТА





Operating, storage and installation instructions Lightning Arresters AZBD- - - 0

PACKING

Lightning arresters are packed in stable cardboard boxes. Each cardboard box contains:

- 3 lightning arresters fitted with threaded studs.
- 3 plastic bags with nuts and washes
- 1 mounting guide



TRANSPORT AND STORAGE

Secure lightning arresters against crushing, falling or sliding during transport and storage
Respect safety precautions for proper handling during transport and storage
Store lightning arresters in their cardboard box and in clean and ventilated room

INSPECTION

After opening of boxes, check:

- Lightning arrester marking must correspond to the bought product
- Presence of all components according to this guide
- Cleanness of threaded rods to avoid any seizing during installation of lightning arrester
- Cleanness of external silicone housing which must be without cuts or holes.





Operating, storage and installation instructions
Lightning Arresters AZBD- - - 0

RECOMMENDATIONS AND MAINTENANCE

PERSONNEL IN CHARGE OF INSTALLATION MUST BE PROFESSIONAL AND SAFE WORKING TRAINED.
ONLY PERSONNEL WHO HAVE UNDERSTOOD OPERATING AND INSTALLATION INSTRUCTIONS MAY BE ALLOWED TO MOUNT LIGHTNING ARRESTERS

AVOID ANY USE OF SHARP TOOLS WHICH COULD DAMAGE LIGHTNING ARRESTER HOUSING, NOTABLY DURING BOX OPENING.

MINIMUM CLEARANCE DISTANCE BETWEEN ARRESTERS AND BETWEEN ARRESTERS AND EARTH ARE SPECIFIED ON THE TABLE PAGE 1. THESE DISTANCES MUST BE USED FOR LIGHTNING ARRESTER MOUNTING.

FOR LIGHTNING ARRESTER TYPR AZB __ 2, CONNECT ALWAYS DISCONNECTOR TO THE EARTH WITH FLEXIBLE CABLE TO AVOID BLOCKAGE OF DISCONNECTOR OPERATING.


TO CONNECT AND TO MOUNT LIGHTNING ARRESTER, DO NOT EXCEED SPECIFIED TORQUE.

AFTER LIGHTNING ARRESTER INSTALLATION, CLEAN SILICONE HOUSING WITH SOFT AND CLEAN CLOTH.

LIGHTNING ARRESTERS INSTALLED ACCORDING TO THIS GUIDE DO NOT REQUIRE ANY PREVENTIVE MAINTENANCE.
REPLACE LIGHTNING ARRESTERS IF FAULT INDICATOR OR DISCONNECTOR OPERATE OR AFTER FLASHOVER.

ENVIRONMENT ASPECT

The lightning arresters DERVASIL do not contain any dangerous material for environment. After use they must be destroyed in an approved center.







Operating, storage and installation instructions Lightning Arresters AZBD- - - 0


INSTALLATION EXAMPLE

Always mount lightning arresters as close as possible to the apparatuses to be protected

TRANSFORMER PROTECTION



CABLE PROTECTION



DERVASIL Route de Popenot 42800 Saint Joseph FRANCE
Téléphone : +33 (0)4 77 83 22 81 – Fax : +33 (0)4 77 83 22 80
Email : info@dervasil.com
Web : www.dervasil.com

This documentation is not as per agreement.
DERVASIL reserves the right to modify without prior notice.
Non-contractuel pictures and drawings

ВРЪЗНО С ОПИТИАНАТА



464




Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZBD— 0

DERVASIL предлага диапазон от най-последно поколение вентилни отводи със силиконов гумен корпус и металооксидни варистори.


- 10 kA Вентилни отводи Клас 1

Тези вентилни отводи нямат вътрешни искрови междини. Те показват стабилни характеристики с частична константа, много кратки времена за реакция (30 до 50 ns).

Пряко инжектиране на силиконова гума над вътрешните варистори гарантира абсолютно уплътняване, отлично поведение без експлозия при късо съединение. Тествани са в съответствие с последната версия на IEC стандарта 60099-4



РЪКОВОДСТВО ЗА МОНТАЖ





Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZBD— 0

ОПАКОВКА

Вентилните отводи са опаковани в стабилни картонени кутии. Всяка картонена кутия съдържа:

- 3 вентилни отвода, закрепени с резбовани щифтове.
- 3 найлонови торби с гайки и шайби
- 1 инструкция за монтаж


ТРАНСПОРТИРАНЕ И СЪХРАНЕНИЕ НА СКЛАД


Да се защитят вентилните отводи срещу удар, падане или плъзгане по време на транспортиране и съхранение. Спазвайте предпазните мерки за безопасност за подходящи манипулации по време на транспортирането и съхранението. Съхранявайте вентилните отводи в техните картонени кутии и в чисто и проветрено помещение.

ИНСПЕКЦИЯ

След отваряне на кутиите, проверете:

- Маркировката на вентилните отводи трябва да съответства на закупения продукт
- Наличието на всички компоненти съгласно това ръководство
- Почистване на резбованите щанги за избягване на всякакво замядане по време на монтажа на вентилните отводи
- Почистване на външния силиконов корпус, който трябва да бъде без нарязвания или отвори.





Инструкции за експлоатация, монтаж, обслужване
и съхранение на склад
Вентилни отводи AZBD— 0

ПРЕПОРЪКИ И ПОДДРЪЖКА

ПЕРСОНАЛЪТ, ОТГОВОРЕН ЗА МОНТАЖА, ТРЯБВА ДА БЪДЕ ПРОФЕСИОНАЛЕН И ОБУЧЕН ЗА БЕЗОПАСНА РАБОТА. САМО ПЕРСОНАЛ, КОЙТО Е РАЗБРАЛ ИНСТРУКЦИИТЕ ЗА ЕКСПЛОАТАЦИЯ И МОНТАЖ, МОЖЕ ДА МОНТИРА ВЕНТИЛНИ ОТВОДИ

ДА СЕ ИЗБЯГВА ИЗПОЛЗВАНЕТО НА ОСТРИ ИНСТРУМЕНТИ, КОИТО МОГАТ ДА ПОВРЕДЯТ КОРПУСА НА ВЕНТИЛНИТЕ ОТВОДИ, ОСОБЕНО ПО ВРЕМЕ НА ОТВАРЯНЕ НА КУТИЯТА.

МИНИМАЛНАТА МЕЖДИНА МЕЖДУ ВЕНТИЛНИТЕ ОТВОДИ И МЕЖДУ ВЕНТИЛНИТЕ ОТВОДИ И ЗАЗЕМЯВАНЕТО Е ОПРЕДЕЛЕНА НА ТАБЛИЦАТА НА СТРАНИЦА 1. ТЕЗИ РАЗСТОЯНИЯ ТРЯБВА ДА СЕ ИЗПОЛЗВАТ ЗА МОНТАЖ НА ВЕНТИЛНИТЕ ОТВОДИ.

ЗА ВЕНТИЛНО ОТВОДИ ТИП AZB __ 2, ВИНАГИ СВЪРЗВАЙТЕ РАЗЕДИНИТЕЛЯ КЪМ ЗЕМЯ С ГЪВКАВ КАБЕЛ, ЗА ДА ИЗБЕГНЕТЕ БЛОКИРАНЕТО НА РАБОТАТА НА РАЗЕДИНИТЕЛЯ.


ЗА СВЪРЗВАНЕ И МОНТАЖ НА ВЕНТИЛНИ ОТВОДИ ДА НЕ СЕ ПРЕВИШАВА ОПРЕДЕЛЕНИЯ ВЪРТЯЩ МОМЕНТ.

СЛЕД МОНТАЖА НА ВЕНТИЛНИТЕ ОТВОДИ, ПОЧИСТЕТЕ СИЛИКОНОВИЯ КОРПУС С МЕКА И ЧИСТА КЪРПА.

ВЕНТИЛНИТЕ ОТВОДИ, КОИТО СА МОНТИРАНИ СЪГЛАСНО ТОВА РЪКОВОДСТВО, НЕ ИЗИСКВАТ НИКАКВО ПРОФИЛАКТИЧНО ТЕХНИЧЕСКО ОБСЛУЖВАНЕ. ЗАМЕНЕТЕ ВЕНТИЛНИТЕ ОТВОДИ, АКО Е ПОВРЕДЕН ИНДИКАТОРЪТ ИЛИ РАЗЕДИНИТЕЛЯТ РАБОТИ ИЛИ СЛЕД ПРЕМОСТВАНЕ

ЕКОЛОГИЧЕН АСПЕКТ

Вентилните отводи DERVASIL не съдържат никакви материали, опасни за околната среда. След използване те трябва да бъдат разрушени в одобрен център.






Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZBD— 0

ПРИМЕР ЗА МОНТАЖ


Винаги монтирайте вентилните отводи колкото е възможно по-близо до оборудването, за да бъде то защитено

ЗАЩИТА НА ТРАНСФОРМАТОРА

Вертикално положение на казана на трансформатора




Хоризонтално положение



КАБЕЛНА ЗАЩИТА

Хоризонтално положени



DERVASIL Route de Popenot 42800 Saint Joseph FRANCE
Téléphone : +33 (0)4 77 83 22 81 - Fax : +33 (0)4 77 83 22 80
Email : info@dervasil.com Web : www.dervasil.com

Тази документация не се издава по взаимно съгласие.


DERVASIL си запазва правото на промени без предварително уведомление.
Не съдържа снимки и чертежи по договор





QUALITY DEPART.

| | |
|---|-------------------|
| SPECIFICATION OF PURCHASE PACKING CARDBOARD BOX AND PALLET | SP Indice A |
| | DATE : 09/06/2005 |
| | PAGE : 1 / 5 |



MATERIAL: Cardboard
TC 900 thickness 14.4 mm

WEIGHT: 11 kg

RECYCLABLE :
Standard EN13430

Max Charge :400 kg

LIST OF UPDATE

| Revision | Date | Description of modifications |
|----------|----------|-------------------------------|
| A | 12/09/00 | Creation of the specification |

This document is an element of the knowledge of the company, and for this reason it can not be distributed to the outside

| | Date | Function | Name | |
|--------------|------------|----------|-----------|----------------------------|
| Writing | 09/06/2005 | R & D | DUSSOL L | на основание чл. 2 от ЗЗЛД |
| Verification | 09/06/2005 | Purchase | MOUNIER S | на основание чл. 2 от ЗЗЛД |
| Approval | 09/06/2005 | Director | GAZZOLA C | |


ВЯРНО С ОРИГИНАЛАТА





QUALITY DEPART.

| | |
|---|-------------------|
| SPECIFICATION OF PURCHASE PACKING CARDBOARD BOX AND PALLET | SP Indice A |
| | DATE : 09/06/2005 |
| | PAGE : 2 / 5 |




ВЪРНО С ОРЪГИНАЛАТА



QUALITY DEPART.

| | |
|---|-------------------|
| SPECIFICATION OF PURCHASE PACKING CARDBOARD BOX AND PALLET | SP Indice A |
| | DATE : 09/06/2005 |
| | PAGE : 3 / 5 |



MATERIAL: Cardboard TC 700
thickness 14.6 mm - 9 PLOTS

HEIGHT : 140 mm

WEIGHT: 2 kg

RECYCLABLE : Standard EN13430

Max Charge : 600 kg

PALLET

ВЪРХО С ОПИТИНАТА





431



QUALITY DEPART.

| | |
|----------------------------------|-------------------|
| SPECIFICATION OF PURCHASE | SP Indice A |
| PACKING CARDBOARD BOX AND PALLET | DATE : 09/06/2005 |
| | PAGE : 4 / 5 |



[Handwritten signature]

ВЯРЧО С СЕРВИСАТА




412



QUALITY DEPART.

| | |
|---|-------------------|
| SPECIFICATION OF PURCHASE PACKING CARDBOARD BOX AND PALLET | SP Indice A |
| | DATE : 09/06/2005 |
| | PAGE : 5 / 5 |

STEEL STRAPPING



[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРЪДИЛАТА




413



ОТДЕЛ ПО КАЧЕСТВОТО

| | |
|---|------------------|
| СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ | SP Indice A |
| | ДАТА: 09/06/2005 |
| | СТРАНИЦА: 1 / 5 |



МАТЕРИАЛ: Картон
ТС 900 дебелина 14.4 mm
ТЕГЛО: 11 kg
ГОДНИ ЗА РЕЦИКЛИРАНЕ :
Стандарт EN13430
Максимално зареждане: 400 kg

СПИСЪК НА АКТУАЛИЗАЦИИТЕ

| Редакция | Дата | Описание на промените |
|----------|----------|---------------------------|
| A | 12/09/00 | Изготвяне на спецификация |

Този документ е елемент от ноу-хау на компанията и поради тази причина той не може да бъде разпространяван извън нея

| | Дата | Функция | Име | Подпис |
|-------------|------------|----------|-----------|----------------------------|
| Вписване | 09/06/2005 | R & D | DUSSOL L | на основание чл. 2 от ЗЗЛД |
| Верификация | 09/06/2005 | Покупка | MOUNIER S | |
| Одобрил | 09/06/2005 | Директор | GAZZOLA C | на основание чл. 2 от ЗЗЛД |



на основание чл. 2 от ЗЗЛД





ОТДЕЛ ПО КАЧЕСТВОТО

| | |
|---|------------------|
| СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ | SP Indice A |
| | ДАТА: 09/06/2005 |
| | СТРАНИЦА: 2 / 5 |






dervasil

ОТДЕЛ ПО КАЧЕСТВОТО

| | |
|---|------------------|
| СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ | SP Indice A |
| | ДАТА: 09/06/2005 |
| | СТРАНИЦА: 3 / 5 |



МАТЕРИАЛ: Картон ТС 700
дебелина 14.6 mm - 9 PLOTS

ВИСОЧИНА : 140 mm

ТЕГЛО: 2 kg

ПОДЛЕЖИ НА РЕЦИКЛИРАНЕ :
Стандарт EN13430

Максимален заряд :600 kg

ПАЛЕТ







dervasil

ОТДЕЛ ПО КАЧЕСТВОТО

| | |
|---|------------------|
| СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ | SP Indice A |
| | ДАТА: 09/06/2005 |
| | СТРАНИЦА: 4 / 5 |



[Handwritten signature]

[Handwritten signature]



477




dervasil

ОТДЕЛ ПО КАЧЕСТВОТО

| | |
|---|------------------|
| СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ | SP Indice A |
| | ДАТА: 09/06/2005 |
| | СТРАНИЦА: 5 / 5 |

СТОМАНЕНА ЛЕНТА



[Handwritten signatures]





dervasil

groupe sicame

SAS au capital de 907 190 €

COMPOSANTS DE PROTECTION POUR LES RESEAUX D'ENERGIE ELECTRIQUE

Direction - Services commerciaux - Usine
Route de Popenot
42800 SAINT JOSEPH

Tél. (33) 04 77 75 29 98
Fax (33) 04 77 83 22 80
E-mail : info@dervasil.com

V/REF

N/REF.

Certificate

EMETTEUR

To whom it may concerns

We undersign, DERVASIL S.A.S, subsidiary of SICAME S.A, French manufacturer for hardware and accessories for electrical lines and network since 1955 with headquarters located at 19230 POMPADOUR CEDEX / France represented by Stéphane Pradella, Area manager, certify that :

The Medium Voltage Lightning Arresters manufactured by our company in France DERVASIL S.A.S
Types AZC and AZBD

are manufactured according to ISO 9001-2008, AFAQ certified and qualified by type tests performed in independent laboratories.
Dervasil MV Arresters are conforming to international standards EN 60099-4 and IEC/TS 60815-3.

Dervasil (Ferraz) Arresters with silicone housing are now installed on French network for more than 20 years and are still giving full service satisfaction.

Therefore, we can certify a lifetime of more than 20 years.

St Joseph on
May 28th, 2013




SAS au capital de 907 190 €
Route de Popenot - 42800 SAINT-JO
Tél. 04 77 75 29 98 - Fax 04 77 83
RC St-Etienne 423 136 977 - Code NAF

на основание чл. 2 от ЗЗЛД



Siège social : SAINT-JOSEPH - SIREN 423 136 977 - R.C.ST-ETIENNE



479

DERVASIL
Управление
Route De Popenot
42800 Saint-Joseph
Тел.(33) 04 77 75 29 98
Факс.(33) 04 77 83 22 80
E-mail : info@dervasil.com

Сертификат

До тези, за които се отнася.

Ние долуподписаните, DERVASIL S.A.S., филиал на SICAME S.A, френски производител на оборудване/части и аксесоари за електрически мрежи от 1955г. със седалище в 19230 Rompradour CEDEX/Франция представлявано от Stéphane PRADELLA, Регионален мениджър, потвърждаваме че:

Вентилните отводи за средно напрежение типове AZC и AZBD, произведени във Франция от DERVASIL S.A.S

са в съответствие с ISO 9001 – 2008, сертифицирани от AFAQ и проверени с протоколи от изпитвания на независими лаборатории.

Вентилните отводи за средно напрежение на Dervasil са в съответствие с международния стандарт EN 60099-4 и IEC/TS 60815-3.

Вентилните отводи на Dervasil (Ferraz) със силиконова обвивка, които са били инсталирани във френската електрическа мрежа от преди повече от 20 години са все още в употреба и дават удовлетворителни резултати.

Следователно декларираме експлоатационната дълготрайност повече от 20 години (минимум 20 години).

St Joseph
28.05.2013

на основание чл. 2 от ЗЗЛД



480

Приложение №3 към Техническото предложение

СРОКОВЕ ЗА ДОСТАВКА


| № | Наименование | Мярка | Количество със срок на доставка до 7 кал. дни | Количество със срок на доставка до 30 кал. дни |
|---|---|-------|---|--|
| 1 | 2 | 3 | 4 | 5 |
| 1 | Вентилен отвод метало - оксиден тип без искрови разрядници, 10 kV, 10kA, клас 2 | бр. | 3 | 5 |
| 2 | Вентилен отвод метало - оксиден тип без искрови разрядници, 20 kV, 10kA, клас 1 | бр. | 20 | 50 |
| 3 | Вентилен отвод метало - оксиден тип без искрови разрядници, 20 kV, 10kA, клас 2 | бр. | 20 | 50 |

Забележки:

- 1/ Срокът на доставките започва да тече от датата на изпращане на поръчката.
- 2/ Количествата в колона 4, със срок на доставка до 7 /седем/ календарни дни, се доставят след SAP поръчка до посочените в обявлението складове на Възложителя за покриване на спешни нужди на Възложителя.
Възложителят може да поръчва посоченото спешно количество веднъж месечно.
- 3/ В случай, че крайният срок на доставката съвпада с празничен или неработен ден, то доставката се извършва не по-късно от първия работен ден след изтичането на срока.
- 4/ При поръчки на Възложителя на количества в рамките на потвърдените от Изпълнителя и недоставени в посочените срокове, ще бъдат налагани неустойки, съгласно условията на договора.
- 5/ Възложителят може да поръча количества по-малки от посочените в колони 4 и 5.
- 6/ Възложителят може да поръчва количества по-високи от посочените в колони 4 и 5, като това обстоятелство ще бъде посочено текстово в съответната поръчка изпратена към Изпълнителя. С потвърждението на поръчката, Изпълнителят вписва в същата очаквана дата за доставка на количествата надвишаващи посочените в колони 4 и 5.
- 7/ Количествата за доставка в колони 4 и 5 са отделни и независими едно от друго.
- 8/ Количествата за доставка в колона 5 не включват в себе си количествата за доставка в колона 4.
- 9/ Възложителят има право да направи едновременно поръчки за доставка на количества от колони 4 и 5.

Дата 02.04.2018 г.

ПОДПИС и ПЕЧАТ:



Ивайло Конярски
Управител



поставя се в комплекта на техническото предложение
ОБРАЗЕЦ!

ДЕКЛАРАЦИЯ

за приемане на условията в проекта на рамково споразумение и проекта на конкретен договор, неразделна част от рамковото споразумение

Долуподписаният Ивайло Арангелов Конярски, в качеството ми на представляващ „ВАК-02” ООД, участник в процедура за възлагане на обществена поръчка с реф. № РРД17-158 и предмет: „Доставка на вентилни отводи средно напрежение (СрН)“,

ДЕКЛАРИРАМ, ЧЕ:

1. Приемам условията в проекта на рамково споразумение, приложен в документацията за участие.
2. Приемам условията в проекта на конкретен договор, неразделна част от рамковото споразумение, приложен в документацията за участие.

Дата 02.04.2018 г.

Декларатор: _____
/ Ивайло Конярски /

„ВАК - 02” ООД
на основание чл. 2 от ЗЗЛД



поставя се в комплекта на техническото предложение
ОБРАЗЕЦ!

ДЕКЛАРАЦИЯ
за срока на валидност на офертата

Долуподписаният Ивайло Арангелов Конярски, притежаващ лична карта № 640267725, издадена на 02.06.2010 г. от МВР София област – гр. София, адрес: гр. Самоков, ул Христо Йончев № 7А, в качеството ми на Управител на „ВАК-02“ ООД, участник в процедура за възлагане на обществена поръчка с реф. № PPD17-158 и предмет: „Доставка на вентилни отводи средно напрежение (СрН)“,

ДЕКЛАРИРАМ, ЧЕ:

С подаване на настоящата оферта, направените от нас предложения и поети ангажименти са валидни за срока, посочен в обявлението, считано от крайния срок за подаване на офертите.

Дата 02.04.2018 г.

Декларатор:

на основание чл. 2 от ЗЗЛД

/ Ивайло Конярски /

Забележка:

Декларацията се подписва от законния представител на участника или от надлежно упълномощено лице, което подава офертата.

