


| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.4.1.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 44,6 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.4.2 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1380 V | — |
| | No breakdown or flashover | | P |
| 8.3.4.3 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | 0,01 mA | P |
| 8.3.4.4 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Busmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 6 mm ² | — |
| | - test current I_e (A) | 32 A | — |
| | Measured temperature-rise | see appended table 8.3.4.4 on page 110 | P |

ВЯРНО С
ОРИГИНАЛА




TRF No. IEC60947_3B

[Handwritten signature]

| IEC 60947-3 | | | |
|-------------|---|-------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.5 | TEST SEQUENCE III: SHORT-CIRCUIT PERFORMANCE CAPABILITY | | N/A |
| 8.3.5.1 | Short-time withstand current test | | N/A |
| | Rated short-time withstand current I_{cw} (A) ($>12 \cdot I_e$ max) | | N/A |
| | test voltage (V) | L1: L2: L3: | — |
| | r.m.s. test current (A) | L1: L2: L3: | — |
| | peak test current (A) | L1: L2: L3: | — |
| | power factor/time constant | L1: L2: L3: | — |
| | test duration (s) | | — |
| 8.3.5.1.5 | Behaviour of the equipment during the test | | N/A |
| | Test performed without: | | — |
| | - endanger to the operator | | N/A |
| | - cause damage to adjacent equipment | | N/A |
| | No permanent arcing | | N/A |
| | No flash over between poles and poles and frame | | N/A |
| | No melting of the fuse in the detection circuit | | N/A |
| 8.3.5.1.6 | Condition of the equipment after making and breaking capacity tests | | N/A |
| | Immediately after the test equipment must work satisfactorily | | N/A |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | | N/A |
| | - equipment is able to carry its rated current after normal closing operation | | N/A |


ВЯРНО С
ОРИГИНАЛА



TRF No. IEC60947_3B

| IEC 60947-3 | | | |
|-------------|---|-------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.5.2 | Short-circuit making capacity | | N/A |
| | Rated short-circuit making capacity I _{cm} (A) | | N/A |
| | test voltage (1.05xU _e) (V): | L1: L2: L3: | — |
| | r.m.s. test current (A) | L1: L2: L3: | — |
| | maximum peak test current (factor n) | | N/A |
| | power factor/time constant | L1: L2: L3: | N/A |
| | current duration (s) | | — |
| | Time interval between the cycles | | — |
| 8.3.5.2.5 | Behaviour of the equipment during the test | | N/A |
| | Test performed without: | | — |
| | - endanger to the operator | | N/A |
| | - cause damage to adjacent equipment | | N/A |
| | No permanent arcing | | N/A |
| | No flash over between poles and poles and frame | | N/A |
| | No melting of the fuse in the detection circuit | | N/A |
| 8.3.5.2.6 | Condition of the equipment after making and breaking capacity tests | | N/A |
| | Immediately after the test equipment must work satisfactorily | | N/A |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | | N/A |
| | - equipment is able to carry its rated current after normal closing operation | | N/A |
| 8.3.5.3 | Dielectric verification | | N/A |
| | test voltage: 2*U _e with a minimum of 1000V~ | | — |
| | No flashover or breakdown | | N/A |

ВЯРНО С
ОРИГИНАЛА



TRF No. IEC60947_3B


[Handwritten signature]

| IEC 60947-3 | | | |
|-------------|--|---------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.5.4 | Leakage current | | N/A |
| | test voltage (1,1 Ue) (V) | | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole | | N/A |
| | Leakage current (other utilization categories) ≤ 2,0 mA/pole | | N/A |
| 8.3.5.5 | Temperature-rise verification | | N/A |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | | — |
| | - manufacturer's model or type reference | | — |
| | - rated current (A) | | — |
| | - power loss (W) | | — |
| | - rated breaking capacity (kA) | | — |
| | - conductor cross-section (mm ²) | | — |
| | - test current I _e (A) | | — |
| | Measured temperature-rise | see appended table 8.3.5.5 on page __ | N/A |

[Handwritten signature]

[Handwritten signature]

**ВЯРНО С
ОРИГИНАЛА**



[Handwritten signature]


TRF No. IEC60947_3B

[Handwritten signature]

| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 15: 400 V, 32 A, 1-pole) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated voltage (V) | 400 V | — |
| | - rated current (A) | 32 A (gG) | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 420 V L2: — L3: — | — |
| | test current (kA) | L1: 101 kA L2: — L3: — | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,19 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | |
| | - max. let-through current (kA) | L1: 6,5 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 7000 A ² s L2: — L3: — | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 4,94 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 5000 A ² s L2: — L3: — | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 8,7 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1000 V (tested with 1380 V) | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 440 V (tested with 759 V) | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,008 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 6 mm ² | — |
| | - test current I_e (A) | 32 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 110 | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 16: 400 V, 32 A, 1-pole+N) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated voltage (V) | 400 V | — |
| | - rated current (A) | 32 A (gG) | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 420 V L2: — L3: — | — |
| | test current (kA) | L1: 101 kA L2: — L3: — | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,19 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | — |
| | - max. let-through current (kA) | L1: 6,54 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 7000 A ² s L2: — L3: — | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 3,7 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 4000 A ² s L2: — L3: — | — |

TRF No. IEC60947_3B


ВЕРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 24,8 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1000 V (tested with 1380 V) | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 440 V (tested with 759 V) | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,002 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 6 mm ² | — |
| | - test current I_e (A) | 32 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 111 | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 17: 400 V, 32 A, 2-poles) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated voltage (V) | 400 V | — |
| | - rated current (A) | 32 A (gG) | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 420 V (242,5 V x $\sqrt{3}$) L2: 420 V (242,5 V x $\sqrt{3}$) L3: — | — |
| | test current (kA) | L1: 101 kA L2: 101 kA L3: — | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,19 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | — |
| | - max. let-through current (kA) | L1: 6,35 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 5000 A ² s L2: — L3: — | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 6,15 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 5000 A ² s L2: — L3: — | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 22 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1000 V (tested with 1380 V) | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 440 V (tested with 759 V) | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,001 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 6 mm ² | — |
| | - test current I_e (A) | 32 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 111 | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 18: 400 V, 32 A, 3-poles+N) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | Busmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated voltage (V) | 400 V | — |
| | - rated current (A) | 32 A (gG) | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 U _e) (V) | L1: 420 V (242,5 V x √3) L2: 420 V (242,5 V x √3) L3: 420 V (242,5 V x √3) | — |
| | test current (kA) | L1: 103 kA L2: 100 kA L3: 101 kA | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,19 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | |
| | - max. let-through current (kA) | L1: 0,4 kA L2: 4,8 kA L3: 4,8 kA | — |
| | - Joule integral I ² dt (A ² s) | L1: 0 A ² s L2: 4000 A ² s L3: 4000 A ² s | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 1,6 kA L2: 4,2 kA L3: 4,4 kA | — |
| | - Joule integral I ² dt (A ² s) | L1: 0 A ² s L2: 4000 A ² s L3: 4000 A ² s | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 49,1 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1000 V (tested with 1380 V) | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 440 V (tested with 759 V) | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,001 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 6 mm ² | — |
| | - test current I_e (A) | 32 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 111 | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 19: 500 V, 25 A, 1-pole) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G25 | — |
| | - rated voltage (V) | 500 V | — |
| | - rated current (A) | 25 A (gG) | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 537 V L2: — L3: — | — |
| | test current (kA) | L1: 107 kA L2: — L3: — | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,2 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | — |
| | - max. let-through current (kA) | L1: 2,59 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 1000 A ² s L2: — L3: — | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 3,56 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 2000 A ² s L2: — L3: — | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 11,4 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1000 V (tested with 1380 V) | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 550 V (tested with 759 V) | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,001 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G25 | — |
| | - rated current (A) | 25 A (gG) | — |
| | - power loss (W) | 2,6 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 4 mm ² | — |
| | - test current I_e (A) | 25 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 112 | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 20: 500 V, 25 A, 1-pole+N) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G25 | — |
| | - rated voltage (V) | 500 V | — |
| | - rated current (A) | 25 A (gG) | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 537 V L2: — L3: — | — |
| | test current (kA) | L1: 107 kA L2: — L3: — | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,2 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | — |
| | - max. let-through current (kA) | L1: 3,8 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 2000 A ² s L2: — L3: — | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 2,22 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 1000 A ² s L2: — L3: — | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 20,6 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1000 V (tested with 1380 V) | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 550 V (tested with 759 V) | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,001 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G25 | — |
| | - rated current (A) | 25 A (gG) | — |
| | - power loss (W) | 2,6 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 4 mm ² | — |
| | - test current I_e (A) | 25 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 112 | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 21: 500 V, 25 A, 2-poles) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G25 | — |
| | - rated voltage (V) | 500 V | — |
| | - rated current (A) | 25 A (gG) | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 537 V (310 V x $\sqrt{3}$) L2: 537 V (310 V x $\sqrt{3}$) L3: — | — |
| | test current (kA) | L1: 107 kA L2: 107 kA L3: — | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,2 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | — |
| | - max. let-through current (kA) | L1: 3,71 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 1000 A ² s L2: — L3: — | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 3,64 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 1000 A ² s L2: — L3: — | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 31,2 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1000 V (tested with 1380 V) | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage ($1,1 U_e$) (V) | 550 V (tested with 759 V) | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,005 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G25 | — |
| | - rated current (A) | 25 A (gG) | — |
| | - power loss (W) | 2,6 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 4 mm ² | — |
| | - test current I_e (A) | 25 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 112 | P |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА




| IEC 60947-3 | | | |
|-------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 22: 500 V, 25 A, 3-poles+N) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G25 | — |
| | - rated voltage (V) | 500 V | — |
| | - rated current (A) | 25 A (gG) | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 730 V (421,5 V x $\sqrt{3}$) L2: 730 V (421,5 V x $\sqrt{3}$) L3: 730 V (421,5 V x $\sqrt{3}$) | — |
| | test current (kA) | L1: 102 kA L2: 102 kA L3: 101 kA | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,2 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | |
| | - max. let-through current (kA) | L1: 1,9 kA L2: 3,8 kA L3: 2,0 kA | — |
| | - Joule integral I ² dt (A ² s) | L1: 1000 A ² s L2: 2000 A ² s L3: 1000 A ² s | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,4 m/s | — |
| | - max. let-through current (kA) | L1: 0 kA L2: 3,16 kA L3: 3,16 kA | — |
| | - Joule integral I ² dt (A ² s) | L1: 0 A ² s L2: 1000 A ² s L3: 1000 A ² s | — |

TRF No. IEC60947_3B



ВЯРНО С
ОРИГИНАЛА




| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 46,4 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1000 V (tested with 1380 V) | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 550 V (tested with 759 V) | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,002 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G25 | — |
| | - rated current (A) | 25 A (gG) | — |
| | - power loss (W) | 2,6 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 4 mm ² | — |
| | - test current I_e (A) | 25 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 113 | P |

TRF No. IEC60947_3B



ВЯРНО С
ОРИГИНАЛА


0000
MIG 23 LTD



| IEC 60947-3 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 23: 690 V, 10 A, 1-pole) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | SIBA | — |
| | - manufacturer's model or type reference | 50 179 06.10 | — |
| | - rated voltage (V) | 690 V | — |
| | - rated current (A) | 10 A (gR) | — |
| | - rated breaking capacity (kA) | 200 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 725 V L2: — L3: — | — |
| | test current (kA) | L1: 52,7 kA L2: — L3: — | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,13 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | — |
| | - max. let-through current (kA) | L1: 2,0 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 0 A ² s L2: — L3: — | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 0,77 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 0 A ² s L2: — L3: — | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 18,8 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,002 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | SIBA | — |
| | - manufacturer's model or type reference | 50 179 06.10 | — |
| | - rated current (A) | 10 A (gR) | — |
| | - power loss (W) | 2,3 W | — |
| | - rated breaking capacity (kA) | 200 kA | — |
| | - conductor cross-section (mm ²) | 1,5 mm ² | — |
| | - test current I_e (A) | 10 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 113 | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 24: 690 V, 10 A, 1-pole+N) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | SIBA | — |
| | - manufacturer's model or type reference | 50 179 06.10 | — |
| | - rated voltage (V) | 690 V | — |
| | - rated current (A) | 10 A (gR) | — |
| | - rated breaking capacity (kA) | 200 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 726 V L2: — L3: — | — |
| | test current (kA) | L1: 52,7 kA L2: — L3: — | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,13 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | — |
| | - max. let-through current (kA) | L1: 1,02 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 0 A ² s L2: — L3: — | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 0,78 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 0 A ² s L2: — L3: — | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 25,4 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage ($1,1 U_e$) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,001 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | SIBA | — |
| | - manufacturer's model or type reference | 50 179 06.10 | — |
| | - rated current (A) | 10 A (gR) | — |
| | - power loss (W) | 2,3 W | — |
| | - rated breaking capacity (kA) | 200 kA | — |
| | - conductor cross-section (mm ²) | 1,5 mm ² | — |
| | - test current I_e (A) | 10 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 113 | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 25: 690 V, 10 A, 2-poles) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | SIBA | — |
| | - manufacturer's model or type reference | 50 179 06.10 | — |
| | - rated voltage (V) | 690 V | — |
| | - rated current (A) | 10 A (gR) | — |
| | - rated breaking capacity (kA) | 200 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 726 V (419,16 V x $\sqrt{3}$) L2: 726 V (419,16 V x $\sqrt{3}$) L3: — | — |
| | test current (kA) | L1: 52,7 kA L2: 52,7 kA L3: — | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,13 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | |
| | - max. let-through current (kA) | L1: 0,61 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 0 A ² s L2: — L3: — | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,5 m/s | — |
| | - max. let-through current (kA) | L1: 0,55 kA L2: — L3: — | — |
| | - Joule integral I ² dt (A ² s) | L1: 0 A ² s L2: — L3: — | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 34,2 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,003 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | SIBA | — |
| | - manufacturer's model or type reference | 50 179 06.10 | — |
| | - rated current (A) | 10 A (gR) | — |
| | - power loss (W) | 2,3 W | — |
| | - rated breaking capacity (kA) | 200 kA | — |
| | - conductor cross-section (mm ²) | 1,5 mm ² | — |
| | - test current I_e (A) | 10 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 114 | P |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6 | TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT (Sample No. 26: 690 V, 32 A, 3-poles+N) | | P |
| | Protective device details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated voltage (V) | 400 V | — |
| | - rated current (A) | 32 A (gG) | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| 8.3.6.2 | Fuse protected short-circuit withstand | | P |
| | test voltage (1,05 Ue) (V) | L1: 726 V (419,16 V x $\sqrt{3}$) L2: 726 V (419,16 V x $\sqrt{3}$) L3: 726 V (419,16 V x $\sqrt{3}$) | — |
| | test current (kA) | L1: 50,9 kA L2: 52,2 kA L3: 51,0 kA | — |
| | rated frequency (Hz) | 50 Hz | — |
| | power factor | 0,23 | — |
| | Time constant (ms) | — | — |
| | Fuse protected short-circuit withstand (equipment in closed position) | | |
| | - max. let-through current (kA) | L1: 0,9 kA L2: 5,6 kA L3: 5,6 kA | — |
| | - Joule integral I ² dt (A ² s) | L1: 2000 A ² s L2: 8000 A ² s L3: 6000 A ² s | — |
| | Fuse protected short-circuit making | | P |
| | - mean velocity of 15 manually under no-load conditions operations (m/s) | 1,6 m/s | — |
| | - point at which the measurement is made | point of rotation | — |
| | - test speed during the fuse protected short-circuit making (m/s) | 1,4 m/s | — |
| | - max. let-through current (kA) | L1: 5,3 kA L2: 5,3 kA L3: 0 kA | — |
| | - Joule integral I ² dt (A ² s) | L1: 5000 A ² s L2: 5000 A ² s L3: 0 A ² s | — |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.6.2.5 | Behaviour of the equipment during the test | | P |
| | Test performed without: | | — |
| | - endanger to the operator | | P |
| | - cause damage to adjacent equipment | | P |
| | No permanent arcing | | P |
| | No flash over between poles and poles and frame | | P |
| | No melting of the fuse in the detection circuit | | P |
| 8.3.6.2.6 | Condition of the equipment after making and breaking capacity tests | | P |
| | Immediately after the test equipment must work satisfactorily | | P |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | 51,6 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | - equipment is able to carry its rated current after normal closing operation | | P |
| 8.3.6.3 | Dielectric verification | | P |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.6.4 | Leakage current | | P |
| | test voltage (1,1 U_e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) $\leq 2,0$ mA/pole | 0,002 mA | P |
| 8.3.6.5 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - conductor cross-section (mm ²) | 6 mm ² | — |
| | - test current I_e (A) | 32 A | — |
| | Measured temperature-rise | see appended table 8.3.6.5 on page 114 | P |


TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.7 | TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY (Sample No. 27: 690 V, 32 A, 1-pole) | | P |
| 8.3.7.1 | Overload test | | P |
| | ambient temperature 10-40 °C | 25,6 °C | — |
| | test enclosure W x H x D (mm x mm x mm) | — | — |
| | material of enclosure | — | — |
| | test current 1,6xI _{th} e or 1,6xI _{th} (A) | 52 | — |
| | cable/busbar cross-section (mm ²) / length (mm) ... | 6 mm ² cable / 1000 mm long | — |
| | Fuse-link details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - time duration of the overload test (s) | 824 s | — |
| | Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed | | P |
| | Required opening force not greater than the test force of 8.2.5.2 and table 8 | 14 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | The equipment has not undergone any impairment hindering such operation | | P |
| 8.3.7.2 | Dielectric verification | | P |
| | test voltage: 2*U _e with a minimum of 1000V~ | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.7.3 | Leakage current | | P |
| | test voltage (1,1 U _e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole | | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | 0,002 mA | P |


TRF No. IEC60947_3B



| IEC 60947-3 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.7.4 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | Fuse links aged during the overload test are replaced by new fuse-links | | P |
| | - conductor cross-section (mm ²) | 6 mm ² | — |
| | - test current I _e (A) | 32 A | — |
| | Measured temperature-rise | see appended table 8.3.7.4 on page 114 | P |

TRF No. IEC60947_3B


**ВЯРНО С
ОРИГИНАЛА**



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.7 | TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY (Sample No. 28: 690 V, 32 A, 2-poles) | | P |
| 8.3.7.1 | Overload test | | P |
| | ambient temperature 10-40 °C | 23,6 °C | — |
| | test enclosure W x H x D (mm x mm x mm) | — | — |
| | material of enclosure | — | — |
| | test current 1,6xI _{th} e or 1,6xI _{th} (A) | 52 | — |
| | cable/busbar cross-section (mm ²) / length (mm) ... | 6 mm ² cable / 1000 mm long | — |
| | Fuse-link details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - time duration of the overload test (s) | 573 s | — |
| | Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed | | P |
| | Required opening force not greater than the test force of 8.2.5.2 and table 8 | 17,2 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | The equipment has not undergone any impairment hindering such operation | | P |
| 8.3.7.2 | Dielectric verification | | P |
| | test voltage: 2*U _e with a minimum of 1000V~ | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.7.3 | Leakage current | | P |
| | test voltage (1,1 U _e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole | | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | 0,001 mA | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.7.4 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | Fuse links aged during the overload test are replaced by new fuse-links | | P |
| | - conductor cross-section (mm ²) | 6 mm ² | — |
| | - test current I _e (A) | 32 A | — |
| | Measured temperature-rise | see appended table 8.3.7.4 on page 115 | P |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.7 | TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY (Sample No. 29: 690 V, 32 A, 3-poles+N) | | P |
| 8.3.7.1 | Overload test | | P |
| | ambient temperature 10-40 °C | 23,6 °C | — |
| | test enclosure W x H x D (mm x mm x mm) | — | — |
| | material of enclosure | — | — |
| | test current 1,6xI _{th} e or 1,6xI _{th} (A) | 52 | — |
| | cable/busbar cross-section (mm ²) / length (mm) | 6 mm ² cable / 1000 mm long | — |
| | Fuse-link details: | | P |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | - time duration of the overload test (s) | 540 s | — |
| | Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed | | P |
| | Required opening force not greater than the test force of 8.2.5.2 and table 8 | 35,2 N (required opening force) 150 N (test force acc. tab. 8) | P |
| | The equipment has not undergone any impairment hindering such operation | | P |
| 8.3.7.2 | Dielectric verification | | P |
| | test voltage: 2*U _e with a minimum of 1000V~ | 1380 V | — |
| | No flashover or breakdown | | P |
| 8.3.7.3 | Leakage current | | P |
| | test voltage (1,1 U _e) (V) | 759 V | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole | | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | 0,001 mA | P |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА




| IEC 60947-3 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.7.4 | Temperature-rise verification | | P |
| | Fuse-link details (fuse-combination units only): | | — |
| | - manufacturer's name, trademark or identification mark | Bussmann | — |
| | - manufacturer's model or type reference | C10G32 | — |
| | - rated current (A) | 32 A (gG) | — |
| | - power loss (W) | 2,9 W | — |
| | - rated breaking capacity (kA) | 120 kA | — |
| | Fuse links aged during the overload test are replaced by new fuse-links | | P |
| | - conductor cross-section (mm ²) | 6 mm ² | — |
| | - test current I _e (A) | 32 A | — |
| | Measured temperature-rise | see appended table 8.3.7.4 on page 115 | P |

| | | | |
|---------|--|-----------|-----|
| 8.4 | ELECTROMAGNETIC COMPATIBILITY TESTS | | N/A |
| 8.4.1 | Immunity | | N/A |
| 8.4.1.1 | Equipment not incorporating electronic circuits: no tests necessary | | N/A |
| 8.4.1.2 | Equipment incorporating electronic circuits: | | N/A |
| | Equipment utilizing circuits in which all components are passive are not required to be tested | | N/A |
| | All other equipment, requirements according to 7.3.3.2 and limits according table 6 apply | | N/A |
| | Performed tests..... | see _____ | N/A |
| | No unintentional separation or closing of contacts has occurred during these tests | | N/A |
| 8.4.2 | Emission | | N/A |
| 8.4.2.1 | Equipment not incorporating electronic circuits: no tests necessary | | N/A |
| 8.4.2.2 | Equipment incorporating electronic circuits: | | N/A |
| | Equipment utilizing circuits in which all components are passive are not required to be tested | | N/A |
| | All other equipment, requirements according to 7.3.3.2 and limits according table 7 apply | | N/A |
| | Performed tests..... | see _____ | N/A |

TRF No. IEC60947_3B

**ВЯРНО С
ОРИГИНАЛА**



[Handwritten signature]

| IEC 60947-3 | | | |
|----------------------------|---|-----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| Annex A (normative) | | | N/A |
| A | Equipment for direct switching of a single motor | | N/A |
| A.1 | Additional rated duties.....: | | N/A |
| A.1.1 | - intermittent periodic duty | | N/A |
| | - intermittent duty | | N/A |
| A.1.1.1 | Classes of intermittent duty | | N/A |
| | -class 1: up to 1 operating cycle per hour | | N/A |
| | -class 3: up to 3 operating cycle per hour | | N/A |
| | -class 12: up to 12 operating cycles per hour | | N/A |
| | -class 30: up to 30 operating cycles per hour | | N/A |
| | -class 120: up to 120 operating cycles per hour | | N/A |
| A.1.2 | Temporary duty.....: | | N/A |
| A.5 | Mechanical durability: | | N/A |
| | Equipment mounted according to manufacturer's instruction | | N/A |
| | Preferred number of no-load operating cycles expressed in millions.....: | | N/A |
| | 0,001 – 0,003 – 0,01 – 0,03 – 0,1 – 0,3 - 1 | | N/A |
| | If no mechanical endurance is stated by the manufacturer, a minimum mechanical endurance according to the class of intermittent duty shall be tested. | Class of intermittent duty: | N/A |
| | Number of no-load operating cycles performed.....: | _____ | N/A |
| A.6 | Electrical durability: | | N/A |
| | - test according to manufacturer's instruction | | N/A |
| A.7 | Verification of making and breaking capacities: | | N/A |
| | - utilization category | | — |
| | - rated operational voltage Ue (V) | | — |
| | - rated operational current Ie (A) or power (kW) | | — |
| | Conditions for make/break operations or make operations: | | — |
| | - test voltage, U = 1,05 Ue (V): | L1: L2: L3: | — |
| | - test current, I = x Ie (A): | L1: L2: L3: | — |

TRF No. IEC60947_3B



| IEC 60947-3 | | | |
|-------------|--|-------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - power factor | L1: L2: L3: | — |
| | Conditions for make/break operations: | | N/A |
| | - test voltage, $U = 1,05 U_e$ (V): | L1: L2: L3: | — |
| | - test current, $I =$ x I_e (A): | L1: L2: L3: | — |
| | - power factor/ time constant | L1: L2: L3: | — |
| | Number of make/break or make and break operations | | N/A |
| | - recovery voltage duration (≥ 50 ms) | | N/A |
| | - current duration (ms) | | — |
| | - time interval between operations | | N/A |
| | Characteristic of transient recovery voltage if necessary: | | N/A |
| | - oscillatory frequency (kHz) | | — |
| | - measured oscillatory frequency (kHz) | L1: L2: L3: | N/A |
| | - factor γ | L1: L2: L3: | N/A |
| 8.3.3.3.5 | Behaviour of the equipment during making and breaking capacity tests | | N/A |
| | Test performed without: | | — |
| | - endanger to the operator | | N/A |
| | - cause damage to adjacent equipment | | N/A |
| | No permanent arcing | | N/A |
| | No flash over between poles and poles and frame | | N/A |
| | No melting of the fuse in the detection circuit | | N/A |

[Handwritten signature]

TRF No. IEC60947_3B


[Handwritten signature]



| IEC 60947-3 | | | |
|-------------|--|-------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3.3.6 | Condition of the equipment after making and breaking capacity tests | | N/A |
| | Immediately after the test equipment must work satisfactorily | | N/A |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | | N/A |
| | - equipment is able to carry its rated current after normal closing operation | | N/A |
| 8.3.3.4 | Dielectric verification | | N/A |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | | — |
| | No flashover or breakdown | | N/A |
| 8.3.3.5 | Leakage current | | N/A |
| | test voltage (1,1 U_e) (V) | | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories): ≤ 2 mA/pole) | | N/A |
| 8.3.3.6 | Temperature-rise verification | | N/A |
| | - conductor cross-section (mm ²) | | — |
| | - test current I_e (A) | | — |
| | Measured temperature-rise | see ___ | N/A |
| A.8 | Operational performance test: | | N/A |
| | - utilization category | | — |
| | - rated operational voltage (V) | | — |
| | - rated operational current (A) | | — |
| | Test conditions for electrical operation cycles: | | N/A |
| | - test voltage (V) | L1: L2: L3: | — |
| | - test current (A) | L1: L2: L3: | — |
| | - power factor/time constant | L1: L2: L3: | — |
| | Number of cycles with current | | N/A |
| | Number of cycles without current | | N/A |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | First test sequence (with/without current) | | — |
| | Second test sequence (with/without current) | | — |
| | - time interval between first and second test sequence | | — |
| 8.3.4.1.5 | Behaviour of the equipment during the operational performance test | | N/A |
| | Test performed without: | | — |
| | - endanger to the operator | | N/A |
| | -cause damage to adjacent equipment | | N/A |
| | No permanent arcing | | N/A |
| | No flash over between poles and poles and frame | | N/A |
| | No melting of the fuse in the detection circuit | | N/A |
| 8.3.4.1.6 | Condition of the equipment after making and breaking capacity tests | | N/A |
| | Immediately after the test equipment must work satisfactorily | | N/A |
| | - required opening force not greater than the test force of 8.2.5.2 and table 8 | | N/A |
| | - equipment is able to carry its rated current after normal closing operation | | N/A |
| 8.3.4.2 | Dielectric verification | | N/A |
| | test voltage: $2 \cdot U_e$ with a minimum of 1000V~ | | — |
| | No breakdown or flashover | | N/A |
| 8.3.4.3 | Leakage current | | N/A |
| | test voltage (1,1 U_e) (V) | | — |
| | Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole | | N/A |
| | Leakage current (other utilization categories) ≤ 2 mA/pole | | N/A |
| 8.3.4.4 | Temperature-rise verification | | N/A |
| | - conductor cross-section (mm ²) | | — |
| | - test current I_e (A) | | — |
| | Measured temperature-rise | see __ | N/A |
| A.9 | Special tests: | see __ | N/A |

TRF No. IEC60947_3B


ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|----------------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| Annex C (normative) | | | N/A |
| C | Single pole operated three pole switches | | N/A |
| C.1 | Three pole operated switches of fundamentally the same design, already successfully tested are deemed to satisfy the requirements of individually operated three pole devices. | | N/A |
| C.2 | Additional-tests to be performed on single pole operated three pole switches | | N/A |
| | Test "8.3.3.3 Making and breaking capacities" according to test sequence I with following modifications | | N/A |
| | L1 and L2 are closed, L3 is subjected to the required make-break operation cycle | | N/A |
| | L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle | | N/A |
| | Test performed in a three phase circuit | | N/A |
| | Test "8.3.4.1 Operational performance" according to test sequence II with following modifications | | N/A |
| | L1 and L2 are closed, L3 is subjected to the required make-break operation cycle | | N/A |
| | L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle | | N/A |
| | Test performed in a three phase circuit | | N/A |
| | Test "8.3.6.2 Fuse protected short circuit test" according to test sequence IV with following modifications | | N/A |
| | For the making test L1 shall be open and L2 closed, L3 is subjected to the required make operation cycle | | N/A |
| | L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle | | N/A |
| | Test performed in a three phase circuit | | N/A |
| C.5 | Instruction for use | | N/A |
| | The product literature includes following statement : | | N/A |
| | These devices are intended for power distribution systems where switching and/or isolating of an individual phase may be necessary and shall not be used for the switching of the primary circuit of three-phase equipment. | | N/A |

TRF No. IEC60947_3B

**ВЯРНО С
ОРИГИНАЛА**



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |


| 7.1.4 | TABLE: Clearance and creepage distance measurements | | | | | | |
|---|---|--------------|------------------|---------|-------------------|----------|--|
| clearance cl and creepage distance dcr at/of: | Up (V) | U r.m.s. (V) | required cl (mm) | cl (mm) | required dcr (mm) | dcr (mm) | |
| Between active parts and parts intended to be touched | 7300 | 800 | 2 | >5,5 | 11 | >11 | |
| Between active parts and enclosure | 7300 | 800 | 2 | >5,5 | 11 | >11 | |
| Between active parts and fuse-link with the contacts in open position | 9800 | 800 | 2 | >5,5 | 11 | >11 | |
| supplementary information: | | | | | | | |

| 8.3.3.1 | TABLE: Temperature-rise (measurements) (Sample No. 1: I _e = 25 A) | | P |
|---|---|------------------------------|---|
| Temperature rise dT of part: | dT (K) measured | dT (K) required | |
| Above terminals (cable connection) | 39,3 | 70 | |
| Below terminals (cable connection) | 35,3 | 70 | |
| Manual operating means: metallie / non-metallic | 4,3 | 25 | |
| Parts intended to be touched but not hand-held: metallie / non-metallic | 8,5 | 40 | |
| Parts which need not be touched during normal operation: metallie / non-metallic | 12,8 | 50 | |
| supplementary information: | | Ambient temperature: 22,7 °C | |

| 8.3.3.6 | TABLE: Temperature-rise (measurements) (Sample No. 1: I _e = 25 A) | | P |
|---|---|------------------------------|---|
| Temperature rise dT of part: | dT (K) measured | dT (K) required | |
| Terminals | 37,2 | 80 | |
| Manual operating means: metallie / non-metallic | 4,6 | 35 | |
| Parts intended to be touched but not hand-held: metallie / non-metallic | 6,1 | 50 | |
| Parts which need not be touched during normal operation: metallie / non-metallic | 17,0 | 60 | |
| supplementary information: | | Ambient temperature: 22,9 °C | |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |


| 8.3.3.1 | TABLE: Temperature-rise (measurements) (Sample No. 2: $I_b = 10 A$) | P | |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Above terminals (cable connection) | | 31,7 | 70 |
| Below terminals (cable connection) | | 29,8 | 70 |
| Manual operating means: metallic / non-metallic | | 5,0 | 25 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 8,8 | 40 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 15,3 | 50 |
| supplementary information: | | Ambient temperature: 22,7 °C | |

| 8.3.3.6 | TABLE: Temperature-rise (measurements) (Sample No. 2: $I_b = 10 A$) | P | |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 32,9 | 80 |
| Manual operating means: metallic / non-metallic | | 3,7 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 5,4 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 19,4 | 60 |
| supplementary information: | | Ambient temperature: 23,8 °C | |

| 8.3.3.1 | TABLE: Temperature-rise (measurements) (Sample No. 3: $I_b = 32 A$) | P | |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Above terminals (cable connection) | | 45,0 | 70 |
| Below terminals (cable connection) | | 37,5 | 70 |
| Manual operating means: metallic / non-metallic | | 5,5 | 25 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 13,8 | 40 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 12,0 | 50 |
| supplementary information: | | Ambient temperature: 22,7 °C | |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 8.3.3.6 | TABLE: Temperature-rise (measurements) (Sample No. 3: $I_b = 32$ A) | | P |
|---|--|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 39,0 | 80 |
| Manual operating means: metallie / non-metallic | | 4,8 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 5,4 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 21,1 | 60 |
| supplementary information: | | Ambient temperature: 24,3 °C | |

| 8.3.3.1 | TABLE: Temperature-rise (measurements) (Sample No. 4: $I_b = 32$ A) | | P |
|---|--|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Above terminals (cable connection) | | 48,5 | 70 |
| Below terminals (cable connection) | | 47,3 | 70 |
| Manual operating means: metallie / non-metallic | | 7,8 | 25 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 21,8 | 40 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 14,5 | 50 |
| supplementary information: | | Ambient temperature: 22,7 °C | |

| 8.3.3.6 | TABLE: Temperature-rise (measurements) (Sample No. 4: $I_b = 32$ A) | | P |
|---|--|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 49,0 | 80 |
| Manual operating means: metallie / non-metallic | | 8,8 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 12,9 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 26,9 | 60 |
| supplementary information: | | Ambient temperature: 24,4 °C | |

TRF No. IEC60947_3B



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |


| 8.3.3.1 | TABLE: Temperature-rise (measurements) (Sample No. 5: $I_e = 25$ A) | P | |
|--|--|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Above terminals (cable connection) | | 44,3 | 70 |
| Below terminals (cable connection) | | 42,9 | 70 |
| Manual operating means: metallic / non-metallic | | 10,6 | 25 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 13,3 | 40 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 15,2 | 50 |
| supplementary information: | | Ambient temperature: 22,7 °C | |

| 8.3.3.6 | TABLE: Temperature-rise (measurements) (Sample No. 5: $I_e = 25$ A) | P | |
|--|--|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 47,5 | 80 |
| Manual operating means: metallic / non-metallic | | 8,9 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 16,2 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 22,8 | 60 |
| supplementary information: | | Ambient temperature: 22,9 °C | |

| 8.3.3.1 | TABLE: Temperature-rise (measurements) (Sample No. 6: $I_e = 10$ A) | P | |
|--|--|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Above terminals (cable connection) | | 44,5 | 70 |
| Below terminals (cable connection) | | 40,8 | 70 |
| Manual operating means: metallic / non-metallic | | 9,3 | 25 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 19,5 | 40 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 14,8 | 50 |
| supplementary information: | | Ambient temperature: 22,7 °C | |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 8.3.3.6 | TABLE: Temperature-rise (measurements) (Sample No. 6: I ₀ = 10 A) | | P |
|--|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 50,4 | 80 |
| Manual operating means: metallic / non-metallic | | 6,3 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 13,8 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 27,0 | 60 |
| supplementary information: | | Ambient temperature: 23,8 °C | |

| 8.3.3.1 | TABLE: Temperature-rise (measurements) (Sample No. 7: I ₀ = 32 A) | | P |
|--|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Above terminals (cable connection) | | 63,8 | 70 |
| Below terminals (cable connection) | | 63,9 | 70 |
| Manual operating means: metallic / non-metallic | | 16,9 | 25 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 32,8 | 40 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 22,3 | 50 |
| supplementary information: | | Ambient temperature: 22,7 °C | |

| 8.3.3.6 | TABLE: Temperature-rise (measurements) (Sample No. 7: I ₀ = 32 A) | | P |
|--|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 59,9 | 80 |
| Manual operating means: metallic / non-metallic | | 11,2 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 23,7 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 27,6 | 60 |
| supplementary information: | | Ambient temperature: 24,4 °C | |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |


| 8.3.4.4 | TABLE: Temperature-rise (measurements) (Sample No. 8: $I_e = 25\text{ A}$) | P | |
|---|--|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 39,6 | 80 |
| Manual operating means: metallic / non-metallic | | 5,5 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 17,6 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 25,9 | 60 |
| supplementary information: | | Ambient temperature: 25,3 °C | |

| 8.3.4.4 | TABLE: Temperature-rise (measurements) (Sample No. 9: $I_e = 10\text{ A}$) | P | |
|---|--|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 43,1 | 80 |
| Manual operating means: metallic / non-metallic | | 3,3 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 14,0 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 20,3 | 60 |
| supplementary information: | | Ambient temperature: 25,3 °C | |

| 8.3.4.4 | TABLE: Temperature-rise (measurements) (Sample No. 10: $I_e = 32\text{ A}$) | P | |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 47,5 | 80 |
| Manual operating means: metallic / non-metallic | | 10,8 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 24,4 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 26,1 | 60 |
| supplementary information: | | Ambient temperature: 25,3 °C | |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |


| 8.3.4.4 | TABLE: Temperature-rise (measurements) (Sample No. 11: $I_e = 32$ A) | | P |
|--|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 42,5 | 80 |
| Manual operating means: metallic / non-metallic | | 9,2 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 22,1 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 22,5 | 60 |
| supplementary information: | | Ambient temperature: 25,3 °C | |

| 8.3.4.4 | TABLE: Temperature-rise (measurements) (Sample No. 12: $I_e = 25$ A) | | P |
|--|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 48,9 | 80 |
| Manual operating means: metallic / non-metallic | | 8,4 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 28,8 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 30,4 | 60 |
| supplementary information: | | Ambient temperature: 25,3 °C | |

| 8.3.4.4 | TABLE: Temperature-rise (measurements) (Sample No. 13: $I_e = 10$ A) | | P |
|--|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 43,8 | 80 |
| Manual operating means: metallic / non-metallic | | 9,3 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 28,5 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 28,7 | 60 |
| supplementary information: | | Ambient temperature: 25,3 °C | |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |


| 8.3.4.4 | TABLE: Temperature-rise (measurements) (Sample No. 14: $I_e = 32$ A) | | P |
|--|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 44,1 | 80 |
| Manual operating means: metallic / non-metallic | | 14,5 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 34,0 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 23,3 | 60 |
| supplementary information: | | Ambient temperature: 25,3 °C | |

| 8.3.5.5 | TABLE: Temperature-rise (measurements) | | N/A |
|--|--|--------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | | |
| Manual operating means: metallic / non-metallic | | | |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | | |
| Parts which need not be touched during normal operation: metallic / non-metallic | | | |
| supplementary information: | | | |

| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 15: $I_e = 32$ A) | | P |
|--|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 53,5 | 80 |
| Manual operating means: metallic / non-metallic | | 6,0 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 16,8 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 26,3 | 60 |
| supplementary information: | | Ambient temperature: 23,5 °C | |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 16: $I_e = 32$ A) | P | |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 58,5 | 80 |
| Manual operating means: metallie / non-metallic | | 10,2 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 21,8 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 40,5 | 60 |
| supplementary information: | | Ambient temperature: 24,9 °C | |

| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 17: $I_e = 32$ A) | P | |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 65,9 | 80 |
| Manual operating means: metallie / non-metallic | | 14,1 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 28,4 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 44,7 | 60 |
| supplementary information: | | Ambient temperature: 24,6 °C | |

| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 18: $I_e = 32$ A) | P | |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 60,3 | 80 |
| Manual operating means: metallie / non-metallic | | 16,6 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 35,0 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 33,5 | 60 |
| supplementary information: | | Ambient temperature: 24,2 °C | |

TRF No. IEC60947_3B



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |


| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 19: $I_e = 25$ A) | | P |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 35,6 | 80 |
| Manual operating means: metallie / non-metallic | | 6,5 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 15,7 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 22,0 | 60 |
| supplementary information: | | Ambient temperature: 24,6 °C | |

| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 20: $I_e = 25$ A) | | P |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 42,1 | 80 |
| Manual operating means: metallie / non-metallic | | 8,6 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 19,1 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 24,3 | 60 |
| supplementary information: | | Ambient temperature: 24,6 °C | |

| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 21: $I_e = 25$ A) | | P |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 46,6 | 80 |
| Manual operating means: metallie / non-metallic | | 12,9 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 26,5 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 28,2 | 60 |
| supplementary information: | | Ambient temperature: 24,6 °C | |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |


| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 22: $I_e = 25$ A) | | P |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 57,7 | 80 |
| Manual operating means: metallie / non-metallic | | 16,8 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 33,8 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 30,6 | 60 |
| supplementary information: | | Ambient temperature: 24,6 °C | |

| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 23: $I_e = 10$ A) | | P |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 33,5 | 80 |
| Manual operating means: metallie / non-metallic | | 3,5 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 13,0 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 19,0 | 60 |
| supplementary information: | | Ambient temperature: 23,3 °C | |

| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 24: $I_e = 10$ A) | | P |
|---|---|------------------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 31,9 | 80 |
| Manual operating means: metallie / non-metallic | | 6,1 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 17,1 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 19,3 | 60 |
| supplementary information: | | Ambient temperature: 23,3 °C | |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |


| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 25: I _e = 10 A) | | P |
|---|--|----------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 45,7 | 80 |
| Manual operating means: metallic / non-metallic | | 8,4 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 24,1 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 25,3 | 60 |
| supplementary information: | | Ambient temperature: | 23,3 °C |

| 8.3.6.5 | TABLE: Temperature-rise (measurements) (Sample No. 26: I _e = 32 A) | | P |
|---|--|----------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 56,8 | 80 |
| Manual operating means: metallic / non-metallic | | 13,5 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 33,0 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 30,8 | 60 |
| supplementary information: | | Ambient temperature: | 24,6 °C |

| 8.3.7.4 | TABLE: Temperature-rise (measurements) (Sample No. 27: I _e = 32 A) | | P |
|---|--|----------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 42,5 | 80 |
| Manual operating means: metallic / non-metallic | | 2,8 | 35 |
| Parts intended to be touched but not hand-held: metallic / non-metallic | | 14,0 | 50 |
| Parts which need not be touched during normal operation: metallic / non-metallic | | 21,6 | 60 |
| supplementary information: | | Ambient temperature: | 22,6 °C |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА




| IEC 60947-3 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 8.3.7.4 | TABLE: Temperature-rise (measurements) (Sample No. 28: I _e = 32 A) | | P |
|---|--|----------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 46,8 | 80 |
| Manual operating means: metallie / non-metallic | | 11,7 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 31,8 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 35,4 | 60 |
| supplementary information: | | Ambient temperature: | 23,4 °C |

| 8.3.7.4 | TABLE: Temperature-rise (measurements) (Sample No. 29: I _e = 32 A) | | P |
|---|--|----------------------|--------------------|
| Temperature rise dT of part: | | dT (K) measured | dT (K) required |
| Terminals | | 53,6 | 80 |
| Manual operating means: metallie / non-metallic | | 17,5 | 35 |
| Parts intended to be touched but not hand-held: metallie / non-metallic | | 33,4 | 50 |
| Parts which need not be touched during normal operation: metallie / non-metallic | | 41,5 | 60 |
| supplementary information: | | Ambient temperature: | 23,8 °C |

TRF No. IEC60947_3B

ВЯРНО С
ОРИГИНАЛА



List of test equipment used:

(Note: This is an example of the required attachment. Other forms with a different layout but containing similar information are also acceptable.)

| Clause | Measurement / testing | Testing / measuring equipment / material used | Range used | Calibration date |
|--------|-----------------------|--|------------|------------------|
| | | | | |
| | | Not applicable, only required for the MT programs | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

[Handwritten signature]

[Handwritten signature]

TRF No. IEC60947_3B

**ВЯРНО С
ОРИГИНАЛА**




[Handwritten signature]

Herstellererklärung

zur Baumusterkonformität der Sicherungshalter für zylindrische Sicherungen in den Bauartausführungen der Hersteller
Wöhner GmbH & Co. KG und OEZ, s.r.o.,

| Wöhner GmbH & Co. KG | OEZ s.r.o. | |
|----------------------|------------|------------|
| Wöhner Nr. | ID code | ITEM |
| 31.971.062 | 41003 | OPVF10-1 |
| 31.974.062 | 41004 | OPVF10-2 |
| 31.110.162 | 41005 | OPVA10-1 |
| 31.130.162 | 41006 | OPVA10-1-S |
| 31.111.162 | 41007 | OPVA10-1N |
| 31.112.162 | 41008 | OPVA10-2 |
| 31.132.162 | 41009 | OPVA10-2-S |
| 31.113.162 | 41010 | OPVA10-3 |
| 31.133.162 | 41011 | OPVA10-3-S |
| 31.114.162 | 41012 | OPVA10-3N |
| 31.275.062 | 41013 | OPVP10-1 |
| 31.276.062 | 41014 | OPVP10-2 |
| 31.277.062 | 41015 | OPVP10-3 |
| 31.115.162 | 41016 | OPVA14-1 |
| 31.135.162 | 41017 | OPVA14-1-S |
| 31.116.162 | 41018 | OPVA14-1N |
| 31.117.162 | 41019 | OPVA14-2 |
| 31.137.162 | 41020 | OPVA14-2-S |
| 31.118.162 | 41021 | OPVA14-3 |
| 31.138.162 | 41022 | OPVA14-3-S |
| 31.119.162 | 41023 | OPVA14-3N |
| 31.278.062 | 41024 | OPVP14-1 |
| 31.279.062 | 41025 | OPVP14-2 |
| 31.280.062 | 41026 | OPVP14-3 |
| 31.120.162 | 41027 | OPVA22-1 |
| 31.140.162 | 41028 | OPVA22-1-S |
| 31.121.162 | 41029 | OPVA22-1N |
| 31.122.162 | 41030 | OPVA22-2 |

ВЯРНО С
ОРИГИНАЛА



| | | |
|------------|-------|------------|
| 31.142.162 | 41031 | OPVA22-2-S |
| 31.123.162 | 41032 | OPVA22-3 |
| 31.143.162 | 41033 | OPVA22-3-S |
| 31.124.162 | 41034 | OPVA22-3N |
| 31.281.062 | 41035 | OPVP22-1 |
| 31.282.062 | 41036 | OPVP22-2 |
| 31.283.062 | 41037 | OPVP22-3 |

Fertigungsstätte für die oben genannten Sicherungshalter:

Wöhner GmbH & Co. KG
Mönchrödener Strasse 10
D - 96472 Rödental

VDE-Aktenzeichen

разяснение как да влизам във Вашата система за преглед на продуктовия каталог.

DE 1-29309 249800-4402-0708/158641 (14x51)
DE1-50312 249800-4402-0708/158641 (22x58)

Zurzeit noch in Bearbeitung (10x38 PV)

Hiermit erklären wir, dass die oben genannten Sicherungshalter der Hersteller Wöhner GmbH & Co. KG und OEZ, s.r.o. in der angegebenen Fertigungsstätte nach denselben Zeichnungen gefertigt werden.

Wir bestätigen, dass die Sicherungshalter auch unter dem Firmennamen OEZ, s.r.o. vertrieben werden können.


Beide Geräteausführungen besitzen einen identischen Aufbau bezüglich der Konstruktion und des verwendeten Materials und unterscheiden sich nur im äußeren Design und in den Aufschriften.

Rödental, den 28.06.2012

на основание чл. 2 от ЗЗЛД

Alex Büttner
(Geschäftsleitung)

ВЯРНО С
ОРИГИНАЛА






LAB 12138
Page 1 (26)
Date 17th of October 2003

Task: WTL 6/1 - Type test taken pattern from DIN EN 60947-7-1 and LPP1129

Test objects:



WTL 6/1

Cat.-no. 10167000000

Materials:

| | |
|-----------------------------|---------------------|
| housing: | Wemid beige |
| current bar: | Cu-ETP gal. Sn |
| clamping yoke: | steel gal. ZnC |
| clamping screw: | M3,5 steel gal. ZnC |
| leading plate of discon.: | steel gal. ZnC |
| contact element of discon.: | E-CU57 gal. Sn |
| insulation of disconnecter: | PA 66 orange |
| screw of disconnecter: | M3 steel gal. ZnC |

de

E-Mail:
DGS
Hr.Roß

MEEK
Hr.Strate

Manufacturer: Weidmüller Interface

Date of manufacture: Q 03-00009030-030221-00

Receipt of test objects: 51st week 2002

Period of test performance: 14th and 38th – 39th week 2003

Conclusion of result: The type test has been passed.


copy:

O. Despang
(tester)

F. Maris
(approved)

W 041.00

ВЯРНО С
ОРИГИНАЛА



All test results only apply to the objects tested. Reproduction of this laboratory report by extract with written permission only. The german version is binding. Accreditation only applies to special standards for connectors, terminal blocks, safety requirements for electronic devices, relays and EMC.

Weidmüller Interface GmbH & Co. KG
Ohmstraße 9
D-32 758 Detmold

Telefon (05231) 14-0
Telefax (05231) 14-1689

Rechtsform: Kommanditgesellschaft
Sitz: Detmold
Registergericht: Detmold HRA 246

Komplementärin: Weidmüller Interface Führungsgesellschaft mbH
Sitz: Detmold
Geschäftsführer: Registergericht: Detmold HRB 1677
Thomas H. Hagen, Dr. Willfried Pesch

F_LAB_IEC947-7-1S:20

Summary: The following technical data apply to WTL 6/1:

Rated voltage: 630 V using as measuring disconnecting terminal
 500 V using as disconnecting terminal
 (disconnect-function in conditions without load resp. voltage)

Rated impulse voltage: 6 kV using as measuring disconnecting terminal
 8 kV using as disconnecting terminal

Pollution degree: 3

Overvoltage category: III

Rated current: 41 A

Clampable cross sections:


| | |
|-----------------------|--------------------------|
| solid | 0,5 - 10 mm ² |
| stranded | 1,5 - 10 mm ² |
| flexible | 0,5 - 10 mm ² |
| flexible with ferrule | 0,5 - 6 mm ² |

AWG 20 - AWG 8

Gauge size: A 5

Length of insulation stripping: 12 mm

Test torques: 1,0 Nm for the fixing screw in clamping yoke as manufacturer's data
 0,5 Nm for the fixing screw of disconnecter







Table of content:

| Tests | Page |
|---|------|
| 1 Electrical tests | |
| 1.1.1 Clearance and creepage distance with closed disconnecter (in assembly)..... | 4 |
| 1.1.3 Clearance and creepage distance with opened disconnecter (in assembly) | 5 |
| 1.2.1 Dielectric strength with closed disconnecter | 6 |
| 1.2.1.1 Breakthrough or flashover voltage with closed disconnecter..... | 6 |
| 1.2.2 Dielectric strength with opened disconnecter (within terminal)..... | 7 |
| 1.2.2.1 Breakthrough or flashover voltage with opened disconnecter (within terminal) .. | 7 |
| 1.3.1 Rated impulse voltage with closed disconnecter..... | 8 |
| 1.3.2 Rated impulse voltage with opened disconnecter (within terminal) | 9 |
| 1.4 Temperature rise test | 10 |
| 1.5 Short-time withstand current..... | 12 |
| 1.6 Life time test (additional test)..... | 13 |
| 2 Mechanical tests | |
| 2.1 Attachment of the terminal block on its support | 15 |
| 2.2 Mechanical strength of clamping units..... | 16 |
| 2.3 Test for damage to and accidental loosening of conductors (flexion test) | 19 |
| 2.5 Pull-out force | 19 |
| 2.6 Connecting capacity | 23 |
| 2.7 Rated cross-section (gauge size) | 23 |
| 2.8 Type identification and marking | 24 |
| 3 Thermal characteristics | |
| 3.1 Needle flame test | 25 |
| 4 Miscellaneous tests | |
| 4.1 General function | 26 |

ВЯРНО С
 ОРИГИНАЛА





LAB 12138
Page 4 (26)
Date 17th of October 2003

1 Electrical tests
1.1.1 Clearance and creepage distance with closed disconnecter (in assembly)
1.1.2 Length of insulation stripping

Standard: IEC 60947-1 section 8.3.3.4 / 12.01
DIN VDE 0110-1 / 04.97
LPV 2005

Test performance: Clearance and creepage distances have been measured on 5 new specimen, taking into account the worst case of connected conductors. Screws are tightened with IEC-torque. Clearance and creepage distances are measured between two adjacent terminal blocks and between a terminal block and the metal support to which the terminal block is attached.

Test equipment 215134 gauge CD-15CP Mitutoyo

| Test | Unit | Req. | Results |
|---|------|--------|------------------------------------|
| clearance and creepage distance between adjacent terminal blocks | | | |
| with H07V-U10 | | | path: |
| shortest clearance | mm | ≥ 5,5* | 11 conductor - conductor |
| shortest creepage dist. | mm | ≥ 8* | 11 conductor - conductor |
| with H07V-K6+ferrule | | | |
| shortest clearance | mm | ≥ 5,5* | 9,5 conductor - conductor |
| shortest creepage dist. | mm | ≥ 8* | 9,5 conductor - conductor |
| with H07V-U6 | | | |
| shortest clearance | mm | ≥ 5,5* | 12,6 conductor - conductor |
| shortest creepage dist. | mm | ≥ 8* | 14,0 conductor - conductor |
| clearance and creepage distance between terminal blocks and their support | | | |
| with H07V-U10 | | | path: |
| shortest clearance | mm | ≥ 5,5* | 15,5 clamping yoke - mounting rail |
| shortest creepage dist. | mm | ≥ 8* | 17,2 conductor - mounting rail |
| with H07V-K6+ferrule | | | |
| shortest clearance | mm | ≥ 5,5* | 15,5 clamping yoke - mounting rail |
| shortest creepage dist. | mm | ≥ 8* | 17,2 conductor - mounting rail |
| * Req. for 630V/ 6kV/3 | | | |
| comparative tracking index | CTI | 600 | 600 für Wemid |
| length of insulation stripping | mm | - | 12 ± 0,5 |

Evaluation: The test objects met the requirements.

Note: Taking into account a limited range of clampable cross sections, 0,5 to 6mm² solid, an insulation voltage of 800V is leadable using as measuring disconnecting terminal.

**ВЯРНО С
ОРИГИНАЛА**

МИГ 23 LTD.
СОФИЯ

LAB 12138
 Page 5 (26)
 Date 17th of October 2003

1.1.3 Clearance and creepage distance with opened disconnecter (in assembly) additional test


Standard: IEC 60947-1 section 8.3.3.4 / 12.01
 DIN VDE 0110-1 / 04.97
 LPV 2005

Test performance: Clearance and creepage distances are measured with opened disconnecter across the separating-distance.


Test equipment 215134 gauge CD-15CP Mitutoyo


| Test | Unit | Req. | Results | |
|--|------|------|---------|------------------------------------|
| clearance and creepage distance across the separating distance | | | | |
| shortest clearance | mm | -- | 4,5 | path: current bar - current bar |
| shortest creepage dist. | mm | -- | 4,5 | current bar - current bar |

Evaluation: Data only for information.

ВЯРНО С
 ОРИГИНАЛА





LAB 12138
 Page 6 (26)
 Date 17th of October 2003

1.2.1 Dielectric strength with closed disconnecter

Standard: IEC 60947-1 section 8.3.3.4.1 / 12.01
 IEC 60947-7-1 section 8.4.3 / 07.02
 LPV 2203

1.2.1.1 Breakthrough or flashover voltage with closed disconnecter (additional test)

Standard: LPV 2204


Test performance: Five new terminal blocks are mounted on a rail and wired with the most unfavourable type(s) and cross-section(s) of conductors. Screws are tightened with IEC-torque. The sinusoidal test voltage (50 Hz) is according to IEC 60947-1 table 12A and is applied first between adjacent terminal blocks and then between all terminal blocks connected together and the mounting rail. The test voltage increases with a slew rate of not more than 200V/s and then keeps constant for at least 5s. The voltage then is increased with the same slew rate until breakdown or flashover.

Test equipment: E197 High-voltage test automat RMG500 Sefelec
 M035 Torque driver Stahlwille

| Test | Unit | Req. | Results |
|--|------|------|--|
| dielectric strength with H07V-U10 | kV | 2 | test passed |
| breakdown or flashover voltage - closed disconnecter | kV | > 2 | 7,9 flash over plug socket – plug socket |

Evaluation: The test objects met the requirements.



1.2.2 Dielectric strength with opened disconnecter (within the terminals)

Standard: IEC 60947-1 section 8.3.3.4.1 / 12.01
IEC 60947-7-1 section 8.4.3 / 07.02
LPV 2203

1.2.2.1 Breakthrough or flashover voltage with opened disconnecter (within the terminals) (additional test)

Standard: LPV 2204

Test performance: Five new terminal blocks are mounted on a rail and wired with the most unfavourable type(s) and cross-section(s) of conductors. Screws are tightened with IEC-torque. The sinusoidal test voltage (50 Hz) is according to IEC 60947-1 table 12A and is applied first between adjacent terminal blocks and then between all terminal blocks connected together and the mounting rail. The test voltage increases with a slew rate of not more than 200V/s and then keeps constant for at least 5s. The voltage then is increased with the same slew rate until breakdown or flashover.


Test equipment: E197 High-voltage test automat RMG500 Sefelec
M035 Torque driver Stahlwille


| Test | Unit | Req. | Results |
|--|------|------|--|
| dielectric strength with H07V-U10 | kV | 2 | test passed |
| breakdown or flashover voltage - opened disconnecter | kV | > 2 | 4,3 flashover: current bar – current bar within the terminal |

Evaluation: The test objects met the requirements.



ВЯРНО С
ОРИГИНАЛА





1.3.1 Rated impulse voltage with closed disconnector

Standard: IEC 60947-7-1 section 8.4.3 / 07.02
 LPV 2226


Test performance: Five new terminal blocks are mounted on a rail and wired with the most unfavourable type(s) and cross-section(s) of conductors. Screws are tightened with IEC-torque. The test voltage is applied first between adjacent terminal blocks and then between all terminal blocks connected together and the mounting rail. The test is performed with a waveform 1.2/50µs with at least 1s pause between the pulses and each 10 pulses with alternating polarity.

Test equipment: E119 Transient voltage generator PU12 Haefely

| Test | Unit | Req. | Results |
|---|------|------|----------------------|
| rated impulse voltage with H07V-U10 - closed disconnector | kV | 7,25 | test passed with 7,5 |

Evaluation: The test objects met the requirements.



1.3.2 Rated impulse voltage with opened disconnecter (within the terminals)

Standard: IEC 60947-7-1 section 8.4.3 / 07.02
 LPV 2226

Test performance: Five new terminal blocks are mounted on a rail and wired with the most unfavourable type(s) and cross-section(s) of conductors. Screws are tightened with IEC-torque. The test voltage is applied first between adjacent terminal blocks and then between all terminal blocks connected together and the mounting rail. The test is performed with a waveform 1.2/50µs with at least 1s pause between the pulses and each 10 pulses with alternating polarity.

Test equipment: E119 Transient voltage generator PU12 Haefely


| Test | Unit | Req. | Results |
|--|------|------|-------------|
| rated impulse voltage with H07V-U10 across separating distance | | | |
| - function as measuring disconnecting terminal | kV | 6* | test passed |
| - function as disconnecting terminal | kV | 8** | test passed |

* on the basis of 630 V rated voltage
 ** on the basis of 500 V rated voltage

Evaluation: The test objects met the requirements.




ВЯРНО С
 ОРИГИНАЛА





LAB 12138
 Page 10 (26)
 Date 17th of October 2003

1.4 Temperature rise test
1.4.1 Temperature rise with the rated cross-section
1.4.2 Temperature rise with the largest cross-section
 (additional test)


Standard: IEC 60947-7-1 section 7.2.1 / 07.02
 LPV 2040

Test performance: Each five terminal blocks are mounted on a rail and wired in series with the rated resp. the largest cross-section. The minimum length of each conductor is 1m up to 10mm² cross-section resp. 2m for larger cross-sections. Screws are tightened with IEC-torque or with a higher value specified by the manufacturer. Temperatures are measured with Ni-CrNi thermocouples at the 3 centre terminals. A load current acc. to table 4 or table 5 of IEC 60947-7-1 is applied until steadily temperature is reached.

Test equipment: E042 Current transformer TIL05 600/6 H & B
 E087 Thermometer Comark 2001 Testem
 E017 DMM Typ 169 Keithley
 M104 Torque meter TM 2001 A Holger Clasen
 E166 Voltage drop measuring device self construction

| Test | Unit | Req. | Results | | | | | | | | | | | | |
|--|------------------|------------------|--|------------------|------------------|------------------|---|------|------|------|-------|------|------|------|-------|
| temperature rise test with rated cross-section H07V-U6 | | | | | | | | | | | | | | | |
| torque used | Nm | - | clamping units: 0,8 disconnecter: 0,5 | | | | | | | | | | | | |
| voltage drop conductor - conductor at I = 4,1 A | | | | | | | | | | | | | | | |
| | | | <table border="1"> <thead> <tr> <th>X_{avg}</th> <th>X_{min}</th> <th>X_{max}</th> <th>s</th> </tr> </thead> <tbody> <tr> <td>0,99</td> <td>0,92</td> <td>1,13</td> <td>0,089</td> </tr> <tr> <td>1,00</td> <td>0,87</td> <td>1,30</td> <td>0,179</td> </tr> </tbody> </table> | X _{avg} | X _{min} | X _{max} | s | 0,99 | 0,92 | 1,13 | 0,089 | 1,00 | 0,87 | 1,30 | 0,179 |
| X _{avg} | X _{min} | X _{max} | s | | | | | | | | | | | | |
| 0,99 | 0,92 | 1,13 | 0,089 | | | | | | | | | | | | |
| 1,00 | 0,87 | 1,30 | 0,179 | | | | | | | | | | | | |
| before test | mV | ≤ 3,2 | | | | | | | | | | | | | |
| after test | mV | - | | | | | | | | | | | | | |
| max. change of one terminal | % | ≤ 50 | +15,0 | | | | | | | | | | | | |
| temperature rise at I _N = 41 A | mV | - | +0,17 (1,13 → 1,30) | | | | | | | | | | | | |
| visual examination | K | ≤ 45 | 44 | | | | | | | | | | | | |
| | - | - | no damages visible | | | | | | | | | | | | |


**ВЯРНО С
ОРИГИНАЛА**



| Test | Unit | Req. | Results | | | |
|---|------|-------|---------------------|-----------|-----------|-------|
| temperature rise test with largest cross-section H07V-U10 | | | | | | |
| voltage drop conductor - conductor at I = 5,7 A | | | | | | |
| | | | X_{avg} | X_{min} | X_{max} | s |
| before test | mV | ≤ 3,2 | 1,09 | 0,97 | 1,32 | 0,149 |
| after test | mV | - | 1,05 | 0,95 | 1,25 | 0,124 |
| max. change | % | ≤ 50 | -6,9 | | | |
| of one terminal | mV | - | -0,08 (1,16 → 1,08) | | | |
| temperature rise | K | ≤ 45 | 37 | | | |
| at $I_N = 57$ A | | | | | | |
| visual examination | - | - | no damages visible | | | |

Evaluation: The test objects met the requirements.






LAB 12138
Page 12 (26)
Date 17th of October 2003

1.5 Short-time withstand current
1.5.1 Short-time withstand current with the rated cross-section
1.5.2 Short-time withstand current with the largest cross-section (additional test)

Standard: IEC 60947-7-1 section 7.2.3 / 07.02

Test performance: Each five terminal blocks are mounted on a rail and wired in series with the rated resp. the largest cross-section. Screws are tightened with IEC-torque or with a higher value specified by the manufacturer. Specimens are loaded with a current pulse of 120 A/mm² corresponding to the connected cross-section for 1s.


Test equipment:

| | | |
|------|------------------------------------|-------------------|
| E078 | High current transformer 20kA/4kA | Ruhstrat |
| E149 | Current transformer GSA 200/50 | KWK |
| E166 | Voltage drop measuring device | self construction |
| E160 | 4-Channel-Oscilloscope Kombigraf 4 | Gould |
| E017 | DMM Typ 169 | Keithley |
| M104 | Torque meter TM 2001 A | Holger Clasen |

| Test | Unit | Req. | Results | | | | | | | | | | | | | | | | | | | | | | | | | |
|---|------------------|------------------|--|-------|------------------|------------------|------------------|---|-------------|------|------|------|-------|------------|------|------|------|-------|-------------|------|-------|--|--|-----------------|----|---|---------------------|--|
| short-time withstand current with rated cross-section H07V-U6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| torque used | Nm | - | clamping units: 0,8 disconnecter: 0,5 | | | | | | | | | | | | | | | | | | | | | | | | | |
| applied test current | A | ≥ 720 | 735 | | | | | | | | | | | | | | | | | | | | | | | | | |
| voltage drop conductor - conductor at I = 4,1 A | | | <table border="1"> <thead> <tr> <th></th> <th>X_{avg}</th> <th>X_{min}</th> <th>X_{max}</th> <th>s</th> </tr> </thead> <tbody> <tr> <td>before test</td> <td>1,07</td> <td>0,92</td> <td>1,35</td> <td>0,192</td> </tr> <tr> <td>after test</td> <td>1,23</td> <td>0,91</td> <td>1,88</td> <td>0,436</td> </tr> <tr> <td>max. change</td> <td>≤ 50</td> <td colspan="3">+39,2</td> </tr> <tr> <td>of one terminal</td> <td>mV</td> <td>-</td> <td colspan="2">+0,53 (1,35 → 1,88)</td> </tr> </tbody> </table> | | X _{avg} | X _{min} | X _{max} | s | before test | 1,07 | 0,92 | 1,35 | 0,192 | after test | 1,23 | 0,91 | 1,88 | 0,436 | max. change | ≤ 50 | +39,2 | | | of one terminal | mV | - | +0,53 (1,35 → 1,88) | |
| | X _{avg} | X _{min} | X _{max} | s | | | | | | | | | | | | | | | | | | | | | | | | |
| before test | 1,07 | 0,92 | 1,35 | 0,192 | | | | | | | | | | | | | | | | | | | | | | | | |
| after test | 1,23 | 0,91 | 1,88 | 0,436 | | | | | | | | | | | | | | | | | | | | | | | | |
| max. change | ≤ 50 | +39,2 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| of one terminal | mV | - | +0,53 (1,35 → 1,88) | | | | | | | | | | | | | | | | | | | | | | | | | |
| visual examination | - | - | no damages visible | | | | | | | | | | | | | | | | | | | | | | | | | |
| short-time withstand current with largest cross-section H07V-U10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| applied test current | A | ≥ 1200 | 1330 | | | | | | | | | | | | | | | | | | | | | | | | | |
| voltage drop conductor - conductor at I = 5,7 A | | | <table border="1"> <thead> <tr> <th></th> <th>X_{avg}</th> <th>X_{min}</th> <th>X_{max}</th> <th>s</th> </tr> </thead> <tbody> <tr> <td>before test</td> <td>0,93</td> <td>0,90</td> <td>0,97</td> <td>0,029</td> </tr> <tr> <td>after test</td> <td>0,92</td> <td>0,89</td> <td>0,96</td> <td>0,030</td> </tr> <tr> <td>max. change</td> <td>≤ 50</td> <td colspan="3">-5,3</td> </tr> <tr> <td>of one terminal</td> <td>mV</td> <td>-</td> <td colspan="2">-0,05 (0,94 → 0,89)</td> </tr> </tbody> </table> | | X _{avg} | X _{min} | X _{max} | s | before test | 0,93 | 0,90 | 0,97 | 0,029 | after test | 0,92 | 0,89 | 0,96 | 0,030 | max. change | ≤ 50 | -5,3 | | | of one terminal | mV | - | -0,05 (0,94 → 0,89) | |
| | X _{avg} | X _{min} | X _{max} | s | | | | | | | | | | | | | | | | | | | | | | | | |
| before test | 0,93 | 0,90 | 0,97 | 0,029 | | | | | | | | | | | | | | | | | | | | | | | | |
| after test | 0,92 | 0,89 | 0,96 | 0,030 | | | | | | | | | | | | | | | | | | | | | | | | |
| max. change | ≤ 50 | -5,3 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| of one terminal | mV | - | -0,05 (0,94 → 0,89) | | | | | | | | | | | | | | | | | | | | | | | | | |
| visual examination | - | - | no damages visible | | | | | | | | | | | | | | | | | | | | | | | | | |

Evaluation: The test objects met the requirements.

**ВЯРНО С
ОРИГИНАЛА**



1.6 Life time test (additional test)

Standard: ---

Test performance: Each five terminal blocks are mounted on a rail and wired in series with the rated cross-section. Screws are tightened with IEC-torque. After measuring the voltage drops, the disconnectors were actuated 50 cycles in conditions without load and voltage. Then the complete test assembly was stored for 168h in 130°C dry heat. Finally the test samples have to pass the voltage drop test, after cooling to ambient temperature. The voltage drop was measured with the help of the plug sockets.


Test equipment: E166 Voltage drop-Messplatz Eigenbau
M104 Torque meter TM 2001 A Holger Clasen

| Test | Unit | Req. | Results |
|---|------|-------|--|
| Life time test 130°C / 168h with rated cross-section H07V-U6 | | | |
| torque used | Nm | - | clamping units: 0,8 disconnecter: 0,5 |
| actuating cycles disconnecter | - | 50 | 50 test passed |
| voltage drop left clamping unit conductor – plug-socket at I = 4,1 A | | | |
| | | | <i>X_{avg} X_{min} X_{max} s</i> |
| before test | mV | ≤ 1,6 | 0,24 0,21 0,25 0,015 |
| after test | mV | - | 0,20 0,18 0,20 0,009 |
| max. change of one terminal | % | ≤ 50 | -20,0 |
| | mV | - | -0,05 (0,25 → 0,20) |
| voltage drop right clamping unit conductor – plug-socket at I = 4,1 A | | | |
| | | | <i>X_{avg} X_{min} X_{max} s</i> |
| before test | mV | ≤ 1,6 | 0,24 0,21 0,27 0,022 |
| after test | mV | - | 0,21 0,19 0,24 0,018 |
| max. change of one terminal | % | ≤ 50 | -22,2 |
| | mV | - | -0,06 (0,27 → 0,21) |

Handwritten signature

Handwritten signature


Handwritten signature



LAB 12138
 Page 14 (26)
 Date 17th of October 2003

| Test | Unit | Req. | Results | | | | | | | | | | | | | | | | | | | | |
|---|-----------|-----------|---|-----------|-----------|-----------|---|-------------|----|-------|----------------------------|------------|----|---|----------------------------|-------------|---|------|------|-----------------|----|---|---------------------|
| Life time test 130°C / 168h with rated cross-section H07V-U6 | | | | | | | | | | | | | | | | | | | | | | | |
| torque used | Nm | - | clamping units: 0,8 disconnecter: 0,5 | | | | | | | | | | | | | | | | | | | | |
| actuating cycles disconnecter | - | 50 | 50 test passed | | | | | | | | | | | | | | | | | | | | |
| voltage drop disconnecter plug-socket - plug-socket at I = 4,1 A | | | | | | | | | | | | | | | | | | | | | | | |
| | | | <table border="1"> <thead> <tr> <th>X_{avg}</th> <th>X_{min}</th> <th>X_{max}</th> <th>s</th> </tr> </thead> <tbody> <tr> <td>before test</td> <td>mV</td> <td>≤ 3,2</td> <td>0,30 0,28 0,33 0,019</td> </tr> <tr> <td>after test</td> <td>mV</td> <td>-</td> <td>0,30 0,28 0,31 0,013</td> </tr> <tr> <td>max. change</td> <td>%</td> <td>≤ 50</td> <td>+3,3</td> </tr> <tr> <td>of one terminal</td> <td>mV</td> <td>-</td> <td>+0,01 (0,30 → 0,31)</td> </tr> </tbody> </table> | X_{avg} | X_{min} | X_{max} | s | before test | mV | ≤ 3,2 | 0,30 0,28 0,33 0,019 | after test | mV | - | 0,30 0,28 0,31 0,013 | max. change | % | ≤ 50 | +3,3 | of one terminal | mV | - | +0,01 (0,30 → 0,31) |
| X_{avg} | X_{min} | X_{max} | s | | | | | | | | | | | | | | | | | | | | |
| before test | mV | ≤ 3,2 | 0,30 0,28 0,33 0,019 | | | | | | | | | | | | | | | | | | | | |
| after test | mV | - | 0,30 0,28 0,31 0,013 | | | | | | | | | | | | | | | | | | | | |
| max. change | % | ≤ 50 | +3,3 | | | | | | | | | | | | | | | | | | | | |
| of one terminal | mV | - | +0,01 (0,30 → 0,31) | | | | | | | | | | | | | | | | | | | | |
| visual examination | - | - | no damages visible | | | | | | | | | | | | | | | | | | | | |

Evaluation: The test objects met the requirements.



LAB 12138
 Page 15 (26)
 Date 17th of October 2003

2 Mechanical tests
2.1 Attachment of the terminal block on its support

Standard: IEC 60947-7-1 section 8.3.2 / 07.02

Test performance: Five new terminal blocks are mounted on a test rail with min. dimensions. A steel pin with a diameter acc. to table 3 of IEC 60947-7-1 is clamped successively in each clamping unit. Screws are tightened with IEC-torque resp. 110% of the torque stated by the manufacturer. In a distance of 100 mm to the clamping point a force acc. to table 3 of IEC 60947-7-1 is applied to the pin regularly and without shocks in both vertical directions. During the test, no terminal block shall work free from its rail or support, nor suffer any other damage.

Test equipment: M123 Push-/pull-force meter Erichsen
 695805/2 Test rail mounting rail 35/7,5 min Weidmüller
 M029 Torque driver Stahlwille


| Test | Unit | Req. | Results |
|---|------|------|--------------------|
| torque used | Nm | - | 0,8 |
| fixing of the terminal block on its support | N | ≥ 5 | test passed |
| visual examination | - | - | no damages visible |

Evaluation: The test objects met the requirements.

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]



LAB 12138
 Page 16 (26)
 Date 17th of October 2003

2.2 Mechanical strength of clamping units
2.2.1 Test with nominal torque


Standard: IEC 60947-7-1 section 8.3.3.1 / 07.02
 LPV 2201

Test performance: Five new terminal blocks are mounted on a rail. Conductors of the rated cross-section are connected and disconnected five times. Screws are tightened with IEC-torque resp. 110% of the torque stated by the manufacturer. After every loosening a new conductor will be used.
 Voltage drop is measured before and after the test with the smallest flexible and the rated rigid cross-section.

| | |
|--|--------------|
| size of thread: | M 3,5 |
| IEC- torque clamping screw: | 0,8 Nm |
| torque acc. manufacturer clamping screw: | 1,0 Nm |
| test torque + 10%: | 1,1 Nm |
| size of thread: | M 3 |
| IEC- torque disconnecter screw: | 0,5 Nm |
| smallest cross-section, flexible: | H05V-K0,5 |
| test conductor, rigid: | H07V-U10 |


Test equipment: E166 Voltage drop-Messplatz self construction
 M104 Torque meter TM 2001 Clasen

Measuring spots:



Note: Voltage drops are measured with the help of the plug-sockets.

ВЯРНО С
 ОРИГИНАЛА



| Test | Unit | Req. | Results | | | | | | | | | | | | | | | | | | | | |
|---|---------------------|------------------|--|------------------|------------------|------------------|---|------|------|------|-------|------|------|------|-------|-------|--|--|--|---------------------|--|--|--|
| voltage drop conductor - current bar, left with H05V-K0,5 at I= 0,6A before test after test max. change of one terminal H07V-U10 at I = 5,7 A before test after test max. change of one terminal five connections and disconnections visual examination | | | <table border="1"> <thead> <tr> <th>X_{avg}</th> <th>X_{min}</th> <th>X_{max}</th> <th>s</th> </tr> </thead> <tbody> <tr> <td>0,24</td> <td>0,23</td> <td>0,25</td> <td>0,009</td> </tr> <tr> <td>0,26</td> <td>0,24</td> <td>0,28</td> <td>0,016</td> </tr> <tr> <td colspan="4">+17,3</td> </tr> <tr> <td colspan="4">+0,04 (0,23 → 0,27)</td> </tr> </tbody> </table> | X _{avg} | X _{min} | X _{max} | s | 0,24 | 0,23 | 0,25 | 0,009 | 0,26 | 0,24 | 0,28 | 0,016 | +17,3 | | | | +0,04 (0,23 → 0,27) | | | |
| | X _{avg} | X _{min} | X _{max} | s | | | | | | | | | | | | | | | | | | | |
| | 0,24 | 0,23 | 0,25 | 0,009 | | | | | | | | | | | | | | | | | | | |
| | 0,26 | 0,24 | 0,28 | 0,016 | | | | | | | | | | | | | | | | | | | |
| | +17,3 | | | | | | | | | | | | | | | | | | | | | | |
| | +0,04 (0,23 → 0,27) | | | | | | | | | | | | | | | | | | | | | | |
| | mV | ≤ 1,6 | | | | | | | | | | | | | | | | | | | | | |
| | mV | - | | | | | | | | | | | | | | | | | | | | | |
| | % | ≤ 50 | | | | | | | | | | | | | | | | | | | | | |
| | mV | - | | | | | | | | | | | | | | | | | | | | | |
| mV | ≤ 1,6 | | | | | | | | | | | | | | | | | | | | | | |
| mV | - | | | | | | | | | | | | | | | | | | | | | | |
| % | ≤ 50 | | | | | | | | | | | | | | | | | | | | | | |
| mV | - | | | | | | | | | | | | | | | | | | | | | | |
| - | - | - | test passed | | | | | | | | | | | | | | | | | | | | |
| - | - | - | no damages visible | | | | | | | | | | | | | | | | | | | | |


| Test | Unit | Req. | Results | | | | | | | | | | | | | | | | | | | | |
|--|---------------------|------------------|---|------------------|------------------|------------------|---|------|------|------|-------|------|------|------|-------|------|--|--|--|---------------------|--|--|--|
| voltage drop conductor - current bar, right with H05V-K0,5 at I= 0,6A before test after test max. change of one terminal H07V-U10 at I = 5,7 A before test after test max. change of one terminal five connections and disconnections visual examination | | | <table border="1"> <thead> <tr> <th>X_{avg}</th> <th>X_{min}</th> <th>X_{max}</th> <th>s</th> </tr> </thead> <tbody> <tr> <td>0,26</td> <td>0,23</td> <td>0,29</td> <td>0,026</td> </tr> <tr> <td>0,24</td> <td>0,23</td> <td>0,25</td> <td>0,008</td> </tr> <tr> <td colspan="4">+8,6</td> </tr> <tr> <td colspan="4">+0,02 (0,23 → 0,25)</td> </tr> </tbody> </table> | X _{avg} | X _{min} | X _{max} | s | 0,26 | 0,23 | 0,29 | 0,026 | 0,24 | 0,23 | 0,25 | 0,008 | +8,6 | | | | +0,02 (0,23 → 0,25) | | | |
| | X _{avg} | X _{min} | X _{max} | s | | | | | | | | | | | | | | | | | | | |
| | 0,26 | 0,23 | 0,29 | 0,026 | | | | | | | | | | | | | | | | | | | |
| | 0,24 | 0,23 | 0,25 | 0,008 | | | | | | | | | | | | | | | | | | | |
| | +8,6 | | | | | | | | | | | | | | | | | | | | | | |
| | +0,02 (0,23 → 0,25) | | | | | | | | | | | | | | | | | | | | | | |
| | mV | ≤ 1,6 | | | | | | | | | | | | | | | | | | | | | |
| | mV | - | | | | | | | | | | | | | | | | | | | | | |
| | % | ≤ 50 | | | | | | | | | | | | | | | | | | | | | |
| | mV | - | | | | | | | | | | | | | | | | | | | | | |
| mV | ≤ 1,6 | | | | | | | | | | | | | | | | | | | | | | |
| mV | - | | | | | | | | | | | | | | | | | | | | | | |
| % | ≤ 50 | | | | | | | | | | | | | | | | | | | | | | |
| mV | - | | | | | | | | | | | | | | | | | | | | | | |
| - | - | - | test passed | | | | | | | | | | | | | | | | | | | | |
| - | - | - | no damages visible | | | | | | | | | | | | | | | | | | | | |

Evaluation:

The test objects met the requirements.

Handwritten signatures and initials on the right side of the page.

Handwritten signature at the bottom left.



LAB 12138
 Page 18 (26)
 Date 17th of October 2003

2.2.2 Test with twice the nominal torque
 (additional test)

Standard: taken pattern from IEC 60947-7-1 section 8.3.3.1 / 07.02
 LPV 2201


Test performance: Five new terminal blocks are mounted on a rail. Conductors of the largest cross section are connected and disconnected five times. Screws are tightened with twice the nominal torque acc. to A 1040. After every loosening a new conductor will be used. After the test the torque with no load shall not be more than 0,05Nm for threads up to size M 3.5 resp. 0,1Nm for larger sizes.

thread of clamping screw: M 3,5
thread of disconnector screw: M 3
 2× nominal torque acc. to A 1040
clamping screw: 1,6 Nm
 max. torque of
screw of disconnector: 0,8 Nm

Test equipment: M104 Torque meter TM 2001 Clasen

| Test | Unit | Req. | Results | | | |
|--|------|--------|-------------|-----------|-----------|------|
| Five connections and disconnections - clamping screw - screw of disconnector | Nm | 1,6 | test passed | | | |
| | Nm | 0,8 | test passed | | | |
| torque with no load after the test - clamping screw - screw of disconnector | | | X_{avg} | X_{min} | X_{max} | s |
| | Nm | ≤ 0,05 | 0,03 | 0,02 | 0,05 | 0,01 |
| | Nm | ≤ 0,05 | 0,01 | 0,01 | 0,01 | 0 |

Evaluation: The test objects met the requirements.



LAB 12138
 Page 19 (26)
 Date 17th of October 2003

2.3 Test for damage to and accidental loosening of conductors (flexion test)
2.4 Pull-out test
2.5 Pull-out force

Standard: IEC 60947-7-1 section 8.3.3.2 / 07.02
 LPV 2202

Test performance: The test is performed on each five new clamping units with every clampable type of conductor and

- with the smallest clampable cross-section,
- with the rated cross-section,


and, if applicable

- with the largest clampable cross-section, if larger than the rated cross-section,
- with the maximum number of conductors of the smallest cross-section simultaneously connectable,
- with the maximum number of conductors of the largest cross-section simultaneously connectable,
- with the maximum number of conductors of the smallest and largest cross-section simultaneously connectable.

Screws are tightened with IEC-torque. Each conductor is subjected to circular motions with a mass suspended from its end. After the flexion test a static pull-force is applied to every conductor for 1 min. Then the pull-out force is determined at a speed of 30mm/min. Ferrules of the following type have been crimped with PZ 6/5:

| | | | |
|-----------------------|-----------|----------|------------|
| conductor H05V-K0,5: | H 0,5/10 | Cat.-no. | 9004050000 |
| conductor H05V-K0,75: | H 0,75/10 | Cat.-no. | 0542500000 |
| conductor H05V-K1: | H 1,0/10 | Cat.-no. | 0282800000 |
| conductor H07V-K 1,5 | H 1,5/12 | Cat.-no. | 9004060000 |
| conductor H07V-K 2,5 | H 2,5/12 | Cat.-no. | 0186100000 |
| conductor H07V-K 6 | H 6/12 | Cat.-no. | 0191900000 |

Test equipment: M104 Torque meter TM 2001 Clasen
 M093 Universal test machine 1445 Zwick




| Test | Unit | Req. | Results |
|--------------------------|------|------|-------------|
| flexion test | | | |
| 1 × H05V-U0,5 | kg | 0,3 | test passed |
| 1 × H05V-K0,5 | kg | 0,3 | test passed |
| 1 × H07V-K10 (*) | kg | 2,0 | test passed |
| 1 × H07V-U10 | kg | 2,0 | test passed |
| 1 × H07V-R10 (*) | kg | 2,0 | test passed |
| 1 × H07V-K6 + ferrule | kg | 1,4 | test passed |
| 1 × AWG 20/1 | kg | 0,3 | test passed |
| 1 × AWG 20/7 | kg | 0,3 | test passed |
| 1 × AWG 20/19 | kg | 0,3 | test passed |
| 1 × AWG 8/7 (*) | kg | 2,0 | test passed |
| 2 × H05V-U0,5 | kg | 0,3 | test passed |
| 2 × H05V-K0,5 | kg | 0,3 | test passed |
| 2 × H05V-K0,5 + ferrule | kg | 0,3 | test passed |
| 2 × H05V-U0,75 | kg | 0,4 | test passed |
| 2 × H05V-K0,75 | kg | 0,4 | test passed |
| 2 × H05V-K0,75 + ferrule | kg | 0,4 | test passed |
| 2 × H05V-U1,0 | kg | 0,4 | test passed |
| 2 × H05V-K1,0 | kg | 0,4 | test passed |
| 2 × H05V-K1,0 + ferrule | kg | 0,4 | test passed |
| 2 × H07V-U1,5 | kg | 0,4 | test passed |
| 2 × H07V-K1,5 | kg | 0,4 | test passed |
| 2 × H07V-K1,5 + ferrule | kg | 0,4 | test passed |
| 2 × H07V-U 2,5 | kg | 0,7 | test passed |
| 2 × H07V-K2,5 | kg | 0,7 | test passed |
| 2 × H07V-K2,5 + ferrule | kg | 0,7 | test passed |

(*) torque raised up to 1,0 Nm

[Handwritten signature]

[Handwritten signature]


[Handwritten signature]



| Test | Unit | Req. | Results |
|--------------------------|------|------|-------------|
| pull-out test | | | |
| 1 × H05V-U0,5 | N | 30 | test passed |
| 1 × H05V-K0,5 | N | 30 | test passed |
| 1 × H07V-U10 | N | 90 | test passed |
| 1 × H07V-R10 (*) | N | 90 | test passed |
| 1 × H07V-K10 (*) | N | 90 | test passed |
| 1 × H07V-K6 + ferrule | N | 80 | test passed |
| 1 × AWG 20/1 | N | 30 | test passed |
| 1 × AWG 20/7 | N | 30 | test passed |
| 1 × AWG 20/19 | N | 30 | test passed |
| 1 × AWG 8/7 (*) | N | 90 | test passed |
| 2 × H05V-U0,5 | N | 30 | test passed |
| 2 × H05V-K0,5 | N | 30 | test passed |
| 2 × H05V-K0,5 + ferrule | N | 30 | test passed |
| 2 × H05V-U0,75 | N | 30 | test passed |
| 2 × H05V-K0,75 | N | 30 | test passed |
| 2 × H05V-K0,75 + ferrule | N | 30 | test passed |
| 2 × H05V-U1,0 | N | 35 | test passed |
| 2 × H05V-K1,0 | N | 35 | test passed |
| 2 × H05V-K1,0 + ferrule | N | 35 | test passed |
| 2 × H07V-U1,5 | N | 40 | test passed |
| 2 × H07V-K1,5 | N | 40 | test passed |
| 2 × H07V-K1,5 + ferrule | N | 40 | test passed |
| 2 × H07V-U2,5 | N | 50 | test passed |
| 2 × H07V-K2,5 | N | 50 | test passed |
| 2 × H07V-K2,5 + ferrule | N | 50 | test passed |

(*) torque raised up to 1,0 Nm








| Test | Unit | Req. | Results | | | |
|--------------------------|------|------|------------------|------------------|------------------|-------|
| | | | X _{avg} | X _{min} | X _{max} | s |
| pull-out force | | | | | | |
| 1 × H05V-U0,5 | N | > 30 | 115 | 100 | 121 | 8,9 |
| 1 × H05V-K0,5 | N | > 30 | 84 | 71 | 100 | 10,8 |
| 1 × H07V-U10 | N | > 90 | 240 | 202 | 306 | 41,6 |
| 1 × H07V-R10 (*) | N | > 90 | 357 | 262 | 466 | 85,7 |
| 1 × H07V-K10 (*) | N | > 90 | 397 | 248 | 589 | 139,4 |
| 1 × H07V-K 6 + ferrule | N | > 80 | 268 | 198 | 462 | 110 |
| 1 × AWG 20/1 | N | > 30 | 133 | 131,8 | 134 | 0,89 |
| 1 × AWG 20/7 | N | > 30 | 121 | 94 | 138 | 20,3 |
| 1 × AWG 20/19 | N | > 30 | 140 | 129 | 146 | 7,3 |
| 1 × AWG 8/7 (*) | N | > 90 | 377 | 190 | 505 | 129,3 |
| 2 × H05V-U0,5 | N | > 30 | 92 | 57 | 126 | 31,9 |
| 2 × H05V-K0,5 | N | > 30 | 80 | 57 | 105 | 18,5 |
| 2 × H05V-K0,5 + ferrule | N | > 30 | 105 | 84 | 117 | 84,1 |
| 2 × H05V-U0,75 | N | > 30 | 182 | 167 | 191 | 12,2 |
| 2 × H05V-K0,75 | N | > 30 | 127 | 88 | 145 | 23,3 |
| 2 × H05V-K0,75 + ferrule | N | > 30 | 120 | 92 | 141 | 25,2 |
| 2 × H05V-U1,0 | N | > 35 | 178 | 122 | 201 | 31,9 |
| 2 × H05V-K1,0 | N | > 35 | 131 | 110 | 149 | 19,8 |
| 2 × H05V-K1,0 + ferrule | N | > 35 | 184 | 126 | 218 | 40,3 |
| 2 × H07V-U1,5 | N | > 40 | 231 | 206 | 258 | 21,6 |
| 2 × H07V-K1,5 | N | > 40 | 278 | 200 | 327 | 52,8 |
| 2 × H07V-K1,5 + ferrule | N | > 40 | 274 | 242 | 299 | 21,5 |
| 2 × H07V-U2,5 | N | > 50 | 351 | 293 | 406 | 45,5 |
| 2 × H07V-K2,5 | N | > 50 | 299 | 247 | 339 | 36,3 |
| 2 × H07V-K2,5 + ferrule | N | > 50 | 214 | 147 | 221 | 56,0 |

(*) torque raised up to 1,0 Nm

Evaluation: The test objects met the requirements.



LAB 12138
Page 23 (26)
Date 17th of October 2003



2.6 Connecting capacity
2.7 Rated cross-section (gauge size)

Standard: IEC 60947-7-1 section 7.1.6 / 07.02

Test performance: The appropriate gauge shall be inserted by its inherent weight.

| Test | Req. | Results |
|---------------------|------|------------|
| connecting capacity | | |
| gauge size | A5 | insertable |

Evaluation: The test objects met the requirements.




2.8 Type identification and marking


Standard: IEC 60947-7-1 section 5 und 7.1.4 / 07.02

Test performance: A terminal block shall be marked in a durable and legible manner with


- the name of the manufacturer or a trade mark by which the manufacturer can be readily identified
- a type reference permitting its identification in order to obtain relevant information from the manufacturer or his catalogue.

A terminal block shall have provision, or at least space, for identification marks or numbers for each clamping unit or terminal assembly related to the circuit of which it forms a part.



| Test | Req. | Results |
|---|-----------|---|
| inscriptions | | |
| mark of origin | necessary | Weidmüller  |
| type identification | necessary | WTL 6/1 |
| relevant standard | - | --- |
| rated cross-section | - | 6 mm ² |
| rated insulation voltage | - | 400V (caused by the results of the insulation tests, a changing to 500V is possible) |
| marking | | |
| area for inscriptions or grooves and the like to fix labels | present | present |



Inscriptions:



Evaluation: The test objects met the requirements.

LAB 12138
 Page 25 (26)
 Date 17th of October 2003

3 Thermal characteristics
3.1 Needle flame test

Standard: IEC 60947-7-1 section 7.1.5 / 07.02
 IEC 60695-2-2 / 04.91



Test performance: The test flame is applied for 10s. For insulation walls <1mm and/or area <100mm² the flame is applied for 5s. After flame is removed, the duration of burning in the case of ignition is measured. The test is passed if duration of burning is <30s and if burning or glowing particles falling down cause no ignition of the tissue paper.

Test equipment: E177 Thermometer T202KC Digitron

| Test | Unit | Req. | Results |
|--------------------------|------|------|---------|
| flame application time | s | 10 | 10 |
| duration of burning | s | < 0 | 0 |
| ignition of tissue paper | - | none | none |

Evaluation: The test objects met the requirements.







- 4** **Miscellaneous tests**
- 4.1** **General function**
- 4.1.1** **Handling (additional test)**
- 4.1.2** **Function of accessory**

Standard: Taking pattern from LPV 2224

Test performance: The general function, handling and function of accessory are criticised subjectively.

| Test | Results |
|--|--|
| General function | no complaints |
| Handling | no complaints |
| mounting and dismounting | no complaints with screw driver SD 0,8 × 4 |
| connection and disconnection of conductors | no complaints with screw driver DIN 5264-A 0,8 × 4 |
| Function of accessory | |
| screw driver | SD 0,8 × 4 usable (cat.-no. 9024030000) DIN 5264-A 0,6 × 3,5 usable (cat.-no. 9008340000) |
| cross connector | QL 2 - 10 |
| cover | WAP/WTL |
| labels | DEK8 and WS 12/6,5 |
| end brackets | WEW 35/2 |





СПИСЪК на приложените лабораторни изпитания

1. Типово изпитание на клема WTL6/1, съгласно DIN EN 60947-7-1 и LPP1129;
2. Изпитване на вибрации на клема WTL6/1, съгласно DIN EN 50155;
3. Изпитване на клема WTL6/1 за работа в агресивна среда SO2.
4. Лабораторни изпитания на материала Wemid за електрически, механични, термични и други свойства.
5. Типово изпитание на разединител с цилиндрични стопяеми вложки OPV10/3, съгласно EN60947-1 и EN60947-3.

Дата: 08.08.2018

на основание чл. 2 от ЗЗЛД

Deutsche Akkreditierungsstelle GmbH

Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1 subsection 1 AkkStelleGBV

Signatory to the Multilateral Agreements of EA, ILAC and IAF for Mutual Recognition

Accreditation



The Deutsche Akkreditierungsstelle GmbH attests that the testing laboratory

VDE Prüf- und Zertifizierungsinstitut GmbH

at the following locations:

Merianstraße 28, 63069 Offenbach
Goethering 43, 63067 Offenbach
Landsberger Allee 378a, 12681 Berlin

is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out tests in the following fields:

Verification of technical documentation and investigation of airborne acoustical noise of equipment and machines listed in this annex according to article 12 of Directive 2000/14/EG; Measurement of sound power level for equipment and machines according to article 13 of Directive 2000/14/EG; Safety of machines as defined by Directive 2006/42/EG for products listed in the annex;

Type testing covered by the authorization for granting the GS Mark according to the German Product Safety Act (ProdSG) for products listed in the annex;

Safety of electrical equipment and their components; Electronic components; Industrial low-voltage switchgear and controlgear and installations; Electric tools and power drive systems; Cables and cords; Laboratory equipment; Photometry; Optics; Energy efficiency; Environmental tests and methods for performance measuring; Accumulators and batteries; Electromagnetic Compatibility (EMC) and radio; Acoustics and noise emission; Electric bicycles (Pedelec);

Analytic chemistry; Functional safety; Energy Star Program (EPA) for the products listed in the annex; Technical Directive for power generation units and power installations - Part 3: Determination of electric characteristics of power generation units for medium-voltage power grid, high-voltage grid and supergrid; Construction products;

Testing of construction products (system for evaluation and inspection of performance reliability 3) according to Regulation (EU) No. 305/2011 for determination of harmonised conditions for marketing of construction products (Constructional Products Regulation CPR)

The accreditation certificate shall only apply in connection with the notice of accreditation of 23.03.2018 with the accreditation number D-PL-12061-01 and is valid until 16.06.2021. It comprises the cover sheet, the reverse side of the cover sheet and the following annex with a total of 197 pages на основании чл. 2 от ЗЗЛД

Registration number of the certificate: **D-PL-12061-01-01**

Frankfurt am Main,
23.03.2018

Dipl.-Ing. (FH) Ralf Egner
Head of Division

Translation issued:
23.03.2018

This document is a translation. The definitive version is the original German accreditation certificate.

See notes overleaf.



Deutsche Akkreditierungsstelle GmbH

Office Berlin
Spittelmarkt 10
10117 Berlin

Office Frankfurt am Main
Europa-Allee 52
60327 Frankfurt am Main

Office Braunschweig
Bundesallee 100
38116 Braunschweig

The publication of extracts of the accreditation certificate is subject to the prior written approval by Deutsche Akkreditierungsstelle GmbH (DAkkS). Exempted is the unchanged form of separate disseminations of the cover sheet by the conformity assessment body mentioned overleaf.

No impression shall be made that the accreditation also extends to fields beyond the scope of accreditation attested by DAkkS.

The accreditation was granted pursuant to the Act on the Accreditation Body (AkkStelleG) of 31 July 2009 (Federal Law Gazette I p. 2625) and the Regulation (EC) No 765/2008 of the European Parliament and of the Council of 9 July 2008 setting out the requirements for accreditation and market surveillance relating to the marketing of products (Official Journal of the European Union L 218 of 9 July 2008, p. 30). DAkkS is a signatory to the Multilateral Agreements for Mutual Recognition of the European co-operation for Accreditation (EA), International Accreditation Forum (IAF) and International Laboratory Accreditation Cooperation (ILAC). The signatories to these agreements recognise each other's accreditations.


The up-to-date state of membership can be retrieved from the following websites:

EA: www.european-accreditation.org

ILAC: www.ilac.org

IAF: www.iaf.nu

ВЯРНО С
ОРИГИНАЛА



АМО 90

АМО 90 ЕООД
БЮРО ЗА ПРЕВОДИ
1000 София
ул. Г.С.Раковски 127, офис 336
тел. 0889 319 040
0878 314 090

3200 Бяла Слатина
ул. Климент Охридски 63
тел. 0915 827 48
E-mail: amo90@abv.bg
www.amo90.com

Превод от немски език



Немска акредитираща служба

Немска акредитираща служба ГмбХ

Съгласно параграф 8, ал. 1 от AkkStelleG във връзка с параграф 1, ал. 1 от AkkStelleGBV

е подписала многостранното споразумение на EA, ILAC и IAF за взаимно признаване

АКРЕДИТАЦИЯ



Немска акредитираща служба ГмбХ с настоящето потвърждава, че изпитателната лаборатория

Weidmüllerinterface GmbH&Co. KG
Централна Лаборатория
ул. Орбкер 48, 32758 Детмолд

е компетентна да извършва изпитания по DIN EN ISO/IEC 17025:2005 в следните области:

Безопасност на електрически средства за производство, индустриални уреди за ниско напрежение, куплунги, изпитания на околната среда и електромагнитна съвместимост.

Сертификатът за акредитация е валиден само за периода от 16.07.2015 до 06.03.2019 с акредитационен номер D-PL-12095-01. Той се състои от настоящата заглавна страница, задната страница и приложението, обхващащо общо 10 страници.

Регистрационен номер на сертификата: **D-PL-12095-01-00**

Франкфурт на Майн, 16.07.2015 г.



инж. Р. Егнер подпис не се чете
Ръководител отдел

Виж забележките отзад.


Подписаната, Аксиния Асенова Ганева, удостоверявам верността на превода направен от мен от английски и немски на български език на приложения документ – Акредитация. Преводът се състои от 1 страница.

на основание чл. 2 от ЗЗЛД

Превода



ВЕРНО С
РИГИНАЛА



Deutsche Akkreditierungsstelle GmbH

Bellehene gemäß § 8 Absatz 1 AkkStelleG i.V.m. § 1 Absatz 1 AkkStelleGBV
Unterzeichnerin der Multilateralen Abkommen
von EA, ILAC und IAF zur gegenseitigen Anerkennung

Akkreditierung



Die Deutsche Akkreditierungsstelle GmbH bestätigt hiermit, dass das Prüflaboratorium

Weidmüller Interface GmbH & Co. KG
Zentrallabor
Orbker Straße 48, 32758 Detmold

die Kompetenz nach DIN EN ISO/IEC 17025:2005 besitzt, Prüfungen in folgenden Bereichen durchzuführen:

**Sicherheit elektrischer Betriebsmittel, Industrielle Niederspannungsgeräte,
Steckverbinder, Umweltprüfungen, Elektromagnetische Verträglichkeit (EMV)**

Die Akkreditierungsurkunde gilt nur in Verbindung mit dem Bescheid vom 16.07.2015 mit der Akkreditierungsnummer D-PL-12095-01 und ist gültig bis 06.03.2019. Sie besteht aus diesem Deckblatt, der Rückseite des Deckblatts und der folgenden Anlage mit insgesamt 10 Seiten.

Registrierungsnummer der Urkunde: D-PL-12095-01-00

на основании чл. 2 от ЗЗЛД

Frankfurt am Main, 16.07.2015

Siehe Hinweise auf der Rückseite

Im Auftrag
Abteilungsleiter



АМО 90

АМО 90 ЕООД
БЮРО ЗА ПРЕВОДИ
1000 София
ул. Г.С.Раковски 127, офис 336
тел. 0889 319 040
0878 314 090

3200 Бяла Слатина
ул. Климент Охридски 63
тел. 0915 827 48
E-mail: amo90@abv.bg
www.amo90.com

Превод от немски език

Уведомление на орган в рамките на директивата за техническа хармонизация

от : Централен орган на провинциите за до: Европейска комисия
безопасност (ZLS) Генерална дирекция РАСТЕЖ
Розенкавалиерплац 2 200 Rue de la Loi,
D-8 1925 Мюнхен В-1049 Брюксел.
Германия Други държави-членки

референция :

Законодателство: 2000/1 4 / ЕО Емисии на шум в околната
среда на съоръжения за използване на открито

Име на органа, адрес, телефон, факс, имейл, уебсайт :

Институт за изпитване и сертифициране VDE /VDE - Prüf- und Zertifizierungsinstitut GmbH/
Мерианщрасе 28
63069 Офенбах
Германия
Тел : +49 (0) 69 8306 0
факс : +49 (0) 69 8306 555
Email : vde-institut@vde.com
Website : www.vde.com

Орган :

NB 0366

Създаден: неизвестно (Уведомления до 2006 не са включени в тези списъци) | последна
актуализация : 15/08/2016

Органът официално е акредитиран по:


EN 45012 - EN ISO/IEC 17021

EN 45001 - EN ISO/IEC 17025

EN 45011 - EN ISO/IEC 17065

Наименование на Националния орган по акредитация (NAB): DAkkS (Deutsche
Akkreditierungsstelle GmbH)

Акредитацията обхваща категориите продукти и процедурите за оценка на
съответствието, засегнатите от това уведомление : Да




Задачи, изпълнени от органа :

Създаден : 03/05/2016 | последна актуализация : 03/05/2016


| Продуктова линия, продукт /използване по предназначение/продуктова гама | Процедура/модули | Анекси или членове на директиви |
|--|---|--|
| <p>Оборудване, обект на ограничение на шума</p> <ul style="list-style-type: none"> - уплътнителни машини (само вибрационни и не-вибрационни валежи, вибрационни плочи и трамбовки) - компресори (<350 кВт) - бетонни къртачи и къртачни чукове, ръчни - хидравлични агрегати - Косачки за трева (с изключение на земеделска и горска техника и многоцелеви устройства, чийто основен моторизиран елемент има инсталирана мощност над 20 кВт) - тример за трева / тример за тревата в краищата на лехи - Мотокултиватори (<3 кВт) - Електрически генератори (<400 кВт) - заваръчни генератори | <p>Пълно гарантиране на качеството</p> <p>Вътрешен контрол на продукцията с оценка на техническата документация и периодичен контрол</p> <p>Верификация на модула</p> | <p>Annex VIII</p> <p>Annex VI</p> <p>Annex VII</p> |

Подписаната, Аксиния Асенова Ганева, удостоверявам верността на превода направен от мен от английски и немски на български език на приложения документ – Уведомление на орган в рамките на директивата за техническа хармонизация. Преводът се състои от 2 страници

на основание чл. 2 от
Преводът 33ЛД



Handwritten signatures and scribbles.



Handwritten signature at the bottom left.

Notification of a Body in the framework of a technical harmonization directive

From : Zentralstelle der Länder für
Sicherheitstechnik (ZLS)
Rosenkavalierplatz 2
D-81925 München
Germany

To : **European Commission**
GROWTH Directorate-General
200 Rue de la Loi,
B-1049 Brussels.
Other Member States

Reference :

Legislation : 2000/14/EC Noise emission in the environment by equipment for use outdoors

Body name, address, telephone, fax, email, website :

VDE - Prüf- und Zertifizierungsinstitut GmbH
Merianstraße 28
63069 Offenbach
Germany
Phone : +49 (0) 69 8306 0
Fax : +49 (0) 69 8306 555
Email : vde-institut@vde.com
Website : www.vde.com

Body :

NB 0366



Created : Unknown (Notifications pre-dating 2006 are not available in these lists) | **Last update :** 15/08/2016

The body is formally accredited against :

EN 45012 - EN ISO/IEC 17021
EN 45001 - EN ISO/IEC 17025
EN 45011 - EN ISO/IEC 17065

Name of National Accreditation Body (NAB) : DAkkS (Deutsche Akkreditierungsstelle GmbH)

The accreditation covers the product categories and conformity assessment procedures concerned by this notification : Yes




Tasks performed by the Body :

Created : 03/05/2016 | Last update : 03/05/2016

| Product family, product /Intended use/Product range | Procedure/Modules | Annexes or articles of the directives |
|--|--|---------------------------------------|
| Equipment subject to noise limits - compaction machines (only vibrating and non-vibrating rollers, vibratory plates and vibratory rammers) - compressors (< 350 kW) - concrete-breakers and picks, hand-held - hydraulic power packs - lawnmowers (excluding agricultural and forestry equipment, and multi-purpose devices, the main motorised component of which has an installed power of more than 20 kW) - lawn trimmers/lawn edge trimmers - motor hoes (< 3 kW) - power generators (< 400 kW) - welding generators | Full quality assurance Internal control of production with assessment of technical documentation and periodical checking Unit verification | Annex VIII Annex VI Annex VII |

Handwritten signatures and scribbles.



Handwritten signature.

Инструкции за транспортиране, складиране, монтиране, вкл. въртящия момент на затягане на клемовите съединения, обслужване и поддържане

I. Материалите се доставят пакетирани в кутии и кашони. Всяка опаковка е удобна за транспортиране и съхранение. За запазване цялостта на опаковките не се изискват специални условия на транспорт и складиране.

II. При транспорт:

- II. Да не се подлагат на преки атмосферни влияния – дъжд, сняг.
- III. Товаро-разтоварните работи да се извършват в сухо време.
- IV. Да се транспортират внимателно в стандартната си опаковка и да не се хвърлят или притискат силно.

III. Правилно складиране:

Редът и начинът за приемане, съхранение на материалите е съгласно Наредба №7 за проучване и доставка на машини и съоръжение към Правилника за капитално строителство и съгласно стандартизационните документи.

- 1. Материалите да се съхраняват в закрити, сухи помещения, годни за складиране на електрически материали.
- 2. Да не се подлагат на преки атмосферни влияния – дъжд, сняг.
- 3. В отворена кутия трябва да се вземат мерки за отстраняване на възможността за попадане на прах, пепел и др.
- 4. Температурен диапазон в помещението - (-5°C до +40°C)
- 5. Относителна влажност в помещението – до 50% при 40°C, 90% при 20°C
- 6. Чистота на средата – чиста от химически активни или агресивни компоненти, действащи разрушаващо на електрическата изолация и тоководещите части

IV. Монтаж

Монтажът на оборудването се осъществява върху стандартна DIN-шина.

Монтажът, демонтажът и работата с предпазител-прекъсвачи със стопяеми цилиндрични вложки трябва да се извършва единствено и само от квалифициран и опълномощен за това персонал. Задължително е да се вземат мерки за безопасност съгласно утвърдените наредби и правилници и да се осигуряват изискваните лични предпазни средства при работа по електрически мрежи. Не се допуска да се прави опит за ремонт или модификация на оборудването.

Въртящият момент на затягане на клемовите съединения е 2Nm.

V. Обслужване и поддържане

Предпазител-прекъсвачи със стопяеми цилиндрични вложки не изискват специална поддръжка. Необходимо е периодично да се проверява целостта на вложката и при необходимост тя да бъде подменена.


на основание чл. 2 от
ЗЗЛД

гр. София

17.01.2017г.

Съставил:

инж. Петър Ценов



СРОКОВЕ ЗА ДОСТАВКА И МОНТАЖ

| № | Наименование | Мярка | Количество със срок на доставка и монтаж до 30 кал. дни |
|---|--|-------|---|
| 1 | 2 | 3 | 4 |
| 1 | БКТП(К)-20/800/2, Д – отпр. и отстр., TS1 (ККТ) | бр. | 1 |
| 2 | БКТП(К)-20/800/3, Д – отпр. и отстр., TS1 (КККТ) | бр. | 1 |
| 3 | БКТП(К)-20/800/2, Д – отпред и отстрани, тесен, TS9 (ККТ) | бр. | 1 |
| 4 | БКТП(К)-20/800/3, Д – отпред и отстрани, тесен, TS9 (КККТ) | бр. | 1 |
| 5 | БКТП (К)-20/800/2,Д-отпр., TS2 (ККТ) | бр. | 1 |
| 6 | БКТП (К)-20/800/3,Д-отпр., TS2 (КККТ) | бр. | 1 |

Забележки:

1/ Срокът на доставката и монтажа започва да тече от датата на изпращане на поръчката.

2/ В случай, че крайният срок на доставката съпада с празничен или неработен ден, то доставката се извършва не по-късно от първия работен ден след изтичането на срока.

3/ При поръчки на Възложителя на количества в рамките на потвърдените от Изпълнителя и недоставени в посочените срокове, ще бъдат налагани неустойки, съгласно условията на договора.

4/ Възложителят може да поръчва количество по-високо от посоченото в колона 4, като това обстоятелство ще бъде посочено текстово в съответната поръчка изпратена към Изпълнителя. С потвърждението на поръчката, Изпълнителят вписва в същата очаквана дата за доставка на количествата надвишаващи посочените в колона 4.

на основание чл. 2 от
ЗЗЛД

Дата 10.08.2018 г.

ПОДПИС И ПЕЧАТ:

Антон Илиев
(име и фамилия)
Управител

(длъжност на представляващия участника)

Референтен № PPD 18-063

ДЕКЛАРАЦИЯ

за приемане на условията в проекта на рамково споразумение и проекта на конкретен договор,
неразделна част от рамковото споразумение

Долуподписаният/-ната/ **Антон Иванов Илиев**, в качеството ми на **Управител**, представляващ „МИГ 23“ ЕООД с ЕИК 131490350, участник в процедура от вида „договаряне без предварителна покана за участие“, за сключване на рамково споразумение с реф. № PPD 18-063 и предмет: „Доставка и монтаж на бетонови комплектни трансформаторни постове (БКТП)“, обособена/и позиция/и №№: Обособена позиция 1 – "Доставка и монтаж на бетонови комплектни трансформаторни постове (БКТП) - обслужвани отвън".

ДЕКЛАРИРАМ, ЧЕ:

1. Приемам условията в проекта на рамково споразумение, приложен в документацията за участие.
2. Приемам условията в проекта на конкретен договор, неразделна част от рамковото споразумение, приложен в документацията за участие.

Информирани сме, че Възложителят (включително чрез неговия помощен орган, а именно назначената за провеждане на поръчката оценителна комисия) ще обработва и съхранява личните ми данни, посочени в настоящата декларация, за целите на провеждане на обществената поръчка, като за целта ще предприеме всички необходими според действащата нормативна уредба мерки за защита на личните ми данни.

Дата 10.08.2018 г.



Декларатор:

на основание чл. 2 от
ЗЗЛД

Антон Илиев
/име, подпис и печат /

Забележка:

Декларацията се подписва от законния представител на участника или от надлежно упълномощено лице, което подава офертата.

Когато участник подава оферта за повече от една обособена позиция, може да бъде изготвена, подписана и подадена само една декларация (според настоящия образец), но на съответното място в декларацията задължително се отбелязват номерата на всички обособени позиции, за които участникът участва. Възможно е по преценка на участника, когато същият участва за повече от една обособена позиция, да изготви и подпише отделни декларации (съобразно настоящия образец) за всяка отделна обособена позиция, за която участва.

Референтен № PPD 18-063

ДЕКЛАРАЦИЯ
за срока на валидност на офертата

Долуподписаният **Антон Иванов Илиев,**
(собствено бащино фамилно име)

притежаващ лична карта № [REDACTED] на основание чл. 2 от ЗЗЛД адрес:

[REDACTED] на основание чл. 2 от ЗЗЛД

в качеството ми на **Управител**
(посочва се длъжността)
на **„МИГ 23“ ЕООД, с ЕИК 131490350**
(посочете наименованието на участника)

участник в процедура от вида „договаряне без предварителна покана за участие“, за сключване на рамково споразумение, с реф. № PPD 18-063 и предмет: „**Доставка и монтаж на бетонови комплектни трансформаторни постове (БКТП)**“, обособена/и позиция/и №№: **Обособена позиция 1 – "Доставка и монтаж на бетонови комплектни трансформаторни постове (БКТП) - обслужвани отвън"**.

(наименование на поръчката)

ДЕКЛАРИРАМ, ЧЕ:

С подаване на настоящата оферта, направените от нас предложения и поети ангажименти за обособена/и позиция/и №№: **Обособена позиция 1 – "Доставка и монтаж на бетонови комплектни трансформаторни постове (БКТП) - обслужвани отвън"**, са валидни за срок от 6 (шест) месеца, считано от крайния срок за подаване на офертите.

Информирани сме, че Възложителят (включително чрез неговия помощен орган, а именно назначената за провеждане на поръчката оценителна комисия) ще обработва и съхранява личните ми данни, посочени в настоящата декларация, за целите на провеждане на обществената поръчка, като за целта ще предприеме всички необходими според действащата нормативна уредба мерки за защита на личните ми данни.

Дата 10.08.2018 г.

Декларатор: [REDACTED]

Антон Илиев
/име, подпис и печат/

Забележка:

Декларацията се подписва от законния представител на участника или от надлежно упълномощено лице, което подава офертата.

Когато участник подава оферта за повече от една обособена позиция, може да бъде изготвена, подписана и подадена само една декларация (според настоящия образец), но на съответното място в декларацията задължително се отбелязват номерата на всички обособени позиции, за които участникът участва. Възможно е по преценка на участника, когато същият участва за повече от една обособена позиция, да изготви и подпише отделни декларации (съобразно настоящия образец) за всяка отделна обособена позиция, за която участва.

Референтен № PPD 18-063