


ПРОТОКОЛИ ОТ ТИПОВИ ИЗПИТАНИЯ за VARISIL HE-1 тип вентилни отводи с полимерна външна изолация

Проведени типови изпитания	Референтни стандарти	Изпитани мостри	ИЗПИТАТЕЛНИ ПРОТОКОЛИ			Допълнителна информация
			Справка	Дата	Език	
Изпитания за издръжливост на външната изолацията	IEC 60099-4 §10.8.2	Външна изолация стойност 12kV, 24&36kV Външна изолация стойност 18kV	CESI AT-A1/025452 CESI AT-A1/025961	Септември 3, 2001 Септември 5, 2001	Английски Английски	
Изпитания на остатъчното напрежение със стръмен мълниев и превключвателен токов импулс	IEC 60099-4 §10.8.3	Метално-окисен варистор ном. Напрежение 5кV	Tridelta TR-E 13001RS	2013	Английски	Волт-амперни характеристични криви V18992 01 XX/E rev.03/октомври 26, 2012, англ./
Изпитания за издръжливост на предължителен токов импулс	IEC 60099-4 §10.8.4	Метално-окисен варистор ном. Напрежение 5кV	Tridelta TR-E 13001LD	2013	Английски	
Изпитване в експлуатационен режим с висок токов импулс	IEC 60099-4 §10.8.5	5 kV	Tridelta TR-E 1300 OD	Март 7, 2013	Английски	
Напрежено-времева импулс		HE-1 обсег			Английски	напрежено-времеви характеристични криви UT8992 01 XX/E rev.00- октомври 26, 2012 англ./




(

(

Изпитания при късо съединение	IEC 60099-4 §10.8.7	HE-S 24 вентилни отводи	CESI A8018577	Юни 25 , 2008	Английски	
Изпитания за частични разряди	IEC 60099-4 §10.8.8	HE-36 вентилни отводи	CESI AT-A0/042489	Декември 22, 2000	Английски	
Изпитания на момент на огъване	IEC 60099-4 §10.8.13	HE- S 42 вентилни отводи	Tridelta TR/SCUS TR- E1219BM	Ноември 15, 2012	Английски	
	IEC 60099-4 §10.8.14.2.1/ 1000 часа изпитание/	HE 36 вентилни отводи	CESI AT-A2/032924	Декември 18, 2002	Английски	
Изпитване за стареене	IEC 60099-4 §10.8.14.2.2/ 5000 часа изпитание/	HE 24 вентилни отводи	CESI AT-A3/007530	Март 27, 2003	Английски	

С

[Handwritten signature]



(C)

(C)



TRIDELTA Parafoúdes S.A.

TYPE TESTS PERFORMED	REFERENCE STANDARD	SAMPLES TESTED	TEST REPORT		ADDITIONAL INFORMATION
			Reference	Date	
Short circuit tests	IEC 60099-4 § 10.8.7	HE-S 24 surge arresters	CESI A8018577	June 25, 2008	see Note 2
Partial discharge test	IEC 60099-4 § 10.8.8	HE 36 surge arresters	CESI AT-A0/042489	December 22, 2000	see Note 2
Bending moment test	IEC 60099-4 § 10.8.13	HE-S 42 surge arresters	TRIDELTA / SCÚS TR-E 12019BM	November 15, 2012	see Note 2
Weather ageing test	IEC 60099-4 § 10.8.14.2.1 (1000 h test)	HE 36 surge arrester	CESI AT-A2/032924	December 18, 2002	see Note 2
	IEC 60099-4 § 10.8.14.2.2 (5000 h test)	HE 24 surge arrester	CESI AT-A3/007530	March 27, 2003	see Note 2

Note 1 : Reference is made to the latest version of IEC 60099-4 standard, namely edition 2.2 published in May 2009

Note 2 : The HE-I arrester design is very similar to the HE and identical to the HE-S.

In particular, the HE-I arrester range is built with MO resistors of the same size than HE and HE-S but upgraded to line discharge class 2, and resulting in lower voltage stress per unit length and unit thickness.



Therefore, type tests carried out on HE or HE-S samples also cover the HE-I range as long as the MO resistor performance are not directly involved.

ВЯРНО С
ОРИГИНАЛА

Reference : TPF ST HE-I 01 / E rev. 03

Date : March 8, 2013

Page : 2 / 2




ВЯРНО С
ОРИГИНАЛА

TRIDELTA Parafoudres S.A.

**TYPE TEST REPORTS relating to
VARISIL™ HE-I polymer housed surge arresters & associated accessories**

TYPE TESTS PERFORMED	REFERENCE STANDARD	SAMPLES TESTED	TEST REPORT		ADDITIONAL INFORMATION
			Reference	Date	
Insulation withstand tests on the housings	IEC 60099-4 § 10.8.2	Housings rated 12 kV, 24 kV & 36 kV	CESI AT-A1/025452	September 3, 2001	see Note 2
		Housing rated 18 kV	CESI AT-A1/025961	September 5, 2001	
Steep, lightning and switching current impulse residual voltage tests	IEC 60099-4 § 10.8.3	5 kV MO resistors	TRIDELTA TR-E 13001RS	January 22, 2013	Voltage vs current characteristic curve VI 8982 01 XX / E rev. 00 (October 26, 2012, English)
Long duration current impulse withstand test	IEC 60099-4 § 10.8.4	5 kV MO resistors	TRIDELTA TR-E 13001LD	January 22, 2013	see Note 2
High current impulse operating duty test	IEC 60099-4 § 10.8.5	5 kV prorated sections	TRIDELTA TR-E 13001OD	March 7, 2013	
Voltage vs time characteristic curve	IEC 60099-4 § 6.10	HE-I range			Curve UT 8982 01 XX / E rev. 00 (October 26, 2012, English)



Reference : TPF ST HE-I 01 / E rev. 03

Date : March 8, 2013

Page : 1 / 2

INSULATION
AT-AO / 041765

TEN DIELECTRIQUE
HE ENEL

~~REPLACE PAROET~~
~~CESI AT-AO / 041765~~

REPLACE PAROET
CESI AT-AO / 041765



[Handwritten signature]

ISEC

[Handwritten mark]

[Large handwritten signature]

ВЯРНО С
ОРИГИНАЛА



client ALSTOM Parafoudres S.A. - Bagnères de Bigorre Cedex (France)

equipment under test housing of 10kA polymeric housed surge arresters

tests performed dry lightning impulse voltage test;
wet power frequency voltage test.

normative documents IEC 60099-4 (1991-06)

receipt date of the sample december 15, 2000
test date from december 19, 2000 to february 01, 2001

the test results relate only to the sample tested
this document shall not be reproduced except in full without the written approval of CESI
and of the accreditation body, if any

n° 0030

no. of pages 12 no. of pages annexed --

issue date September 03, 2001

prepared PeC/TEST - C. Dei Giorgio *Alberto Sironi*

verified PeC/TEST - A. Sironi


approved PeC/TEST - V. Scaroni

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Competenze
Il Responsabile Test Laboratori

CESI Eletrotecnico Sperimentale Italiano
Giuliano Morla Spa
Via R. Rubattino 54
20134 Milano - Italia
Tel. 02 57 022125.1
Fax 02 57 022125.400
www.cesi.it

Capitale sociale 8.550.000 Euro
interamente versato
Codice fiscale e numero
iscrizione CCIAA 00793580150
P.I. IT00793580150

Registro Imprese di Milano
Sezione C.R.
N. R.E.A. 429223
P.I. IT00793580150



tests witnessed by: Mr. F. Malpiece - ALSTOM Parafoudre S.A.

identification of the object: effected
The Manufacturer guarantees that the tested objects are manufactured according to the submitted drawings.
CESTI checked that these drawings adequately represents in shape and dimensions the essential details and the parts of the tested objects.
These drawings identified by CESTI and numbered A0/041852 no.1 (12kV), A0/041853 no.1 (24kV), A0/041855 no.1 (36kV) are annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked:
AT-A0/041765

The measurement uncertainties of the test results reported in this document are the following:




- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
- dielectric tests with direct voltage : voltage: $\pm 3\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.


activity code: 29380X
keywords: 12015R 23801L 31020W 41040M 53001D 62501B

70

ВЯРНО С
ОРИГИНАЛА


page	test date	contents
4		rated characteristics of the test voltage declared by the manufacturer
5		test voltage values
5		summary of test results
6		dry lightning impulse voltage test
7	dec.19, 2000 - feb.01,	wet power frequency voltage test
8	dec.19, 2000 - feb.01,	circuit A002
9		circuit A059
10		panoramic view of the test samples
11		panoramic view of the test arrangement
12		reference document annexed 12KV sample - drawing no. W 8997 12 31 identified by CEST and numbered A0/041852 no.1 24KV sample - drawing no. W 8997 24 31 identified by CEST and numbered A0/041853 no.1 36KV sample - drawing no. W 8997 36 31 identified by CEST and numbered A0/041855 no.1



ВЯРНО С
ОРИГИНАЛА

rated characteristics of the test voltage declared by the manufacturer

12kV sample


manufacturer ALSTOM Parafudre S.A.
 type HE
 drawing no. W 8997 12 31
 rated voltage (U_r) 12 kV
 nominal discharge current (I_n) 10 kA
 line discharge class 1
 dry lightning impulse withstand voltage 95 kV_{pk}
 wet power frequency withstand voltage 38 kV_{rms}

24kV sample

manufacturer ALSTOM Parafudre S.A.
 type HE
 drawing no. W 8997 24 31
 rated voltage (U_r) 24 kV
 nominal discharge current (I_n) 10 kA
 line discharge class 1
 dry lightning impulse withstand voltage 125 kV_{pk}
 wet power frequency withstand voltage 50 kV_{rms}

36kV sample

manufacturer ALSTOM Parafudre S.A.
 type HE
 drawing no. W 8997 36 31
 rated voltage (U_r) 36 kV
 continuous operating voltage (U_c) 30 kV_{rms}
 nominal discharge current (I_n) 10 kA
 line discharge class 1
 dry lightning impulse withstand voltage 170 kV_{pk}
 wet power frequency withstand voltage 70 kV_{rms}



**ВЕРНО С
ОРИГИНАЛА**

80

Test Report

test voltage values

12kV sample

Lightning impulse voltage test (dry)
Power frequency voltage test (wet)

95 kV_{pk}
38 kV_{rms}

24kV sample

Lightning impulse voltage test (dry)
Power frequency voltage test (wet)

125 kV_{pk}
50 kV_{rms}

36kV sample



Lightning impulse voltage test (dry)
Power frequency voltage test (wet)

170 kV_{pk}
70 kV_{rms}



ВЕРНОЕ
ОРИГИНАЛА

[Handwritten signature]



ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]

summary of test result

dry lightning impulse voltage test

For each rated voltage level one housing of 10kA polymeric housed surge arresters was tested. The test was performed at the specified lightning impulse voltage obtained applying the corrections for atmospheric conditions. Fifteen impulses were applied at positive and negative polarity to each sample under test. No external flashovers occurred and the housings have not been damaged by these tests. Therefore the test result is to be considered positive.

wet power frequency voltage test

For each rated voltage level one housing of 10kA polymeric housed surge arresters was tested. The test samples withstood for one minute the wet power frequency withstand voltage claimed by the manufacturer. Therefore the test result is to be considered positive.



Handwritten signature



Test Report

CESTEST

AT-A1/025452

p.7

note:

test date	positive polarity						negative polarity					
	requested voltage	K	applied voltage	applied impulses	flashover	test result	requested voltage	K	applied voltage	applied impulses	flashover	test result
12kV sample	95,0	0,978	92,9	15	0	withstand	95,0	0,978	92,9	15	0	withstand
24kV sample	125,0	0,978	122,3	15	0	withstand	125,0	0,978	122,3	15	0	withstand
35kV sample	170,0	0,988	167,6	15	0	withstand	170,0	0,988	170,0	15	0	withstand
December 19, 2000												
December 19, 2000												
February 01, 2001												

test circuit: A002

test object: housing of 10kA polymeric housed surge arresters

dry lightning impulse voltage test

Handwritten signature

ВЕРНО С
ОРИГИНАЛА

Large handwritten signature

Test Report



AT-A1/026452

p.8

Site:

test housing	required (U)	K _{res}	K _i	applied (U × K _i)	test duration	test result	test date	Voltage	
								correction factor	withstand
12kV sample	38,0		1,008	38,2	60	withstand	December 19, 2000		
24kV sample	50,0		1,008	50,3	60	withstand	December 19, 2000		
36kV sample	70,0		1,000	70,0	60	withstand	February 01, 2001		

precipitation conditions	water temperature °C	water resistivity Ω × m	precipitation rate mm / min			horizontal
			top	center	bottom	
	15,0	100,0	--	1,5	1,6	--

test circuit : A059
 object: housing of 10kA polymeric housed surge arresters
 wet power frequency voltage test


100013220



ВЯРНО С
 ОРИГИНАЛА

85

circuit A002



Lightning impulse test circuit

- Cg : impulse generator capacitance
- Rf : Front resistor
- Rc : Tail resistor
- Cc : Load capacitance
- D : Divider type RC series
- K : coaxial cable
- S : attenuation and termination unit
- Osc : Oscilloscope


ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]




Test Report

panoramic view of the test samples




12kV sample



24kV sample


36kV sample

ВЯРНО С
ОРИГИНАЛА



87


circuit A059



power frequency measuring circuit

- TV₂: voltage transformer
- V₂: voltmeter
- D : voltage divider type RC series low voltage arm
- V₃: voltmeter
- TV₁: voltage transformer
- V₁: voltmeter

[Handwritten signature]




ВЕРНО С
ОРИГИНАЛА


[Large handwritten signature]

Test Report


panoramic view of the test arrangement




12kV sample



24kV sample




36kV sample



ВЯРНО С
ОРИГИНАЛА



Handwritten signature



Nominal arc length : 195 mm
 Nominal creepage distance : 480 mm

<input checked="" type="checkbox"/> Libre <input type="checkbox"/> Confidential		Accessibilité du plan :	
Modification :		Dessinateur :	
Tolérances générales :		Date :	
Matière :		Vérification :	
Traitement :		Echelle :	
12 kV rated silicone rubber housing for VARISIL type HE surge arresters.		Dessinateur : HS Date : 12/12/00	
Ce plan est propriété de ALSTOM Perofredes SA : il ne peut être ni reproduit ni communiqué sans autorisation préalable		ALSTOM TRANSMISSION & DISTRIBUTION Perofredes B.P. 256 65202 Beugnères-de-Bigorre	
A4 APF W 8997 12 31		Folio : 1 / 1 Indice : 00	



Handwritten signature

**ВЯРНО С
 ОРИГИНАЛА**


Large handwritten signature

Index: 00		Foto: 1/1		W 8997 24 31		A3 APF		Ce plan se referă la ALSTOM (firmă) și la un component sau o echipament precizie	
45202 Boghies-de-Segre BP 256 TRANSMISSION & DISTRIBUTION ALSTOM		24 kV rated silicone rubber housing for VARISIL type HE surge arresters.		Date: 12/12/00 Verificator:		Date: HS Descriere:		Date: Verificator:	
Modificari:		Tel: / /		Date:		Verificator:		Disponibilitate la plan: <input type="checkbox"/> Condus <input type="checkbox"/> Date	

Nominal arc length : 270 mm
 Nominal creepage distance : 800 mm



ВЯРНО С
 ОРИГИНАЛА



CESI

[Handwritten signature]

[Handwritten signature]

ТЕНУЕ ДІВЕРСІОНА
НЕ БУЕЛ

SECRET
SECRET
SECRET

ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]
[Handwritten signature]
[Handwritten signature]
32



client

ALSTOM Parafoudes S.A. - Bagnères de Bigorre Cedex (France)

equipment under test

polymer housed surge arrester housing

tests performed

lightning impulse voltage test;
power frequency voltage test - wet.

normative documents

ENEL technical specifications DY 557 (July 1999, draft), DY 1018
(May 1999, draft); IEC 60099-4 (1991-06)

receipt date of the sample

May 29, 2001

test date

from May 30, 2001

to May 30, 2001

the test results relate only to the sample tested
this document shall not be reproduced except in full without the written approval of CESI
and of the accreditation body, if any

no. of pages

12

no. of pages annexed

issue date

September 5, 2001

prepared

PeC/TEST - C. Del Giorgio

verified

PeC/TEST - A. Sironi

Aut. Del. Sironi

approved

PeC/TEST - V. Scaroni

CESI
CENTRO ELETTROTECNICO SPINALE ITALIANO
P.le S. Ambrogio, 1
11100 Spinalba (VI) - Italia
Il Responsabile è il sottoscritto

CESI
Centro Elettrotecnico
Spinalba (Italia)
Direttore: Nicola SPA

Via R. Rubattino, 54
20134 Milano - Italia
Telefono +39 0212126.1
Fax +39 0221266440
www.cesit.it

Capitale sociale 8.500.000 Euro
Intensivazione
Codice fiscale e numero
Iscrizione CCIAA 00735580150

Regolare gestione di Milano
Codice Civile
N. 11100735580150
P.I. 1100735580150

ВЯРНО С
ОРИГИНАЛА



tests witnessed by: Mr. F. Malpiece - ALSTOM Parafuodres S.A.

identification of the object: effected
The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.
CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.
These drawings identified by CESI and numbered A1/021094 no.1 and no.4 are annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked:
AT-A1/016942

The measurement uncertainties of the test results reported in this document are the following:
- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
- dielectric tests with direct voltage : voltage: $\pm 3\%$
The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.


activity code: 31126P
keywords: 12015R 23801L 31020W 41040M 53001D 62501B

**ВЯРНО С
ОРИГИНАЛА**

10

test date	page	contents
	4	rated characteristics of the test voltage declared by the manufacturer
	5	test voltage values
	6	summary of test result
	7	dry lightning impulse withstand voltage test
	8	wet power frequency withstand voltage test
	9	circuit A002
	10	circuit A059
	11	panoramic view of the test samples
	12	panoramic view of the test arrangement
May 30, 2001		reference document annexed - drawings identified by CEST and numbered A1/021094 no.1 and no.4

**ВЯРНО С
 ОРИГИНАЛА**



rated characteristics of the test voltage declared by the manufacturer

manufacturer	ALSTOM Parafudre S.A.
ALSTOM designation	VARISIL HE 18 sd/E
ENEL type	DY 557/4
code	B 8997 07 18
drawing no.	W 8997 07 18/I
rated voltage (U _r)	18 kV
continuous operating voltage (U _c)	15 kV
nominal discharge current (I _n)	10 kA
line discharge class	1
minimum creepage distance of arrester housing	650 mm


bracket type	S3/E
drawing no.	B 8997 09 41/I

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

**ВЯРНО С
ОРИГИНАЛА**



test voltage values

arrester housing

Lightning impulse voltage test (dry)

$U_{pk} = 1,3 \times U_{impL} = 1,3 \times 65 = 84,5 \text{ kV}_{pk}$

U_{impL} : lightning impulse protection level (according to ENEL technical specifications) = 65 kV_{pk}

Power frequency voltage test (wet)

$U_{pk} = 0,88 \times U_{impL} = 0,88 \times 65 = 57,2 \text{ kV}_{pk}$

$U_{rms} = U_{pk} / \sqrt{2} = 40,44 \text{ kV}_{rms}$

U_{impL} : lightning impulse protection level (according to ENEL technical specifications) = 65 kV_{pk}

bracket


Lightning impulse voltage test (dry)

$U_{wet} = 73 \text{ kV}_{pk}$

Power frequency voltage test (wet)

$U_{wet} = 40 \text{ kV}_{rms}$

**ВЯРНО С
 ОРИГИНАЛА**



summary of test result

arrester housing

dry lightning impulse voltage test

For each rated voltage level one housing of 10kA polymeric housed surge arresters was tested. The test was performed at the specified lightning impulse voltage obtained applying the corrections for atmospheric conditions.

Fifteen impulses were applied at positive and negative polarity to each sample under test.

No external flashovers occurred and the housings have not been damaged by these tests. Therefore the test result is to be considered positive.

wet power frequency voltage test

For each rated voltage level one housing of 10kA polymeric housed surge arresters was tested.

The test samples withstood for one minute the wet power frequency withstand voltage claimed by the manufacturer.

Therefore the test result is to be considered positive.

bracket

dry lightning impulse voltage test

For each rated voltage level one bracket of surge arresters was tested.

The test was performed at the specified lightning impulse voltage obtained applying the corrections for atmospheric conditions.

Fifteen impulses were applied at positive and negative polarity to each sample under test.

No external flashovers occurred and the housings have not been damaged by these tests. Therefore the test result is to be considered positive.


wet power frequency voltage test

For each rated voltage level one bracket of surge-arresters was tested.

The test samples withstood for one minute the wet-power frequency withstand voltage claimed by the manufacturer.

Therefore the test result is to be considered positive.

ВЯРНО С
ОРИГИНАЛА



Test Report



AT-A1/028961

p.7

note:

test object	requested voltage	correction factor	applied voltage	applied impulses	flashover no.	test result	positive polarity						test date
							requested voltage	K	KV _{max}	no.	flashover	test result	
1	73,0	0,978	71,4	15	0	withstand	73,0	0,978	71,4	15	0	withstand	May 30, 2001

test object: bracket

note:


test object	requested voltage	correction factor	applied voltage	applied impulses	flashover no.	test result	negative polarity						test date
							requested voltage	K	KV _{max}	no.	flashover	test result	
1	84,5	0,989	84,5	15	0	withstand	84,5	0,989	84,5	15	0	withstand	May 30, 2001

test object: polymer housed surge arrester housing

test circuit: A002

dry lightning impulse withstand voltage test

100A1320



ВЯРНО С
ОРИГИНАЛА

Test Report



AT-A1/025961

p.8

Note:

test object	required (U)	voltage correction factor	applied (U x K _f)	test duration	test result	withstand	May 30, 2001
	K _{res}						
no.	40,0	0,990	39,6	60			
test circuit : bracket							

Note:

test object	required (U)	voltage correction factor	applied (U x K _f)	test duration	test result	withstand	May 30, 2001
	K _{res}						
no.	57,2	0,992	56,7	60			
test circuit : polymer housed surge arrester housing							


test circuit : A059
wet power frequency withstand voltage test

precipitation conditions	precipitation rate mm / min	water temperature °C	water resistivity Ω x m	top	center	bottom
				precipitation rate mm / min	water temperature °C	water resistivity Ω x m
				vertical	horizontal	
				1,8	1,6	--
				--	--	22,5
				--	--	95,0

**ВЯРНО С
ОРИГИНАЛА**

NO0A12200


circuit A002




lightning impulse test circuit

- Cg : Impulse generator capacitance
- Rf : Front resistor
- Rc : Tail resistor
- Cc : Load capacitance
- D : Divider type RC series
- K : coaxial cable
- S : attenuation and termination unit
- Osc : Oscilloscope

ВЯРНО С
ОРИГИНАЛА



circuit A059



power frequency measuring circuit

- TV_2 : voltage transformer
- V_2 : voltmeter
- D : voltage divider type RC series low voltage arm
- V_g : voltmeter
- TV_1 : voltage transformer
- V_1 : voltmeter

[Handwritten signature]

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА

[Large handwritten signature]

[Circular stamp with text and a signature across it]


[Handwritten text: Служба 02]

panoramic view of the test sample



ВЯРНО С
ОРИГИНАЛА

103




[Handwritten signature]

CESI

[Handwritten initials]

**ВЯРНО С
ОРИГИНАЛА**

[Handwritten signature]



(

(

CONFIDENTIAL

8

40

Type Test Report
 No.: TR-E 13001LD

Equipment under test: Polymer housed surge arrester of line discharge class 2 type series, VARISIL HE-I, TRIDELTA Parafoudres S.A.

Normative documents: IEC 60099-4 Edition 2.2 clause 8.4

Test performed: Long duration current impulse withstand test - Line discharge class 2

Test date: 09/10th of January 2013

Number of pages: 10

Attention: The test results relate only to the sample(s) tested. This document shall not be reproduced without written approval of TRIDELTA Testing facilities.


First issue date: 22nd of January 2013

Tested / Edited by: Dipl.-Ing. U. Plötner

Approved by: Dipl.-Ing. H. Klaube







Hermisdorf, 22nd of January 2013



TRIDELTA Überspannungsableiter GmbH
 Marie-Curie-Straße 3
 07629 Hermisdorf - Deutschland
 Telefon: +49 (0)3 66 01/9328 300
 Fax: +49 (0)3 66 01/9328 301
 Internet: <http://www.tridelta.de>

ВЕРНО С
ОРИГИНАЛА

Subject:

Surge arrester type series: VARISIL HE-1,
 manufactured by TRIDELTA Parafoudres S.A.
 Tests on 3 arrester sections, each consisting of 1 resistor TRIDELTA OD40.

Caused by:

Type Test Report

Test arrangement / course of test:

Test acc. to IEC 60099-4 Edition 2.2 clause 8.4
 "Long duration current impulse withstand test"

The test was performed on 3 arrester sections of rated voltage of (5.22...5.28) kV.

Test procedure:

Measurements before the test:

- measurement of reference voltage at reference current $I=1$ mA,
- measurement of residual voltage at $I=125$ A (40/100),
- measurement of residual voltage at $I=10$ kA (8/20)

The test was carried out at ambient temperature of 20 °C in open air.
 Each section was subjected to 18 discharges, divided in 6 groups of 3 impulses.

Parameters for the line discharge test (clause 8.4.2 table 5)

$$Z = 2.4 \cdot U_r = 1267 \Omega$$

$$U_r = 3.2 \cdot U_n = 16.90 \text{ kV}$$

$$T = 2000 \mu\text{s}$$


Required long duration impulse energy:

$$W = U_{(25\%A)} \cdot (U_r - U_{(25\%A)}) \cdot T \cdot I/Z$$

$$W = 9.98 \cdot (16.90 - 9.93) \cdot 2 / 12.67$$

$$W = 10.85 \text{ kJ}$$

$$W' = 2.05 \text{ kJ/kV}_r$$



ВЯРНО С
 ОРИГИНАЛА

Test samples and results:


sample no.	LD 1	LD 2	LD 3
U_{ref} ($I=1$ mA) [kV]	7.10	7.11	7.19
$U_{j=0,735 \times U_{ref}}$ ($I=1$ mA) [kV]	5.22	5.23	5.28

Residual voltage at 125 A (40/100) U_{res} [kV]	9.89	9.82	9.93
Nominal residual voltage at 10 kA (8/20)			
before [kV]	13.44	13.33	13.47
after [kV]	13.46	13.33	13.48
change [%]	+0.15	±0.00	+0.07
real charging voltage [kV]	26.4		
number of discharges	18		
duration of peak [μ s]	1980		
discharge current 1 st 18 th [A]	515	519	515
	509	513	508
residual voltage 1 st 18 th [kV]	10.66	10.53	10.67
	10.81	10.71	10.85
impulse energy 1 st 18 th [kJ]	12.75	12.70	12.76
	12.80	12.77	12.82
specific energy per impulse: average 18 imp. [kJ/kV U_{ref}]	2.45	2.44	2.43

The applied energy for each impulse on each tested sample was higher than the calculated (required) energy.

During the test there were no breakdowns or flashovers. The visual inspection after the test showed no cracks or other damages. The change of the nominal residual voltage amounted less than +0.15 %. The samples passed the test.

**ВЯРНО С
ОРИГИНАЛА**





ВЯРНО С
ОРИГИНАЛА




The following oscillograms show the results of the measurements.


Sample LD 1:



1st impulse
Line discharge class 2



18th impulse
Line discharge class 2



ВЯРНО С
ОРИГИНАЛА

109


Cyff

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА



Sample LD 2:




Nominal residual voltage
before the test at 10 kA (8/20)




Nominal residual voltage
after the test at 10 kA (8/20)

1st impulse
Line discharge class 2



18th impulse
Line discharge class 2



[Handwritten signature]


[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]




ВЯРНО С
ОРИГИНАЛА




TR-E 13001LD

Nominal residual voltage
before the test at 10 kA (8/20)


Sample LD 3:




Nominal residual voltage
after the test at 10 kA (8/20)



1st impulse
Line discharge class 2



16th impulse
Line discharge class 2





ВЯРНО С
ОРИГИНАЛА






Test circuit for Residual voltage test on prorated arrester sections:



- C_m, C_s Capacitive divider
- R_{mv} Damping resistance of the HV-side condenser (C_{mv})
- R_{mv} HV-side measuring resistance
- C_{mv} HV-side measuring capacitance
- R_{mv} Damping resistance of the LV-side condenser (C_{lv})
- R_{lv} LV-side measuring resistance
- C_{lv} LV-side measuring capacitance
- L_m Charging inductance (not...)
- C_{mv}, C_{lv} Charging capacitances (not...)
- CT Current transformer

Test circuit for Long duration current impulse withstand test



- R_{mv} Damping resistance of the HV-side condenser (C_{mv})
- R_{mv} HV-side measuring resistance
- C_{mv} HV-side measuring capacitance
- R_{mv} Damping resistance of the LV-side condenser (C_{lv})
- R_{lv} LV-side measuring resistance
- C_{lv} LV-side measuring capacitance
- Z_m Measuring impedance
- L_m Inductance (not...)
- C_m Charging capacitances (not...)

ВЯРНО С
ОРИГИНАЛА

Type Test Report
No.: TR-E 13001RS

Equipment under test: Polymer housed surge arrester of line discharge class 2 type series, VARISIL HE-I, TRIDELTA Parafoudres S.A.

Normative documents: IEC 60099-4 Edition 2.2 clause 8.3

Test performed: Residual voltage test

Test date: 08/09th of January 2013

Number of pages: 13

Attention: The test results relate only to the sample(s) tested.
This document shall not be reproduced without written approval of TRIDELTA Testing facilities.

First issue date: 22nd of January 2013


Tested / Edited by: Dipl.-Ing. U. Plötner

Approved by: Dipl.-Ing. H. Klaube

Hermsdorf, 22nd of January 2013

ВЯРНО С
ОРИГИНАЛА


TRIDELTA Überspannungsableiter GmbH
Marie-Curie-Straße 3
07629 Hermsdorf - Deutschland
Telefon: +49 (0)3 66 01/9328 300
Fax: +49 (0)3 66 01/9328 301
Internet: <http://www.tridelta.de>



Subject:

Surge arrester type series: VARISIL HE-I,
 manufactured by TRIDELTA Parafoudres S.A.

Tests on 3 arrester sections, each consisting of 1 resistor, TRIDELTA OD40.



ВЯРНО С
 ОРИГИНАЛА

Caused by:

Type Test Report

Test arrangement/course of test:

Test acc. to IEC 60099-4 Edition 2.2 clause 8.3 "Residual voltage tests"

The test was performed on 3 arrester sections of rated voltage of (5.24 ... 5.26) kV.

sample no.		RV 1	RV 2	RV 3
$\hat{U}_{ref} (\hat{i}=1 \text{ mA})$	[kV]	7.15	7.13	7.15
$U_r=0,735 \times \hat{U}_{ref} (\hat{i}=1 \text{ mA})$	[kV]	5.26	5.24	5.26

Test procedure:

- Clause 8.3.1 Steep current impulse residual voltage test (1/20)
 $\hat{i} = (5 \text{ kA}, 10 \text{ kA}, 20 \text{ kA})$
- Clause 8.3.2 Lightning impulse residual voltage test (8/20)
 $\hat{i} = (500\text{A}, 1 \text{ kA}, 2.5 \text{ kA}, 5 \text{ kA}, 10 \text{ kA}, 20 \text{ kA}, 40 \text{ kA})$
- Clause 8.3.3 Switching impulse residual voltage test (40/100)
 $\hat{i} = 125 \text{ A}, (250\text{A}, 500 \text{ A}, 1\text{kA}, 2\text{kA}, 3\text{kA})$

Test results:

Residual voltage test at steep current impulse 1/20 (The residual voltage of the arrester sections was determined with correction for inductive effects of the voltage measuring circuit)

\hat{i} [kA]	sample	5	10	20
\hat{u} [kV]	RV 1	13.17	14.17	15.44
	RV 2	13.08	14.07	15.38
	RV 3	13.16	14.14	15.46

Residual voltage test at lightning current impulse 8/20

\hat{i} [kA]	sample	0.5	1	2.5	5	10	20	40
\hat{u} [kV]	RV 1	10.64	11.07	11.78	12.48	13.47	14.83	16.79
	RV 2	10.52	10.93	11.66	12.36	13.36	14.73	16.71
	RV 3	10.64	11.05	11.77	12.49	13.47	14.83	16.80



Residual voltage test at switching current impulse 40/100

\hat{i} [A]	sample	125	250	500	1000	2000	3000
\hat{u} [kV]	RV 1	9.94	10.23	10.56	10.91	11.40	11.76
	RV 2	9.83	10.10	10.43	10.78	11.27	11.63
	RV 3	9.93	10.21	10.56	10.91	11.39	11.75

**ВЯРНО С
ОРИГИНАЛ.**

117 *св*


The diagram shows the results of the measurement on Sample 1:




ВЯРНО С
ОРИГИНАЛА

The following oscillograms show the measurement on Sample 1;

5 kA (1/<20)




10 kA (1/<20)




ВЯРНО С
ОРИГИНАЛ.







20 kA (1/20)



500 A (8/20)




**ВЯРНО С
ОРИГИНАЛА**



1 kA (8/20)

[Handwritten signature]




2,5 kA (8/20)

[Handwritten signature]


**ВЯРНО С
ОРИГИНАЛА**

[Handwritten signature]
 221 СМЖ


5 kA (8/20)




10 kA (8/20)




ВЕРНО С
ОРИГИНАЛА





20 kA (8/20)

[Handwritten signature]




40 kA (8/20)

[Handwritten signature]


**ВЯРНО С
ОРИГИНАЛА**

[Handwritten signature]
123
[Handwritten signature]


125 A (40/100)




250 A (40/100)




ВЕРНО С
ОРИГИНАЛА




500 A (40/100)




1 kA (40/100)



ВЯРНО С
ОРИГИНАЛА




2 kA (40/100)





3 kA (40/100)

ВЯРНО С
ОРИГИНАЛА



Test circuit for Residual voltage test on prorated arrester sections:



C_1, C_2	Capacitive divider
R_{dHV}	Damping resistance of the HV-side condensor (C_{HV})
R_{HV}	HV-side measuring resistance
C_{HV}	HV-side measuring capacitance
R_{dLV}	Damping resistance of the LV-side condensor (C_{LV})
R_{LV}	LV-side measuring resistance
C_{LV}	LV-side measuring capacitance
L_n	Charging inductance ($n=1...9$)
C_{n1}, C_{n2}	Charging capacitances ($n=1...9$)
CT	Current transformer

Handwritten signature

**ВЯРНО С
ОРИГИНАЛА**



(C)

(C)

Type Test Report
No.: TR-E 13001LD

Equipment under test: Polymer housed surge arrester of line discharge class 2 type series, VARISIL HE-I, TRIDELTA Parafoudres S.A.

Normative documents: IEC 60099-4 Edition 2.2 clause 8.4

Test performed: Long duration current impulse withstand test - Line discharge class 2

Test date: 09/10th of January 2013

Number of pages: 10

Attention: The test results relate only to the sample(s) tested. This document shall not be reproduced without written approval of TRIDELTA Testing facilities.

First issue date: 22nd of January 2013


Tested / Edited by: Dipl.-Ing. U. Plötner

Approved by: Dipl.-Ing. H. Klaube

Hermisdorf, 22nd of January 2013

ВЯРНО С
ОРИГИНАЛА

TRIDELTA Überspannungsableiter GmbH
 Marie-Curie-Straße 3
 07629 Hermisdorf - Deutschland
 Telefon: +49 (0)3 66 01/9328 300
 Fax: +49 (0)3 66 01/9328 301
 Internet: <http://www.tridelta.de>



Subject:

**Surge arrester type series: VARISIL HE-I,
manufactured by TRIDELTA Parafoudres S.A.**

Tests on 3 arrester sections, each consisting of 1 resistor TRIDELTA OD40.

Caused by:

Type Test Report

Test arrangement / course of test:

Test acc. to IEC 60099-4 Edition 2.2 clause 8.4
"Long duration current impulse withstand test"

The test was performed on 3 arrester sections of rated voltage of (5.22...5.28) kV.

Test procedure:

Measurements before the test:

- measurement of reference voltage at reference current $\hat{i}=1$ mA,
- measurement of residual voltage at $\hat{i}=125$ A (40/100),
- measurement of residual voltage at $\hat{i}=10$ kA (8/20)

The test was carried out at ambient temperature of 20 °C in open air.
Each section was subjected to 18 discharges, divided in 6 groups of 3 impulses.

Parameters for the line discharge test (clause 8.4.2 table 5)

$$Z = 2.4 \cdot U_r = 12.67 \Omega$$

$$U_L = 3.2 \cdot U_r = 16.90 \text{ kV}$$

$$T = 2000 \mu\text{s}$$

Required long duration impulse energy:


$$W = U_{(125A)} \cdot (U_L - U_{(125A)}) \cdot T \cdot 1/Z$$

$$W = 9.93 \cdot (16.90 - 9.93) \cdot 2/12.67$$

$$W = 10.85 \text{ kJ}$$

$$W' = 2.05 \text{ kJ/kV}U_r$$

**ВЪРНО С
ОРИГИНАЛА**



Test samples and results:

sample no.	LD 1	LD 2	LD 3
$\hat{U}_{ref} (\hat{i}=1 \text{ mA})$ [kV]	7.10	7.11	7.19
$U_r=0,735 \times \hat{U}_{ref} (\hat{i}=1 \text{ mA})$ [kV]	5.22	5.23	5.28

Residual voltage at 125 A (40/100) \hat{U}_{res} [kV]	9.89	9.82	9.93
Nominal residual voltage at 10 kA (8/20) before [kV]	13.44	13.33	13.47
after [kV]	13.46	13.33	13.48
change [%]	+0.15	± 0.00	+0.07
real charging voltage [kV]	26.4		
number of discharges	18		
duration of peak [μs]	1980		
discharge current 1 st [A]	515	519	515
18 th [A]	509	513	508
residual voltage 1 st [kV]	10.66	10.53	10.67
18 th [kV]	10.81	10.71	10.85
impulse energy 1 st [kJ]	12.75	12.70	12.76
18 th [kJ]	12.80	12.77	12.82
specific energy per impulse: average 18 imp. [kJ/kV U_r]	2.45	2.44	2.43


The applied energy for each impulse on each tested sample was higher than the calculated (required) energy.

During the test there were no breakdowns or flashovers. The visual inspection after the test showed no cracks or other damages.

The change of the nominal residual voltage amounted less than +0.15 %.


The samples passed the test.

**ВЯРНО
ОРИГИНАЛ**




The following oscillograms show the results of the measurements.

Sample LD 1:




Nominal residual voltage before the test at 10 kA (8/20)



Nominal residual voltage after the test at 10 kA (8/20)


ВЕРНО С
ОРИГИНАЛА





1st impulse
 Line discharge class 2

[Handwritten signature]




18th impulse
 Line discharge class 2

[Handwritten signature]


ВЯРНО (ОРИГИНАЛ)

132
[Handwritten signature]
 [Circular stamp]

Sample LD 2:





Nominal residual voltage
before the test at 10 kA (8/20)




Nominal residual voltage
after the test at 10 kA (8/20)

ВЯРНО С
ОРИГИНАЛА






1st impulse
Line discharge class 2




18th impulse
Line discharge class 2


ВЯРНО С
ОРИГИНАЛА



Sample LD 3:





Nominal residual voltage before the test at 10 kA (8/20)



Nominal residual voltage after the test at 10 kA (8/20)


ВЯРНО С
ОРИГИНАЛА





1st impulse
Line discharge class 2

[Handwritten scribbles]



18th impulse
Line discharge class 2



**ВЯРНО С
ОРИГИНАЛА**

[Handwritten signature]

136
[Handwritten signature]


WEST PNEUMATICS

Test circuit for Residual voltage test on prorated arrester sections:




C_1, C_2	Capacitive divider
R_{dHV}	Damping resistance of the HV-side condenser (C_{HV})
R_{HV}	HV-side measuring resistance
C_{HV}	HV-side measuring capacitance
R_{dLV}	Damping resistance of the LV-side condenser (C_{LV})
R_{LV}	LV-side measuring resistance
C_{LV}	LV-side measuring capacitance
L_n	Charging inductance ($n=1...9$)
C_{n1}, C_{n2}	Charging capacitances ($n=1...9$)
CT	Current transformer

Test circuit for Long duration current impulse withstand test



R_{dHV}	Damping resistance of the HV-side condenser (C_{HV})
R_{HV}	HV-side measuring resistance
C_{HV}	HV-side measuring capacitance
R_{dLV}	Damping resistance of the LV-side condenser (C_{LV})
R_{LV}	LV-side measuring resistance
C_{LV}	LV-side measuring capacitance
Z_m	Measuring impedance
L_n	Inductance ($n=1...9$)
C_n	Charging capacitances ($n=1...9$)

ВЯРНО С
ОРИГИНАЛА



HIGH CURRENT
OPERATION

TR-E 130010D

Test Report

Type Test Report

No.: TR-E 130010D

Equipment under test: Polymer housed surge arrester of line discharge class 2 type series, VARISIL HE-1, TRIDELTA Parafoudres S.A.

Normative documents: IEC 60099-4 Edition 2.2 clause 10.8.5/8.5

Test performed: Operating duty tests - pre-stressed with 2 line discharge class 2 impulses

Test date: 26th -27th of February 2013

Number of pages: 19

Attention: The test results relate only to the sample(s) tested. This document shall not be reproduced without written approval of TRIDELTA Testing facilities.

First issue date: 07th of March 2013

Tested / Edited by: Dipl.-Ing. U. Plötner (Test engineer)
Approved by: Dipl.-Ing. H. Klaube (Senior R&D engineer)

Hermisdorf, 07th of March 2013

TRIDELTA Überwachungsabteiler GmbH
Marie-Curie-Straße 3
07629 Hermisdorf - Deutschland
Telefon: +49 (0)3 66 01/9328 300
Fax: +49 (0)3 66 01/9328 301
Internet: <http://www.tridelta.de>

ВЯРНО С
ОРИГИНАЛА
138
C.M.

Subject:
Surge arrester type series: VARISIL HE-I,
manufactured by TRIDELTA Parafoudres S.A.

Tests on 3 arrester sections, each consisting of 1 resistor TRIDELTA OD40.

Caused by:
Type Test Report

Test arrangement / course of test:

Test acc. to IEC 60099-4 Edition 2.2 clause 10.8.5


"Switching surge operating duty test" according to clause 10.8.5.5

The test was performed on 3 arrester sections of rated voltage of 5.45 – 5.51 kV. The initial measurements and the conditioning were carried out with housing at ambient temperature of 20 °C.

During the subsequent line discharge class 2 and power frequency voltage applications the varistors were placed in a test vessel (thermal model). These test samples represent the thermal and electrical behaviour of a complete assembled arrester or arrester unit containing most resistors per unit length.


Test procedure:

- initial measurements:
 - measurement of reference voltage at reference current $i=1$ mA,
 - measurement of residual voltage at $i=125$ A (40/100),
 - measurement of residual voltage at $i=10$ kA (8/20)
- conditioning:
 - 20 impulses 10 kA (8/20) divided in 4 groups of 5 discharges at 1.2 times of U_c , impulse polarity was the same as that of the half cycle of power frequency voltage during which the impulse occurs at 60 ° el. before peak.
- conditioning:
 - 2 impulses 100 kA (4/10) with the same polarity as for 10 kA conditioning, preheating the test samples (thermal model) to 60 °C
- 2 discharges of line discharge class 2 (impulse distance 60 s)
- application of the rated voltage U_r within ≤ 100 ms for 10 s and switching the test voltage to continuous operating voltage U_c for 30 min. and continuous registration of varistor current and power loss for prove of thermal stabilisation
- after cooling down to ambient temperature,
 - one additional line discharge class 2 impulse applied to the sample
 - measurement of nominal residual voltage at 10 kA (8/20),
 - evaluation of the sample,



✓ ВЯРНО С
ОРИГИНАЛА

Arrester section (thermal model) of VARISIL ... HE-I type series metal oxide surge arrester



- 1 ZnO varistor type OD40
- 2 Prepreg wrapper
- 3 Silicone tube
- 4 Aluminium end plug
- 5 Uncompressed foamed-material (Polyurethane)
- 6 Electrical terminals
- 7 Silicone shed

ВЕРНО С
ОРИГИНАЛА

140


с/л

Test samples and results:

sample no.	ODT 1	ODT 2	ODT 3
$U_{ref} (=1 \text{ mA})$ [kV]	7.50	7.42	7.46
$U_r = U_{ref}(Sec) \cdot \frac{U_r(A)}{U_{ref min}(A)}$			
$U_r = U_{ref} \cdot 0.795$ [kV]	5.51	5.45	5.48
$U_e = 0.8 \cdot U_r$ [kV]	4.41	4.36	4.39
$U_{res} (25 \text{ A, } 40/100)$ [kV]	9.75	9.80	9.87
calculation of class 2 energy: $W = U_{res} (U_L - U_{res}) \cdot T/Z$ [kJ]	11.62	11.45	11.51
nominal residual voltage at 10 kA (8/20) before the test [kV]	13.39	13.26	13.30
after the test [kV]	13.52	13.39	13.45
change [%]	+ 0.97	+ 0.98	+ 1.13
conditioning with 20 impulses 10 kA (8/20) at $U = 1.2 \cdot U_e$	passed	passed	passed
conditioning with 2 imp. 100 kA (4/10) energy per impulse [kJ/kV $_{U_r}$]	passed ≈ 2.77	passed ≈ 2.80	passed ≈ 2.78
line discharge test, class 2 [kJ/kV $_{U_r}$]			
1 st impulse	2.42	2.46	2.45
2 nd impulse	2.42	2.47	2.46
switching time to rated voltage [ms]	92.2	88.7	88.9
rated voltage (10 s) U_r^* [kV]	5.51	5.45	5.48
\hat{i} [mA]	189	179	140
P_{max} [W]	197	182	157
cont. operating voltage U_c^* [kV]	4.41	4.36	4.39
after 5 min. \hat{i} [mA]	1.50	1.42	1.34
P [W]	1.98	1.84	1.71
after 30 min. \hat{i} [mA]	0.75	0.76	0.76
P [W]	0.69	0.62	0.62

All Samples were able to cool down during the continuous operating voltage application.
The visual inspection after the test did not show any breakdowns, flashovers or mechanical damages. One additional line discharge class 2 impulse was applied after the samples have cooled down to ambient temperature to verify that no damage

ВЯРНО С
ОРИГИНАЛА




Test Report

occurred (checked by oscillographic records).
 The change of nominal residual voltage was less then $\pm 1.13\%$.
 The samples passed the test.

The following figures show the oscillograms of the operating duty tests.


Sample ODT 1:



Nominal residual voltage before the test at 10 kA (8/20)

(Large handwritten signature)


04




ВЯРНО С
ОРИГИНАЛ

(Large handwritten signature)


Nominal residual voltage
after the test at 10 kA (8/20)



ВЯРНО С
ОРИГИНАЛА




conditioning with 10 kA, 8/20
at $U=1.2 U_c$
20th impulse




conditioning with 100 kA,
4/10

1st impulse



conditioning with 100 kA,
4/10

2nd impulse



[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА




[Handwritten signature]




1st impulse
line discharge class 2




2nd impulse
line discharge class 2
and process of switching to
rated voltage.






Sample ODT 2:




[Handwritten signature]


**ВЯРНО С
ОРИГИНАЛА**



[Handwritten signature]




Nominal residual voltage after the test at 10 kA (8/20)




ВЯРНО С
ОРИГИНАЛА


conditioning with 10 kA, 8/20 at $U=1.2 U_c$ 20th impulse



conditioning with
100 kA, 4/10
1st impulse




conditioning with
100 kA, 4/10
2nd impulse







ВЯРНО С
ОРИГИНАЛА

148





ВЕРНО С
ОРИГИНАЛА

1st impulse
line discharge class 2




2nd impulse
line discharge class 2
and process of
switching to rated
voltage





Sample ODT 3:




ВЯРНО С
ОРИГИНАЛА

150
снл




ВЯРНО С
ОРИГИНАЛА

Nominal residual voltage
after the test at 10 kA, 8/20)




conditioning with 10 kA, 8/20
at U=1.2 U_c
20th impulse




conditioning with 100 kA,
4/10

1st impulse



conditioning with 100 kA,
4/10


2nd impulse




ВЯРНО С
ОРИГИНАЛ.

152


с/л



1st impulse
Line discharge class 2




2nd impulse
line discharge class 2
and process of switching to
rated voltage



ВЯРНО С
ОРИГИНАЛА

Course of test voltage and watt loss



[Handwritten signature]

[Large handwritten signature]

ВЯРНО С
ОРИГИНАЛА

[Large handwritten signature]

154
[Handwritten signature]

DATA & RESULTS FOR THE ACCELERATED AGEING TEST performed on metal oxide resistors intended for VARISIL Type HE-1 surge arresters

Test conditions : according to the procedure and the requirements defined at clause 8.5.2 of IEC 60099-4 - Edition 22 (May 2009)

Test samples : 3 sliced parts of HE-1 surge arrester built with a single MO resistor rated 5 kV

Test voltage : $U_{ct} = U_c (1 + D \times H) \times U_{ref} / U_{refm}$ where : $U_c = 4000$ V rms is the continuous operating voltage of a MO resistor rated 5 kV

$D = 15$ %/m is the maximum distortion of voltage distributed considered within the HE-1 range


$H = 0,655$ m is the maximum arrester length corresponding to the HE-1 S4 model

$U_{ref} = 5090$ V peakVZ is the reference voltage at 1 mA peak a.c. of the test samples


$U_{refm} = 4810$ V peakVZ is the specified minimum reference voltage for a MO resistor rated 5 kV

$U_{ct} = 4660$ V rms

Testing Sample	no. 1	no. 2	no. 3
16	4,28	4,81	4,14
12	4,00	4,19	3,86
24	3,76	4,19	3,62
48	3,36	3,74	3,27
72	3,11	3,44	3,07
96	2,91	3,14	2,87
168	2,59	2,78	2,59
216	2,43	2,58	2,43
312	2,31	2,46	2,31
384	2,27	2,43	2,39
456	2,21	2,43	2,27
528	2,24	2,40	2,30
600	2,24	2,43	2,27
672	2,21	2,43	2,39
744	2,18	2,40	2,27
816	2,15	2,36	2,24
888	2,18	2,40	2,27
960	2,18	2,40	2,27
1032	2,18	2,36	2,27




CONCLUSION : as both P2ct <= 1,1 x P3ct and P2ct <= P1ct for all three test samples, the switching surge operating duty test according to clause 10.8.5 of IEC 60099-4 can be performed on new MOV blocks at Ustr and Usc without any additional correction



ВЯРНО С
ОРИГИНАЛА


Test circuit for Residual voltage test on prorated arrester sections:



C_n, C_t	Capacitive divider
R_{HV}	Damping resistance of the HV-side condenser (C_{HV})
R_{LV}	HV-side measuring resistance
C_{HV}	HV-side measuring capacitance
R_{LV}	Damping resistance of the LV-side condenser (C_{LV})
C_{LV}	LV-side measuring capacitance
L_n	LV-side measuring inductance
C_{n1}, C_{n2}	Charging inductance ($n=1, \dots, 8$)
CT	Charging capacitance ($n=1, \dots, 8$)
	Current transformer

Current waveforms:
8/20 μs
40/100 μs
1/20 μs

Test circuit for operating duty test:



T	Test transformer
$S1$	AC switch
C_n, C_t	Capacitive divider
R_{HV}	Damping resistance of the HV-side condenser (C_{HV})
C_{HV}	HV-side measuring capacitance
R_{LV}	Damping resistance of the LV-side condenser (C_{LV})
C_{LV}	LV-side measuring capacitance
Z_m	Measuring impedance
L_n	Charging inductance ($n=1, \dots, 8$)
C_{n1}, C_{n2}	Charging capacitance ($n=1, \dots, 8$)

[Handwritten signature]

[Handwritten signature]

**ВЯРНО С
ОРИГИНАЛА**


153

[Handwritten initials]

(

(

temps (s)	p.u. de Ur		p.u. de Uc	
	neuf	énergie max	neuf	énergie max
0,1	1,270	1,143	1,588	1,429
0,5	1,220	1,098	1,525	1,373
1	1,200	1,080	1,500	1,350
5	1,158	1,042	1,448	1,303
10	1,140	1,026	1,425	1,283
60	1,090	0,981	1,363	1,226
120	1,073	0,966	1,341	1,207
300	1,050	0,945	1,313	1,181
600	1,035	0,932	1,294	1,164
1800	1,010	0,909	1,263	1,136
3600	0,995	0,896	1,244	1,119
10800	0,975	0,878	1,219	1,097
36000	0,958	0,862	1,198	1,078
86400	0,948	0,853	1,185	1,067
604800	0,938	0,844	1,173	1,055





ВЯРНО С
ОРИГИНАЛА

[Large handwritten signature]


0

0


TENUE MINIMALE AUX SURTENSIONS TEMPORAIRES des parafoudres VARISIL HE-I selon Annexe D de la CEI 60099-4



ВЕРНО
ОРИГИНАЛ




TENUE MINIMALE AUX SURTENSIONS TEMPORAIRES des parafoudres VARISIL HE-I selon Annexe D de la CEI 60099-4



[Handwritten signature]

ОРПХОС
ОТДЕЛЕНИЕ
ЭЛЕКТРОЭНЕРГЕТИКИ
ДЛЯ ПРОМЫШЛЕННОСТИ
И СЕЛЬСКОХОЗЯЙСТВЕННОГО
КОМПЛЕКСА
И Т.Д.





(


100-100-100

(


**MINIMUM TEMPORARY OVERVOLTAGE WITHSTAND CAPABILITY
of VARISIL Type HE-I Surge Arresters according to Annex D of IEC 60099-4**



ОРГИНАЛ
PERMISSIBLE DURATION (s)




**MINIMUM TEMPORARY OVERVOLTAGE WITHSTAND CAPABILITY
of VARISIL Type HE-I Surge Arresters according to Annex D of IEC 60099-4**



1 ВЯРНО С
ОРИГИНАЛ

101



Client AREVA Parafoudres S.A.
Bagneres de Bigorre - FRANCE

Tested equipment Polymer-housed metal-oxide surge arresters

Tests carried out Short-circuit tests

Standards/Specifications IEC 60099-4 (2006-07)

Test date from May 20, 2008 to May 21, 2008

PUBBLICATO A8018577 (PAD - 1073222)

The results reported in this document relate only to the tested equipment.
Partial reproduction of this document is permitted only with the written permission from CESI

No. of pages 18

No. of pages annexed

ВЯРНО С
ОРИГИНАЛА

Issue date June 25, 2008

Prepared Unit LABORATORIES - P. Beccarini

Verified Unit LABORATORIES - D. Ronchi

Approved Unit LABORATORIES - R. Nicolini

CESI S.p.A.
Energy Division

Technical Area Components
"Testing Laboratories"
Manager



Tests witnessed by

Mr. F. Malpiece
Mr. H. Sauvage

AREVA Parafoudres S.A. - Bagneres de Bigorre - France
AREVA Parafoudres S.A. - Bagneres de Bigorre - France

Identification of the object

Not requested.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: A8014192

The measurement uncertainties of the test results reported in the document are the following:


voltage: $\pm 5\%$; current: $\pm 5\%$; time: $\pm 5\%$; temperature: $\pm 2^\circ\text{C}$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

Receipt date of the sample


May 19, 2008

ВЯРНО С
ОРИГИНАЛА



163

Contents	Page	Test date
<p>Rated characteristics of the tested object assigned by the Client</p> <p>Test arrangement</p> <p>Tests performed</p> <ul style="list-style-type: none"> High-current short-circuit test with 20,5 kA for 0,214 s High-current short-circuit test with 12,2 kA for 0,204 s High-current short-circuit test with 6,50 kA for 0,204 s Low-current short-circuit test with 630 A for 1,00 s <p>Test circuit</p> <p>Photos</p> <p>Pages annexed</p> <p>Oscillograms (No.7)</p>	<p>4</p> <p>5</p> <p>6</p> <p>7</p> <p>8</p> <p>9</p> <p>10</p> <p>11 to 18</p>	<p>May 21, 2008</p> <p>May 21, 2008</p> <p>May 20, 2008</p> <p>May 20, 2008</p>



ВЕРНО (ОРИГИНАЛ)

184

CESI

A8018577

Test Report


Approved

Page 3

Rated characteristics of the tested object assigned by the Client


Polymer-housed metal-oxide surge arrester	
Manufacturer	AREVA Parafoudres S. A.
Type	HE / HE-S
Drawing	-
Rated voltage (Ur)	24 kV
Maximum continuous operating voltage (Uc)	20 kV
Rated frequency	50-60 Hz
Nominal discharge current (8/20 μ s impulse shape)	10 kA
Line discharge class	I
Rated short circuit current	
High current	for 0,2 s ; 20,0 kA
Low current	for 1,0 s ; 0,60 kA

ВЯРНО С
ОРИГИНАЛА



165

D8046 - Test arrangement




- 1 : Surge arrester
- 2 : Flexible conductor
- 3 : Rigid conductor
- 4 : Base
- 5 : Surrounding fence
- 6 : Insulating wood platform

- A : 1,00 m
- B : 0,40 m
- C : 1,80 m
- D : 1,00 m

ВЯРНО С
ОРИГИНАЛА

The arrester to be tested was installed on a base at 1,40 m to ground in the middle of an enclosure of 1,80 m in side. The enclosure was positioned on the insulating wood platform.

The live side of the supply was connected to the upper end of the arrester while the return circuit, earthed, was connected to the lower end. The live conductor was directed to the opposite direction as the earth conductor



168

High-current short-circuit test with 20,5 kA for 0,214 s

Test circuit: See D0046 Power factor: <0,15 Frequency: 50 Hz

**ВЯРНО С
ОРИГИНАЛА**



Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
-	-	kA	kA

Test arrangement: See D8046

A photo detector was used to determine the venting time.
 In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.
 The short-circuit current of the auxiliary low power source has been set at about 20 A.
 The voltage applied to the arrester was increased in order to get a current equal to 100 mA (0-peak) and kept at this value or slightly adjusted till arrester failure.
 The pre-failure process duration was 2 minutes and 45 seconds.
 The short-circuit test was performed 4 minutes and 01 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new.

Date: May 21, 2008

Test No.	Oscillogram		Arrester under test No.	Duration s	Test voltage kV	Test current		Time to flame extinction after the test s	Venting time	Notes
	No.	Sheets				Peak value kA	rms value kA			
1	30	1	4	0,214	18,0	48,6	20,5	14	ms 1,0	No. -

Condition of the apparatus after the tests: see photos No.1 and 2

- There was not violent shattering.
- The arrester structure was damaged by the test.
- The arrester remained connected to the supply and return circuit.
- No fragment were found inside or outside the enclosure.

Acceptance criteria: Fulfilled.
 Test result: Positive.

High-current short-circuit test with 12,2 kA for 0,204 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
27	1	kA 12,2	kA 33,8

Test arrangement : See D8046
 A photo detector was used to determine the venting time
 In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.
 The short-circuit current of the auxiliary low power source has been set at about 20 A.
 The voltage applied to the arrester was increased in order to get a current equal to 100 mA (0-peak) and kept at this value or slightly adjusted till arrester failure.
 The pre-failure process duration was 2 minutes and 40 seconds.
 The short-circuit test was performed 3 minutes and 50 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new.

Date: May 21, 2008


Test No.	Oscillogram No.	Arrester under test No.	Duration s	Test voltage kV	Test current		Time to flame extinction after the test s	Venting time ms	Notes
					Peak value kA	rms value kA			
2	28	3	0,204	18,0	31,0	12,2	-	1,0	-

Condition of the apparatus after the tests: see photos No.3 and 4

- There was not violent shattering.
- The arrester structure was damaged by the test.
- The arrester remained connected to the supply and return circuit.
- No fragment were found inside or outside the enclosure.

Acceptance criteria: Fulfilled.
 Test result: Positive.

ВЯРНО С
ОРИГИНАЛА




CESI

Test Report

High-current short-circuit test with 6,50 kA for 0,204 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

160



Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
25	1	kA	kA
		6,60	18,1

Test arrangement : See D8046

A photo detector was used to determine the venting time.
 In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.
 The short-circuit current of the auxiliary low power source has been set at about 20 A.
 The voltage applied to the arrester was increased in order to get a current equal to 100 mA (0-peak) and kept at this value or slightly adjusted till arrester failure.
 The pre-failure process duration was 3 minutes and 0 seconds.
 The short-circuit test was performed 4 minutes and 10 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new.

Date: May 20, 2008

Test No.	Oscillogram		Arrester under test No.	Duration s	Test voltage kV	Test current		Time to flame extinction after the test s	Venting time ms	Notes
	No.	Sheets				Peak value kA	rms value kA			
3	26	1	2	0,204	18,0	16,0	6,50	-	2,0	-

Condition of the apparatus after the tests: see photos No.5 and 6

- There was not violent shattering.
- The arrester structure remained (almost) intact.
- The arrester remained connected to the supply and return circuit.
- No fragment were found inside or outside the enclosure.

Acceptance criteria: Fulfilled.
 Test result: Positive.

Low-current short-circuit test with 630 A for 1,00 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

No.	Prospective test current		Peak value
	Oscillogram	rms value	
22	Sheets	A	A
	1	630	1590

Test arrangement : See D8046
 A photo detector was used to determine the venting time.
 In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.
 The short-circuit current of the auxiliary low power source has been set at about 20 A.
 The voltage applied to the arrester was increased in order to get a current equal to 100 mA (0-peak) and kept at this value or slightly adjusted till arrester failure.
 The pre-failure process duration was 3 minutes and 05 seconds.
 The short-circuit test was performed 3 minutes and 15 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new.

Date: May 20, 2008


Test No.	Oscillogram No.	Arrester under test	Duration	Test voltage	Test current		Time to flame extinction after the test	Venting time	Notes
					Peak value	rms value			
4	24	No. 1	1,00 s	kV 23,0	A 1190	A 630	s 105	ms 8,0	No. -

Condition of the apparatus after the tests: see photos No.7 and 8

- There was not violent shattering.
- The arrester structure was damaged by the test.
- The arrester remained connected to the supply and return circuit.
- No fragments were found inside or outside the enclosure.

Acceptance criteria: Fulfilled.
 Test/result: Positive.

ВЕРНО С
 ОРИГИНАЛА



120

CESI


Test Report

Approved


A8018577

Page 9

Test circuit D0046




Symbols used in this diagram are the same as those on the oscillograms.



ВЕРНО С
ОРИГИНАЛА

[Handwritten signature]



ВЯРНО
ОРИГИНАЛ

[Handwritten signature]

Photo No.1

[Handwritten signature]



172









Photo No.2

ВЯРНО С
ОРИГИНАЛА



ВЯРНО С
ОРИГИНАЛ

Photo No.3



174





Photo No. ВЯРНО С
ОРИГИНАЛА

175








Photo No.5

ВЯРНО
ОРИГИНА





ВЯРНО С
ОРИГИНАЛА
Photo No.6

177






Photo No.7

ВЯРНО С
ОРИГИНАЛ







ВЯРНО С
ОРИГИНАЛА
Photo No. 8

179

I = 637 A
Ip = 1,59 kA
dT = 104 ms



ВЯРНО
ОРИГИНАЛ




СЕСИ P140 A801419270022


261 265 270 275 280 285 290 295 300 305 310 315 320 325 330 335 340 345 350 355 360 365 370 375 380 385 390 395 400 405
1 [ms/div.]

Sam: 2SEC, Osc: BD3F, Cal: BD3F

I = 630 A
Ip = 1,19 kA
dT = 1 s
dT = 8,0 ms




ВЯРНО С
ОРИГИНАЛА




CESI P140 A8014192/0024

Sam: 2SEC, Osc: BD3F, Cal: BD3F


I= 6,59 kA
Ip= 18,1 kA
dT= 103 ms



I = 6,5 kA
Ip = 16 kA
dT = 204 ms
dT = 2,0 ms




ВЯРНО С
ОРИГИНАЛА



CESI P140 A8014192/0026

I = 12,2 kA
Ip = 33,8 kA
dT = 104 ms



VENT-8V
1848

ВЯРН
ОРИГИНАЛ


GESI P140 A8014192/0020

276 280 285 290 295 300 305 310 315 320 325 330 335 340 345 350 355 360 365 370 375 380 387


1 [ms/div.]

Sam: 1SEC, Osc: BD3F, Cal: BD3F

I = 12,2 kA
Ip = 31 kA
dT = 214 ms
dT = 1,02 ms



ВЯРНО С
ОРИГИНАЛА



U5KV

I12kA


VENT3V

CESI P140 A8014192/0028

2 [ms/div.]

Sam: tSEC, Osc: BD3F, Cal: BD3F

I= 20,5 kA
Ip= 48,6 kA
dT= 214 ms
dT= 1,53 ms



(

(

client **ALSTOM Parafoudres S.A. - Bagneres de Bigorre Cedex (France)**

equipment under test **three 10kA polymer housed surge arresters, type HE**

tests performed **partial discharges test**

normative documents **IEC 60099-4 (1991-06)**

receipt date of the sample **december 15, 2000**

test date **from december 22, 2000 to december 22, 2000**

the test results relate only to the sample tested
this document shall not be reproduced except in full without the written approval of CESI
and of the accreditation body, if any

no. of pages **10** no. of pages annexed **2**

issue date **december 22, 2000**

prepared **PeC/TEST - C. Del Giorgio**

verified **PeC/TEST - A. Sironi**

approved **PeC/TEST - V. Scarioni**

n° 0030

**ВЯРНО С
ОРИГИНАЛА**

CESI
CENTRO ELETTOTECNICO Sperimentale ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio



(

(

tests witnessed by: Mr. F. Malpiece - ALSTOM Parafudre S.A.

identification of the object: effected

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawing identified by CESI and numbered A0/042527 no.1 is annexed to this document.

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
- dielectric tests with direct voltage : voltage: $\pm 3\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

ВЯРНО С
ОРИГИНАЛ

laboratory information

CESI testing team:

Mr. M. Amato

test laboratory:


P220 (faraday Cage)

activity code:


29380X

keywords:

12015R 23801L 31020W 41040M 53001D 62501B



188



contents	page	test date
rated characteristics of the test voltage declared by the manufacturer	4	
panoramic view of the test samples	5	
panoramic view of the test arrangement	6	
test voltage values	7	
circuit A027 - partial discharges measurement - high voltage circuit	8	
circuit A022 - partial discharges measurement - direct circuit - scheme 1a	9	december 22, 2000
partial discharges test	10	


pages annexed

②scillogram (total pages:2)


reference document annexed

drawing no. W 8997 01 36 identified by CEST and numbered A0/042527 no.1

Handwritten signature



**ВЯРНО С
ОРИГИНАЛА**



AT-A0/042489


6

6

rated characteristics of the test voltage declared by the manufacturer

polymer housed surge arrester

manufacturer
type
drawing no.
rated voltage (U_r)
continuous operating voltage (U_c)
nominal discharge current (I_N)
line discharge class
dry lightning impulse withstand voltage
wet power frequency withstand voltage



ALSTOM Parafoudre S.A.
HE
W 8997 01 36
36 kV
30 kV_{rms}
10 kA
1
170 kV_{pk}
70 kV_{rms}

NOTE: CESI marked the three polymer housed surge arresters from no.1 to no.3




ВЯРНО С
ОРИГИНАЛА





190






panoramic view of the test sample





ВЯРНО С
ОРИГИНАЛА




191



panoramic view of the test arrangement



**ВЯРНО С
ОРИГИНАЛА**



(C)


(C)

test voltage values

Partial discharges test


prestressing ($\leq 10s$) = $U_p = 36,0$ kV

measure = $1,05 \times U_p = 1,05 \times 30,0 = 31,5$ kV




ВЯРНО
ОРИГИНАЛ





circuit A027

Plant P220. High voltage circuit
partial discharges measurement



- F : wide band filter TELEC; 380 V; 100 A
- G : Faraday cage
- S : single phase circuit breaker SACE; 600 V; 800 A
- R : regulator CORMES; power 66 kVA; voltage 380 V/0 + 220 V
- T : booster transformer PIVI; power 250 kVA; voltage 200-400 V/250 kV
- C_k : coupling capacitor PASSONI & VILLA; 300 pF; 250 kV (internat to T)
- TA : current transformer CGS; ratio 150-300 A/5 A
- TV₁ : voltage transformer; ratio 220 V/100 V
- V₁ : voltmeter CESI no. 6393
- RS : partial discharge detector BIDDLE; CESI no. 09596

ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

1934



10

11

circuit A022


partial discharges measurement

direct circuit
scheme 1a




- C_k : coupling capacitor 300 pF; CESI no. -----
- Z_m : coupling impedance
- P : calibrator CESI no.02526
- RS : partial discharge detector BIDDLE; CESI no.09596
- CRO: oscilloscope CESI no.06351

Handwritten signature



ВЯРНО С
ОРИГИНАЛА



(

(

7 7

1 3

partial discharges test

test object: polymer housed surge arresters, type HE
 test circuit: A027
 measurement circuit: A022 ("direct" calibration : 0,2 pC/mV, on CRO, oscillogram no.1)
 arrangement: see page 6


atmospheric conditions		
b	t	h
kPa	°C	g / m³
101,5	20,0 (13,5)	7,3

date: december 22, 2000

test sample	applied voltage	duration of voltage application	temperature of the test object	partial discharge measurement				note
				voltage increase	voltage decrease	CRO readout	oscillogram	
	kV _{rms}	sec	°C	CRO readout	Q max	CRO readout	Q max	
1	36,0 (U _i)	≤10	20,0	mV	pC	mV	pC	no.
	31,0 (1,05U _i)	measure	20,0	--	--	≤5	≤1	4
2	36,0 (U _i)	≤10	20,0	--	--	--	--	--
	31,0 (1,05U _i)	measure	20,0	--	--	≤5	≤1	5
3	36,0 (U _i)	≤10	20,0	--	--	--	--	--
	31,0 (1,05U _i)	measure	20,0	--	--	≤5	≤1	6

ВЯРТО С
ОРИГИНАЛА

Before the test have been made: measure of the background noise; the result: p.d. ≤5mV ≤1pC (oscillogram no.2)
 Corona's effect (oscillogram no.3)



CESI TEST
 Test Services


(

(

17-11-2019

10


|



Oscillogram no.1

Channel 1 :
voltage : 100 mV/div


calibration of the measure circuit
 $q = 50\text{pC} = 250\text{mV}$
 $K = 0,2\text{pC/mV}$



Oscillogram no.2

Channel 1 :
voltage : 20 mV/div


measure of the background noise
p.d. $\leq 5\text{mV} \leq 1\text{pC}$




Oscillogram no.3

Channel 1 :
voltage : 100 mV/div

полюса отрицательной полярности
ВАРИАНТ
ОРИГИНАЛА






Oscillogram no.4

Channel 1 :
voltage : 20 mV/div


sample no.1
U = 31kV
p.d. $\leq 5\text{mV} \leq 1\text{pC}$



Oscillogram no.5

Channel 1 :
voltage : 20 mV/div

sample no.2
U = 31kV
p.d. $\leq 5\text{mV} \leq 1\text{pC}$




Oscillogram no.6


Channel 1 :
voltage : 20 mV/div

sample no.3
U = 31kV
p.d. $\leq 5\text{mV} \leq 1\text{pC}$

ВЕРНО С
ОРИГИНАЛА

198C488





Modification :		Destinateur :	Date :	Vérification :
Tolérances générales :		Destinateur : HS Date : 12/12/00 Vérification : <i>[Signature]</i>		
Matière :		Echelle :		
Traitements :		ALSTOM TRANSMISSION & DISTRIBUTION Paroissière B.P. 236 65202 Baginbras-de-Bigorre		
<input checked="" type="checkbox"/> Accessibilité du plan : <input type="checkbox"/> Confidential : <input type="checkbox"/> Type :		Ce plan est propriété de ALSTOM Paroissière SA : il ne peut être reproduit ni communiqué sans autorisation préalable		
VARISIL type HE 36 surge arrester		Folio : 1 / 1 Indice : 00		
A3 APF W 8997 01 36		A B		

PROTOCOLI : DATA

ОБВЯЗНО
ОРИГНАЛ

A 0 / 0 4 2 2 2 n.0 0 1 2 2 03-2000

Firma: *[Signature]*

199 *[Signature]*

[Large handwritten signature]



Type Test Report
 No.: TR-E 12019BM

Equipment under test: Polymer housed surge arrester of line discharge class 1, type series VARISIL HE-S TRIDELTA Parafoudres S.A.

Normative documents: IEC 60099-4 Edition 2.2 clause 10:8.9 / 8.9

Test performed: Bending moment test

Test date: 18th of October 2012 to 13th of November 2012

Number of pages: 19

Attention: The test results relate only to the sample(s) tested. This document shall not be reproduced without written approval of TRIDELTA Testing facilities.


First issue date: 15th of November 2012

Dipl.-Ing. T. Holzer	<i>T. Holzer</i>	(Test Engineer, Tridelta)
Dipl.-Ing. H. Klaube	<i>H. K. Klaube</i>	(R&D Head, Tridelta)
Dipl.-Ing. S. Schreib	<i>S. Schreib</i>	(Head SCUS GmbH)

[Handwritten Signature]

Hermesdorf, 15th of November 2012

TRIDELTA S.A. - Nonnenmühlensiedlung 11111
 Marie-Curie-Straße 2
 27622 Hermesdorf - Deutschland
 Telefon +49 (0) 56 51 9328 300
 Fax +49 (0) 56 51 9328 301
 Internet <http://www.tridelta.de>




ВЯРНО С
 ВЯРНО С
 ОРИГИНАЛА

[Large Handwritten Signature]

Test Report

TR-E 12019BM



subject

Test of Bending Moment
Surge Arrester Series
VARISIL HE-S

manufacturer

TRIDELTA Parafoudres S.A.
Boulevard de l'Adour - B.P. 256
F - 65203 Bagères de Bigorre Cedex

caused by

Type Test acc. to IEC 60099-4 Ed.2.2 Item 10.8.9 (2009-05)
Confirmation of
SSL: 200 Nm
SSL: 250 Nm

Test arrangement/course of test

Test acc. to IEC 60099-4 Ed. 2.2. Item 10.8.9 (2009-05)

The test was performed on 3 arresters made of 1 mechanical unit. The arresters were attached directly to the mounting surface of the testing machine. The direction of the load was through and perpendicular to the longitudinal axis of the arrester unit.

Test procedure:

1. Sample preparation/ Initial measurements acc. to 10.8.9.2
2. Bending moment test with SSL acc. to 10.8.9.3 a on 2 arrester units
3. Mechanical/thermal preconditioning acc. to 10.8.9.3.1 on 1 arrester unit
4. Water immersion test acc. to 10.8.9.3.2 on 3 arrester units
5. Test evaluation/ Final measurements acc. to 10.8.9.4

Sample	Typo
A	VARISIL HE-S 42
B	VARISIL HE-S 42
C	VARISIL HE-S 42

The surge arrester type series "VARISIL HE-S" passed all tests, acc. to IEC 60099-4 Ed. 2.2 (0.8.9), successfully. SSL = 200 Nm, SSL = 250 Nm; terminal torque = 45 Nm

Coordinated by :
worked out by :
checked by :

S. Schreib, see test report "12-137_PBR_rev1 Product test - VARISIL TM HE-S 42" from SCUS
T. Hölzer
H. Knaubo

ВЕРНО С
ОРИГИНАЛА

201

Test Report

TR-E 12019BM

Test results

1. Sample preparation/ Initial measurements

Watt losses at U_c

Sample No.	Voltage kV	watt losses W
A	35	3,63
B	35	3,79
C	35	3,72



Ambient temperature 20 °C

Partial discharge test

Sample No.	voltage kV	measured value pC	max. permitted value pC	ground noise pC	evaluation/ result
A	36,75	< 2	10	< 2	passed
B	36,75	< 2	10	< 2	passed
C	36,75	< 2	10	< 2	passed

Residual voltage test

Sample No.	measured value kV	current kA
A	114,9	10,2
B	114,6	10,2
C	114,6	10,2



ВЕРНО С
ОРИГИНАЛА

202

Test Report

TR-E 12019BM

2. Bending Moment test with SSL

Sample No.	Cantilever mm	Force N	Bending moment Nm	maximum deflection mm	residual deflection mm
A	397	630	250	4,53	-0,55
B	397	630	250	4,72	0,52

Sample C was subjected to the mechanical/thermal preconditioning

The residual deflection was measured in the interval 1 min to 10 min after release of the load. There was no visible damage.

3. Mechanical/thermal preconditioning

a. Terminal torque preconditioning

The arrester terminal torque of 45 Nm was applied for duration of 30s.

Cantilever mm	Force N	Torque moment Nm
300	150	45

There was no visible damage.

b. Thermo-mechanical preconditioning

The sample was subjected to the thermo-mechanical preconditioning acc. to 10.8.9.3.1.2 with the specified long-term load (SLL) of 200 Nm.

Cantilever = 397 mm; Force = 504 N

Measured displacement:

	Start without load	Start with load	End with load	End without load
Position 0° (+60°C)	0 mm	4,07 mm	11,26 mm	11,4 mm
Position 180° (+25°C)	0 mm	11,89 mm	14,04 mm	14,2 mm
Position 270° (+40°C)	0 mm	10,07 mm	11,97 mm	12,2 mm
Position 90° (-40°C)	0 mm	11,19 mm	13,48 mm	13,7 mm

4. Water Immersion test

All samples were subjected to the water immersion test acc. to 10.8.9.3.2



ВЯРНО С
ОРИГИНАЛА

203

Test Report

TR-E 12019BM

5. Test evaluation/ Final measurements

Watt losses at 1s

Sample No.	Voltage kV	watt losses W	Increase from initial measurement %	evaluation/ result
A	35	3,62	-0,3	passed
B	35	3,64	-4	passed
C	35	3,63	-2,4	passed

Ambient temperature 20 °C
 The increase in watt losses is not more than 20% from the initial measurements. After the end of boiling, the arresters were removed from the water (50 °C) (08:15 AM; 09:11:2012) and cooled to ambient temperature. The measurement was executed within 8h after cooling (02:30 PM; 09:11:2012).
 The ambient temperature does not deviate more than 3K from the initial measurements.

Partial discharge test

Sample No.	voltage kV	measured value pC	max. permitted value pC	ground noise pC	evaluation/ result
A	36,75	<2	10	<2	passed
B	36,75	<2	10	<2	passed
C	36,75	<2	10	<2	passed

Reference voltage before two impulses at nominal discharge current

Sample No.	measured value kV
A	40,7
B	40,6
C	40,7

Residual voltage test (first impulse)

Sample No.	measured value kV	current kA	Increase from initial measurement %	evaluation/ result
A	114,5	10,2	-0,3	passed
B	115,1	10,2	+0,4	passed
C	114,3	10,2	-0,3	passed

The measured values are not more than 5% different from the initial measurement.

Residual voltage test (second impulse)

Sample No.	measured value kV	current kA	Increase from initial measurement %	Increase from first impulse %	evaluation/ result
A	115,2	10,2	+0,3	+0,6	passed
B	115,4	10,2	+0,7	+0,3	passed
C	115,2	10,2	+0,5	+0,8	passed

The measured values are not more than 5% different from the initial measurement. The difference in voltage between two successive impulses at nominal discharge current does not exceed 2%. The oscillograms of voltage and current do not reveal any partial or full breakdown of the test sample.

Reference voltage after two impulses at nominal discharge current




Sample No.	measured value kV	increase %	evaluation/ result
A	41,2	+1,2	passed
B	41,2	+1,5	passed
C	41,3	+1,5	passed

The change in reference voltage measured before and after the two residual voltage tests does not exceed 2%.

The surge arrester type series "VARISIL HE-S" passed all tests, acc. to IEC 60099-4 Ed. 2.2 10.8.9, successfully. SIL = 200 Nm, SSL = 250 Nm and terminal torque = 48 Nm

ВЕРНО С
 ОРИГИНАЛА

Appendix 1 Sample preparation/ Initial measurements




ВЕРНО С
ОРИГИНАЛА

205

Test Report

TR-E 12019BM



Residual voltage test of sample No. C

[Handwritten signature]




[Handwritten signature]

ВЕРНО С
ОРИГИНАЛА

[Large handwritten signature]

206



Appendix 2 Bonding moment test with SSL



ВЕРНО С
ОРИГИНАЛА

Test Report

Appendix 3 Thermo-mechanical preconditioning






[Handwritten signature]


[Circular stamp: INSTITUT ZA VEŠTAČENJE I PROJEKTOVANJE]

ВЯРНО С
ОРИГИНАЛА


[Large handwritten signature]



ВЕРНО С
ОРИГИНАЛА



Appendix 4 Water Immersion test



[Handwritten signature]






[Large handwritten signature]

ВЯРНО С
ОРИГИНАЛА


012

Appendix 5 Test evaluation/ Final measurements




**ВЯРНО С
ОРИГИНАЛА**

Test Report




Residual voltage test of sample No. C (first impulse)






Residual voltage test of sample No. A (second impulse)

[Handwritten signature]




[Large handwritten signature]

ВЯРНО С
ОРИГИНАЛА



ВЯРНО С
ОРИГИНАЛА

Appendix 6 Test arrangement



HT	Test transformer	PEO S/100 A/K-2
M1	AC peak voltmeter	MU 14
M2	Partial discharge detector	MTE 3
Osc	Oscilloscope	Philips PM 3208
R _{sh}	Shunt resistor	10000
Z _B	Blocking impedance	40mH
C _C	Coupling capacity	C 06
Z _M	Measuring impedance	H 322
Cal	Calibrator	PET 2-1
TS	Test sample	
PA	Power Analyzer	ZES ZIMMER LMG95

Test circuit for measurement of reference voltage and partial discharges



[Handwritten signature]

[Circular stamp: OZARSKA LIPA, ZEMSKA VELESKA ŠKOLA, ZEMSKA VELESKA ŠKOLA]


[Handwritten signature]

**ВЕРНО С
ОРИГИНАЛА**


214




Appendix 7 Photos



ВЕРНО С
ОРИГИНАЛА




climatic chamber for bending moment test and thermo-mechanical preconditioning



test arrangement inside the climatic chamber for bending moment test and thermo-mechanical preconditioning



[Handwritten signature]




[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА

[Large handwritten signature]



Water immersion test arrangement / boiling tank



Water immersion test arrangement / boiling tank with arrester

7000 ВЯРНО С
ОРИГИНАЛА

SLL = 200 N.m
SSL = 250 N.m

Manufacturer:	Manufacturer:	Date:	Version:
VARISIL	VARISIL		
Product Name:	Product Name:	Part No.:	Part No.:
VARISIL Type HE-S 42	VARISIL Type HE-S 42	8998-00-42	8998-00-42
Polymer Housed Surge Arrester	Polymer Housed Surge Arrester		
A3 TPF W 8998 00 42 / E		170-200	

[Handwritten signature]



[Large handwritten signature]

ВЕРНО С
ОРИГИНАЛА



WEATHER TESTING

client ALSTOM Parafoudres S.A. - Bagrieres de Bigorre (France)

equipment under test Polymer housed metal-oxide surge arrester type VARISIL HE 36

tests performed Weather ageing test - Test series A

normative documents IEC 60099-4 (2001-12) edition 1.2

receipt date of the sample July 18, 2002

test date from August 07, 2002 to October 18, 2002

the test results relate only to the sample tested
 this document shall not be reproduced except in full without the written approval of CESI
 and of the accreditation body, if any

no. of pages 23 no. of pages annexed 4

issue date December 18, 2002

ВЕРНО С
ОРИГИНАЛА

prepared PeC/TEST - M. Bonomelli

verified PeC/TEST - A. Sironi

approved PeC/TEST - V. Scarloni



tests witnessed by: /

Identification of the object: The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.

The drawing identified by CESI and numbered A2/016115 is annexed to this document.

- The measurement uncertainties of the test results reported in this document are the following:
- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
 - dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
 - dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

ВЕРНО С
ОРИГИНАЛА

laboratory information

CESI testing team:

Mr. M. Bonomelli
Mr. M. Gregori - Mr. L. Podavitte

test laboratory: P177 - surge arrester laboratory

test laboratory: P189 - weather ageing laboratory

activity code: 33618J

keywords: 12015R, 223600, 31020W, 44060J, 53001D, 62570N



(C)


(C)

contents	page	test date
Test object characteristics	4	
Reference standard	5	
Test procedure	6	
Summary of test result	7	
Initial measurement	8 ÷ 9	07 August 2002
Visual examination	10	28 August ÷ 10 October
Final measurement	11 ÷ 12	11 October 2002
Photos	13 ÷ 20	
Technical data of the test circuit	21 ÷ 23	

ВЕРНО
ОРИГИНАЛ

Page annexed: oscillogram n. 06
Reference document annexed: ALSTOM drawing W 6997 01 36

221




AT-A2/032924

C

C

Test object characteristics

type: Metal-oxide surge arrester type HE 36 (sample #1)

electrical characteristics (claimed by the client)

manufacturer's name	ALSTOM Parafoudrés S.A.
nominal discharge current - I_n [kA]	10,0
rated voltage - U_n [kV]	36
continuous operating voltage - U_c [kV]	30,0
minimum reference voltage - [kV _{pkwz}]	34,1
maximum residual voltage - [kV _{pk}]	97,8
rated frequency - [Hz]	50 - 60


geometrical characteristics (measured on the test sample)

total height [mm]	325
number of large sheds	10
number of small sheds	9
shed large diameter [mm]	115
shed small diameter [mm]	85
shed spacing [mm]	30
core diameter [mm]	50
creepage distance [mm]	1200

other characteristics

housing material	polymeric
housing color	grey

**ВЯРНО С
ОРИГИНАЛА**





Reference Standard

IEC 60099-4 (2001-12) edition 1.2 Clause 9.7.9
" Metal-oxide surge arrester without gaps for a.c. system"

Test carried out

test carried out	number of sample tested
initial measurements	One sample The sample was identified by the manufacturer as sample #1
weather test series A - 1000 hours	
final measurements and visual inspection	

A view of the test object is shown at page 14 (aged sample)

ВЯРНО С
ОРИГИНАЛА



Test procedure

Initial measurement

- The reference voltage have been measured at reference current equal to 1 mA_{pk}
- Internal partial discharge have been measured.
The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec. Then the voltage has been decreased to 1,05 times the continuous operating voltage (U_c) and the partial discharge level has been measured according to the reference standard.

Test series A - 1000 hours

The test specimens have been mounted inside the test chamber in vertical position. The test specimens has been energized at U_{test} = 20.8 kV_{rms} and kept for a total duration of 1000 hours in the test chamber filled with salt fog in the following conditions:

- salinity of the water solution: 10 kg/m³ for the first 445 hours, 5 kg/m³ for the last 555 hours
- water flow rate 0.4 ± 0.1 l/h*m³

The fog was not directly sprayed against the test specimens.

A view of the test configuration is shown on page 13

Final measurement

- The reference voltage have been measured at reference current equal to 1 mA_{pk}
- Internal partial discharge have been measured.
The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec. The voltage has been decreased to 1,05 times the continuous operating voltage (U_c) and the partial discharge level has been measured according to the reference standard.
- The test samples have been visually inspected

Note The test was carried out in parallel with other two specimens with different design

ВЯРНО С
ОРИГИНАЛА





Summary of test result

Test series A - 1000 hours

No overcurrent trip out occurred during the test.

Visual inspection

No tracking, shed puncture or significant erosions have been evidenced by the visual inspection carried out at the end of the test.

Variation of the reference voltage

	before test	after test	variation
	kV	kV	%
sample #1	33.93	34.09	+ 0.47

Acceptance criteria: variation before/after less than 5 %

Partial discharge level

	before test	after test
	pC	pC
sample #1	< 1	< 1

Acceptance criteria: partial discharge level less than 10 pC

All acceptance criteria according to the reference standard are satisfied and therefore the results is to be considered positive.

ВЯРНО С
ОРИГИНАЛА






Measurement of the reference voltage - initial

test object: Metal-oxide surge arrester
test circuit: A019



date: August 07, 2002



oscill. no.	voltage kV	sample #1			power W	3rd harmonic amplitude μ A
		current + mA _{cr}	current - mA _{cr}	current mA _{rms}		
01	33,93	1,00	1,09	0,58	9.18	161,87



ВЯРНО С
ОРИГИНАЛА



C.

C.

Measurement of partial discharges - initial

test object: Metal-oxide surge arrester

test circuit circuit: A012

measurement circuit: A022 ("direct" calibration : 0,2 pC/mV, on CRO, see oscillogram n. ...)


arrangement: ---

atmospheric conditions	
b	h
kPa	g / m ³
t	22
°C	

date: August 07, 2002

test condition	applied voltage KV _{max}	duration of voltage application sec	temperature of the test object °C	partial discharge measurement		oscillogram no.	note
				voltage increase CRO readout mV	voltage decrease CRO readout mV		
sample #1				Q max pC	Q max pC	04	
sample #1	36	10	26	≤ 5	≤ 1		
	31,5			≤ 5	≤ 1	05	

Note: background noise ≤ 1 pC, see oscillogram n. 03



**ВЯРНО
ОРИГИНАЛ**

22
Test-Report

CESTEST


AT-A2/032924




Visual examination


The housing of the specimen has been inspected visually.
See photos from page 15 to 20.

No tracking, shed puncture or significant erosions have been evidenced by the visual inspection carried out at the end of the test.



ВЯРНО С
ОРИГИНАЛА






Measurement of the reference voltage - final

test object: Metal-oxide surge arrester
test circuit: A019

date: October 11, 2002



oscill.	voltage	sample no. #1			power	3rd harmonic amplitude
		current	current	current		
no.	kV	+ mA _{op}	- mA _{op}	mA _{max}	W	μA
02	34,09	0,98	0,99	0,35	8,11	141,89



ВЯРНО ()
ОРИГИНАЛ



Handwritten signature and a circular stamp containing the text "СЛ" and "229".

(

(

Measurement of partial discharges - final

test object: Metal-oxide surge arrester

test circuit: A012

measurement circuit: A022 ("direct" calibration : 0,2 pC/mV, on CRO, see oscillogram n. ...)

arrangement: ---

atmospheric conditions		
b	t	h
kPa	°C	g / m³
	20	

date: October 11, 2002

test condition	applied voltage	duration of voltage application	temperature of the test object	partial discharge measurement				oscillogram	note	
				voltage increase	voltage decrease	CRO readout	Q max			CRO readout
sample #1	kV _{rms}	sec	°C	mV	mV	pC	pC	no.		
		Calibration of the test circuit								
	36	10	20	≤ 5	≤ 5	≤ 1	50	07		
	31,5		20					08		

Note: background noise ≤ 1 pC, see oscillogram n. 06

ВЕРНО С
ОРИГИНАЛА



AT-A2/032924



Test Report

①


②

③

Photo n. 1: test configuration



ВЯРНО С
ОРИГИНАЛА




3

3

100

Photo n. 2 - sample #1 after the test




ІРНО С
ГИНАЛ



8


8

Photo n. 3 - sample #1 after the test



SAMPLE N. 1
TYPE VARISIL HE 36
AFTER 1000 hours

ВЯРНО С
ОРИГИНАЛА








Photo n. 4 - sample #1 after the test



ВЯРНО С
ОРИГИНАЛА




•

⌋

⌋

Photo n. 5 - sample #1 after the test



ВЯРНО С
ОРИГИНАЛА







Photo n. 6 - sample #1 after the test

[Handwritten signature]



ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]

[Large handwritten signature]

[Handwritten signature]


236 *[Handwritten signature]*

①

②

Photo n. 7 - sample #1 after the test

[Handwritten signature]



SAMPLE N. 1

[Large handwritten signature]

ВЯРНО С
ОРИГИНАЛА


[Handwritten initials]

237 *[Handwritten signature]*



8

2

Photo n. 8 - sample #1 after the test




ВЯРНО С
ОРИГИНАЛ



8

8

circuit A019



power frequency supply

RE : programmable supply CESI no. 9889 ; type 3H series 3000

PC : personal computer

T : transformer type PIV1; voltage 200 V/ 50 kV

current shunt (R) CESI no.11537 ; $R = 1034 \Omega$

oscilloscope CESI no. 4552

type Data Precision DATA 6000

Handwritten signature

voltage divider (D) CESI no.11120 $K=1010$

electro optical system CESI no. 11519/520

oscilloscope CESI no. 4552

type Data Precision DATA 6000

ВЯРНО С
ОРИГИНАЛА

Handwritten signature


Large handwritten signature



5

5

circuit A012



power frequency test circuit

- R : regulator type CORMES; power 66 kVA ; voltage 380 V/0 - 0,22 kV
- TA : current transformer CGS; ratio 150-300/5
- I₁ : amperometer direct reading INDEX
- TV₁: voltage transformer CGS ; ratio 220-440/100
- V₁ : voltmeter direct reading TSE
- R_{bt} : protection resistor --- Ω
- T : booster transformer PIVI ; power 250 kVA ; voltage 200-400 V/250 kV
- TV₂: voltage transformer type CGS ; CESI no. 287; ratio 30000/100
- V₂ : voltmeter CESI no. 6393

Handwritten mark resembling the letters 'VA'.

**ВЯРНО С
ОРИГИНАЛ**

Large handwritten signature and a circular stamp with the number 210 and the word 'Сух' (Dry).


8

8

circuit A022

partial discharges measurement

direct circuit
scheme 1a



- C_k : coupling capacitor 0,3 nF
- Z_m : coupling impedance
- P : calibrator no.Cesi 3466
- RS : partial discharge detector Biddle; no. CESI 9595
- CRO: oscilloscope no. CESI 6353

ВЕРНО С
ОРИГИНАЛ


2

2


CESI GPS

A 2 / 03 2924 - 001

BUF . A1




BUF . A3



ВЯРНО С
ОРИГИНАЛ

CESI GPS


A 2 / 03 2924 - 001




3

3

BUF.A1




BUF.A3



[Handwritten signature]

ВЯРНО С
ОРИГИНАЛ.




CESI GPS

A 2 / 0 3 2 9 2 4 - 0 0 2

8.

9.




Oscillogram no. 06

Channel 1 :
 voltage : 5 mV/div.
 time : s

Channel 2 :
 voltage : V
 time : s

background noise of the circuit
 $Q_{max} \leq 1 \text{ pC}$

Oscillogram no. 07




Channel 1 :
 voltage : 100 mV/div.
 time : s

Channel 2 :
 voltage : V
 time : s

calibration of the test circuit
 $50 \text{ pC}/250 \text{ mV} = 0,2 \text{ pC/mV}$

Oscillogram no. 08



Channel 1 :
 voltage : 5 mV/div.
 time : s


Channel 2 :
 voltage : V
 time : s

Sample no. 01 before the test
 $U = 31,5 \text{ kV}$
 $Q_{max} \leq 1 \text{ pC}$

ВЯРНО
 ОРИГИНАЛ

2

3




Oscillogram no. 03

Channel 1 :
voltage : 5 mV/div.
time : s

Channel 2 :
voltage : V
time : s

background noise of the circuit
 $Q_{max} \leq 1 \text{ pC}$




Oscillogram no. 04

Channel 1 :
voltage : 100 mV/div.
time : s

Channel 2 :
voltage : V
time : s

calibration of the test circuit
 $50 \text{ pC}/250 \text{ mV} = 0,2 \text{ pC/mV}$



Oscillogram no. 05

Channel 1 :
voltage : 10 mV/div.
time : s

Channel 2 :
voltage : V
time : s

Sample no. 01 before the test
 $U = 31,5 \text{ kV}$
 $Q_{max} \leq 1 \text{ pC}$

ВЯРНО С
ОРИГИНАЛ





8

9

10

11

upper side of
the surge arrester



CESI

PROTOCOLLO DATA

A 21018 115 n.001 27 MAG. 2002

Firma Marco Geronzi

ВЕРНО С
ОРИГИНАЛА


<input type="checkbox"/> Accessibilité du plan: <input checked="" type="checkbox"/> Confidentiel <input type="checkbox"/> Libre	Modification:	Dessinateur:	Date:	Vérification:			
	Tolérances générales:						
	Matière:						
	Traitement:						
Ce plan est propriété de ALSTOM Parafoudres SA: Il ne peut être ni reproduit ni communiqué sans autorisation préalable.	Echelle :	Dessinateur: HS	Date: 03/05/02	Vérification:			
	VARISIL Type HE 36 Surge Arrester						
	ALSTOM TRANSMISSION & DISTRIBUTION Parafoudres B.P 256 65202 Bagnères-de-Bigorre						
A4		APF		W 8997 01 36		Fp/1p : 1 / Ind : 02	

8

8

8

CESI



Vs. rif.

Ns. rif. PeC - A3/001926

Data 21-01-2002

Messrs.
ALSTOM transmission & distribution
Parafoudres
65202 Bagnères-de-Bigorre
Att. Mr. Frederic Malpiece

Subject: Weather ageing test according to IEC standard 60099-4 (2001-12) on one polymer housed surge arrester type HE 24

Dear Sirs,

With reference to your request and awaiting to get ready the test report relevant to the subject we wish to send you here below a summary of the test carried out and of the relevant results

1. TEST OBJECTS

One polymer housed surge arrester type HE 24 (drawing W 8997 01 24)

The following ratings were assigned by the manufacturer:

- Rated voltage: 24 kV
- Continuous operating voltage: 20 kV
- Nominal discharge current: 10 kA


ВЯРНО С
ОРИГИНАЛА

2. NORMATIVE REFERENCES

IEC 600994 (2001-12): "Surge arresters - metal oxide surge arresters without gaps for a.c. systems"



Pag 1/1



3. TEST PLAN

The test was carried according to IEC 60099-4 at item 9.7.10 test series B
The surge arrester, mounted in vertical position, was energized at a power frequency voltage equal to 13.9 kV for 5000 hours while submitted to the various environmental stresses as specified in figure 9 of the standard.

Before and after the test the partial discharges and the reference voltage were measured for comparison.

Note that, according to Alstom request, the test voltage was $24/\sqrt{3} = 13.9$ kV while the continuous operating voltage specified for the surge arrester is 20 kV

4. TEST RESULTS

No overcurrent trip-out occurred during the test.


No tracking, shed puncture, deep erosions or other significant damages were observed at the end of the test.

The partial discharge level measured before and after the test was less than 1 pC

The reference voltage measured before and after the test were respectively 23.16 kV and 22.93 kV with a decreasing of about 1%.

5. CONCLUSION

All the acceptance criteria specified by the standard at item 9.7.10.3 are satisfied and therefore the test result is to be considered positive.



ВЯРНО С
ОРИГИНАЛА

Test Report

CESI TEST
Testing Services

AT-A3/007530

p.1

client **ALSTOM Parafoudres S.A. - Bagneres de Bigorre (France)**

equipment under test **Polymer housed metal-oxide surge arrester type VARISIL HE 24**

tests performed **Weather ageing test - Test series B**

normative documents **IEC 60099-4 (2001-12) edition 1.2**

receipt date of the sample **02 May, 2002**

test date **from 15 May, 2002 to 15 December, 2002**

the test results relate only to the sample tested
this document shall not be reproduced except in full without the written approval of CESI

**ВЯРНО С
ОРИГИНАЛА**

no. of pages **23** no. of pages annexed **4**

issue date **27 March 2003**

prepared **PeC/TEST - M. Bonomelli**

verified **PeC/TEST - A. Sironi**

approved **PeC/TEST - V. Scarioni**

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio

CESI
Centro Elettrotecnico
Sperimentale Italiano
Giacinto Motta SpA

Via R. Rubattino 54
20134 Milano - Italia
Telefono +39 022125.1
Fax +39 0221255440
www.cesi.it

Capitale sociale 8 550 000 Euro
interamente versato
Codice fiscale e numero
iscrizione CCIAA 00793580150

Registro Imprese di Milano
Sezione Ordinaria
N. R.E.A. 429222
P.I. IT00793580150

249


tests witnessed by: /

Identification of the object: The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.

The drawing identified by CESI and numbered A3/011332 is annexed to this document.

ВЯРНО С
ОРИГИНАЛА



The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

CESI testing team:

Mr. Bonomelli

Mr. M. Gregori - Mr. L. Podavitto

test laboratory: P177 - surge arrester laboratory

test laboratory: P189 - weather ageing laboratory

activity code: 3361BJ

keywords: 12015R, 22360D, 31020W, 44060J, 53001D, 62670N

250

Am

contents	page	test dates
Test object characteristics	4	
Reference standard	5	
Test procedure	6	
Summary of test result	9	20.05.2002 + 15.12.2002
Initial measurement	10+11	03.07.2002
Visual examination	12	
Final measurement	13+14	09.12.2002
Photos	15+23	

Page attached: oscillogram n. 04.

Reference document annexed: ALSTOM drawing A11071332 n. 1

ВЯРНО С
ОРИГИНАЛА

251



Test Report

AT-A3/007530

p.3

Test object characteristics

type: Metal-oxide surge arrester type VARISIL HE 24

electrical characteristics (claimed by the client)

manufacturer's name	ALETOM Parafoudres S.A.
nominal discharge current - I_n (kA)	10,0
rated voltage - U_n (kV)	24
continuous operating voltage - U_c (kV)	20
rated frequency - (Hz)	50 - 60


geometrical characteristics (measured on the test sample)

total height (mm)	245
number of large sheds	7
number of small sheds	7
shed large diameter (mm)	110
shed small diameter (mm)	80
shed spacing (mm)	30 (large-large), 15 (large-small)
core diameter (mm)	50
creepage distance (mm)	800

ВЕРНО С
ОРИГИНАЛА

other characteristics

housing material	silicon
housing color	gray



252

[Handwritten signature]

Reference Standard

IEC 60099-4 (2001-12) edition 1.2 at clause 9.7,10
" Metal-oxide surge arrester without gaps for a.c. system"

Test carried out

test carried out	number of sample tested
initial measurements	One sample identified as sample #6
weather test series D - 6000 hours	
final measurements and visual inspection	

A view of the test object is shown at page 16.

ВЯРНО С
ОРИГИНАЛА



[Handwritten signature]
253
[Handwritten signature]

Test procedure

Initial measurement

- The reference voltage have been measured at reference current equal to 1 mA_{ref}
 - Internal partial discharge have been measured.
- The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec. Then the voltage has been decreased to 1,05 times the continuous operating voltage (U_c) and the partial discharge level has been measured according to the reference standard.

Test series A - 5000 hours

The test specimen has been installed in the test chamber in vertical position.
 The test specimen has been kept energized at the voltage U_{test} = 13.9 kV_{rms} while submitted to the daily multi-stress environmental cycle as specified below.
 The multi-stress environmental cycle was repeated 200 times for a total duration of 5000 hours.
 The main characteristics of the different environmental stresses applied during the test are reported in the following table:

environmental stress	daily duration (h)	total duration (h)	severity
salt fog	8	1664	7 g/l - 0,4 l/h/m ²
humidification	4	832	59 %
rain	2	416	100 l/m ² - 1,5 mm/min
U.V. radiation	12	2496	50 mW/cm ²
heating	10	2000	50 °C


A scheme of the daily cycle is shown at page 7.

A scheme of the test configuration is shown at page 8.

A view of the test configuration is shown on page 17.

ВЯРНО С

ОДИННАКА




Note The test was carried out in parallel with other specimens with different design

Note According to client request the test voltage was $24/\sqrt{3} = 13.9$ kV while the specified continuous operating voltage is 20 kV

Final measurement

- The reference voltage have been measured at reference current equal to 1 mA_{ref}
 - Internal partial discharge have been measured.
- The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec. The voltage has been decreased to 1,05 times the continuous operating voltage (U_c) and the partial discharge level has been measured according to the reference standard.
- The test samples have been visually inspected

AS



[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА

Fig. 4 - Daily cycle

[Handwritten scribbles]

[Handwritten signature]
[Circular stamp]
Cyst

255

[Handwritten signature]




Fig. 6 - Scheme of the test configuration

256

Am

Summary of test result

Test series B - 5000 hours

No flashover occurred during the test

Visual inspection

No tracking, shed puncture, erosion or any significant deterioration has been evidenced by the visual inspection carried out at the end of the test.

Variation of the reference voltage

	before test	after test	variation
	kV	kV	%
sample #5	23,16	22,99	- 1,0

Acceptance criteria: variation before/after less than 5 %


Partial discharge level

	before test	after test
	pC	pC
sample #5	< 1	< 1

**ВЯРНО С
ОРИГИНАЛА**

Acceptance criteria: partial discharge level less than 10 pC

All acceptance criteria according to the reference standard are satisfied and therefore the results is to be considered positive.




257

Measurement of the reference voltage - initial

test object: Metal-oxide surge arrester

date: 09 March, 2002

desc., no.	voltage kV	sample #2			power W	3rd harmonic amplitude μA
		current + mA _{cs}	current - mA _{cs}	current mA _{res}		
1	23,10	1,0	0,88	0,89	7,70	1,78




ВЕРНО С
ОРИГИНАЛА

[Handwritten signature]

Visual examination

The housing of the specimen has been inspected visually.
No tracking, shed puncture, erosion or any significant deterioration has been evidenced by the visual inspection carried out at the end of the test.
See photos from page 18 to 23.

✓ ВЯРНО С
ОРИГИНАЛА



260

AM

Test Report

Measurement of the reference voltage - final

test object: Metal-oxide surge arrester

date: 09 December, 2002

seq. no.	voltage kV	sample no. #5			power W	3rd harmonic amplitude µA
		current + mA _{op}	current - mA _{op}	current mA _{res}		
2	22,93	0,65	1,04	0,55	---	

ВЯРНО С
ОРИГИНАЛА


Ch

18001

ПРОТОКОЛИ ОТ ТИПОВИ ИЗПИТАНИЯ за VARISIL HE-S тип вентилни отводи с полимерна външна изолация

Проведени типови изпитания	Референтни стандарти	Изпитани мостри	ИЗПИТАТЕЛНИ ПРОТОКОЛИ			Допълнителна информация
			Справка	Дата	Език	
Изпитания за		Външна изолация	CESI AT-A1/025452	Септември 3, 2001	Английски	
издържливост на външната изолацията	IEC 60099- 4 §10.8.2	стойност 12kV, 24&36kV Външна изолация стойност 18kV, тип S3 изолационна конзола	CESI AT-A1/025961	Септември 5, 2001	Английски	
Изпитания на остатъчното напрежение със стръмен мълниев и прекъсвачтелен токов импулс	IEC 60099- 4 §10.8.3	Напрежение 6 kV	CESI AT-A0/041526	Януари 25, 2001	Английски	Волт-амперни характеристикини криви VI8998 01 XX/E rev.01/януари 04, 2010, англ./
Изпитания за издържливост на продължителен токов импулс	IEC 60099- 4 §10.8.4	HE 6 kV SID2	CESI A5/046538	Януари 22, 2013	Английски	
Изпитване в експлуатационен режим с висок токов импулс	IEC 60099- 4 §10.8.5	HE 6 kV SID2	CESI A5/055428	Март 7, 2013	Английски	
Напрежено-времева характеристична крива	IEC 60099- 4 §6.10	HE-S обсер		2013	Английски	Волт-амперни характеристикини криви VI8998 01 XX/E rev.01/януари 04, 2010, англ./


20
00
CVS/характеристична крива



8

8

Тест на разединител	IEC 60099- 4 §8.6.2.1	Тип S3D2 разединител	Септември 14, 2011	Английски	
	IEC 60099- 4 §8.6.2.2		Септември 14, 2011	Английски	
	IEC 60099- 4 §8.6.3		Септември 13, 2011	Английски	
Изпитания при късо съединение	IEC 60099- 4 §10.8.7	HE-S 24 вентилни отводи	Юни 25, 2008	Английски	
Изпитания за частични разряди	IEC 60099- 4 §10.8.8	HE-36 вентилни отводи	Декември 22,2000	Английски	
Изпитания на момент на огъване	IEC 60099- 4 §10.8.13	HE- S 42 вентилни отводи	Ноември 15, 2012	Английски	
Изпитване за стареене	IEC 60099- 4 §10.8.14.2.1/ 1000 часа изпитание/	HE 36 вентилни отводи	Декември 18, 2002	Английски	
	IEC 60099- 4 §10.8.14.2.2/ 5000 часа изпитание/	HE 24 вентилни отводи	Март 27, 2003	Английски	




8

9

10
11
12


13



TRIDELTA Parafoudres S.A.

**TYPE TEST REPORTS relating to
VARISIL™ HE-S polymer housed surge arresters & associated accessories**

TYPE TESTS PERFORMED	REFERENCE STANDARD	SAMPLES TESTED	TEST REPORT		ADDITIONAL INFORMATION
			Reference	Date	
Insulation withstand tests on the housings & the insulating bracket	IEC 60099-4 § 10.8.2	Housings rated 12 kV, 24 kV & 36 kV	CESI AT-A1/025452	September 3, 2001	see Note 2
		Housing rated 18 kV & Type S3 insulating bracket	CESI AT-A1/025961	September 5, 2001	
Steep, lightning and switching current impulse residual voltage tests	IEC 60099-4 § 10.8.3	HE 6 kV prated sections	CESI AT-A0/041526	January 25, 2001	see Note 2 & Voltage vs current characteristic curve VI 8998 01 XX / E rev. 01 (January 4, 2010, English)
Long duration current impulse withstand test	IEC 60099-4 § 10.8.4	HE 6 kV S1D2 prated sections	CESI A5/046538	September 28, 2005	see Note 2
High current impulse operating duty test	IEC 60099-4 § 10.8.5	HE 6 kV S1D2 prated sections	CESI A5/055428	December 14, 2005	see Note 2
Voltage vs time characteristic curve	IEC 60099-4 § 6.10	HE-S range			Curve UT 8998 01 XX / E rev. 01 (January 4, 2010, English)
Tests on disconnector	IEC 60099-4 § 8.6.2.1	Type S3D2 disconnector	CESI B1027449	September 14, 2011	Test carried out in series with a HE 6 kV S3D2 section
	IEC 60099-4 § 8.6.2.2		CESI B1027448	September 14, 2011	Test carried out in series with a HE 6 kV S3D2 section
	IEC 60099-4 § 8.6.3		CESI B1027905	September 13, 2011	Current vs time characteristic curve CT 8997 09 9X / E rev. 02 (September 14, 2011, English)



Reference: TPF ST HE-S 01 / E rev. 02

Date : January 9, 2013

Page : 1 / 2

20
07

TRIDELTA



TRIDELTA Parafoudres S.A.

26


TYPE TESTS PERFORMED	REFERENCE STANDARD	SAMPLES TESTED	TEST REPORT		ADDITIONAL INFORMATION
			Reference	Date	
Short circuit tests	IEC 60099-4 § 10.8.7	HE-S 24 surge arresters	CESI A8018577	June 25, 2008	English
Partial discharge test	IEC 60099-4 § 10.8.8	HE 36 surge arresters	CESI AT-A0/042489	December 22, 2000	English
Bending moment test	IEC 60099-4 § 10.8.13	HE-S 42 surge arresters	TRIDELTA / SCÜS TR-E 12019BM	November 15, 2012	English
Weather ageing test	IEC 60099-4 § 10.8.14.2.1 (1000 h test)	HE 36 surge arrester	CESI AT-A2/032924	December 18, 2002	English
	IEC 60099-4 § 10.8.14.2.2 (5000 h test)	HE 24 surge arrester	CESI AT-A3/007530	March 27, 2003	English

Note 1 : Reference is made to the latest version of IEC 60099-4 standard, namely edition 2.2 published in May 2009

Note 2 : The HE-S arrester design is very similar to the HE and is in particular built with the same MO resistors, resulting in the same voltage stress per unit length but even lower voltage stress per unit thickness.

Therefore, the type tests carried out on HE samples for checking the MO resistor or/and insulation performance also cover the HE-S range.

ВЯРНО С
ОРИГИНАЛА



TENU D'ELECTRIQUE
HE ENEL

REPLACE PAROET
CESI AT-AO 104745


REPLACE PAROET
CESI AT-AO 104745


ISEC

ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]
[Handwritten signature]
[Handwritten signature]
207

[Handwritten signature]
[Handwritten signature]
[Handwritten signature]
C 477





client **ALSTOM Parafoudres S.A. - Bagnères de Bigorre Cedex (France)**

equipment under test **housing of 10kA polymeric housed surge arresters**

tests performed **dry lightning impulse voltage test;
wet power frequency voltage test.**

normative documents **IEC 60099-4 (1991-06)**

receipt date of the sample **december 15, 2000**
test date **from december 19, 2000 to february 01, 2001**

the test results relate only to the sample tested
this document shall not be reproduced except in full without the written approval of CESI
and of the accreditation body, if any



no. of pages **12** no. of pages annexed **-**

issue date **September 03, 2001**

prepared **PeC/TEST - C. Del Giorgio**

verified **PeC/TEST - A. Sironi**

approved **PeC/TEST - V. Scarioni**

Alberto Sironi

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prov. to Compagnoni
Il Responsabile *V. Scarioni*

CESI
Centro Elettrotecnico
Sperimentale Italiano
Cielinto Morta Spa
Via R. Rubattino 64
20139 Milano, Italia
Telefono +39 02 21255440
Fax +39 02 21255440
www.cesi.it
Capitale sociale 8 650 000 Euro
Inserimento versato
Codice veicolo e numero
Iscrizione C.C.I.A.A. 00735580150
Registro Imprese di Milano
Sezione Ordinaria
N. F.E.A. 429222
P.I. IT00735580150

**ВЯРНО С
ОРИГИНАЛА**

tests witnessed by: Mr. F. Malpiece - ALSTOM Parafudre S.A.

identification of the object: effected
The Manufacturer guarantees that the tested objects are manufactured according to the submitted drawings.
CESI checked that these drawings adequately represents in shape and dimensions the essential details and the parts of the tested objects.
These drawings identified by CESI and numbered A0/041852 no.1 (12kV), A0/041853 no.1 (24kV), A0/041855 no.1 (36kV) are annexed to this document.


The data necessary to permit repetition of the tests are contained in the document marked:
AT-A0/041765

The measurement uncertainties of the test results reported in this document are the following:
- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
- dielectric tests with direct voltage : voltage: $\pm 3\%$
The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.


activity code: 29380X
keywords: 12015R 23801L 31020W 41040M 53001D 62501B

ВЕРНО С
ОРИГИНАЛА

269



test date	page	contents
	4	rated characteristics of the test voltage declared by the manufacturer
	5	test voltage values
	6	summary of test results
	7	dry lightning impulse voltage test
	8	wet power frequency voltage test
	9	dry lightning impulse voltage test
	10	summary of test results
	11	panoramic view of the test samples
	12	panoramic view of the test arrangement
		reference document annexed
		12kV sample - drawing no. W 8997 12 31 identified by CESI and numbered A0/041852 no.1
		24kV sample - drawing no. W 8997 24 31 identified by CESI and numbered A0/041853 no.1
		36kV sample - drawing no. W 8997 36 31 identified by CESI and numbered A0/041855 no.1
dec.19, 2000 - feb.01,		
dec.19, 2000 - feb.01,		



ВЯРНО С
 С
 ОРИГИНАЛА

rated characteristics of the test voltage declared by the manufacturer

12kV sample


manufacturer	ALSTOM Parafudre S.A.
type	HE
drawing no.	W 8997 12 31
rated voltage (U _r)	12 kV
nominal discharge current (I _n)	10 kA
line discharge class	1
dry lightning impulse withstand voltage	95 kV _{pk}
wet power frequency withstand voltage	38 kV _{rms}

24kV sample

manufacturer	ALSTOM Parafudre S.A.
type	HE
drawing no.	W 8997 24 31
rated voltage (U _r)	24 kV
nominal discharge current (I _n)	10 kA
line discharge class	1
dry lightning impulse withstand voltage	125 kV _{pk}
wet power frequency withstand voltage	50 kV _{rms}

36kV sample

manufacturer	ALSTOM Parafudre S.A.
type	HE
drawing no.	W 8997 36 31
rated voltage (U _r)	36 kV
continuous operating voltage (U _c)	30 kV _{rms}
nominal discharge current (I _n)	10 kA
line discharge class	1
dry lightning impulse withstand voltage	170 kV _{pk}
wet power frequency withstand voltage	70 kV _{rms}



ВЯРНО
ОРИГИНАЛ

271

test voltage values

12kV sample

Lightning impulse voltage test (dry)
Power frequency voltage test (wet)

95 kV_{pk}
38 kV_{rms}

24kV sample

Lightning impulse voltage test (dry)
Power frequency voltage test (wet)


125 kV_{pk}
50 kV_{rms}

36kV sample

Lightning impulse voltage test (dry)
Power frequency voltage test (wet)

170 kV_{pk}
70 kV_{rms}

ВЯРНО С
ОРИГИНАЛА



272


summary of test result

dry lightning impulse voltage test

For each rated voltage level one housing of 10kA polymeric housed surge arresters was tested. The test was performed at the specified lightning impulse voltage obtained applying the corrections for atmospheric conditions. Fifteen impulses were applied at positive and negative polarity to each sample under test. No external flashovers occurred and the housings have not been damaged by these tests. Therefore the test result is to be considered positive.


wet power frequency voltage test

For each rated voltage level one housing of 10kA polymeric housed surge arresters was tested. The test samples withstood for one minute the wet power frequency withstand voltage claimed by the manufacturer. Therefore the test result is to be considered positive.



ВЯРКО С
ОРИГИНАЛА

274



[Handwritten signature]

Test Report



AT-A1/025452

p.7

note:

test housing	positive polarity			negative polarity			test result	no.	flashover	test result	test date
	requested voltage	KV	correction factor	applied voltage	KV	correction factor					
12kV sample	95,0	0,978	92,9	15	0	withstand	0	withstand	December 19, 2000		
24kV sample	125,0	0,978	122,3	15	0	withstand	0	withstand	December 19, 2000		
36kV sample	170,0	0,986	167,6	15	0	withstand	0	withstand	February 01, 2001		

test circuit: A002

test object: housing of 10kA polymeric housed surge arresters

dry lightning impulse voltage test

MOA14200

ВЕРНО (ОРИГИНАЛ)

[Large handwritten signature]

Test Report



AT-A1/0254B2


p.8

Date:


test housing	required (U)	K ₁	K ₂	applied (U x K)	test duration	test result	test date
12kV sample	38,0	1,006	38,2	60	withstand	December 19, 2000	
24kV sample	50,0	1,006	50,3	60	withstand	December 19, 2000	
36kV sample	70,0	1,000	70,0	60	withstand	February 01, 2001	

precipitation conditions		precipitation rate mm / min		water temperature °C		water resistivity Ω x m	
vertical	--	1,5	--	15,0	100,0	horizontal	--
top	--	1,5	--				
center	--						
bottom	--						

Object: housing of 10kA polymeric fuses
 test circuit: A059
 wet power frequency voltage test
ОРИГИНАЛ
ВЯРНО



circuit A002




lightning impulse test circuit

- Cg : Impulse generator capacitance
- Rf : Front resistor
- Rc : Tail resistor
- Cc : Load capacitance
- D : Divider type RC series
- K : coaxial cable
- S : attenuation and termination unit
- Osc : Oscilloscope


277

ВЯРНО
СРИГИНА


[Handwritten signature]



panoramic view of the test samples




12kV sample



24kV sample




36kV sample



ВЯРНО С И
ОРИГИНАЛА

circuit A059



power frequency measuring circuit


- TV₂: voltage transformer
- V₂: voltmeter
- D : voltage divider type RC series
- low voltage arm
- V₃: voltmeter
- TV₁: voltage transformer
- V₁: voltmeter

Handwritten signatures and initials are present at the bottom of the page.


ВЯРНО С
ОРИГИНАЛА

Large handwritten signature and a circular stamp are located at the top of the page. The stamp contains the text 'C' and other illegible markings.


panoramic view of the test arrangement




12kV sample



24kV sample




36kV sample



ВЯРНО С
ОРИГИНАЛА



[Handwritten signature]



PROTOCOLLO DATA
 N° 0418220011900099
 Firma: *[Signature]*

Nominal arc length : 195 mm
 Nominal creepage distance : 480 mm

Accessibilité du plan : <input checked="" type="checkbox"/> Libre <input type="checkbox"/> Confidentiel		Modification :		Destinateur : HS		Date : 12/12/00		Vérification : <i>[Signature]</i>	
Tolérances générales :		Matière :		Echelle :		12 kV rated silicone rubber housing for VARISIL type HE surge arresters.		ALSTOM TRANSMISSION & DISTRIBUTION Parafoudre B.P. 256 65202 Bozignères-de-Bigorre	
Ce plan est propriété de ALSTOM Parafoudre SA : il ne peut être ni reproduit ni communiqué sans autorisation préalable		A4 APF W 8997 12 31		Folio : 1 / 1		Indice : 00		A	

[Handwritten signature]



ВАРНО С
 ОРИГИНАЛА

182

Caution en regardant ce schéma ALSTOM France S.A. 11, Avenue de la République 92000 Nanterre Cedex		Assemblée de plan: <input type="checkbox"/> Confirmer <input type="checkbox"/> Approuver
Modificator: Date:	Dessinateur: Date:	Vérification: Date:
Téléphones généraux:		
Matière:		
Traitement:		
Désignation: HS Date: 12/12/00 Vérification:		
24 kV rated silicone rubber housing for VARISIL type HE surge arresters		
ALSTOM TRANSMISSION & DISTRIBUTION BP 256 65202 Nogent-sur-Vernois		
Photos: 1/1 Index: 00		

Nominal arc length: 270 mm
 Nominal creepage distance: 800 mm


PROTOSUO DATA
 A/0104183:000119 (2000)
 Mays 08



ВЯРНО С
 ОРИГИНАЛА

TENUE ELECTRIQUE
HE BNEL


RECEIVED
RECEIVED
RECEIVED



ISEC

04

ВЯРНО С
ОРИГИНАЛА



283

client ALSTOM Parafoudres S.A. - Bagnères de Bigorre Cedex (France)

equipment under test polymer housed surge arrester housing

tests performed lightning impulse voltage test;
power frequency voltage test - wet.

normative documents ENEL technical specifications DY 557 (July 1999, draft), DY 1018 (May 1999, draft); IEC 60099-4 (1991-06)

receipt date of the sample May 29, 2001
test date from May 30, 2001 to May 30, 2001

the test results relate only to the sample tested
this document shall not be reproduced except in full without the written approval of CESI
and of the accreditation body, if any

no. of pages 12 no. of pages annexed -

issue date September 5, 2001


prepared PeC/TEST - C. Del Giorgio *C. Del Giorgio*

verified PeC/TEST - A. Sironi *Albino Sironi*

approved PeC/TEST - V. Scaroni

CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile *V. Scaroni*

CESI
Centro Elettrotecnico
Sperimentale Italiano
Giacinto Motta SpA
Via R. Rubattino, 54
20134 Milano - Italia
Telefono +39 02212511
Fax +39 0221255440
www.cesi.it
Capitale sociale 0.150.000 Euro
Credito Imprese di Milano
N. Registro Imprese
N. R.E.A. 403922
Codice fiscale e numero
Inscrizione CCIAA 00793580150
P.I. IT00793580150




ВЯРНО С
ОРИГИНАЛА

tests witnessed by: Mr. F. Malpiece - ALSTOM Parafuodros S.A.

identification of the object: effected
The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.
CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.
These drawings identified by CESI and numbered A1/021094 no.1 and no.4 are annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked:
AT-A1/016942

The measurement uncertainties of the test results reported in this document are the following:
- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
- dielectric tests with direct voltage : voltage: $\pm 3\%$
The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.




ВЯРНО С
ОРИГИНАЛА

285

activity code: 31126P
keywords: 12015R 23801L 31020W 41040M 53001D 62501B

test date	page	contents
May 30, 2001	4	rated characteristics of the test voltage declared by the manufacturer
May 30, 2001	5	test voltage values
May 30, 2001	6	summary of test result
May 30, 2001	7	dry lightning impulse withstand voltage test
May 30, 2001	8	wet power frequency withstand voltage test
May 30, 2001	9	circuit A002
May 30, 2001	10	circuit A059
May 30, 2001	11	panoramic view of the test samples
May 30, 2001	12	panoramic view of the test arrangement
		reference document annexed - drawings identified by CESI and numbered A1/021094 no.1 and no.4



ВЯРНО С
ОРИГИНАЛА

MOA1022

rated characteristics of the test voltage declared by the manufacturer

manufacturer ALSTOM Parafoudre S.A.
 ALSTOM designation VARISIL HE 18 sd/E
 ENEL type DY 557/4
 code B 8997 07 18
 drawing no. W 8997 07 18/I
 rated voltage (U_r) 18 kV
 continuous operating voltage (U_c) 15 kV
 nominal discharge current (I_n) 10 kA
 line discharge class 1
 minimum creepage distance of arrester housing 650 mm

bracket type S3/E
 drawing no. B 8997 09 41/I



ВЯРНО С
ОРИГИНАЛА

test voltage values

arrester housing

Lightning impulse voltage test (dry)

$U_{pk} = 1,3 \times U_{imp} = 1,3 \times 65 = 84,5 \text{ kV}_{pk}$

U_{imp} : lightning impulse protection level (according to ENEL technical specifications) = 65 kV_{pk}

Power frequency voltage test (wet)

$U_{pk} = 0,88 \times U_{imp} = 0,88 \times 65 = 57,2 \text{ kV}_{pk}$

$U_{rms} = U_{pk} / \sqrt{2} = 40,44 \text{ kV}_{rms}$

U_{imp} : lightning impulse protection level (according to ENEL technical specifications) = 65 kV_{pk}


bracket

Lightning impulse voltage test (dry)

$U_{test} = 73 \text{ kV}_{pk}$

Power frequency voltage test (wet)

$U_{test} = 40 \text{ kV}_{rms}$



ВЯРНО С
ОРИГИНАЛА

summary of test result

arrester housing

dry lightning impulse voltage test

For each rated voltage level one housing of 10kA polymeric housed surge arresters was tested. The test was performed at the specified lightning impulse voltage obtained applying the corrections for atmospheric conditions.

Fifteen impulses were applied at positive and negative polarity to each sample under test. No external flashovers occurred and the housings have not been damaged by these tests. Therefore the test result is to be considered positive.

wet power frequency voltage test

For each rated voltage level one housing of 10kA polymeric housed surge arresters was tested. The test samples withstood for one minute the wet power frequency withstand voltage claimed by the manufacturer.

Therefore the test result is to be considered positive.

bracket

dry lightning impulse voltage test

For each rated voltage level one bracket of surge arresters was tested. The test was performed at the specified lightning impulse voltage obtained applying the corrections for atmospheric conditions.

Fifteen impulses were applied at positive and negative polarity to each sample under test. No external flashovers occurred and the housings have not been damaged by these tests. Therefore the test result is to be considered positive.

wet power frequency voltage test

For each rated voltage level one bracket of surge arresters was tested. The test samples withstood for one minute the wet power frequency withstand voltage claimed by the manufacturer.

Therefore the test result is to be considered positive.



ВЯРНО С
ОРИГИНАЛА

Test Report



AT-A1/028961

p.7

note:

test object	no.	KV _{max}	K	applied voltage	applied impulses	flashover	positive polarity						test result	withstand
							requested voltage	correction factor	applied voltage	KV _{max}	K	0,978		
	1	73,0	0,978	71,4	15	0	73,0	0,978	71,4	15	0	withstand	May 30, 2001	
	test date	test result	test result	test result	test result	test result	negative polarity						test result	withstand

test object: bracket

note:

test object	no.	KV _{max}	K	applied voltage	applied impulses	flashover	positive polarity						test result	withstand
							requested voltage	correction factor	applied voltage	KV _{max}	K	0,989		
	1	84,5	0,989	84,5	15	0	84,5	0,989	84,5	15	0	withstand	May 30, 2001	
	test date	test result	test result	test result	test result	test result	negative polarity						test result	withstand

test object: polymer housed surge arrester housing

test circuit: A002

dry lightning impulse withstand voltage test

10011200



290



[Handwritten signature]

Test Report

CESTEST
Testing Services

AT-A1/025961

p.8

Note:

test object	no.	1	test duration	test result	withstand	May 30, 2001
	required (U)	40,0				
voltage	K _v	0,990	applied (U x K _v)	test duration	test result	May 30, 2001
	correction factor	39,6				

test circuit : bracket

Note:

test object	no.	1	test duration	test result	withstand	May 30, 2001
	required (U)	57,2				
voltage	K _v	0,992	applied (U x K _v)	test duration	test result	May 30, 2001
	correction factor	56,7				

test circuit : polymer housed surge arrester housing


precipitation conditions	precipitation rate mm / min	top	--	water temperature °C	water resistivity Ω x m
		center	1,8		
		bottom	--	22,6	95,0
			1,8		
vertical					
horizontal					

test circuit: A059

wet power frequency withstand voltage test

NOGATZEB



**ВЯРНО С
ОРИГИНАЛА**



[Handwritten signature]

163

circuit A002




lightning impulse test circuit

- Cg : Impulse generator capacitance
- Rf : Front resistor
- Rc : Tail resistor
- Cc : Load capacitance
- D : Divider type RC series
- K : coaxial cable
- S : attenuation and termination unit
- Osc : Oscilloscope

ВЯРНО С
ОРИГИНАЛА

circuit A059



power frequency measuring circuit

- TV₂: voltage transformer
- V₂: voltmeter
- D : voltage divider type RC series
- low voltage arm
- V_b: voltmeter
- TV₁: voltage transformer
- V₁: voltmeter



[Large handwritten signature]




293

ВЯРНО С
ОРИГИНАЛ

panoramic view of the test sample



ВЯРНО С
ОРИГИНАЛА



[Handwritten signature]

Т.А.0/04506

ISEC

[Handwritten signature]


ВЕРНО С
ОРИГИНАЛ

[Large handwritten signature]

295

client Alstom Parafudres S.A. - Bagnères de Bigorre (France)

equipment under test Metal-oxide surge arrester type VARISIL HE



tests performed Residual voltage test

normative documents Client's request based on IEC 60099-4 (1998)

receipt date of the sample December 15, 2000
 test date from December 18, 2000 to December 19, 2000

the test results relate only to the sample tested
 this document shall not be reproduced except in full without the written approval of CESI
 and of the accreditation body, if any

no. of pages 14 no. of pages annexed 27
 issue date January 25, 2001

prepared PeC/TEST - R. Malgesini *R. Malgesini*

verified PeC/TEST - A. Sironi *A. Sironi*

approved PeC/TEST - V. Scarioni

CESI
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
 Via R. Rubattino, 54
 20134 Milano, Italia
 Prov. di Milano
 Il Responsabile del Laboratorio

CESI
 Centro Elettrotecnico
 Sperimentale Italiano
 Giacomo Meola spa
 Via R. Rubattino, 54
 20134 Milano, Italia
 Telefono +39 02212541
 Fax +39 0221255440
 http://www.cesi.it

Capitale sociale 17,1 miliardi
 Impiegati circa 428222
 C.C.I.A.A. Milano
 Registro della Imprese
 di Milano n. 84067

Sede legale
 Via Melegnano, 150
 P.I. 070793550150
 C.F. 00793550150

ВАРНО С
 ОРИГИНАЛА

tests witnessed by:

identification of the object: The manufacturer guarantees that the tested object is manufactured according to the submitted drawing.
CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.
The drawing identified by CESI and numbered A1/002574 is annexed to this document.

The measurement uncertainties of the test results reported in this document are the following:
- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

CESI testing team: L. Podavitte
I. Guacci

test laboratory: P177 surge arrester laboratory


activity code: 29380X

keywords: 12015R, 23810H, 31020W, 46030U, 53001D

ВЯРНО С
ОРИГИНАЛА

297





ВЯРНО С
ОРИГИНАЛА

Test Report

TESTEST

AT-A0/041526

p.3

test date	page	contents
	4	Test object characteristics
	6	Reference standard
	6	Test carried out
	6	Test object identification
	6	Test procedure
	7	Lightning impulse residual voltage test
	8	Switching impulse residual voltage test
	10	Steep current impulse residual voltage test
	11	Technical data of the test circuit
December 18 - 19, 2000	12	Page annexed: oscillograms no. 27
December 19, 2000		Reference document annexed: Drawing of test sample CESI no. A1/002574 (1 page)

208

Test object characteristics

type: Metal-oxide surge arrester type VARISIL HE

electrical characteristics (claimed by the client)


manufacturer's name	Alstom Parafúndos S.A. - Bagnères de Bigorre - France
nominal discharge current - I_n [kA]	10,0
rated voltage - U_r [kV]	5,0
continuous operating voltage - U_c [kV]	5,0
minimum reference voltage - U_{refmin} [kV]	5,8
reference current - I_{ref} [mA]	1,0
rated frequency - [Hz]	50 - 60
year of manufacture	2000

geometrical characteristics (measured on the test sample)

total height [mm]	268
number of sheds	9
shed diameter [mm]	max 106 - min 76
shed spacing [mm]	max 30 - min 15
core diameter [mm]	50

other characteristics

housing material	silicone rubber
housing color	gray




299





ВЯРНО С
ОРИГИНАЛ

000130016




Photograph of metal-oxide surge arrester.



ВЯРНО С
ОРИГИНАЛА

300

Reference Standard


Client request's based on IEC 60099-4 (1998) Clause 7.3
" Metal-oxide surge arrester without gaps for a.c. system "

Test carried out

test carried out	number of sample tested
Lightning impulse residual voltage test	3
Switching impulse residual voltage test	
Steep current impulse residual voltage test	


Test object identification


test object names	identification of test sample (given by the client)
metal-oxide surge arrester	1 - 2 - 3



**ВЯРНО С
ОРИГИНАЛА**

301





Test procedure

- The lightning impulse residual voltage with current waveshape having front time equal to 8 μ s and time to half value equal to 20 μ s at the following values has been measured:

- $I_N = 10,0$ kA
- 0.5 $I_N = 5$ kA
- 2 $I_N = 20,0$ kA
- 4 $I_N = 40,0$ kA

- The switching impulse residual voltage with current waveshape having front time greater than 30 μ s and time to half value roughly twice of front time at the following values has been measured:

- 125 A
- 500 A
- 1000 A

- The steep current residual voltage at I_N with current waveshape having front time equal to 1 μ s and time to half value not longer than 20 μ s at the following values has been measured:

- $I_N = 10,0$ kA
- 0.5 $I_N = 5$ kA

**ВЯРНО С
ОРИГИНАЛА**

Lightning impulse residual voltage test. IEC 60099-4 Standard

test object: Metal-oxide surge arrester
test circuit: AO14

date: December 18 - 19, 2000

sample no.	requested current	charging voltage kV	ocillogram no.	current waveform μ S	discharge current kA	residual voltage kV	lightning impulse protection level kV
1	$0,5 \times I_n$	20,1	4	8,4/19,0	4,96	14,04	
	I_n	28,0	1	8,4/18,4	10,1	15,09	
	$2,0 \times I_n$	42,8	7	8,2/19,0	20,0	16,55	
	$4,0 \times I_n$	56,1	10	8,1/18,0	39,7	18,73	
2	$0,5 \times I_n$	20,2	5	8,4/19,0	5,00	14,04	
	I_n	28,0	2	8,4/18,4	10,0	15,09	
	$2,0 \times I_n$	42,7	8	8,2/19,0	19,9	16,47	
	$4,0 \times I_n$	56,2	11	8,1/18,0	39,7	18,73	
3	$0,5 \times I_n$	20,2	6	8,4/19,0	5,08	14,06	
	I_n	27,8	3	8,4/18,4	10,0	15,01	
	$2,0 \times I_n$	43,0	9	8,2/19,0	20,0	16,65	
	$4,0 \times I_n$	56,3	12	8,1/18,0	39,8	18,80	

see relevant curve in the following page

	oscilloscope settings		
	sampling division μ S	input V_m	attenuation
current	$0,5 I_n$	0,5	20:5
	I_n	0,5	50:5
	$2 I_n$	1,0	50:5
	$4 I_n$	1,0	100:5
voltage	$0,5 U_n$	1,0	20:5
	U_n	1,0	20:5
	$2 U_n$	1,0	20:5
	$4 U_n$	1,0	20:5


[Handwritten signature]


[Handwritten mark]

ВАРНО С
ОРИГИНАЛА


393

[Large handwritten signature]





ВЯРНО С
ОРИГИНАЛА



Switching impulse residual voltage test. IEC 60099-4 Standard

test object: Metal-oxide surge arrester
test circuit: A014B

date: December 19, 2000

sample no.	requested current A	charging voltage kV	oscillogram no.	current waveshape μs	discharge current A	residual voltage kV
1	125	11,6	13	30,0/83,0	125,0	11,26
	500	13,9	16	34,0/79,0	496,0	11,85
	1000	16,8	19	35,0/78,0	1010	12,35
2	125	11,5	14	30,0/83,0	122,0	11,22
	500	14,0	17	34,0/79,0	500,0	11,95
	1000	16,8	20	35,0/76,0	1015	12,36
3	125	11,5	15	30,0/83,0	125,0	11,22
	500	13,9	18	34,0/79,0	495,0	11,87
	1000	16,8	21	35,0/76,0	1020	12,27

	sampling division μs	oscilloscope settings		attenuation
		input V_{in}		
current (125A)	20	0,5		5:5
current (500A)		0,5		20:5
current (1000A)		0,5		50:5
voltage (125A)	20	0,8		20:5
voltage (500A)		0,8		20:5
voltage (1000A)		0,8		20:5

[Handwritten signature]

**ВАРНО С
ОРИГИНАЛА**


305

[Handwritten signature]



Stoop current impulse residual voltage test. IEC 60099-4 Standard

test object: Metal-oxide surge arrester
test circuit: A014A




date: December 19, 2000

sample no.	charging		oscillogram no.	current waveshape μs	discharge		residual voltage kV
	voltage kV	current kA			current kA	voltage kV	
1	24,0	5,00	22	1,10/2,35	5,00	14,89	
	34,4	9,96	25		9,96	16,14	
2	24,1	5,04	23		5,04	14,83	
	34,4	9,98	26		9,98	16,14	
3	24,1	5,06	24		5,06	14,73	
	34,5	10,0	27	10,0	16,14		

oscilloscope settings	
sampling division μs	input attenuation
1,0	V_{div}
	10 - 20 x 10
	5 /

ВЯРНО С !
ОРИГИНАЛА

circuit A014



impulse generator

plant P177
 no. of stages 1
 C_0 4.98 (6,64 x 40 kA) μ F
 L_0 8 (5 x 40 kA) μ H
 S spark gap

current shunt (R) CESI no. 6042 ; $R = 0,002\Omega$; 100 kA
 electro optical system CESI no. 11517/518 ; attenuation 20:5 - 10:5
 oscilloscope CESI no. 11873
 type Tektronix TDS 540

voltage divider (D) CESI no.11120 ; $k = 1013$
 electro optical system CESI no.11519/520 ; attenuation 50:5
 oscilloscope CESI no. 11873
 type Tektronix TDS 540

[Handwritten signature]


ВЕРНО С 1
 ОРИГИНАЛА

307

ИИД0014030


[Handwritten signature]

[Large handwritten signature]



ВЯРНО С
ОРИГИНАЛА

circuit A014B




impulse generator

plant P177
no. of stages 1
C_g 6,64 μF
L_a 100 μH
S spark gap

current shunt (R) CESI no. 6039 ; R = 0.020 Ω ; 10 kA
electro optical system CESI no.11517/518 ;
oscilloscope CESI no. 11873
type Tektronix TDS 540

voltage divider (D) CESI no. 11120 ; k = 1009
electro optical system CESI no.11519/520 ; attenuation
oscilloscope CESI no. 11873
type Tektronix TDS 540

circuit A014A



impulse generator

plant P177
 no. of stages 1
 C_g 0,25 μ F
 L_c 1 μ H
 S spark gap

current TA (R) type Pearson CESI no.8250 ; 0,01 V x A
 oscilloscope CESI no. 11873
 type Tektronix TDS 540

voltage divider (D) CESI no.11120 ; k = 1009
 oscilloscope CESI no. 11873
 type Tektronix TDS 540


[Handwritten signature]

09


ВЯРНО С
 ОПРИГИНАЛА



[Large handwritten signature]




ВЯРНО С
ОРИГИНАЛА



CESI TEST A0/041526 oscillogramma n. 1

CV8

[Handwritten signature]




CESI TEST AO/041526 oscillogramma n. 2


[Large handwritten signature]

09


ВЕРНО С
ОРИГИНАЛА




ВЯРНО С
ОРИГИНАЛА



CESI TEST A0/04/1526 oscillogramma n. 3




[Handwritten signature]




CESI TEST A0/041526 oscillogramma n. 4

[Handwritten signature]


**ВЯРНО С
ОРИГИНАЛА**




ВЯРНО С
ОРИГИНАЛА



CESI TEST A0/04-1526 oscillogramma n. 5



[Handwritten signature]



CESI TEST A0/041526 oscillogramma n. 6

[Handwritten mark]


ВЪРНО С
ОРИГИНАЛА

[Handwritten signature]

[Handwritten signature]
315




ВЯРНО С
ОРИГИНАЛА



CESI TEST A0/041526 oscillograma n. 7



[Handwritten signature]



CESI TEST A0/04/1526 oscillogramma n. 8


Tek stopped: 1 Acquisitions

[Handwritten signature]


[Handwritten mark]

ВЪРНО С
ОРИГИНАЛА


317




ВЯРНО С
ОРИГИНАЛА



CESI TEST A0/041526 oscillogramma n. 9



[Handwritten signature]





CESI TEST A0/041526 oscillogramma n. 10


[Handwritten signature]
ОРЖИНО С
СИГНАЛА

[Handwritten signature]


ВЕРНО С
ОРИГИНАЛА



CESI TEST A0/041526 oscillogramma n. 11



[Handwritten signature]




CESI TEST A0/041526 oscilogramma n. 12

[Handwritten signature]


[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА



321



ВЕРНО С
ОРИГИНАЛА




CESI TEST A0/041526 oscillogramma n. 13




CESI TEST A0/041526 oscillogramma n. 14

ВЯРНО С
ОРИГИНАЛА




ВЯРНО С
ОРИГИНАЛА



CESI TEST AO/041526 oscillogramma n. 15



[Handwritten signature]




CESI TEST A0/041526 oscillogramma n. 16


[Handwritten signature]

ВЕРНО С
ОРИГИНАЛА

3:5




ВЯРНО С
ОРИГИНАЛА



CESI TEST A0/041526 oscillogramma n. 17



[Handwritten signature]




CESI TEST A0/041526 осциллограмма n. 18


[Handwritten signature]

**ВЯРНО
ОРИГИНАЛ**


327




ВЯРНО СЪ
ОРИГИНАЛА



CESI TEST A0/041526 oscillogramma n. 19



[Handwritten signature]





CESI TEST A0/041526 oscilogramma n. 20

[Handwritten signature]


**ВЯРНО С
ОРИГИНАЛА**

329


ВЯРНО С
ОРИГИНАЛА



CESI TEST A0/041526 oscillogramma n. 21



[Handwritten signature]





CESI TEST AO/041526 oscillogramma n. 22

[Handwritten signature]

**ВЯРНО С
ОРИГИНАЛА
331**



ВЯРНО С
ОРИГИНАЛА



CESI TEST AO/041526 oscillogramma n. 23

I = 20,5 kA
Ip = 48,6 kA
dT = 214 ms
dT = 1,53 ms

Handwritten signature



Sam: 1SEC, Osc: BD3F, Cal: BD3F

~~ВЪРНО С
ОРИГИНАЛА~~

599


VENT 3 V

CESI P-140 A8014192/0030

(1)

(1)

Handwritten signature



CESI TEST A0/041526 oscillogramma n. 24

Handwritten signature

Handwritten mark



Handwritten mark

ВЯРНО С
ОРИГИНАЛА


333

Handwritten signature


ВЕРНО С
ОРИГИНАЛА



CESI TEST A0/041526 oscillogramma n. 25



[Handwritten signature]



CESI TEST AO/041526 oscillogramma n. 26



[Handwritten signature]

[Handwritten mark]


[Handwritten signature]

ВЕРНО С
ОРИГИНАЛА

ВЯРНО С
ОРИГИНАЛА




CESI TEST AO/04-1526 oscillogramma n. 27



Accettata da p.n.:	<input type="checkbox"/>
Confidat:	<input type="checkbox"/>
Es:	<input checked="" type="checkbox"/>
Modifications:	
Tollerances générales:	
Matériau:	
Traitement:	
Esquisse:	
Construteur:	HS
Date:	12/12/00
Verification:	[Signature]
ALSTOM TRANSPORT & SYSTEMS Route de B.P. 256 65702 Esbrey-de-Bizore	
VARISIL type HE 6 kV electrical section	
A4 APF W 8997 01 06	
Folio:	1 / 1
Indice:	00

ВЯРНО С
ОРИГИНАЛА



Test Report



A5/046538

Approved

Page 1

Client AREVA Parafoudres S.A. - Bagneres de Bigorre (France)

Tested equipment Polymer housed metal-oxide surge arrester type VARISIL HB fitted with type SnD2 disconnecter

Tests carried out Long duration current impulse withstand tests

Standards/Specifications IEC 60099-4 (2004-05)

Test date from September 26, 2005 September 28, 2005

The results reported in this document relate only to the tested equipment.
 Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 21 No. of pages annexed

Issue date September 28, 2005

Prepared BU PeC - M. Gregori

Verified BU PeC - R. Malgesini

Approved BU PeC - M. de Nigris

ВІДПОВІДЬ
ОРИГІНАЛ

CESI
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
 Business Unit
 Prove e Componenti
 Il Responsabile del Laboratorio



Test Report



A5/046538

Approved


Page 2

Tests witnessed by: -

Mr F. Malpiece - AREVA Parafoudres S.A.

ВЯРНО С
ОРИГИНАЛА

Identification of the object: Not Requested



The data necessary to permit repetition of the tests are contained in the document marked: ---

- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
dielectric tests with direct voltage : voltage: $\pm 3\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values

Laboratory information

Receipt date of the sample September 26, 2005
Test location CESI - Via Rubattino 54 - Milan
CESI testing team Mr L. Podavitte - Mr I. Guacci
Test laboratory P177
Activity code 42926J

339

content	page a	test date
Test object characteristics	4	
Photograph of the test sample	5	
Reference standard	6	
Test carried out	6	
Test object identification	7	
Test procedure	8	
Summary of the test result	9	September 26, 2005
Power frequency voltage characteristics	10	September 26, 2005
Lightning impulse residual voltage measurement before the test	11	September 26, 2005
Switching impulse residual voltage test	12	September 26, 2005
Voltage correction factor and energy calculations	13-15	September 27, 2005
Long duration current impulse withstand test	16	September 27, 2005
Long duration current impulse withstand test (additional shot)	17	September 28, 2005
Lightning impulse-residual voltage measurement after the test	18-21	September 28, 2005
Technical data of the test circuit		

Pages annexed:
oscillograms n. 24 pages


[Handwritten signature]



ВЯРНЪ С
ОРИГИНАЛА

AS/046538
Page 3

Approved



CESI

n° 0030

Test Report

[Handwritten signature]

Test Report



n° 0030

Approved

A5/046538

Page 4

Test object characteristics

type: Polymer housed metal-oxide surge arrester

electrical characteristics (assigned by the client)

ВЯРНО С
ОРИГИНАЛА



Manufacturer's name	AREVA Parafoudres S.A. - Bagnères de Bigorre (France)
Nominal discharge current - I_N [kA]	10
Rated voltage - U_r [kV]	$U_{ref} \times 1,035$
Continuous operating voltage - U_c [kV]	$U_{ref} \times 0,880$
Reference current - I_{ref} [mA]	1,0
Line discharge class	1
Rated frequency - [Hz]	50 - 60

geometrical characteristics (measured on the test sample)

Height [mm]	245
Number of sheds	n. 4 large -- n. 3 small
Shed diameter [mm]	103 large - 73 small
Core diameter [mm]	48



other characteristics

Housing material	Silicone
Housing color	Grey



ВЯРНО С
ОРИГИНАЛА

Photo no. 1



Reference Standard

IEC 60099-4 (2004-05) Clause 10.8.4


"Metal-oxide surge arrester without gaps for a.c. system"

Test carried out	Number of sample tested
Long duration current impulse withstand test	3

Test object identification

Test object name	Identification of test sample (given by Cesi)
polymer housed metal-oxide surge arresters	LD1-LD2-LD3

ВЕРНО С
ОРИГИНАЛА



Test procedure

- The power frequency voltage at reference current ($I_{ref} = 1 \text{ mA}$) has been measured
- The lightning impulse residual voltage at $I_H = 10 \text{ kA}$ has been measured
- The switching impulse residual voltage with current waveshape having front time greater then to $30 \mu\text{s}$ but less than $100 \mu\text{s}$ and time to half value roughly twice has been measured according to table 4 of the reference standard at following current level:
 $I = 125 \text{ A}$
- Eighteen long duration current impulses with the specified calculated energy (see pag.12) on a virtual duration of $2000 \mu\text{s}$ have been applied in six groups of three operations.
Intervals between operations of the same groups have been about 60 seconds; between different groups the samples have been let to cool down to near ambient temperature
- After the eighteenth impulse the test samples have been cool down to ambient temperature and a nineteenth impulse has been applied
- The measurement of the lightning impulse residual voltage at I_H has been repeated

ВЕРНО С
ОРИГИНАЛА



Visual inspection and summary test results

Variation of lightning impulse residual voltage at I_N

Sample	before test		after test		variation
	discharge current kA	residual voltage kV	discharge current kA	residual voltage kV	
LD1	10,15	16,12	10,05	15,99	- 0,81
LD2	10,20	15,89	10,05	16,00	0,69
LD3	10,20	15,92	10,00	15,84	- 0,50


The visual inspection of the metal-oxide surge arrester after the test has revealed no sign of physical damage. The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%).

The oscillographic record of the 19th impulse doesn't reveal any sign of internal discharge.

The disconnectors did not operate

All acceptance criteria according to the reference standard are satisfied and therefore the result is to be considered positive.

ВЕРНО С
ОРИГИНАЛА



Test Report



A5/046538

Approved

Page 9

Power frequency voltage-current characteristics. IEC 60099-4 Standard

Test circuit: A0019


Date: September 26, 2005

Sample No. LD1						
Oscillogram	Voltage	current	Current	current	power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
1	6,08	1,00	0,98	0,59	2,06	---

Sample No. LD2						
Oscillogram	Voltage	current	Current	current	Power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
2	6,01	1,02	0,98	0,58	2,03	---

Sample No. LD3						
Oscillogram	Voltage	current	Current	current	Power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
3	6,04	1,01	0,97	0,580	2,00	---

ВЯРНО С
ОРИГИНАЛА



Long duration current impulse withstand test. IEC 60099-4 Standard

Lightning impulse residual voltage measurement before the test

Test circuit: A0120


Date: September 26, 2005

Sample	Requested Current	Charging Voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.		kV	No.	μ s	kA	kV
LD1	I _N	29,8	4	8,6/18,6	10,15	16,12
LD2		29,7	5		10,20	15,89
LD3		29,7	6		10,20	15,92

Oscilloscope settings			
	Sampling division	Input	attenuation
	μ s	V _{div}	
Current	5	0,5	50:5
Voltage	5	0,5	50:5

Notes:

ВЯРНО С
ОРИГИНАЛА



Test Report



A5/046538

Approved

Page 11

Switching impulse residual voltage test. IEC 60099-4 Standard

Test circuit: A0122

Date: September 26, 2005


Sample No.	Requested Current A	Charging voltage kV	Oscillogram No.	Current waveshape μs	Discharge current A	Residual voltage kV	Switching impulse protection level kV
LD1	125	14,0	7	31/68	130	12,26	12,26
LD2	125	13,9	8		128	12,13	
LD3	125	13,9	9		130	12,07	

	Oscilloscope settings		
	sampling division μs	input V_{div}	attenuation
Current	20	0,5	5:5
Voltage	20	0,5	50:5

Notes:

by

ВЯРНО С
ОРИГИНАЛА



Long duration current impulse withstand test, IEC 60099-4 Standard

Voltage correction factor and energy calculations

Date: September 26, 2005


Sample	U_{ref} [1]	kU_r [2]	kU_c [3]	U_r' [4]	U_c' [5]
No.	kV			kV	kV
LD1	6,08	1,035	0,880	6,29	5,35
LD2	6,01			6,22	5,29
LD3	6,04			6,25	5,32

- [1] U_{ref} : measured reference voltage
- [2] kU_r : maximum guarantees factor for calculation of U_r
- [3] kU_c : maximum guarantees factor for calculation of U_c
- [4] U_r' : corrected rated voltage [4] = [1] × [2]
- [5] U_c' : corrected continuous operating voltage [5] = [1] × [3]

Sample	U_r'	U_L	V_{res}	T	Z	W	W'
No.	kV		kV	μs	Ω	kJ	kJ/kV
LD1	6,29	20,13	12,07	2000	30,82	6,31	1,003
LD2	6,22	19,90			30,48	6,21	0,998
LD3	6,25	20,00			30,63	6,25	1,000

- V_{res} : switching impulse residual voltage
- U_L, T, Z : see table 5 of IEC 60099-4 Standard
- W : $= V_{res} \times (U_L - V_{res}) \times (T/Z)$

ВЯРНО С
ОРИГИНАЛА



Test Report



n° 0030

Approved

A5/046538

Page 13

Long duration current impulse withstand test. IEC 60099-4 Standard

Test circuit: A017


Date: September 27, 2005

Sample No.	Impulse No.	Charging voltage V _c kV	Oscillogram No.	Peak current I A	Residual voltage V _r kV	Energy E kJ
LD1	1	13,6		249	11,22	6,41
	2	13,7		260	11,15	6,69
	3	13,7	10	256	11,22	6,66
	4	13,6		260	11,16	6,62
	5	13,6		254	11,12	6,55
	6	13,6		255	11,12	6,60
	7	13,6		260	11,15	6,81
	8	13,6		255	11,20	6,61
	9	13,6	13	250	11,20	6,48
	10	13,6		253	11,20	6,60
	11	13,6		250	11,15	6,53
	12	13,6		254	11,20	6,58
	13	13,5		240	11,10	6,48
	14	13,5		245	11,20	6,40
	15	13,5		240	11,20	6,37
	16	13,5		245	11,20	6,49
	17	13,5		244	11,25	6,45
	18	13,5	16	250	11,25	6,50

Notes:

Measured waveshape	
virtual duration	virtual total duration
μs	μs
2080	2560

	Oscilloscope settings		Attenuation
	sampling division	Input	
Current	μs	V _{div}	10:5
Voltage	50	1,0	50:5
	50	0,5	



Test Report

CESI  n° 0030

AS/046538

Page 14

ВЕРНО С
ОРИГИНАЛА

Continued

Date: September 27, 2005

Sample No.	Impulse No.	Charging voltage V_c kV	Oscillogram No.	Peak current I A	Residual voltage V_r kV	Energy E KJ
LD2	1	13,6		258	11,12	6,60
	2	13,7		263	11,00	6,70
	3	13,6	11	257	11,05	6,61
	4	13,6		264	11,00	6,77
	5	13,6		263	11,00	6,78
	6	13,6		265	11,00	6,77
	7	13,6		265	11,00	6,80
	8	13,6		264	11,10	6,75
	9	13,6	14	265	11,05	6,78
	10	13,6		264	11,05	6,80
	11	13,6		266	11,05	6,77
	12	13,6		264	11,00	6,75
	13	13,5		258	11,05	6,60
	14	13,5		258	11,04	6,62
	15	13,5		260	11,05	6,62
	16	13,5		258	11,00	6,60
	17	13,5		260	11,00	6,62
	18	13,5	17	260	11,05	6,63

Notes:

Measured waveshape	
virtual duration μs	virtual total duration μs
2080	2560

Oscilloscope settings			
	sampling division μs	input V_{div}	Attenuation
Current	50	1,0	10:5
Voltage	50	0,5	50:5

Continued

Test Report



A5/046538

Approved

Page 15

Continued

Date: September 27, 2005

Sample No.	Impulse No.	Charging voltage V_c kV	Oscillogram No.	Peak current I A	Residual voltage V_r kV	Energy E kJ
LD3	1	13,6		269	11,12	6,80
	2	13,6		262	11,12	6,74
	3	13,6	12	260	11,15	6,70
	4	13,6		263	11,10	6,76
	5	13,6		264	11,10	6,80
	6	13,6		263	11,10	6,78
	7	13,6		264	11,10	6,79
	8	13,6		263	11,10	6,77
	9	13,6	15	264	11,10	6,80
	10	13,6		260	11,10	6,85
	11	13,6		258	11,10	6,62
	12	13,5		250	11,00	6,37
	13	13,6		263	11,00	6,92
	14	13,5		258	11,10	6,63
	15	13,5		257	11,10	6,66
	16	13,5		258	11,10	6,68
	17	13,5		257	11,15	6,63
	18	13,5	18	259	11,10	6,67

Notes:

Virtual duration	Measured waveshape	virtual total duration
μs		μs
2080		2560

	Oscilloscope settings		
	sampling division	input	Attenuation
Current	μs 50	V_{cr} 1,0	10:5
Voltage	50	0,5	50:5

ОРИГИНАЛ

352
Continued
chf

Long duration current impulse withstand test. IEC 60099-4 Standard

(check the integrity of the internal parts with an additional shot at ambient temperature)

Test circuit: A017


Date: September 27, 2005

Sample	Impulse	Charging voltage V_c	Oscillogram	Peak current I	Residual voltage V_r	Energy E
No.	No.	kV	No.	A	kV	kJ
LD1	19	13,6	19	250	11,20	6,50
LD2	19	13,6	20	260	11,00	6,70
LD3	19	13,6	21	260	11,10	6,73

Notes:

Measured waveshape	
virtual duration	virtual total duration
μs	μs
2080	2560

	Oscilloscope settings		
	sampling division	input	Attenuation
	μs	V_{div}	
Current	50	1,0	10:5
Voltage	50	0,5	50:5



БЕЛКО С
СРБИЈА

Test Report



A5/046538

n° 0030

Approved

Page 17

Long duration current impulse withstand test, IEC 60099-4 Standard

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: September 28, 2005

Sample No.	Requested Current	Charging voltage kV	Oscillogram No.	Current waveshape μs	Discharge current kA	Residual voltage kV
LD1	I_N	29,8	22	8,6/18,6	10,05	15,99
LD2		29,7	23		10,05	16,00
LD3		29,7	24		10,00	15,84


	Oscilloscope settings		
	sampling division μs	input V_{div}	attenuation
Current	5	0,5	50:5
Voltage	5	0,5	50:5

Notes:

Handwritten signature


Large handwritten signature

ВЯРНО С
ОРИГИНАЛА



Handwritten signature

Circuit A0019



Power frequency supply

- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV


Current measuring system

- R - Current shunt CESI No.31120; R= 941,4 Ω
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090


Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522; attenuation 50:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090

ВЕРНО С
ОРИГИНАЛА



Circuit A0120



Impulse generator

- No. of stages 1
- Cg 4,98 μ F
- Lc 10 μ H
- S - Spark-gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.13027
- Electro optical system CESI No.11521/522;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)


Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No.11517/518;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)


Handwritten signature

Handwritten signature

Handwritten signature



Circuit A0122



Impulse generator

- No. of stages 1
- Cg 3,32 μ F
- Lc 100 μ H
- S - Spark-gap


Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system


- Sh - Current shunt CESI No.6037; R= 20 m Ω ; peak current= 250 kA
- Electro optical system CESI No 11517/519
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

ВЯРНО С
ОРИГИНАЛА



[Handwritten signature]

Circuit A0017



Impulse generator

- C₁ ... C₁₃ - capacitors 0,83 μF
- L₁ ... L₁₃ - inductors 7 mH
- L₁₄ - inductor 14 mH

S: - spark gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Cy

[Handwritten signature]

Current measuring system



- Sh - Current shunt CESI No.6042; R= 2 mΩ
- Electro optical system CESI No 11521/11522.
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

ВЯРНО С
ОРИГИНАЛА


[Handwritten signature]

353 *[Handwritten initials]*

[Handwritten signature]





CESI - Pec A5046538 oscillogram n. 1



ВЯРНО СЪ
ОРИГИНАЛА

[Handwritten signature]



CESI - Pec A5046538 oscillogram n. 2

cy



ВЯРНО С 1
ОРИГИНАЛА

[Handwritten signature]




[Handwritten signature]


[Handwritten signature]




CESI - Pec A5046538 oscillogram n/3



ВЯРНО С
ОРИГИНАЛА




СЕСІ РсС А5046538 Oscillogram n. 4



ВЕРНО С
ОРИГИНАЛ

[Handwritten signature]


[Handwritten signature]




CESI PeC A5046538 Oscillogram n. 5

363


ВЕРНО С
ИСТИНАТА






CESI PeC A5046538 Oscillogram n. 6

ВСТАНОВЛЕНА
 СИГНАЛА
 364
 СГ




365

CESI PeC A5046538 Oscillogram n. 7




ОБЪЕДИНЕННЫЙ
ЦЕНТРАЛЬНЫЙ
ОБЪЕДИНЕННЫЙ
ОБЪЕДИНЕННЫЙ




СЕСІ РєС А5046538 Oscillogram n. 8

ВЕРНО С
ОРИГИНАЛ
ЛА





CESI PeC A5046538 Oscillogram n. 9




[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА


[Handwritten signature]

CESI PeC A5046538 Oscillogram n. 10







CESI PeC A5046538 Oscillogram n. 11



CESI PeC A5046538 Oscillogram n. 12




Handwritten signature and scribbles at the bottom right of the page.



ВЯРНО С
ОРИГИНАЛА

CESI PeC A5046538 Oscillogram n. 13




CESI PeC A5046538 Oscillogram n. 14

ВЯРНО С
ОРИГИНАЛА




Handwritten signature and scribbles.



CESI PaC A5046538 Oscillogram n. 18


ОРИГИНАЛ




Handwritten signature

Handwritten signature

Handwritten mark




СЕСИ РсС А5046538 Oscillogram n. 17




ВЯРНО С
ОРИГИНАЛА

CESI PeC A5046538 Oscillogram n. 18




[Handwritten signature]

[Handwritten signature]




CESI PeC A5048538 Oscillogram n. 19



[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА

CESI PeC A5046538. Oscillogram n. 20




[Handwritten signature]

[Handwritten mark]



СЭСІ РсС А5046538 Oscillogram n. 21



Handwritten signature

ВЕРНО С
ОРИГИНАЛА


СЭСИ РсС А5046538 Oscillogram n. 22



Handwritten signature

Handwritten signature


Handwritten mark



CESI PeC A5046538 Oscillogram n. 23

48

331



Handwritten signature

СЕСІ РсС А5048538 Oscillogram n. 24

ОРИГИНАЛ



Handwritten signature

Handwritten mark

(

(

(

(

Test Report

Client: ARSEVA Peraldores S.A. - Regiment de Bigorre (France)
 Tested equipment: Polymer bonded metal-oxide surge arrester type VARGSEL HE fitted with type SMDZ disconnector
 Tests carried out: High current impulse operating duty test

Standard/Specifications: IEC 60399-4 (2004-05)

Test date: from November 30, 2005 to December 2, 2005

The results reported in this document relate only to the tested equipment.
 Page(s) reproduction of this document is permitted only with the written permission from CESI.

	No. of pages annexed
No. of pages	45
Issue date	December 14, 2005
Reported	BU FeC - M. Geyson <i>M. Geyson</i>
Validated	BU FeC - R. Malgouyres <i>R. Malgouyres</i>
Approved	BU FeC - M. de Nigris <i>M. de Nigris</i>


CESI
 CENTRO RISPONSAZIONALE SPERIMENTALE ITALIANO
 Divisione Unità
 Protezione Impianti
 in Accordo con *[Signature]*


CESI
 Centro RISPONSAZIONALE SPERIMENTALE ITALIANO
 Via B. Beolario 64
 20134 Milano - Italia
 Tel. +39 02 420272
 Fax +39 02 420273
 E-mail: info@cesi.it
 Internet: www.cesi.it
 Registro Imprese di Milano
 n. 01207600150
 P.I. 01207600150

[Large handwritten signature]

ВЯРНО С
 ОРИГИНАЛА
 334

[Large handwritten signature]

[Large handwritten signature]




Tests witnessed by:

M.F. Malpica - ANEVA/Pantofolini S.A.

Identification of the object:

Not requested

- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
- dielectric tests with direct voltage : voltage: $\pm 3\%$
The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values


Laboratory information:

Receipt date of the sample : November 30, 2005
Test location : CESI - Via Rubertino 54 - Milan
CESI testing team : L. Pedrini
Test laboratory : P177
Activity code : 46879G

A10010G

ВЯРНО С
ОРИГИНАЛА

Handwritten signature



Approved



№ 0010

СЕСІ

Test Report

test date	page	Content
November 26-28, 2009	4	Test object of investigation
	5	Photograph of the test object
	6	Reference standard
	6	Reference standard
	6	Reference standard
	6	Test control test
	6	Test object identification
	7	Test procedure
	8	Visual inspection and summary of test results
	9-17	High speed impact operating duty test
	18-24	Technical data

А10110


Handwritten initials

**ВЯРНО С
ОРИГІНАЛА**

Handwritten signature

Handwritten signature

Handwritten mark



Test object characteristics

Type: Polymer based metal-oxide surge arrester (thermal equivalent)

Electrical characteristics (assigned by the client)

Manufacturer's name	ARZVA, Parafonites S.A. - Espoores (to Espoores (France))
Nominal discharge current - I_n [kA]	10.0
Rated voltage - U_r [kV]	U _r = 1,035
Continuous operating voltage - U_c [kV]	U _c = 0,880
Reference current - I_{ref} [mA]	1.0
Line discharge class	1
Rated frequency - [Hz]	50 - 60

Geometrical characteristics (measured with thermal insulation)

Total height [mm]	245
Number of sheds	n. 4 large - n. 3 small
Shed diameter [mm]	104 large - 74 small
Core diameter [mm]	48

Other characteristics

Insulating material	Silicone
Insulating color	Grey

NOTE: The surge arresters were tested with the additional thermal insulation supplied by the Client. The verification of the thermal equivalency according to annex B was carried out by the Client (see annexed document n. AS8577452)

ВЯРНО С
ОРИГИНАЛА




Photo no. 1

[Handwritten signature]

СЕРТИФИКАЦИЯ
AS005408
СЕРТИФИКАЦИЯ

[Handwritten mark]

[Handwritten signature]

**ВЯРНО С
ОРИГИНАЛА**

338

ALZGIC

[Handwritten signature]

[Handwritten signature]

Reference standard

The test was carried according to the IEC 60099-4 (2004) Standard - Clause 8.5


"Metal-oxide surge arrester without gaps for a.c. system"

Test carried out

test carried out	number of sample tested
high current impulse symmetrical test	3

Test object identification

test object names	identification of test sample (assigned by the CESI)
polymer bonded metal-oxide surge arrester	OD1-OD2-OD3



ВЯРНО С
ОРИГИНАЛА

Test procedure (Foreseen by the relevant standard)


- The power frequency reference voltage at $U_{ref} = 1.0$ mA has been measured
- The lightning impulse residual voltage at $I_N = 10$ kA has been measured
- The voltage correction factors have been calculated according to reference standard
- The pre-conditioning has been performed on surge arrester at ambient temperature according to reference standard as per the following procedure:
 - Twenty shots 820 μ s at I_N have been applied superimposed to the power frequency at the voltage level 1.2*U_L. The shots have been applied in four groups of five impulses. The interval between impulses of the same group was 30-60 seconds while the interval between groups was 30 minutes. The polarity of the impulses was the same as that of the half cycle of power frequency voltage during which it occurred (positive) and they were applied 60 electrical degrees before the peak of the power frequency.
 - The samples have been let to cool down to ambient temperature
 - The first high current impulse having waveforms 4/10 μ s and peak value equal to 100 kA has been applied
- The surge arrester section kept in an oven at the temperature of 60 °C till thermal equilibrium

The second high current impulses having waveforms 4/10 μ s and peak value equal to 100 kA has been applied. A time shorter than 100 ms after the application of the second high current impulse the sample has been submerged at U_L for 10 sec. and then at the voltage U_L for 30 min. to verify the thermal stability.

- The lightning impulse residual voltage at $I_N = 10.0$ kA has been repeated two times.

CS

ВЯРНО С
ОРИГИНАЛА
330




Visual inspection and summary test results

Variation of lightning impulse residual voltage at 1s

Sample	before test		after test		variation %
	discharge current kA	residual voltage kV	discharge current kA	residual voltage kV	
OD1	10,0	15,61	10,16	15,87	1,67
OD2	10,0	15,64	10,15	15,95	1,98
OD3	10,0	15,76	10,15	15,92	1,01

The visual inspection after the test has revealed no sign of physical damage. The variation of lightning impulse residual voltage before and after the test was less than 5%.
The disconnection did not occur.
The thermal stability was achieved. The oscillogram record of the two last shots doesn't reveal any sign of internal discharge.
All acceptance criteria are satisfied and therefore the test result is to be considered positive.



ВЯРНО С
ОРИГИНАЛА

High current impulse operating duty test.
 Power frequency voltage-current characteristics.
 Test circuit: A019
 Date: November 30, 2003

Sample No. OD1						
Oscilloscope No.	voltage kV	current +mA _{cr}	current -mA _{cr}	power W	3rd harmonic amplitude μA	
1	5.98	1.03	1.00	0.590	1.99	-

Sample No. OD2						
Oscilloscope No.	voltage kV	current +mA _{cr}	current -mA _{cr}	power W	3rd harmonic amplitude μA	
2	5.97	1.02	1.01	0.600	2.03	-

Sample No. OD3						
Oscilloscope No.	voltage kV	current +mA _{cr}	current -mA _{cr}	power W	3rd harmonic amplitude μA	
3	5.95	1.00	0.95	0.590	1.95	-

[Handwritten signature]

[Circular stamp: ESTERILIZADO]

[Handwritten signature]

ВЯРНО С
 ОРИГИНАЛА
 392

[Handwritten signature]


333

High current impulse operating duty test.

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: November 30, 2005



Sample No.	Requested current In	Charging voltage kV	Oscilloscope No.	Current waveform IIS	Discharge current IIA	Residual voltage kV
OD1	10.0	29.6	4	8.7/18.5	10.0	15.61
OD2	10.0	29.6	5		10.0	15.64
OD3	10.0	29.6	6		10.0	15.76

Oscilloscope settings	
sampling division IIS	input attenuation
Current 5.0	V/div 50.5
Voltage 5.0	20.5

Notes:


ВЯРНО С !
ОРИГИНАЛА

Voltage correction factor

Date: November 30, 2005

Sample No.	U _{ref} [1] KV	K _{CU} [2]	K _{UC} [3]	U ₁ [4] KV	U ₂ [5] KV	U ₁ [6] KV
021	5.98			6.19	5.25	6.31
022	5.97	1.035	0.880	6.18	5.25	6.30
023	5.95			6.16	5.23	6.28

- [1] U_{ref} : measured reference voltage
- [2] K_{CU} : factor claimed by the manufacturer for calculation of U₁
- [3] K_{UC} : factor claimed by the manufacturer for calculation of U₂
- [4] U₁ : corrected rated voltage [4] = [1] × [2]
- [5] U₂ : corrected continuous operating voltage [5] = [1] × [3]
- [6] U₁ : corrected voltage to be applied during the conditioning [6] = 1.2 × [5]



A14610

ВЯРНО С
ОРИГИНАЛА


39.4

High current impulse operating duty test, IEC 60099-4 Standard

Conditioning

Test circuit: A0115

Date: November 30, 2005



ВЯРНО С
ОРИГИНАЛА

Imp. No.	Cct. No.	Sample No. OD1		Cct. No.	Sample No. OD2		Cct. No.	Sample No. OD3	
		charging kA	peak current kA		charging kV	peak current kA		charging kV	peak current kA
1	7	38.5	10.0		38.5	10.0		38.5	10.0
2		38.5	10.0		38.5	10.0		38.5	10.0
3		38.5	10.0		38.5	10.0		38.5	10.0
4		38.5	10.0		38.5	10.0		38.5	10.0
5	8	38.5	10.0	9	38.5	10.0	10	38.5	10.0
6		38.5	10.0		38.5	10.0		38.5	10.0
7		38.5	10.0		38.5	10.0		38.5	10.0
8		38.5	10.0		38.5	10.0		38.5	10.0
9		38.5	10.0		38.5	10.0		38.5	10.0
10	11	38.5	10.0	12	38.5	10.0	13	38.5	10.0
11		38.5	10.0		38.5	10.0		38.5	10.0
12		38.5	10.0		38.5	10.0		38.5	10.0
13		38.5	10.0		38.5	10.0		38.5	10.0
14		38.5	10.0		38.5	10.0		38.5	10.0
15		38.5	10.0		38.5	10.0		38.5	10.0
16		38.5	10.0		38.5	10.0		38.5	10.0
17		38.5	10.0		38.5	10.0		38.5	10.0
18		38.5	10.0		38.5	10.0		38.5	10.0
19		38.5	10.0		38.5	10.0		38.5	10.0
20	14	38.5	10.0	15	38.5	10.0	16	38.5	10.0

Power frequency voltage applied to the test sample	Sample No. OD1 6.31	Sample No. OD2 6.30	Sample No. OD3 6.28
--	------------------------	------------------------	------------------------

Oscilloscope settings	sampling division	Input	attenuation
	Current	10	50:5
	Voltage	10	50:5

Notes:

High current impulse operating duty test, IEC 60099-4 Standard

Application of the first high current impulse

Test circuit: A0121

Date: December 1, 2005

Sample No.	Impulse No.	Charge voltage kV	Oscillogram No.	Residual voltage kV	Discharge current kA	Current waveshape
GD1	1	81,0 x 2	17	26,5	94,5	4,59,6 μ s
GD2		81,0 x 2	18	26,6	94,5	opposite polarity 6 %
GD3		81,2 x 2	19	26,0	95,0	

Oscilloscope settings	
amplifying division μ s	2
input V/div	1,0
Current	300-5
Voltage	30-5


Notes:



ВЕРНО С
ОРИГИНАЛА

396





High current impulse operating duty test IEC 60099-4 Standard
 Application of the second high current impulse, of the rated voltage U_1 , and evaluation of thermal stability

Test circuit: A0123-A0204-A0131
 Sample No.: OD1
 Preheating temperature: 61 °C
 Date: December 01, 2005

Second high current impulse application

Charging No.	Charging voltage kV	Residual voltage kV	Discharge current EA	Current waveform
20	81 x 2	28,4	94,0	4.5/9.6 μ s opposite polarity 6 %

U_1 voltage application

Qualification No.	Time s	Voltage kV	Current +mA	Current +mA	Power W
21	0	6,19	31,0	50,0	---
22	10		22,0	35,0	---

U_1 voltage application

Qualification No.	Time min	Voltage kV	Current +mA	Current +mA	Power W
23	0		6,60	7,60	11,3
	5		1,64	2,5	2,17
	10	5,26	1,54	1,88	2,84
24	15		1,53	1,68	2,55
	20		1,54	1,54	2,36
	25		1,51	1,51	2,17
25	30		1,50	1,50	2,10

ВЕРНО С
ОРИГИНАЛА

continued

Continued

Sample No.: 002

Preheating temperature: 60 °C

Date: December 01, 2005

Second high current impulse application

Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Current waveform $4,571 \mu s$ opposite polarity 6%
26	83.7.2	28.0	97	

U₁ voltage application

Oscillogram No.	Time min	Voltage kV	Current +mA _{av}	Current -mA _{av}	Power W
27	0	6.18	35	84	---
28	10		23	34	---

U₂ voltage application

Oscillogram No.	Time min	Voltage kV	Current +mA _{av}	Current -mA _{av}	Power W
29	0		5.10	8.40	12.50
	5		1.72	2.77	3.85
	10		1.59	2.31	3.48
30	15	5.25	1.66	2.11	2.98
	20		1.55	1.93	2.98
	25		1.52	1.75	2.46
31	30		1.50	1.60	2.38

continued

A1150G

ВЕРНО С
ОРИГИНАЛ
398



Handwritten signature

Handwritten signature

Handwritten signature

Handwritten signature

Handwritten mark


Certified

Sample No.: 003

Preheating temperature: 61 °C

Date: December 01, 2005

Second high current impulse application



Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Current waveform μs
32	83 x 2	28,5	97,0	4,5/9,6 μs opposite polarity 6 %

U_1 voltage application

Oscillogram No.	Time μs	Voltage kV	Current +mA _{av}	Current -mA _{av}	Power W
33	0	6,16	20,0	48,0	—
34	10		20,0	31,0	—

U_2 voltage application

Oscillogram No.	Time min	Voltage kV	Current +mA _{av}	Current -mA _{av}	Power W
35	1	5,23	4,9	7,5	11,7
	5		1,61	2,06	3,15
	10		1,57	1,8	2,52
36	15	5,23	1,34	1,47	2,21
	20		1,31	1,43	1,96
37	25	5,23	1,25	1,30	1,81
	30		1,20	1,30	1,74

ВЯРНО С
 ОРИГИНАЛА

continued

High current impulse operating duty test, IEC 60099-4 Standard

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: December 2, 2005

Sample No.	Requested current	Charging voltage	Capacitors	Current wave shape	Discharge current	Residual voltage
No.	kV	No.	μs	kA	kV	
OD1	30.0	38		10.14	15.81	
	30.0	39		10.16	15.87	
OD2	30.0	40	3,6*18,6	10.18	15.96	
	30.0	41		10.15	15.95	
OD3	30.0	42		10.16	15.89	
	30.0	43		10.15	15.92	

	sampling division	Oscilloscope settings	
		Input	attenuation
Current	5.0	0.5	50:5
Voltage	5.0	1.0	20:5

Notes:

[Handwritten signature]





[Large handwritten signature]

ВЯРНО С
ОРИГИНАЛА

400

[Handwritten signature]

Circuit A0019



ВЕРНО С
ОРИГИНАЛА

Power frequency supply


- RE - programmable supply type LARCEL A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRANSFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current limit CESI N° 31120; R-94140
- CSC - Electro optical system CESI N°-; animation 55
- CSC - Oscilloscope type SONY TEKTRONIX K10 710; CESI N° 6318

Voltage measuring system

- D - Voltage divider SAGE; CESI N° 11120
- CSC - Electro optical system CESI N° 1150011824; animation 55
- CSC - Oscilloscope type SONY TEKTRONIX K10 710; CESI N° 6318



Impulse generator

- No. of rings: 2
- Cg: 2.49 μF
- Lc: 18 μH
- S: - Spark-gap


Voltage measuring system

- D: - Voltage divider SACTI, CEST No. 13027
- OSC: - Electro optical system CEST No. 11521522
- OSC: - Oscilloscope type TEKTRONIX TDS 540A; CEST No. 13217 (see channel No.2)

Current measuring system

- Sh: - Current shunt CEST No. 6042, R= 2 mΩ; peak current= 250 kA
- OSC: - Electro optical system CEST No. 11517518
- OSC: - Oscilloscope type TEKTRONIX TDS 540A; CEST No. 13217 (see channel No.1)

[Handwritten signature]




CyH


[Large handwritten signature]

ՀԱՅԱՍՏԱՆԻ ՀԱՆՐԱՊԵՏՈՒԹՅԱՆ ԳՐԱԴԱՐԱՆ

[Handwritten signature]



Circuit A0015



Impulse generator

- No. of stages: 1
- C₀ - Capacitor 4,98 μF
- L - Inductance of the circuit
- L₀ - Inductor 10 μH
- S - Switch gpp
- Resistor blocks has been added
- Power frequency supply
- RE - Resistor type specialpurpose, power 20 W/A; voltage 380 V/220 V
- T - Transformer type Pivi; power 20 kVA; voltage 220 V/ 15 kV
- B - Blocking gpp


Current measuring system

- Sh - Current shunt CESI No.6042; R = 0,001 Ω
- CSC - Electro optical system CESI No.1151711518; attenuation 20:5
- CSC - Oscilloscope type Tektronix-540A; CESI No.13217 (on channel No.1)

Voltage measuring system

- D - Voltage divider SAGI; CESI No.1126; R = 1010
- CSC - Electro optical system CESI No.1152011521; attenuation 50:5
- CSC - Oscilloscope type Tektronix-540A; CESI No.13217 (on channel No.2)

ВЯРНО С
ОРИГИНАЛА



Impulse generator

- No. of stages 2
- Cg 3,32 μF
- S - Spark-gap


Voltage measuring system

- D - Voltage divider (not used)

Current measuring system

- Sh - Current shunt, CESI No. 6642, R=2 mΩ; peak current= 250 mA
- OSC - Electro optical system CESI No. 1521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No. 13217 (on channel No.1)

[Handwritten signature]



A01210

ВЯРНО С
ОРИГИНАЛА


404

[Handwritten mark]

[Large handwritten signature]

[Handwritten signature]

Circuit A0123




Impulse generator circuit

No. of stages 2


C_g 332 μF

S - spark-gap



ВЯРНО СЪ
ОРИГИНАЛА

Circuit A0120



Impulse generator circuit A0124

I - Circuit-breaker

Impulsive current measuring system

- Sh₁ - Current shunt CESI No.60.62; R=2 m.Ω
- OSC₁ - Electro optical system CESI No.1151/518; attenuation 300:5
- OSC₂ - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

Power frequency circuit A0130

Voltage measuring system

- D - Voltage divider S&C; CESI No.11027
- OSC₁ - Electro optical system CESI No.806/8015; attenuation 50:5
- OSC₂ - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)
- OSC₃ - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.5090 (on channel No.2)


Power frequency current measuring system

- Sh₂ - Current shunt CESI P=400 Ω - Electro optical system CESI No.801/8017; attenuation 300:5 - 5:5

OSC₂ - Oscilloscope type TEKTRONIX TDS 744A; CESI No.1397 (on channel No.1)

А00210


[Handwritten signature]



[Handwritten signature]


ВЕРНО С
 ОРИГИНАЛА
 106

[Handwritten signature]



ВЯРНО С
 ОРИГИНАЛА

Circuit A0131




Power-frequency circuit

- from 380Vac power supply
- R₁ single-phase voltage regulator CORMES; power 20 kVA; voltage 380/0/220 V/ac
- R₂ single-phase voltage regulator CORMES; power 10 kVA; voltage 380/0/220 V/ac
- T₁ voltage transformer type SPECIALTBA-SF50; power 30 kVA; voltage 200-400 V/15-30 kV

A0131G

[Handwritten signature]



СЭС1.Р-С А5055428 Осцилограмм а. 1


[Handwritten signature]

[Handwritten signature]


[Handwritten signature]

ВЕРНО С
ОРИГИНАЛ

[Handwritten mark]





ВЯРНО С !
ОРИГИНАЛА



CEST POC A6055428 Oscillogram n. 2

Handwritten signature



СЕСІ-РсС А5055428 Осцилограм n. 3

Handwritten signature



ВЯРНО С
ОРИГІНАЛА

Handwritten initials

Handwritten signature


Handwritten initials

ВЯРНО С !
ОРИГИНАЛА



СЕСИ РсС А2035428 Oscillogram. 4

Handwritten signature



CESI PoC A5055422 Oscillogram n. 5


Large handwritten signature

ВЕРНО С
ПОДПИСАНА


Handwritten initials

Handwritten signature

Handwritten initials





ВЯРНО С
ОРИГИНАЛА



CESI PeC A5055423 Oscillogram n. 6

Handwritten signature




CESI PeC A505423 Oscillogram n. 7

Handwritten signature


ВЯРНО С
ОРИГИНАЛА

Handwritten signature

Handwritten mark





✓ ВЯРНО С
ОРИГИНАЛА



СЕСИ РС А5055428 Осцилограмм n. 8

Handwritten signature



CESI PeC A505422 Oscillogram n. 9

Handwritten signature


Handwritten signature

Handwritten signature


ВЯРНО С
ОРИГИНАЛА
410

Handwritten signature

Handwritten signature




ВЯРНО С
ОРИГИНАЛА




CESI PeC A5055428 Oscillogram n. 10

Handwritten signature



Handwritten initials





CESI PeC A3055423 Oscillogram n. 11

Handwritten signature

ВЯРНО С
ОРИГИНАЛА


Handwritten signature

Е ВЯРНО С
ОРИГИНАЛА



СЕСИ Рес 15455428 Oscillogram n. 12

Handwritten signature



CESI Рес А5055428 Осцилограмм n. 13


Handwritten signature

Handwritten initials 'СЧ'


ВЯРНО С
ОРИГИНОЛА
120

Handwritten initials 'СЧ'

Handwritten signature





ВЕРНО С
ОРИГИНАЛА



CESI Рес А5055428 Oscillogram n. 14

Handwritten signature




СЕСИ РЭС А5065428 Осцилограм н. 15

Handwritten signature


Handwritten initials 'СВ'

ВЯРНО С
ОРИГИНАЛА
422


Handwritten signature




Г ВЯРНО С
ОРИГИНАЛА



CESI P e C A5055428 Oscillogram n. 16



Handwritten signature



CESI PeC A5055428 Oscilogram n. 17

Сей



04

Handwritten signature

ВЕРНО С
ОРИГИНАЛА

Handwritten signature


ВЯРНО С
ОРИГИНАЛА



СЕСИ Рес А3055428 Oscillogram n. 18

СВХ

[Handwritten signature]



СЕСИ Рес А5055428 Осцилограм n. 19

Сей



[Handwritten signature]

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА



СЕСИ РЕС А5055428 Осцилограм н. 20



Handwritten signature



СЕСИ Рес А305423 Oscilogram n. 21



Handwritten initials 'СВ'

ВЯРНО С
ОРИГИНАЛА


Handwritten signature

Handwritten signature


ВЯРНО С
ОРИГИНАЛА



СЕСИ РсС А3055428 Oscillogram n. 22



[Handwritten signature]





CEST PeC A5055428 Oscillogram n. 23

СМ
СМ


[Handwritten signature]

ВЯРНО СЪ
ОРИГИНАЛ


ВЯРНО СЪ
ОРИГИНАЛА



CEST PeC A5055428 Oscillogram n. 24





[Handwritten signature]



СЭСІ РсС А5055428 Oscillogram n. 25



[Handwritten signature]
СРНО С
ОРИГИНАЛА
[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА



СЕСИ РсС А5055428 Oscillogram n. 26

[Handwritten signature]



CESI PeC A5055428 Oscillogram n. 27



[Handwritten signature]

[Handwritten signature]


ВЕРНО С
ОРИГИНАЛ

434


ВЪРНО С
ОРИГИНАЛА



CESI PeC A5055428 Oscillogram n. 28



[Handwritten signature]





CESI PeC A5055428 Oscillogram n. 29

[Handwritten signature]


[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА


ВЯРНО С
ОРИГИНАЛА



CESI PeC A5055428 Oscillogram n. 30




[Handwritten signature]




СЭС1 РсС А5055428 Oscillogram n. 31

[Handwritten signature]
[Handwritten signature]


ВЯРНО С
ОРИГІНАЛА
138




ВЯРНО С
ОРИГИНАЛА



CESI PeC A5055428 Oscillogram n. 32



[Handwritten signature]





CESI PeC A5055428 Oscillogram n. 33


[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА


ВЯРНО С
ОРИГИНАЛА



СЭСИ РсС А5055428 Oscillogram n. 34



[Handwritten signature]





СЭСІ РсС А5055428 Осцилограм н. 35

[Handwritten signature]

ОПРНО
СЕРТИФИКАТ

[Handwritten signature]


ВЯРНО С
ОРИГИНАЛА



CESI PaC A5055428 Oscillogram n. 36



[Handwritten signature]




CESI PсC A5055428 Oscillogram n. 37

ce


[Large handwritten signature]

cy

ВЯРНО С
ОРИГИНАЛА




ВЯРНО С
ОРИГИНАЛА



CESI PeC A5055428 Oscillogram n. 38



[Handwritten signature]





CEST PeC A5055428 Oscillogram n. 39

[Large handwritten signature]

[Handwritten initials]

ВЯРНО С
ОРИГИНАЛА


ВЯРНО С
ОРИГИНАЛА



CESI PeC A5055428 Oscillogram n. 40



[Handwritten signature]





СЭСІ РсС А5055428 Oscillogram n. 41


[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА
418


ВЯРНО С
ОРИГИНАЛА



CESI PeC A5055428 Oscillogram n. 42



[Handwritten signature]



СЕСИ РѢС А5055428 Oscillogram n. 43

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

ВЯРНО СЪ
ОРИГИНАЛА
450

DATA & RESULTS FOR THE ACCELERATED AGEING TEST performed on metal oxide varistor blocks intended for VARISIL Type HE surge arresters

Test conditions: according to the requirements and the procedure defined in clause 8.2 of IEC 60099-4 - Edition 2.0 (May 2004)

Test samples: 3 sliced parts of HE surge arrester built with a single MOV block rated 6 kV

Test voltage: $U_{ct} = U_0 \times (1 + D \times H) \times U_{ref} / U_{refm}$

where: $U_0 = 5100$ V rms is the continuous operating voltage of a MOV block rated 6 kV

$D = 12$ %/m is the maximum distortion of voltage distribution within the HE range (1)

$H = 0,326$ m is the maximum total height within the HE range (1)

$U_{ref} = 6855$ V peak/V2 is the reference voltage at 1 mA peak a.c. of the test samples

$U_{refm} = 5800$ V peak/V2 is the specified minimum reference voltage for a MOV block rated 6 kV

$U_{ct} = 6350$ V rms

Sample no. 1	2,05	1,90
Sample no. 2	2,30	1,90
Sample no. 3	2,00	1,72

Sample no. 1	1,67	1,57
Sample no. 2	1,76	1,67
Sample no. 3	1,47	1,35

Sample no. 1	1,22	1,22
Sample no. 2	1,33	1,35
Sample no. 3	1,23	1,22

Sample no. 1	1,01	0,92
Sample no. 2	1,02	0,92
Sample no. 3	0,90	0,83

Sample no. 1	0,88	0,79
Sample no. 2	0,85	0,79
Sample no. 3	0,83	0,77


Sample no. 1	0,66	0,61
Sample no. 2	0,66	0,76
Sample no. 3	0,64	0,76

Sample no. 1	0,64	0,74
Sample no. 2	0,64	0,74
Sample no. 3	0,64	0,74

Sample no. 1	0,83	0,74
Sample no. 2	0,83	0,74
Sample no. 3	0,83	0,74

Sample no. 1	0,82	0,73
Sample no. 2	0,82	0,73
Sample no. 3	0,81	0,72


Sample no. 1	0,81	0,73
Sample no. 2	0,81	0,73
Sample no. 3	0,80	0,72



CONCLUSION: as both $P_{ct} \leq 1,1 \times P_{ct}$ and $P_{ct} \leq P_{ct}$ for all three test samples, the high current impulse operating duty test according to clause 9.7.5 of IEC 60099-4 can be performed on new MOV blocks at Ur and Usc

without any additional correction


Note (1): the values indicated refer to VARISIL Type HE 36 surge arrester which represents both the longest unit and the highest specific voltage stress per unit length



ВЕРНО С
ОРИГИНАЛА



Handwritten signature




Cooling time (min)	VARISIL Type HE 36 surge arrester	6 kV PRORATED SECTION
0	120.0	120.0
5	104.0	105.0
10	92.5	93.5
15	82.5	84.0
20	73.5	76.5
25	66.0	69.0
30	60.0	63.5
35	54.5	58.5
40	50.0	54.0
45	46.0	50.0
50	42.5	46.5
55	39.0	43.5
60	36.5	41.0
65	34.0	39.0
70	32.0	37.0
75	30.5	36.0
80	29.0	33.5
85	27.5	32.0
90	26.5	31.0
95	26.5	30.0
100	24.5	29.0
105	24.0	28.5
110	23.5	27.5
115	23.0	27.0
120	22.5	27.0

Test conditions : according to the requirements and the procedure defined in clause 10.5.3.2 and Annex B of IEC 60099-4 - Edition 2.0 (May 2004)
 Still air ambient temperature : 17 +/- 2 °C
 Time delay to reach the temperature of 120 °C by application of a power frequency overvoltage : app. 32 min
 In both cases, the temperature was measured at a single point of the MO varistor located between 1/2 and 1/3 of the test sample length from its energised end

DATA & RESULTS FOR VERIFICATION OF THE THERMAL EQUIVALENCY between VARISIL Type HE 36 complete surge arrester and 6 kV PRORATED SECTION under test

Handwritten signature

ВЯЧ 152 с
 ОРИГИНАЛА




U(t) gamme HE-S


temps (s)	U / Ur			U / Uc		
	neuf	1 x 100 kA	2 x 100 kA	neuf	1 x 100 kA	2 x 100 kA
0.1	1.327	1.194	1.154	1.561	1.405	1.368
0.5	1.285	1.157	1.118	1.512	1.361	1.315
1	1.267	1.140	1.102	1.491	1.342	1.297
5	1.227	1.104	1.067	1.444	1.299	1.256
10	1.210	1.089	1.053	1.424	1.281	1.238
60	1.163	1.047	1.012	1.368	1.231	1.190
120	1.144	1.030	0.995	1.346	1.211	1.171
300	1.121	1.009	0.975	1.319	1.187	1.147
600	1.103	0.993	0.960	1.298	1.168	1.129
1800	1.075	0.968	0.935	1.265	1.138	1.100
3600	1.059	0.953	0.921	1.246	1.121	1.084
10800	1.035	0.932	0.900	1.218	1.096	1.059
36000	1.012	0.911	0.880	1.191	1.072	1.036
86400	1.002	0.902	0.872	1.179	1.061	1.026
604800	0.994	0.895	0.865	1.169	1.052	1.017

09


ВЯРНО С
ОРИГИНАЛА

09





MINIMUM TEMPORARY OVERVOLTAGE WITHSTAND CAPABILITY of VARISIL Type HE-S Surge Arresters according to Annex D of IEC 60099-4



ВЯРНО
ОРИГИНАЛ




3


3

Vertical line at the bottom right edge of the page.

MINIMUM TEMPORARY OVERVOLTAGE WITHSTANDING CAPABILITY of VARISIL Type HE-S Surge Arresters according to Annex D of IEC 60099-4



ВЯРНО С
ОРИГИНАЛ




8

8

8

**TENUE MINIMALE AUX SURTENSIONS TEMPORAIRES
des parafoudres VARISIL HE-S selon Annexe D de la CEI 60099-4**



КОПИЯ С
ОРИГИНАЛА



456
С/Ф

8.

8.

**TENUE MINIMALE AUX SURTENSIONS TEMPORAIRES
des parafoudres VARISIL HE-S selon Annexe D de la CEI 60099-4**

ВЯРНО С
ОРИГИНАЛ



8

8

Client TRIDELTA PARAFOUDES S.A.

Address of the Client Boulevard de l'Adour - BP 256 - 65202 Bagnères de Bigorre Cedex (France)

Manufacturer TRIDELTA PARAFOUDES S.A.

Tested samples/items Disconnecter type S3D2 for metal oxide surge arrester

Tests carried out Long-duration current impulse withstand test

Standards/Specifications IEC 60099-4 - Edition 2.2 (2009-05)

Tests date from September 12, 2011 to September 13, 2011

The results reported in this document relate only to the tested sample/items. Partial reproduction of this document is permitted only with the written permission from CESI. Any reference to the Accreditation body shall include name, registration number and scope.



DAI-PL-284/09-00

Testing laboratory accredited ISO/IEC 17025:2005 in the fields of:
High-Voltage Equipment and their Components
Transformers and their Components
Low-Voltage Switching Devices and Switchgears
Electromagnetic Compatibility (EMC)

No. of pages	20	No. of pages annexed	8
Issue date	September 14, 2011		
Prepared	PPR - Gregori Marco		
Verified	PPR - Vidoni Mauro, TPI - Sironi Alberto		
Approved	PMI - The Manager - Arcidiaco Lorenzo		

CESI S.p.A.
Testing & Certification Division
Testing Operations Area
"Milan Platform"
Management

Registro Imprese di Milano
Sezione Ordinaria
P. I.E.A. 425822
P. I. 110015506160

Capitale sociale 8.550.000 Euro
Instruments versato
Codice fiscale e numero
P. I.E.A. 425822
Sezione C.C.I.A.A. 001763860150

Via R. Robuffino 54
20134 Milano - Italia
Telefono: 02 527125.1
Fax: 02 527125.40
http://www.cesi.it

CESI
Centro Elettrotecnico
Sperimentale Italiano
Giussano (MI) spa

A100010 rev.6


PUBBLICATO B1027449 (PAD - 1535450)

ВАРНО С
ОРИГИНАЛА

[Large handwritten signature]

[Handwritten initials]

[Handwritten signature]



Tests witnessed by: --

Mr. Frederic Malpicec
Mr. A. Athanasus

TRIDELTA Parafoudres S.A.
PUBLIC POWER CORPORATION

Identification of the object:

Not requested

Test evaluation

With reference to the Standards/Specifications listed in the first page and the characteristics of the tested sample assigned by manufacturer, the carried out tests passed SUCCESSFULLY.

The data necessary to permit repetition of the tests are contained in the document marked: --

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$ time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$ time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$ time parameters: $\pm 3,5\%$
- dielectric tests with direct voltage : voltage: $\pm 3\%$ time parameters: $\pm 3,5\%$
- partial discharge measurement : up to 10 pC: ± 1 pC above 10 pC: $\pm 10\%$ humidity: $\pm 10\%$
- atmospheric conditions : temperature: $\pm 2\text{ }^\circ\text{C}$ pressure: $\pm 0,133$ kPa

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory information

Receipt date of the sample	September 12, 2011
Test location	CESI - Via Rubattino 54 - Milan
CESI testing team	Mr. L. Podavite - Mr. I. Guacci
Test laboratory	P177
Activity code	AE11PMI018

459

ВЯРНО С
ОРИГИНАЛА

content	page a	test date
Test object characteristics	4	
Pictures of the test sample	from 5 to 6	
Reference standard	7	
Test carried out	7	
Test object identification	7	
Test procedure	8	
Visual Inspection	9	
Power frequency voltage characteristics	10	September 12, 2011
Lightning impulse residual voltage measurement before the test	11	September 12, 2011
Switching impulse residual voltage test	12	September 12, 2011
Voltage correction factor and energy calculations	13	September 12, 2011
Long duration current impulse withstand test	14	September 12&13, 2011
Lightning impulse residual voltage measurement after the test	15	September 13, 2011
Check the integrity of the internal parts with an additional shot	16	September 13, 2011
Technical data of the test circuit	from page 17 to 20	

Pages annexed:
oscillograms n. 8 pages

ВЯНО
ОРИГИНАЛ

Test object characteristics

type: Disconnector type S3D2 for metal oxide surge arrester

The table below lists the electrical characteristics (assigned by the client) of the surge arresters for which the disconnectors are designed

electrical characteristics (assigned by the client)

Manufacturer's name	TRIDELTA PARAFONDRES S.A.
Normal discharge current - I_n [kA]	10
Rated voltage - U_r [kV]	1,035 x U_{ref}
Continuous operating voltage - U_c [kV]	0,880 x U_{ref}
Reference current - I_{ref} [mA]	1,0
Line discharge class	1
Standard rated frequency - [Hz]	50/60
year of manufacture	2011

ВЯРНО С
ОРИГИНАЛА

Pictures of the sample




Photo no. 1





Photo no. 2

[Handwritten signature]

[Handwritten signature]

**ВЯРНО С
ОРИГИНАЛА**

[Large handwritten signature]






Photo no. 3





Photo no. 4



ВЯРНО С
ОРИГИНАЛА

Test Report

Approved

Reference Standard

IEC 60099-4 (2009/05) – Edition 2.2 – Clause 8.6.2.1
“Metal-oxide surge arresters without gaps for a.c. systems”

Test carried out	Number of samples tested
Long-duration current impulse withstand test	3

Test object identification

Test object name	Identification of test sample (given by CESI)
Disconnector type S3D2 for metal oxide surge arrester	ILD – 2LD – 3LD

ВЯРНО С
ОРИГИНАЛА

A1265TG

Test procedure

The test has been performed on three disconnectors connected in series.

A suitable surge arrester section was supplied by the Client.

It was used, as part of the circuit in this frame, connected in series with the test samples, to get proper impulse current waves and power frequency current flowing through the disconnectors.

The test procedure consisted of the following sequence:


- a) Measurement of the power frequency reference voltage at the reference current
- b) Measurement of the lightning impulse residual voltage at nominal discharge current
- c) Measurement of the switching impulse residual voltage at the lowest current peak prescribed by the standard in table 4 that is 125 A.
- d) Calculation of the specified energy associated to each long duration current impulse according to clause 8.4.2 of the reference standard
- e) Application of eighteen long duration current impulses with the specified energy and a virtual duration of 2000 μ s in six groups of three operations each.
 - intervals between operations of the same group: 60 seconds
 - interval between different groups: as required to cool down the samples to near ambient temperature
- f) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value
- g) After cooling down to near ambient temperature cooling down to near ambient temperature application of a nineteenth impulse to check the sample integrity

The disconnectors did not operate.

The acceptance criteria are fulfilled. The test result is positive.

ВЯРНО С
ОРИГИНАЛА

405



CESI

Test Report

Approved

Visual inspection after the test

The disconnectors withstood the full procedure without operation and without showing any visible damage.

**ВЯРНО С
ОРИГИНАЛА**

Long-duration current impulse withstand test.

Reference voltage test.


Test circuit: A0019

Date: September 12, 2011

Oscillogram No.	Voltage kV	current		power W	3rd harmonic amplitude μ A
		+mA _G	-mA _G		
1	6,05	0,97	1,05	1,70	—

Sample No. IID-2LD-3LD

ВЯРНО С
ОРИГИНАЛА



467

Long-duration current impulse withstand test.


Switching impulse residual voltage test.

Test circuit: A0122

Date: September 12, 2011

Sample No.	Requested current A	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current A	Residual voltage kV
ILD-2LD-3LD	125	12.7	3	30/61,0	129	11,28

Notes:



ВЯРНО С
ОРИГИНАЛА

Long duration current impulse withstand test.

Voltage correction factor and energy calculations

Date: September 12, 2011

Sample No.	U_{ref} [1] KV	kU_f [2] KV	kU_c [3] KV	U_f [4] KV	U_c [5] KV
1LD-2LD-3LD	6,05	1,035	0,880	6,262	5,324

- [1] U_{ref} : measured reference voltage
- [2] kU_f : maximum guarantees factor for calculation of U_r
- [3] kU_c : maximum guarantees factor for calculation of U_c
- [4] U_f : corrected rated voltage [4] = [1] × [2]
- [5] U_c : corrected continuous operating voltage [5] = [1] × [3]

Sample No.	U_f KV	U_L KV	V_{rms} KV	T	Z KV	W KJ	W' KJ/KV
1LD-2LD-3LD	6,262	20,04	11,28	2000	30,68	6,442	1,029

- V_{rms} : switching impulse residual voltage
- U_L, T, Z : see table 5 of IEC 60099-4 standard
- W : $= V_{rms} \times (U_L - V_{rms}) \times (T / Z)$

ВЯРНО С
ОРИГИНАЛА



Test Report

Approved

+ Long duration current impulse withstand test.

Test circuit: A0017

Date: September 12, 2011

Sample No.	Impulse No.	Charging voltage V_c kV	Oscillogram No.	Peak current I A	Residual voltage V_r kV	Energy E kJ
ILD-3LD-3LD	1	35.8		255.0	11.49	6.45
	2	35.8		256.0	11.57	6.50
	3	36.0	4	256.0	11.64	6.55
	4	36.0		257.0	11.59	6.53
	5	36.0		256.0	11.60	6.55
	6	36.0		256.0	11.66	6.56
	7	36.0		256.0	11.77	6.54
	8	36.0		257.0	11.65	6.54
	9	36.0	5	256.0	11.68	6.56
	10	36.0		256.0	11.78	6.57
	11	36.0		256.0	11.66	6.54
	12	36.0		256.0	11.73	6.55
	13	36.0		256.0	11.72	6.56
	14	36.0		256.0	11.68	6.53
	15	36.0		256.0	11.65	6.53
	16	36.0		256.0	11.61	6.54
	17	36.0		256.0	11.68	6.56
	18	36.0		256.0	11.74	6.57

Notes:

virtual duration μs	Measured waveshape	virtual total duration μs
2010		2540

continued

ВЯРНО С
ОРИГИНАЛА

471

Long-duration current impulse withstand test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: September 13, 2011

Sample No.	Requested Current	Charging voltage	Oscillogram No.	Current waveshape	Discharge current	Residual voltage
	kA	kV	No.	μ s	kA	kV
1LD-2LD-3LD	1 ₀	28,0	7	8,5/17,6	10,10	15,60

Notes:

472

ВЯРНО С
ОРИГИНАЛА

Long duration current impulse withstand test.

(check the integrity of the internal parts with an additional shot at ambient temperature)

Test circuit: A0017

Date: September 13, 2011


Sample	Impulse	Charging voltage V_c	Oscillogram	Peak current	Residual voltage	Energy
No.	No.	kV	No.	A	kV	kJ
1LD-2LD-3LD	19	36,0	8	257	11,62	6,52

Notes:

Measured waveshape	
virtual duration	virtual total duration
μ s	μ s
2010	2540



Circuit A0019



Power frequency supply

- RE - programmable supply type PACIFIC A.C. Power Source 140 ASX; CESI no. 0560408
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI No.31120; R= 941,4 Ω
- Electro optical system CESI No.11517/518
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 0562226 (on channel No.1)

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 0562226 (on channel No.2)


Software system:

- SW - S.A.D. Surge arrester version 1.0

ВЯРНО С
ОРИГИНАЛА

8/11
CESI

Circuit A0017



Impulse generator

- C₁ ... C₄ - capacitors 0,83 μF
- L₁ ... L₃ - inductors 7 mH
- L₂, L₄ - inductor 14 mH

S : - spark gap

A surge arrester section has been added

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/11522

- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1051/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 0562226 (on channel No.2)


Current measuring system

- Sh - Current shunt CESI No.6039; R= 20 mΩ
- Electro optical system CESI No11517/11518

- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1051/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 0562226 (on channel No.1)


Software system:

- SW - S.A.J.D. Surge arrester version 1.0





CESI B1027449 Oscillogram n. 1


[Handwritten signature]



ВЕРНО С
ОРИГИНАЛА



CESI B1027449 Oscillogram n. 2




[Handwritten signature]

CESI B1027449 Oscillogram n. 3


ВАРНО С
ОРИГИНАЛА

[Handwritten signature]

[Handwritten signature]
 130 *[Handwritten signature]*



CESI B1027449 Oscillogram n. 4





ВЯРНО С
ОРИГИЛА


CESI B1027449 Oscillogram n. 5

[Handwritten signatures and scribbles]

182
[Handwritten signature]






CESI B1027449 Oscillogram n. 6



CESI B1027449 Oscilogram n. 7

[Handwritten signature]





CESI B1027449 Oscillogram n. 8

Test Report

Approved

Client TRIDELTA PARAFONDRES S.A.

Address of the Client Boulevard de l'Adour - BP 256 - 65202 Bagnères de Bigorre Cedex (France)

Manufacturer TRIDELTA PARAFONDRES S.A.

Tested samples/items Disconnector type S3D2 for metal oxide surge arrester

Tests carried out Operating duty test

Standards/Specifications IEC 60099-4 - Edition 2.2 (2009-05)

Tests date from September 12, 2011 to September 14, 2011

The results reported in this document relate only to the tested articles/items.
 Partial reproduction of this document is permitted only with the written permission from CESI.
 Any reference to the Accreditation body shall include name, registration number and scope.



Testing laboratory accredited ISO/IEC 17025:2005 in the fields of:
 High-Voltage Equipment and their Components
 Transformers and their Components
 Low-Voltage Switching Devices and Switchgears
 Electromagnetic Compatibility (EMC)

No. of pages	24	No. of pages annexed	15
Issue date	September 14, 2011		
Prepared	PPR - Gregori Marco <small>PROF. ING. 0221251</small>		
Verified	PPR - Vidotti Mauro, TPI - Sironi Alberto <small>PROF. ING. 0221251</small>		
Approved	P.M. - The Manager - Arcidiaco Lorenzo <small>PROF. ING. 0221251</small>		

CESI S.p.A.
 Testing & Certification Division
 "Milan Platform"
 Manager

Lorenzo Arcidiaco

PUBBLICATO B1027448 (PAD - 1636813)

A100010 rev.6

ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]

[Handwritten signature]

138
[Handwritten initials]

Registro Imprese di Milano
 Sezione Ordinaria
 Inscrittura numero
 P.I. IT07935580150

Capelleccolo 6 550 000 Euro
 Registro Imprese
 Inscrittura numero
 P.I. IT07935580150

Via B. Reuchlin 54
 20134 Milano - Italia
 Telefono +39 0221251
 Fax +39 022125140
 info@cesispa.it

Tests witnessed by:

Mr. Frédéric Malpice
Mr A. Athanasas

TRIDELTA Parafoutres S.A.
PUBLIC POWER CORPORATION

Identification of the object:

Not requested

Test evaluation

With reference to the Standards/Specifications listed in the first page and the characteristics of the tested sample assigned by manufacturer, the carried out tests passed SUCCESSFULLY.

The data necessary to permit repetition of the tests are contained in the document marked: ---

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$ time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$ time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$ time parameters: $\pm 3,5\%$
- dielectric tests with direct voltage : voltage: $\pm 3\%$ time parameters: $\pm 3,5\%$
- partial discharge measurement : up to 10 pC: ± 1 pC above 10 pC: $\pm 10\%$
- atmospheric conditions : temperature: $\pm 2\text{ }^\circ\text{C}$ pressure: $\pm 0,133\text{ kPa}$ humidity: $\pm 10\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory information

Receipt date of the sample : September 12, 2011

Test location : CESI - Via Rubattino 54 - Milan

CESI testing team : Mr. L. Podavite

Test laboratory : P177

Activity code : AE11PM018




content	page	test date
Test object characteristics	4	
Pictures of the test object	from 5 to 6	
Reference standard	7	
Test carried out	7	
Test object identification	7	
Test procedure	8	
Visual inspection and summary of test result	9	
High current operating duty test	from page 10 to 16	September 12 to 14, 2011
Technical data	from page 17 to 24	

ВЯРНО С
ОРИГИНАЛА

Pages annexed:

Oscillograms n. 15 pages



Test object characteristics

type: Disconnector type S3D2 for metal oxide surge arrester

The table below lists the electrical characteristics (assigned by the client) of the surge arresters for which the disconnectors are designed

electrical characteristics (assigned by the client)

Manufacturer's name	TRIDELTA PARAFODRES S.A.
Nominal discharge current - I_n [kA]	10
Rated voltage - U_r [kV]	1,035 x Uref
Continuous operating voltage - U_c [kV]	0,880 x Uref
Reference current - I_{ref} [mA]	1,0
Line discharge class	1
Standard rated frequency - [Hz]	50/60
year of manufacture	2011



**ВЯРНО С
ОРИГИНАЛА**

489

Pictures of the sample




Photo no. 1




Photo no. 2

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]
[Circular stamp]

[Handwritten signature]




Photo no. 3




Photo no. 4



491

ВЯРНО С
ОРИГИНАЛА

Test Report

Approved



Reference Standard

IEC 60099-4 (2009/05) – Edition 2.2 – Clause 8.6.2
“Metal-oxide surge arresters without gaps for a.c. systems”


Test carried out Operating duty test	Number of samples tested 3
---	-------------------------------

Test object identification

Test object name Disconnector type S3D2 for metal oxide surge arrester	Identification of test sample (given by CESI) 10D-20D-30D
---	---



ВЕРНО С
ОРИГИНАЛА



Test procedure

The test has been performed on three disconnectors connected in series. A suitable surge arrester section was supplied by the Client. It was used, as part of the circuit in this frame, connected in series with the test samples, to get proper impulse current waves and power frequency current flowing through the disconnectors.

The test procedure consisted of the following sequence:

- a) Measurement of the power frequency reference voltage at the reference current
- b) Measurement of the lightning impulse residual voltage at the nominal discharge current
- c) Calculation of the voltage correction factors according to the reference standard
- d) Conditioning 1: application of twenty impulses $8/20 \mu\text{s}$ at the nominal discharge current superimposed to the power frequency voltage at 1,2 times U_c in four groups of five impulses
 - interval between impulses of the same group: 50-60 seconds
 - interval between groups: 30 minutes
 - polarity of the impulses: same as that of the half cycle of power frequency voltage during which it occurred (positive)
 - synchronization of the impulses: 60 electrical degrees before the peak of the power frequency.
- e) Conditioning 2: application of one high current impulse $4/10 \mu\text{s}$ at 100 kA
- f) Heating in an oven at the temperature of $60 \text{ }^\circ\text{C}$ till thermal equilibrium
- g) Application of a second high current impulse $4/10 \mu\text{s}$ at 100 kA. A time shorter than 100 ms after the application of the second high current shot energization at U_1 for 10 sec. and then at U_2 for 30 min. to verify the thermal stability.
- b) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value with two impulses at 30 sec to 60 sec. time interval in between

The disconnectors did not operate.

The acceptance criteria are fulfilled. The test result is positive.



493

ВЯРНО С
ОРИГИНАЛА

Visual inspection after the test

The disconnectors withstood the full procedure without operation and without showing any visible damage.

ВЯРНО С
ОРИГИНАЛА

Operating duty test.

Reference voltage test

Test circuit: A0019

Date: September 12, 2011

Sample No. 10D-20D-30D						
Oscillogram No.	voltage kV	current + mA _{cr}	current - mA _{cr}	current mA _{max}	power W	3rd harmonic amplitude μ A
1	6.05	0.98	1.01	0.56	1.71	--



495

Operating duty test.

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: September 12, 2011

Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current kA	Residual Voltage kV
10D-20D-30D	I_r	28,0	2	8,5/17,6	10,04	15,57

Notes:

ВЯРНО С
ОРГИНАЛА

Operating duty test.

Voltage correction factor and energy calculations

Date: September 13, 2011

Sample	U _{ref} [1] kV	KU _f [2]	KU _c [3]	U _f [4] kV	U _c [5] kV	U _* [6] kV
10D-20D-30D	6,05	1,035	0,880	6,262	5,324	6,389

- [1] U_{ref} : measured reference voltage
- [2] KU_f : factor claimed by the manufacturer for calculation of U_f
- [3] KU_c : factor claimed by the manufacturer for calculation of U_c
- [4] U_f : corrected rated voltage [4] = [1] × [2]
- [5] U_c : corrected continuous operating voltage [5] = [1] × [3]
- [6] U_{*} : corrected voltage to be applied during the conditioning [6] = 1.2 × [5]

ВЕРНО С
ОРИГИНАЛА

497

Operating duty test.

Conditioning

Test circuit: A0015

Date: September 13, 2011

Imp. No.	Osc. No.	Sample No. 10D-20D-30D charging voltage kV	Sample No. 10D-20D-30D peak current kA	Note:
1	4	36.6	10.0	
2		36.6	10.0	
3		36.6	10.0	
4		36.6	10.0	
5	5	36.6	10.0	
6		36.6	10.0	
7		36.6	10.0	
8		36.6	10.0	
9		36.6	10.0	
10	6	36.6	10.0	
11		36.6	10.0	
12		36.6	10.0	
13		36.6	10.0	
14		36.6	10.0	
15		36.6	10.0	
16		36.6	10.0	
17		36.6	10.0	
18		36.6	10.0	
19		36.6	10.0	
20	7	36.6	10.0	

Power frequency voltage applied to the test disconnectors	Sample No. 10D-20D-30D 6,389
---	---------------------------------

Notes:

ВЕРНО С
ОРИГИНАЛА



Operating duty test.

Conditioning: Application of two 100 kA 4/10 μ s high current impulses (second part)

Test circuit: A0121

Date: September 13, 2011

Sample	Impulse	Charging	Oscillogram	Discharge	Current	Opposite polarity
No.	No.	voltage	No.	current	waveshape	
		kV		kA	μ s	%
10D-20D-30D	1	83.1 \times 2	8	100.3	4.5/9.9	5.0

Notes:



ВЕРНО С
ОРИГИНАЛА

Test Report

Operating duty test.

Application of the high current impulse, corrected rated voltage U_r and corrected continuous operating U_c for evaluation of the thermal stability.

Test circuit: A0123-A0020-A0131

Sample No.: 10D-20D-30D

Ambient temperature 18 °C

Preheating temperature: 61 °C

Date: September 14, 2011

Second high current impulse application


Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Current waveshape μ s
9	83,0x2	---	96,0	4,5/9,9

Corrected rated voltage U_r application

Oscillogram No.	Time s	Voltage kV	Current + mA _{gr}	Current - mA _{gr}	Power W
10	0	6,262	21,0	32,1	---
11	10		11,5	16,0	---

Corrected continuous operating voltage U_c application to evaluate the thermal stability

Oscillogram No.	Time min	Voltage kV	Current + mA _{gr}	Current - mA _{gr}	Power W
12	0		1,66	2,20	3,39
	5		0,83	0,81	1,30
	10		0,80	0,77	1,10
13	15	5,324	0,78	0,77	0,96
	20		0,77	0,75	0,87
	25		0,76	0,74	0,80
14	30		0,76	0,73	0,74



Operating duty test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: September 14, 2011


Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current kA	Residual voltage kV
10D-20D-30D	I_n	28.0	15	8,5/17,6	10,18	15,74
		28.0	16		10,16	15,73

Notes:



ВЕРНО С
КОПИЯ ОРИГИНАЛА

Circuit A0019



Power frequency supply

- RE - programmable supply type PACIFIC A.C. Power Sourcec 140 ASX.; CESI no. 0560408
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI No.3.1120; R= 941,4 Ω
- Electro optical system CESI No.1.1517/518
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NL-PXI 8108/NL-PXI 5122; CESI No 056227- 0562226 (on channel No.1)

Voltage measuring system

- D - Voltage divider SAGI; CESI No.1.1120
- Electro optical system CESI No.1.1521/522
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NL-PXI 8108/NL-PXI 5122; CESI No 056227- 0562226 (on channel No.2)


Software system:

- SW - S.A.D. Surge arrester version 1.0


[Handwritten signature]

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА



Circuit A0120



Impulse generator

- No. of stages 1
- Cg 4,98 μF
- Lc 10 μH
- S - Spark-gap

Voltage measuring system.


- D - Voltage divider SAGi; CESI No.13027
- Electro optical system CESI No.11521/522;
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 0562226 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 mΩ; peak current= 250 kA
- Electro optical system CESI No.11517/518;
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 0562226 (on channel No.1)

Software system:


- SW - S.A.D. Surge arrester version 1.0



ВЯРНО С
ОРИГИНАЛА

503

Test Report



Impulse generator

- No. of stages 1
- Cg 1,66 μ F
- Lc 120 μ H
- S - Spark-gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No 11521/522
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.2)

Current measuring system


- Sh - Current shunt CESI No.6037, R= 20 m Ω ; peak current= 250 kA
- Electro optical system CESI No 11517/519
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122; CESI No 056227- 0562226 (on channel No.1)

Software system:


- SW - S.A.D. Surges arrester version 1.0

ВЯРНО С
ОРИГИНАЛА

534



Circuit A0015



Impulse generator

No. of stages: 1

Cz - Capacitor 4,98 μF

L - Inductance of the circuit

Lc - Inductor 10 μH

S - Spark gap

One resistor block has been added

Power frequency supply

RE - Regulator type specialtransfo; power 20 kVA; voltage 380 V/ 220 V

T - Transformer Type Pvi; power 30 kVA; voltage 220 V/ 15 kV

B - Blocking gap

Current measuring system

Sh - Current shunt CESI No.6037; R= 20 mΩ; peak current= 250 kA

OSC - Electro optical system CESI No 11517/519

OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122/ NI-PXI 5152; CESI No 056227- 0562226 (on channel No.1)

Voltage measuring system.


D - Voltage divider SAGI; CESI No.11120

OSC - Electro optical system CESI No 11521/522

OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122/ NI-PXI 5152; CESI No 056227- 0562226 (on channel No.2)

Software system:


SW - S.A.D. Surge arrester version 1.0



ВЯРНО С
ОРИГИНАЛА

Test Report

Circuit A0121



Impulse generator

No. of stages 2
 Cg 3,32 μF

S - Spark-gap

Three blocks in series have been added

Voltage measuring system.

- D - Voltage divider SAGI, CESI No.11120
- Electro optical system CESI No.11517/518
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 056222/6 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No. 6042; R= 2 mΩ; peak current= 250 mA
- Electro optical system CESI No.11521/522
- OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122;
- CESI No 056227- 056222/6 (on channel No.1)

Software system:


SW - S.A.D. Surge arrester version 1.0

ВЯРНО С
ОРИГИНАЛА

506



Circuit A0123



Impulse generator circuit

No. of stages 2

Cg 3.32 μF

S - spark-gap




ВЕРНО С
ОРИГИНАЛА

507

Test Report

Circuit A0020



Impulse generator circuit A0123

I - Circuit-breaker

Impulsive current measuring system

Sh1 - Current shunt CESI No.6042; R=2 mΩ

OSC1 - Electro optical system CESI No.11517/518

OSC1 - Oscilloscope type TEKTRONIX IDS 540A; CESI No.13217 (on channel No.1)

Power frequency current circuit A0130

Voltage measuring system.

D - Voltage divider SAGI; CESI No.11120

OSC - Electro optical system CESI No.8009/8015

OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122;

OSC - CESI No 056227-0562226 (on channel No.2)

Power frequency current measuring system

Sh2 (MCOV) - Current shunt CESI R= 1000 Ω - Electro optical system CESI No.11519/11520

OSC - Oscilloscope type NATIONAL INSTRUMENT NI PXI-1031/NI-PXI 8108/NI-PXI 5122;

OSC - CESI No 056227-0562226 (on channel No.1)

Software system:


SW - S.A.D. Surge arrester version 1.0

Handwritten signature at the top of the page.

508

The bottom of the page features a large official stamp with the text "СЕРТИФИКАТ" and "ОПТИКА". A handwritten signature is written over the stamp. The number "508" is written to the left of the stamp.

Circuit A0131



Power-frequency circuit


from 380Vac power supply

R₁ single-phase voltage regulator CORMES; power 20 kVA; voltage 380/0/4220 Vac

R₂ single-phase voltage regulator CORMES; power 10 kVA; voltage 380/0/4220 Vac

T₁ voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200-400 V/15-50 kV







Handwritten signature

CESI B1027448 Oscillogram n. 1

Handwritten signature
Handwritten signature
 510



ВЯРНО С
 ОРИГИНАЛА
 CESI B1027448 Oscillogram n. 5





Handwritten signature

CE51B1027448 Oscillogram, m. G


**ВЯРНО С
ОРИГИНАЛА**

Handwritten signature






ВЯРНО С
 ОП/СЕСІВ 1027448 Oscillogram n. 7



515




[Handwritten signature]

CE51 B1027448 Oscillogram n. 8

ВЯРНО С
ОРИГИНАЛА




516



ВЯРНО С
ОРИГИНАЛА

CESI B1027448 Oscillogram n. 9






Handwritten signature

CESI B1027448 Oscillogram n. 10

ОПШНО С
ОПРЕДЕЛНАТА



018

Handwritten signature




ОРИГИНАЛ

CESI B1027448 Oscillogram n. 11



Handwritten signature




OPRYPHO CA
VILIANA

CESI B1027448 Oscillogram n. 12



Handwritten signature

3:0






ВЯРНО С
ОРИГИНАЛА




CESI B1027448 Oscillogram n. 13




Handwritten signature

CESI B1027448 Oscillogram n. 14


ВАРНО С
КОПИЈАТА






**ВЯРНО С
ОРИГИНАЛА**

CESI B1027448 Oscillogram n. 15






[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА

CESI B1027448 Oscillogram n. 16

[Handwritten signature]

524



3

3

Test Report

Approved

Client Tridelta Parafoudres S.A.
Address of the Client Boulevard de l'Adour
65202 Bagnères de Bigorre Cedex - France
Manufacturer Tridelta Parafoudres S.A.
Tested samples/items Disconnectors for polymer housed metal-oxide surge arresters
Tests carried out Disconnector operation test

PUBBLICATO B1027905 (PAD - 1539/88)

Standards/Specifications IEC 60099-4 - Edition 2.2 (2009-05) at clause 8.6.3

Tests date from September 13, 2011 to September 13, 2011

The results reported in this document relate only to the tested sample/items.
Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 16 **No. of pages annexed** 35

Issue date September 13, 2011


Prepared PPR - Assolari Mauro

Verified PPR - Viclori Mauro, TPI - Sironi Alberto

Approved PMI - The Manager - Arcidiaco Lorenzo

CESI S.p.A.
Testing & Certification Division
Testing Operations Area
"Milan Platform"
Milano

ВЕРНО С
ОРИГИНАЛА



CESI
S.p.A. - Elettronica
Sperimentale Italiana
Giulio Motta spa
Via B. Rubellato 54
20134 Milano - Italia
Telefono +39 022125.1
Fax +39 0221253446
http://www.cesi.it

Regolatore Imprese di Milano
Sezione Orizzonti
Strumento formato
Codice fiscale e numero
P.I. 110078350750
Iscrizione CCIAA 07/86360150

Tests witnessed by
Mr. Malpiece
Mr. Athanasas

Tridelta, Parafoudres S.A.
Public Power Corporation S.A.

Identification of the object

not requested

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: ---


The measurement uncertainties of the main test results reported in this document comply with the following limits:

- voltage: $\pm 5,0$ % (budgetary estimation)
- current: $\pm 3,5$ % (document A9027618)
- time: $\pm 1,4$ % (document A9030312)

The measurement uncertainties are estimated at the level of twice the standard deviation corresponding, in the case of normal distribution, to a confidence level of about 95 %.

Laboratory information


Receipt date of the sample	September, 2011
Test location	CESI - Via Rubattino 54 - Milano
CESI testing team	S. Neri C. Signorini A. Carboni
Test laboratory	P102 / MP1
Activity code	AE11FMI018



526


ВЯРНО С
ОРИГИНАЛА

Contents	Page	Test date
rated characteristics of the equipment under test declared by the Client	4	September 13, 2011
disconnecter operation test	5 to 8	
arrangement and test modalities	5	
single-phase current tests	6	
diagram of time versus curve	7	
test circuit M0015	8	
photos of the equipment under test	9 to 13	
laboratory information	14 to 16	
pages annexed		
oscillograms (no. of pages: 33)		



ВЕРНО С
ОРИГИНАЛА

СТ
: : :



Test Report

Disconnecter operation test

Arrangements and test modalities

The disconnectors were tested alone, without the surge arrester.

The applied prospective voltage was about 4850 V.

The equipment was hang up to a copper support placed in horizontal position as shown in the photos no.1 and no.2.


Five samples of disconnectors were tested for each of the three current values stated by the Standard that are 800 A, 200 A and 20 A.

Test result

For all the samples tested a correct operation occurred with a permanent and effective disconnection.


The test result is positive.

ВЯРНО С
ОРИГИНАЛА



529

Time current versus curve



Handwritten signature


Handwritten scribbles

531



Handwritten signature

Test circuit M0015



The symbols used in this diagram are the same as those on the oscillograms.






Photo no. 1





Photo no. 2

A large, stylized handwritten signature in black ink, located in the upper right quadrant of the page. The signature is fluid and appears to be a personal name or initials.

A large, bold handwritten signature in black ink, located in the bottom right area of the page. It is very expressive and covers a significant portion of the lower right section.

A smaller handwritten signature in black ink, positioned above the circular stamp in the bottom right area.



ВЯРНО С
ОРИГИНАЛА

533

ВЕРНО С
ОРИГИНАЛА

534




Photo no. 3
sample new




Photo no. 4
sample new




Photo no. 5
sample new before the test




Photo no. 6
sample no.800A 1 DO after the test






Photo no. 7
sample no.200A.1 DO after the test




Photo no. 8
sample no.200A.1 DO after the test

ВЕРНО С
ОРИГИНАЛА

536




Photo no. 9
sample no.20A.1 DO after the test




Photo no. 10
sample no.20A.1 DO after the test

037



Laboratory information

Date: September 13, 2011

Characteristics of supply circuit

Tests		Supply	OTE MV		OTE LV	
from	to		K	position	K	position
T1	15	23 kV Lambrate	4,667	-	-	-

Characteristics of measuring system

Measure	ref.	Transducer	National Instrument		Krenz channel No.
			SCXI No.	PXI No.	
I	G2		1	1	
U	N1 - N2		2	2	
V	A1 - A3		3	3	

Symbols assigned in "ref." column refer to the measuring equipment listed in page "Laboratory P102 - MP1. Measuring system characteristics."

Other measuring equipment:
Ohmmeter CESI number:



Laboratory P102 - MPI
Measuring system characteristics

Ref.	Type	CESI No.
A1	Voltage transformer TV2 - R-S	9032
A2	Voltage transformer TV2 - S-T	9033
A3	Resistive dividers for TV2	14142
B1	Resistive divider K= 206,5	11465
B2	Resistive divider K= 206,5	11466
B3	Resistive divider K= 206,5	11467
B4	Resistive divider K= 206,5	11468
C1	Current transformer TA2 - R	17060
C2	Current transformer TA2 - S	17061
C3	Current transformer TA2 - T	17059
C4	Resistive burden for TA2	5562
D1	Current transformer 4000 A / 5 A	14466
D2	Resistive burden for TA3	17072
E1	Shunt 40 $\mu\Omega$ - 100 kA - R	8231
E2	Shunt 40 $\mu\Omega$ - 100 kA - S	8232
E3	Shunt 40 $\mu\Omega$ - 100 kA - T	8230
F1	Shunt 1,33 m Ω - 5 kA - R	7965
F2	Shunt 1,33 m Ω - 5 kA - S	7966
F3	Shunt 1,33 m Ω - 5 kA - T	7968
G1	Shunt 1,6 m Ω - 5 kA - additional	7964
G2	Shunt 1,6 m Ω - 5 kA - additional	7963
G3	Shunt 1,6 m Ω - 5 kA - additional	7967
H1	Shunt 80 $\mu\Omega$ - 100 kA	5524
H2	Shunt 80 $\mu\Omega$ - 100 kA	5525
H3	Shunt 80 $\mu\Omega$ - 100 kA	5526
J1	Electro-optical link for thermocouple T	13372
J2	Electro-optical link for thermocouple T	14556
J3	Electro-optical link for thermocouple J	17074
J4	Electro-optical link for thermocouple J	17076
J5	Electro-optical link for thermocouple J	17078
J6	Electro-optical link for thermocouple K	22463
J7	Electro-optical link for thermocouple K	22465
J8	Electro-optical link for thermocouple K	22467
J9	Electro-optical link for thermocouple K	22469

Ref.	Type	CESI No.
K1	Shunt 160 $\mu\Omega$ - 30 kA	5559
K2	Shunt 160 $\mu\Omega$ - 30 kA	5560
K3	Shunt 160 $\mu\Omega$ - 30 kA	5561
L1	Shunt 111 m Ω	9754
L2	Shunt 111 m Ω	9758
L3	Shunt 111 m Ω	9759
=	KRENZ TRC1	13119
=	KRENZ TRC2	13120
M1	Voltage transformer 24 kV / 100 V	3387
N1	Divider RC 30 kV	14677
N2	Divider RC 30 kV	14678
N3	Divider RC 30 kV	14679
N4	Divider RC 30 kV	11990
N5	Divider RC 30 kV	11991
N6	Divider RC 30 kV	11992
P1	Sekering bridge	696
P2	Resistive box	8451
R1	Micro-ohmmeter MOM600A	14204
S1	Micro-ohmmeter OMZ1	14643
T1	Megger METRISO	13139
U1	Thermocouples calibrator CALUS 5	23138
V1	Digital multimeter FLUKE 8060A	17519
Z1	Temperature probe FLUKE 80T-150U	3831
Z2	Shunt 150A/80mV	3477
Z3	Digital multimeter FLUKE 8060A	9893

Measuring software: SAD - P102 Software release: 4.2 - 31/12/2002 Hardware: VAX 4200 with VMS 5.4

Prepared by: C. Del Giorgio

Date: 11/03/2010



Ip.I= 2,113 kA
I.I= 808,6 A
Dc.I= 102,6 ms
Vb.V= 4,879 kV
F.I= 50,03 Hz
Cf.I= 0,05

V4KV

U5KV

11,05 kA



511


ОРИГИНАЛА

0,0 10,0 20,0 30,0 40,0 50,0 60,0 70,0 80,0 90,0 100,0 110,0 120,0 130,0 140,0 150,0 160,0 170,0 180,0 190,0 200,0
2 [ms/div.]

Samt: 600MS, Osc: INT-BD1F, Cal: TAR1F

CESI P102 B11027905, Oscill. No. 0005

Ip.I= 1,179 kA
I.I= 754,2 A
Dc.I= 98,81 ms
I2t.I= 55,49 kA2s
Vb.V= 4,859 kV
Da.I= 90,92 ms
E.I= 53 kJ
P.I= 1,796 MW
F.I= 49,95 Hz



0,0 10,0 20,0 30,0 40,0 50,0 60,0 70,0 80,0 90,0 100,0 110,0 120,0 130,0 140,0 150,0 160,0 170,0 180,0 190,0 200,0
2 [ms/div.]

CESI P102 B1/027905, Oscill. No. 0008

Samt: 800MS, Osc: INT-BD1F, Cal: INT1F



512

U 1 kV


I 1 kA

Ip.I= 1,179 kA
 I.I= 754,2 A
 Dc.I= 98,81 ms
 I2t.I= 55,49 kA2s
 Vb.V= 4,859 kV
 Da.I= 90,92 ms
 E.I= 53 kJ
 P.I= 1,796 MW
 F.I= 49,95 Hz
 dt= 8,306 ms



[Handwritten signature]

[Handwritten signature]




50,0 52,5 55,0 57,5 60,0 62,5 65,0 67,5 70,0 72,5 75,0 77,5 80,0 82,5 85,0 87,5 90,0 92,5 95,0 97,5 100,0
 0,5 [ms/div.]


Sam: 600MS, Osc: INT-BDIF, Cal: INTIF

GESI P102 B1/027905, Oscill. No. 0008

Ip.I= 1,184 kA
 I.I= 773,3 A
 Dc.I= 99,07 ms
 I2t.I= 57,49 kA2s
 Vb.V= 4,854 kV
 Da.I= 92,77 ms
 E.I= 41,06 kJ
 P.I= 1,382 MW
 F.I= 49,98 Hz



Sam: 500MS, Osc: INT-BDIF, Cal: INT1F



514


U1KV

I1KA

0,0 10,0 20,0 30,0 40,0 50,0 60,0 70,0 80,0 90,0 100,0 110,0 120,0 130,0 140,0 150,0 160,0 170,0 180,0 190,0 200,0
 CESI P102 B1/027905, Oscill. No. 0010 2 [ms/div.]

Ip.I= 1,184 kA
 I.I= 773,3 A
 Dc.I= 99,07 ms
 I2t.I= 57,49 kA2s
 Vb.V= 4,854 kV
 Da.I= 92,77 ms
 E.I= 41,06 kJ
 P.I= 1,382 MW
 F.I= 49,98 Hz
 dT= 7,825 ms

[Handwritten signature]



Sam: 600MS, Osc: INT-BDIF, Cal: INTIF


ВЯРНО С
ОРИГИНАЛА



CEESI P102 B1/027905, Oscill. No. 0010

315

Ip.I= 1,187 kA
I.I= 757,6 A
Dc.I= 98,61 ms
I2t.I= 54,63 kA2s
Vb.V= 4,867 kV
Da.I= 91,44 ms
E.I= 58,78 kJ
P.I= 1,814 MW
F.I= 49,98 Hz



0,0 10,0 20,0 30,0 40,0 50,0 60,0 70,0 80,0 90,0 100,0 110,0 120,0 130,0 140,0 150,0 160,0 170,0 180,0 190,0 200,0
2 [ms/div.]

Sam: 600MS, Osc: INT-BD1F, Cal: INT1F

ВЯРНО С
ОРИГИНАЛА
V44

U1KV

I1KA

CESI P102 B1/027905, Oscill. No. 0011

Ip.I= 1,187 kA
 I.I= 757,6 A
 Dc.I= 98,61 ms
 I2t.I= 54,63 kA2s
 Vb.V= 4,867 kV
 Da.I= 91,44 ms
 E.I= 58,78 kJ
 P.I= 1,814 MW
 F.I= 49,98 Hz
 dt= 7,669 ms



V 4 kV

U 0,50 kV

11 kA

517



CESI P102 B1/027905, Oscill. No. 0011


50,0 52,5 55,0 57,5 60,0 62,5 65,0 67,5 70,0 72,5 75,0 77,5 80,0 82,5 85,0 87,5 90,0 92,5 95,0 97,5 100,0

0,5 [ms/div.]

Samt: 900MS, Osc: INT-BD1F, Cal: INT1F

Handwritten signature

Ip.I= 1,169 kA
 I.I= 751,5 A
 Dc.I= 98,6 ms
 I2t.I= 54,62 kA2s
 Vb.V= 4,874 kV
 Da.I= 90,16 ms
 E.I= 55,24 kJ
 P.I= 1,769 MW
 F.I= 49,95 Hz




U1 kV

I1 kA

0,0 10,0 20,0 30,0 40,0 50,0 60,0 70,0 80,0 90,0 100,0 110,0 120,0 130,0 140,0 150,0 160,0 170,0 180,0 190,0 200,0
 2 [ms/div.]

CESI P102 B1/027905, Oscill. No. 0012


Samt: 600MS, Osc: INT-BDIF, Cal: INTIF



518

Ip.I= 1,169 kA
 I.I= 751,5 A
 Dc.I= 98,6 ms
 I2t.I= 54,62 kA2s
 Vb.V= 4,874 kV
 Da.I= 90,16 ms
 E.I= 55,24 kJ
 P.I= 1,769 MW
 F.I= 49,95 Hz
 dT= 8,681 ms

[Handwritten signature]




Sam: 600MS, Osc: INT-BD1F, Cal: INT1F

11KV
 ВЕРНО С
 КОПИИ
 ОРИГИНАЛА
 519
[Handwritten signature]

50,0 52,5 55,0 57,5 60,0 62,5 65,0 67,5 70,0 72,5 75,0 77,5 80,0 82,5 85,0 87,5 90,0 92,5 95,0 97,5 100,0
 0,5 [ms/div.]
CESI P102 B1/027905, Oscill. No. 0012

Ip.I= 1,155 KA
 I.I= 772,3 A
 Dc.I= 98,98 ms
 I2t.I= 56,97 KA2s
 Vb.V= 4,861 KV
 Da.I= 92,32 ms
 E.I= 43,36 KJ
 P.I= 1,582 MW
 F.I= 49,97 Hz



0,0 10,0 20,0 30,0 40,0 50,0 60,0 70,0 80,0 90,0 100,0 110,0 120,0 130,0 140,0 150,0 160,0 170,0 180,0 190,0 200,0
 2 [ms/div]

Sam: 600MS, Osc: INT-BD1F, Cal: INT1F


CESI P102 B1/027905, Oscill. No. 0013



530

$I_p.I = 1,155 \text{ kA}$
 $I.I = 772,3 \text{ A}$
 $Dc.I = 98,98 \text{ ms}$
 $I2t.I = 56,97 \text{ kA}^2\text{s}$
 $Vb.V = 4,861 \text{ kV}$
 $Da.I = 92,32 \text{ ms}$
 $E.I = 43,36 \text{ kJ}$
 $P.I = 1,582 \text{ MW}$
 $F.I = 49,97 \text{ Hz}$
 $dT = 7,031 \text{ ms}$

Handwritten signature



Sam: 600MS, Osc: INT-BD1F, Cal: INT1F


0,5 [ms/div.]

50,0 52,5 55,0 57,5 60,0 62,5 65,0 67,5 70,0 72,5 75,0 77,5 80,0 82,5 85,0 87,5 90,0 92,5 95,0 97,5 100,0

531
 U 0.50 KV
 V 4 KV
Handwritten signature
 ВЪРНО С
 ОПРИНАЛА
 СЪЛ

CESI P102 B1/027905, Oscill. No. 0013

$I_p.I = 535,7 \text{ A}$
 $I.I = 204,7 \text{ A}$
 $Dc.I = 102 \text{ ms}$
 $Vb.V = 4,819 \text{ kV}$
 $F.I = 50,02 \text{ Hz}$
 $Cf.I = 0,05$



0,0 10,0 20,0 30,0 40,0 50,0 60,0 70,0 80,0 90,0 100,0 110,0 120,0 130,0 140,0 150,0 160,0 170,0 180,0 190,0 200,0
2 [ms/div.]
Samt: 600MS, Osc: INT-BD1F, Cal: TARIF

ВЕРНО С
ОРИГИНАЛА
V4KV

552


U 5KV

I 200 A

CESI P102 B1/027905, Oscill. No. 0016

Ip.I= 294,7 A
 I.I= 189 A
 Dc.I= 198,5 ms
 I2t.I= 7,017 kA2s
 Vb.V= 4,81 kV
 Da.I= 171 ms
 E.I= 32,65 kJ
 P.I= 498,1 kW
 F.I= 50,02 Hz

Handwritten signature



Samt: 600MS, Osc: NT-BD1F, Cat: NT1F


ВЪРНО С
 ОРИГИНАЛА *
 *

Handwritten signature

CESI P102 B1/027905, Oscill. No. 0017

553

Ip.I= 294,7 A
 I.I= 189 A
 Dc.I= 198,5 ms
 I2t.I= 7,017 kA2s
 Vb.V= 4,81 kV
 Da.I= 171 ms
 E.I= 32,65 kJ
 P.I= 498,1 kW
 F.I= 50,02 Hz
 dT= 27,79 ms



Samt: 800MS, Osc: INT-BD1F, Cal: INT1F


CESI P102 B1/027905, Oscill. No. 0017
 0,5 [ms/div.]

ВЕРНО С
 КОПИЯ
 ОРИГИНАЛА

554

Ip.I= 291,1 A
 I.I= 194 A
 Dc.I= 198,5 ms
 I2L.I= 7,289 kA2s
 Vb.V= 4,82 kV
 Da.I= 186,4 ms
 E.I= 27,45 kJ
 P.I= 493,8 kW
 F.I= 49,98 Hz


Handwritten signature



Sam: 600MS, Osc: INT-BD1F, Cal: INT1F

Handwritten signature


ВЪРНО С
ОРИГИНАЛА



CESI P102 B1/027905, Oscill. No. 0018

533

Ip.I= 291,1 A
 I.I= 194 A
 Dc.I= 198,5 ms
 I2t.I= 7,289 KA2s
 Vb.V= 4,82 KV
 Da.I= 186,4 ms
 E.I= 27,45 KJ
 P.I= 493,8 KW
 F.I= 49,98 Hz
 dT= 26,54 ms



Sam: 600MS, Osc: INT-BD/F, Cat: INT1F

CESI P102 B1/027905, Oscill. No. 0018
 0,5 [ms/div.]

ВЯРНО С
 ОРИГИНАЛА


V44

556

U 0,50 KV

I 200 A

Ip.I= 306,6 A
 I.I= 197,9 A
 Dc.I= 198,3 ms
 I2t.I= 7,328 KA2s
 Vb.V= 4,831 kV
 Da.I= 188,7 ms
 E.I= 29,19 kJ
 P.I= 460,4 kW
 F.I= 49,95 Hz



Sam: 600MS, Osc: INT-BD1F, Cal: INT1F

CEI P102 B1/027905, Oscill. No. 0019


ВЕРНО С
 ОПТИНАЛА
 557 1200A

CGO

[Handwritten signature]

[Handwritten signature]

$I_p, I = 306,6 \text{ A}$
 $I, I = 197,9 \text{ A}$
 $Dc, I = 198,3 \text{ ms}$
 $I2t, I = 7,328 \text{ kA}^2\text{s}$
 $Vb, V = 4,831 \text{ kV}$
 $Da, I = 188,7 \text{ ms}$
 $E, I = 29,19 \text{ kJ}$
 $P, I = 460,4 \text{ kW}$
 $F, I = 49,95 \text{ Hz}$
 $dt = 23,18 \text{ ms}$



ОРГАН
 ВЛАДИ
 V 4 kV
 53


53
 U 0,50 kV

1200 A

CESI P102 B1/027905, Oscill. No. 0019

Sam: 600MS, Osc: INT-8DIF, Cat: INT1F

Ip.I= 302,1 A
I.I= 192 A
Dc.I= 198,7 ms
I2t.I= 7,317 KA2s
Vb.V= 4,823 KV
Da.I= 177,2 ms
E.I= 29,69 KJ
P.I= 482,8 KW
F.I= 49,97 Hz



Sam: 600MS, Osc: INT-BDIF, Cal: INTIF

V4KV

U1KVZ

I200A




ВЯРНО С
ОРИГИНАЛА

CESI P102 B1/027905, Oscill. No. 0020

51 530

Ip.I= 302,1 A
 I.I= 192 A
 Dc.I= 198,7 ms
 I2t.I= 7,317 kA2s
 Vb.V= 4,823 kV
 Da.I= 177,2 ms
 E.I= 29,69 kJ
 P.I= 482,8 kW
 F.I= 49,97 Hz
 dT= 21,62 ms




50,0 55,0 60,0 65,0 70,0 75,0 80,0 85,0 90,0 95,0 100,0 105,0 110,0 115,0 120,0
 0,5 [ms/div.]
 Sam: 600MS, Osc: INT-BDIF, Cal: INT1F

CESI P102 B1/027905, Oscill. No. 0020

ВЕРНО С
 ОРИГИНАЛА
 560

Ip.I= 307,9 A
I.I= 196,9 A
Dc.I= 198,3 ms
I2t.I= 7,329 kA2s
Vb.V= 4,821 kV
Da.I= 174,6 ms
E.I= 27,54 kJ
P.I= 523 kW
F.I= 49,94 Hz


Handwritten signature



Samr: 600MS, Osc: INT-BD1F, Cal: INT1F


581

ВЕРНО С
ОРИГИНАЛА



CESI P102 B1/027905, Oscill. No. 0021

Ip.I= 307,9 A
I.I= 196,9 A
Dc.I= 198,3 ms
I2t.I= 7,329 kA2s
Vb.V= 4,821 kV
Da.I= 174,6 ms
E.I= 27,54 kJ
P.I= 523 kW
F.I= 49,94 Hz
dT= 24,53 ms



Samt: 600MS, Osc: INT-BD1F, Cal: INT1F


562
ВЕРНО С
ОРИГИНАЛА
V4 kV

CESI P102 B1/027905, Oscill. No. 0021

U 0,50 kV

I 200 A


Ip.I= 53,67 A
I.I= 20,32 A
Dc.I= 98,92 ms
Vb.V= 4,88 kV
F.I= 49,95 Hz
Cf.I= 0,04



Sam: 600MS, Osc: INT-BDIF, Cal: TAR1F

553
ВЕРНО С
ОРИГИНАЛА
СЧ
CESI-B102 B1/027905, Oscill. No. 0023

Ip.I= 28,7 A
 I.I= 20,16 A
 Dc.I= 625,3 ms
 I2t.I= 220,6 A2s
 Ua.U= 4,872 kV
 Vb.V= 4,865 kV
 Da.I= 625,3 ms
 E.I= 4,885 kJ
 P.I= 56,7 kW
 F.I= 49,95 Hz



0,0 50,0 100,0 150,0 200,0 250,0 300,0 350,0 400,0 450,0 500,0 550,0 600,0 650,0 700,0 750,0 800,0
 10 [ms/div.]
 Sam: 2S, Osc: INT-BD1F, Cal: INT1F

CESI P102 B1/027905, Oscill. No. 0024


564
 ВЕРНО С
 ОРИГИНАЛА
 V4KV

U 2 kV

I 20 A

$I_p.I = 28,7 \text{ A}$
 $I.I = 20,16 \text{ A}$
 $Dc.I = 625,3 \text{ ms}$
 $I2t.I = 220,6 \text{ A2s}$
 $Ua.U = 4,872 \text{ kV}$
 $Vb.V = 4,865 \text{ kV}$
 $Da.I = 625,3 \text{ ms}$
 $E.I = 4,885 \text{ kJ}$
 $P.I = 56,7 \text{ kW}$
 $F.I = 49,95 \text{ Hz}$
 $dT = 423 \text{ ms}$

[Handwritten signature]




Sam: 2S, Osc: INT-BDIF, Cal: INTIF

CESI P402 B1/027905, Oscill. No. 0024

ВЕРНО С
 ОРИГИНАЛА
[Handwritten signature]

565

Ip.I= 28,72 A
 I.I= 20,16 A
 Dc.I= 265,1 ms
 I2t.I= 86,13 A2s
 Ua.U= 4,834 kV
 Vb.V= 4,864 kV
 Da.I= 255,1 ms
 E.I= 3,036 kJ
 P.I= 55,78 kW
 F.I= 50,03 Hz



0,0 20,0 40,0 60,0 80,0 100,0 120,0 140,0 160,0 180,0 200,0 220,0 240,0 260,0 280,0 300,0 320,0 340,0 360,0 380,0 400,0
 B1/027905, Oscill. No. 0025
 2,5 [ms/div.]

Sam: 2S, Osc: INT-BDIF, Cal: INTIF

586
 ВЯРНО С
 ОРИГИНАЛА
 V4KV


U 2 kV

I 20 A

CESI P102

Ip.I= 28,72 A
 I.I= 20,16 A
 DC.I= 265,1 ms
 I2L.I= 86,13 A2s
 Ua.U= 4,834 KV
 Vb.V= 4,864 KV
 Da.I= 255,1 ms
 E.I= 3,036 kJ
 P.I= 55,78 KW
 F.I= 50,03 Hz
 dT= 124,2 ms

Handwritten signature



150,0 155,0 160,0 165,0 170,0 175,0 180,0 185,0 190,0 195,0 200,0 205,0 210,0 215,0 220,0 225,0 230,0 235,0 240,0 245,0 250,0
 1 [ms/div.]


Sam: 2S, Osc: INT-BD1F, Cal: INT1F

Handwritten signature

ВЪРНО С
 ОРИГИНАЛА
 587


CESI P102 B1/027905, Oscill. No. 0025

Ip.I= 29,02 A
 I.I= 20,09 A
 Dc.I= 492,9 ms
 I2t.I= 167,5 A2s
 Ua.U= 4,842 kV
 Vb.V= 4,837 kV
 Da.I= 492,9 ms
 E.I= 4,228 kJ
 P.I= 56,23 kW
 F.I= 50 Hz



CESI P102 B1/027905, Oscill. No. 0026


Samt: 2S, Osc: INT-BDIF, Cat: INT-IF



566

Ip.I= 29,02 A
 I.I= 20,09 A
 Dc.I= 492,9 ms
 I2L.I= 167,5 A2s
 Ua.U= 4,842 kV
 Vb.V= 4,837 kV
 Da.I= 492,9 ms
 E.I= 4,228 kJ
 P.I= 56,23 kW
 F.I= 50 Hz
 dT= 319,6 ms

Handwritten signature




Samt: 2S, Osc: INT-BD1F, Cal: INT1F

CESI P102 B1/027905, Oscill. No. 0026



00569

Ip.I= 28,5 A
 I.I= 20,03 A
 Dc.I= 476,2 ms
 I2t.I= 167 A2s
 Ua.U= 4,831 kV
 Vb.V= 4,837 kV
 Da.I= 476,2 ms
 E.I= 3,616 kJ
 P.I= 57,16 kW
 F.I= 50,03 Hz



U 2 kV

I 20 A

CESI P102 B1/027905, Oscill. No. 0027
 Samr. 2S, Osc. INT-BDIF, Cal: INT:F

ВЕРНО С
 ОРИГИНАЛА

Ip.I= 28,5 A
 I.I= 20,03 A
 Dc.I= 476,2 ms
 I2t.I= 167 A2s
 Ua.U= 4,831 kV
 Vb.V= 4,837 kV
 Da.I= 476,2 ms
 E.I= 3,616 kJ
 P.I= 57,16 kW
 F.I= 50,03 Hz
 dT= 327,1 ms

Handwritten signature

V 4 kV

U 0,50 kV

Handwritten signature


120
 ВЯРНО С
 ОРИГИНАЛА
 120

57

350,0 355,0 360,0 365,0 370,0 375,0 380,0 385,0 390,0 395,0 400,0 405,0 410,0 415,0 420,0 425,0 430,0 435,0 440,0 445,0 450,0
 1 [ms/div.]

CESI P102 B1/027905, Oscill. No. 0027
 Sam: 2S, Osc: INT-BD1F, Cal: INT1F

Ip.I= 28,99 A
 I.I= 20,11 A
 Dc.I= 492,1 ms
 I2t.I= 169,1 A2s
 Ua.U= 4,857 kV
 Vb.V= 4,84 kV
 Da.I= 491,8 ms
 E.I= 4,137 kJ
 P.I= 57,17 kW
 F.I= 49,93 Hz




ВЯРНО
 ОРИГИНАЛ
 V.A.K.V
 572

CESI P102 B1/027905, Oscill. No. 0028

Samt: 2S, Osec: INT-8D1F, Cal: INT1F

Ip.I= 28,99 A
 I.I= 20,11 A
 Dc.I= 492,1 ms
 I2L.I= 169,1 A2s
 Ua.U= 4,857 kV
 Vb.V= 4,84 kV
 Da.I= 491,8 ms
 E.I= 4,137 kJ
 P.I= 57,17 kW
 F.I= 49,93 Hz
 dT= 314,2 ms

Handwritten signature



350,0 355,0 360,0 365,0 370,0 375,0 380,0 385,0 390,0 395,0 400,0 405,0 410,0 415,0 420,0 425,0 430,0 435,0 440,0 445,0 450,0
 Sam: 2S, Osc: INT-BD1F, Cal: INT1F

Handwritten signature


ВЯРНО С
 ОРИГИНАЛА
 120A *
Handwritten signature

CESI P102 B1/027905, Oscill. No. 0028

373


6

6

[Handwritten signature]


CESI

[Handwritten signature]
[Handwritten signature]
[Handwritten signature]



Client ARVEA Parafoudres S.A.
Bagneres de Bigorre - FRANCE

Tested equipment Polymer-housed metal-oxide surge arresters


Tests carried out Short-circuit tests

Standards/Specifications IEC 60099-4 (2006-07)

Test date from May 20, 2008 to May 21, 2008

The results reported in this document relate only to the tested equipment.
Partial reproduction of this document is permitted only with the written permission from CESI

PUBBLICATO A8018577 (PAD - 1073222)



No. of pages	18	No. of pages annexed	7
Issue date	June 25, 2008		
Prepared	Unit LABORATORIES - P. Beccarini	CESI S.p.A. Energy Division Technical Area Components Testing Laboratories	
Verified	Unit LABORATORIES - D. Ronchi		
Approved	Unit LABORATORIES - R. Nicolini		

CESI
Centro Elettrotecnico
di Ricerca e Sviluppo
Giucarro, via del
Giucarro, 10
00144 Roma, Italia
Tel. +39 06 212126.1
Fax +39 06 212126.440
http://www.cesi.it

Capitale sociale € 590 000 Euro
Rappresentante legale
N. R.E.A. 429222
P.I. 1100793580150

Registro Imprese di Milano
N. R.E.A. 429222
P.I. 1100793580150



1073222

Tests witnessed by

Mr. F. Malpice
Mr. H. Sauvage

AREVA Parafoudres S.A. - Bagnères de Bigorre - France
AREVA Parafoudres S.A. - Bagnères de Bigorre - France

Identification of the object

Not requested.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: A8014192

The measurement uncertainties of the test results reported in the document are the following:

voltage: $\pm 5\%$; current: $\pm 5\%$; time: $\pm 5\%$; temperature: $\pm 2\text{ }^\circ\text{C}$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.



Receipt date of the sample

May 19, 2008



575

Contents	Page	Test date
<p>Rated characteristics of the tested object assigned by the Client</p>		
<p>Test arrangement</p>	4	May 21, 2008
<p>Tests performed</p>	5	May 21, 2008
<p>High-current short-circuit test with 20,5 kA for 0,214 s</p>	6	May 20, 2008
<p>High-current short-circuit test with 12,2 kA for 0,204 s</p>	7	May 20, 2008
<p>High-current short-circuit test with 6,50 kA for 0,204 s</p>	8	May 20, 2008
<p>Low-current short-circuit test with 630 A for 1,00 s</p>	9	May 20, 2008
<p>Test circuit</p>	10	
<p>Photos</p>	11 to 18	
<p>Pages annexed</p>		
<p>Oscillograms (No.7)</p>		

A8018577

CESI

Test Report

ВЯРНО С
ОРИГИНАЛА


577

Rated characteristics of the tested object assigned by the Client

Polymer-housed metal-oxide surge arrester	
Manufacturer	AREVA Parafoudres S. A.
Type	HE / HE-S
Drawing	
Rated voltage (Ur)	24 kV
Maximum continuous operating voltage (Uc)	20 kV
Rated frequency	50-60 Hz
Normal discharge current (8/20 μ s impulse shape)	10 kA
Line discharge class	1
Rated short circuit current	
High current	for 0,2 s ; 20,0 kA
Low current	for 1,0 s ; 0,60 kA



D8046 - Test arrangement



- A : 1,00 m
- B : 0,40 m
- C : 1,80 m
- D : 1,00 m

- 1 : Surge arrester
- 2 : Flexible conductor
- 3 : Rigid conductor
- 4 : Base
- 5 : Surrounding fence
- 6 : Insulating wood platform

The arrester to be tested was installed on a base at 1,40 m to ground in the middle of an enclosure of 1,80 m in side. The enclosure was positioned on the insulating wood platform. The live side of the supply was connected to the upper end of the arrester while the return circuit, earthed, was connected to the lower end. The live conductor was directed to the opposite direction as the earth conductor

[Handwritten signature]



[Large handwritten signature]

ВЯРНО С
ОРИГИНАЛА

High-current short-circuit test with 20,5 kA for 0,214 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
-	-	kA	kA
-	-	-	-

Test arrangements: See D8046

A photo detector was used to determine the venting time.
 In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.
 The short-circuit current of the auxiliary low power source has been set at about 20 A.
 The voltage applied to the arrester was increased in order to get a current equal to 100 mA (0-peak) and kept at this value or slightly adjusted till arrester failure.
 The pre-failure process duration was 2 minutes and 45 seconds.
 The short-circuit test was performed 4 minutes and 01 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new.

Date: May 21, 2008

Test No.	Oscillogram		Arrester under test No.	Duration s	Test voltage kV	Test current		Time to flame extinction after the test s	Venting time ms	Notes
	No.	Sheets				Peak value kA	rms value kA			
1	30	1	4	0,214	18,0	48,6	20,5	14	1,0	No.
										-

Condition of the apparatus after the tests: see photos No.1 and 2

- There was not violent shattering.
- The arrester structure was damaged by the test.
- The arrester remained connected to the supply and return circuit.
- No fragment were found inside or outside the enclosure.

Acceptance criteria: Fulfilled.

Test result: Positive.

High-current short-circuit test with 12,2 kA for 0,204 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
27	1	kA 12,2	kA 33,8

Test arrangement : See D8046

A photo detector was used to determine the venting time
 In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.
 The short-circuit current of the auxiliary low power source has been set at about 20 A.
 The voltage applied to the arrester was increased in order to get a current equal to 100 mA (0-peak) and kept at this value or slightly adjusted till arrester failure.
 The pre-failure process duration was 2 minutes and 40 seconds
 The short-circuit test was performed 3 minutes and 50 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new.


Date: May 21, 2008

Test No.	Oscillogram No.	Arrester under test No.	Duration s	Test voltage kV	Test current		Time to flame extinction after the test s	Venting time ms	Notes
					Peak value kA	rms value kA			
2	28	3	0,204	18,0	31,0	12,2	-	1,0	

Condition of the apparatus after the tests: see photos No.3 and 4

- There was not violent shattering.
- The arrester structure was damaged by the test.
- The arrester remained connected to the supply and return circuit.
- No fragment were found inside or outside the enclosure.


Acceptance criteria: **Fulfilled.**
 Test result: **Positive.**



A8018577

High-current short-circuit test with 6,50 kA for 0,204 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz



Test arrangement - See D8046

A photo detector was used to determine the venting time.
 In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.
 The short-circuit current of the auxiliary low power source has been set at about 20 A.
 The voltage applied to the arrester was increased in order to get a current equal to 100 mA (0-peak) and kept at this value or slightly adjusted till arrester failure.
 The pre-failure process duration was 3 minutes and 0 seconds.
 The short-circuit test was performed 4 minutes and 10 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new.

Date: May 20, 2008

Test No.	Oscillogram		Arrester under test No.	Duration s	Test voltage kV	Test current		Time to flame extinction after the test s	Venting time ms	Notes
	No.	Sheets				Peak value kA	rms value kA			
3	26	1	2	0,204	18,0	16,0	6,50	-	2,0	No. -

Condition of the apparatus after the tests: see photos No.5 and 6

- There was not violent shattering.
- The arrester structure remained (almost) intact.
- The arrester remained connected to the supply and return circuit.
- No fragment were found inside or outside the enclosure.

Acceptance criteria: Fulfilled.
 Test result: Positive.

Oscillogram No.	Prospective test current		Peak value kA
	Sheets	rms value kA	
25	1	6,60	18,1

Low-current short-circuit test with 630 A for 1,00 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
22	1	A 630	A 1590

Test arrangement : See D8046

A photo detector was used to determine the venting time.
 In order to achieve the internal discharge the surge arrester has been electrically pre-failed by means of a power frequency over-voltage application using an auxiliary low power source.
 The short-circuit current of the auxiliary low power source has been set at about 20 A.
 The voltage applied to the arrester was increased in order to get a current equal to 100 mA (0-peak) and kept at this value or slightly adjusted till arrester failure.
 The pre-failure process duration was 3 minutes and 05 seconds.
 The short-circuit test was performed 3 minutes and 15 sec after the completion of the pre-failure process.

Condition of the apparatus before the tests: new.


Date: May 26, 2008

Test No.	Oscillogram No.	Arrester under test No.	Duration s	Test voltage kV	Peak value A	Test current rms value A	Time to flame extinction after the test s	Venting time ms	Notes
4	24	1	1,00	23,0	1190	630	105	8,0	No. -

Condition of the apparatus after the tests: see photos No.7 and 8


- There was no violent shattering.
- The arrester structure was damaged by the test.
- The arrester remained connected to the supply and return circuit.
- No fragments were found inside or outside the enclosure.

Acceptance criteria: Fulfilled.
 Test result: Positive.





Test circuit D0046



Symbols used in this diagram are the same as those on the oscillograms.

CESI

Test Report




Photo No.1

ВЯРНО С
ОРИГИНАЛА

535




Photo No.2

ВЯРНО С
ОРИГИНАЛА

CESI

Test Report




Photo No.3

[Handwritten signature]



[Handwritten signature]



[Handwritten signature]

[Handwritten signature]

537



538




Photo No.4

CESI

Test Report





Photo No.5

[Handwritten signature]



[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА

539




Photo No.6



530

CESI

Test Report

Handwritten signature




Photo No.7

Large handwritten signature

**ВЯРНО С
ОРИГИНАЛА**

531




Photo No.8



D10931G

ВЯРНО С
ОРИГИНАЛА

592

I = 637 A
Ip = 1,59 kA
dT = 104 ms

Handwritten signature



U 5 KV

I 600 A

500

VENT 8 V


**ВЯРНО С
ОРИГИНАЛА**

261 265 270 275 280 285 290 295 300 305 310 315 320 325 330 335 340 345 350 355 360 365 370 375 380 385 390 395 400 405
1 [ms/div.]

Sam: 2SEC, Osc: BD3F, Cal: BD3F

CESI P140 A8014192/0022

I = 630 A
Ip = 1,19 kA
dT = 1 s
dT = 8,0 ms





ВЕРИТЕ С
ОРИГИНАЛА

Sam: 28EC, Osc: BD3F, Cat: BD3F

CESI P140 A8014192/0024

I = 6,59 kA
Ip = 18,1 kA
dT = 103 ms

Handwritten signature




276 280 285 290 295 300 305 310 315 320 325 330 335 340 345 350 355 360 365 370 375 380 385 390
1 [ms/div.]

Sam: 2SEC, Osc: BD3F, Cal: BD3F

CESI P140 A8014192/0025

I = 6,5 kA
Ip = 16 kA
dT = 204 ms
dT = 2,0 ms





СЕСИ P140 A8014192/0026

Samt: 2SEC, Osc: BD3F, Cal: BD3F

I = 12,2 kA
Ip = 33,8 kA
dT = 104 ms

Handwritten signature



276 280 285 290 295 300 305 310 315 320 325 330 335 340 345 350 355 360 365 370 375 380 387
1 [ms/div.]

CESI P140 A8014192/0027


Sam: 1SEC, Osc: BD&F, Cal: BD&F

ВЯРНО С
ОРИГИНАЛА



Handwritten signature
112 kA
597

I = 12,2 kA
Ip = 31 kA
dT = 214 ms
dT = 1,02 ms



270 280 290 300 310 320 330 340 350 360 370 380 390 400 410 420 430 440 450 460 470 480 490 500 510
2 [ms/div.]

CESI P140 A8014192/0028

Sam: 1SEC, Osc: BD3F, Cal: BD3F

U 5 kV



СИ
СВ
СВ

I 12 kA

VENT 3 V

I = 20,5 kA
Ip = 48,6 kA
dT = 214 ms
dT = 1,53 ms

Handwritten signature



Sam: 1SEC, Osc: BD3F, Cal: BD3F

CESI P140 A8014192/0030

ВЕРНО С
ОРИГИНАЛА

Handwritten signature

599

VENT 3V

U5KV

I 20 kA

6

6

client ALSTOM Parafoudres S.A. - Bagnères de Bigorre Cedex (France)

equipment under test three 10KA polymer housed surge arresters, type HE

tests performed partial discharges test

normative documents IEC 60099-4 (1991-06)

receipt date of the sample december 15, 2000

test date from december 22, 2000 to december 22, 2000

the test results relate only to the sample tested
this document shall not be reproduced (except in full without the written approval of CESI)
and of the accreditation body, if any

n° 0030

no. of pages 10 no. of pages annexed 2

issue date december 22, 2000

prepared PaC/TEST - C. Dei Giorgio

verified PeC/TEST - A. Sironi

approved PaC/TEST - V. Scartoni

CENTRO ELETTROTECNICO STRUMENTALE ITALIANO

Proloco Compagnoni
Il Responsabile del Laboratorio

CESI
Centro Elettrotecnico
Strumentale Italiano
Giuliano Morici spa

Via R. Rubattino 54
20134 Milano - Italia
Telefono +39 0221251
Fax +39 0221255440
http://www.cesi.it


Capitale sociale 17,1 miliardi
Intervento Verato
CCIAA di Milano n. 425222
Registro delle Imprese
di Milano n. 94057

Sezione Ordinanza
Tribunale Milano
P.I. IT00793580150
C.F. 00793580150

009

ВЯРНО С
ОРИГИНАЛА

1600



tests witnessed by: Mr. F. Malpiece - ALSTOM Parafudre S.A.



Handwritten notes and signatures in the header area, including 'CJH' and other illegible text.

identification of the object: effected
The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.
CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.
This drawing identified by CESI and numbered A0/042527 no.1 is annexed to this document.

The measurement uncertainties of the test results reported in this document are the following:
- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
- dielectric tests with direct voltage : voltage: $\pm 3\%$
The measurement uncertainties, are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

CESI testing team: Mr. M. Amato

test laboratory: P220 (faraday Cage)

activity code: 29380X
keywords: 12015R 23801L 31020W 41040M 53001D 62501B

Handwritten signature



test date	page	contents
december 22, 2000	4	rated characteristics of the test voltage declared by the manufacturer
	5	panoramic view of the test samples
	6	panoramic view of the test arrangement
	7	test voltage values
	8	circuit A027 - partial discharges measurement - high voltage circuit
	9	circuit A022 - partial discharges measurement - direct circuit - scheme 1a
	10	partial discharges test
		pages annexed
		Oscillogram (total pages:2)
		reference document annexed
		drawing no. W 8997 01 36 identified by CESTEST and numbered A0/042527 no.1

MEMO A100223

Large handwritten signature

Handwritten initials

**ВЯРНО С
ОРИГИНАЛА**

602



603


rated characteristics of the test voltage declared by the manufacturer

polymer housed surge arrester


manufacturer	ALSTOM Parafudre S.A.
type	HE
drawing no.	W 8987 01 36
rated voltage (U _r)	36 kV
continuous operating voltage (U _c)	30 kV _{rms}
nominal discharge current (I _n)	10 kA
line discharge class	1
dry lightning impulse withstand voltage	170 kV _{pk}
wet power frequency withstand voltage	70 kV _{rms}

NOTE: CESI marked the three polymer housed surge arresters from no.1 to no.3

panoramic view of the test sample



Handwritten signature



Large handwritten signature

Handwritten signature

ВЯРНО С
ОРИГИНАЛА

604

panoramic view of the test arrangement



ВЯРНО С
ОРИГИНАЛА
655

test voltage values

Partial discharges test

prestressing ($\leq 10s$) = $U_1 = 36,0$ KV

measure = $1,05 \times U_0 = 1,05 \times 30,0 = 31,5$ KV


ВЯРНО С
ОРИГИНАЛА

633



circuit A027

Plant P220. High voltage circuit:
partial discharges measurement




- F : wide band filter TELEC; 380 V; 100 A
- G : Faraday cage
- S : single phase circuit breaker SACE; 600 V; 800 A
- R : regulator CORMES; power 66 kVA; voltage 380 V/0 + 220 V
- T : booster transformer PIV; power 250 kVA; voltage 200-400 V/250 kV
- C_k : coupling capacitor PASSONI & VILLA; 300 pF; 250 kV (interstat to T)
- TA : current transformer CGS; ratio 150-300 A/5 A
- TV₁ : voltage transformer; ratio 220 V/100 V
- V₁ : voltmeter CESI no. 6393
- RS : partial discharge detector BIDDLE; CESI no. 09596



circuit A022

partial discharges measurement

direct circuit
scheme 1a



- C_k : coupling capacitor 300 pF; CESI no.
- Z_m : coupling impedance
- P : calibrator CESI no.02526.
- RS : partial discharge detector BIDDLE; CESI no.09596
- CRO: oscilloscope CESI no.06351.


[Handwritten scribbles]

[Handwritten initials]

ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]
008

[Handwritten signature]



Test Report



AT-A0/042489

p.10

Before the test have been made: measure of the background noise; the result: p.d. $\leq 5\text{mV}$ $\leq 1\text{PC}$ (oscillogram no.2)
Corona's effect (oscillogram no.3)

test	applied	duration of	temperature	of the test object	partial discharge measurement	note
1	30,0 (V)	≤ 10	20,0	--	--	oscillogram
	31,0 (1,05U)	measure	20,0	--	≤ 5	no.
2	30,0 (V)	≤ 10	20,0	--	--	
	31,0 (1,05U)	measure	20,0	--	≤ 5	
3	30,0 (V)	≤ 10	20,0	--	--	
	31,0 (1,05U)	measure	20,0	--	≤ 5	

date: december 22, 2000

atmospheric conditions	
b	h
KPa	$^{\circ}\text{C}$
101,5	20,0 (13,5)
7,3	


test object: polymer housed surge arresters, type HE
test circuit: A027
measurement circuit: A022 ("direct" calibration: 0,2 pC/mV, on CRO, oscillogram no.1)
arrangement: see page 6

MO041720

ВЯРНО С
ОРИГИНАЛА




609



Oscillogram no.1

Channel 1 :
voltage : 100 mV/div


calibration of the measure circuit
 $q = 50\text{pC}$
 $K = 0,2\text{pC/mV}$



Oscillogram no.2

Channel 1 :
voltage : 20 mV/div

measure of the background noise
p.d. $\leq 5\text{mV}$ $\leq 1\text{pC}$



Oscillogram no.3

Channel 1 :
voltage : 100 mV/div

corona effect
negative polarity

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА


610

[Handwritten mark]

[Handwritten mark]

[Handwritten mark]






Oscillogram no.4

Channel 1 :
voltage : 20 mV/div


sample no.1
U = 31kV
p.d. $\leq 5mV \leq 1pC$



Oscillogram no.5

Channel 1 :
voltage : 20 mV/div


sample no.2
U = 31kV
p.d. $\leq 5mV \leq 1pC$



Oscillogram no.6



Channel 1 :
voltage : 20 mV/div

sample no.3
U = 31kV
p.d. $\leq 5mV \leq 1pC$



ВЯРНО С
ОРИГИНАЛА

Handwritten signature



Handwritten signature

Handwritten signature

**ВЯРНО С
ОРИГИНАЛА**

CC

CC

Type Test Report
No.: TR-E 12019BM

Equipment under test: Polymer housed surge arrester of line discharge class 1, type series VARISIL HE-S TRIDELTA Parafoudres S.A.

Normative documents: IEC 60099-4 Edition 2.2 clause 10.8.9 / 8.9

Test performed: Bending moment test

Test date: 19th of October 2012 to 13th of November 2012

Number of pages: 19

Attention: The test results relate only to the sample(s) tested. This document shall not be reproduced without written approval of TRIDELTA Testing facilities.

First issue date: 15th of November 2012

Dipl.-Ing. T. Holzer *T. Holzer* (Test Engineer, Tridelta)

Dipl.-Ing. H. Klaupe *H. Klaupe* (R&D Head, Tridelta)

Dipl.-Ing. S. Schreib *S. Schreib* (Head SCUS GmbH)

Hermisdorf, 15th of November 2012

TRIDELTA - Testmanagement GmbH
Marie-Curie-Str. 5
37820 Hermisdorf - Deutschland
Telefon: +49 (0) 56 519328 300
Fax: +49 (0) 56 519328 301
Internet: <http://www.tridelta.de>

ВЯРНО С
ОРИГИНАЛА



Subject

Test of Bending Moment
Surge Arrestor Series
VARISIL HE-S

Manufacturer

TRIDELTA Paralaouires S.A.
Boulevard de l'Adour - B.P. 256
F - 65202 Bagneux de Bigorre Cedex

Caused by

Type Test acc. to IEC 60099-4 Ed.2.2 Item 10.8.9 (2009-05)
Confirmation of
SSL = 200 Nm
SSL = 250 Nm

Test arrangement/course of test

Test acc. to IEC 60099-4 Ed. 2.2, Item 10.8.9 (2009-05)

The test was performed on 3 arrestors made of 1 mechanical unit. The arrestors were attached directly to the mounting surface of the testing machine. The direction of the load was through and perpendicular to the longitudinal axis of the arrestor unit.

Test procedure:

1. Sample preparation/ initial measurements acc. to 10.8.9.2
2. Bending moment test with SSL acc. to 10.8.9.3 a on 2 arrestor units
3. Mechanical/normal preconditioning acc. to 10.8.9.3.1 on 1 arrestor unit
4. Water immersion test acc. to 10.8.9.3.2 on 3 arrestor units
5. Test evaluation/ Final measurements acc. to 10.8.9.4

Sample	Typo
A	VARISIL HE-S 42
B	VARISIL HE-S 42
C	VARISIL HE-S 42

The surge arrestor type series "VARISIL HE-S" passed all tests, acc. to IEC 60099-4 Ed. 2.2 10.8.9, successfully. SSL = 200 Nm, SSL = 250 Nm; terminal torque = 45 Nm

Coordinated by :
worked out by :
checked by :

S. Schreib, see test report "12-137 PB2_rev1 Product test - VARISIL TM HE-S 42" from SCUS
T. Hölzer
H. Klubo



ВЯРНО С
ОРИГИНАЛА

014

Test results

1. Sample preparation/ Initial measurements

Wait losses at U₀

Sample No.	Voltage kV	wait losses W
A	35	3,53
B	35	3,79
C	35	3,72

Ambient temperature 20 °C


Partial discharge test

Sample No.	voltage kV	measured value pC	max. permitted value pC	ground noise pC	evaluation/ result
A	36,75	< 2	10	< 2	passed
B	36,75	< 2	10	< 2	passed
C	36,75	< 2	10	< 2	passed

Residual voltage test

Sample No.	measured value kV	current kA
A	114,9	10,2
B	114,6	10,2
C	114,6	10,2

ВЯРНО С
ОРИГИНАЛА



Test Report

2. Bonding Moment test with SSL

Sample No.	Caniliver mm	Force N	Bending moment Nm	maximum deflection mm	residual deflection mm
A	397	630	250	4,58	-0,55
B	397	630	250	4,72	0,52

Sample C was subjected to the mechanical/normal preconditioning

The residual deflection was measured in the interval 1 min to 10 min after release of the load. There was no visible damage.

3. Mechanical/normal preconditioning

a. Terminal torque preconditioning

The arrester terminal torque of 45 Nm was applied for duration of 30s.

Caniliver mm	Force N	Torque moment Nm
300	150	45

There was no visible damage.

b. Thermo-mechanical preconditioning

The sample was subjected to the thermo-mechanical preconditioning acc. to 10.8.9.3.1.2 with the specified long-term load (SLL) of 200 Nm.


Caniliver = 397 mm; Force = 504 N

Measured displacement:

	Start without load	Start with load	End with load	maximum deflection	End without load
Position 0° (-60°C)	0 mm	4,07 mm	11,26 mm	11,4 mm	2,57 mm
Position 180° (-25°C)	0 mm	11,89 mm	14,04 mm	14,2 mm	0,82 mm
Position 270° (-40°C)	0 mm	10,07 mm	11,97 mm	12,2 mm	0,26 mm
Position 90° (-40°C)	0 mm	11,19 mm	13,48 mm	13,7 mm	0,48 mm

4. Water immersion test

All samples were subjected to the water immersion test acc. to 10.8.9.3.2



ВЯРНО С
ОРИГИНАЛА

Test Report

TR-E 12019BM

5. Test evaluation/ Final measurements

Watt losses at 20 °C

Sample No.	Voltage kV	watt losses W	Increase from initial measurement %	evaluation/ result
A	35	3,62	-0,3	passed
B	35	3,64	-4	passed
C	35	3,63	-2,4	passed

Ambient temperature 20 °C

The increase in watt losses is not more than 20% from the initial measurements. After the end of boiling, the arresters were removed from the water (50 °C) (09:15 AM, 09.11.2012) and cooled to ambient temperature. The measurement was executed within 8h after cooling (02:30 PM, 09.11.2012).

The ambient temperature does not deviate more than 3K from the initial measurements.

Partial discharge test

Sample No.	voltage kV	measured value pC	max. permitted value pC	ground noise pC	evaluation/ result
A	36,75	<2	10	<2	passed
B	36,75	<2	10	<2	passed
C	36,75	<2	10	<2	passed

Reference voltage before two impulses at nominal discharge current

Sample No.	measured value kV
A	40,7
B	40,6
C	40,7

Residual voltage test (first impulse)

Sample No.	measured value kV	current kA	Increase from initial measurement %	evaluation/ result
A	114,5	10,2	-0,3	passed
B	115,1	10,2	+0,4	passed
C	114,3	10,2	-0,3	passed

The measured values are not more than 5% different from the initial measurement.

Residual voltage test (second impulse)

Sample No.	measured value kV	current kA	Increase from initial measurement %	Increase from first impulse %	evaluation/ result
A	115,2	10,2	+0,3	+0,6	passed
B	115,4	10,2	+0,7	+0,3	passed
C	115,2	10,2	+0,5	+0,8	passed

The measured values are not more than 5% different from the initial measurement. The difference in voltage between two successive impulses at nominal discharge current does not exceed 2%. The oscillograms of voltage and current do not reveal any partial or full breakdown of the test sample.

Reference voltage after two impulses at nominal discharge current

Sample No.	measured value kV	increase %	evaluation/ result
A	41,2	+1,2	passed
B	41,2	+1,5	passed
C	41,3	+1,5	passed

The change in reference voltage measured before and after the two residual voltage tests does not exceed 2%.

The surge arrester type series "VARISIL HE-S" passed all tests, acc. to IEC 60098-4 Ed. 2.2 10.8.9, successfully. SIL = 200 Nm. SSL = 250 Nm and terminal torque = 45 Nm


ВЯРНО С
ОРИГИНАЛА




617

Test Report


Appendix 1 Sample preparation/ Initial measurements




Residual voltage test of sample No.A



Residual voltage test of sample No.B



ВЯРНО С
ОРИГИНАЛА



Handwritten signature


Large handwritten signature

ВЯРНО С
ОРИГИНАЛА




619

Appendix 2 Bending moment test with SSL



Force vs. time and deflection vs. time of sample A





Force vs. time and deflection vs. time of sample B

ВЯРНО С
ОРИГИНАЛА



019

Appendix 3 Thermo-mechanical preconditioning






Handwritten signature

Large handwritten signature


ВЯРНО С
ОРИГИНАЛА

621







ВЯРНО С
ОРИГИНАЛА



022



Appendix 4 Water Immersion test



Handwritten signature

Handwritten signature




ВЯРНО С
ОРИГИНАЛА

323




Test Report


Appendix 5 Test evaluation/ Final measurements



ВАРНО С
ОФИЦИАЛНА



Residual voltage test of sample No. C (first impulse)



Residual voltage test of sample No. A (second impulse)

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА



639






026

ВЯРНО С
ОРИГИНАЛА





HT	Test transformer	PEO 8/100 A/K-2
M1	AC peak voltmeter	MU 14
M2	Partial discharge detector	MTE 3
Osc	Oscilloscope	Philips PM 5208
R _{sh}	Shunt resistor	10000
Z _B	Blocking impedance	40mH
C _C	Coupling capacity	C 06
Z _M	Measuring impedance	H 322
Cal	Calibrator	PET 2-1
TS	Test sample	
PA	Power Analyzer	ZES ZIMMER LMG95

Test circuit for measurement of reference voltage and partial discharges


Handwritten signature

Large handwritten signature

ВЯРНО С
ОРИГИНАЛА

Handwritten signature





GENERAL INFORMATION

Impulse Generator IP 120198M Mz

n	12
C ₀	2000nF
I _m	± 10 mA
W	± 120 M

Number of stages: *

Capacitance per stage

Max. lightning current impulse

Total charging energy


Individual Components:

- Charging resistor R_c (10 kΩ)
- Discharge resistor R_d (1.05 kΩ)
- Print impedance Z₀ (2 μH, 1.5 D)
- Comptel's capacitive LV divider
- 10 mA Shunt
- Digital impulse voltage measuring system

CMC 070200
SMAV 10000
MAS 100-142

Test circuit for residual voltage

Appendix 7 Photos




test arrangement for measuring of partial discharge, reference voltage and power losses




ВЯРНО С
ОРИГИНАЛА

Handwritten signature



climate chamber for bending moment tests and thermo-mechanical preconditioning




test arrangement inside the climate chamber for bending moment test and thermo-mechanical preconditioning


Handwritten signature

ВЯРНО С
ОРИГИНАЛА


629



Handwritten signature



Water immersion test arrangement / boiling tank



Water immersion test arrangement / boiling tank with arrester

ВЯРНО С
ОРИГИНАЛА

Handwritten signature and stamp

630

Handwritten signature

SLL = 200 N.m
 SSL = 250 N.m

Q10	Modulacek	Dobrotivac	Dobnik	Verifikator
VARISIL Type HE-S 42 Polymer-Housed Surge Arrester				
A3 TPF W:8998 00 42 / E				

Large handwritten signature

ВЯРНО С
ОРИГИНАЛА



(

(

(

client ALSTOM Parafoudres S.A. - Bagnères de Bigorre (France)

equipment under test Polymer housed metal-oxide surge arrester type VAFISIL HE 36

tests performed Weather ageing test - Test scifes A

normative documents IEC 60099-4: (2001-12) edition 1.2

receipt date of the sample July 18, 2002

test date from August 07, 2002 to October 18, 2002

the test results relate only to the sample tested
 this document shall not be reproduced except in full without the written approval of CESTI
 and of the accreditation body, if any

no. of pages 23 no. of pages annexed 4

issue date December 18, 2002


prepared PeC/TEST - M. Bonomelli

verified PeC/TEST - A. Sironi

approved PeC/TEST - V. Scaroni

CESTI Centro Elettrotecnico Industriale S.p.A. Via R. Rubattino 54 20134 Milano - Italia
 Tel. 02 760011 Fax 02 7600140 www.cesti.it
 CESTI is a member of the Bureau Veritas Group
 Capitale sociale 8 500 000 Euro Registro Imprese di Milano
 Sostegno Circolare N. R.E.A. 4229225
 P.I. 110079300150

ВЯРНО С
 ОПРИГНАЛА



tests witnessed by: /

identification of the object: The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.
CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.
The drawing identified by CESI and numbered A2/016115 is annexed to this document.

The measurement uncertainties of the test results reported in this document are the following:
- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$
The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

CESI testing team: Mr. M. Bonomelli
Mr. M. Gregori - Mr. L. Podavikta

test laboratory: P177 - surge arrester laboratory
test laboratory: P189 - weather ageing laboratory
activity code: 33618J
keywords: 12015R, 223600, 31020W, 44060J, 53001D, 62370N

ВЯРНО С
ОРИГИНАЛА



033

033

[Handwritten signature]

test date	page	contents
	4	Test object characteristics
	4	Reference standard
	5	Test procedure
	6	Summary of test result
	7	Initial measurement
	10	Visual examination
	11	Final measurement
	11+12	Photos
	13+20	Technical data of the test circuit
07 August 2002	8+9	
28 August + 10 October	10	
11 October 2002	11+12	
	13+20	
	21+23	

Page annexed: oscillogram n. 08
Reference document annexed: ALSTOM drawing W 8997 01 36

Test object characteristics

Reference standard

Test procedure

Summary of test result

Initial measurement


Visual examination

Final measurement

Photos

Technical data of the test circuit

**ВЯРНО С
ОРИГИНАЛА**



119

Test Report

Test object characteristics

type: Metal-oxide surge arrester type HE 36 (sample #1)

electrical characteristics (claimed by the client)


manufacturer's name	ALSTOM Parafousure S.A.
nominal discharge current - I_n [kA]	10,0
rated voltage - U_n [kV]	36
continuous operating voltage - U_c [kV]	30,0
minimum reference voltage - $[U_{ref}]$	34,1
maximum residual voltage - $[U_{res}]$	97,5
rated frequency - [Hz]	50 - 60

geometrical characteristics (measured on the test sample)

total height [mm]	325
number of large sheds	10
number of small sheds	9
shed large diameter [mm]	115
shed small diameter [mm]	85
shed spacing [mm]	30
core diameter [mm]	50
creepage distance [mm]	1200

other characteristics

housing material	polymeric
housing color	grey



**ВЯРНО С
ОРИГИНАЛА**

635

Reference Standard

IEC 60099-4 (2001-12) edition 1.2 Clause 9.7.9

* Metal-oxide surge arrester without gaps for a.c. system*

Test carried out

test carried out	number of samples tested
initial measurements	One sample
weather test device A - 1000 hours	
final measurements and visual inspection	

The sample was identified by the manufacturer as sample #1

A view of the test object is shown at page 14 (aged sample)

ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]



[Handwritten signature]



Test procedure

Initial measurement

- The reference voltage have been measured at reference current equal to 1 mA_{ref}.
- Internal partial discharge have been measured.
- The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec. Then the voltage has been decreased to 1,05 times the continuous operating voltage (U_c) and the partial discharge level has been measured according to the reference standard.

Test series A - 1000 hours

The test specimens have been mounted inside the test chamber in vertical position. The test specimens has been energized at U_{test} = 20.8 kV_{rms} and kept for a total duration of 1000 hours in the test chamber filled with salt fog in the following conditions:

- salinity of the water solution: 10 kg/m³ for the first 445 hours, 5 kg/m³ for the last 555 hours
- water flow rate 0.4 ± 0.1 l/h·m²

The fog was not directly sprayed against the test specimens.

A view of the test configuration is shown on page 13

Final measurement

- The reference voltage have been measured at reference current equal to 1 mA_{ref}.
- Internal partial discharge have been measured.
- The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec. The voltage has been decreased to 1,05 times the continuous operating voltage (U_c) and the partial discharge level has been measured according to the reference standard.
- The test samples have been visually inspected

Nota The test was carried out in parallel with other two specimens with different design

ВЯРНО С
ОРИГИНАЛА

037

Test Report

CESTEST

AT-A2/032924

p.7

Summary of test results

Test series A - 1000 hours

No overcurrent trip out occurred during the test.

Visual inspection

No tracking, ched, puncture or significant erosions have been evidenced by the visual inspection carried out at the end of the test.

Variation of the reference voltage

sample #1	before test	after test	variation %
	kV	kV	
	33.93	34.09	+ 0.47

Acceptance criteria: variation before/after less than 5 %

Partial discharge level

sample #1	before test	after test
	pC	pC
	< 1	< 1

Acceptance criteria: partial discharge level less than 10 pC

All acceptance criteria according to the reference standard are satisfied and therefore the results is to be considered positive.

ВЯРНО С
ОРИГИНАЛА

638



сус

Measurement of the reference voltage - initial

test object: Metal-oxide surge arrester
test circuit: AD19


date: August 07, 2002

oscill. no.	voltage kV	current + mA _{eff}	sample #/1		current mA _{eff}	power W	3rd harmonic amplitude μA
			current - mA _{eff}	power μA			
01	33,93	1,00	1,09	0,58	9,18	181,87	

ВЯРНО С
ОРИГИНАЛА

839

0-1 7-10-2002 10:00:00 AM



Handwritten signature

[Handwritten signature]

137-00

Test Report



AT-A2/032924

p.9

Note: background noise ≤ 1 pC, see oscillogram n. 03

test	applied	duration of voltage application	temperature of the test object	partial discharge measurement	oscillogram	note
sample #1	kV _{max}	sec	°C	CRO readout	PC	
sample #1	28	10		50	04	
sample #1	36			≤ 5		
sample #1	31,5			≤ 1	06	≤ 1
sample #1				≤ 6		
sample #1				≤ 1		

atmospheric conditions		
h	t	p
	°C	kPa
	22	

Measurement of partial discharges - Initial
 test object: Metal-oxide surge arrester
 test circuit circuit: A012
 measurement circuit: A022 ("direct" calibration: 0,2 pC/nV, on CRO, on CRO, see oscillogram n. ...)
 arrangement: —

date: August 07, 2002

ВЯРНО С
ОРИГИНАЛА



[Large handwritten signature]

Test Report

Visual examination

The housing of the specimen has been inspected visually. See photos from page 15 to 20.

No tracking, shed, puncture or significant erosions have been evidenced by the visual inspection carried out at the end of the test.



ВЯРНО С
ОРИГИНАЛА

REDACTED

REDACTED

REDACTED

Measurement of the reference voltage - final

test object: Metal-oxide surge arrester
test circuit: AOT9

date: October 11, 2002

oscill. no.	voltage kV	current		current mA _{avg}	power W	3rd harmonic amplitude μ A
		+ mA ₁	- mA ₂			
02	34,09	0,98	0,89	0,35	6,11	141,89

sample no. #1

ВЯРНО С
ОРИГИНАЛА


312

Handwritten initials/signature

Stamp: СЕРТИФИКАТ
Handwritten signature: chf

Large handwritten signature at the top of the page

Photo n. 1: test configuration




Handwritten signature

ВЯРНО С
ОРИГИНАЛА

Large handwritten signature


03 11



Handwritten mark

Handwritten signature

Photo n. 2 - sample #1 after the test




ВЯРНО С
ОРИГИНАЛА

Handwritten signature
* 1998

МОНАСТЕРИУМ
1998


Photo n. 3 - sample #1 after the test



ВЯРНО С
ОРИГИНАЛА


Handwritten signature

810



Handwritten signature

Photo n. 4 - sample #1 after the test



ВЯРНО С
ОРИГИНАЛА




617

10:00 2003-03-24

01:13 2003-03-24

МОНАХОВ

Photo n. 5 - sample #1 after the test.



ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]

018

[Handwritten signature]

Photo n. 6 - sample #1 after the test.



ВЯРНО С
ОРИГИНАЛА

619

MODA132516


01-1

2003-03-01-AT

7/4



Photo n. 7 - sample #7 after the test




[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА

[Large handwritten signature]

850

[Handwritten initials]




ANDALUSIE

Photo n. 8 - sample #1 after the test



ВЯРНО С
ОРИГИНАЛА

circuit A019



power frequency supply

RE : programmable supply CESI no. 9889 ; type 3H series 3000

PC : personal computer

T : transformer type PIV; voltage 200 V/ 50 kV

current shunt (R) CESI no.11537 ; R = 1084 Ω

oscilloscope CESI no. 4552

type Data Precision DATA 6000

voltage divider (D) CESI no.11120 K = 1010

electro optical system CESI no. 11519/520

oscilloscope CESI no. 4552

type Data Precision DATA 6000

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА


[Large handwritten signature]

002



[Handwritten signature]

circuit A012



power frequency test circuit

- R : regulator type CORMES; power 66 kVA ; voltage 330 V/0 - 0,22 kV
- TA : current transformer CGS; ratio 150-300/5
- I₁ : amperemeter direct reading INDEX
- TV₁ : voltage transformer CGS; ratio 220-440/100
- V₁ : voltmeter direct reading TSE
- R_p : protection resistor — Ω
- T : booster transformer (PVI) power 250 kVA ; voltage 200-400 V/250 kV
- TV₂ : voltage transformer type CGS ; CESI no. 287; ratio 30000/100
- V₂ : voltmeter CESI no. 6394




ВАРНО С
ОРИГИНАЛА

circuit A022

partial discharges measurement

direct circuit
scheme 1a



- C_k : coupling capacitor 0,3 nF
- Z_m : coupling impedance
- P : calibrator no. Cesi 3466
- R_S : partial discharge detector Biddley, no. CESI 9595
- CRO: oscilloscope no. CESI 9353

ВЕРНО С
ОРИГИНАЛОМ

[Handwritten signature]


[Handwritten signature]



[Handwritten signature]

CESI GPS

A 21032924-001





CESI GPS

A 21032924-001

ВЯРНО С
ОРИГИНАЛА



[Handwritten signature]



CESI GPS

A 21032924-002

ВЯРНО С
ОРИГИНАЛА


[Large handwritten signature]

656



CESI

AT-A2/032924




Oscillogram no. 06

Channel 1 :
voltage : 5 mV/div.
time : s

Channel 2 :
voltage : V
time : s

background noise of the circuit
 $C_{max} \leq 1 \text{ pC}$



Oscillogram no. 07

Channel 1 :
voltage : 100 mV/div.
time : s

Channel 2 :
voltage : V
time : s

calibration of the test circuit
 $50 \text{ pC}/250 \text{ mV} \approx 0,2 \text{ pC/mV}$



Oscillogram no. 08

Channel 1 :
voltage : 5 mV/div.
time : s

Channel 2 :
voltage : V
time : s

Sample no. 01 before the test
 $U = 31,5 \text{ kV}$
 $C_{max} \leq 1 \text{ pC}$



ВЯРНО С
ОРИГИНАЛА

037


[Handwritten signature]

Oscillogram no. 03

Channel 1 :
voltage : 5 mV/div.
time : 5

Channel 2 :
voltage : V
time : s

background noise of the circuit
 $Q_{max} \leq 1 pC$




Oscillogram no. 04

Channel 1 :
voltage : 100 mV/div.
time : 5

Channel 2 :
voltage : V
time : s

calibration of the test circuit
 $50 pC/250 mV \approx 0,2 pC/mV$




Oscillogram no. 05

Channel 1 :
voltage : 10 mV/div.
time : 5

Channel 2 :
voltage : V
time : s

Sample no. 01 before the test
 $U \approx 31,5 kV$
 $Q_{max} \leq 1 pC$



ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]



053

[Handwritten signature]

[Circular stamp with text and handwritten signature]

ВЯРНО С
ОРИГИНАЛА

853

<p>upper side of the surge arrester</p> 			
<p>PROTOCOLLO DATA</p> <p>A 21016 115 000 4 27-AUG-2002</p> <p>Firma: <i>Alaince Godeaux</i></p>		<p>CESI</p>	
<p>Accessibilité du plan: <input type="checkbox"/> Libre</p> <p>Confidentialité: <input type="checkbox"/> ALSTOM Perforex SA ne peut être ni reproduire ni communiqué sans autorisation préalable.</p>		<p>Modification: _____ Dessinateur: HS Date: 03/05/02 Vérification: <i>pp</i></p>	
<p>Tolérances générales: _____</p> <p>Matière: _____</p> <p>Traitement: _____</p>		<p>ALSTOM TRANSMISSION & DISTRIBUTION Perforex B.P. 256 65202 Bagnères-de-Bigorre</p>	
<p>VARISIL Type HE 36 Surge Arrester</p>		<p>Folio : 1 / 1 Ind : 02</p>	
<p>A4 APF W 8997 01 36</p>		<p>2002.11.01 RT</p>	

CESI

Messrs.
ALSTOM transmission & distribution
Parafoudres
65202 Bagneres-de-Bigorre
Att. Mr. Frederic Malpicce

Va. nr.
N. nr. PeC-A3/001926
Data 21-01-2002

Subject: Weather ageing test according to IEC standard 60099-4 (2001-12) on one polymer housed surge arrester type HE 24

Dear Sirs,

With reference to your request and awaiting to get ready the test report relevant to the subject, we wish to send you here below a summary of the test carried out and of the relevant results

1. TEST OBJECTS

One polymer housed surge arrester type HE 24 (drawing W 8987 01 24)

The following ratings were assigned by the manufacturer.

- Rated voltage: 24 kV
- Continuous operating voltage: 20 kV
- Nominal discharge current: 10 kA

2. NORMATIVE REFERENCES

IEC 60099-4 (2001-12): "Surge arresters - metal oxide surge arresters without gaps for a.c. systems"

ВЪРНО С
ОРИГИНАЛА

660



Capitale sociale € 650.000 Euro
Sede e Direzione Generale
Incarichi e incaricati
Cedola fiscale e numero
iscrizione CCIAA: 0279380750
P.I. 15076300150

Via S. Ruffino 54
00144 Roma
Telefono +39 0272511
Fax +39 021255540
www.cesit.it

CESI
Centro Elettrotecnico
Giulio Iuliano
Giulio Iuliano SPA

3. TEST PLAN

The test was carried according to IEC 60099-4 at item 9.7.10 test series B. The surge arrester, mounted in vertical position, was energized at a power frequency voltage equal to 13.9 kV for 5000 hours while submitted to the various environmental stresses as specified in figure 9 of the standard. Before and after the test the partial discharges and the reference voltage were measured for comparison.

Note that, according to Alstom request, the test voltage was $24\sqrt{3} = 13.9$ kV while the continuous operating voltage specified for the surge arrester is 20 kV.

4. TEST RESULTS

No overcurrent trip-out occurred during the test.

No tracking, shed puncture, deep erosions or other significant damages were observed at the end of the test.

The partial discharge level measured before and after the test was less than 1 pC. The reference voltage measured before and after the test were respectively 23.16 kV and 22.93 kV with a decreasing of about 1%.

5. CONCLUSION

All the acceptance criteria specified by the standard at item 9.7.10.3 are satisfied and therefore the test result is to be considered positive.

Mod.003M

Am

ВЯРНО С
ОРИГИНАЛА

client: ALSTOM Parafoudres S.A. - Bagnères de Bigorre (France)

equipment under test: Polymer housed metal-oxide surge arrester type VARISIL HE 24

tests performed: Weather ageing test - Test series B

normative documents: IEC 60099-4 (2001-12) edition 1.2

receipt date of the sample: 02 May, 2002
test date: from 15 May, 2002 to 15 December, 2002

this test results relate only to the sample tested.
this document shall not be reproduced except in full without the written approval of CESI.

no. of pages: 23 no. of pages annexed: 4

issue date: 27 March 2003

prepared: PeC/TEST - M. Bononelli

verified: PeC/TEST - A. Sironi

approved: PeC/TEST - V. Scarfoni

M. Bononelli
A. Sironi

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Busseto (VC) - Italia
P.le Repubblica 2/A - Laboratorio

CESI
Centro Elettrotecnico
Sperimentale Italiano
Giuliano Natta SPA

Capitale sociale 8.550.000 Euro
Sede legale: 020722
Via E. Ruffino 54
20134 Milano
Tel. 02 235440
02 235440
www.cesi.it

Registro Imprese di Milano
Sede operativa: 020722
P.I. 02079350150
Codice fiscale a numero
iscrittione CCIAA 00793550160

AW

ВЕРНО С
ОРИГИНАЛА



[Handwritten signature]

Test Report

tests witnessed by:

Identification of the object. The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.
 CESIT checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.
 The drawing identified by CESI and numbered AT/D11332 is annexed to this document.

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with impulse current : peak value: $\pm 3\%$; time parameters: $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3\%$

The measurement uncertainties are assessed at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95%) and have to be considered as maximum values.

laboratory information

CESI testing team: Mr. Bonomelli
 Mr. M. Girard - Mr. L. Podavitte

test laboratory: P177 - surge arrester laboratory
 test laboratory: P129 - weather aging laboratory
 activity code: 3361B1
 keywords: 1201SR, 223800, 3102BW, 44050J, 53001D, 52570H

Man



ВЕРНО С
 ОРИГИНАЛА

Handwritten signature


Page annexed: oscillogram n. 04.
 Reference document annexed: ALSTOM drawing A1/011332 n. 1

- Test object characteristics
- Reference standard
- Test procedure
- Summary of test result
- Initial measurement
- Visual examination
- Final measurement
- Photos

test date	page	contents
20.05.2002+15.12.2002	4	Test object characteristics
03.07.2002	5	Reference standard
08.12.2002	6	Test procedure
	9	Summary of test result
	10+11	Initial measurement
	12	Visual examination
	13+14	Final measurement
	15+23	Photos

Handwritten signature

1 89



Test object characteristics:

type: Metal-oxide surge arrester type VARISIL HE 24

electrical characteristics (claimed by the client):

manufacturer's name	ALLSTON Perofiches S.A.
nominal discharge current - I_n [kA]	10.0
rated voltage - U_n [kV]	24
continuous operating voltage - U_c [kV]	20
rated frequency - [Hz]	50 - 60

geometrical characteristics (measured on the test sample)

total height [mm]	245
number of large sheds	7
number of small sheds	7
shed large diameter [mm]	110
shed small diameter [mm]	60
shed spacing [mm]	30 (large sheds); 25 (small sheds)
wire diameter [mm]	50
creepage distance [mm]	200

other characteristics

insulating material	silicon
insulating color	gray



ВЯРНО С
ОРИГИНАЛА

665

880

Reference Standard:

IEC 60088-4 (2001-12), edition 1.2, at clause 9.7.10
- Metal-oxide surge arrester without gaps for a.c. system

Test carried out

test carried out	number of sample tested
Initial measurements	
weather test series B - 5000 hours	One sample identified as sample #6
Final measurements and visual inspection	

A view of the test object is shown at page 10.

[Handwritten signature]


**ВЯРНО С
ОРИГИНАЛА**

636

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]





Test procedure:

Initial measurement:

- The reference voltage have been measured at reference current equal to 1 mA_{ref}.
- Internal partial discharge have been measured.
- The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec.
- Then the voltage has been decreased to 1.05 times the continuous operating voltage (U_c) and the partial discharge level has been measured according to the reference standard.

Test series A - 5000 hours:

The test specimen has been installed in the test chamber in vertical position.
 The test specimen has been kept energized at the voltage U_{test} = 13.9 kV_{rms} while submitted to the daily multi-stress environmental cycle as specified below.
 The multi-stress environmental cycle was repeated 208 times for a total duration of 5000 hours.
 The main characteristics of the different environmental stresses applied during the test are reported in the following table:

environmental stress	daily duration (h)	total duration (h)	severity
soft top	0	1984	7 μm - 0.4 μm/m ²
humidification	4	832	30% SH
rain	2	416	100 μm - 1.5 mm/min
U.V. radiation	12	2496	50 mW/cm ²
heating	10	2560	50 °C

A scheme of the daily cycle is shown at page 7.

A scheme of the test configuration is shown at page 8.

A view of the test configuration is shown on page 17.

Note: The test was carried out in parallel with other specimens with different design.

Note: According to client request the test voltage was 24kV_{rms} = 13.9 kV while the specified continuous operating voltage is 20 kV

Final measurement:

- The reference voltage have been measured at reference current equal to 1 mA_{ref}.
- Internal partial discharge have been measured.
- The application voltage has been increased up to rated voltage (U_r) and maintained for 10 sec. The voltage has been decreased to 1.05 times the continuous operating voltage (U_c) and the partial discharge level has been measured according to the reference standard.
- The test samples have been visually inspected.

ВАРНО С
ОРИГИНАЛА

Handwritten initials or mark.

[Handwritten signature]

Time [hours]

Time [hours]	0	2	4	6	8	10	12	14	16	18	20	22	24
HUMIDIFICATION													
HEATING - 50 C													
RAIN													
SALT FOG - 7 g/l													
SOLAR SIMULATION													
VOLTAGE													

Fig. 4 - Daily cycle


[Handwritten mark]

[Handwritten signature]

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА

[Handwritten signature]







Fig. 5 - Scheme of the test configuration



ВЯРНО С
ОРИГИНАЛА

Test Report



AT-A3/007530

p.3

Summary of test result:

Test series IS - 5000 hours

No flashover occurred during the test

Visual inspection

No tracking, shed, puncture, erosion or any significant deterioration has been evidenced by the visual inspection carried out at the end of the test.

Variation of the reference voltage

	before test		after test		variation	
	kV		kV		%	
sample #5	23,15		22,99		-1,0	

Acceptance criteria: variation before/after: less than 5 %

Partial discharge level

	before test		after test	
	pC		pC	
sample #5	< 1		< 1	

Acceptance criteria: partial discharge level less than 10 pC

All acceptance criteria according to the reference standard are satisfied and therefore the results is to be considered positive.

ВЕРНО С
ОРИГИНАЛА



Handwritten signature

Handwritten signature


Large handwritten signature at the top of the page

Measurement of the reference voltage - initial

test object: Mena-codlo surpa arrester

date: 03 March, 2003

example 45						
order	voltage	current	current	current	power	3rd harmonic amplitude
no.	V	+ mA	- mA	mA	W	%
1	23,16	1,0	0,99	0,99	3,78	1,78



ВЯРНО С
ОРИГИНАЛА

671

am

Visual examination.

The housing of the specimen has been inspected visually. No tracking, shed puncture, erosion or any significant discoloration has been evidenced by the visual inspection carried out at the end of the test. See photos from page 18 to 23.



ВЯРНО С
ОРИГИНАЛА

673

AM

Test Report

CESI TEST

AT-A3(007630)

p.13

Measurement of the reference voltage - final

test object: Metal-oxide surge arrester

date: 09 December, 2002

date:		voltage		current		current		sample no. 25		power		3rd harmonic amplitude	
no.	KV	mA	mA	mA	mA	mA	mA	mA	mA	VA	VA	VA	VA
2	22.95	0.85	1.04	0.85	1.04	0.85	1.04	0.85	1.04	0.85	1.04	0.85	1.04

BRITISH STANDARD

[Handwritten signature]

[Handwritten signature]



[Handwritten signature]



Deutsche Akkreditierungsstelle GmbH

Anlage zur Akkreditierungsurkunde D-PL-11195-01-00 nach DIN EN ISO/IEC 17025:2005

Gültigkeitsdauer: 16.01.2013 bis 15.01.2018

Urkundeninhaber:

SCUS GmbH Service Center Umweltsimulation
Heidelberger Straße 20, 01189 Dresden

Prüfungen in den Bereichen:

mechanische und klimatische Umweltsimulationsprüfungen an Packstoffen, Packmitteln, Packstücken (Bereich Verpackung) und technischen Produkten, wie Klima-, Schock- und Vibrations- sowie Stoßprüfungen und deren Kombination

verwendete Abkürzungen: siehe letzte Seite

*Innerhalb der mit * gekennzeichneten Prüfbereiche ist dem Laboratorium, ohne dass es einer vorherigen Information und Zustimmung der DAkKS bedarf, die freie Auswahl von genormten oder ihnen gleichzusetzenden Prüfverfahren gestattet.*

Die aufgeführten Prüfverfahren sind beispielhaft. Das Laboratorium verfügt über eine aktuelle Liste aller Prüfverfahren im flexiblen Akkreditierungsbereich

1 Umweltsimulationsprüfungen Bereich Verpackung

DIN EN 13054
2001-05

Verpackung - Versandfertige Packstücke - Prüfung zur Bestimmung des Schwerpunktes eines Packstückes

ВЕРНО С
ОРИГИНАЛА

DIN EN 14149
2003-11


Verpackung - Versandfertige Packstücke und Ladeinheiten - Vertikale Stoßprüfung durch Kippen

DIN EN 22248
1993-02


Verpackung; Versandfertige Packstücke; Vertikale Stoßprüfung (freier Fall)

DIN EN 28768
1993-02

Verpackung; Versandfertige Packstücke; Umsturzprüfung



046




Anlage zur Akkreditierungsurkunde D-PL-11195-01-00

DIN ISO 10531 2000-03	Verpackung - Versandfertige Packstücke - Festigkeitsprüfung von Ladeeinheiten
DIN EN ISO 2234 2002-12	Verpackung - Versandfertige Packstücke und Ladeeinheiten - Stapelprüfung unter statischer Last
DIN EN ISO 2244 2002-12	Verpackung - Versandfertige Packstücke und Ladeeinheiten - Horizontale Stoßprüfung
DIN EN ISO 3037 2007-06	Wellpappe - Bestimmung des Kantenstauchwiderstandes (Verfahren für ungewachste Kanten)
DIN EN ISO 12048 2001-04	Verpackung - Versandfertige Packstücke - Kompressions- und Stapelprüfung unter Verwendung einer Kompressionsprüfmaschine
DIN EN ISO 2247 2002-12	Verpackung - Versandfertige Packstücke und Ladeeinheiten - Schwingprüfung mit niedriger Festfrequenz
DIN EN ISO 8318 2002-12	Verpackung - Versandfertige Packstücke und Ladeeinheiten - Schwingprüfung mit variabler sinusförmiger Frequenz
DIN EN ISO 13355 2003-10	Verpackung - Versandfertige Packstücke und Ladeeinheiten - Schwingprüfung mit vertikaler rauschförmiger Anregung
DIN EN 15552 2008-11	Verpackung - Versandfertige Packstücke und Ladeeinheiten - Prüfpläne für gewöhnliche Transportketten
DIN EN 22206 1993-02	Verpackung - Versandfertige Packstücke - Bezeichnung von Flächen, Kanten und Ecken für die Prüfung
DIN EN ISO 4180 2010-12	Versandfertige Packstücke - Allgemeine Regeln für die Erstellung von Prüfplänen
DIN EN 60721-3-6/A2 1997-07	Klassifizierung von Umweltbedingungen - Teil 3: Klassen von Umwelteinflußgrößen und deren Grenzwerte - Einsatz auf Schiffen
DIN EN ISO 2233 2001-11	Verpackung - Versandfertige Packstücke und Ladeeinheiten - Klimatische Vorbehandlung für die Prüfung
DIN EN ISO 2759 2003-11	Pappe - Bestimmung der Berstfestigkeit (ISO 2759:2001)



**ВЕРНО С
ОРИГИНАЛА**




Anlage zur Akkreditierungsurkunde D-PL-11195-01-00

DIN EN ISO 2873 2002-12	Verpackung - Versandfertige Packstücke und Ladeinheiten – Unterdruckprüfung (ISO 2873:2000)
DIN 53142-1 2004-12	Prüfung von Pappe - Durchstoßprüfung - Teil 1: Prüfung mit dem Pendelschlagwerk
DIN 55440-1 1991-11	Packmittelprüfung - Stauchprüfung - Prüfung mit konstanter Vorschubgeschwindigkeit
DIN EN ISO 527-3 2003-07	Kunststoffe - Bestimmung der Zugeigenschaften - Teil 3: Prüfbedingungen für Folien und Tafeln
DIN EN ISO 1924-2 2009-05	Papier und Pappe - Bestimmung von Eigenschaften bei zug- förmiger Belastung - Teil 2: Verfahren mit konstanter Dehn- geschwindigkeit
ISTA Ressource Book 2012	Guideline Transport
ASTM D 642-00 2010-08	Standard Test Method for Determining Compressive Resistance of Shipping Containers, Components and Unit Loads
ASTM D 4169-09 2009-11	Standard Practice for Performance Testing of Shipping Containers and Systems
ASTM 6653-01 2010-10	Standard Test Methods for Determining the Effects of High Attitude on Packaging Systems by vacuum Method

2 **Umweltsimulationsprüfungen Bereich technische Produkte**

DIN EN 61373 2011-04	Bahnanwendungen - Betriebsmittel von Bahnfahrzeugen - Prüfungen für Schwingen und Schocken
DIN EN 60068-2-1 2008-01	Umgebungseinflüsse - Teil 2-1: Prüfverfahren - Prüfung A: Kälte (IEC 60068-2-1:2007)
DIN EN 60068-2-2 2008-05	Umweltprüfungen - Teil 2-2: Prüfverfahren - Prüfung B: Trockene Wärme (IEC 60068-2-2: 2007)

**ВЕРНО С
ОРИГИНАЛА**



Anlage zur Akkreditierungsurkunde D-PL-11195-01-00

- DIN EN 60068-2-6
2008-10 Umweltprüfungen - Teil 2-6: Prüfverfahren - Prüfung Fc:
Schwingen, sinusförmig (IEC 60068-2-6: 2007)
- DIN EN 60068-2-27
2010-02 Umweltprüfungen - Teil 2-27: Prüfverfahren - Prüfung Ea und
Leitfaden: Schocken (IEC 60068-2-27: 2008)
- DIN EN 60068-2-30
2006-06 Umgebungseinflüsse - Teil 2-30: Prüfverfahren - Prüfung Db:
Feuchte Wärme, zyklisch (12 + 12 Stunden)
(IEC 60068-2-30:2005)
- DIN EN 60068-2-32
1995-03 Umweltprüfungen - Teil 2-32: Prüfverfahren - Prüfung Ed: Frei
Fallen (IEC 60068-2-32:1975 + A1:1982 + A2:1990)
- DIN EN 60068-2-64
2009-04 Umweltprüfungen - Teil 2-64: Prüfverfahren - Prüfung Fh:
Schwingen, Breitbandrauschen (digital geregelt) und Leitfaden
(IEC 60068-2-64: 2008)
- DIN EN 60068-2-78
2010-10 Umweltprüfungen - Teil 2-78: Prüfverfahren - Prüfung Cab:
Feuchte Wärme, konstant (IEC 104/523/CD: 2010)


1 Umweltsimulationsprüfungen Bereich Verpackung *

Prüfart	Messgröße / Prüfparameter	Mess- und Prüfbereich	Kleinste erreichbare Messunsicherheit K=2	Beispielhafte Prüfverfahren
Druckprüfung, Stauchprüfung, Stapelprüfung	Kraft	max. 50 N max. 500 N max. 10 kN max. 50 kN	1 %	DIN 55440-1 DIN EN ISO 12048 ASTM D642-00 ASTM 4169-09
	Stauchweg	0,01 bis 1.800 mm	1 %	
	Dehnung	0,001 bis 1.200 mm	1 %	
Zugprüfung, Zugeigenschaften von Kunststoffen	Kraft	max. 50 N max. 500 N max. 10 kN	1 %	DIN EN ISO 527-3 DIN EN ISO 1924-2

Gültigkeitsdauer: 16.01.2013 bis 15.01.2018

ВЕРНО С
ОРИГИНАЛА

679






Anlage zur Akkreditierungsurkunde D-PL-11195-01-00

Deutsche Akkreditierungsstelle


Prüfart	Messgröße / Prüfparameter	Mess- und Prüfbereich	Kleinste erreichbare Messunsicherheit K=2	Beispielhafte Prüfverfahren
Berstfestigkeit	Druck	4000 kPa	3 %	DIN EN ISO 2759
Durchstoßarbeit	Energie	48 J	2 %	DIN 53142-1
Schwingprüfung, Vibrationsprüfung, Schockprüfung, Prellen	Kraftvektor	Sinus: max. 56 kN Rauschen: max. 56 kN Schock: 166 kN	-	DIN EN ISO 8318 DIN EN ISO 13355 ASTM 4169-09
	Schwingweg-amplitude Spitze-Spitze	max. 63,5 mm	-	
	Schwing-geschwindigkeit	Standard max. 2,0 m/s	-	
	Beschleunigung	max. 1.750 m/s ²	3 %	
	Frequenzbereich	3 Hz bis 3000 Hz	0,1 %	
Klimaprüfung	Temperatur	+5 °C bis +90 °C	0,5 K	ISTA Series
	Relative Luftfeuchte	10 % bis 98 %	2 % r. F.	
Temperatur-prüfung	Temperatur	-60 °C bis +180 °C	0,5 K	ISTA Series
horizontaler Stoß	Geschwindigkeit	0 bis 5 m/s	3,5 %	DIN EN ISO 2244
Fallprüfung	Freifall	0 bis 2000 mm	1 %	DIN EN 22248
Unterdruck-prüfung	Unterdruck	188 bis 1013 mbar	1 %	DIN EN ISO 2873

ВЕРНО С
ОРИГИНАЛА



Gültigkeitsdauer: 16.01.2013 bis 15.01.2018

630




Anlage zur Akkreditierungsurkunde D-PL-11195-01-00

2 Umweltsimulationsprüfungen Bereich technische Produkte*

Prüfungsart	Messgröße / Prüfparameter	Mess- und Prüfbereich	Kleinste erreichbare Messunsicherheit K=2	Charakteristische Prüfverfahren
Schwingprüfung, Vibrationsprüfung, Schockprüfung	Kraftvektor	Sinus: max. 56 kN Rauschen: max. 56 kN Schock: 166 kN	-	DIN EN 60068-2-6 DIN EN 60068-2-27 DIN EN 60068-2-64
	Schwingweg- amplitude Spitze-Spitze	max. 63,5 mm	-	
	Schwing- geschwindigkeit	Standard max. 2,0 m/s	-	
	Beschleunigung	max. 1.750 m/s ²	3 %	
	Frequenzbereich	3 Hz bis 3000 Hz	0,1 %	
Klimaprüfung	Temperatur	+5 °C bis +90 °C	0,5 K	DIN EN 60068-2-30 DIN EN 60068-2-78
	Relative Luftfeuchte	10 % bis 98 %	2 % r. F.	
Temperatur- prüfung	Temperatur	-60 °C bis +180 °C	1 K	DIN EN 60068-2-1 DIN EN 60068-2-2
Fallprüfung	Freifall	10 bis 2000 mm	1 %	DIN EN 60068-2-32

verwendete Abkürzungen:

ASTM	American Society for Testing and Materials
DIN	Deutsches Institut für Normung
EN	Europäische Norm
ISO	International Organization for Standardization
ISTA	International Safe Transit Association
TGL	Technische Güte- und Lieferbedingungen


ВЯРНО С
ОРИГИНАЛА




Gültigkeitsdauer: 16.01.2013 bis 15.01.2018

681


6/6



TRIDELTA Parafoudres S.A.


Вентилни отводи за разпределителни системи

VARISIL™ тип HE



**ОБЩО ТЕХНИЧЕСКО ОПИСАНИЕ
ИНСТРУКЦИЯ ЗА МОНТАЖ, ЕКСПЛОАТАЦИЯ И
ОБСЛУЖВАНЕ. УКАЗАНИЯ ЗА СЪХРАНЕНИЕ НА СКЛАД
СПИСЪК НА ВСИЧКИ ОСНОВНИ СТАНДАРТИ,
ИЗПОЛЗВАНИ ПРИ РАЗРАБОТВАНЕТО И
ИЗПИТВАНЕТО НА ВЕНТИЛНИТЕ ОТВОДИ**







Януари 2010



TRIDELTA Parafoudres S.A.

Съдържание

ПРЕДГОВОР	4
1 ВЕНТИЛНИ ОТВОДИ	5
1.1 Защитни устройства	5
1.2 Въздушни искроразрядници	5
1.3 Силициево-карбидни вентилни отводи с въздушни междини (SiC)	6
1.4 Метало-оксидни вентилни отводи без въздушни междини (MOSA)	7
2 ОБХВАТ НА РАЗПРОСТРАНЕНИЕ ОТ TRIDELTA НА МЕТАЛО-ОКСИДНИ ВЕНТИЛНИ ОТВОДИ В ПОЛИМЕРЕН КОРПУС	10
2.1 Продуктова номенклатура на VARISIL™ тип HE	10
2.2 Дизайн на VARISIL™ тип HE	10
3 ДОПЪЛНИТЕЛНИ ЧАСТИ ЗА ВЕНТИЛНИ ОТВОДИ VARISIL™ тип HE	15
3.1 Прекъсвач или индикатор за повреда	15
3.2 Конзоли и накрайници	16
3.2.1 Конзоли	16
3.2.2 Накрайници	16
4 ПРОЦЕДУРА ЗА ИЗБОР НА ВЕНТИЛЕН ОТВОД VARISIL™ тип HE	17
4.1 Номинален разряден ток	17
4.2 Защитно ниво	17



4.3	Постоянно напрежение фаза-земя на мрежата	18
4.4	Временни условия на свръхнапрежение	18
4.4.1	Способ на заземяване в неутрална точка	18
4.4.2	Долно съпротивление на опората	20




TRIDELTA Parafoudres S.A.

5 ПРЕПОРЪКИ ЗА ИНСТАЛИРАНЕ 23

5.1	Дължина на свързващите проводници	23
5.2	Долно съпротивление на опората	23
5.3	Отстояния	24
5.4	Електрически връзки	25
5.4.1	Свързване към земята	25
5.4.2	Свързване към линията	25
5.4.3	Сили на затягане	25
5.5	Опаковка	25
5.5.1	Обработка и транспорт	26
5.5.2	Съхранение	26
5.5.3	Поддръжка	26

6 СТАНДАРТИ И ТЕСТОВЕ 27

6.1	Еталонен стандарт	27
6.2	Други приложими стандарти	27
6.3	Типови тестове	27
6.4	Тестове за приемане на стандарт	28
6.5	Рутинни тестове	29



684



TRIDELTA Parafoudres S.A.

ВЕНТИЛНИ ОТВОДИ VARISIL™ тип HE

ПРЕДГОВОР

Каквото и да е системното напрежение, електрическите мрежи са подложени на краткотрайни свръхнапрежения, които често повреждат оборудването (силови трансформатори, подземни кабели, ...), поради високото им ниво.

Съществуват два основни типа свръхнапрежения:

- свръхнапрежения от вътрешен произход, т.е. причинени от оперирането или схемата на мрежата (комутационно пренапрежение, резонансни явления, ...);
- свръхнапрежения от външен произход, т.е. генерирани от външни явления, сред които най-важна е мълнията.

Доказано е, че при средноволтажни мрежи (разпределителни мрежи), свръхнапреженията, породени от удари на мълния са най-често срещаните енергийни натоварвания, независимо от това дали са причинени от преки удари (свръхнапрежения, дължащи се на галванична връзка) или в по-малка степен от непреки удари (свръхнапрежения, дължащи се на кондензаторна и/или индукционна връзка).

Тяхното ниво може да достигне няколко стотин киловолта и да надхвърли много изолационната издръжливост на оборудването. Тези свръхнапрежения могат след това да предизвикат искрене или/и пробив на изолацията на оборудването, ако преди това предварително не е било инсталирано подходящо защитно устройство на разрядника.

В случай, че действително възникне подобен проблем, операторите вероятно ще съжаляват, че не са инвестирали във вентилни отводи, чиято цена е много по ниска от тази на повреденото оборудване.



685



TRIDELTA Parafoudres S.A.

1 ВЕНТИЛНИ ОТВОДИ

1.1 Защитни устройства

Съществуват два основни типа защитни устройства за разпределителните мрежи: въздушни искроразрядници и вентилни отводи.

Те обикновено се включват между фазата и земята, така че да се създаде слаба точка в изолацията на системата и така да се осигури защита на оборудването от свръхнапрежение срещу индуктивно или пряко пренапрежение

Искроразрядниците все още широко се използват за защита на въздушно изолирано оборудване или когато не е необходимо ниско изолационно ниво.

Обаче, за да се подобри качеството на обслужването се изискват по-високи характеристики и тогава са необходими вентилните отводи. На разположение са две технологии за вентилните отводи:

- **вентилни отводи SiC** : техният активен комплект е съвкупност от елементарни въздушни междини и нелинейни силициево-карбидни резистори, които са свързани в серии;

- **вентилни отводи MO** : техният активен комплект е изработен само от нелинейни метало-оксидни резистори.

Технологията на MO е възникнала в началото на 70-те години и осигурява по-добри експлоатационни качества от SiC. Поради това вентилните отводи SiC постепенно са били заменени с вентилни отводи MO, чиито последен дизайн с полимерен корпус сега се използва широко по света.

1.2 Въздушни искроразрядници


Въздушният искроразрядник е по-старото, по-простото и по-евтиното устройство за защита от пренапрежение.

Дизайн

Обикновено той се изработва от два електрода: първият се свързва с линейната страна на оборудването, което следва да бъде защитено, а вторият се заземява.

Принцип на действие

Въздушната междина между тези два електрода е слаба точка в изолацията на мрежата. Въздушното разстояние може да бъде настроено, за да се регулира пробивното напрежение до исканата стойност.



Защитно ниво

Защитното ниво на искровия разрядник е максимумът на пробивното напрежение при стандартно 1.2/50 импулсно напрежение при удар от мълния.



TRIDELTA Parafoudres S.A.

Предимства и недостатъци

Въпреки, че искроразрядниците са много евтини, много здрави и могат да бъдат лесно монтирани те притежават редица недостатъци, по-важните от които са:

- при възникване на искров пробив, електрическата дъга не може спонтанно да се загаси и затова трябва да се включи прекъсвачът, за да се елиминира късото съединение;

- искровият пробив води до формиране на вълна със заден фронт, което може да причини повреда на близкото намотъчно устройство;

- пробивното напрежение зависи от климатичните условия (температура, влажност...), а също и от предното нарастване на свръхнапрежението. При стръмен фронт на вълната, в действителност напрежението, приложено към оборудването може да бъде много по-голямо от самото пробивно напрежение (време на реакция), което също би могло да доведе до неочаквана повреда.

1.3 Силициево-карбидни вентилни отводи с междини (SiC)

При вентилните отводи SiC са премахнати някои от недостатъците на въздушните искроразрядници. Принципът бе да се използва нелинейно съпротивление в серии заедно с въздушна междина, за да се предотврати протичането на силен ток по време на работа. Силициевият карбид бе първият материал с висок нелинеен фактор, подходящ за подобно приложение. Нелинейните резистори са изработени от SiC гранули, които са пресовани като дискове с метализирана повърхност за по-добър електрически контакт.


Дизайн

Тъй като силициевият карбид има нелинейни свойства в ограничен обхват спрямо стойностите на плътността на електрическия ток, то едно устройство без междини би се повредило веднага при нормално напрежение фаза-земя. Въздушните междини са задължителни, за да се изолират дисковете при нормални условия.

Поради това, сърцевината на силициево карбидни вентилни отводи е изработена от SiC резистори в серии с няколко елементарни въздушни междинни. Тази сърцевина е поместена в порцеланов корпус, напълнен със сух въздух или азот. Подходяща уплътнителна система предотвратява проникването на влага, тъй като експлоатацията и надеждността са много чувствителни към влажност.

Принцип на действие

При номинално напрежение фаза-земя, въздушните междини изолират вентилния отвод. В случай на свръхнапрежение, надвишаващо пробивното напрежение на междините, токовият импулс преминава през SiC резисторите, чието съпротивление се намалява с увеличаването на тока (нелинейно свойство), което ограничава действителното ниво на свръхнапрежение. След като енергията на пренапрежение бъде абсорбирана, вентилният отвод остава проводим докато приложимото



напрежение достигне нула : съпротивлението на SiC резисторите е достатъчно високо, за да елиминира тока и за да изолира отново вентилния отвод. Благодарение на нелинейното съпротивление на SiC резисторите, силициево-карбидните вентилни отводи могат да ограничат свръхнапреженията, при което се спазват изискванията за непрекъснатост на електроснабдяването.



TRIDELTA Parafoudres S.A.

Защитно ниво

Защитното ниво на силициево-карбидния вентилен отвод се определя като максимална стойност в т.ч.:

- 1,2/50 импулс при удар от мълния максимално пробивно напрежение ;
- максимално пробивно напрежение на фронта на вълната, разделено на 1.15;
- максимално остатъчно напрежение при номинален разряден ток.

Останали недостатъци

Независимо от това, че позволяват да се избегнат повечето от недостатъците на единичните искроразрядници, вентилните отводи SiC все още имат някои недостатъци:

- след като свръхнапрежението бъде ограничено, все още протича ток с промишлена честота (наричан „остатъчен ток”, който може да достигне сто или повече ампера) докато прилаганото напрежение стигне нула, като в най- лошия случай това става в продължение на половин цикъл;
- въпреки, че сериите от въздушни междини са поставени в плътен корпус, пробивното напрежение е чувствително към външното разпределение на напрежението по порцелановия корпус, което се променя под въздействия на околната среда (дъжд, сол, мъгла, ...).

1.4 Метало-оксидни вентилни отводи в цялостен корпус (MOSA)

През 60-те години нелинейните резистори, изработени от метални оксиди са били проектирани за защита на електронно оборудване. Десет години по-късно бяха внедрени МО вентилни отводи, предназначени за средно волтово приложение.


Те се характеризират с две основни предимства:

- много висок нелинеен фактор при разширен обхват на стойностите за плътност на тока;
- много по-висока способност за поглъщане на енергия отколкото при вентилните отводи SiC .

Дизайн

Високата нелинейност при разширен обхват на тока позволява да се премахнат въздушните междини. Резисторите МО са вградени в плътен корпус, който обикновено е от порцеланов тип. Порцелановият корпус трябва да бъде снабден със система за освобождаване на налягане, за да се избегне разрушаване поради вътрешна повреда (например вследствие на много силен удар от мълния).

Наскоро производителите заместиха този традиционен порцеланов корпус с полимерен корпус с подходящи свойства, така че да издържа на климатични въздействия и да осигурява трекинг устойчивост. За да се получи изискваната механична якост на вентилния отвод (която преди това бе постигана от самия порцеланов корпус), понастоящем метало-оксидните резистори се обвиват със смола, усилена чрез фибростъкло.



Производственият процес на МО резисторите (наричани също "MOV блокове") изисква голям опит, за да се постигне очакваното действие и надеждност. По време на производствения процес се изисква особено голямо внимание. Един блок се прави от цинков оксид (90 %) смесен с други метални оксиди (бисмут, кобалт, манган, ...). Формулата (химичният състав) и процесите (особено цикъла на спичане) се контролират внимателно, за да се гарантират високи нива на качество и надеждност.



TRIDELTA Parafoudres S.A.

Принцип на действие

Основното предимство на един МО резистор е високата нелинейна характеристична крива на тока спрямо напрежението (виж кривата на стр. 13).

При номинално напрежение фаза-земля, импедансът на един МО вентилен отвод е много висок, тъй че утечката на тока е много ниска (обикновено по-малко от 0.1 mA). Когато възникне свръхнапрежение, омното съпротивление намалява много бързо, така че ударният ток да протече към земята и нивото на свръхнапрежение се ограничава. Нелинейният фактор е толкова висок, че между 0.1 mA и 10 kA напрежението само се удвоява.

Защитно ниво

Защитното ниво на метало-оксидния вентилен отвод се определя като максимално остатъчно напрежение при номинален разряден ток.

Определяне на параметрите

Изборът на подходящ вентилен отвод (т.е. дефиниране на съответното разчетно напрежение) се основава на съображения, имащи противоположни тенденции:

- да се оптимизира предоставената защита, но колкото по-ниско е защитното ниво, толкова по-ниско е разчетното напрежение;

- да се осигури издържане на прилаганите напрежения, но колкото по-висока е устойчивостта на напрежение, толкова по-високо е разчетното напрежение.

Пълната процедура за избор е дадена в раздел 4.

Във всички случаи, вентилният отвод променя електрическата енергия в топлинна енергия. При електрическо натоварване вътрешната температура на МО резисторите може да се повиши много бързо. Ако поетата енергия е по-висока от способността за топлинно разсейване, то могат да възникнат повреди поради явление на топлинен пробив.


Категории на разряд по линията

Енергията при комутационните пренапрежения зависи от волтажа на системата. Колкото по-висок е волтажа на системата, толкова по-висока е акумулираната енергия поради капацитета на мрежата. При високоволтажни мрежи енергията на някои пренапрежения дори може да надвиши тази от удари при мълния.

Поради това, стандартът IEC 60099-4 определя категории на разряд (от 1 до 5), отговарящи на повишената способност за поглъщане на енергия при комутационни пренапрежения. При разпределителните мрежи обикновено се използва категория 1. Категориите 2 и 3 преди всичко се прилагат за волтажи на системи в диапазон от 60 до 245 kV, а категориите 4 и 5 над това.

Забележки :

1. Категория на разряд по линията се прилага само към вентилни отводи, които имат номинален разряден ток от 10 kA (категории от 1 до 3) и от 20 kA (категории 4 и 5).



2. Вентилни отводи от категория 2 или 3 на разряд по линията могат да бъдат необходими за средноволтажни подстанции в случай на висока реактивна мощност (наличие на кондензаторни батерии за компенсаторна цел).



TRIDELTA Parafoudres S.A.

Основни характеристики на вентилен отвод MO

- Разчетното напрежение (U_r) е максимално допустимата rms стойност на напрежение с промишлена честота, което може да бъде приложено към вентилния отвод в продължение на 10 s (т.е. временно) след поглъщане на разчетната енергия.

- Постоянното оперативно напрежение (U_c) е максималното напрежение, което може да бъде прилагано непрекъснато към вентилния отвод при дадени външни условия.

- Номиналният разряден ток (I_n) е най-високата стойност на стандартния 8/20 токов импулс при мълния, който се използва за класифициране на един вентилен отвод. Той може да бъде или 5 kA, 10 kA или дори 20 kA : защитното ниво на вентилния отвод срещу мълния се определя при тази стойност на тока.

- Способността за поглъщане на енергия може да бъде зададена за устойчивост към висок токов импулс (4/10 токов импулс при мълния) или за устойчивост към много продължителен токов импулс (продължителност и най-висока стойност съгласно изискванията за категории на разряд по линията).

Предимства на MO вентилни отводи спрямо SiC вентилни отводи


Благодарение на високата нелинейност и способността за поглъщане на енергия при MO резисторите, метало-оксидните вентилни отводи имат много предимства пред предишната силициево-карбидна технология:

- не се абсорбира остатъчен ток ;
- защитното ниво се контролира по-добре, тъй като то вече не зависи от стойността на пробивно напрежение, което се подлага на флукуации;
- остатъчното напрежение при високи стойности на тока е много по-ниско;
- режимът на работа при сурови климатични условия е много подобрен;
- размерът и теглото са много по-малки.

Предимства на MOSA в полимерен корпус


Последната технология се възползва както от MO резисторите, така и от изработване на полимерен корпус. Подобни вентилни отводи все още предлагат повече предимства пред конвенционалните метало-оксидни вентилни отводи:

- теглото е почти наполовина от подобните вентилни отводи в порцеланов корпус, което улеснява както транспортирането, така и обработката;
- диелектричната здравина е подобрена;
- сигурността е повишена в случай на повреда, тъй като силно раздробяване на корпуса не може да възникне;
- режимът на работа при сурови климатични условия е много по-добър благодарение на естествената хидрофобност и устойчивост към UV на полимерния корпус, особено ако е изготвен от силиконов каучук;



- намаленият размер позволява да се извърши монтаж по-близо до оборудването и във всяко положение, така че да се подобри защитата от свръхнапрежение.

Благодарение на горните важни предимства MOSA в полимерен корпус са доказали, че са идеалните устройства за защита при пренапрежения на оборудването в разпределителната мрежа.



TRIDELTA Parafoudres S.A.

2 ОБХВАТ НА РАЗПРОСТРАНЕНИЕ ОТ TRIDELTA НА МЕТАЛО-ОКСИДНИ ВЕНТИЛНИ ОТВОДИ В ПОЛИМЕРЕН КОРПУС

2.1 Продуктова номенклатура на VARISIL™ тип HE

Продуктите VARISIL™ тип HE са 10 kA метало-оксидни вентилни отводи за разпределителни мрежи, специално предназначени за райони, подложени на силни удари от мълния и са с високо ниво на замърсяване на околната среда. Обхватът включва системни напрежения от 5.5 kV до 36 kV. В таблицата на стр. 14 са представени основните характеристики на вентилните отводи VARISIL™ тип HE. Номенклатурата включва четири различни размера, които съответно се използват за разчетни напрежения до 12 kV, 18 kV, 24 kV и 36 kV.

2.2 Дизайн на VARISIL™ тип HE

Активната част е изработена от MOV блокове обвити със синтетична смола, усиленa чрез фибростъкло, чийто дизайн е патентован. Това ядро осигурява механичната издръжливост и е покрито с полимерен корпус, изработен от силиконов каучук, подходящ за райони с високо ниво на замърсяване на околната среда.

MOV блокове на TRIDELTA

TRIDELTA произвежда своите блокове в добре известни цехове.

Формулата (химичният състав) и процесите (особено цикълът на спичане) се контролират внимателно, за да се гарантират високи нива на качество и надеждност.

Композитна обвивка


Тялото на вентилния отвод е изработено от синтетична смола, усиленa чрез фибростъкло, чийто дизайн е патентован. Тази рамка осигурява перфектно капсулиране на MOV блоковете и надежден режим на работа при условия на повреда.

Корпус от силиконов каучук

Силиконовият каучук, използван за външна изолация е показал задоволителни характеристики при високоволтово приложение.

Най-важният довод за успеха на силиконовия каучук при тези приложения е неговата способност да поддържа хидрофобна повърхност дори при замърсяване, както и да възвръща хидрофобността, ако тя е била временно изчезнала по време на изключителна електрическа активност.

Хидрофобността фактически е удавяне на вода при разпръснати капки вода като се избягват големи зони на повърхностна проводимост. В замърсена околна среда



силиконовият каучук показва съществени предимства пред керамични материали, като порцелан, по отношение на работния режим при електрически разряд (виж диаграмата на стр. 12).




TRIDÉLTA Parafoudres S.A.

В допълнение, изключителната устойчивост на силиконовия каучук към ултравиолетови лъчи, окисляване и озон осигурява, че материалът ще остане функционален при дълго влияние на околната среда. Това се дължи предимно на факта, че силиконовият каучук е неорганичен материал с молекулярни връзки силиций - кислород ($\text{Si} - \text{O}$) и с много по-малка чувствителност към UV радиация, отколкото молекулярните връзки въглерод - въглерод - при EPM, EPDM и XLPE (полиетилен с междумолекулярни връзки).

11




692




TRIDELTA Parafoudries S.A.


COMPARISON OF FLASHOVER PERFORMANCE OF SILICONE RUBBER & CONVENTIONAL CERAMIC MATERIALS



[Handwritten signature]


[Handwritten signature]





TRIDELTA Parafoudres S.A.


COMPARISON OF CURRENT vs VOLTAGE CHARACTERISTIC CURVES for MO and SiC SURGE ARRESTERS having the same protective level



[Handwritten signature]


[Handwritten signature]

RESISTIVE CURRENT (A. peak)



[Handwritten signature]


[Handwritten signature]



TRIDELTA Parafourires S.A.

CHARACTERISTICS OF TRIDELTA VARISIL™ Type HE SURGE ARRESTERS

TYPE	HE 05	HE 06	HE 09	HE 10	HE 12	HE 15	HE 18	HE 21	HE 24	HE 27	HE 30	HE 33	HE 36
Rated voltage Ur (kV rms)	5	6	9	10	12	15	18	21	24	27	30	33	36
Continuous Operating Voltage Uc (kV rms)	4.25	5.1	7.65	8.4	10.2	12.7	15.3	17.5	20	22.5	25	27.5	30
Maximum residual voltage at In (kV)	15.2	16.4	28.1	29.3	32.8	43.3	49.1	59.7	65.1	76.8	81.1	92.8	97.5
Nominal discharge current In	10 kA with 8/20 bi-exponential waveshape												
High current impulse withstand (Energy absorption capability)	100 kA with 4/10 bi-exponential waveshape (4.0 kJ/kV of Ur)												
Long duration current impulse withstand (Energy absorption capability)	300 A with 2000 μs rectangular waveshape (2.0 kJ/kV of Ur)												
Short circuit withstand	20 kA / 0.2 s - 600 A / 1 s												
Leakage distance	480 mm			650 mm			800 mm			1200 mm			





TRIDELTA Parafoudres S.A.


3 ДОПЪЛНИТЕЛНИ ЧАСТИ ЗА ВЕНТИЛНИ ОТВОДИ VARISIL™ тип HE

3.1 Прекъсвач или индикатор за повреда

Прекъсвач

Прекъсвачът е устройство, позволяващо автоматично да се отвори връзката на вентилния отвод към земята.


В случай на повреда на вентилния отвод, вътрешното пиротехническо устройство сработва заради възникналия електрически и термален ток при късо съединение. Модулът изключва и така прекъсва връзката на вентилния отвод към земята, предотвратявайки поддържане на повредата. Благодарение на това устройство се осигурява непрекъснатост на работата.




Техническо усъвършенстване :

Отсега нататък ние ще интегрираме функцията на прекъсване в изолационната поддържаща конзола, за да се оптимизира монтажа и функционирането на вентилния отвод.

В частност, повишено е нивото на устойчивост към импулсния ток.





TRIDELTA Parafoudres S.A.

Характеристики на прекъсвач SnD2 :

Гаранция за функциониране под 20 mm лед.

Чувствителност към ток при късо съединение:

20 A eff. / 0,4 s maximum
10 A eff. / 1 s maximum
5 A eff. / 3 s maximum

Устойчивост към импулсен ток :

Вълна на мълния 4/10 :	> 2 последователни импулса от 100 kA
Вълна на превключване 30/80 :	> 2 последователни импулса от 35 kA
Правоъгълна вълна 2000 μ s :	> 5 последователни импулса от 300 A

Приложения :

При стандартна доставка с модел S1D2 се оборудват VARISIL™ HE, HEL и HE-S при разчетно напрежение до 18 kV, а с модел S3D2 се оборудва от 21 kV.



697




TRIDELTA Parafoudres S.A.

Индикатор за повреда

Когато операторът иска непрекъснатост на защитата, то всеки повреден вентилен отвод трябва да остане включен в мрежата, за да се поддържа защитата. Опцията "IF" включва модул на индикатор за повреда. В случай на натоварване, надвишаващо способността на вентилния отвод за поглъщане на енергия, токът във веригата на късо съединение предизвиква появата на червен сигнал. Така всеки повреден вентилен отвод може да бъде лесно открит от значително разстояние. Чувствителността е 10 A / 0.5 s. Тази опция се препоръчва за мрежи с ниски токове на късо съединение (условия на заземяване с изолирана или компенсирана неутрална точка).

**SENSITIVITY OF THE FAULT INDICATOR INTENDED FOR
VARISIL Type HE Version IF SURGE ARRESTERS**



3.2 Конзола и накрайници


3.2.1 Конзола


- Индивидуална конзола (по 1 елемент за всеки вентилен отвод) : стандартна конзола NEMA за монтиране върху траверса.

3.2.2 Накрайници

- опция "NO" и "SnD2" : M12 болт, пружинна шайба и скоба от страната на линията / M12 болт, пружинна и плоска шайба от страната на земята;

- опция "IF" : M12 болт, пружинна шайба и стяга от страната на линията / M16 щифт, пружинна и плоска шайба от страната на земята.





TRIDELTA Parafoudres S.A.

4 ПРОЦЕДУРА ЗА ИЗБОР НА ВЕНТИЛЕН ОТВОД VARISIL™ тип HE

Изборът на подходящ вентилен отвод се базира върху четири параметъра:

- Номинален разряден ток ;
- Защитно ниво ;
- Постоянно напрежение фаза-земя на мрежата;
- Временно свръхнапрежение в мрежата при условия на повреда.

4.1 Номинален разряден ток

Стандартите IEC 60099-4 и IEEE C62.11 дефинират два основни типа вентилни отвода за разпределители мрежи :

- 5 kA / нормален режим на работа, отнасящ се до върхова стойност на токовия импулс от 65 kA ;
- 10 kA / тежък режим на работа, отнасящ се до върхова стойност на токовия импулс от 100 kA.

Изборът на съответен тип зависи от нивото на гръмотевичните бури в района на монтаж, т.е. от честотата на мълниите и нивото на тока при удари от мълния. В тропическите райони има по-високо ниво на гръмотевични бури, поради това там се нуждаят от вентилни отводи 10 kA. За умерените райони обикновено са подходящи вентилни отводи 5 kA, но при по-сурови местни условия може да са необходими от тип 10 kA (например при планини).

В следващия пример ние ще изберем вентилен отвод VARISIL™ тип HE, който е от тип 10 kA / тежък режим на работа.



4.2 Защитно ниво


Предназначението на вентилния отвод е да се предотврати възпламеняване или пробив на изолацията на оборудването. За да се провери дали това изискване действително е изпълнено, трябва да се сравнят две стойности:

- устойчивост на изолацията на оборудването при 1.2/50 импулсно напрежение при удар от мълния (BIL или LIWL);
- остатъчно напрежение на вентилния отвод при номинален разряд (U_p).

За да се имат предвид възможни по-високи разрядни токове, както и дължината на свързващите проводници, препоръчва се да има минимално съотношение от 1.4 между тези две стойности, т.е. да се поддържа коефициента на надеждност над 40%.

1-ви критерий
 $U_p < BIL / 1,4$





TRIDELTA Parafoudres S.A.

Всички вентилни отводи, отговарящи на това изискване могат да бъдат взети от таблицата на стр. 14.

Примерът се отнася до мрежа с 11 kV системно напрежение и BIL от 75 kV. Първият критерий се отнася до всички вентилни отводи VARISIL™ тип HE, които имат защитно ниво по-ниско от $75 / 1.4 = 53$ kV, т.е. с разчетно напрежение $U_r \leq 18$ kV.

4.3 Постоянно напрежение фаза-земя на мрежата

При нормални условия, постоянното оперативно напрежение U_c на вентилния отвод трябва да бъде по-високо от максималното напрежение фаза-земя в мрежата. Трябва да се знае максималното системно напрежение U_m .

2-ри критерий
 $U_c > U_m / 1,732$

В нашия пример максималното системно напрежение е 12 kV, което води до максимално напрежение фаза-земя от $12 / 1.732 = 6.9$ kV. Всички вентилни отводи VARISIL™ тип HE, които имат $U_r \geq 9$ kV отговарят на това изискване.

4.4 Временни условия на свръхнапрежение

При условие на повреда на една фаза, напреженията фаза-земя са небалансирани. Способът на заземяване в неутрална точка в подстанцията оказва влияние върху действителните напрежения, прилагани към вентилни отводи, които са свързани със здрави фази.


4.4.1 Способ на заземяване в неутрална точка

Могат да се използват 4 способа на заземяване в неутрална точка:

- твърд;
- импедансен (резисторен и/или индукционен);
- изолиран;
- компенсирани (бобина на Петерсен).

Факторът на заземяване K_d характеризира небалансираното въздействие. Това е съотношението между максималното напрежение фаза-земя, прилагано към здрави фази при повреда на една фаза и максималното напрежение фаза-земя при нормални условия ($U_m / \sqrt{3}$).

Той може да бъде установен от характеристики на мрежата като например: мощност на веригата при късо съединение, съпротивление на земята, импеданс на трансформаторите и линията и т.н.



TRIDELTA Parafoudres S.A.

Типичните стойности на този фактор са дадени в таблицата по-долу:

Свързване в неутрална точка	Kd
твърдо заземяване	< 1.4
чрез импеданс	1.4 à 1.73
изолирано	1.6 à 1.8
чрез бобина на Петерсен	1.73 à 1.9

Операционното време на закъснение на прекъсвача на веригата също трябва да се има предвид.

В долната таблица са дадени типичните данни за прекъсване:

Свързване в неутрална точка	Време на реакция
твърдо заземяване	0.1 до 0.5 s
чрез импеданс	0.2 до 1 s
изолирано	0.5 до 8 h
чрез бобина на Петерсен	0.5 s постоянно

Временното свръхнапрежение (TOV), прилагано към вентилните отводи ще бъде различно в зависимост от способа на заземяване в неутрална точка.

Производителите трябва да предоставят крива за устойчивост към временно свръхнапрежение TOV, която характеризира работата на вентилните отводи при подобни натоварвания.

Кривата на стр. 21 се отнася до вентилните отводи VARISIL™ тип HE.

Подходящите вентилни отводи трябва да бъдат избрани както следва:

3-и критерий
<ul style="list-style-type: none">• Умножете максималното напрежение фаза-земя в мрежата ($U_m/1.732$) по фактора Kd.• От кривата TOV, определете напрежението, което трябва да се издържи ($k \times U_r$) при максимална продължителност на състоянията на повреда.• Изчислете необходимия минимум на разчетното напрежение U_r.


В примера неутралната точка е свързана към земята чрез импеданс, с фактор на заземяване 1.55 и максимална продължителност на повреда 1 s.


• Kd = 1.55 : временно свръхнапрежение = $6.9 \times 1.55 = 10.7 \text{ kV}$

• k за 1 s : $k = 1.14 \text{ т.е. } U_t = 1.14 \times U_r$

Критерий за избор : $1.14 \times U_r > 10.7 \text{ т.е. } U_r > 9.4 \text{ kV}$.

Минималното разчетно напрежение, необходимо за вентилния отвод е $U_r = 10 \text{ kV}$.





TRIDELTA Parafoudres S.A.

4.4.2 Долно съпротивление на опората

Ако съпротивлението на земята на някои места е високо, то поведението на системата е като че ли неутралната точка е била заземена чрез висок импеданс. Тогава изчисленията трябва да се направят със съответно завишен фактор K_d (виж точка 5.2 за повече информация).

Краен избор

Ако повече от един отвод отговаря и на трите критерия, то тогава трябва да бъде предпочетен вентилният отвод с най-ниско разчетно напрежение, за да се подобри работата по защитата.

Само специални местни условия (високо долно съпротивление, явления на ферорезонанс) биха могли да оправдаят избора на по-високо разчетно напрежение.

В примера :

1-ви критерий : $U_r \leq 18 \text{ kV}$

2-ри критерий : $U_c > 6.9 \text{ kV}$


3-ти критерий : $U_r > 9.4 \text{ kV}$


Могат да бъдат използвани 4 модела : разчетни напрежения от 10 kV, 12 kV, 15 kV или 18 kV.

Вентилен отвод 10 kV следва да бъде предпочетен, тъй като осигурява най-ниско защитно ниво.

Забележка : За разпределителна мрежа с високо локално земно съпротивление (фактор на заземяване 1.732), критерият за избор по-скоро ще насочи към разчетно напрежение 12 kV.



В таблицата на стр. 23 са посочени типичните разчетни напрежения, които се използват при най-често срещаните системни напрежения.






TRIDELTA Parafoudres S.A.

**MINIMUM OVERVOLTAGE WITHSTAND CAPABILITY
of VARISIL Type HE SURGE ARRESTERS
according to Annex D of IEC 60099-4**






TRIDELTA Parafoudres S.A.


SIMPLIFIED GUIDE for the selection of the rated voltage Ur of VARISIL™ Type HE surge arresters

Depending on the neutral point grounding conditions, the more severe stresses are either of continuous or temporary type.

Nominal system voltage Un (kV)	6	10	11	13.8	15	20	22	30	33
Maximum system voltage Um (kV)	7.2	11	12	15	17.5	22	24	33	36
Solidly earthed neutral point	6	9	10	12	15	18	21	27	30
Grounding through impedance	9	10/12	12	15	18	21/24	24	33	36
Isolated neutral point	9	12	15	15/18	18	24	27	36	—
Grounding through Petersen coil	9	12	15	18	21	24/27	27	—	—

Забележка : Стойностите в червено е необходимо да бъдат проверени в съответствие с действителния фактор на заземяване или / и с максималната продължителност на повреда.





TRIDELTA Parafoudres S.A.

5 ПРЕПОРЪКИ ЗА ИНСТАЛИРАНЕ

За да се получи ефективна защита срещу свръхнапрежение, необходимо е да се поддържа минимално съотношение от 1.4 между изолационното ниво (BIL или LIWL) на оборудването и защитното ниво (U_p) на вентилния отвод като се имат предвид дължината на свързващите проводници и възможните по-високи разрядни токове.

5.1 Дължина на свързващите проводници

Обикновено се счита, че специфичната индуктивност на кабелите е около $1 \mu\text{H/m}$.

При 40 kA (средна стойност) на токов импулс при мълния с форма на вълната 4/10 индукционното напрежение U_i е:

$$U_i = L \times di/dt = 1 \mu\text{H/m} \times 40 \text{ kA} / 4 \mu\text{s} \quad \text{т.е. } U_i = 10 \text{ kV/m} \text{ от дължината на кабела.}$$

При по-висока степен на повишаване или при върхови стойности (например 100 kA), тази стойност би могла да бъде много по-голяма (до 25 kV/m или дори повече).

Препоръки

Дължината на свързването, която трябва да се има предвид представлява общата дължина, където протича разрядния ток, т.е. дължината на проводниците между вентилния отвод и точката на свързване към линията, както и между вентилния отвод и общата точка на свързване към земята.

Обичайна практика е при монтаж на опората е да се свърже заземената страна на вентилния отвод към клемата за заземяване на корпуса на трансформатора, който се инсталира отдолу. Това би следвало да се избягва, за да се подобри ефективността на защитата срещу свръхнапрежение. Вместо това силно се препоръчва клемата за заземяване на корпуса на трансформатора директно да се свърже към заземената точка на закрепване на вентилния отвод. Най-малко 10 kV могат да бъдат спестени при този способ на свързване към земята.


Колкото по-къси са свързващите проводници, толкова по-добра е защитата срещу свръхнапрежение.

5.2 Долно съпротивление на опората

Условия при мълния

Ако омното съпротивление на местната почва е доста голямо (минерални характеристики на пръстта, липса на влага), напрежението в общата точка на заземяване между трансформатора и вентилния отвод достига много висока стойност при токови импулси от мълния.





TRIDELTA Parafoudres S.A.

В този случай, основната опасност е да се получи искрене между корпуса на трансформатора и вторичните намотки (ниско напрежение с твърдо заземена неутрална точка и подлежащо на разпределение). Независимо от номиналното напрежение, вентилните отводи за разпределителни мрежи не са предназначени да се справят с подобно явление. Все пак, един въздушен искроразрядник, свързан между неутралната точка на ниското напрежение и корпуса трансформатора може да реши този проблема.

Условия на повреда

При условия на повреда в самата система (повреда в заземяването или изолацията), стойността на тока при късо съединение остава доста ниска, тъй като се ограничава от високото омно съпротивление на земята.

В този конкретен случай, вентилните отводи свързани към здрави фази ще бъдат много повече натоварени от гледна точка на напрежение. Тогава следва да се предпочете възможно най-високото разчетно напрежение (фактор на заземяване в по-висок диапазон на стойностите, виж точка 4.4.2).

В заключение се препоръчва съпротивленията на заземяване да бъдат възможно най-ниски. В конкретния случай, при монтиране на опората, долното съпротивление не трябва да надвишава 30 Ω .

5.3 Отстояния


При етапа на инсталиране трябва така да се отчитат луфтовете, че да се гарантира правилна работа на вентилните отводи VARISIL™ тип HE.


Разстоянията между активните части на вентилните отводи и който и да е заземен елемент (разстояние d) както и между активните части на вентилните отводи, свързани към близките фази (разстояние D) следва да бъдат внимателно проверявани.

В долната таблица са препоръчани отстояния в съответствие с разчетното напрежение.

Type HE	05	06	09	10	12	15	18
d (mm)	46	50	86	89	100	132	160
D (mm)	50	54	92	96	108	143	163

Type HE	21	24	27	30	33	36
d (mm)	182	199	234	247	283	297
D (mm)	199	217	258	272	313	330





TRIDELTA Parafoudres S.A.

5.4 Електрически връзки

5.4.1 Свързване към земята

При вентилните отводи VARISIL™ тип HE, които са снабдени с разединително устройство (опция "SD"), трябва да се използва меден кабел (гол или изолиран) с минимум напречно сечение 16 mm² за свързване към земята. Кабел без кабелен накрайник може да се използва при условие, че диаметърът не надвишава 15 mm : при това положение той може директно да се закрепи като се използва доставената метална скоба.

Този кабел трябва да бъде гъвкав и достатъчно дълъг, за да се осигури необходимия луфт в случай, че разединителят работи. Важно е също така да се провери, че никой елемент не може да попречи на движението на кабела при подобни условия.

При вентилните отводи VARISIL™ тип HE имащи или опция "NO" или опция "IF", свързването към земята следва да се извърши чрез заземяване на монтажната конзола.

5.4.2 Свързване към линията

Свързването на вентилните отводи VARISIL™ тип HE към линията трябва да се извърши или чрез меден или чрез алуминиев кабел (голи или изолирани) с минимум напречно сечение 16 mm². Този кабел следва да се свърже към линейния извод M12 на вентилния отвод. Кабел без кабелен накрайник може да се използва при условие, че диаметърът не надвишава 15 mm : при това положение той може директно да се закрепи като се използва доставената метална скоба.

Препоръчва се също така, към вентилния отвод да не се прилага значителен механичен натиск чрез повишено натоварване на линейния кабел.



5.4.3 Сили на затягане

Силите, прилагани за затягане на болтовете и/или гайките на вентилните отводи VARISIL™ тип HE, никога не трябва да надвишават :

- 20 N.m за M12 накрайници (приложими към всички опции);
- 30 N.m за M16 накрайници (опция "IF")

5.5 Опаковка

Вентилните отводи VARISIL™ тип HE са опаковани в отделни сандъци, които могат лесно да се отворят без да са необходими инструменти.





TRIDELTA Parafoudres S.A.

5.5.1 Обработка и транспорт

Благодарение на мекия полимерен корпус на вентилните отводи VARISIL™ тип HE с тях може да се борави с по-малка предпазливост от тази, която се изисква за устройствата с порцеланов корпус. Все пак, трябва да се обърне внимание да се избягва повреждане на:

- полимерния корпус (срязване или разкъсване с остри предмети);
- свързващите болтове и шпилките с резба;
- допълнителните части, ако има такива (изолационна конзола, прекъсвач или индикатор за повреда).

Ако бъдат повредени тези части те могат да попречат на правилния монтаж и/или работа. Препоръчва се, вентилните отводи да останат в оригиналния им сандък до тяхното инсталиране.

5.5.2 Съхранение

Преди употреба вентилните отводи трябва да се държат в тяхната оригинална опаковка. Сандъците следва да се съхраняват в закрити помещения при температура на въздуха в границите на $-20\text{ }^{\circ}\text{C} \div +70\text{ }^{\circ}\text{C}$.


5.5.3 Поддръжка

VARISIL™ тип HE вентилните отводи не изискват техническа поддръжка.

Ако се използват вентилни отводи с разединително устройство (опция "SnD2"), препоръчва се на оператора да извършва периодични проверки на самия терен, за да открие някой вентилен отвод, който може да се е изключил (падане на заземяващия кабел) и да го подмени колкото е възможно по-скоро.

В случай на изключване, следва да се подмени целият комплект (елементът на вентилния отвод / изолационната конзола / модулът за разединяване).





TRIDELTA Parafoudres S.A.

6 СТАНДАРТИ И ТЕСТОВЕ

Номенклатурата на VARISIL™ тип HE вентилни отводи изпълнява всички съответни изисквания на IEC.

6.1 Еталонен стандарт

IEC 60099-4 : "Вентилни отводи / Част 4 : Метало-оксидни вентилни отводи без междини за системи с променлив ток „– 2-ро издание.

6.2 Други приложими стандарти

ANSI/IEEE C62.11 : "IEEE стандарт за метало-оксидни вентилни отводи за енергийни вериги с променлив ток."

IEC 60071-1 : "Свързване на изолацията / Част 1 : Дефиниции, принципи и правила".

IEC 60099-5 : " Вентилни отводи / Част 5 : Препоръки за избор и приложение".

IEC 60270 : "Измервания на частичния разряд".

IEC 60507 : "Тестове при изкуствено замърсяване на високоволтови изолатори, които ще се използват в системи с променлив ток".


IEC 60815 : "Ръководство за избор на изолатори във връзка с условията на замърсяване".

IEC 61109 : "Комбинирани изолатори за надземни проводници с променлив ток с номинално напрежение над 1000 V – Дефиниции, методи за тестване и критерии за приемане".

6.3 Типови тестове

Всички типови тестове са извършени в CESI (Centro Elettrotecnico Sperimentale Italiano), независима лаборатория, намираща се в МИЛАНО - Италия.

Таблица с проведените типови тестове и съответните тестове са на разположение при поискване.


28

6.4 Тестове за приемане на стандарт

В таблицата по-долу са дадени тестовете за приемане на стандарт, които се изискват по IEC 60099-4 :


Test description	Clause of IEC 60099-4	Test samples
Measurement of the reference voltage at 1 mA peak AC	§ 9.2.1.a	Surge Arresters
Measurement of the lightning residual voltage at 10 kA	§ 9.2.1.b	MOV blocks
Measurement of the partial discharge level	§ 9.2.1.c	Surge Arresters

6.5 Рутинни тестове


В таблицата по-долу са посочени рутинните тестове, които се извършват при производството на вентилните отводи VARISIL™ тип HE :

Test description	Clause of IEC 60099-4	Test samples
Measurement of the voltage at 1 mA	Not required	MOV blocks
Measurement of the lightning residual voltage at 10 kA	§ 9.1.b	MOV blocks
Verification of the energy absorption capability (2 shots at 300 A / 2000 µs)	Not required	MOV blocks
Measurement of the reference voltage at 1 mA peak AC	§ 9.1.a	Surge arresters
Verification of the absence from partial discharge and contact noise ⁽¹⁾	§ 9.1.c	Surge arresters

⁽¹⁾ Този тест се провежда в същото време, когато се измерва еталонното напрежение.








TRIDELTA Parafoudres S.A.

Surge Arresters for Distribution Systems

VARISIL™ Type HE



Presentation and Technical Guide

January 2010





TRIDELTA Parafoudres S.A.


Contents

FOREWORD	4
1 SURGE ARRESTERS	5
1.1 Protective devices	5
1.2 Air spark gaps	5
1.3 Gapped Silicon Carbide Surge Arresters (SiC)	6
1.4 Gapless Metal Oxide Surge Arresters (MOSAs)	7
2 TRIDELTA RANGE OF DISTRIBUTION METAL OXIDE POLYMER HOUSED SURGE ARRESTERS	10
2.1 VARISIL™ Type HE product range	10
2.2 VARISIL™ Type HE design	10
3 ACCESSORIES FOR VARISIL™ Type HE SURGE ARRESTERS	15
3.1 Disconnecter or fault indicator	15
3.2 Brackets and terminals	16
3.2.1 Brackets	16
3.2.2 Terminals	16
4 PROCEDURE TO SELECT A VARISIL™ Type HE SURGE ARRESTER	17
4.1 Nominal discharge current	17
4.2 Protective level	17
4.3 Continuous phase-to-earth voltage of the network	18
4.4 Temporary overvoltage conditions	18
4.4.1 Neutral point grounding mode	18
4.4.2 Foot resistance of the pole	20



TRIDELTA Parafoudres S.A.

5	RECOMMENDATIONS FOR INSTALLATION	23
5.1	Length of connection leads	23
5.2	Foot resistance of the pole	23
5.3	Clearances	24
5.4	Electric connections	25
5.4.1	Connection to earth	25
5.4.2	Connection to line	25
5.4.3	Tightening torques	25
5.5	Packaging	25
5.5.1	Handling and transport	26
5.5.2	Storage	26
5.5.3	Maintenance	26
6	STANDARDS AND TESTS	27
6.1	Reference standard	27
6.2	Other applicable standards	27
6.3	Type tests	27
6.4	Standard acceptance tests	28
6.5	Routine tests	29





TRIDELTA Parafoudres S.A.

VARISIL™ Type HE SURGE ARRESTERS

FOREWORD

Whatever the system voltage, power supply networks are stressed by transient overvoltages which often damage the equipment (power transformers, underground cables, ...) because of their high level.


There are two main types of overvoltages :


- overvoltages with internal origin, i.e. caused by operation or layout of the network (switching surges, resonance phenomena, ...)
- overvoltages with external origin, i.e. generated by external phenomena among which lightning is the most important.

On power Medium Voltage networks (Distribution networks), overvoltages due to lightning strokes prove to be the most energetic stresses, whether they are caused by direct strokes (overvoltages due to galvanic coupling) or, at a lower rate, indirect strokes (overvoltages due to capacitive and/or inductive coupling).

Their level may reach several hundreds of kilovolts and then far exceed the insulation withstand of the equipment. These overvoltages may then cause the equipment insulation to flashover or/and to puncture if no suitable surge protection device has been previously installed.

In case such a problem actually occurs, operators might regret not to have invested in surge arresters whose cost is far less than that of damaged equipment.





TRIDELTA Parafoudres S.A.

1 SURGE ARRESTERS

1.1 Protective devices

There are two main types of protection devices for Distribution networks : air spark gaps and surge arresters.

These are generally connected between phase and earth so as to create a weak point in the system insulation and thus ensure the overvoltage protection of the equipment against induced or direct surges.

Spark gaps are still widely used to protect air insulated equipment or when a low insulation level is not needed.

However, to improve quality of service, higher performance is required and surge arresters are necessary. Two technologies of surge arresters are available :

- **SiC surge arresters** : their active stack is an assembly of elementary air gaps and non linear silicon carbide resistors which are connected in series
- **MO surge arresters** : their active stack is only made of non linear metal oxide resistors.

The MO technology appeared in the early 70's and provides better performance than SiC. Therefore SiC surge arresters have been progressively replaced by MO surge arresters whose latest polymer housed design is now widely used throughout the world.

1.2 Air spark gaps

The air spark gap is the elder, the simpler and the cheaper surge protection device.

Design


It is generally made of two electrodes : the first one is connected to the line side of the equipment to be protected and the second one is earthed.

Operating principle

The air gap between these two electrodes is a weak point in the network insulation. The air distance can be set in order to adjust the sparkover voltage to the required value.

Protective level

The protective level of a spark gap is the maximum sparkover voltage under the standard 1.2/50 lightning voltage impulse.





TRIDELTA Parafoudres S.A.

Advantages and drawbacks

Even though spark gaps are very cheap, very strong and can be easily set, they suffer from a lot of disadvantages whose main are :

- once sparkover occurs, the power arc is not able to extinguish spontaneously, so that the circuit breaker has to operate in order to clear the fault current
- sparkover leads to a waveshape with cut tail, which may cause close winding equipment to fail.
- the sparkover voltage depends on climatic conditions (temperature, humidity, ...) and also on the front rise of the overvoltage. In case of steep front of wave, the voltage actually applied to the equipment may be much greater than the sparkover voltage itself (response time), which could also lead to unexpected failure.

1.3 Gapped Silicon Carbide Surge Arresters (SiC)

SiC surge arresters have got rid of some of the drawbacks of the air spark gaps. The principle was to use a non linear resistance in series with the air gap in order to prevent a high power current to flow during operation. Silicon carbide was the first material with a high non linear factor suitable to such an application. Non linear resistors are made of SiC grains, pressed into discs with metallised faces for improved electric contact.

Design


Because silicon carbide has non-linear properties on a limited range of current density values, a gapless device would fail immediately under the normal phase-to-earth voltage. Air gaps are compulsory to isolate the discs under normal conditions.

Therefore, the core of silicon carbide surge arresters is made of SiC resistors in series with several elementary air gaps. This core is enclosed in a porcelain housing filled with dry air or nitrogen. An appropriate sealing system prevents moisture ingress as performance and reliability are very sensitive to humidity.

Operating principle

Under the nominal phase-to-earth voltage, the air gaps isolate the surge arrester. In case of overvoltage exceeding the sparkover voltage of the gaps assembly, a current impulse flows through the SiC resistors whose resistance decreases as the current increases (non linear property), which limits the actual overvoltage level. Once the surge energy has been absorbed, the surge arrester remains conductive till the applied voltage reaches zero at the latest : the resistance of SiC resistors is then high enough to clear the current and to re-isolate the surge arrester.

Thanks to the non linear resistance of their SiC resistors, silicon carbide surge arresters are able to limit overvoltages while respecting the continuity of supply requirements.



TRIDELTA Parafoudres S.A.

Protective level

The protective level of a silicon carbide surge arrester is defined as the maximum value among :

- 1,2/50 lightning impulse maximum sparkover voltage
- front-of-wave maximum sparkover voltage divided by 1.15
- maximum residual voltage at the nominal discharge current.

Remaining disadvantages

Even though they allow to avoid most of the drawbacks of single spark gaps, SiC surge arresters still have some :

- once the overvoltage has been limited, a power frequency current still flows (called "follow current", which can reach a hundred amps or more) till the applied voltage reaches zero, that is during half a cycle in the worst case.
- although the series air gaps are enclosed in a tight housing, the sparkover voltage is sensitive to external voltage distribution along the porcelain housing which is modified by environment stresses (rain, salt fog, ...).

1.4 Gapless Metal Oxide Surge Arresters (MOSAs)

In the 60's, non linear resistors made of metal oxides were designed for the protection of electronic equipment. Ten years later, MO surge arresters intended for Medium Voltage applications were introduced.

These were characterized by two main advantages :


- a very high non linear factor on an extended range of current density values
- a far higher energy absorption capability than SiC surge arresters

Design

The high non-linearity on an extended range of current allows to remove the air gaps. The MO resistors are enclosed into a tight housing which used to be of porcelain type. The porcelain housing must be equipped with a pressure relief system to avoid shattering in case of internal failure (subsequent to a very high lightning stress for instance).

More recently, manufacturers have replaced this traditional porcelain housing by a polymeric housing with appropriate properties so as to withstand climatic stresses and ensure tracking resistance. To get the required mechanical strength for the surge arrester (which was formerly obtained by the porcelain housing itself), the metal oxide resistors are now wrapped in a fibreglass reinforced resin.

The manufacturing process of the MO resistors (also called "MOV blocks") requires a strong experience to get the expected performance and reliability. A particular care is necessary during the manufacture processes. A block is made of zinc oxide (90 %) mixed with others metal oxides (Bismuth, Cobalt, Manganese, ...). The formula (chemical composition) and the processes (especially the sintering cycle) are carefully checked in order to guarantee high quality and reliability levels.





TRIDELTA Parafoudres S.A.

Operating principle

The main advantage of a MO resistor is the highly non linear current vs voltage characteristic curve (see curve on page 13).

Under the nominal phase-to-earth voltage, the impedance of a MO surge arrester is very high so that the leakage current is very low (typically less than 0.1 mA).

When an overvoltage appears, the ohmic resistance decreases very quickly in order that the surge current flows to the earth and the overvoltage level is limited. The non-linear factor is so high that between 0.1 mA and 10 kA the voltage is only doubled.

Protective level

The protective level of a metal oxide surge arrester is defined as the maximum residual voltage at the nominal discharge current.

Dimensioning

Selection of an appropriate surge arrester (i.e. define the suitable rated voltage) is based on considerations having opposite trends :

- optimize the protection provided, but the lower the protective level the lower the rated voltage
- ensure the withstand to applied voltages, but the higher the voltage withstand the higher the rated voltage

The complete procedure for selection is exposed in section 4.

In any case, the surge arrester changes electrical energy into thermal energy. When electrically stressed, the internal temperature of MO resistors may increase very quickly. If the absorbed energy is higher than the heat dissipation capability, failure may occur by a thermal runaway phenomenon.


Line discharge class

The energy of switching surges depends on the system voltage. The higher the system voltage, the higher the stored energy due to capacitive behaviour of the network. In high voltage networks, the energy of some switching surges can even exceed that of lightning strokes.

Therefore, IEC 60099-4 standard defines line discharge classes (from 1 to 5) corresponding to increased energy absorption capability under switching surges. For Distribution networks, class 1 is usually used. Classes 2 and 3 are more commonly specified for system voltages ranging from 60 to 245 kV and classes 4 and 5 above.

Notes :

1. Line discharge class is only applicable to surge arresters having a nominal discharge current of 10 kA (classes 1 to 3) and 20 kA (classes 4 and 5).
2. Line discharge class 2 or 3 surge arresters may be required in Medium Voltage sub-stations in case of high reactive power (presence of capacitor banks for compensation purpose).



TRIDELTA Parafoudres S.A.

Main characteristics of a MO surge arrester

- The rated voltage (U_r) is the maximum permissible rms value of power frequency voltage which can be applied to the surge arrester during 10 s (i.e. temporarily) after absorption of the rated energy.
- The continuous operating voltage (U_c) is the maximum voltage which can be applied continuously to the surge arrester under given ambient conditions.
- The nominal discharge current (I_n) is the peak value of the standard 8/20 lightning current impulse which is used to classify a surge arrester. It can be either 5 kA, 10 kA or even 20 kA : the lightning protective level of the surge arrester is defined at this current value.
- The energy absorption capability can be given for the high current impulse withstand (4/10 lightning current impulse) or for the long duration current impulse withstand (duration and peak value according to line discharge class requirements).

Advantages of MO vs SiC surge arresters

Thanks to the high non-linearity and energy absorption capability of MO resistors, metal oxide surge arresters have many advantages over former silicon carbide technology :


- no follow current is absorbed
- the protective level is better controlled because it no longer depends on a sparkover voltage value which is submitted to fluctuations
- the residual voltage at high current values is much lower
- the behaviour under severe climatic conditions is well improved
- size and weight are far less.

Advantages of polymer housed MOSAs

This latest technology benefits by both the MO resistors and the polymeric housing performance. Such surge arresters still provide more advantages than conventional metal oxide surge arresters :

- the weight is about half the weight of the equivalent porcelain housed surge arresters, which facilitates both transportation and handling
- the dielectric strength is improved
- the safety is increased in case of failure since a violent shattering of the housing cannot occur
- the behaviour under very severe climatic conditions is much better thanks to the natural hydrophobicity and UV resistance of the polymer housing, especially if made of silicone rubber
- the reduced size allows installation closer to the equipment and in any position so as to improve the overvoltage protection.

Thanks to above significant advantages, polymer housed MOSAs prove to be ideal devices for surge protection of Distribution equipment.



TRIDELTA Parafoudres S.A.

2 TRIDELTA RANGE OF DISTRIBUTION METAL OXIDE POLYMER HOUSED SURGE ARRESTERS

2.1 VARISIL™ Type HE product range

VARISIL™ Type HE products are 10 kA metal oxide surge arresters for Distribution networks, specifically designed for areas with strong lightning exposure and high pollution level.

The range covers system voltages from 5.5 kV to 36 kV. Table on page 14 gives the main features of VARISIL™ Type HE surge arresters.

The range includes four different sizes which are respectively used for rated voltages up to 12 kV, 18 kV, 24 kV and 36 kV.

2.2 VARISIL™ Type HE design

The active part is made of MOV blocks wrapped in a fiberglass reinforced synthetic resin whose design is patented.

This core provides the mechanical resistance and is covered by a polymeric housing made of silicone rubber suitable to areas with high pollution level.

TRIDELTA MOV blocks

TRIDELTA manufactures its own blocks in recognized workshops.

The formula (chemical composition) and the processes (especially the sintering cycle) are carefully checked in order to guarantee a high quality and reliability levels.


Composite wrapping


The surge arrester body is made of a fiberglass reinforced synthetic resin whose design is patented. This frame ensures a perfect encapsulation of the MOV blocks and a safe behaviour under fault conditions.

Silicone rubber housing

The silicone rubber used for external insulation has shown satisfactory performance in high voltage applications.



The key point to silicone rubber success in these applications is its ability to maintain a hydrophobic surface, even when contaminated, and to recover hydrophobicity if it is temporarily lost during periods of extreme electrical activity. Hydrophobicity is the fact to capture water under spread drops of water avoiding any large surface conductive areas. In contaminated environments, silicone rubber has demonstrated significant advantages over ceramic materials such as porcelain with respect to flashover performance (see figure on page 12)





TRIDELTA Parafoudres S.A.


In addition, the outstanding resistance of silicone rubber to ultraviolet radiation, oxidation and ozone ensures that the material will remain functional through prolonged environmental exposure. This is mainly due to the fact that silicone rubber is an inorganic material with Silicon-Oxygen (Si-O) molecular links far less sensitive to UV radiation than carbon – carbon molecular links of EPM, EPDM and XLPE (Cross-linked Polyethylene).






TRIDELTA Parafoudres S.A.


COMPARISON OF FLASHOVER PERFORMANCE OF SILICONE RUBBER & CONVENTIONAL CERAMIC MATERIALS






TRIDELTA Parafoudrites S.A.

COMPARISON OF CURRENT vs VOLTAGE CHARACTERISTIC CURVES for MO and SiC SURGE ARRESTERS having the same protective level



[Handwritten signature]

[Handwritten signature]




Technical guide TRIDELTA VARISIL HE_e



TRIDELTA Parafoudres S.A.

CHARACTERISTICS OF TRIDELTA VARISIL™ Type HE SURGE ARRESTERS

TYPE	HE 05	HE 06	HE 09	HE 10	HE 12	HE 15	HE 18	HE 21	HE 24	HE 27	HE 30	HE 33	HE 36
Rated voltage Ur (kV rms)	5	6	9	10	12	15	18	21	24	27	30	33	36
Continuous Operating Voltage Uc (kV rms)	4.25	5.1	7.65	8.4	10.2	12.7	15.3	17.5	20	22.5	25	27.5	30
Maximum residual voltage at In (kV)	15.2	16.4	28.1	29.3	32.8	43.3	49.1	59.7	65.1	76.8	81.1	92.8	97.5
Nominal discharge current In	10 kA with 8/20 bi-exponential waveshape												
High current impulse withstand (Energy absorption capability)	100 kA with 4/10 bi-exponential waveshape (4.0 kJ/kV of Ur)												
Long duration current impulse withstand (Energy absorption capability)	300 A with 2000 µs rectangular waveshape (2.0 kJ/kV of Ur)												
Short circuit withstand	20 kA / 0.2 s - 600 A / 1 s												
Leakage distance	480 mm			650 mm			800 mm			1200 mm			



TRIDELTA Parafoudres S.A.

3 ACCESSORIES FOR VARISIL™ Type HE SURGE ARRESTERS


3.1 Disconnecter or fault indicator

Disconnecter

The disconnecter is a device permitting to automatically open the connexion of the surge arrester to the earth .

In case of failure of the surge arrester, the internal pyrotechnic device operates due to the electrical and the thermal fault current which occurs. The module breaks and disconnects so the connexion of the surge arrester to the earth, avoiding the maintain of the fault. Thanks to this device, the continuity of service is favoured.


OPERATION CHARACTERISTIC CURVE of Type D2 or SnD2
DISCONNECTING DEVICE Intended for VARISIL surge arresters
(also refer to CESI Test Report ref. A5/020072 dated April 27, 2005)




Technical evolution :

Henceforth, we shall integrate the disconnecting function inside the insulating support bracket to optimize the installation and the functioning of the surge arrester

In particular, the immunity level to the impulse current has been increased.





TRIDELTA Parafoudres S.A.

Performances of the disconnecter SnD2 :

Guarantee of functioning under 20 mm of ice

Sensitivity to fault current

20 A eff. / 0,4 s maximum

10 A eff. / 1 s maximum

5 A eff. / 3 s maximum

Immunity to impulse current :


Lightning wave 4/10 : > 2 consecutive impulses of 100 kA


Switching wave 30/80 : > 2 consecutive impulses of 35 kA

Rectangular wave 2000 μ s : > 5 consecutive impulses of 300 A

Applications :

As standard supply, the S1D2 model equips the VARISIL™ HE, HEL and HE-S with rated voltage up to 18 kV and the S3D2 model equips from 21 kV.





TRIDELTA Parafoudres S.A.

[Handwritten signature]


Fault indicator

Whenever the operator requests continuity of protection, each failed surge arrester has to remain connected to the network in order to maintain the protection.

The "IF" option includes a fault indicator module. In case of stress exceeding the energy absorption capability of the surge arrester, the short circuit current causes a red flag to appear. Any failed surge arrester can then be easily detected at a significant distance.

The sensitivity is 10 A / 0.5 s. This option is recommended for networks with low fault currents (isolated or compensated neutral point grounding conditions).

SENSITIVITY OF THE FAULT INDICATOR INTENDED FOR VARISIL Type HE Version IF SURGE ARRESTERS



[Handwritten signature]

3.2 Bracket and terminals


3.2.1 Bracket

- Individual bracket (1 unit per surge arrester) : standard NEMA bracket for mounting on crossarm

3.2.2 Terminals

- "NO" and "SnD2" option : M12 bolt, spring washer and clamp at the line side / M12 bolt, spring and flat washers at the earth side
- "IF" option : M12 bolt, spring washer and line clamp at the line side / M16 stud, spring and flat washers at the earth side.

[Handwritten signature]





TRIDELTA Parafoudres S.A.

4 PROCEDURE TO SELECT A VARISIL™ Type HE SURGE ARRESTER

The selection of an appropriate surge arrester is based on four parameters :

- Nominal discharge current
- Protective level
- Continuous phase-to-earth voltage of the network
- Temporary overvoltage of the network under fault conditions

4.1 Nominal discharge current

IEC 60099-4 and IEEE C62.11 standards define two main types of Distribution surge arresters :

- 5 kA / Normal Duty relating to a high current impulse peak value of 65 kA
- 10 kA / Heavy Duty relating to a high current impulse peak value of 100 kA

Selection of the type depends on the keraunic level of the installation area i.e. the frequency and the current level of lightning strokes. Tropical regions have a higher keraunic level, thus needing 10 kA surge arresters. For temperate regions, 5 kA surge arresters are generally suitable, but more severe local conditions may require a 10 kA type (mountains for instance).

In the following example, we will choose a VARISIL™ Type HE surge arrester which is of 10 kA / Heavy Duty type.

4.2 Protective level


The purpose of the surge arrester is to avoid flashover or puncture of the equipment insulation. To check that this requirement is actually fulfilled, two values must be compared :

- insulation withstand of the equipment under 1.2/50 lightning voltage impulse (BIL or LIWL)
- residual voltage of the surge arrester at the nominal discharge (Up)

In order to take into account possible higher discharge currents and length of connection leads, it is recommended to get a minimum ratio of 1.4 between these two values, i.e. keep the safety margin above 40 %.

1st criterion :

$$U_p < BIL / 1,4$$





TRIDELTA Parafoudres S.A.

All surge arresters meeting this requirement can then be extracted from the table given on page 14.

*The example is a network with 11 kV system voltage and a BIL of 75 kV.
The first criterion then leads to all VARISIL™ Type HE surge arresters having a protective level lower than $75 / 1.4 = 53$ kV, i.e. with a rated voltage $U_r \leq 18$ kV.*

4.3 Continuous phase-to-earth voltage of the network

Under normal conditions, the continuous operating voltage U_c of the surge arrester shall be higher than the maximum phase-to-earth voltage of the network.

The maximum system voltage U_m must then be known.

2nd criterion :

$$U_c > U_m / 1,732$$

*In our example, the maximum system voltage is 12 kV, which leads to a maximum phase-to-earth voltage of $12 / 1.732 = 6.9$ kV.
All VARISIL™ Type HE surge arresters with $U_r \geq 9$ kV then meet the case.*

4.4 Temporary overvoltage conditions

Under single phase fault conditions, the phase-to-earth voltages are unbalanced. The neutral point grounding mode in the substation influences the actual voltages applied to the surge arresters connected to healthy phases.


4.4.1 Neutral point grounding mode


Four modes of neutral point grounding can be used :

- solid
- impedant (resistive and or inductive)
- isolated
- compensated (Petersen coil)

The earth fault factor K_d characterizes the unbalanced effect. It is the ratio between the maximum phase-to-earth voltage on healthy phases under single phase fault conditions and maximum phase-to-earth voltage under normal conditions ($U_m/\sqrt{3}$).

It can be derived from the network features like short circuit power, earth resistances, transformer and line impedances, etc.





TRIDELTA Parafoudres S.A.

Typical values for this factor are given in table below :

Neutral point connection	Kd
Solidly grounded	< 1.4
Through impedance	1.4 à 1.73
Isolated	1.6 à 1.8
Through Petersen coil	1.73 à 1.9

The operation time delay of the circuit breaker must also be considered.
The table below gives typical tripping values :

Neutral point connection	Response time
Solidly grounded	0.1 to 0.5 s
Through impedance	0.2 to 1 s
Isolated	0.5 s to 8 h
Through Petersen coil	0.5 s to continuous

The temporary overvoltage (TOV) applied to the surge arresters will then be different according to the neutral point grounding mode.
Manufacturers should provide a TOV withstand curve which characterizes the performance of the surge arresters under such stresses.
The curve on page 21 relates to VARISIL™ Type HE surge arresters.

Appropriate surge arresters shall then be selected as follows :

3rd criterion :
<ul style="list-style-type: none"> • Multiply the maximum phase-to-earth voltage of the network ($U_m/1.732$) by the Kd factor • From the TOV curve, determine the withstand voltage ($k \times U_r$) for the maximum duration of fault conditions • Calculate the required minimum rated voltage U_r

In the example, the neutral point is connected to earth through an impedance with an earth fault factor of 1.55 and a maximum fault duration of 1 s.

- $K_d = 1.55$: Temporary overvoltage = $6.9 \times 1.55 = 10.7$ kV
- k for 1 s : $k = 1.14$ i.e. $U_t = 1.14 \times U_r$

Selection criterion : $1.14 \times U_r > 10.7$ i.e. $U_r > 9.4$ kV.

The minimum rated voltage required for the surge arrester is then $U_r = 10$ kV.



TRIDELTA Parafoudres S.A.

4.4.2 Foot resistance of the pole

If the earth resistance is locally high, the system behave as if the neutral point was grounded through a high impedance. The calculations must then be made with a Kd factor increased accordingly (see clause 5.2 for more information).

Final selection :

**If more than one single arrester fulfill all 3 criteria,
the surge arrester with the lowest rated voltage shall be preferred
so as to improve the protection performance.**


Only particular local conditions (high foot resistance ,ferroresonance phenomena)
might justify the selection of a higher rated voltage.

In the example : 1st criterion : $U_r \leq 18 \text{ kV}$
2nd criterion : $U_c > 6.9 \text{ kV}$
3rd criterion : $U_r > 9.4 \text{ kV}$

*4 models could then be used : rated voltage of 10 kV, 12 kV, 15 kV or 18 kV.
The 10 kV rated surge arrester shall be preferred as it provides the lowest protective level.*

*Note : for a Distribution network with high local earth resistances (earth fault factor of 1.732),
the selection criteria would rather lead to a rated voltage of 12 kV.*


The table on page 23 indicates the typical rated voltages to be used for common system voltages.






TRIDELTA Parafoudres S.A.

MINIMUM OVERVOLTAGE WITHSTAND CAPABILITY of VARISIL Type HE SURGE ARRESTERS according to Annex D of IEC 60099-4



[Handwritten signature]

[Handwritten signature]



Technical guide TRIDELTA VARISIL HE_e

[Handwritten signature]



TRIDELTA Parafoudres S.A.

SIMPLIFIED GUIDE for the selection of the rated voltage U_r of VARISIL™ Type HE surge arresters

Depending on the neutral point grounding conditions, the more severe stresses are either of continuous or temporary type.

Nominal system voltage U_n (kV)	6	10	11	13.8	15	20	22	30	33
Maximum system voltage U_m (kV)	7.2	11	12	15	17.5	22	24	33	36

Solidly earthed neutral point	6	9	10	12	15	18	21	27	30
-------------------------------	---	---	----	----	----	----	----	----	----

Grounding through impedance	9	<i>10 / 12</i>	12	15	18	<i>21 / 24</i>	24	33	36
-----------------------------	---	----------------	----	----	----	----------------	----	----	----

Isolated neutral point	9	12	15	<i>15 / 18</i>	18	24	27	36	---
------------------------	---	----	----	----------------	----	----	----	----	-----

Grounding through Petersen coil	9	12	15	18	21	<i>24 / 27</i>	27	---	---
---------------------------------	---	----	----	----	----	----------------	----	-----	-----

Note : values in italics need to be validated according to the actual earth fault factor or/and maximum fault duration.



Technical guide TRIDELTA VARISIL HE_e



TRIDELTA Parafoudres S.A.

5 RECOMMENDATIONS FOR INSTALLATION

To obtain an effective overvoltage protection, a minimum ratio of 1.4 shall be kept between the insulation level (BIL or LIWL) of the equipment and the protective level (Up) of the surge arrester so as to take into account the length of connection leads and possible higher discharge currents.

5.1 Length of connection leads

It is generally considered that the specific inductance of cables is around 1 $\mu\text{H}/\text{m}$.

Under a 40 kA (moderate value) lightning current impulse with 4/10 waveshape, the induced voltage U_i is then :

$$U_i = L \times di/dt = 1 \mu\text{H}/\text{m} \times 40 \text{ kA} / 4 \mu\text{s} \quad \text{i.e.} \quad U_i = 10 \text{ kV}/\text{m} \text{ of cable length}$$

For higher rates of rise or peak values (100 kA for instance), this value could be much greater (up to 25 kV/m or even more).

Recommendations

The connection length to be considered is the total length where the discharge current flows, i.e. the length of leads between the surge arrester and the connection point to the line, as well as between the surge arrester and the common connection point to earth.

In case of pole mounting, a usual practice is to connect the earth side of the surge arrester to the earth terminal of the transformer tank which is installed below. This shall be avoided in order to improve the efficiency of the overvoltage protection.


Instead, it is strongly recommended to connect the earth terminal of the transformer tank directly to the earthed fixing point of the surge arrester. At least 10 kV can be saved through this mode of connection to earth.

The shorter the connection leads, the better the overvoltage protection.

5.2 Foot resistance of the pole

Lightning conditions

If the ohmic resistance of the local earth is pretty high (mineral characteristics of the soil, lack of humidity), the voltage at the common earthing point of the transformer and the surge arrester reaches a very high value under lightning current impulses.



TRIDELTA Parafoudres S.A.

In this case, the major risk is flashover between the transformer tank and secondary windings (low voltage neutral point solidly earthed and distributed). Whatever the voltage rating, Distribution surge arresters are not intended to deal with such a phenomenon. However, an air spark gap connected between the LV neutral point and the transformer tank can solve this problem.

Fault conditions

In case of fault conditions due to the system itself (earth fault or insulation damage), the fault current value remains pretty low as limited by the high ohmic resistance of the earth.

In such a particular case, the surge arresters connected to the healthy phases will be more stressed on the voltage point of view. The highest possible rated voltage shall then be preferred (earth fault factor in the higher range of values, see clause 4.4.2).

As a conclusion, it is recommended that earthing resistances be as low as possible. In the particular case of pole mounting, the foot resistance shall not exceed 30 Ω.

5.3 Clearances


At the installation stage, clearances shall be respected so as to guarantee correct operation of VARISIL™ Type HE surge arresters.

The distances between the live parts of surge arresters and any earthed element (distance d) and between the live parts of surge arresters connected to adjacent phases (distance D) shall be carefully checked.

The table below advises clearances according to the rated voltage :

Type HE	05	06	09	10	12	15	18
d (mm)	46	50	86	89	100	132	150
D (mm)	50	54	92	96	108	143	163

Type HE	21	24	27	30	33	36
d (mm)	182	199	234	247	283	297
D (mm)	199	217	258	272	313	330





TRIDELTA Parafoudres S.A.

5.4 Electric connections

5.4.1 Connection to earth

For VARISIL™ Type HE surge arresters equipped with a disconnecting device ("SD" option), a copper lead (bare or insulated) with minimum cross section of 16 mm² must be used for connection to earth. A cable without terminal lug can be used on condition that the diameter does not exceed 15 mm : if so, it can be directly clamped using the metal clamp supplied.

This cable has to be flexible and long enough to provide the required clearance in case the disconnecter operates. It is also important to check that no element can interfere with the cable movement under such conditions.

For VARISIL™ Type HE surge arresters fitted with either "NO" option or "IF" option, connection to earth shall be made through earthing of the mounting bracket.

5.4.2 Connection to line

Line connection of VARISIL™ Type HE surge arresters must be achieved with either a copper or an aluminium cable (bare or insulated) with minimum cross section of 16 mm². This cable shall be connected to the M12 line terminal of the surge arrester. A cable without terminal lug can be used on condition that the diameter does not exceed 15 mm : if so, it can be directly clamped using the metal clamp supplied.

It is also recommended that no significant mechanical stress be applied to the surge arrester through excessive tension of the line cable.


5.4.3 Tightening torques

Torques applied to secure bolts and/or nuts of VARISIL™ Type HE surge arresters shall never exceed :

- 20 N.m for M12 terminals (applicable to all options)
- 30 N.m for M16 terminals ("IF" option)

5.5 Packaging

VARISIL™ Type HE surge arresters are packed inside individual boxes which can be easily opened with no need of tool.





TRIDELTA Parafoudres S.A.

5.5.1 Handling and transport

Thanks to the soft polymer housing, VARISIL™ Type HE surge arresters can be handled with less care than required for porcelain housed devices. However, attention must be paid to avoid damage to :

- the polymeric housing (cut or tear by sharp objects)
- connecting bolts and threaded studs
- accessories if any (insulating bracket, disconnecter or fault indicator)

If damaged, those parts may prevent correct mounting and/or operation. It is then recommended that the surge arresters remain inside their original box till installation.

5.5.2 Storage


Before use, the surge arresters shall be kept inside their original packaging. The boxes shall be stored in sheltered premises with ambient air temperature in the range $-20\text{ }^{\circ}\text{C}$ \div $+70\text{ }^{\circ}\text{C}$.

5.5.3 Maintenance

VARISIL™ Type HE surge arresters are maintenance free.

If surge arresters with disconnecting device are used ("SnD2" option), the operator is advised to perform periodical inspections on site in order to detect any surge arrester which would have disconnected (drop of the earth lead) and replace it as soon as possible.

In case of disconnection, the complete assembly (surge arrester element/insulating bracket/disconnection module) shall be changed.





TRIDELTA Parafoudres S.A.

6 STANDARDS AND TESTS

The VARISIL™ Type HE range fulfils all relevant IEC requirements.

6.1 Reference standard

IEC 60099-4 : "Surge Arresters / Part 4 : Metal-oxide surge arresters without gaps for a.c. systems" – 2nd edition.

6.2 Other applicable standards

ANSI/IEEE C62.11 : "IEEE standard for metal-oxide surge arresters for alternating current power circuits"

IEC 60071-1 : "Insulation co-ordination / Part 1 : Definitions, principles and rules"

IEC 60099-5 : "Surge Arresters / Part 5 : Selection and application recommendations"

IEC 60270 : "Partial discharge measurements"

IEC 60507 : "Artificial pollution tests on high-voltage insulators to be used on a.c. systems"


IEC 60815 : "Guide for the selection of insulators in respect of polluted conditions"

IEC 61109 : "Composite insulators for a.c. overhead lines with a nominal voltage greater than 1000 V – Definitions, test methods and acceptance criteria"

6.3 Type tests

All type tests have been performed in CESI (Centro Elettrotecnico Sperimentale Italiano) independent laboratory located in MILANO - Italy.

The table of the type tests which have been carried out and the corresponding tests are available upon request).



6.4 Standard acceptance tests

The table below reminds the standard acceptance tests which are required by IEC 60099-4 :

Test description	Clause of IEC 60099-4	Test samples
Measurement of the reference voltage at 1 mA peak AC	§ 9.2.1.a	Surge Arresters
Measurement of the lightning residual voltage at 10 kA	§ 9.2.1.b	MOV blocks
Measurement of the partial discharge level	§ 9.2.1.c	Surge Arresters

6.5 Routine tests

The table below indicates the routine tests which are performed during the manufacture of VARISIL™ Type HE surge arresters :

Test description	Clause of IEC 60099-4	Test samples
Measurement of the voltage at 1 mA	Not required	MOV blocks
Measurement of the lightning residual voltage at 10 kA	§ 9.1.b	MOV blocks
Verification of the energy absorption capability (2 shots at 300 A / 2000 µs)	Not required	MOV blocks
Measurement of the reference voltage at 1 mA peak AC	§ 9.1.a	Surge arresters
Verification of the absence from partial discharge and contact noise ⁽¹⁾	§ 9.1.c	Surge arresters

⁽¹⁾ This test is performed at the same time than the measurement of the reference voltage

