

Overview of FBX type test reports

1. 12 kV
 1.1 Switch-disconnector "C"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> • To the earth and between phases <ul style="list-style-type: none"> • 28 kV1mn 50HZ • 75 kV lightning impulse voltage • on the insulating distance <ul style="list-style-type: none"> • 32 kV1mn 50HZ • 85 kV lightning impulse voltage 	KEMA	02-1192	2002
Short time and peak withstand current, main circuit: <ul style="list-style-type: none"> • 20 kA 3s, 52 kAp • 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Short time and peak withstand current, earthing circuit <ul style="list-style-type: none"> • 20 kA 1s, 52 kAp • 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Interlock integrity	KEMA	39-02	2002
Earthing switch IEC 62271-102 class M0, E3 <ul style="list-style-type: none"> • Short time and peak withstand current, • 20 kA 3s, 52 kAp • short circuit making current, • 5 C at 52 kAp / 12 kV 	KEMA	42-02	2002
Making-breaking tests IEC 60265-1: cable switch class M1,E3 at 50Hz and 60Hz <ul style="list-style-type: none"> • TD1, TD2a, 630 A • TD4a 160 A • TD5 20 kA, 52 kAp • TD6a 600 A • TD6b 277 A 	KEMA	42-02	2002
Mechanical endurance: (manual) <ul style="list-style-type: none"> • Switch-disconnector 1000 operations(CO) • Earthing switch 1000 operations 	KEMA	42-02	2002
Mechanical endurance: (electrical) <ul style="list-style-type: none"> • Switch-disconnector 1000 operations(CO) 	AMT	AMTR06468-00	2006
Electrical endurance <ul style="list-style-type: none"> • Switch-disconnector E3 • 100 breaking at 630 A / 12 kV • 5 making operations • Earthing switch E3 • 5 making operations 	KEMA	42-02	2002
Temperature rise <ul style="list-style-type: none"> • 630 A 	KEMA	02-1192	2002
Measurement of resistance	KEMA	02-1192	2002
Partial discharge	KEMA	03-1161 see 66-03	2003
Degree of protection : IP <ul style="list-style-type: none"> • enclosure IP 67 • operating mechanism cover IP 3XC • cable compartment IP3XC 	EDF	HM22/07-508/1GB	2005
Internal arc: see section below			

ВЯРНО С ОРИГИНАЛА



780

1.2 Switch-disconnector with fuse "T1"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> To the earth and between phases <ul style="list-style-type: none"> 28 kV1mn 50HZ 75 kV lightning impulse voltage on the insulating distance <ul style="list-style-type: none"> 32 kV1mn 50HZ 85 kV lightning impulse voltage 	KEMA	02-1192	2002
Short time and peak withstand current main circuit: <ul style="list-style-type: none"> 20 kA 3s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Short time and peak withstand current, earthing circuit: <ul style="list-style-type: none"> 20 kA 1s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Interlock integrity	KEMA	39-02	2002
Earthing switch for transformer IEC 62271-102 <ul style="list-style-type: none"> Short time and peak withstand current, <ul style="list-style-type: none"> 5 kA 1s, 13 kAp short circuit making current, <ul style="list-style-type: none"> 13 kAp / 12 kV 5 making operations 	KEMA	40-02	2002
Making-breaking tests IEC 60265-1: transformer switch class M1,E1 at 50Hz/60Hz <ul style="list-style-type: none"> TD1, 200 A TD4a 60 A TD6a 200 A TD6b 87 A 	KEMA	40-02	2002
Making-breaking on combination <ul style="list-style-type: none"> IEC 60420 <ul style="list-style-type: none"> Td1 20kA (Short circuit current: TDisc) Td2 3,2kA (Integral of Joule maximal: TDiwmax) Td3 152A Td5 1100A (Take over: TDito) IEC 62271-105 <ul style="list-style-type: none"> Transfer current: TDitransfer 1500A 2000A 	KEMA KEMA KEMA	387-02 261-05 303-05	2002 2005 2005
Mechanical endurance : (manual) M1 <ul style="list-style-type: none"> Switch-disconnector 1000 operations(CO) Earthing switch 1000 operations 	KEMA	40-02	2002
Electrical endurance <ul style="list-style-type: none"> Switch-disconnector <ul style="list-style-type: none"> 10 breaking at Ir E1 100 breaking at Ir / 12 kV E3 5 making operations Earthing switch E3 <ul style="list-style-type: none"> 5 making operations 	KEMA on request	40-02	2002
Temperature rise <ul style="list-style-type: none"> 37,5A with fuses 63A 	KEMA	02-1192	2002
Measurement of resistance	KEMA	02-1192	2002
Partial discharge			
Degree of protection: IP <ul style="list-style-type: none"> enclosure IP 67 operating mechanism cover IP 3XC cable compartment IP3XC 	EDF	HM22/07-508/1GB	2005
Internal arc see section below			

ВЯРНО С ОРИГИНАЛА



781

1.3 Vacuum circuit breaker "T2"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> To the earth and between phases <ul style="list-style-type: none"> 28 kV1mn 50HZ 75 kV lightning impulse voltage on the insulating distance <ul style="list-style-type: none"> 32 kV1mn 50HZ 85 kV lightning impulse voltage 	KEMA	03-1161 see 66-03	2003
Short time and peak withstand current, main circuit: <ul style="list-style-type: none"> 20 kA 3s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	66-03	2003
Short time and peak withstand current, earthing circuit: <ul style="list-style-type: none"> 20 kA 1s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	66-03	2003
Interlock integrity	KEMA	66-03	2003
Earthing switch IEC 62271-102 <ul style="list-style-type: none"> Short time and peak withstand current, <ul style="list-style-type: none"> 16 kA 3s, 42 kAp short circuit making current, <ul style="list-style-type: none"> 5 C at 42 kAp / 12 kV 	KEMA	69-03	2003
Making-breaking tests IEC 60265-1: cable switch class M1,E3 at 50Hz and 60Hz <ul style="list-style-type: none"> TD1, TD2a, 630 A TD4a 160 A TD5 20 kA, 52 kAp TD6a 600 A TD6b 277 A 	KEMA	42-02	2002
Making-breaking tests: IEC 62271-100 circuit breaker class M1,E1 at 50Hz and 60Hz <ul style="list-style-type: none"> STC 42 kAp, 16 kA, 3s <ul style="list-style-type: none"> T10-30-60-100s-100a singlephase16kA double earthfault 13,9kA STC 52 kAp, 20 kA, 3s <ul style="list-style-type: none"> T10-30-60-100/SP 	KEMA	67-03	2003
Capacitive switching performance IEC62271-100 circuit breaker class C2 60Hz T60 9,6kA, CC1 8A, CC2 31,5A	KEMA	54-04	2004
Mechanical endurance: (electrical) <ul style="list-style-type: none"> Vacuum CB 2000 operations(CO) 	KEMA	68-03	2003
Mechanical endurance: (mechanical) <ul style="list-style-type: none"> Earthing switch 1000 operations Switch-disconnector 2000 operations(CO) 	KEMA	67-03	2003
Temperature rise <ul style="list-style-type: none"> 630 A 400 A in CB 	KEMA	69-03	2003
Measurement of resistance	KEMA	03-1161 see 66-03	2003
Partial discharge	KEMA	03-1161 see 66-03	2003
Degree of protection : IP <ul style="list-style-type: none"> enclosure IP 67 operating mechanism cover IP 3XC cable compartment IP3XC 			
Internal arc see section below			

ВЯРНО С ОРИГИНАЛА



782

1.3 Metering range "M"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none">To the earth and between phases<ul style="list-style-type: none">28 kV1mn 50HZ75 kV lightning impulse voltageon the insulating distance<ul style="list-style-type: none">32 kV1mn 50HZ85 kV lightning impulse voltage	AGS	E3-024/04 E3-005/04	2004
Short time and peak withstand current, main circuit: 21 kA 3s, 53 kAp <ul style="list-style-type: none">function M1(U-U)function M4(O-O)function M3(U-O)	IPH IPH IPH	1374.1000.3.354 1374.0086.4.094 1374.0086.4.093	2003 2004 2004
Short time current, earthing circuit <ul style="list-style-type: none">20 kA 1s16 kA 3s			
Temperature rise			
Partial discharge			
Degree of protection: IP <ul style="list-style-type: none">enclosure IP 3XC			
Internal arc see section below			

783

ВЯРНО С ОРИГИНАЛА



2. 17 kV

2.1 Switch-disconnector "C"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> To the earth and between phases <ul style="list-style-type: none"> 38 kV1mn 50HZ 95 kV lightning impulse voltage on the insulating distance <ul style="list-style-type: none"> 45 kV1mn 50HZ 110 kV lightning impulse voltage 	KEMA	02-1192	2002
Short time and peak withstand current, main circuit: <ul style="list-style-type: none"> 20 kA 3s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Short time and peak withstand current, earthing circuit: <ul style="list-style-type: none"> 20 kA 1s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Interlock integrity	KEMA	39-02	2002
Earthing switch IEC 62271-102 <ul style="list-style-type: none"> Short time and peak withstand current, <ul style="list-style-type: none"> 20 kA 3s, 52 kAp short circuit making current, <ul style="list-style-type: none"> 5 C at 52 kAp / 17,5 kV 	KEMA	42-02	2002
Making-breaking tests IEC 60265-1: cable switch class M1,E3 at 50Hz and 60Hz <ul style="list-style-type: none"> TD1, TD2a, 630 A TD4a 160 A TD5 20 kA, 52 kAp TD6a 600 A TD6b 277 A 	KEMA	42-02	2002
Mechanical endurance: (manual) <ul style="list-style-type: none"> Switch-disconnector 1000 operations(CO) Earthing switch 1000 operations 	KEMA	42-02	2002
Mechanical endurance: (electrical) <ul style="list-style-type: none"> Switch-disconnector 1000 operations(CO) 	AMT	AMTR06468-00	2006
Electrical endurance <ul style="list-style-type: none"> Switch-disconnector E3 100 breaking at 630 A / 17 kV 5 making operations Earthing switch E3 5 making operations 	KEMA	42-02	2002
Temperature rise <ul style="list-style-type: none"> 630 A 	KEMA	02-1192	2002
Measurement of resistance	KEMA	02-1192	2002
Partial discharge	KEMA	03-1161 see 66-03	2003
Degree of protection: IP <ul style="list-style-type: none"> enclosure IP 67 operating mechanism cover IP 3XC cable compartment IP3XC 	EDF	HM22/07-508/1GB	2005
Internal arc see section below			

ВЯРНО С ОРИГИНАЛА



784

2.2 Switch-disconnector with fuse "T1"


Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> To the earth and between phases <ul style="list-style-type: none"> 38 kV1mn 50HZ 95 kV lightning impulse voltage on the insulating distance <ul style="list-style-type: none"> 45 kV1mn 50HZ 110 kV lightning impulse voltage 	KEMA	02-1192	2002
Short time and peak withstand current main circuit: <ul style="list-style-type: none"> 20 kA 3s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Short time and peak withstand current, earthing circuit: <ul style="list-style-type: none"> 20 kA 1s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Interlock integrity	KEMA	39-02	2002
Earthing switch for transformer IEC 62271-102 <ul style="list-style-type: none"> Short time and peak withstand current, <ul style="list-style-type: none"> 5 kA 1s, 13 kAp short circuit making current, <ul style="list-style-type: none"> 13 kAp / 17,5 kV 5 making operations 	KEMA	40-02	2002
Making-breaking tests IEC 60265-1: transformer switch class M1,E1 at 50Hz/60Hz <ul style="list-style-type: none"> TD1, 200 A TD4a 60 A TD6a 200 A TD6b 87 A 	KEMA	40-02	2002
Making-breaking on combination <ul style="list-style-type: none"> IEC 60420 <ul style="list-style-type: none"> Td1 20kA (Short circuit current: TDisc) Td2 3,2kA (Integral of Joule maximal:TDiwmax) Td3 152A Td5 800A (Take over: TDito) IEC 62271-105 <ul style="list-style-type: none"> Transfer current: TDittransfer 1500A 2000A 	KEMA ?	44-02	2002
Mechanical endurance: (manual) <ul style="list-style-type: none"> Switch-disconnector 1000 operations (CO) Earthing switch 1000 operations 	KEMA	40-02	2002
Electrical endurance <ul style="list-style-type: none"> Switch-disconnector <ul style="list-style-type: none"> 10 breaking at Ir E1 100 breaking at Ir / 12 kV E3 5 making operations Earthing switch E3 <ul style="list-style-type: none"> 5 making operations 	KEMA on request	42-02	2002
Temperature rise <ul style="list-style-type: none"> 37,5A with fuses 63A 	KEMA	02-1192	2002
Measurement of resistance	KEMA	02-1192	2002
Partial discharge			
Degree of protection: IP <ul style="list-style-type: none"> enclosure IP 67 operating mechanism cover IP 3XC cable compartment IP3XC 	EDF	HM22/07-508/1GB	2005
Internal arc see section below			

2.3 Vacuum circuit breaker "T2"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> To the earth and between phases <ul style="list-style-type: none"> 38 kV1mn 50HZ 95 kV lightning impulse voltage on the insulating distance <ul style="list-style-type: none"> 45 kV1mn 50HZ 110 kV lightning impulse voltage 	KEMA	03-1161 see 66-03	2003
Short time and peak withstand current, main circuit: <ul style="list-style-type: none"> 20 kA 3s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	66-03	2003
Short time and peak withstand current, earthing circuit: <ul style="list-style-type: none"> 20 kA 1s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	66-03	2003
Interlock integrity	KEMA	66-03	2003
Earthing switch IEC 62271-102 <ul style="list-style-type: none"> Short time and peak withstand current, <ul style="list-style-type: none"> 16 kA 3s, 42 kAp short circuit making current, <ul style="list-style-type: none"> 5 C at 42 kAp / 17,5 kV 	KEMA	69-03	2003
Making-breaking tests IEC 60265-1: cable switch class M1,E3 at 50Hz and 60Hz <ul style="list-style-type: none"> TD1, TD2a, 630 A TD4a 160 A TD5 20 kA, 52 kAp TD6a 600 A TD6b 277 A 	KEMA	42-02	2002
Making-breaking tests IEC 62271-100: circuit breaker class M1,E1 at 50Hz and 60Hz <ul style="list-style-type: none"> STC 42 kAp, 16 kA, 3s T10-30-60-100s-100a singlephase 16kA double earthfault 13,9kA STC 52 kAp, 20 kA, 3s T10-30-60-100/SP 	KEMA	67-03	2003
	KEMA	54-04	2004
Capacitive switching performance IEC62271-100 circuit breaker class C2 60Hz T60 9,6kA, CC1 8A, CC2 31,5A	KEMA	68-03	2003
Mechanical endurance: (electrical) <ul style="list-style-type: none"> Vacuum CB 2000 operations(CO) 	KEMA	67-03	2003
Mechanical endurance: (mechanical) <ul style="list-style-type: none"> Earthing switch 1000 operations Switch-disconnector 2000 operations(CO) 	KEMA	69-03	2003
Temperature rise <ul style="list-style-type: none"> 630 A 400 A in CB 	KEMA	03-1161 see 66-03	2003
Measurement of resistance	KEMA	03-1161 see 66-03	2003
Partial discharge	KEMA	03-1161 see 66-03	2003
Degree of protection: IP <ul style="list-style-type: none"> enclosure IP 67 operating mechanism cover IP 3XC cable compartment IP3XC 			
Internal arc see section below			



2.4 Metering range "M"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> To the earth and between phases <ul style="list-style-type: none"> 38 kV1mn 50HZ 95 kV lightning impulse voltage on the insulating distance <ul style="list-style-type: none"> 45 kV1mn 50HZ 110 kV lightning impulse voltage 	AGS	E3-024/04 E3-005/04	2004
Short time and peak withstand current, main circuit: 21 kA 3s, 53 kAp <ul style="list-style-type: none"> function M1(U-U) function M4(O-O) function M3(U-O) 	IPH IPH IPH	1374.1000.3.354 1374.0086.4.094 1374.0086.4.093	2003 2004 2004
Short time current, earthing circuit: <ul style="list-style-type: none"> 20 kA 1s 16 kA 3s 			
Temperature rise			
Partial discharge			
Degree of protection: IP <ul style="list-style-type: none"> enclosure IP 3XC 			
Internal arc see section below			



787

3. 24 kV

3.1 Switch-disconnector "C"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> To the earth and between phases <ul style="list-style-type: none"> 50 kV1mn 50HZ 125 kV lightning impulse voltage on the insulating distance <ul style="list-style-type: none"> 60 kV1mn 50HZ 145 kV lightning impulse voltage 	KEMA	02-1192	2002
Short time and peak withstand current, main circuit: <ul style="list-style-type: none"> 20 kA 3s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Short time and peak withstand current, earthing circuit: <ul style="list-style-type: none"> 20 kA 1s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Interlock integrity	KEMA	39-02	2002
Earthing switch IEC 62271-102 <ul style="list-style-type: none"> Short time and peak withstand current, <ul style="list-style-type: none"> 20 kA 3s, 52 kAp short circuit making current, <ul style="list-style-type: none"> 5 C at 52 kAp / 24 kV 	KEMA	41-02	2002
Making-breaking tests IEC 60265-1: cable switch class M1,E3 at 50Hz and 60Hz <ul style="list-style-type: none"> TD1, TD2a, 630 A TD4a 160 A TD5 16 kA, 42 kAp TD6a 600 A TD6b 277 A 	KEMA	41-02	2002
Mechanical endurance: (manual) <ul style="list-style-type: none"> Switch-disconnector 1000 operations(CO) Earthing switch 1000 operations 	KEMA	41-02	2002
Mechanical endurance: (electrical) <ul style="list-style-type: none"> Switch-disconnector 1000 operations(CO) 	AMT	AMTR06468-00	2006
Electrical endurance <ul style="list-style-type: none"> Switch-disconnector E3 100 breaking at 630 A / 24 kV 5 making operations Earthing switch E3 5 making operations 	KEMA	41-02	2002
Temperature rise <ul style="list-style-type: none"> 630 A 	KEMA	02-1192	2002
Measurement of resistance	KEMA	02-1192	2002
Partial discharge	KEMA	03-1161 see 66-03	2003
Degree of protection: IP <ul style="list-style-type: none"> enclosure IP 67 operating mechanism cover IP 3XC cable compartment IP3XC 	EDF	HM22/07-508/1GB	2005
Internal arc see section below			

ВЯРНО С ОРИГИНАЛА



7.88

3.2 Switch-disconnector with fuse "T1"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> To the earth and between phases <ul style="list-style-type: none"> 50 kV1mn 50HZ 125 kV lightning impulse voltage on the insulating distance <ul style="list-style-type: none"> 60 kV1mn 50HZ 145 kV lightning impulse voltage 	KEMA	02-1192	2002
Short time and peak withstand current main circuit: <ul style="list-style-type: none"> 20 kA 3s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Short time and peak withstand current, earthing circuit: <ul style="list-style-type: none"> 20 kA 1s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	39-02	2002
Interlock integrity	KEMA	39-02	2002
Earthing switch for transformer IEC 62271-102 <ul style="list-style-type: none"> Short time and peak withstand current, <ul style="list-style-type: none"> 5 kA 1s, 13 kAp short circuit making current, <ul style="list-style-type: none"> 13 kAp / 24 kV 5 making operations 	KEMA	40-02	2002
Making-breaking tests IEC 60265-1: transformer switch class M1,E1 at 50Hz/60Hz <ul style="list-style-type: none"> TD1, 200 A TD4a 60 A TD6a 200 A TD6b 87 A 	KEMA	40-02	2002
Making-breaking on combination <ul style="list-style-type: none"> IEC 60420 <ul style="list-style-type: none"> Td1 16kA (Short circuit current : TDisc) Td2 3,2kA (Integral of Joule maximal:TDiwmax) Td3 152A Td5 800A (Take over: TDito) IEC 62271-105 <ul style="list-style-type: none"> Transfer current: TDittransfer 1500A 2000A 	KEMA	43-02	2002
Mechanical endurance : (manual) <ul style="list-style-type: none"> Switch-disconnector 1000 operations(CO) Earthing switch 1000 operations 	KEMA	40-02	2002
Electrical endurance <ul style="list-style-type: none"> Switch-disconnector <ul style="list-style-type: none"> 10 breaking at Ir E1 100 breaking at Ir / 24 kV E3 5 making operations Earthing switch E3 <ul style="list-style-type: none"> 5 making operations 	KEMA on request	43-02	2002
Temperature rise <ul style="list-style-type: none"> 37,5A with fuses 63A 	KEMA	02-1192	2002
Measurement of resistance	KEMA	02-1192	2002
Partial discharge			
Degree of protection: IP <ul style="list-style-type: none"> enclosure IP 67 operating mechanism cover IP 3XC cable compartment IP3XC 	EDF	HM22/07-508/1GB	2005
Internal arc see section below			

ВЯРНО С ОРИГИНАЛА



3.3 Vacuum circuit breaker "T2"

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none"> To the earth and between phases <ul style="list-style-type: none"> 50 kV1mn 50HZ 125 kV lightning impulse voltage on the insulating distance <ul style="list-style-type: none"> 60 kV1mn 50HZ 145 kV lightning impulse voltage 	KEMA	03-1161 see 66-03	2003
Short time and peak withstand current, main circuit: <ul style="list-style-type: none"> 20 kA 3s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	66-03	2003
Short time and peak withstand current, earthing circuit: <ul style="list-style-type: none"> 20 kA 1s, 52 kAp 16 kA 3s, 42 kAp 	KEMA	66-03	2003
Interlock integrity	KEMA	66-03	2003
Earthing switch IEC 62271-102 <ul style="list-style-type: none"> Short time and peak withstand current, <ul style="list-style-type: none"> 16 kA 3s, 42 kAp short circuit making current, <ul style="list-style-type: none"> 5 C at 42 kAp / 24 kV 	KEMA	69-03	2003
Making-breaking tests IEC 60265-1: cable switch class M1,E3 at 50Hz and 60Hz <ul style="list-style-type: none"> TD1, TD2a, 630 A TD4a 160 A TD5 20 kA, 42 kAp TD6a 600 A TD6b 277 A 	KEMA	41-02	2002
Making-breaking tests IEC 62271-100: circuit breaker class M1,E1 at 50Hz and 60Hz <ul style="list-style-type: none"> STC 42 kAp, 16 kA, 3s T10-30-60-100s-100a singlephase16kA double earthfault 13,9kA STC 52 kAp, 20 kA, 3s T10-30-60-100/SP 	KEMA	67-03	2003
	KEMA	54-04	2004
Capacitive switching performance IEC62271-100 circuit breaker class C2 60HzT60 9,6kA, CC1 8A, CC2 31,5A	KEMA	68-03	2003
Mechanical endurance : (electrical) <ul style="list-style-type: none"> Vacuum CB 2000 operations(CO) 	KEMA	67-03	2003
Mechanical endurance : (mechanical) <ul style="list-style-type: none"> Earthing switch 1000 operations Switch-disconnector 2000 operations(CO) 	KEMA	69-03	2003
Temperature rise <ul style="list-style-type: none"> 630 A 400 A in CB 	KEMA	03-1161 see 66-03	2003
Measurement of resistance	KEMA	03-1161, see 66-03	2003
Partial discharge	KEMA	03-1161 see 66-03	2003
Degree of protection: IP <ul style="list-style-type: none"> enclosure IP 67 operating mechanism cover IP 3XC cable compartment IP3XC 			
Internal arc see section below			

ВЯРНО С ОРИГИНАЛА



790

3.4 Metering range

Tests in accordance with IEC 60694 and 60298 / 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Dielectric : <ul style="list-style-type: none">To the earth and between phases<ul style="list-style-type: none">50 kV1mn 50HZ125 kV lightning impulse voltageon the insulating distance<ul style="list-style-type: none">60 kV1mn 50HZ145 kV lightning impulse voltage	AGS	E3-024/04 E3-005/04	2004
Short time and peak withstand current, main circuit: 21 kA 3s, 53 kAp <ul style="list-style-type: none">function M1(U-U)function M4(O-O)function M3(U-O)	IPH IPH IPH	1374.1000.3.354 1374.0086.4.094 1374.0086.4.093	2003 2004 2004
Short time current, earthing circuit: <ul style="list-style-type: none">20 kA 1s16 kA 3s			
Temperature rise			
Partial discharge			
Degree of protection: IP <ul style="list-style-type: none">enclosure IP 3XC			

ВЯРНО С ОРИГИНАЛА



791

4. Internal Arc Test - Main Range

Tests in accordance with 62271-200

DESIGNATION	Laboratory	Report N°	Year test
IAC AF 16kA-1s Criteria 1-5 In the gas tank – with simplified gas cooler	ZKU	06-131	2006
IAC AF 20kA-1s Criteria 1-5 In the gas tank – with gas cooler	ZKU	06-035	2006
IAC AFL 16kA-1s Criteria 1-5 In the gas tank – with exhaust duct	ZKU	06-093	2006
IAC AFL 20kA-1s Criteria 1-5 In the gas tank – with exhaust duct	ZKU	06-094	2006
IAC AFL 16kA-1s Criteria 1-5 In the cable compartment – with exhaust duct	ZKU	06-057	2006
IAC AFL 20kA-1s Criteria 1-5 In the cable compartment – with exhaust duct	ZKU	06-058	2006
IAC AFL 20kA-1s Criteria 1-5 With chimney	IPH	1803.2080405.156	2008
IAC AFL 20kA-1s Criteria 1-5 In the gas tank – with gas cooler	IPH	2228.20800724.583	2008
IAC AF 16kA-1s Criteria 1-5 In the cable compartment – with closed bottom	IPH	2228.20800724.584	2008

5. MV/LV Stations

Tests in accordance with IEC 61330

DESIGNATION	Laboratory	Report N°	Year test
Acc. IEC61330 in MV/LV stations Annex A, 16kA-1s, Criteria 1-6	IPH	1374.0877.1.39	2001

6. Metering range

Tests in accordance with IEC 62271-200

DESIGNATION	Laboratory	Report N°	Year test
IAC AF 21kA-1s Criteria 1-5 In a M1 (U-U) metering panel	IPH	1374.0086.4.095	2004
IAC AF 21kA-1s Criteria 1-5 In a M4 (O-O) metering panel	IPH	1374.0086.4.096	2004

7. Global Type Test List

8. Other Tests

Tests in accordance with 62271-200

DESIGNATION	Laboratory	Report N°	Year test
Pressure withstand of tank 5 functions	MEVEL	AMTR06469-00	2006
Short time current on busbar 21KA 3s 52,5KAp 5 functions	CERDA	6193	2008

9. Overview of substations tests

Tests in accordance with IEC IEC62271-202

DESIGNATION	Laboratory	Manufacturer	Type	Client	Report N°	Year test
Acc. IEC62271-202 in MV/LV stations §6.8, 20kA-1s Criteria 1-6	IPH	Scheidt	NZ150/300	RWE/EnBW	2228.1292.7.529	2007
			NZ173/283	E.ON/EnBW	2228.1292.7.530	
			NZ210/290	EnBW	1352.2090275.0114	2009
			NZ190/210	EnBW	1352.2090275.0115	
			NZ210/240 IAC B	EnBW	1352.2090275.0116	
	NZ210/240 IAC A	EnBW	XZ268L015 ⁴⁾			
	NZ130/290 ¹⁾	E.ON, Vattenfall	XZ268L017 ³⁾	2010		
	BEK 250-300 IAC B	„Stadtwerke“	XZ268L018 ⁴⁾			
	BEK 250-300 IAC A	„Stadtwerke“	XZ268L019 ⁴⁾	2007		
	UK1100/1L	E.ON/HEW	1352.2100474.0261			
UKL2817	E.ON	2228.1291.7.649	2008			
UK3015	RWE	2228.1291.7.650				
UK2820-L	EnBW	2228.1291.7.651	2009			
UF2922	EnBW	1528.2080.590.343				
UK1700-23	EnBW	1528.2080.590.344				
UK2820	E.ON	1528.2080.590.345	2008			
UK1700-15	E.ON	1528.2080.590.346				
UK 1700-15 ²⁾ IAC B	E.ON/ RWE/ Vattenfall	3239.2090728.0691	2009			
UF 2536	„Stadtwerke“	3239.2090728.0690				
Acc. IEC62271-202 in MV/LV stations §6.8, 16kA-1s Criteria 1-6	AREVA	AREVA	CLIPPER C27		2228.1291.7	2007
			CLIPPER M		1803.2080405.154	2008
	Gräper	Gräper	HKP	E.ON	1803.2080405.155 ⁴⁾	2008
			MKP 250/400	E.ON	1549.2080426.182	2008
			GPK S1	E.ON	1549.2080426.185	
ZKU	ELBAG	PVTSM-T-C2-250		1549.2080426.186	2010	
		NZ240/310	E.ON	1197.2101067 ³⁾		
		NDV400.6	RWE	1226.2111229.0680	2011	
		SGB Lahmeyer			08-056	2008

1) Analogies possible for NZ145/335 (E.ON, ÜWL) and for NZ 240/310 (E.ON, RWE, Vattenfall)

2) Modified: without 2nd cooling system

3) Under full customer responsibility, test report belongs to customer

4) 21kA/1s

ВЯРНО С ОРИГИНАЛА

793



copy copy
MEVEL
Medium Voltage Electrical Laboratory

Bld de la Résistance
BP 84019
71040 MACON Cedex 9
France
Tel : 33 (0) 3 85 29 35 00
Fax : 33 (0) 3 85 29 36 36

TEST REPORT **AMTR07497-00**

Test object Extensibility components for metal enclosed switchgear
Type FBX E
Manufacturer AREVA T&D
Site of tests MEVEL dielectric test laboratory
Date of tests 17, 18/12/2007
Test specifications IEC 62271-200 (2003)
Tests performed Lightning impulse and power frequency voltage dielectric withstand test
Conformity Requirements according to above specification are met
Issued to AREVA T&D Issue date 20/01/2008
Bd de la Résistance
71040 MACON CEDEX 9



На основание чл. 2
от ЗЗЛД

La reproduction de ce rapport n'est autorisée que sous la forme de fac-similé photographique intégral.
Reproduction of the contents of this report is not allowed in any other form than a complete copy.
L'accréditation COFRAC atteste de la compétence du laboratoire pour les seuls essais couverts par l'accréditation.
COFRAC accreditation proves the laboratory's competence only for the tests included in the scope of accreditation.

DEM 510 01B

Page 1 of 19

ВЯРНО С ОРИГИНАЛА



706

pdf copy



Bld de la Résistance
BP 84019
71040 MACON Cedex 9
France
Tel : 33 (0) 3 85 29 35 00
Fax : 33 (0) 3 85 29 36 36

TEST REPORT

AMTR07498-00

Test object Extensibility components for metal enclosed switchgear

Type FBX E

Manufacturer AREVA T&D

Site of tests MEVEL dielectric test laboratory

Date of tests 17, 18/01/2008

Test specifications IEC 62271-200 (2003)

Tests performed lightning impulse and power frequency voltage dielectric withstand test

Conformity Requirements according to above specification are met

Issued to AREVA T&D Issue date 10/01/2008
 Bd de la Résistance
 71040 MACON CEDEX 9



Laboratoire d'Essai
accrédité N° 1.1654
Portée communiquée
sur demande


На основание чл. 2
от ЗЗЛД

La reproduction de ce rapport n'est autorisée que sous la forme de fac-similé photographique intégral
Reproduction of the contents of this report is not allowed in any other form than a complete copy.

L'accréditation COFRAC atteste de la compétence du laboratoire pour les seuls essais couverts par l'accréditation.
COFRAC accreditation proves the laboratory's competence only for the tests included in the scope of accreditation.

DEM 610 01B

ВЯРНО С ОРИГИНАЛА



795

[Handwritten signature]

zkratovna
Zkušebnictví, a. s.
Podnikatelská 547, 190 11 Praha 9, Běchovice, Czech Republic

TEST REPORT

No. 06 - 057

Test object : High-voltage metal-enclosed switchgear and controlgear
Type : FBX-C/24-16/C-C-T1
Serial No. : FBX—06 12 012 / AMT

Ratings
Rated voltage : 24 kV
Rated normal current : 630 A
Rated frequency : 50 Hz

Manufacturer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Test performed : Arcing due to an internal fault

Customer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Date of test : 16.05. 2006

ELECTRON


[Handwritten signature]

THIS TEST REPORT IS CONFIDENTIAL AND SHALL NOT BE PASSED OVER OR TRANSFERRED TO ANY THIRD PARTY WITHOUT WRITTEN APPROVAL OF THE CUSTOMER.
WITHOUT THE WRITTEN APPROVAL OF THE TESTING LABORATORY ZKRATOVNA SHALL NOT BE REPRODUCED EXCEPT IN FULL.

Number of issued copies: 2
Praha 9, Běchovice

Copy No.: **E**

На основании чл. 2
от 33ЛД



e-version

[Handwritten signature]

[Handwritten signature]
796

copy



Bld de la Résistance
BP 84019
71040 MACON Cedex 9
France
Tel : 33 (0) 3 85 29 35 00
Fax : 33 (0) 3 85 29 36 36

TEST REPORT AMTR07499-00

Test object Extensibility components for metal enclosed switchgear

Type FBX E

Manufacturer AREVA T&D

Site of tests MEVEL dielectric test laboratory

Date of tests 22/01/2008

Test specifications IEC 62271-200 (2003)

Tests performed lightning impulse and power frequency voltage dielectric withstand test

Conformity Requirements according to above specification are met

Issued to AREVA T&D Issue date 20/01/2008
 Bd de la Résistance
 71040 MACON CEDEX 9



Laboratoire d'Essai
accrédité N° 1.1654
Portée communiquée
sur demande

На основание чл. 2
от ЗЗЛД

La reproduction de ce rapport n'est autorisée que sous la forme de fac-similé photographique intégral.
Reproduction of the contents of this report is not allowed in any other form than a complete copy.

L'accréditation COFRAC atteste de la compétence du laboratoire pour les seuls essais couverts par l'accréditation.
COFRAC accreditation proves the laboratory's competence only for the tests included in the scope of accreditation.

ВЯРНО С ОРИГИНАЛА



707

Ar0_0V1

RAPPORT D'ESSAIS
TEST REPORT

N° 6006

Destinataire To	AREVA T&D Mâcon
Appareil Tested equipment	Tableau FBX, type IS C-C-T2 compact Switchboard FBX, type IS C-C-T2 compact
	Ur = 24 kV I _r = 630A fr = 50 Hz
Constructeur Manufacturer	AREVA T&D Mâcon

Objet des essais
Purpose of tests Essais au courant de courte durée et la valeur de crête du courant admissible
Short-time withstand current and peak withstand current tests

Lieu des essais
Site of tests Laboratoire d'Essais de Puissance du CERDA
CERDA High Power Laboratories

Date(s) des essais
Date(s) of tests 16 octobre 2007
October, 16th 2007

Essais effectués conformément aux normes : CEI 62271-200 Ed 1 2003/11 et CEI 60694 Ed2.2 2002/01
Tests performed according to : IEC 62271-200 Ed 1 2003/11 and IEC 60694 Ed2.2 2002/01

Assistait aux essais
Tests witnessed by Mr D. THOMAS

Rapport composé de 8 pages et 10 feuillets joints
Report made of pages and attached leaflets

Date d'émission
Date of issue 7.11.2007

*La reproduction de ce rapport n'est autorisée que sous la forme intégrale
This record of proving test shall only be reproduced in the complete form*

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА

798

zkratovna
Zkušebnictví, a. s.

Podnikatelská 547, 190 11 Praha 9, Běchovice, Czech Republic

TEST REPORT

No. 08 - 006

Test object : High-voltage metal-enclosed switchgear and controlgear
Type : FBX-C/24-20/CCT1
Serial No. : 07/69Y19-05

Ratings
Rated voltage : 24 kV
Rated normal current : 630 A
Rated frequency : 50 Hz

Manufacturer : SUZHOU Areva T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Test performed : Arcing due to an internal fault

Customer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Date of test : 04.02. 2008

THIS TEST REPORT IS CONFIDENTIAL AND SHALL NOT BE PASSED OVER OR TRANSFERRED TO ANY THIRD PARTY WITHOUT WRITTEN APPROVAL OF THE CUSTOMER.
WITHOUT THE WRITTEN APPROVAL OF THE TESTING LABORATORY ZKRATOVNA SHALL NOT BE REPRODUCED EXCEPT IN FULL.


Praha 9, Běchovice

27.2.2008

Tested by:


На основании чл. 2
от 33ЛД

Copy No.: E



e-version

[Handwritten signature]



Bld de la Résistance
BP 84019
71040 MACON Cedex 9
France
Tel: 33 (0) 3 85 29 35 00
Fax: 33 (0) 3 85 29 36 36

TESTS REPORT AMTR06466-01

Object tested Gas Insulated Compact Switchboard
Type FBX-C / 17-20 / C-C-T1
Manufacturer AREVA T&D
Test Location Temperature Rise Laboratory
Test date: 1st March 2006
Reference Standards IEC 62271-200 (11/2003) §6.4 and 6.5 and specification
TST 19-2 (11.02) §1.3.1 and Appendix C Method A
Tests carried out Measurement of the main circuit resistance
Temperature rise test
Conformity Results comply with the reference standards
Issued to Areva T&D 01 June 2006



Accredited Test
Laboratory No. 1.1654

Scope communicated
by request

На основание чл. 2
от ЗЗЛД

The reproduction of this report shall only be authorised under the form of an integral photographic facsimile.
COFRAC accreditation attests to the competence of the laboratory solely for the tests covered by the accreditation.

ВЯРНО С ОРИГИНАЛА



[Handwritten signature]

[Handwritten initials]



Bld de la Résistance
BP 84019
71040 MACON Cedex 9
France
Tel : 33 (0) 3 85 29 35 00
Fax : 33 (0) 3 85 29 36 36

TEST REPORT

AMTR07495-00

Test object	Metal enclosed cubicle Functional unit feeder with current switch-fuse combination
Type	FBX CCT1
Manufacturer	AREVA T&D
Site of tests	MEVEL temperature rise laboratory
Date of tests	28/02 to 4/03/2005
Test specifications	IEC 60694 2002, 62271-200 2003
Tests performed	Temperature rise test
Conformity	Requirements according to above specification are met
Issued to Areva T&D	Issue date 23/10/2007

На основание чл. 2
от ЗЗЛД


La reproduction de ce rapport n'est autorisée que sous la forme de fac-similé photographique intégral.
Reproduction of the contents of this report is not allowed in any other form than a complete copy.

ВЯРНО С ОРИГИНАЛА



801

pdf copy



Bld de la Résistance
BP 84019
71040 MACON Cedex 9
France
Tel : 33 (0) 3 85 29 35 00
Fax : 33 (0) 3 85 29 36 36

TEST REPORT

AMTR08509-00

Test object: Metal enclosed switchgear
 Type: FBX C C
 Manufacturer: Areva T&D
 Site of tests: Temperature-rise tests laboratory
 Date of tests: 17/03/2008
 Test specifications: IEC 62271-200 (11-2003), 62271-1 (10-2007)
 Tests performed: Temperature rise test
 Conformity: Requirements according to above specification are met

Issued to: AREVA T&D
 Bd de la Résistance
 71040 MACON CEDEX 9

Issue date 03/06/2008



На основание чл. 2
от ЗЗЛД

La reproduction de ce rapport n'est autorisée que sous la forme de fac-similé photographique intégral.
Reproduction of the contents of this report is not allowed in any other form than a complete copy.

L'accréditation COFRAC atteste de la compétence du laboratoire pour les seuls essais couverts par l'accréditation.
COFRAC accreditation proves the laboratory's competence only for the tests included in the scope of accreditation.

DEM 510 028

Page 1 of 10

ВЯРНО С ОРИГИНАЛА



602

Sede Central - Egeitza Nagusia - Headquarters
C/ Geldo - Parque Tecnológico de Bizkaia
Edificio 700
48160-Derio (Bizkaia) Spain
Tel. +34 94 607 33 00 (centralita)
Fax. +34 94 607 33 49

Burtzeña
Vega de Tapia, s/n
48903 Burtzeña-Barakaldo (Bizkaia) Spain
Tel. +34 94 607 34 90
Fax. +34 94 607 34 95

Zamudio
Parque Tecnológico
Edificio 101
48170 Zamudio (Bizkaia) Spain

http://www.labein.es
e-mail: labein@labein.es

50
Vicente Fox
Aniversario

labein
tecnalia

ELECTRICAL EQUIPMENT LABORATORY
ENERGY UNIT

Test report

No B125-07-BT-EE-01

Page 1 of 11

Short-time and peak withstand current and short-circuit
making tests on the earthing switch

TEST OBJECT: 24 kV Gas-filled metal-enclosed switchgear with SF6
DESIGNATION: FBX-C/24-20/C-C-T1
REQUESTED BY: AREVA T&D
Boulevard de la Résistance – BP 84019
71040 Mâcon Cedex 9 - France
MANUFACTURER: AREVA T&D
STANDARD: IEC 62271-200:2003
IEC 62271-102:2003
RECEPTION DATE: June 28th 2007
TESTS DATE: July 2nd to 6th 2007

The test object has been subjected to the tests required by the applicant, applying
the procedures specified in the standard indicated before.

THE PRESENT REPORT CONSISTS OF:

No of pages: 11 (and annex of 9)
Photographs: Annex
Oscillograms: Annex

На основание чл. 2
от ЗЗЛД


Este documento es una copia en papel del informe original,
por petición del solicitante

Barakaldo, July 16th 2007

ENAC
ENSAYOS
Nº 4LE148

- * The present report refers only and exclusively to the sample tested and at the moment and conditions in which the measures were made.
- * The partial reproduction of the present document is categorically forbidden without the permission in writing of LABEIN.

ВЯРНО С ОРИГИНАЛА



te+C

Testing, Evaluation & Conformity Services

LABEIN FOUNDATION - ENERGY UNIT
ELECTRICAL EQUIPMENT LABORATORY

Test report

LABEIN-Tecnalia

• Parque Tecnológico de Bizkaia
C/ Geldo - Edificio 700
48160 - Derio (Bizkaia)
Tel. +34 94 404 14 44
Fax +34 94 404 14 45

• Vega de Tapia, s/n
48903 - Burtzena (Bizkaia)
Tel. +34 94 607 34 90
Fax +34 94 607 34 95

• Parque Tecnológico de Bizkaia
Edificio 101
48170 - Zamudio (Bizkaia)

• Pol. Industrial Easabe
Pabellón E-4
20500 - Aratsabaleta (Gipuzkoa)

No CE35-09-AD-03

Page 1 of 5

Short-time and peak withstand current test

<http://www.te-c.es>

TEST OBJECT: 24 kV / 630 A SF6-filled metal-enclosed switchgear

DESIGNATION: FBX-C/24-20/CCT1 with aluminium bushings

REQUESTED BY: AREVA T&D
Boulevard de la Résistance – BP 84019
71040 Mâcon Cedex 9 - France

MANUFACTURER: AREVA T&D

STANDARD: IEC 62271-200:2003

RECEPTION DATE: January 26th 2009

TESTS DATE: January 27th to 29th 2009

The test object has been subjected to the tests required by the applicant, applying the procedures specified in the standard indicated before.

THE PRESENT REPORT CONSISTS OF:

No of pages: 5 (and annex of 4)

Drawings: Annex

Photographs: Annex

Oscillogram: Annex

На основание чл. 2
от ЗЗЛД

This document is a copy in pdf of the original Report,
as requested by the client
Barakaldo, February 3rd 2009

ENAC
E N S A Y O S
Nº 4/LE148

- * The present report refers only and exclusively to the sample tested and at the moment and conditions in which the measures were made.
- * The partial reproduction of the present document is categorically forbidden without the permission in writing of LABEIN.

ВЯРНО С ОРИГИЛАЛА



509

Report: Genciel - Fundación Labeint - C/AS: 75377

LABEIN-Tecnalia


• Parque Tecnológico de Bizkaia
C/ Galdos - Edificio 700
48160 - Derio (Bizkaia)
Tel. +34 94 404 14 44
Fax +34 94 404 14 45

• Vega de Tapia, s/n
48903 - Burtzeña (Bizkaia)
Tel. +34 94 607 34 90
Fax +34 94 607 34 95

• Parque Tecnológico de Bizkaia
Edificio 101
48170 - Zamudio (Bizkaia)

• Pol. Industrial Basabe
Pabellón E-3
20500 - Aretxabaleta (Gipuzkoa)

<http://www.te-c.es>



Testing, Evaluation & Conformity Services

**LABEIN FOUNDATION – ENERGY UNIT
ELECTRICAL EQUIPMENT LABORATORY**

Test report

No CE35-09-AD-04

Page 1 of 5

Short-time and peak withstand current test

TEST OBJECT: 24 kV / 630 A SF6-filled metal-enclosed switchgear
DESIGNATION: FBX-C/24-20/CCT1 with aluminium bushings
REQUESTED BY: AREVA T&D
Boulevard de la Résistance – BP 84019
71040 Mâcon Cedex 9 - France
MANUFACTURER: AREVA T&D
STANDARD: IEC 62271-200:2003
RECEPTION DATE: January 26th 2009
TESTS DATE: January 27th to 29th 2009

The test object has been subjected to the tests required by the applicant, applying the procedures specified in the standard indicated before.

THE PRESENT REPORT CONSISTS OF:

No of pages: 5 (and annex of 4)
Drawings: Annex
Photographs: Annex
Oscillogram: Annex

На основание чл. 2
от ЗЗЛД

This document is a copy in pdf of the original Report,
as requested by the client
Barakaldo, February 3rd 2009



* The present report refers only and exclusively to the sample tested and at the moment and conditions in which the measures were made.
* The partial reproduction of the present document is categorically forbidden without the permission in writing of LABEIN.

ВЯРНО С ОРИГИНАЛА



tecnologia mas Confianza

Basabe Social Fundacion Labeina • 0548275767

LABELIN-Tecnalia

• Parque Tecnológico de Bizkaia
C/ Galdio - Edificio 700
48160 - Derio (Bizkaia)
Tel. +34 94 404 11 44
Fax +34 94 404 14 45

• Vega de Tapia, s/n
48905 - Burtzena (Bizkaia)
Tel. +34 94 607 34 90
Fax +34 94 607 34 95

• Parque Tecnológico de Bizkaia
Edificio 101
48170 - Zamudio (Bizkaia)

• Pol. Industrial Basabe
Pabellón I-3
20500 - Aretxabaleta (Gipuzkoa)

<http://www.te-c.es>

te+c

Testing, Evaluation & Conformity Services

LABELIN FOUNDATION - ENERGY UNIT

ELECTRICAL EQUIPMENT LABORATORY

Test report

No CE35-09-AD-05

Page 1 of 5

Short-time and peak withstand current test

TEST OBJECT: 24 kV / 630 A SF6-filled metal-enclosed switchgear

DESIGNATION: FBX-C/24-20/CCT1 with aluminium bushings

REQUESTED BY: AREVA T&D
Boulevard de la Résistance – BP 84019
71040 Mâcon Cedex 9 - France

MANUFACTURER: AREVA T&D

STANDARD: IEC 62271-200:2003

RECEPTION DATE: January 26th 2009

TESTS DATE: January 27th to 29th 2009

The test object has been subjected to the tests required by the applicant, applying the procedures specified in the standard indicated before.

THE PRESENT REPORT CONSISTS OF:

No of pages: 5 (and annex of 4)

Drawings: Annex

Photographs: Annex

Oscillogram: Annex


На основание чл. 2
от ЗЗЛД

This document is a copy in pdf of the original Report,
as requested by the client
Barakaldo, February 3rd 2009

ENAC
E N S A Y O S
Nº 47EJ48

- * The present report refers only and exclusively to the sample tested and at the moment and conditions in which the measures were made.
- * The partial reproduction of the present document is categorically forbidden without the permission in writing of te LABELIN.

ВЯРНО С ОРИГИНАЛА



LABELIN FOUNDATION - DERIO - 944041144

Client AREVA T&D – MACON (France)

Tested equipment Three-phase switchgear (RMU), for medium voltage, composed by No.3 sections, designed: FBX-C / 24-12 / C-C-T1

Tests carried out Temperature-rise test

Standards/Specifications IEC 62271-200 (2003-11) and IEC 60265-1 (1998-1)

Test date from March 13, 2007 to March 15, 2007

The results reported in this document relate only to the tested equipment.
 Partial reproduction of this document is permitted only with the written permission from CESI.

PUBBLICATO A7007210 (PAD - 948302)

No. of pages 15 **No. of pages annexed**

Issue date July 26, 2007

Prepared Unit LABORATORIES - M. Levati

Verified Unit LABORATORIES - A. Geroli

Approved Area COMPONENTS - V. Scarioni

На основание чл. 2
от ЗЗЛД

CESI Via R. Rubattino 54 Capitale sociale € 550.000 Euro
 Centro Elettrotecnico 20134 Milano - Italia interamente versato
 Sperimentale Italiano Telefono +39 022125.1 Codice fiscale e numero
 Giacinto Motta spa Fax +39 0221255440 Iscrizione CCIAA 00793580150

ВЯРНО С ОРИГИНАЛА

REGISTRO IMPRESE DI MILANO
 Sezione Ordinaria
 N. R.E.A. 429222
 P.I. IT00793580150
 ПЛОВДИВ
 Е А Д



PRODUIT FABRIQUE SOUS SYSTÈME DE MANAGEMENT DE LA QUALITÉ CERTIFIÉ AFAQ ISO 9001/2000
PRODUCT MADE THROUGH AFAQ ISO 9001/2000 CERTIFIED PROCESS

RAPPORT D'ESSAIS / TEST REPORT HM21/07-301/1

Appareil / Apparatus : Tableau HTA insensible à son environnement FBX
Tension assignée / Rated voltage : 24 kV
Courant assigné / Rated current : 400 A
Fréquence assignée / Rated frequency : 50 Hz
Constructeur / Manufacturer : ALSTOM

Objet / Object : Acceptation de type – Défauts internes/ Type tests- Internal faults
Demandeur des essais / Tested for : EGS/DRE/MER
Date(s) et lieu des essais / Date(s) and place of tests : du 17 au 25/04/2003
Les Renardières - L.M.E. - SEMT
Essais réalisés suivant / Tests carried out according to : § 6.107 de la HN64-S-52 de Novembre 2002

Le Rapport est composé des documents suivants / The report comprises the following documents :

- caractéristiques de l'appareil / characteristics of the apparatus : page 3
 - liste des essais effectués / list of tests performed : page 4
 - conditions des essais / tests conditions : pages 5 à 9
 - tableaux et résultats d'essais / tables and tests results : pages 10 à 13
 - photographies / photographs n° : pages 17 à 26
 - oscillogrammes / oscillograms n° : 1001 à 1007
- Ce Rapport comprend / This report includes : 26 pages + 26 feuilles jointes/appended sheets.

« Seule la version française de ce rapport fait foi / The english version of this report is a translation of the original french version. »

La reproduction de ce Rapport d'Essais n'est autorisée que sous la forme de fac-similé photographique intégral, avec l'accord écrit du Laboratoire et du Demandeur des essais.
Reproduction of this Test Report is authorized only in the form of a complete photographic facsimile with the written authorization of the Laboratory and the Applicant.

На основание чл. 2
от ЗЗЛД

На основание чл. 2
от ЗЗЛД

Les Renardières, le



808

PRODUIT FABRIQUE SOUS SYSTEME DE MANAGEMENT DE LA QUALITE CERTIFIE AFAQ ISO 9001/2000
PRODUCT MADE THROUGH AFAQ ISO 9001/2000 CERTIFIED PROCESS

RAPPORT D'ESSAIS / TEST REPORT HM21/07-301/8

Appareil / Apparatus : Tableau HTA insensible à son environnement FBX

Tension assignée / Rated voltage : 24 kV
Courant assigné / Rated current : 400 A
Fréquence assignée / Rated frequency : 50 Hz

Constructeur / Manufacturer : ALSTOM

Objet / Object : Acceptation de type – Défauts internes/ Type tests- Internal faults

Demandeur des essais / Tested for : EGS/DRE/MER

Date(s) et lieu des essais / Date(s) and place of tests : 02/10/2003

Les Renardières - L.M.E. - SEMT

Essais réalisés suivant / Tests carried out according to : § 6.107 de la HN64-S-52 de Novembre 2002

Le Rapport est composé des documents suivants / The report comprises the following documents :

- caractéristiques de l'appareil / characteristics of the apparatus : page 3
- liste des essais effectués / list of tests performed : page 4
- conditions des essais / tests conditions : page 5
- tableaux et résultats d'essais / tables and tests results : page 6
- photographies / photographs n° : page 9
- oscillogrammes / oscillograms n° : 1001

Ce Rapport comprend / This report includes : 9 pages + 6 feuilles jointes/appended sheets.

« Seule la version française de ce rapport fait foi / The english version of this report is a translation of the original french version. »

La reproduction de ce Rapport d'Essais n'est autorisée que sous la forme de fac-similé photographique intégral, avec l'accord écrit du Laboratoire et du Demandeur des essais.

Reproduction of this Test Report is authorized only in the form of a complete photographic facsimile with the written authorization of the Laboratory and the Applicant.

На основание чл. 2
от ЗЗЛД

На основание чл. 2
от ЗЗЛД

Les Renardières, le 15

ВЯРНО С ОРИГИНАЛА

ПЛОДДИЕ

809

Independent, accredited test laboratory · Registration with STLA and LOVAG

TYPE TEST REPORT

NO. 1374.0016.2.001

ALSTOM Sachsenwerk GmbH
Rathenaustraße 2
93055 Regensburg

CLIENT

ALSTOM Sachsenwerk GmbH

MANUFACTURER

Gas-insulated metal-enclosed ring main unit

TEST OBJECT

FBX

TYPE

08 1026 0008

MANUFACTURING NO.

Rated voltage	U_i	12/24 kVA	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Rated normal current	I_r	630 kA	
Rated peak withstand current	I_p	53/42 kA	
Rated short-time withstand current	I_k	21/16 s	
Rated duration of short-circuit	t_k	1	
Values permissible at internal fault		kA	
Peak current		53 kA	
Short-time current		21 s	
Duration of short-circuit		1	
Type of accessibility		Typ A	

IEC 60298:1990 + Corrigendum 1:1995 + Corrigendum 2:1998 + Amendment A1:1994
DIN EN 60298 (VDE 0670 Teil 6):1998-05 + Berichtigung 1:1999-03

NORMATIVE DOCUMENT

Test under conditions of arcing due to internal fault

RANGE OF TESTS PERFORMED

14 and 15 January 2002

DATE OF TEST


The criteria of assessment 1 to 6 of IEC 60298:1990 + Corrigendum 1:1995 + Corrigendum 2:1998 + Amendment A1:1994 were fulfilled. The tests have been PASSED.

TEST RESULT

На основании чл. 2
от ЗЗЛД



Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DATech) e.V. in the fields of low-voltage apparatus and switchgear, power cables and power cable accessories, LV apparatus and switchgear, installation equipment and switching and control equipment



810

Independent, accredited testing station - Member laboratory of STL and LOVAG

TYPE TEST REPORT

NO. 1374.0033.3.044

ALSTOM Sachsenwerk GmbH
Rathenaustraße 2
93055 Regensburg

CLIENT

ALSTOM Sachsenwerk GmbH

MANUFACTURER

Prefabricated HV/LV substation (transformer substation)
with gas-insulated metal-enclosed AC switchgear

TEST OBJECT

Transformer substation: KSTV 20 kV/0.4 kV- 630 kVA
Switchgear: FBX-C/24-16/C-C-T1

TYPE

Transformer substation: Test sample
Switchgear: 598080 2002, 598082 2002

MANUFACTURING
NO.

Rated voltage	U_r	24 kV	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Rated normal current	I_r	630 A	
Rated peak withstand current	I_p	40 kA	
Rated short-time withstand current	I_k	16 kA	
Rated duration of short-circuit	t_k	1 s	
Type of accessibility		Typ A/B	

IEC 61330:1995 /DIN EN 61330:1996 (VDE 0670 Teil 611):1997-08

NORMATIVE
DOCUMENT

Test under conditions of arcing due to internal fault on a transformer substation

RANGE OF TESTS
PERFORMED

- for type A accessibility (restricted to authorized personnel) in front of the medium-voltage switchgear with its doors opened, the rest of the ventilating openings for type B accessibility (unrestricted, including general public). Arc initiation three-pole in the gas compartment with 16.0 kA set short-circuit current for a duration of short-circuit of 1 s.
- for type B accessibility (unrestricted, including general public) with the substation's doors closed. Arc initiation was two-pole in the cable compartment with three-pole-set short-circuit current of 16.0 kA for a duration of short-circuit of 1 s.


12 March 2003

DATE OF TEST

The criteria of assessment 1 to 6 of IEC 61330 and DIN EN 61330 (VDE 0670 Teil 611), resp., have been met.
The tests have been PASSED.

TEST RESULT

На основание чл. 2
от ЗЗЛД



Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DATeX) e.V. in the fields of hv apparatus and switchgear, power cables and power cable accessories - hv apparatus and switchgear, installation equipment and switching and control equipment



DAT - P - 019/92

811

TYPE TEST REPORT

NO. 1374.07294.234

Areva Sachsenwerk GmbH
Rathenaustraße 2
93055 Regensburg

CLIENT

Areva Sachsenwerk GmbH

MANUFACTURER

Metal-enclosed AC switchgear

TEST OBJECT

FBX-C/24-16/C-C-T1

TYPE

Test sample

MANUFACTURING NO.

Rated voltage	U_r	24 KV	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Rated normal current	I_r	630 A	
Rated peak withstand current	I_p	40 kA	
Rated short-time withstand current	I_k	16 kA	
Rated duration of short-circuit	t_k	1 s	
Internal arcing classification		IAC AFL 16 kA 1 s	

IEC 60694: 2002-01

NORMATIVE DOCUMENT

DIN EN 60694 (VDE 0670 Teil 1000): 2002-09

IEC 62271-200: 2003-11

Test under conditions of arcing due to internal fault

RANGE OF TESTS PERFORMED

15 July 2004

DATE OF TEST

The ratings of the test object related to the scope of test have been proved.
The test has been PASSED.

TEST RESULT

На основание чл. 2
от ЗЗЛД

Berlin, 09 September 2004



ВЯРНО С ОРИГИНАЛА



Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DATech) e.V. in the fields of h.v. apparatus and switchgear, power cables and power cable accessories, l.v. apparatus and switchgear, installation equipment and switching and control equipment



DAT - P - 019/92

802

Independent, accredited testing station · Member laboratory of STL and LOVAG

TEST REPORT

NO. 1803.2080405.156

AREVA T&D
Les 4 Chemins Fabrègues
34433 Saint Jean de Védas
FRANCE

CLIENT

AREVA T&D Macon

MANUFACTURER

Metal-enclosed AC switchgear

TEST OBJECT

FBX IS-C-C-T1

TYPE

S000007713

SERIAL NO.

Rated voltage	U_r	24 kV	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Rated normal current	I_r	630 A	
Rated peak withstand current	I_p	50 kA	
Rated short-time withstand current	I_k	20 kA	
Rated duration of short-circuit	t_k	3 s	
Internal arcing classification		IAC AFL 20 kA 1 s	

IEC 62271-200: 2003-11

NORMATIVE DOCUMENT

Test under conditions of arcing due to internal fault in the gas-filled compartment

RANGE OF TESTS PERFORMED

10 April 2008

DATE OF TEST

See Sub-clause 4.6

TEST RESULT

На основание чл. 2
от ЗЗЛД



ВЯРНО С ОРИГИНАЛА



Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DAkT) eV, in the fields of hv. apparatus and switchgear, power cables and power cable accessories, lv. apparatus and switchgear, installation equipment and switching and control equipment.



DAT - P - 019/92

813

[Handwritten signature]

zkratovna
Zkušebnictví, a. s.
Podnikatelská 547, 190 11 Praha 9 – Běchovice, Czech Republic

INDEPENDENT TESTING LABORATORY, ACCREDITED ACCORDING TO ČSN EN ISO/IEC 17025
BY THE ČESKÝ INSTITUT PRO AKREDITACI, O.P.S., UNDER THE NUMBER 1035

TEST REPORT

No. 09 - 058

Test object : High-voltage metal-enclosed switchgear and controlgear
Type : FBX-C/12-25/CCT1
Serial No. : FBX-0909054/AMT

Ratings
Rated voltage : 12 kV
Rated normal current : 630 A
Rated frequency : 50 Hz

Manufacturer : AREVA T&D
bid de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Test performed : Arcing due to an internal fault

Customer : AREVA T&D
bid de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Date of test : 12.05. 2009

◆ **Interpretation of results:**

The acceptance criteria 1 to 5 of IEC 62271-200:2003, cl. 6.106 and Annex A for classification IAC AFL 87% of 25 kA 1 s with two phase arc initiation on the bushing terminals in the cable compartment were met.


THIS TEST REPORT IS CONFIDENTIAL AND SHALL NOT BE PASSED OVER OR TRANSFERRED TO ANY THIRD PARTY WITHOUT WRITTEN APPROVAL OF THE CUSTOMER.
WITHOUT THE WRITTEN APPROVAL OF THE TESTING LABORATORY ZKRATOVNA SHALL NOT BE REPRODUCED, EXCEPT IN FULL.

Praha 9, Běchovice

Tested by: *11.08.2009*



ВЯРНО С ОРИГИНАЛА



На основание чл. 2
от ЗЗЛД



815


zkratovna
Zkušebnictví, a. s.

Podnikatelská 547, 190 11 Praha 9, Běchovice, Czech Republic

TEST REPORT

No. 07 - 120

Test object : High-voltage metal-enclosed switchgear and controlgear
Type : FBX-C/24-20/C-C-T1
Serial No. : FBX-0721000/AMT


Ratings
Rated voltage : 24 kV
Rated normal current : 630 A
Rated frequency : 50 Hz

Manufacturer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Test performed : Arcing due to an internal fault

Customer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Date of test : 02.10. 2007




THIS TEST REPORT IS CONFIDENTIAL AND SHALL NOT BE PASSED OVER OR TRANSFERRED TO ANY THIRD PARTY WITHOUT WRITTEN APPROVAL OF THE CUSTOMER.
WITHOUT THE WRITTEN APPROVAL OF THE TESTING LABORATORY ZKRATOVNA SHALL NOT BE REPRODUCED EXCEPT IN FULL.

Praha 9, Běchovice

Tested by:

На основании чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



e-version

815

zkratovna
Zkušebnictví, a. s.

Podnikatelská 547, 190 11 Praha 9, Běchovice, Czech Republic

TEST REPORT

No. 06 - 131

Test object : High-voltage metal-enclosed switchgear and controlgear
Type : FBX-C/24-16/CCT1
Serial No. : 06-18-01

Ratings
Rated voltage : 24 kV
Rated normal current : 630 A
Rated frequency : 50 Hz

Manufacturer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Test performed : Arcing due to an internal fault

Customer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Date of test : 17.10. 2006


THIS TEST REPORT IS CONFIDENTIAL AND SHALL NOT BE PASSED OVER OR TRANSFERRED TO ANY THIRD PARTY WITHOUT WRITTEN APPROVAL OF THE CUSTOMER.
WITHOUT THE WRITTEN APPROVAL OF THE TESTING LABORATORY ZKRATOVNA SHALL NOT BE REPRODUCED EXCEPT IN FULL.

Praha 9, Běchovice

На основание чл. 2
от ЗЗЛД

WITH THE ACTIVE

ВЯРНО С ОРИГИНАЛА



e-version

216

VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.



No. 5559 /VNL

Test report

Short-time withstand current and peak withstand current tests on the main circuit of FBX-C/24-20/CCT1 metal-enclosed switchgear

4th December 2009

На основание чл. 2
от ЗЗЛД



The accreditation of VEIKI-VNL Ltd.

refers to the test activities registered by HAB (Hungarian Accreditation Board) under No.: NAT-1-1251/2007

H-1158 Budapest, Vaszgolyó u. 2-4.
E-mail: vnl@vnl.hu

Phone:+36.1.417 3157, Fax:+36.1.417 3163
www.vnl.hu

817



VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.

Test Report
No. 5559 / VNL

2 / 6 page

Subject: Short-time withstand current and peak withstand current tests on the main circuit of FBX-C/24-20/CCT1 metal-enclosed switchgear

Kind of the test: Development test

Client: AREVA T&D
381, Bld. de la Résistance – BP 84019
F-71040 Mâcon Cedex 9
FRANCE

Reference and date of the order: No. 3139-4520127354, 05.10.2009

Our reference number: NTL - 18 / 2009

Place and date of the test: VEIKI-VNL Electric Large Laboratories Ltd.
H-1158 Budapest, Vasgolyó u. 2-4.
HUNGARY
18th November 2009

Present at the test in charge of the purchaser:

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



818

zkratovna
Zkušebnictví, a. s.

Podnikatelská 547, 190 11 Praha 9, Běchovice, Czech Republic

TEST REPORT

No. 08 - 007

Test object : High-voltage metal-enclosed switchgear and controlgear
Type : FBX-C/24-20/CCT1
Serial No. : 07/69Y19-06

Ratings
Rated voltage : 24 kV
Rated normal current : 630 A
Rated frequency : 50 Hz

Manufacturer : SUZHOU Areva T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Test performed : Arcing due to an internal fault

Customer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Date of test : 05.02. 2008

THIS TEST REPORT IS CONFIDENTIAL AND SHALL NOT BE PASSED OVER OR TRANSFERRED TO ANY THIRD PARTY WITHOUT WRITTEN APPROVAL OF THE CUSTOMER.
WITHOUT THE WRITTEN APPROVAL OF THE TESTING LABORATORY ZKRATOVNA SHALL NOT BE REPRODUCED EXCEPT IN FULL.

Praha 9, Běchovice

27.2.2008

Tested by:

На основании чл. 2
от 33ЛД

Copy No.: E



e-version



zkratovna
Zkušebnictví, a. s.

Podnikatelská 547, 190 11 Praha 9, Běchovice, Czech Republic

TEST REPORT

No. 08 - 026

Test object : High-voltage metal-enclosed switchgear and controlgear
Type : FBX-C/24-20/C-C-T1
Serial No. : FBX--0721058/AMT

Ratings
Rated voltage : 24 kV
Rated normal current : 630 A
Rated frequency : 50 Hz

Manufacturer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Test performed : Arcing due to an internal fault

Customer : AREVA T&D
bld de la Résistance – BP 84019
71040 Mâcon Cedex – 9, France

Date of test : 26.03. 2008

THIS TEST REPORT IS CONFIDENTIAL AND SHALL NOT BE PASSED OVER OR TRANSFERRED TO ANY THIRD PARTY WITHOUT WRITTEN APPROVAL OF THE CUSTOMER.

WITHOUT THE WRITTEN APPROVAL OF THE TESTING LABORATORY ZKRATOVNA SHALL NOT BE REPRODUCED EXCEPT IN FULL.


Praha 9, Běchovice

5.5.2008

Tested by:

На основании чл. 2
от 33ЛД

Copy No.: E7



e-version

Stamp: ZKRATOVNA, dated 26.03.2008, with handwritten initials 'S.L.D.' and a signature.



[Handwritten signature]
356 AAA

TEST REPORT

Report no. 70370100.000-HVL 03-1130
Client Alstom Sachsenwerk GmbH
Rathenaustrasse 2
93055 Regensburg
Germany

Reference -

Concerning test
Date 10 up to and including 13 June 2003
Place KEMA High-Voltage Laboratory, Arnhem,
the Netherlands
Object gas-insulated ring main unit, 24 kV
Type FBX-E/24-12
Manufacturer same as client

REQUIREMENTS

The requirements as specified in the standard HN 64-S-52.

TEST PROGRAMME

The programme was specified by the client and was as follows:

- 1 measurement of the resistance of the main circuit in accordance with HN 64-S-52 clause 6.4
- 2 temperature-rise test in accordance with HN 64-S-52 clause 6.5
- 3 measurement of the resistance of the main circuit in accordance with HN 64-S-52 clause 6.4.

SUMMARY AND CONCLUSION

The results obtained relate only to the work ordered and to the material tested.
The tests were passed.

[Large handwritten signature]

На основание чл. 2
от ЗЗЛД


Arnhem, 15 August 2003

© Copyright: Publication or reproduction of the contents of this report in any other form than a complete copy to the letter, is not allowed without our written consent.

Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only". The bound version of this report is the only valid version.

Utrechtseweg 310, 6812 AR Arnhem. Telephone +31 26 3 56 31 85. Telefax +31 26 4 43 38 42

ВЯРНО С ОРИГИНАЛА



[Handwritten signature]

821

Independent, accredited testing station -Member laboratory of STL and LOVAG

TYPE TEST REPORT

NO. 1803.2080405.154

AREVA T&D
Les 4 Chemins Fabrègues
34433 Saint Jean de Védas
FRANCE

CLIENT

Transformer substation: AREVA T&D Saint Jean de Védas
Switchgear: AREVA T&D Macon

MANUFACTURER

Prefabricated high-voltage and low-voltage substation
(transformer substation) with gas-insulated medium-voltage switchgear

TEST OBJECT

Transformer substation: Clipper C27
Switchgear: FBX-C/24-20/C-C-T1

TYPE

Transformer substation: 37062007 and 37062008
Switchgear: FBX--0745095/AMT and FBX--0745117/AMT

SERIAL NO.

Rated voltage	U_r	24 kV	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Rated normal current	I_r	630 A	
Rated peak withstand current	I_p	50 kA	
Rated short-time withstand current	I_k	20 kA	
Rated duration of short-circuit	t_k	3 s	
Internal arcing classification		IAC AB 20 kA 1 s	

IEC 62271-202: 2006-06

NORMATIVE DOCUMENT

Test under conditions of arcing due to internal fault

RANGE OF TESTS PERFORMED

10 April 2008

DATE OF TEST

The ratings of the test object related to the scope of test have been proved.
The test has been PASSED.

TEST RESULT

На основание чл. 2
от ЗЗЛД



ВЯРНО С ОРИГИНАЛА



Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DATech) e.V. in the fields of hv apparatus and switchgear, power cables and power cable accessories, lv apparatus and switchgear, installation equipment and switching and control equipment.



DAT - P - 019/92

TEST REPORT

No. 2228.2090315.0254

AREVA T&D MACON
Boulevard de la Résistance
71040 Macon cedex 9
FRANCE

CLIENT

AREVA T&D MACON

MANUFACTURER

High-voltage alternating current switch-disconnector

TEST OBJECT

FBX-E/24-20/C + FBX-E/24-20/C + FBX-E/24-20/C

TYPE

09-17-03 / 09-17-05 / 09-17-06

SERIAL NO.

Rated voltage	U_r	24 kV	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Rated normal current	I_r	630 A	
Rated peak withstand current	I_p	53 kA	
Rated short-time withstand current	I_k	21 kA	
Rated duration of short-circuit	t_k	1 s	

IEC 60265-1: 1998-01
IEC 62271-200: 2003-11
IEC 62271-1: 2007-10

NORMATIVE DOCUMENT

Short-time withstand current and peak withstand current tests of the main switch

RANGE OF TESTS PERFORMED

4 May 2009

DATE OF TEST

See Sub-clause 4.6

TEST RESULT

На основание чл. 2
от ЗЗЛД



ВЯРНО С ОРИГИНАЛА




Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DATech) e.V. in the fields of HV apparatus and switchgear, power cables and power cable accessories, LV apparatus and switchgear, installation equipment and switching and control equipment

Institut „Prüfgebiet für elektrische Hochleistungstechnik“ GmbH (IPH Berlin) is a subsidiary of CESI S.p.A. Milan.



DAT - P - 019/92

VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.



No. 4712 / VNL

Test Report

Short-time withstand current and peak withstand current tests on main circuit of high-voltage switchgear type FBX-E/24-16/C

5th April 2007



The accreditation of VEIKI-VNL Ltd.
refers to the test activities registered by HAB (Hungarian Accreditation Board) under No. NAT-1-1251/2004

H-1158 Budapest, Vasgölyó u. 2-4.
E-mail: vnl@vnl.hu

Phone: +36.1.417 3157, Fax: +36.1.417 3163



ВЯРНО С ОРИГИНАЛА

824



VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.

Test Report
No. 4712/ VNL

2 / 6 page

Subject: Short-time withstand current and peak withstand current tests on main circuit of high-voltage switchgear type FBX-E/24-16/C

Kind of the test: Development test

Client: AREVA T&D
Appareillage Moyenne Tension
Boulevard de la Résistance - BP 84019
71040 Mâcon Cedex 9
FRANCE

Reference and date of the order: 40973 , 17th January 2007

Our reference number: V-104 / 2007

Place and date of the test: VEIKI-VNL Electric Large Laboratories Ltd.
H-1158 Budapest, Vasmolyó u. 2-4
HUNGARY
02nd March 2007

*Present at the test in charge
of the purchaser:*


На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



R25

VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.



No. 4713 / VNL

Test Report

Short-time withstand current and peak withstand current tests on main circuit of high-voltage switchgear type FBX-E/24-16/C

5th April 2007

A large, handwritten signature in black ink, slanted to the right, located on the right side of the page.



The accreditation of VEIKI-VNL Ltd.
refers to the test activities registered by HAV (Hungarian Accreditation Board) under No.: NAT-1-1251/2004

H-1158 Budapest, Vasgölyö u. 2-4.
E-mail: vnl@vnl.hu

Phone: +36.1.417.3157, Fax: +36.1.417.3163

ВЯРНО С ОРИГИНАЛА



826



VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.

Test Report
No. 4713/ VNL

2 / 6 page

Subject:

Short-time withstand current and peak withstand current tests on main circuit of high-voltage switchgear type ÉBX-E/24-16/C

Kind of the test:

Development test

Client:

AREVA T&D
Appareillage Moyenne Tension
Boulevard de la Résistance - BP 84019
71040 Mâcon Cedex 9
FRANCE

Reference and date of the order:

40973 , 17th January 2007

Our reference number:

V-104 / 2007

Place and date of the test:

VEIKI-VNL Electric Large Laboratories Ltd.
H-1158 Budapest, Vaszgolyó u. 2-4
HUNGARY
02nd March 2007

*Present at the test in charge
of the purchaser:*

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



827

VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.



No. 4906 /VNL

Test Report

Verification of the IP coding, Temperature-rise, Mechanical endurance and Tightness test of switchgear type FBX-C/12-20/C-C-T1

17th of January 2008

A large, handwritten signature in black ink, slanted to the right, located on the right side of the page.



STL
participant

The accreditation of VEIKI-VNL Ltd.
refers to the test activities registered by HAB (Hungarian Accreditation Board) under No.: NAT-1-1251/2007

H-1158 Budapest, Vaszgolyó u. 2-4.
E-mail: vnl@vnl.hu

Phone: +36.1.417 3157 Fax: +36.1.417 3163
www.vnl.hu

ВЯРНО С ОРИГИНАЛА



828



VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.

Test Report
No. 4906 / VNL

2 / 9 page

Subject:

Verification of the IP coding, Temperature-rise,
Mechanical endurance and Tightness test of
switchgear type FBX-C/12-20/C-C-T1

Kind of the test:

Type test

Client:

AREVA T&D
Bld. de la Résistance – BP 84019
F-71040 Mâcon cedex 9
France

Reference and date of the order:

3139-4500071613
21st of September 2007

Our reference number:

V-104/2007

Place and date of the test:

VEIKI-VNL Electric Large Laboratories Ltd.
H-1158 Budapest, Vaszgolyó u. 2-4
Hungary
12th – 16th of November 2007

*Present at the test in charge
of the purchaser:*


На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



829


VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.



No. 4947 /VNL

Test report

**Dielectric tests on switchgear type FBX-C/24-12/C-C-T1a
for rated voltage of 24 kV**

9th January 2008





STL
participant

The accreditation of VEIKI-VNL Ltd.
refers to the test activities registered by HAB (Hungarian Accreditation Board) under No.: NAT-1-1251/2007

H-1158 Budapest, Vasgolyó u. 2-4.
E-mail: vnl@vnl.hu

Phone: +36.1.417 3157, Fax: +36.1.417 3163
www.vnl.hu

ВЯРНО С ОРИГИНАЛА

830







VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.

Test Report
No. 4947 / VNL

2 / 6 page

Subject: Dielectric tests on switchgear type
FBX-C/24-12/C-C-T1a for rated voltage of 24 kV

Kind of the test: Clarification test

Client: AREVA T&D
Bld. de la Résistance – BP 84019
F-71040 Mâcon cedex 9
France

Reference and date of the order: 3139-4500076196
27th of November 2007

Our reference number: V-104/2007

Place and date of the test: VEIKI-VNL Electric Large Laboratories Ltd.
H-1158 Budapest, Vasmányos u. 2-4.
Hungary
19th of December 2007

*Present at the test in charge
of the purchaser:*

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



831

VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.



No. 5439 /VNL

Test report

**Dielectric tests on switchgear type FBX-C/24-12/C-C-T1a
for rated voltage of 24 kV**

30th July 2009

A large, stylized handwritten signature in black ink, oriented vertically on the right side of the page.



The accreditation of VEIKI-VNL Ltd.
refers to the test activities registered by HAB (Hungarian Accreditation Board) under No.: NAT-1-1251/2007

H-1158 Budapest, Vasgolyó u. 2-4.
E-mail: vnl@vnl.hu

Phone: +36.1.417 3157, Fax: +36.1.417 3163
www.vnl.hu

ВЯРНО С ОРИГИНАЛА



A handwritten signature in black ink at the bottom left of the page.

A handwritten signature in black ink at the bottom center of the page.



VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.

Test Report
No. 5439 / VNL

2 / 7 page

Subject: Dielectric tests on switchgear type
FBX-C/24-12/C-C-T1a for rated voltage of 24 kV

Kind of the test: Control test

Client: AREVA T&D
Bld. de la Résistance – BP 84019
F-71040 Mâcon cedex 9
France

Reference and date of the order: 3139-4500115010
07th of April 2009

Our reference number: NTL-18/2009

Place and date of the test: VEIKI-VNL Electric Large Laboratories Ltd.
H-1158 Budapest, Vasgolyó u. 2-4.
Hungary
21st of July 2009

*Present at the test in charge
of the purchaser:*

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



833

VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.



No. 5669 /VNL

Test report

**Dielectric tests on the main circuit of the C functions of
FBX-C/24-12/CCT1a metal-enclosed switchgear**

26th February 2010



The accreditation of VEIKI-VNL Ltd.
refers to the test activities registered by HAB (Hungarian Accreditation Board) under No. : NAT-1-1251/2007

H-1158 Budapest, Vasgolyó u. 2-4.
E-mail: vnl@vnl.hu

Phone: +36.1.417 3157, Fax: +36.1.417 3163
www.vnl.hu

ВЯРНО С ОРИГИНАЛА



8301



VEIKI-VNL ELECTRIC LARGE LABORATORIES LTD.

Test Report
No. 5669 / VNL

2 / 7 page

Subject:

Dielectric tests on the main circuit of the C functions of high-voltage switchgear type FBX-C/24-12/CCT1a for rated voltage of 24 kV

Kind of the test:

Control test

Client:

AREVA T&D
Bld. de la Résistance -- BP 84019
F-71040 Mâcon cedex 9
France

Reference and date of the order:

3139-4520134278
11th of January 2010

Our reference number:

NTL-01/2010

Place and date of the test:

VEIKI-VNL Electric Large Laboratories Ltd.
H-1158 Budapest, Vasgolyó u. 2-4.
Hungary
01st of February 2010

*Present at the test in charge
of the purchaser:*

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



835

Ar0_0V1

RAPPORT D'ESSAIS
TEST REPORT

N° 6006

Destinataire To	AREVA T&D Mâcon
Appareil Tested equipment	Tableau FBX, type IS C-C-T2 compact Switchboard FBX, type IS C-C-T2 compact
	Ur = 24 kV I _r = 630A fr = 50 Hz
Constructeur Manufacturer	AREVA T&D Mâcon

Objet des essais
Purpose of tests

Essais au courant de courte durée et la valeur de crête du courant admissible
Short-time withstand current and peak withstand current tests

Lieu des essais
Site of tests

Laboratoire d'Essais de Puissance du CERDA
CERDA High Power Laboratories

Date(s) des essais
Date(s) of tests

16 octobre 2007
October, 16th 2007

Essais effectués conformément aux normes : CEI 62271-200 Ed 1 2003/11 et CEI 60694 Ed2.2 2002/01
Tests performed according to : IEC 62271-200 Ed 1 2003/11 and IEC 60694 Ed2.2 2002/01

Assistait aux essais
Tests witnessed by

На основание чл. 2
от ЗЗЛД

Rapport composé de
Report made of

Date d'émission
Date of issue


*La reproduction de ce rapport n'est autorisée que sous la forme intégrale
This record of proving test shall only be reproduced in the complete form*

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



836



RAPPORT D'ESSAIS
TEST REPORT

N°6037

Destinataire
To AREVA T&D Mâcon (France)

Appareil
Tested equipment Tableau FBX, type IS C-C-T2 compact
Switchboard FBX, type IS C-C-T2 compact

Ur = 24 kV
I_r = 630A
fr = 50 Hz

Constructeur
Manufacturer AREVA T&D Mâcon (France)

Objet des essais
Purpose of tests Essais au courant de courte durée et la valeur de crête du courant admissible
Short-time withstand current and peak withstand current tests

Lieu des essais
Site of tests Laboratoire d'Essais de Puissance du CERDA
CERDA High Power Laboratories

Date des essais
Date of tests 6 novembre 2007
2007, November, the 6th

Essais effectués conformément aux normes :
Tests performed according to : CEI 62271-200 Ed1(2003-11) et CEI 62271-1 Ed1(2007-10)
IEC 62271-200 Ed1(2003-11) and IEC 62271-1 Ed1(2007-10)

Assistait aux essais
Tests witnessed by

Rapport composé de
Report made of

Date d'émission
Date of issue

На основание чл. 2
от ЗЗЛД

*La reproduction de ce rapport n'est autorisée que sous la forme intégrale
This record of proving test shall only be reproduced in the a complete form.
L'accréditation du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation, qui sont identifiés
par le symbole C en page résumé des essais.
COFRAC accreditation demonstrates that the laboratories competence for the sole tests which are in the scope of accreditation, and which
are identified by a C symbol in tests summary pages.*

Le Responsable des Essais
Responsible for the tests

Le Chef du CERDA
Head of CERDA

C. BOURD

На основание чл. 2
от ЗЗЛД

Page n°1

БЛРТО С ОУИИПАНА



637



RAPPORT D'ESSAIS
TEST REPORT

N°6066-1

Destinataire
To AREVA T&D Mâcon (France)

Appareil
Tested equipment Tableau FBX, IS type C-C-T2 compact
Switchboard FBX, IS type C-C-T2 compact

Ur = 24 kV
I_r = 630A
fr = 50 Hz

Constructeur
Manufacturer AREVA T&D Mâcon (France)

Objet des essais
Purpose of tests Essais au courant de courte durée et la valeur de crête du courant admissible
Short-time withstand current and peak withstand current tests

Lieu des essais
Site of tests Laboratoire d'Essais de Puissance du CERDA
CERDA High Power Laboratories

Date des essais
Date of tests 24 et 25 janvier 2008
2008, January, the 24th and 25th

Essais effectués conformément aux normes : CEI 62271-200 Ed1(2003-11) et CEI 62271-1 Ed1(2007-10)
Tests performed according to : IEC 62271-200 Ed1(2003-11) and IEC 62271-1 Ed1(2007-10)

Assistent aux essais
Tests witnessed by

На основание чл. 2
от ЗЗЛД

Rapport composé de
Report made of

Date d'émission
Date of issue

*La reproduction de ce rapport n'est autorisée que sous la forme intégrale
This record of proving test shall only be reproduced in the a complete form.
L'accréditation du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation, qui sont identifiés
par le symbole C en page résumé des essais.
COFRAC accreditation demonstrates that the laboratories competence for the sole tests which are in the scope of accreditation, and which
are identified by a C symbol in tests summary pages.*

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА





RAPPORT D'ESSAIS
TEST REPORT

N°6193

Destinataire
To AREVA T&D Mâcon (France)

Appareil
Tested equipment Tableau FBX, IS type C-C-T1-C-T1compact
Switchboard FBX, IS type C-C-T1-C-T1compact
Ur = 24 kV
I_r = 630A
fr = 50 Hz

Constructeur
Manufacturer AREVA T&D Mâcon (France)

Objet des essais
Purpose of tests Essais au courant de courte durée et la valeur de crête du courant admissible
Short-time withstand current and peak withstand current tests

Lieu des essais
Site of tests Laboratoire d'Essais de Puissance du CERDA
CERDA High Power Laboratories

Date des essais
Date of tests 9 juin 2008
2008, June, the 9th

Essais effectués conformément aux normes :
Tests performed according to : CEI 62271-200 Ed1(2003-11) et CEI 62271-1 Ed1(2007-10)
IEC 62271-200 Ed1(2003-11) and IEC 62271-1 Ed1(2007-10)

Assistaient aux essais
Tests witnessed by
Rapport composé de
Report made of
Date d'émission
Date of issue

На основание чл. 2
от ЗЗЛД


*La reproduction de ce rapport n'est autorisée que sous la forme intégrale
This record of proving test shall only be reproduced in the a complete form.
L'accréditation du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation, qui sont identifiés
par le symbole C en page résumé des essais.
COFRAC accreditation demonstrates that the laboratories competence for the sole tests which are in the scope of accreditation, and which
are identified by a C symbol in tests summary pages.*

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



839



RAPPORT D'ESSAIS
TEST REPORT

N°6216-1

Destinataire
To AREVA T&D Mâcon (France)

Appareil
Tested equipment Tableau FBX, IS type C-C-T1 + C compact
Switchboard FBX, IS type C-C-T1 + C compact
Ur = 24 kV
I_r = 630 A
fr = 50 Hz

Constructeur
Manufacturer AREVA T&D Mâcon (France)

Objet des essais
Purpose of tests Essais au courant de courte durée et la valeur de crête du courant admissible
Short-time withstand current and peak withstand current tests

Lieu des essais
Site of tests Laboratoire d'Essais de Puissance du CERDA
CERDA High Power Laboratories

Date des essais
Date of tests 10 juillet 2008
2008, July, the 10th

Essais effectués conformément aux normes :
Tests performed according to : CEI 62271-200 Ed1(2003-11) et CEI 62271-1 Ed1(2007-10)
IEC 62271-200 Ed1(2003-11) and IEC 62271-1 Ed1(2007-10)

Assistait aux essais
Tests witnessed by

Rapport composé de
Report made of

Date d'émission
Date of issue

На основание чл. 2
от ЗЗЛД

*La reproduction de ce rapport n'est autorisée que sous la forme intégrale
This record of proving test shall only be reproduced in the a complete form.
L'accréditation du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation, qui sont identifiés
par le symbole C en page résumé des essais.
COFRAC accreditation demonstrates that the laboratories competence for the sole tests which are in the scope of accreditation, and which
are identified by a C symbol in tests summary pages.*

На основание чл. 2
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



8/10



RESEARCH-DEVELOPMENT AND TESTING NATIONAL
INSTITUTE FOR ELECTRICAL ENGINEERING

ÎNCERCARE



**ICMET CRAIOVA
HIGH POWER DIVISION**

SR EN ISO / CEI 17025: 2005
CERTIFICAT DE ACREDITARE
nr. LI 004 / 2007

**HIGH POWER LABORATORY
"Ovidiu Rarinca"**

200515-CRAIOVA Calea Bucuresti Nr. 144 ROMANIA
Phone: (351) 402 427; Fax: (251) 415482; (351) 404 890;
E-mail: lmp@icmet.ro

**TEST REPORT
No. 10117**

CUSTOMER: AREVA T&D Appareillage Moyenne Tension
Boulevard de la Resistance BP 84019 – 71040
Mâcon Cedex France

MANUFACTURER: AREVA T&D SAS SUZHOU
285 Jinfeng Road
215129 SUZHOU, JIANGSU - CHINA

TESTED PRODUCT: 12 kV, 630 A, 21 kA Switchboard

REFERENCE STANDARD: IEC 62271-200/2003, clause 6.6

TEST PERFORMED: Short-time withstand current and peak withstand current test

TEST DATE: 11.03.2008

TEST RESULT: Passed the tests


Report has 10 pages and it is edited in 4 copies from which 3 copies for customer.

На основание чл. 2
от ЗЗЛД

1. Results refer to test product only.
2. Publication or reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of division to which laboratory belong to.
3. Accreditation of the laboratory or any of its Test Reports issued under accreditation regime do not constitute or do not imply themselves an approval of the product by the accreditation body.

© ICMET Craiova 2008/IM

ВЯРНО С ОРИГИНАЛА



8/11



RESEARCH-DEVELOPMENT AND TESTING NATIONAL
INSTITUTE FOR ELECTRICAL ENGINEERING


**ICMET CRAIOVA
HIGH POWER DIVISION**

HIGH POWER LABORATORY

"Ovidiu Rarinca"

200515-CRAIOVA Calea Bucuresti Nr. 144 ROMANIA
Phone: (351) 402 427; Fax: (251) 415482; (351) 404 890;
E-mail: imp@icmet.ro

INCERCARE



SR EN ISO / CEI 17025: 2005
CERTIFICAT DE ACREDITARE
nr. LI 004 / 2007



**TEST REPORT
No. 10321**

CUSTOMER: AREVA T&D Appareillage Moyenne Tension
Boulevard de la Resistance BP 84019 – 71040
Mâcon Cedex - France

MANUFACTURER: AREVA T&D Appareillage Moyenne Tension
Boulevard de la Resistance BP 84019 – 71040
Mâcon Cedex - France

TESTED PRODUCT: 24 kV, 21 kA Cubicle

REFERENCE IEC 62271-200/2003, clause 6.6

TEST PERFORMED: Short-time withstand current and peak withstand current test on earthing switch

TEST DATE: 17.10.2008

TEST RESULT: Passed the test

Report has 8 pages and it is edited in 4 copies from which 3 copies for customer.

HEAD OF HIGH POWER DIVISION:

HEAD OF LABORATORY:

На основание чл. 2
от ЗЗЛД

DATE OF ISSUE: 8.12.2008

1. Results refer to test product only.
2. Publication or reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of division to which laboratory belongs to.
3. Accreditation of the laboratory or any of its Test Reports issued under accreditation regime do not constitute or do not imply themselves an approval of the product by the accreditation body.

© ICMET Craiova 2008/IM

ВЯРНО С ОРИГИНАЛА



842



Prüfbericht

Bericht-Nr.: XZ 268 L 015

Ausfertigung-Nr.: 1

Inhalt: 17 Blatt

Prüfobjekt: Fabrikfertige Station mit einer metallgeschotteten, gasisolierten Schaltanlage
Typbezeichnung: NZ 210-240 mit FBX-C/24-20/C-C-T1
Bemessungs-Spannung: 12 / 24 kV **Bemessungs-Strom:** 630 A **Bemessungs-Frequenz:** 50 Hz

Hersteller: Scheidt GmbH & Co. KG, Rinteln, Deutschland (Betonstation)
AREVA T&D, Mâcon, Frankreich (Schaltanlage)

Auftraggeber: Scheidt GmbH & Co. KG, Rinteln, Deutschland

Prüfdatum: 22. September 2009

Angewandte Prüfbestimmungen:

Die Prüfung wurde in Übereinstimmung mit folgende Prüfvorschriften durchgeführt:
IEC 62271-200 / 1st Ed. / 2003-11
IEC 62271-202 / 1st Ed. / 2006-06

Durchgeführte Prüfungen:

Typprüfung ‚Verhalten bei Inneren Fehlern‘ der Schaltanlage innerhalb der fabrikfertigen Station.

Prüfung des Verhaltens der fabrikfertigen Station bei Auftreten eines Störlichtbogens aufgrund eines inneren Fehlers. Die Prüfung wurde dreiphasig im Gasraum der Schaltanlage mit einem Stoßstrom von 54,6 kA und einem Kurzschlussstrom von 20,8 kA - 1,03 s äquivalent zu 21,0 kA - 1,02 s bei 50 Hz durchgeführt.

Fortsetzung auf Blatt 3.

Prüfergebnisse:

Das Prüfobjekt hat die in Übereinstimmung mit den Prüfbestimmungen durchgeführte Prüfung bestanden. Diese Störlichtbogenprüfung kann zur Klassifizierung der fabrikfertigen Station gemäß IAC-A 21kA 1s herangezogen werden.



На основании чл. 2
от ЗЗЛД

Ratingen, 18. Januar 2010

ИНЖЕНЕРИНГ ЕАД, Пловдив 4004, ул Коматевско шосе 92, тел: 032/608 881; факс: 032/608 138
Интернет сайт: www.fikab.com , E-mail: engineering@eng.bg

ДЕКЛАРАЦИЯ

Долуподписаният Петър Иванов Данчев, в качеството си на изпълнителен директор на ИНЖЕНЕРИНГ ЕАД, участник в процедура на договаряне с обявление за възлагане на обществена поръчка №PPD 18-063, с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове (БКТП)“,

ДЕКЛАРИРАМЕ, ЧЕ:

Предлаганите компактни КРУ тип FBX са произведени в завода на Шнайдер Електрик в гр. Макон, Франция. Използваните материали при производството на КРУ тип FBX подлежат на рециклиране спазвайки дейностите подробно описани в инструкцията за „Извеждане от експлоатация на елегазови КРУ след края на живота им“.

Дата 13.08.2018г.



На основание чл. 2
от ЗЗЛД



FBX-C Табло тип ССТ1

Екологичен профил на продукта

SF6-изолирано, табло за
вторично разпределение



Handwritten signature



Schneider
Electric

ВЯРНО С ОРИГИНАЛА




845

Екологичен профил на продукта - PEP

Въведение

Целта на настоящият документ е да предостави информация за екологичните показатели на FBX SF6 изолирано второстепенно разпределително табло през целият му експлоатационен жизнен цикъл.

Данни за производителя



Шнайдер Електрик Индъстрис АД

Ул. Жозеф Моние 35 , Рюейл –Малмезон , Франция

www.schneider-electric.com

Обектът в Масон произвежда комутатори за средно напрежение (HVA). Табла за първично и вторично разпределение. Следвайки стратегиите на Шнайдер Електрик, обекта в Масон провежда политика на респектиране на околната среда. Обекта притежава сертификат по ISO 14001 обхващащ проектирането на продуктите от 2002. На обекта се прилага Система за Управление на околната среда. В рамките на понятието за еко-дизайн, са разработени и внедрени много от процедурите свързани с развитието на продуктите (оперативни инструкции).

Представяне на продукта

Таблото за вторично разпределение FBX е компактно, надеждно и лесно за употреба. То е с дизайн на моно блок, налично в компактна и разширена версия. С различните си опции може да бъде адаптирано към изискванията на потребителите за напрежения до 24kV. Устойчиво е на околната среда, непотъващо и не изисква поддръжка. Ролята на FBX таблата е да предават и разпределят електрическа енергия за приложения като публични мрежи, промишлени инсталации, вятърни паркове и др.

- Изследванията на FBX са базов, международен стандартен модел, който се състои от:
- Две C функции (подаващ входящ или изходящ кабел с комутируем прекъсвач);
- Една T1 функция (защитен панел в комбинация с предпазители и прекъсвач за товар);
- Не моторизирани механични контроли;
- Охлаждаща решетката, позволяваща на образуванияте от вътрешните дъгови газове да дисипират чрез в задната част на блока.

Техническите характеристики на оборудването са както следва:

- Номинално напрежение: 24 kV
- Номинален ток (шина): 630 A
- Номинален ток (панел C): 630 A
- Номинален ток (панел T1): 200 A
- номинален ток на късо съединение, краткосрочен (или равен) на: 16 kA
- Номинална честота : 50/60 Hz

ВЯРНО С ОРИГИНАЛА



846

Разбивка на използваните материали

Посочената по-долу разбивка на използваните материали показва вида и количествата на съставните елементи на функционалната единица (виж § 5).

Метали (Kg)		Термореактивни продукти (kg)	
Стомана	155.810	Епоксидна смола	12.141
Неръждаема стомана	83.854		
Медна сплав	26,514	Gas (kg)	
Алуминиева сплав	9,763	SF6	2,450
Сребро	0,051		
		Еластомери (kg)	
Общо	275.991		0,095
Вкл. олово	0,013	EPDM	
		Други материали (Kg)	
Термопластични продукти (Kg)		Силициев двуокис	3,000
Полиестери	7,330	Порцелан	2,993
Ароматични полиамиди	2,964	Кордиерит/ полит	1,097
Полиамиди	1,198	Натриев алуминосиликат	0,500
Други	0,152	Фенолна смола – импрегнирана хартия	0,430
Общо	11,645	Грес	0,050
		Общо	8,070
		Общо (kg)	310,392

Металите представляват 89 % от общото тегло на FBX, термопластичните продукти 3.7 %, термо реактивните продукти 3,9 %, SF6 газообразни 0,8 %, а останалите 2.6 %. В металните сплави има олово, с концентрация от 38 ppm (0.0038 %).

Анализ на цикъла на живот

Методология

Настоящият анализ е извършен с EIME софтуер, версия 1.6. използваната база данни на софтуерът е ECOBILAN 5.0 (оригинал), с добавени вътрешни модули. Настоящият софтуер е в употреба от 1998 год. насам. Оценка на въздействието върху околната среда е извършена за следните етапи от жизнения цикъл на оборудването: Производство, разпространение и употреба. Край на жизнения цикъл и

ВЯРНО С ОРИГИНАЛА

847



въздействието на тази фаза не са взети предвид, тъй като софтуерът няма възможност за това. Изследванията на оборудването са на FBX SST1, така като е описано на предишната страница. При провеждане на симулацията с EIME, не са взети под внимание термопластичните добавки и въздействието на мястото на производство.

Функционален блок

Функционалната единица, използвана в този анализ е компактно FBX (тип SST1) табло за вторично разпределение, снабдени с 3 MV/HVA предпазители.

Обхват на системата

Анализът обхваща въздействието на фазите на производство, разпределение и употреба върху околната среда. Изчисленията са въз основа на експлоатация от 30 години.

Производство

Използваните материали са тези, които са изброени в разбивката на материалите (вж. описание на продукта). Към тези, ние сме добавили повърхностната обработка (оценка на третиранията повърхност = 2.5m²) и защитното покритие на предния панел (боядисаната площ е изчислена на 1.2m²). Компонентите от под изпълнение, използвани в FBX, имат средно покритие 175.3 t.km. 91 % от SF6 газ се рециклира.

Разпространение

FBX се монтира на дървени палети, тежащи 25 kg, след това се покрива с пластмасово фолио (1 kg) за транспортиране до обекта на клиента. В момента, по-голямата част от потенциалните купувачи на това оборудване са от Европа. Прогнозата ни е, че FBX ще покрива средна дистанция от 1060 км, с камион.

Употреба

Жизненият цикъл на FBX е 30 години.


Подразбира се, че фазите на поддръжка са без допълнения към материалите. Разсеяната енергия (ефект на Джаул) през трите фази, когато оборудването е живо (99.9 % от времето) се оценява на средно 7.3. За целите на EIME симулацията се приема, че произходът на електроенергията е в рамките на Европа. SF6 теч на газ за 30 години представлява 7 % от първоначалната маса на SF6, съдържащи се в рамките на FBX единица.

Край на жизнения цикъл на експлоатация

FBX е изграден от голямо разнообразие от материали: четири групи метали (стоманени сплави, сплави на неръждаема стомана, алуминиеви сплави, медни сплави); 8 термопластични материала (PBT, PA, PET, PPA, POM, PVC, PC & PE); 2 терморективни продукти (стъклени епоксидна смола и силициева епоксидна смола); един еластомер (EPDM); SF6 газ; фенол импрегнирана хартия и натриев

ВЯРНО С ОРИГИНАЛА

848



алуминосиликат. Към тези следва да се добавят материалите изграждащи предпазителите (порцелан, кордиерит, сребро, алуминий и силициев диоксид). Това голямо разнообразие от материали, прави сортирането на различните компоненти на таблото, в края експлоатационния му живот много трудно.

В допълнение, таблото FBX се състои от около 1800 съставни части, включително фиксиращи 1000. Възлите, съставени от най-голямата бройка части са от прекъсвача за натоварване, предпазителите и контролите. Тези голям брой части могат да доведат до изключително труден демонтаж и сортиране на различните материали. ISO 11469 гласи, че пластмасовите компоненти, които са с тегло над 25 грама трябва да бъдат маркирани постоянно. Пластмасовите компоненти в FBX са маркирани всички, за да се улесни сортирането и да се подобри рециклирането.

Всички използвани материали могат да бъдат рециклирани. Независимо от това, трябва да се отбележи следното: някои части, или много малки, или свързани с други, не могат да бъдат рециклирани, тъй като те правят операцията по рециклиране, много трудна (и нерентабилна).

Каналите за рециклиране, които следва да се използват, са:

■ Материали за рециклиране на метали и пластмаси (механично рециклиране на гранули, субпродукти или химично рециклиране до разпадане на продуктите в мономери).

■ Възможно е също и енергийно базирано валоризиране на използваната пластмаса, спестяване на гориво при производството на енергия, тъй като пластмасите отделят топлина при горене.

Относно използваните газове, Шнайдер Електрик предлага на клиентите си възможността да директно изпомпване навън на резервоара на FBX. В този случай след това SF6 е оползотворен и рециклиран от доставчика.


Екологично въздействие

Софтуерът EIME изчислява екологичното въздействие на базата отчитане на 11 критерия:

- Изчерпване на суровини (RMD)
- Енергийно изчерпване (ED)
- Водно изчерпване (WD)
- Глобално затопляне (GW)
- Намаляване на озоновия слой (OD)
- Токсичност на водата (WT)
- Токсичност на въздуха (AT)
- Образуване на фото-химичен озонов слой (POC)
- Подкиселяване на въздуха (AA)
- Евтрофикация на водата (WE)
- Производство на опасни отпадъци (HWP)

ВЯРНО С ОРИГИНАЛА





Резултатите за въздействието върху околната среда на трите фази (производство (M) - разпределение (D) и употреба (U)) на FBX-ССТ1, проучване върху 30-годишен период

Индикатори	Съкратено	Мярка	S = M + D + U	M	D	U
Изчерпване на суровини	RMD	Y-1	6,28E-12	6,26E-12	1,77E-15	1,80E-14
Енергийно изчерпване	ED	MJ	3,85E+04	1,67E+04	1,58E+03	2,02E+04
Водно изчерпване	WD	dm ³	1,27E+04	1,00E+04	1,19E+02	2,63E+03
Глобално затопляне	GW	g ~CO ₂	5,58E+06	1,34E+06	1,05E+05	4,14E+06
Намаляване на озоновия слой	OD	g ~CFC-11	5,12E-01	2,89E-01	6,64E-02	1,57E-01
Токсичност на въздуха	AT	m ³	6,42E+08	3,44E+08	3,84E+07	2,60E+08
Образуване на фотохимичен озонов слой	POC	g ~C ₂ H ₄	1,01E+03	4,33E+02	1,30E+02	4,47E+02
Подкиселяване на въздуха	AA	g ~H ⁺	5,14E+02	2,75E+02	2,47E+01	2,14E+02
Токсичност на водата	WT	kg	3,52E+05	2,66E+05	1,19E+04	7,44E+04
Еутрофикация на водата	WE	g ~PO ₄	7,18E+01	6,52E+01	1,72E+00	4,91E+00
Производство на опасни отпадъци	HWP	kg	1,93E+01	1,00E+00	5,99E-02	1,82E+01

Първоначално следва да се отбележи, че фазата на разпространението има малко въздействие върху околната среда в сравнение с фазите на употреба и производство. Фазата на производство оказва най-силно въздействие върху околната среда (7 от 11).

Фазите на производство и употреба имат влияние върху глобалната околна среда (RMD, AA & OD по време на първата фаза, GW по време на последната), както и върху околната среда в близост до производствената или експлоатационна площадка (WD, WT, WE и AT за първия; ED & HWP за последния).

Принципният метод на повърхностна обработка представлява електролитно цинково покритие, нанесено чрез използването на галванична вана, последвано от процес на пасивиране с тривалентен хром, много по-малка степен опасен за човека и за околната среда от процеса на хексавалентен хром.

FBX не включва компоненти на оловото (Pb); все пак има няколко сплави със съдържание на олово. Съдържанието на олово FBX е ниско (41 ppm).

Заклучение

Липсата на поддръжка през срока на експлоатация на FBX е основно предимство и потвърждение за надеждността и издръжливостта на оборудването. Въздействията върху околната среда, независимо дали са глобални или локални, се разпростират през фазите на производство и поддръжка. На фаза на употреба оказва въздействие върху глобалното затопляне и производството на отпадъци, докато фазата на производство има въздействие върху водите и изчерпването на суровини.

ВЯРНО С ОРИГИНАЛА

850





Ние се ангажираме да защитим нашата планета посредством "Комбиниран иновации и непрекъснато подобрене за посрещане на новите екологични предизвикателства".

Шнайдер Електрик Индъстрис АД
Ул. Жозеф Моние 35 , Рюейл –Малмезон , Франция
www.schneider-electric.com

Настоящият документ се основава на ISO14020, който се отнася до общите принципи на екологичните декларации и на ISO14025, свързани с тип III декларации за околната среда. Изготвен съгласно инструкциите в Справочника относно екологичните профили на продукта , версия V5.

Изготвен и публикуван от : Шнайдер Електрик
Октомври 2010

ВЯРНО С ОРИГИНАЛА



851