

Приложение ТС 8
към Технически спецификации
от процедура PPD 15-031

ДЕКЛАРАЦИЯ

относно период на функционалност и необслужваемост

Долуподписаният **Ехиязар Гарабед Узунян**, в качеството ми на **управител** на **ИНТЕРКОМПЛЕКС ООД**, със седалище и адрес на управление: **гр. Пловдив бул. Пещерско шосе 201**, вписано в Търговския регистър към Агенцията по вписванията с ЕИК **115096057**, във връзка с обявената процедура за възлагане на обществена поръчка от **ЧЕЗ РАЗПРЕДЕЛЕНИЕ БЪЛГАРИЯ АД**.

Наименование на обекта на обществената поръчка:
„Доставка на товари прекъсвачи СрН /ТПМЗ/“, реф № **PPD 15-031**

ДЕКЛАРИРАМ:


1. Предлаганите мощностни разединители, производство на „АВВ“ – Полша, изпълняват изискването за минимум 4 - годишен период на пълна функционалност и необслужваемост по отношение на контактните системи, лостовите механизми и пружинните задвижвания.
2. Правя настоящата декларация на основание предоставените ми документи от производителя - „АВВ“ – Полша, приложени към настоящата документация.

Известно ми е, че при деклариране на неверни данни, нося наказателна отговорност по чл. 313 от НК.

07.08.2015 година



Ехиязар Узунян



Декларация на производител

До: АББ България ЕООД
бул. Христофор Колумб № 9, ет. 3
1592 София, България

Ние, АББ Sp.z.o.o., разположени на адрес: ул. Зеганска № 1, 04-713 Варшава, производител на товари прекъсвачи за вътрешен монтаж, тип NAL(F), с настоящото потвърждаваме гаранцията за пълна функционалност и необслужваемост за период от най-малко 4 години, считано от датата на доставка по отношение на лостовите механизми, контактните системи и пружинните механизми, при условие, че с тях е работено правилно, в съответствие с ръководството за експлоатация и при стандартни условия. Механичните натоварвания по време на гаранционния период не бива да бъдат превишавани, в противен случай гаранцията е невалидна.

Фирма: фирмен печат на АББ - Полша

Име:

В качеството на:

Подпис: не се чете







ABB Sp. z o.o.
Siedziba spółki
ul. Żegalska 1
04-713 Warszawa
tel.: 22 22 02 000, 22 02 001
fax: 22 22 02 031, 22 02 231



Sąd Rejonowy dla m.st. Warszawy
w Warszawie, XIII Wydział
Gospodarczy Krajowego Rejestru
Sądowego, Nr KRS: 0000004705



NIP: 526-010-44-84, PE: 5260104484
Nr REGON: 140005536W01W
Kapitał zakładowy: 350 655 734,00 zł
www.abb.pl



Warszawa, date: 2015-06-16

Manufacturer's Declaration

To: ABB Bulgaria EOOD
9 Christofor Columbus Blvd.fl.3
1592,Sofia,Bulgaria

We, ABB Sp.z.o.o., located in 1 Zegańska St. 04-713 Warszawa, producer of indoor switch disconnectors NAL(F) type do hereby confirm warranty for full functionality and maintenance free for minimum 4 years period from the delivery date for the lever mechanisms, contact systems and spring mechanisms in case they are operated properly in accordance with operation manual and under standard conditions. Mechanical endurance during the warranty period should not be exceeded, otherwise warranty is void.

The warranty repairs are handed by ABB Sp.z.o.o

Company:
Name:
In the Capacity of:
Signed:

ABB
ABB Sp. z o.o.
ul. Bitwy Warszawskiej 1920 r. nr 18
02-360 Warszawa
NIP 526-030-44-84 REGON 010017168
ODZIAŁ WARSZAWIE
ul. Zegańska 1 Warszawa
tel.(022) 651 52 689

CS
ABB Sp. z o.o.
Siedziba spółki
ul. Zegańska 1
04-713 Warszawa
tel.: 22 22 02 000, 22 02 001
fax: 22 22 02 031, 22 02 231

Sąd Rejonowy dla m.st. Warszawy
w Warszawie, XIII Wydział
Gospodarczy Krajowego Rejestru
Sądowego, nr KRS: 000004745

NIP: 526-030-44-84, PL 5260304484
Nr GROS: E0008536WBW
Kapitał zakładowy: 350 655 734,00 zł
www.abb.pl



ВЯРНО С
ОРИГИНАЛ *ly*

ABB	INSTRUKCJA KONTROLI PRODUKCYJNEJ /PRODUCTION CONTROL INSTRUCTION	
Stanowisko/Stand:	POMIAR REZYSTANCJI STYKÓW / ИЗМЕРВАНЕ НА СЪПРОТИВЛЕНИЕТО RESISTANCE MEASUREMENT	
Numer/Number	IT 04-03-013	Strona 5 z 5

Dopuszczalne wartości rezystancji przedstawia poniższa tabelka (wartości rezystancji podane w $\mu\Omega$)

/For permissible values see chart below (values in $\mu\Omega$)

За граничните стойности виж таблицата по-долу (стойностите са в $\mu\Omega$)

NAL – NALF		L1		L2		L3	
[V]	[A]	Nom.	Max.	Nom.	Max.	Nom.	Max.
12kV	630	66	75	66	75	66	75
	1250	25	35	25	35	25	35
17,5kV - 24kV	630	85	105	85	105	85	105
	1250	35	45	35	45	35	45
36 kV	630-800	52	60	52	60	52	60

Revision	EC No.		Responsible:		Title	Language
	Date		PL-ABB		Pomiar rezystancji styków /Resistance measurement (Измерване на съпротивление)	PL/EN
	Location	Date	Name			Format
Made	PL-ABB	19-02-10	A. Poplawska		IT 04-03-013	A4
Checked	PL-ABB	19-02-10	P. Skwiot			
Approved	PL-ABB	19-02-10	W. Pankratjew			
ABB	ABB Technology Ltd.					



**ВЯРНО С
ОРИГИНАЛА**




40

РЕЗЕРВНИ ЧАСТИ - NAL / NALF

№	№ по каталог	Описание	Тип на товаровия прекъсвач
1		Адаптор, от стар към нов тип изкл. механизъм при изгорял предпазител	NALF12, NALF24
2	1YMX301114M0001	Дъгогасителна камера 12/17/24kV	NAL12, NAL24, NALF12, NALF24
4	1YMX028906M0001	Дъгогасителни контакти 12/17/24/36/40,5 kV (2 psc.)	NAL12, NAL24, NALF12, NALF24
7	1YMX240709M0001	Контактен нож с зацепващо у-во 12-630A	NAL12, NALF12
9	1YMX200143M0001	Контактен нож с зацепващо у-во 17/24-630A	NAL24, NALF24
14	1YMX241266M0009	Механизъм за изключване при изгорял предпазител F3 12/210 от страната на завъртане на подвижните контакти	NALF12
20	1YMX241266M0010	Механизъм за изключване при изгорял предпазител F3 24/275 от страната на завъртане на подвижните контакти	NALF24
23	1YMX343858M0003	Механизъм за изключване при изгорял предпазител, общи пластмасови части 12-36kV	NALF12, NALF24
24	1YMX138662M0001	Изолатор NAL 12kV	NAL12, NALF12
25	1YMX138702M0001	Изолатор NAL 17/24kV	NAL24, NALF24
28	1YMX240717M0001	Изолатор с дъгогасителна камера 12-630A	NAL12, NALF12
30	1YMX240718M0001	Изолатор с дъгогасителна камера 17/24-630A	NAL24, NALF24
33	1YMX304763M0002	Главен контакт, от страната на отваряне 12/17/24-630A	NAL12, NAL24, NALF12, NALF24
36	1YMX400019M0002	Главен контакт, от страната на завъртане на подвижните контакти 12-630A	NAL12, NALF12
38	1YMX342853M0002	Главен контакт, от страната на завъртане на подвижните контакти 17/24-630A	NAL24, NALF24
40	1YMX400094M0002	Бутало с бутален прът 12kV	NAL12, NALF12
41	1YMX400096M0002	Бутало с бутален прът 17/24kV	NAL24, NALF24
43	1YMX023837M0001	Натягаща пружина, дъгогасителен контакт	NAL12, NAL24, NALF12, NALF24
44	1YMX138661M0001	Подпорен изолатор 12kV	NAL12, NALF12
45	1YMX138701M0001	Подпорен изолатор 17/24kV	NAL24, NALF24
47	1YMX241253M0001	Подпорен изолатор за основа за предпазители F 12kV	NALF12

Срок на доставка: до 30 дни след поръчка.

07.08.2015 г.




 Кандидат: ИНТЕРКОМПЛЕКС ООД
 Екипър Узунян - управител

ТИПОВЕ ИЗКЛЮЧВАТЕЛНИ БОБИНИ И СПОМАГАТЕНИ ПРЕВКЛЮЧВАТЕЛИ

Таблица 1

Изключвателна бобина за А-механизъм без помощни контакти	220 VAC	1YMX054740M0001
Изключвателна бобина за А-механизъм без помощни контакти	125 VAC	1YMX054741M0002
Изключвателна бобина за А-механизъм без помощни контакти	110 VAC	1YMX054741M0001
Изключвателна бобина за А-механизъм без помощни контакти	220 VDC	1YMX054742M0001
Изключвателна бобина за А-механизъм без помощни контакти	125 VDC	1YMX054743M0002
Изключвателна бобина за А-механизъм без помощни контакти	110 VDC	1YMX054743M0001
Изключвателна бобина за А-механизъм без помощни контакти	4S V DC	1YMX054744M0001
Изключвателна бобина за А-механизъм без помощни контакти	24 V DC	1YMX054745M0001
Резервна изключвателна бобина за А-механизъм	220 VAC	1YMX054250M0001
Резервна изключвателна бобина за А-механизъм	125 VAC	1YMX054251M0002
Резервна изключвателна бобина за А-механизъм	110 VAC	1YMX054251M0001
Резервна изключвателна бобина за А-механизъм	220 VDC	1YMX054252M0001
Резервна изключвателна бобина за А-механизъм	125 VDC	1YMX054253M0002
Резервна изключвателна бобина за А-механизъм	110 VDC	1YMX054253M0001
Резервна изключвателна бобина за А-механизъм	4S V DC	1YMX054254M0001
Резервна изключвателна бобина за А-механизъм	24 V DC	1YMX054255M0001





Таблица 2

Помощни контакти		
за NAL(F) 12-24	2NO+2NC	1YMX054713M0001
за NAL(F) 12-24	4NO+4NC	1YMX054714M0002
за NAL(F) 12-24	8NO+8NC	1YMX054715M0001
за E/EB 12-24	2NO+2NC	1YMX054716M0001
за E/EB 12-24	4NO+4NC	1YMX054717M0001
за прекъсване от предпазител		1YMX053390M0001


Изключвателните бобини се използват винаги в комплект с помощни контакти, посочени в таблица 2.

07.08.2015 г.

Кандидат ИНТЕРКОМПЛЕКС ООД
 Елиян Узунян - управител

Трансмісія TC 13



Instytut Elektrotechniki Electrotechnical Institute

Certyfikat Systemu Jakości / Certificate of Quality System: PCBC 978/3/2009
Jednostka Notyfikowana przez UE Nr / EU Notified body No: 1460

04-713 WARSZAWA ul. M. Pożaryskiego 28; tel./fax: (48) 22 812 04 07



CERTYFIKAT_{WN} CERTIFICATE_{IV}

Nr/No. 0257/NBR/2013

Wydany na podstawie § 4 ust.4 p.2 Statutu Instytutu Elektrotechniki o badaniach, atestowaniu i certyfikacji aparatów i urządzeń elektrycznych oraz w oparciu o pismo Ministerstwa Gospodarki, Pracy i Polityki Społecznej Nr DIN-V/RK/62/2004 z dnia 8.04.2004 r. uprawniające Instytut Elektrotechniki do wydawania opinii o jakości aparatury i urządzeń elektrycznych wysokiego i niskiego napięcia, prądu przemiennego i stałego oraz wszelkiego sprzętu, oprzyrządowania i komponentów zasilanych energią elektryczną lub przeznaczonych do pracy pod napięciem a także z upoważnienia Short-Circuit Testing Liaison (STL) do wydawania Certyfikatów Badania Typu.

Issued on the basis of § 4 clause 4 p.2 of the Electrotechnical Institute Statute connected with testing attestation and certification of electrical apparatus and the Ministry of Economy, Labour and Social Policy disposition No. DIN-V/RK/62/2004 of 8.04.2004 relating to the authorisation of the Electrotechnical Institute to issue the opinions on the quality of high and low voltage, alternating and direct current electrical apparatus, devices and every equipment, instrumentation and components supplied by electrical energy or designated for live working and according to the Short-Circuit Testing Liaison (STL) authorization for issue Type Test Certificates

Dla: / For:

ABB Sp. z o.o.

Ul. Żegańska 1
04 – 713 Warszawa

Dotyczy wyrobów: / Applies to the product:

Rozłączniki SN

MV Switches

Typu / Type NAL 12; NALF 12 i/and NAL 17,5; NALF 17,5

z Uziemnikami typu / with Earthing Switches types E 12; EB 12 i/and E 17,5 i/and EB 17,5

Certyfikat stanowi podstawę przyjmowania do eksploatacji, wyżej wymienionych wyrobów, dla Zakładów Energetycznych, Elektrowni, Zakładów Przemysłowych oraz innych Przedsiębiorstw wytwarzających, przesyłających lub użytkujących energię elektryczną.

Certificate is the basis for implementation of above mentioned products for Power Engineering Plants, Electric Power Stations, Industry Plants and other Enterprises which generate, transmit or utilize electrical energy.



ВАРНО С
ОРИГИНАЛ

Handwritten signature and initials



CERTYFIKAT WN / CERTIFICATE IV Nr/No. 0257/NBR/2013
STWIERDZENIE DANYCH ZNAMIONOWYCH / STATEMENT OF RATING

Rozłączniki SN / MV Switches

Typu / Type NAL 12; NALF 12 i / and NAL 17,5; NALF 17,5

z Uziemnikami typu / with Earthing Switches types E 12; EB 12 i / and E 17,5 i / and EB 17,5

Na podstawie wyników badań przeprowadzonych w Laboratoriach IEI/LAR - Cert. IEL: 6452/LAR/03; 6855/LAR/05; 6671/LAR/04
 Akc. AB074, SATS, KEMA, NEFI, NEBB zawartych w Sprawozdaniach Nr: 6955/LAR/05; 7126/NBR/06; SATS: 95-B01; 96-B03
 On the basis of results of the tests carried out at the Laboratories IEI/LAR - Accr. NEBB: 790185; 790117; 790155; 790182; KEMA: 810176
 Cert. AB074, SATS, KEMA, NEFI, NEBB included in the test Reports No: 820031; NEFI: 950077; 950078; 910279; 1336; 1337

można przypisać następujące dane znamionowe: / it is assigned the following rating:

Napięcie znamionowe / Rated voltage	12 kV	17,5 kV
Częstotliwość znamionowa / Rated frequency	50 Hz	
Napięcie wytrzymywane o częstotliwości sieciowej Power frequency withstand voltage	42 kV / 48 kV (1min)	45 kV / 60 kV (1min)
Napięcie wytrzymywane udarowe piorunowe Lightning impulse withstand voltage	75 kV / 85 kV _(1,2/50µs)	95 kV / 110 kV _(1,2/50µs)
Prąd znamionowy ciągły / Rated continuous current	400 A; 630 A; 1250 A	
Prąd wyłączeniowy w obwodzie o małej indukcyjności Mainly active load breaking current	400 A; 630 A; 1250 A	
Prąd znamionowy krótkotrwały wytrzymywany Rated short-time withstand current	31,5 kA(1s); 25 kA(2s) 20 kA(3s)	31,5 kA(1s); 25 kA(2s)
Prąd znamionowy szczytowy wytrzymywany Rated peak withstand current	82 kA	
Znamionowy prąd załączeniowy / Rated making current	67 kA	50 kA
Znamionowy prąd wyłączeniowy ładowania kabli i linii Cables charging and lines breaking current	150 A	45 A
Znamionowy prąd zwarcia doziemnego Earth fault breaking current	150 A	70 A
Prąd wyl. ładowania kabli i linii w war. zwarcia doziemn. Cables charging switching current under earth fault condition	90 A	40 A
Znamionowy prąd przechodni / Rated transfer current	1 600 A	
Trwałość mechaniczna ZW / Mechanical endurance CO	2 000 cykli / cycles	
Klasa / Class	E 3	

Niniejszy Certyfikat odnosi się tylko do przedmiotu badanego. Producent ponosi odpowiedzialność za każdy inny wyrób oznaczony tak samo jak wyrób badany. This Certificate applies to the tested object only. The responsibility for conformity of any objects having the same designations as the tested one rests with the Manufacturer.

Termin ważności Certyfikatu: / This Certificate is valid till: 19.08.2016

Przedmiot badania został poddany sprawdzeniu i uznany, w zakresie określonym w Sprawozdaniach za zgodny z normami:
 A sample of the product has been tested and found, in a scope specified in the Test Reports, to be in conformity with the standards:

PN-EN 62271-1:2009 „Wysokonapięciowa aparatura rozdzielcza i sterownicza. Część 1: Postanowienia wspólne”

IEC 62271-1:2007 „High-voltage switchgear and controlgear. Part 1: Common specifications”

PN-EN 62271-102:2005 „Wysokonapięciowa aparatura rozdzielcza i sterownicza.

Część 102: Odłączniki i uziemniki wysokiego napięcia prądu przemiennego”

IEC 62271-102:2001 „High-voltage switchgear and controlgear. Part 102: High-voltage alternating current disconnectors and earthing switches”

PN-EN 60265-1:2001 „Rozłączniki wysokonapięciowe. Część 1: Rozłączniki na napięcie wyższe niż 1 kV i niższe niż 52 kV”

IEC 60265-1:2001 „High-voltage switches Part 1: Switches for rated voltage above 1 kV and less than 52 kV”

PN-EN 62271-105:2005 „Wysokonapięciowa aparatura rozdzielcza i sterownicza. Część 105: Zestawy rozłączników z bezpieczn. prądu przemiennego”

IEC 62271-105:2002 „High-voltage switchgear and controlgear. Part 105: Alternating current switch-fuse combinations”

i normy związane / and related standards

W oparciu o powyższe stwierdza się, że wyrób spełnia wymagania stawiane urządzeniom przeznaczonym do stosowania w elektroenergetyce.

On the basis of above this is to certify that product fulfills requirements stated for the equipment designated in power engineering application.

Laboratorium Badawcze
 Aparatury Rozdzielczej
 High Voltage & Short Circuit Testing Laboratory

Albert Gmiterek

WARSZAWA / Warsaw, 2013-08-19

Dyrektor

Institute of Electrical Engineering
 Director of Electrotechnical Institute

Wiesław Wilczyński



ВЯРНО С
 ОПИТНААА

le 21



Instytut Elektrotechniki Electrotechnical Institute

Certyfikat Systemu Jakości / Certificate of Quality System: PCBC 976/1/2003
Jednostka Notyfikowana Nr / Notified body No: 1460

04-703 WARSZAWA ul. M. Pożaryskiego 28



CERTYFIKAT_{WN} CERTIFICATE_{IV}

Nr/No. **0683/NBR/2014**

Wydany na podstawie § 7 punkt 9 Statutu Instytutu Elektrotechniki o atestowaniu wyrobów oraz zgodnie z pismem Ministerstwa Gospodarki, Pracy i Polityki Społecznej Nr DJN-V/RK/62/2004 z dnia 8.04.2004 r. dotyczącym uprawnienia Instytutu Elektrotechniki do wydawania opinii o jakości aparatury i urządzeń elektrycznych wysokiego i niskiego napięcia, prądu przemiennego i stałego oraz wszelkiego sprzętu, oprzyrządowania i komponentów zasilanych energią elektryczną lub przeznaczonych do pracy pod napięciem a także z upoważnienia Short-Circuit Testing Liaison (STL) do wydawania Certyfikatów Badania Typu.

Issued on the basis of § 7 clause 9 of the Electrotechnical Institute Statute and the Ministry of Economy, Labour and Social Policy disposition No. DJN-V/RK/62/2004 of 8.04.2004 relating to the authorisation of the Electrotechnical Institute to issue the opinions on the quality of high and low voltage, alternating and direct current electrical apparatus, devices and every equipment, instrumentation and components supplied by electrical energy or designated for live working and according to the Short-Circuit Testing Liaison (STL) authorization for issue Type Test Certificates.

Dla / for:

ABB Sp. z o.o.

UL. ŻEGAŃSKA 1
04 - 713 WARSZAWA

Dotyczy wyrobu. / Applies to the product.

ROZŁĄCZNIKI SN


Typ NAL 24 i NALF 24
z Uziemnikami typ E 24 i EB 24

MV SWITCHES

Types NAL 24 and NALF 24
with Earthing Switches type E 24 and EB 24

Certyfikat stanowi podstawę przyjmowania do eksploatacji, wyżej wymienionych wyrobów, dla Zakładów Energetycznych, Elektrowni, Zakładów Przemysłowych oraz innych Przedsiębiorstw wytwarzających, przesyłających lub użytkujących energię elektryczną.

Certificate is the basis for implementation of above mentioned products for Power Engineering Plants, Electrical Stations, Industry Plants and other Enterprises which generate, transmit or utilize electrical energy.



ВЯРНО С
ОРИГИНАЛА



CERTYFIKAT WNV / CERTIFICATE IVV Nr/No. 0683/NBR/2014

STWIERDZENIE DANYCH ZNAMIONOWYCH / STATEMENT OF RATING

Rozłączniki SN typ NAL 24 i NALF 24
z Uziemnikami typ E 24 i EB 24

MV Switches type NAL 24 and NALF 24
with Earthing Switches type E 24 and EB 24

Na podstawie wyników badań przeprowadzonych w Laboratorium IEBLAR
Certyfikat Akredytacji AB 074 i SATS zawartych w Sprawozdaniach Nr:
On the basis of results of the tests carried out at the IEBLAR and SATS
Laboratories included in the Test Reports No:

6975/LAR/05; 6956/LAR/05; 6671/LAR/04
NEFI 95-B04; 1143; 95-B05; 95-B08; 1176; 96-B03
96-B04; 960006; 67; XB 113 H 63; XB 113 H 64

można przypisać następujące dane znamionowe: / It is assigned the following rating:

Napięcie znamionowe / Rated voltage	24 kV
Częstotliwość znamionowa-Liczba faz / Rated frequency-Number of phases	50 Hz - 3
Napięcie wytrzymywane o częstotliwości sieciowej (1 min) Power frequency withstand voltage (1 min)	55 kV / 70 kV
Napięcie udarowe piorunowe wytrzymywane (1,2/50 µs) Lightning impulse withstand voltage (1,2/50 µs)	125 kV / 145 kV
Prąd znamionowy ciągły / Rated continuous current	400 A; 630 A; 1250 A
Prąd wyłączalny w obwodzie przeważnie indukcyjnym Mainly active load breaking current	400 A; 630 A; 1250 A
Prąd wyłączalny ładowania kabli i linii Cable and lines charging breaking current	80 A
Prąd wyłączalny zwarcia doziemnego / Earth fault breaking current	55 A
Prąd wyłączalny ładowania kabli i linii w warunkach zwarcia doziemnego Cables and lines charging breaking current under earth fault conditions	31,5 A
Prąd przechodni znamionowy / Rated transfer current	900 A
Prąd znamionowy krótkotrwały wytrzymywany Rated short-time withstand current	31,5 kA (1s); 31,5 kA (1s); 31,5 kA (1s) 20 kA (2s); 20 kA (2s); 25 kA (2s) 16 kA (3s); 16 kA (3s); 16 kA (3s)
Prąd znamionowy szczytowy wytrzymywany / Rated peak withstand current	82 kA
Prąd załączany zwarciovy / Short-circuit making current	50 kA (2 x)
Trwałość mechaniczna ZW / Mechanical endurance CO	2 000 cykli/cycles
Klasa / Class	E 3

Niniejszy Certyfikat odnosi się tylko do obiektu badanego. Producent ponosi odpowiedzialność za każdy inny wyrób oznaczony tak samo jak obiekt badany. This Certificate applies to the tested object only. The responsibility for conformity of any object having the same designations as the tested one rests with the Manufacturer.

Termin ważności Certyfikatu: / This Certificate is valid till: 01.09.2017

Na podstawie wyników przeprowadzonych badań uznaje się zgodność obiektu, w zakresie określonym w Sprawozdaniach, z załączonymi normami: / A sample of the product has been tested and found, in a scope specified in the Test Reports, to be in conformity with the standards:

- PN-EN 60265-1:2001 „Rozłączniki wysokonapięciowe. Część 1. Rozłączniki na napięcie znamionowe wyższe niż 1 kV i niższe niż 52 kV”
IEC 60265-1:2001 „High voltage switches – Part 1: Switches for rated voltage above 1 kV and less than 52 kV”
PN-EN 62271-102:2003 „Aparatura wysokiego napięcia. Część 102: Odłączniki i uziemniki”
IEC 62271-102:2003 „High voltage switchgear and controlgear. Part 102: High-voltage alternating current disconnectors and earthing switches

W oparciu o powyższe stwierdza się, że wyrób spełnia wymagania stawiane urządzeniom przeznaczonym do stosowania w elektroenergetyce. / On the basis of above this is to certify that product fulfills requirements stated for the equipment designed to power engineering application.

Kierownik
Laboratorium Badawczego
Aparatury Rozdzielczej
Head of High Voltage and Short-Circuit Testing Laboratory

dr inż. Albert Gmitrzak



Warszawa / Warsaw, 2014.09.01

Dyrektor


Instytutu Elektrotechniki
Director of Electrotechnical Institute

dr inż. Stefan Paradowski

ВЯРНОЕ
ОПРЕДЕЛЕНИЕ



40



High Voltage & Short-Circuit Testing Laboratory
Laboratorium Badawcze Aparatury Rozdzielczej
INSTYTUT ELEKTROTECHNICZNY - ELEKTROENERGETYCZNY INSTYTUT ROZDZIELCZY
04-703 WARSZAWA; ul. M. Pożaryskiego 28
tel: (52) 231 82 04 97; tel: (52) 231 82 23 38; e-mail: ipec@ipec.lublin.pl
Certificate PCBC ISO 9001 Nr 076-02003; Notified body Nr 1400

TEST REPORT of type test

Tested apparatus

MV Switches with Earthing Switches

Type

NAL 12 and NAL 17,5; E 12 and E 17,5

Rated voltage:

12 kV / 17,5 kV Rated current: 400 A 600 A 1 250 A Frequency: 50 Hz

Manufacturer

ABB Sp. z o.o.

Oddział w Przasnysz
Ul. Leszno 59; 06-300 Przasnysz

Order

ABB Sp. z o.o.

Ul. Bitwy Warszawskiej 1920 r. Nr 18; 02-366 Warszawa

Date of the test

April 2004

Tested by

Laboratorium Badawcze Aparatury Rozdzielczej
04-703 Warszawa; ul. Pożaryskiego 28
Certyfikat Akredytacji PCA Nr AB 074

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this report has been subjected to the series of proving tests in accordance with the standards IEC 60265 - 1; IEC 62271 - 102

The results are shown in the record of Proving Tests. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the manufacturer. The Test Report applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designators with that tested rests with the Manufacturer.

This Test Report comprises 10 sheets and 5 oscillograms. Only integral reproduction of this Test Report, or reproductions of this page accompanied by any page on which are stated the endorsed ratings of the apparatus tested, are permitted without permission from Laboratory.



Tests were witnessed by ABB representative - mgr eng. Piotr Piekarski

1. Tested objects

- 1a. Current Switch type NAL 12 with Earthing Switch type E 12 - pole distance 150 mm.
- 1b. Current Switch type NAL 17,5 with Earthing Switch type E 17,5 - pole distance 170 mm.

Technical parameters declared by manufacturer

Rated voltage	12 kV	17,5 kV
Rated frequency	50 Hz	
Power frequency withstand voltage 1 min	28 kV	38 kV
To earth and between poles	32 kV	45 kV
Between opened contacts	85 kV	38 kV
Lightning impulse withstand voltage 1,2/50 μs	95 kV	110 kV
To earth and between poles	400 A; 600 A; 1250 A	31,5 kA (1s)
Rated current	82 kA	50 kA
Rated short-time withstand voltage	45 A	70 A
Rated peak withstand voltage	2000 C-O cycles	E3
Rated making current		
Rated breaking current of overhead lines and cables		
Rated breaking current to earth short-circuit		
Mechanical durability		
Class		

ВАРНО С
ОРИГИНАЛ

[Handwritten signature]

2. Test results

Tests performed according to:

IEC 60265 -1 - High voltage switches.

Part 1: Switches on rated voltage above 1 kV and less than 52 kV

IEC 62271 -102 High voltage switchgear and controlgear . Part 102: Disconnectors and earthing switches.

Tests performed in circuit with parameters presented on page 5 in testing circuit presented on page 6.

Expected rms value of current – 31,5 kA

Peak value – 82 kA

Duration – 1 s

View of tested switch NAL 12 prepared to the test demonstrates photo 1.

View from earthing switch E 12 side demonstrates photo 2.

View of tested switch NAL 17.5 prepared to the test demonstrates photo 3.

View from earthing switch E 17.5 side demonstrates photo 4.

Real values of currents during NAL 12 kV switch shows oscillogram No 78694 but for earthing switch E 12 oscillogram No 78696.

Real values of currents during NAL 17.5 kV switch shows oscillogram No 78697 but for earthing switch E 17.5 oscillograms No 78690 and 78695.

Results presented at Table 1

Hazard do not cause any damages of current busses or insulation elements.

Object pass the test

Table 1.

No	No of oscil.	Phase	Current			Time [s]
			peak I_{pr} [kA]	RMS (3 halfperiods) [kA]	interim IS I_m [kA]	
1	78694	L1	-	34	31,8	1,02
		L2	-	34,7	33,2	
		L3	82	36,2	33,3	
2	78696	L1	-	33,6	31,5	1,02
		L2	-	35	33,0	
		L3	82,2	37,0	32,0	
3	78697	L1	-	34,4	31,4	1,02
		L2	-	35,1	32,8	
		L3	82,0	37,5	32,0	
4	78690	L1	-	-	31,3	1,2
		L2	-	-	32,5	
		L3	-	-	32	
5	78695	L1	-	-	-	0,11
		L2	-	-	-	
		L3	89,9	-	-	



ВЕРНО С
ОРИГІНАЛ

TEST CONDITIONS

Of short-time and peak withstand current test

Tested object:

MV Switches NAL

Test circuit:

according to the diagram

GENERATOR: TJ 25

Configuration : star

Neutral : earthed by resistor 700 Ω

TRANSFORMER: TWP

Configuration of supplied windings : triangle

Configuration of supplying windings : star

Neutral : earthed

supplying 10 kV


ratio $\frac{\text{supplied}}{\text{supplying}} = \frac{0.25 \times \sqrt{3} \text{ kV}}{10 \text{ kV}}$

Short-circuit place:

insulated

Testing chamber:

No 1



Testing diagram




[Handwritten signature]

[Handwritten signature]




**ВЯРНО С
ОРИГИНАЛА**

[Handwritten signature]
49



View of tested apparatus from earthing switch E 12 side



View of Switch NAL 12 before the test inside testing chamber

[Handwritten signature]



**ВЯРНО С
ОРИГИНАЛА**


[Handwritten signature]



View of tested apparatus from earthing switch E 17,5 side



Handwritten signature





View of Switch NAL 17,5 before the test inside testing chamber

Handwritten signature





**ВЯРНО С
ОРИГІНАЛА**

Handwritten number 21 51



ВЕРНО С
ОРИГИНАЛА

51



[Handwritten signature]

[Handwritten signature]




ВЕРНО С
ОРИГИНАЛ

[Handwritten signature]

Date: 2004-04-23 14:07:17 Oscylogram №: 78697

LABORATORIAE MEDICINAE
KARLSKAIA



[Handwritten signature]



ВЯРНО С
ОРИГИНАЛ

[Handwritten signature]



SPRAWOZDANIE Nr / TEST REPORT No. 6957/LAR/05

ZAKŁAD WIELKICH MOCY HIGH POWER DEPARTMENT

INSTYTUT ELEKTROTECHNIKI - ELECTROTECHNICAL INSTITUTE 04-703 WARSZAWA, ul. M. Podgórskiego 28 tel./fax.: (0-22) 812 04 07; tel.: (0-22) 812 25 38; e-mail: iw@iel.waw.pl

SPRAWOZDANIE Z PRÓB W WARUNKACH ZWARCIA DOZIEMNEGO TEST REPORT OF TESTS UNDER EARTH FAULT CONDITIONS

BADANY APARAT APPARATUS

TYP DESIGNATION

Napięcie znamionowe 24 kV Rated Voltage

PRODUCENT MANUFACTURER

ZLECENIODAWCA TESTED FOR

DATA BADAŃ DATE(S) OF TESTS

WYKONAŁ WCA BADAN TESTED BY

Przedmiot badań, wykonany zgodnie z dokumentacją, rysunkami konstrukcyjnymi i fotografiami, stanowiącymi załącznik do niniejszego sprawozdania, poddany został próbom zgodnie z normą PN-EN 60265-1:2001. The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this report has been subjected to the series of proving tests in accordance with PN-EN 60265-1:2001

Niniejsze Sprawozdanie odnosi się wyłącznie do badanego obiektu. Producent ponosi odpowiedzialność za każdy egzemplarz wyrobu oznakowany identycznie jak wyrób badany. The Test Report applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designators with that tested tests with the Manufacturer.

Sprawozdanie zawiera ogółem 28 stron i może być powielane wyłącznie w całości. Powielanie częściowe dozwolone jest po uzyskaniu pisemnej zgody Laboratorium LAR. This Test Report comprises 28 sheets in total. Only integral reproduction of this Test Report is permitted without written permission from LAR Laboratory

Kierownik Laboratorium / Head of Laboratory

Ph. D. Eng. Albert Gmitrzak

Warszawa 07.06.2005



ВЯРНО С ОПРИГНАЛА

PARAMETRY TECHNICZNE DEKLAROWANE PRZEZ PRODUCENTA I POTWIERDZONE BADANIAMI RATINGS ASSIGNED BY THE MANUFACTURER AND PROVED BY TESTS

Table with 2 columns: Parameter (Voltage, Earth fault current, Cable charging current, Frequency) and Value (24 kV, 55 A, 31.5 A, 50 Hz)

WYKAZ PRÓB / SUMMARY OF TESTS

Table with 2 columns: Test description (Earth fault test, Cable charging test) and Page number (5, 6)

PN-EN 60265-1:2001 Rozłączniki na napięcia znamionowe wyższe niż 1 kV i niższe niż 52 kV. Część 1: Rozłączniki na napięcia znamionowe wyższe niż 1 kV i niższe niż 52 kV.

W badaniach uczestniczył / The tests were observed by:

mgr inż. Tomasz Sinkiewicz ABB Sp. z o.o. Oddział w Przasnyszu, ul. Leszno 59, 06-300 Przasnysz

Dokumenty identyfikacyjne / Identification of the apparatus

Wymiary obiektu są zgodne z dołączonymi rysunkami wymiarowymi. The apparatus is constructed in accordance with the drawings incorporated in this report.

Rysunek / Drawing: NHP 343070

Handwritten signature



RODZAJ PROBY TYPE OF TEST	Łączenie prądu zwarcia doziemnego (szereg probierczy 6a) Earth fault off-load switching current test (test duty 6a)	OBWÓD PROBIERCZY TEST CIRCUIT	OP1
G WB ZZ D T			
G	Generator TJ 100		
WB	Wyłącznik bezpieczeństwa Master breaker		
ZZ	Zalącznik zwiarcioowy Making switch		
D	Dławiki Inductance		
T	Transformator Transformer		
DN	Dzielnik napięcia Voltage divider		
PP	Przekładnik prądowy Current transformer		
OB	Obiekt badany Tested object		

RODZAJ PROBY TYPE OF TEST	Łączenie prądów ładowania kabli i linii napowietrznych w warunkach zwarcia doziemnego (szereg probierczy 6b) Cable charging switching current under earth fault conditions (test duty 6b)	OBWÓD PROBIERCZY TEST CIRCUIT	OP2
G WB ZZ D T			
G	Generator TJ 100		
WB	Wyłącznik bezpieczeństwa Master breaker		
ZZ	Zalącznik zwiarcioowy Making switch		
D	Dławiki Inductance		
T	Transformator Transformer		
DN	Dzielnik napięcia Voltage divider		
PP	Przekładnik prądowy Current transformer		
OB	Obiekt badany Tested object		



ВЕРНО С
ОРИГИНАЛ



TESTS RESULTS



RODZAJ PRÓBY TYPE OF TEST	Łączenie prądu zwarcia doziemnego (szereg probierczy 6a) Earth fault off-load switching current test (test duty 6a)	OBWÓD PROBIERCZY TEST CIRCUIT	OP1
Typ napędu / Operating mechanism: Typ: NMMDI 220V AC/DC Art: 5DLN 527601-F			
Numer oscylogramu Oscillogram no.	Napięcie probiercze Test voltage (kV)	Prąd probierczy I_{ob} Test current I_{ob} (A)	Uwagi Remarks
80719	24.0	55.0	
80722	24.4	58.6	
80723	24.4	58.5	
80724	24.3	57.9	
80725	24.5	58.8	
80726	24.5	58.8	
80727	24.3	57.6	
80728	24.3	57.8	
80729	24.3	57.6	
80730	24.5	58.8	



ВЕРНО С
ОРИГИНАЛА 01 57



RODZAJ PRÓBY TYPE OF TEST	Łączenie prądów ładowania kabli i linii napowietrznych w warunkach zwarcia doziemnego (szereg probierczy 6b) Cable charging switching current under earth fault conditions (test duty 6b)	OBWÓD PROBIERCZY TEST CIRCUIT	OP2
Wartości prądów i napięć są podawane kolejno dla fazy L1 i L2. Current and voltage values are given for L1 and L2.			
Typ napędu / Operating mechanism: Typ: NMMDI 220V AC/DC Art: 5DLN 527601-F			
Numer oscylogramu Oscillogram no.	Napięcie probiercze Test voltage (kV)	Prąd probierczy I_{ob} Test current I_{ob} (A)	Uwagi Remarks
80704	24.9	33.2	
	24.6	31.5	
80709	25.3	32.4	
	24.7	32.9	
80710	25.3	32.4	
	24.8	32.5	
80711	24.7	31.7	
	24.2	31.5	
80712	25.0	32.4	
	24.7	32.3	
80713	24.6	32.1	
	24.3	32.1	
80714	25.1	32.5	
	24.8	33.1	
80715	24.5	32.3	
	24.1	32.4	
80717	24.9	32.7	
	24.7	32.5	
80718	25.0	32.3	
	24.5	31.9	





Sprawozdanie z badań Nr Test Report No. 6957/LAR/05 Strona/Page 12/28

INSTYTUT ELEKTROTECHNIKI
LABORATORIUM BADAWCZE APARATURY ROZDZIELCZEJ
ELECTROTECHNICAL INSTITUTE
SWITCHGEAR AND CONTROLGEAR TESTING LABORATORY



Data: 2005-05-31 10:36:38 Oscylogram Nr: 80726




Sprawozdanie z badań Nr Test Report No. 6957/LAR/05 Strona/Page 11/28




INSTYTUT ELEKTROTECHNIKI
LABORATORIUM BADAWCZE APARATURY ROZDZIELCZEJ
ELECTROTECHNICAL INSTITUTE
SWITCHGEAR AND CONTROLGEAR TESTING LABORATORY




Data: 2005-05-31 10:32:57 Oscylogram Nr: 80725




ВРНО С
ОРИГИНАЛ 61



ВЕРНО С
ОРИГИНАЛ



[Handwritten signature]




[Handwritten signature]





ВЕРНО С
ОРИГИНАЛА

[Handwritten marks]



[Handwritten signature]





[Handwritten signature]




ВЕРНО С
ОРИГИНАЛА

[Handwritten initials] 64




ВЕРНО С
ОРИГИНАЛА


01 65



Oszylogram Nr. 80715 Data: 2005-05-30 13:53:45





Oszylogram Nr. 80714 Data: 2005-05-30 13:50:22




ВЕРНО С
ОРИГИНАЛА

01 66



ВЕРНО С
ОРИГИНАЛА

61 67



LABORATORIUM BADAWCZE APARATURY ROZDZIELCZEJ High Voltage & Short-Circuit Testing Laboratory INSTYTUT ELEKTROTECHNIKI - ELECTROTECHNICAL INSTITUTE 04-703 WARSZAWA: ul. M. Pożaryskiego 28 tel./fax: (+8-23) 812 04 07, tel.: (+8-23) 812 23 38, e-mail: iwar@iel.pwr.edu.pl Certyfikat PCBC ISO 9001 Nr 97601/2003; EU Notified body Nr 1460

TEST REPORT of short-circuit performance

TESTED APPARATUS MV Fuse Switch combination NALF 12-6A I50R version KL; Fuses: CEF 12-125A TYPE 12 kV Rated current 125 A Frequency 50 Hz

ABB Sp. z o.o. Oddział w Przasnyszu Ul. Leszno 59; 06 - 300 Przasnysz ABB Sp. z o.o. Ul. Żegańska 1; 04-713 Warszawa 19.06.2007

MANUFACTURER BORDERER DATE of the TEST TESTED BY

Laboratorium Badawcze Aparatury Rozdzielczej 04-703 Warszawa; ul. Pożaryskiego 28 Certyfikat Akredytacji PCA Nr AB 074


The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this report has been subjected to the series of proving tests in accordance with the standards IEC60694:2002; PN-EN60694:2004; IEC62271-105; PN-EN62271-105:2004(U); PN-EN60265-1:2001

The results are shown in the record of Proving Tests. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the manufacturer. The Test Report applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designators with that tested rests with the Manufacturer.

This Test Report comprises 11 sheets in total, 3 oscillograms included. Only integral reproduction of this Test Report, or reproductions of this page accompanied by any page on which are stated the endorsed ratings of the apparatus tested, are permitted without permission from Laboratory.

Head of Laboratory Dyring Albert Gmityzak

Warsaw 28.06.2007



ВАРНО С ОРИГИНАЛА

Handwritten initials and date

Tests performed

Standard's PN-EN 60694 item 6.6 Short-time and peak withstand current

Appearance of tested apparatus shows drawings on pages 3 - 5

Tests were performed according to:

PN-EN 60694:2004 „Pozanowienia wspolne dotyczace norm na wysokonapieciowa aparature rozdzielcza i sterownicza”

IEC 60694:2002 „Common specifications for high-voltage switchgear and controlgear standards”

PN-EN 62271-105:2004(U) „Wysokonapieciowa aparatura rozdzielcza i sterownicza. Czesc 102: Wysokonapieciowe zestawy rozlacznikow z bezpiecznikami”

IEC 62271-105 „High-voltage alternating current fuse switch combinations”

PN-EN 60265-1:2001 „Rozlaczniki wysokonapieciowe. Czesc 1: Rozlaczniki na napiecie znamionowe wyzsze niz 1 kV i nizsze niz 52 kV”

Tests were witnessed by ABB representative mgr inz. Wojciech Pankratiew


Short-circuit test result

Table with columns: No, No of oscill., Phase, Peak value, RMS expected value, Limited value, Time. It contains three rows of test results for phases L1, L2, and L3.


Any deformations of current buses and supporting insulation elements were observed. Fuse links don't changes positions. Oscillograms enclosed.

Tested apparatus pass the test

7484a/LAR/07
Page 4



[Handwritten signature]



7484a



[Handwritten signature]



ВЯРНО С
ОРИГІНАЛА

[Handwritten initials]





TEST CONDITIONS
Of short-time and peak withstand current test

Tested object: **NALF 12-6A 150R**
 Test circuit: according to the diagram
GENERATOR: TJ 25
 Configuration: star
 Neutral: earthed by resistor 700 Ω

TRANSFORMER: TWP
 Configuration of supplied windings: triangle
 Configuration of supplying windings: star

Neutral: earthed
 supplying = 10 kV
 supplied = $0.25 \times \sqrt{3}$ kV

Short-circuit place: insulated
 Testing chamber: No 1



Standard references for marking and forming:
 Lengths and angles dimensions: mm
 Form and position: DN ISO 2768 T1
 Tolerance: DN ISO 2768 T2

RESERVE ALL RIGHTS IN THIS DOCUMENT AND IN THE INFORMATION CONTAINED THEREIN. REPRODUCTION, USE OR DISCLOSURE TO THIRD PARTIES WITHOUT EXPRESS AUTHORITY IS STRICTLY FORBIDDEN.

Material	MGS	Material	Standard	Quantity	Agg.	Weight
Type		Supplier	Supplements	Supplementarity		
Revision		Manufacturer	PL-ABB	Title	Support for fuse contacts	
Location		Date	2007-04-17	Author	Scale	1:1
Drawn	PL-ABB	Name	P. Skwiniot	Checked	Language	EN
Checked	PL-ABB	Date	2007-04-17	Drawn	Formate	A4
Approved	PL-ABB	Name	A. Syniowski	Checked	Sheet No.	1/1
Signature	PL-ABB	Date	2007-04-17	Approved	Drawing No.	1YMX888246
Signature	PL-ABB	Name	W. Pankratjev	Signature		
Signature	PL-ABB	Name	PIPM	Signature		

ВЯРНО С
ОРИГИНАЛ



- Signi.
- G - Generator TJ - 25
 - R - Resistor
 - WB - Circuit breaker
 - ZZ - Making switch
 - DL - Reactors
 - T - Transformer TWP
 - B - Shunts





Diagram of short-time and peak withstand current test

**ВЯРНО С
ОРИГИНАЛА**




[Handwritten signature]




Tested apparatus on the short-circuit testing stand

7484a/LAR/07
Page 10



7484a/LAR/07
Page 9



ВЯРНО С
ОРИГИНАЛ

Handwritten initials or marks.


[Handwritten signature]

Date: 2007-06-19 12:00:24 Oscylogram Nr. 83834

LABORATORIUM BADAŃ CHEM. I FIZYK. WARSZAWA

ROZŁĄCZENIA ILMF 12P150-4YXKL

7484a/LAR/07 Page. 11



[Large handwritten signature]



ВЕРНО С
ОРИГИНАЛА

[Handwritten initials]



SPRAWOZDANIE Nr / TEST REPORT No. 6956/LAR/05

ZAKŁAD WIELKICH MOCY

HIGH POWER DEPARTMENT
INSTYTUT ELEKTROTECHNIKI - ELECTROTECHNICAL INSTITUTE
04-703 WARSZAWA, ul. M. Pełczyńskiego 23
tel./fax: (0-22) 812 04 07; tel: (0-22) 812 23 38; e-mail: awr@iel.waw.pl
Certyfikat Akredytacji / Certificate Accreditation PCA Nr. AB 074



SPRAWOZDANIE Z BADANIA PRĄDU PRZECHODNIEGO
TEST REPORT OF BREAKING TESTS AT THE TRANSFER CURRENT
ZESTAW ROZŁĄCZNIKA Z BEZPIECZNIKAMI
SWICH-FUSE COMBINATION

TYP NALF 24 **Nr seryjny** 14665/2005
DESIGNATION **Serial No.**
Napięcie znamionowe 24 kV **Częstotliwość** 50 Hz
Rated Voltage **Rated Frequency**

PRODUCENT ABB Sp. z o.o.
MANUFACTURER ul. Bitwy Warszawskiej 1920 r. nr 18, 02-366 Warszawa
Oddział w Przasnyszu, ul. Leszno 59, 06-300 Przasnysz

CELENIODAWCA ABB Sp. z o.o.
TESTED FOR 18.05.2005
DATA BADAŃ Laboratorium Badawcze Aparatury Rozdzielczej
DATE(S) OF TESTS Switchgear and Controlgear Testing Laboratory
WYKONAWCA 04-703 Warszawa; ul. Połczyńskiego 28, Certyfikat Akredytacji PCA Nr AB 074
TESTED BY

Przedmiot badań, wykonany zgodnie z dokumentacją, rysunkami konstrukcyjnymi i fotografiami, stanowiącymi załącznik do niniejszego sprawozdania, poddany został próbom zgodnie z normą PN-EN 62271-105:2004 (U).
The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this report has been subjected to the series of proving tests in accordance with PN-EN 62271-105:2004 (U).

Niniejsze Sprawozdanie odnosi się wyłącznie do badanego obiektu.
Producent ponosi odpowiedzialność za każdy egzemplarz wyrobu oznakowany identycznie jak wyrób badany.
The Test Report applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designators with that tested rests with the Manufacturer.

Sprawozdanie zawiera ogółem 13 stron i może być powielane wyłącznie w całości.
Powielanie częściowe dozwolone jest po uzyskaniu pisemnej zgody Laboratorium LAR.
This Test Report comprises 13 sheets in total.
Only integral reproduction of this Test Report is permitted without written permission from LAR Laboratory

Kierownik Laboratorium / Head of Laboratory



ВАРНО
ОРИГИНАЛ 45

Ph. D. Eng. Albert Gmitrzak

Warszawa 07.06.2005

PARAMETRY TECHNICZNE DEKLAROWANE PRZEZ PRODUCENTA
RATINGS ASSIGNED BY THE MANUFACTURER AND PROVED BY TESTS

Napięcie znamionowe 24 kV
Voltage
Prąd przechodni znamionowy 900 A
Rated transfer current
Częstotliwość 50 Hz
Frequency

WYKAZ PRÓB / SUMMARY OF TESTS

	STRONA PAGE
Próba wyłączenia prądu znamionowego przechodniego 1250A Breaking test at the rated transfer current 1250 A	4
Próba wyłączenia prądu znamionowego przechodniego 900A Breaking test at the rated transfer current 900 A	4

PN-EN 62271-105:2004 (U) Wysokonapięciowa aparatura rozdzielcza i sterownicza.
Część 105: Wysokonapięciowe zestawy rozłączników z bezpiecznikami.


W badaniach uczestniczył / The tests were observed by:

mgr inż. Tomasz Sinkiewicz ABB Sp. z o. o.
Oddział w Przasnyszu, ul. Leszno 59, 06-300 Przasnysz

Dokumenty identyfikacyjne / Identification of the apparatus

Wymiary obiektu są zgodne z dołączonymi rysunkami wymiarowymi.
The apparatus is constructed in accordance with the drawings incorporated in this report.

Rysunek / Drawing: 343379



ВЯРНО С
 ОПИТНААА


21 46




TESTS RESULTS

RODZAJ PRÓBY	Próba wyłączenia prądu znamionowego	OBWÓD PROBIERCZY	TEST CIRCUIT	OP1
TYPE OF TEST	Breaking test at the rated transfer current 900 A			
Wartości prądów i napięć są podawane kolejno dla fazy L1, L2 i L3. Current and voltage values are given for L1, L2 and L3.				
Typ bezpiecznika / Fuse type: CEF 24 kV - 100 A				
Numer oscylogramu	Napięcie probiercze (kV)	Prąd probierczy wyłączany przez rozłącznik (kA)	Uwagi	Remarks
80671	24.0	1.13 1.12		Rozłącznik nie wyłączył prądu Switch failed to break the current

RODZAJ PRÓBY	Próba wyłączenia prądu znamionowego	OBWÓD PROBIERCZY	TEST CIRCUIT	OP1
TYPE OF TEST	Breaking test at the rated transfer current 900 A			
Wartości prądów i napięć są podawane kolejno dla fazy L1, L2 i L3. Current and voltage values are given for L1, L2 and L3.				
Typ bezpiecznika / Fuse type: CEF 24 kV - 80 A				
Numer oscylogramu	Napięcie probiercze (kV)	Prąd probierczy wyłączany przez rozłącznik (A)	Uwagi	Remarks
80674	23.9 23.9 24.1	784 784 -		
80675	23.3 23.3 24.5	784 - 784		
80679	23.3 23.5 24.3	- 783 784		



[Handwritten signature]





[Large handwritten signature]



ВЕРНО С
ОРИГИНАЛ



[Handwritten initials]



ВЕРНО С
ОРИГИНАЛ

Test object before test with the fuse in phase L3
 Obiekt badany z bezpiecznikiem w fazie L3 przed próbą

Test object after test with the fuse in phase L3
 Obiekt badany z bezpiecznikiem w fazie L3 po próbie



Sprawozdanie z Badań Nr
 Test Report No.
 6956L AR/05
 Strona/Page 10/13



INSTYTUT ELEKTROTECHNIKI
 LABORATORIUM BADAWCZE APARATURY I KONTROLI
 SWITCHGEAR AND CONTROL GEAR TESTING LABORATORY



[Handwritten signature]

Test object before test with the fuse in phase L3
 Obiekt badany z bezpiecznikiem w fazie L3 przed próbą

Test object after test with the fuse in phase L3
 Obiekt badany z bezpiecznikiem w fazie L3 po próbie




Sprawozdanie z Badań Nr
 Test Report No.
 6956L AR/05
 Strona/Page 9/13

INSTYTUT ELEKTROTECHNIKI
 LABORATORIUM BADAWCZE APARATURY I KONTROLI
 SWITCHGEAR AND CONTROL GEAR TESTING LABORATORY



ВЯРНО С
 ОРИГИНАЛ


[Handwritten initials]



I = 900 A
 Obiekt badany z bezpiecznikiem w fazie L1 po próbie
 Test object after test with the fuse in phase L1


Sprawozdanie z Badań Nr
 Test Report No.
 6956/L AR/05
 Strona/Page 12/13

INSTYTUT ELEKTROTECHNIKI
 LABORATORIUM BADAWCZE APARATURY ROZDZIELCZEJ ELEKTROTECHNICZAL INSTITUTE
 SWITCHGEAR AND CONTROL GEAR TESTING LABORATORY



I = 900 A
 Obiekt badany z bezpiecznikiem w fazie L1 przed próbą
 Test object before test with the fuse in phase L1


[Handwritten signature]



I = 900 A
 Obiekt badany z bezpiecznikiem w fazie L2 po próbie
 Test object after test with the fuse in phase L2

Sprawozdanie z Badań Nr
 Test Report No.
 6956/L AR/05
 Strona/Page 11/13

INSTYTUT ELEKTROTECHNIKI
 LABORATORIUM BADAWCZE APARATURY ROZDZIELCZEJ ELEKTROTECHNICZAL INSTITUTE
 SWITCHGEAR AND CONTROL GEAR TESTING LABORATORY




I = 900 A
 Obiekt badany z bezpiecznikiem w fazie L2 przed próbą
 Test object before test with the fuse in phase L2



ВРНО С
 ОПИЛНАА *01 80*

[Handwritten signature]



Sprawy z Balan Nr
Test Report No.
6956/LAR/05
Siemra/ Page 13/13

INSTYTUT ELEKTROTECHNICZNY
LABORATORIUM BADAWEK APARATURY KOZDZIELCZEJ I ELEKTROTECHNICZNEJ
SWITCZOWEJ I KONTROLI TESTING LABORATORY

[Large handwritten signature]



ВЯРНО
ОРИГИНАЛ

[Handwritten signature]

Report No.: 1143 Page No.: 1

REPORT OF PERFORMANCE

Apparatus: High-voltage switch disconnecter
Designation: NAL-24 with type A mechanism
Client: ABB Distribusjon AS, Sklen, Norway
Manufacturer: ABB Distribusjon AS, Sklen, Norway
Date(s) of test: 20. and 23. of October 1995

The test has been in accordance with:
 The client's instruction based on IEC Publication 265-1, Second edition 1983, § 6.101. Making and breaking tests. Test duty no. 4.

The performance of the apparatus tested and the observations made during the test have been recorded in tables with test results and hardcopies from data acquisition system. The documents of this report are:

Ratings of the test object:	Page No.:
Technical Data of Test Circuit:	Page No.: 8
Test result(s) / Conclusion:	Page No.: 3
Table(s) with test results:	Page No.: 4 to 7
Circuit diagram(s):	Page No.: 9
Drawings(s):	Page No.: 10 and 11
Photo(s):	Page No.: 12
Client's observer(s):	Page No.:
Data acquisition (Oscillograms):	Rec. No.: 18871, 34871 and 34972, 34874 to 34893, 34996 to 35007

Sklen, 25. of Oct. 1995

Bjørn Kamperhaug
Bjørn Kamperhaug
(Test Engineer)

Tor Bratberg
Tor Bratberg
(Technical Manager)

Copy right. Publication or reproduction of this report in any other form than by complete copy to the letter, is prohibited without our written consent.

NEFI Kortslutningslaboratorium (High Power Laboratory)
P. O. Box 108, Sentrum, 3701 SKIEN | Sjøliervegen 71, 3721 SKIEN, Norway - Tel.: +47 35590338 - Fax: +47 35590815
FIN-RAPPTERTY 1143 DOC

Report No.: 1143

Page No.: 1

REPORT OF PERFORMANCE

Apparatus: High-voltage switch disconnecter
Designation: NAL-24 with type A mechanism
Client: ABB Distribusjon AS, Sklen, Norway
Manufacturer: ABB Distribusjon AS, Sklen, Norway
Date(s) of test: 20. and 23. of October 1995

The test has been in accordance with:

The client's instruction based on IEC Publication 265-1, Second edition 1983, § 6.101. Making and breaking tests. Test duty no. 4.

The performance of the apparatus tested and the observations made during the test have been recorded in tables with test results and hardcopies from data acquisition system. The documents of this report are:

Ratings of the test object:	Page No.:
Technical Data of Test Circuit:	Page No.: 8
Test result(s) / Conclusion:	Page No.: 3
Table(s) with test results:	Page No.: 4 to 7
Circuit diagram(s):	Page No.: 9
Drawings(s):	Page No.: 10 and 11
Photo(s):	Page No.: 12
Client's observer(s):	Page No.:
Data acquisition (Oscillograms):	Rec. No.: 18871, 34871 and 34972, 34874 to 34893, 34996 to 35007

Sklen, 25. of Oct. 1995

Bjørn Kamperhaug
Bjørn Kamperhaug
(Test Engineer)

Tor Bratberg
Tor Bratberg
(Technical Manager)

Copy right. Publication or reproduction of this report in any other form than by complete copy to the letter, is prohibited without our written consent.

NEFI Kortslutningslaboratorium (High Power Laboratory)
P. O. Box 108, Sentrum, 3701 SKIEN | Sjøliervegen 71, 3721 SKIEN, Norway - Tel.: +47 35590338 - Fax: +47 35590815
FIN-RAPPTERTY 1143 DOC

Test object

The test object was a high-voltage switch disconnecter type NAL 24 with a stored energy, independent manually spring operated mechanism type A.

The test object was marked with serial no. N 27720.

Publication

The client's instruction based on IEC Publication 265-1, Second edition 1983, § 6.101, Test duty no. 4.

Test procedure

The purpose of the test was to verify a breaking capacity with a capacitive load of 80 A at a test voltage of 24 kV.

The test was performed with breaking operations only. The switch disconnecter was operated by means of the 220 V DC trip coil.

The switch disconnecter was mounted in a test rack in vertical position.

A rotating pointer was fastened to the rotating centre of the main contact knife in phase R, in order to control the condition of the switch disconnecter and to calculate the arcing times.

Tests performed

- A No load test, closing operation, rec no. 34971
- B No load test, opening operation, rec no. 34972
- C Resistance measurement at 100 A DC, between the termination contacts of each pole
- D 20 breaking operations with capacitive load, with the supply circuit connected to the upper side of the switch disconnecter, rec. no. 34974 to 34993
- E 10 breaking operations with capacitive load, with the supply circuit connected to the lower side of the switch disconnecter, rec. no. 34996 to 35005

ВРНОС
ОРИГИНАЛ

- F No load test, closing operation, rec no. 35006
- G No load test, opening operation, rec no. 35007
- H Resistance measurement at 100 A DC, between the termination contacts of each pole

Test result

The values obtained during the test are listed in tables on page no. 4 to 7.
 The test object fulfilled the requirement for the test. It was no sign of any burning marks on the main contacts.
 No re-ignitions or restrikes occurred during the breaking operations.
 The over-voltages during the breaking operations were far below the permitted limit.

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛ
01 83



Performance under No-Load condition
Values recorded

Type of apparatus: High-voltage switch disconnector with a two spring mechanism
 Travel recorder: Rotating polymer linear to the relation of the main contact knife in phase k
 Closing device: Manually by means of the handle
 Opening device: By means of the 220 V DC trip coil

Total travel closing contacts: 334 mm (circle sector)		Total travel opening contacts: 406 mm (circle sector)	
Test Number	Oscillogram, Record Number	Operation	Remarks
A	3497 I	C	
B	3497 II	O	
C	3497 III	NONE	
D		C	
E		O	
F		NONE	
G		C	
H		O	
Travel after contact touch (Last phase to separate) 31 mm Travel to contact separation (First phase to separate) 80.4 mm Closing speed 7.5 m/s First cursor reference (before contact touch) 10.3 mm Last cursor reference (after first cursor ref.) 6.0 mm Opening speed 6.0 m/s First cursor reference (after contact sep.) 0 ms Last cursor reference (after first cursor ref.) 6.1 mm Resistance measurement between termination contacts at 100 A DC. (micro ohm) Ambient temperature 23.5 Deg C Signature BKA Date 19.10.95			

NO-LOAD

Test D

Testing of Making- and Breaking-Capacity
Values recorded

Test require ment: Cont. from previous page
Operating sequence: Cont. from previous page
Type of test circuit: _____
Connections to apparatus tested: _____
Supply from the upper side: _____

Ambient temperature: 22 Deg. C
Test date: 20.10.95.
Signature: DKA

Test-No.	Oscillogram No.	Operation	Voltage before test	Making current (Max. value) A	Breaking current	Average	Recovery voltage	Recovery voltage	Average between phases	Closing-/Opening time	Arcing time
11	34984	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0
12	34985	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0
13	34986	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0
14	34987	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0
15	34988	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0
16	34989	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0
17	34990	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0
18	34991	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0
19	34992	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0
20	34993	0	0	0	0	80,7	24,1	24,1	24,1	8,0	8,0

Remarks: Cont. next page

Condition of apparatus after Test:

Test D

Testing of Making- and Breaking-Capacity
Values recorded

Test requirement: IEC 265-1 TD 1
Operating sequence: 20 x Open
Condition of apparatus before test: New and clean

Ambient temperature: 22 Deg. C
Test date: 20.10.95.
Signature: DKA

Test-No.	Oscillogram No.	Operation	Voltage before test	Making current (Max. value) A	Breaking current	Average	Recovery voltage	Recovery voltage	Average between phases	Closing-/Opening time	Arcing time
1	34974	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0
2	34975	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0
3	34976	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0
4	34977	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0
5	34978	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0
6	34979	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0
7	34980	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0
8	34981	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0
9	34982	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0
10	34983	0	0	81,3	79,8	81,0	24,2	24,2	24,2	8,0	8,0

Remarks: Cont. next page

Condition of apparatus after Test:

ВРНО С
ОРИГИНАЛ 84



Testing of Making- and Breaking Capacity
Values recorded

Requirement: IEC 265-1 PD 4
Operating sequence: 10 x Open
Condition of apparatus before test: Pretested during test
Condition of apparatus after test: See page no. 3.

Remarks:

Test-No.	Oscillogram No.	Operation	Voltage before test	Making current (Max. value) A	Breaking current	Average voltage	Recovery voltage	Average between phases	Closing-/Opening time	Arcing time
21	34996		0	R 81,6	R 81,6	80,9	24,2	24,3	8,5	3,5
22	34997		0	A S 80,1	T 81,1	80,9	24,2	24,3	8,5	3,5
23	34998		0	R 81,6	R 81,6	80,9	24,2	24,3	8,5	3,5
24	34999		0	R 81,6	R 81,6	80,9	24,2	24,3	8,5	3,5
25	35000		0	R 81,6	R 81,6	80,9	24,2	24,3	8,5	3,5
26	35001		0	R 81,6	R 81,6	80,9	24,2	24,3	8,5	3,5
27	35002		0	R 81,6	R 81,6	80,9	24,2	24,3	8,5	3,5
28	35003		0	R 81,6	R 81,6	80,9	24,2	24,3	8,5	3,5
29	35004		0	R 81,6	R 81,6	80,9	24,2	24,3	8,5	3,5
30	35005		0	R 81,6	R 81,6	80,9	24,2	24,3	8,5	3,5

Ambient temperature: 23,5 Deg. C
Test date: 23.10.97
Signature: IOKA

Type of test circuit:
Connections to apparatus tested:
Supply from the lower side

Technical Data of Test Circuit

Test Number	1-20	21-30
Record Number	34974-34993	34996-35005
Number of phases (test circuit)	3	3
Operating frequency (Hz)	50	50
Power factor source side	0,1 1)	0,1 1)
Power factor load side	0,088 2)	0,088 2)
Load before test object (% of total)		
Transformer connection symbol	Dyn	Dyn
Transformer star point	Earthed	Earthed
Short circuit point	Isolated	Isolated
TRV Source side U _c /I _B (kV/μs)	44/86,6	44/86,6
TRV Load side U _c /I _B (kV/μs)		
Res. frequency load side (kHz)		
Damping factor (j)		
Circuit diagram (Page No.)	0	0
Supply side	Upper	Lower

Remarks:


1) The supply circuit is, according to the IEC 265-1 publication, as during a test with the mainly active load
2) Capacitive load

ВЯРНО С
ОПИСАНИЕ

1-85




Make / Break test, IEC 265-1, Test duty 4



- K = Making switch
- TO = Test object
- SC = Short circuit point
- J = Earth connection
- F = Protection fuses
- Cs/Rs = Resonance freq. adj.

FILE:CAPLOAD

- S = 17 kV supply voltage
- EI = Safety switch
- R = Resistance
- X = Reactance
- TR = Transformer
- I = Current measuring
- Ij = Current meas. to earth (option)
- U = Phase voltage
- Uj = Voltage measuring
- C = Capacitive load




1	2	3	4	5	6	7	8	9	10
1	2	3	4	5	6	7	8	9	10
1	2	3	4	5	6	7	8	9	10

1	2	3	4	5	6	7	8	9	10
1	2	3	4	5	6	7	8	9	10
1	2	3	4	5	6	7	8	9	10

ВЕРНО С
ОРИГИНАЛ



№3701 SKIEN, Stalensvegen 71, N-3721 SKIEN TR. (03) 560338 Fax: (03) 560615





Test object




[Handwritten signature]

ВЕРНО С
ОПТИМА А *[Handwritten signature]*







ВЯРНО С
 ОРИГИНАЛ



MOVE
IT
IS
IR
UF
US
UR

[Handwritten signature]




MOVE
T (L3)
S (L2)
H (L1)




[Large handwritten scribbles]

ВЕРНО С
ОРИГИНАЛОМ 89




[Handwritten signature]




ВЕРНО
ОРИГИНАЛ
СЕРТИФИКАТ
ИЗДАНИЕ
1995

[Handwritten signature]




NEFI Kortslutningslaboratorium





NEFI Kortslutningslaboratorium



ВЯРНО С
ОРИГИНАЛ




ВЕРНО
 ОРИГИНАЛ
 li 92




ВРНО С
 ОПИГНААА 01 92

NEFI Kortslutningslaboratorium




NEFI Kortslutningslaboratorium




ВЕРНО С
ОРИГИНАЛА

67 94

NEFI Kortslutningslaboratorium




NEFI Kortslutningslaboratorium




ВАРНО С
ОРИГИНАЛ

ly 95

NEFI Kortslutningslaboratorium




NEFI Kortslutningslaboratorium



ВАРНОЕ
ОРГАН


Л 96

NEFI Kortslutningslaboratorium




MOVE
IT
IS
IR
UT
US
UR

NEFI Kortslutningslaboratorium




MOVE
IT
IS
IR
UT
US
UR




ВЯРНО С
ОРИГИНАЛ

99

NEFI Kortslutningslaboratorium




NEFI Kortslutningslaboratorium




ВЕРНО С
ОРИГИНАЛА

01 98

NEFI Kortslutningslaboratorium




NEFI Kortslutningslaboratorium





[Handwritten signature]



ВЕРНО
ОРИГИНАЛ
[Handwritten signature]




[Handwritten signature]




ВЯНО С
 ОРИГИНАЛ *[Handwritten signature]*

NEFI Kortslutningslaboratorium




[Handwritten signature]

NEFI Kortslutningslaboratorium




ВЯЧНО
ОРИГИНАЛ
[Handwritten signature]

NEFI Kortslutningslaboratorium



[Handwritten signature]

NEFI Kortslutningslaboratorium




[Handwritten signature]




ВЪРНО С
 ОПИТИНАА *BY 101*

NEFI Kortslutningslaboratorium



[Handwritten signature]


NEFI Kortslutningslaboratorium



[Handwritten signature]



ВЕРНО С
ОРИГИНАЛА *[Handwritten mark]*



ВЕРНО С
ОРИГИНАЛ

SATS

Scandinavian Association for Testing Switchgear
c/o EFI - Norwegian Electric Power Research Institute
Sem Sælandsv. 11 7034 Trondheim NORWAY
Telephone: +47-7-597200 Telex: 53 510 efl n Telex: 47-7-597250

REPORT OF PERFORMANCE No. 96-B04

TITLE:

Dielectric tests on high-voltage
switch disconnector with
integrated earthing switch
type NALE 24 and
switch-fuse combination
type NALF 24.

ВЕРНО С
ОРИГИНАЛА



Trondheim 1996-01-09

Place and Date

[Signature]

SATS Secretary Approval

Copyright: Publication or reproduction of the contents of this report in any other form than by a complete copy to the latter, is not allowed without the written consent from SATS.

[Signature]

SATS

Scandinavian Association for Testing Switchgear
c/o EFI - The Norwegian Research Institute of Electricity Supply
Sem Sælandsv. 11 7034 Trondheim-NTH NORWAY
Tel. (07)597200 Telex 53519 efl n

REPORT OF PERFORMANCE No. 96-B04

APPARATUS: High-voltage switch disconnector with integrated earthing switch and high-voltage switch-fuse combination
DESIGNATION: NALE 24 and NALF 24
MANUFACTURER: ABB Distribusjon AS, Skien, Norway
DATE(S) OF TESTS: 3. to 6. of November 1992

TESTING ASSIGNED BY THE MANUFACTURER

Rated 1 min. power-frequency withstand voltage; (rms value):
50 kV to earth, between poles and across open switching device
60 kV across isolating distance
Rated lightning impulse withstand voltage; (peak value):
125 kV to earth, between poles and across open switching device
145 kV across isolating distance

THE TESTS HAVE BEEN MADE IN ACCORDANCE WITH
See page no. 5.

The performance of the apparatus tested and the observations made during the tests have been recorded in the tables with test results and oscillograms.

THE DOCUMENTS FORMING PART OF THIS REPORT ARE

Table with test results Nos.: Page No.: 7 to 14
Oscillogram Nos.: Page No.: 20

Page No.: 15 to 19

Drawing Nos.:
Diagram Nos.:
Photograph Nos.:

Copyright: Publication or reproduction of the contents of this report in any other form than by a complete copy to the latter, is not allowed without our written consent.

Skien, 4. of January 1996

Place and Date

[Signature]

SATS Secretary

[Signature]
Lage: Trondheim

Contents

- Front sheet..... Page No.: 1
- Information sheet (SATS)..... Page No.: 2
- Contents..... Page No.: 3 (This page)
- Préface, Chapter 1..... Page No.: 4
- Test object, Chapter 2..... Page No.: 4
- Conclusion, Chapter 3..... Page No.: 4
- Dielectric tests, Chapter 4..... Page No.: 5
- Tables with test results..... Page No.: 7 to 14
- Drawings..... Page No.: 15 to 19
- Oscillograms..... Page No.: 20

1. Preface

The tests were witnessed by SATS observer, Mr. Arne Nesse, EFI (Norwegian Electric Power Research Institute).

Parts of the tests were also witnessed by:

Mr. Sten Thygesen, ABB Distribusjon, Skien, Norway

The tests have been performed at ABB Distribusjon AS, Electrotechnical and Mechanical Laboratory, Skien, Norway.

2. Test objects

- High-voltage switch disconnecter type NAL 24.
- High-voltage earthing switch type E 24.
- High-voltage switch-fuse combination type NALF 24.


The high-voltage earthing switch type 24 was mounted on the lower side, (hinge side), of the high-voltage switch type NAL 24. The high-voltage earthing switch is then an integrated part of the high-voltage switch and in this combination called NALE 24.

The test objects were manufactured by ABB Distribusjon AS, Skien, Norway.

All fuses used during tests were manufactured by ABB Distribusjon AS, Skien, Norway.

3. Conclusion

The test objects passed the lightning impulse withstand voltage and the power-frequency withstand voltage tests successfully according to IEC Publication 285-1 (1983), IEC Publication 420 (1990-11), IEC Publication 60-1 (1989-11) and IEC Publication 694 (1980).



ВЕРНО
ОРИГИНАЛ

4. Dielectric tests

4.1 Test objects

- High-voltage switch disconnector (with earthing switch) type NALE 24, with type K-mechanism, serial no. 239222.
- High-voltage switch-fuse combination type NALF 24, equipped with fuses type CEF 24 kV, 40 A, serial no. 239221.

4.2 Lightning impulse withstand voltage tests

4.2.1 Publication

IEC Publication 265-1, Second edition 1983, IEC Publication 420, Second edition 1990-11, IEC Publication 60-1, Second edition 1989-11 and IEC Publication 694, First edition 1980, § 6.1.6. Lightning impulse voltage tests.

4.2.2 Test procedure

15 consecutive lightning impulses with both polarities applied on each configuration from 1 to 8, on all phases in succession.
Configuration no. is equal to test condition no. as given in table VIII.

4.2.3 Technical data of test equipment

Lightning impulse generator:
Voltage range: 0 - 400 kV
Max energy: 10 kJ

Wave form: 1,2/50 10-6 s.

4.2.4 Test result

The number of disruptive discharges on self-restoring insulation did not exceed two for each series of 15 impulses and no disruptive discharges on non-self-restoring insulation occurred.

The test voltage was 125 kV to earth, between poles and across open switching device and 145 kV across isolating distance.
For detailed test results, ref. to page no. 7, 8, 9 and 11, 12 and 13.



ВЕРНО С
ОПИСАНА

601109

4.3 Power frequency voltage tests

4.3.1 Publication

IEC Publication 265-1, Second edition 1983, IEC Publication 420, Second edition 1990-11, IEC Publication 60-1, Second edition 1989-11 and IEC Publication 694, First edition 1980, § 6.1.7. Power frequency voltage withstand tests.

4.3.2 Test procedure

Voltage applied on each configuration from 1 to 9, on all phases in succession.
Configuration no. is equal to test condition no. as given in table VIII, IEC Publication 694 (1980).

Duration of each test was 1 minute.

4.3.3 Technical data of test equipment

Power frequency transformer, single phase:

Voltage range: 0 - 60 kV, 50 Hz
Output short-time: 50 kVA
Short-circuit current, load side: 1A

4.3.4 Test result

No disruptive discharges occurred, on the test.

The test voltage was 50 kV to earth, between poles and across open switching device, and 60 kV across the isolating distance.

For detailed test results, ref. to page no. 10 and 14.

LIGHTNING IMPULSE VOLTAGE TEST									
TABLE WITH TEST RESULTS									
Report no.: 96-804	Test no.:		Sheet no.: 1 of 3						
Test object: Switch-fuse com. NALF 24	Date: 05.11.92		Date: 05.11.92						
Climatic conditions			Applied correction factor: 0.994						
Temperature: 22 °C			Tank filling pressure:						
Humidity: 11 g/m ³									
Atmospheric pressure: 760 mm Hg									
Configuration	Phase(s)	Polarity %	Minimum applied Voltage U [kV]	No. of impulses		Wave-form Tr/Tn [µs]	Record no.	Remarks	
				Total	No. of discharges				
1	L1	-	90	5	0	1.2/50			
1	L1	-	126	15	0	1.2/50			
1	L1	+	90	5	0	1.2/50			
1	L1	+	126.5	15	0	1.2/50			
2	L2	-	90	5	0	1.2/50			
2	L2	-	126	15	0	1.2/50			
2	L2	+	90	5	0	1.2/50			
2	L2	+	126	15	0	1.2/50			
3	L3	-	90	5	0	1.2/50			
3	L3	-	126	15	0	1.2/50			
3	L3	+	90	5	0	1.2/50			
3	L3	+	126	15	1	1.2/50			
4	L1	-	90	5	0	1.2/50			
4	L1	-	126	15	0	1.2/50			
4	L1	+	90	5	0	1.2/50			
4	L1	+	126	15	0	1.2/50			
4	L1	+	126	15	0	1.2/50			
5	L2	-	90	5	0	1.2/50			
5	L2	-	126	15	0	1.2/50			
5	L2	+	90	5	0	1.2/50			
5	L2	+	126	15	1	1.2/50			
6	L3	-	90	5	0	1.2/50			
6	L3	-	126	15	0	1.2/50			
6	L3	+	90	5	0	1.2/50			
6	L3	+	126	15	0	1.2/50			

Notes:



ВІДНОС
ОРУЖИНАА
07.10.92

LIGHTNING IMPULSE VOLTAGE TEST									
TABLE WITH TEST RESULTS									
Report no.: 96-804	Test no.:		Sheet no.: 2 of 3						
Test object: Switch-fuse com. NALF 24	Date: 05.11.92		Date: 05.11.92						
Climatic conditions			Applied correction factor: 0.994						
Temperature: 22 °C			Tank filling pressure:						
Humidity: 11 g/m ³									
Atmospheric pressure: 760 mm Hg									
Configuration	Phase(s)	Polarity %	Minimum applied Voltage U [kV]	No. of impulses		Wave-form Tr/Tn [µs]	Record no.	Remarks	
				Total	No. of discharges				
7	L1	-	90	5	0	1.2/50			
7	L1	-	126	15	0	1.2/50			
7	L1	+	90	5	0	1.2/50			
7	L1	+	126	15	0	1.2/50			
8	L2	-	90	5	0	1.2/50			
8	L2	-	126	15	0	1.2/50			
8	L2	+	90	5	0	1.2/50			
8	L2	+	126	15	0	1.2/50			
9	L3	-	90	5	0	1.2/50			
9	L3	-	126	15	0	1.2/50			
9	L3	+	90	5	0	1.2/50			
9	L3	+	126	15	0	1.2/50			

Notes:

LIGHTNING IMPULSE VOLTAGE TEST									
TABLE WITH TEST RESULTS									
Report no.: 96-B04		Test no.:		Sheet no.: 3 of 3					
Test object: Switch-fuse comb. NALF 24		Date: 06.11.92							
Climate conditions:		Applied correction factor: 0.988							
Temperature: 21.5 °C		Tank filling pressure:							
Humidity: 11 g/m ³		Atmospheric pressure: 754 mm Hg							
Configuration	Phase(s)	Polarity	Minimum applied Voltage (kV)	No. of impulses	Wave form T _{1/10} (µs)	Record no.	Remarks	No. of discharges	
								Total	
4*	L1	-	112	5	0	1,2/50			
4*	L1	-	146	15	0	1,2/50			
4*	L1	+	111	5	0	1,2/50			
4*	L1	+	146	15	0	1,2/50			
5*	L2	-	111	5	0	1,2/50			
5*	L2	-	146	15	0	1,2/50			
5*	L2	+	111	5	0	1,2/50			
5*	L2	+	146	15	0	1,2/50			
5*	L3	-	111	5	0	1,2/50			
5*	L3	-	146	15	0	1,2/50			
5*	L3	+	111	5	0	1,2/50			
5*	L3	+	146	15	0	1,2/50			
7*	L1	-	111	5	0	1,2/50			
7*	L1	-	146	15	0	1,2/50			
7*	L1	+	111	5	0	1,2/50			
7*	L1	+	146	15	0	1,2/50			
8*	L2	-	111	5	0	1,2/50			
8*	L2	-	146	15	0	1,2/50			
8*	L2	+	111	5	0	1,2/50			
8*	L2	+	146	15	0	1,2/50			
9*	L3	-	111	5	0	1,2/50			
9*	L3	-	146	15	0	1,2/50			
9*	L3	+	111	5	0	1,2/50			
9*	L3	+	146	15	0	1,2/50			

Notes:
Ref. to note table VIII, IEC Publication 694 (1980). The base F and the terminals of the switching device except the terminal opposite the energized terminals were insulated from earth.



POWER FREQUENCY VOLTAGE TEST									
TABLE WITH TEST RESULTS									
Report no.: 96-B04		Test no.:		Sheet no.: 1 of 1					
Test object: Switch-fuse comb. NALF 24		Date: 05.11.92							
Climate conditions:		Applied correction factor: 0.994							
Temperature: 22 °C		Tank filling pressure:							
Humidity: 11 g/m ³		Atmospheric pressure: 750 mm Hg							
Configuration	Phase (s)	Freq. (Hz)	Voltage (kV)	Duration (min)	Disruptive discharge (at least)	Remarks			
1	L1	50	50	1	-				
2	L2	50	50	1	-				
3	L3	50	50	1	-				
7	L1	50	50	1	-				
8	L2	50	50	1	-				
9	L3	50	50	1	-				
4	L1	50	50	1	-				
5	L2	50	50	1	-				
6	L3	50	50	1	-				
4*	L1	50	50	1	-				
5*	L2	50	50	1	-				
5*	L3	50	50	1	-				
7*	L1	50	50	1	-				
8*	L2	50	50	1	-				
9*	L3	50	50	1	-				

Notes:
Ref. to note table VIII, IEC Publication 694 (1980). The base F and the terminals of the switching device except the terminal opposite the energized terminals were insulated from earth.

ВРНО С
ОРИГИНАЛ

LIGHTNING IMPULSE VOLTAGE TEST									
TABLE WITH TEST RESULTS									
Report no.: 96-B04	Test no.:		Sheet no.: 1 of 3						
Test object: NALE 24	Date: 03.11.92		Applied correction factor: 0.965						
Climatic conditions			Tank filling pressure:						
Temperature: 21 °C									
Humidity: 11 g/m ³									
Atmospheric pressure: 735 mm Hg									
Configuration	Phases	Polarity +/-	Minimum applied Voltage U (kV)	No. of impulses		Wave-form T _{1/10} [µs]	Record no.	Remarks	
				Total	No. of discharges				
1	L1	-	90	5	0	1.2/50			
1	L1	-	125	15	0	1.2/50			
1	L1	+	90	5	0	1.2/50			
1	L1	+	125	15	0	1.2/50			
2	L2	-	90	5	0	1.2/50			
2	L2	-	125	15	0	1.2/50			
2	L2	+	90	5	0	1.2/50			
2	L2	+	125	15	0	1.2/50			
3	L3	-	90	5	0	1.2/50			
3	L3	-	125	15	0	1.2/50			
3	L3	+	90	5	0	1.2/50			
3	L3	+	125	15	0	1.2/50			
4	L1	-	90	5	0	1.2/50			
4	L1	-	125	15	0	1.2/50			
4	L1	+	90	5	0	1.2/50			
4	L1	+	125	15	0	1.2/50			
5	L2	-	90	5	0	1.2/50			
5	L2	-	125	15	0	1.2/50			
5	L2	+	90	5	0	1.2/50			
5	L2	+	125	15	0	1.2/50			
6	L3	-	90	5	0	1.2/50			
6	L3	-	125	15	0	1.2/50			
6	L3	+	90	5	0	1.2/50			
6	L3	+	125	15	0	1.2/50			

Notes:



File: R:\APPT\TEXT\96-B04.DOC

LIGHTNING IMPULSE VOLTAGE TEST									
TABLE WITH TEST RESULTS									
Report no.: 96-B04	Test no.:		Sheet no.: 2 of 3						
Test object: NALE 24	Date: 03.11.92		Applied correction factor: 0.965						
Climatic conditions			Tank filling pressure:						
Temperature: 21 °C									
Humidity: 11 g/m ³									
Atmospheric pressure: 735 mm Hg									
Configuration	Phases	Polarity +/-	Minimum applied Voltage U (kV)	No. of impulses		Wave-form T _{1/10} [µs]	Record no.	Remarks	
				Total	No. of discharges				
7	L1	-	90	5	0	1.2/50			
7	L1	-	125	15	0	1.2/50			
7	L1	+	90	5	0	1.2/50			
7	L1	+	125	15	0	1.2/50			
8	L2	-	90	5	0	1.2/50			
8	L2	-	125	15	0	1.2/50			
8	L2	+	90	5	0	1.2/50			
8	L2	+	125	15	0	1.2/50			
9	L3	-	90	5	0	1.2/50			
9	L3	-	125	15	0	1.2/50			
9	L3	+	90	5	0	1.2/50			
9	L3	+	125	15	0	1.2/50			

Notes:

File: R:\APPT\TEXT\96-B04.DOC

ВЯРНО С
ОРИГИНАЛА

LIGHTNING IMPULSE VOLTAGE TEST									
TABLE WITH TEST RESULTS									
Report no.: 96-B04	Sheet no.: 3 of 3								
Test object: NALE 24	Date: 03.11.92								
Climatic conditions				Applied correction factor: 0.965					
Temperature: 21 °C				Tank filling pressure:					
Humidity: 11 g/m ³									
Atmospheric pressure: 735 mm Hg									
Configuration	Phase (s)	Polarity +/-	Minimum applied Voltage U (kV)	No. of impulses	Wave-form T/T _{1/2} [µs]	Record no.	Remarks	No. of discharges	
								Total	
4*	L1	-	110	5	0	12/50			
4*	L1	-	145	15	0	12/50			
4*	L1	+	110	5	0	12/50			
4*	L1	+	145.5	15	0	12/50			
5*	L2	-	110	5	0	12/50			
5*	L2	-	145	15	0	12/50			
5*	L2	+	110	5	0	12/50			
5*	L2	+	145.5	15	0	12/50			
6*	L3	-	110	5	0	12/50			
6*	L3	-	145	15	0	12/50			
6*	L3	+	110	5	0	12/50			
6*	L3	+	145.5	15	0	12/50			
7*	L1	-	110	5	0	12/50			
7*	L1	-	145	15	0	12/50			
7*	L1	+	110	5	0	12/50			
7*	L1	+	145	15	0	12/50			
8*	L2	-	110	5	0	12/50			
8*	L2	-	145	15	0	12/50			
8*	L2	+	110	5	0	12/50			
8*	L2	+	145.5	15	0	12/50			
9*	L3	-	110	5	0	12/50			
9*	L3	-	145	15	0	12/50			
9*	L3	+	110	5	0	12/50			
9*	L3	+	145.2	15	0	12/50			



Notes:
 Ref. to note table VIII, IEC Publication 694 (1980). The base F and the terminals of the switching device except the terminal opposite the energized terminals were insulated from earth.





ВЯРНО С
 ОПИТИВАЛА
 119

POWER FREQUENCY VOLTAGE TEST									
TABLE WITH TEST RESULTS									
Report no.: 96-B04	Sheet no.: 1 of 1								
Test object: NALE 24	Date: 05.11.92								
Climatic conditions				Applied correction factor: 0.965					
Temperature: 21 °C				Tank filling pressure:					
Humidity: 11 g/m ³									
Atmospheric pressure: 735 mm Hg									
Configuration	Phase (s)	Freq. [Hz]	Voltage [kV]	Duration [min]	Disruptive discharge after time [minsec]	Remarks			
1	L1	50	50	1	-				
2	L2	50	50	1	-				
3	L3	50	50	1	-				
7	L1	50	50	1	-				
8	L2	50	50	1	-				
9	L3	50	50	1	-				
4	L1	50	50	1	-				
5	L2	50	50	1	-				
6	L3	50	50	1	-				
4*	L1	50	50	1	-				
5*	L2	50	50	1	-				
6*	L3	50	50	1	-				
7*	L1	50	50	1	-				
8*	L2	50	50	1	-				
9*	L3	50	50	1	-				




Notes:
 Ref. to note table VIII, IEC Publication 694 (1980). The base F and the terminals of the switching device except the terminal opposite the energized terminals were insulated from earth.



ВЯРНО С
 ОПИГНААА 102



ВЕРНО С
ОРИГИНАЛУ МА



ВЯРНО С
 ОПРИТНААА

Handwritten signature and initials.

SATS

Scandinavian Association for Testing Switchgear

c/o EFI - The Norwegian Research Institute of Electricity Supply
Sem Sælandsøy, 11 7034 Trondheim-NTH NORWAY
Tel. (07)597200 Telex 66513 efi n

REPORT OF PERFORMANCE No. 96-B03

APPARATUS: High-voltage switch disconnecter and high-voltage switch-fuse combination
DESIGNATION: NAL 24 and NALF 24

MANUFACTURER: ABB Distribusjon AS, Skien, Norway
DATE OF TESTS: 24. of November to 3. of December 1992.

RATINGS ASSIGNED BY THE MANUFACTURER

NAL 24 : rated current : 630 A

NALF 24 : rated current with CEF 63 A

h.v.fuse : 63 A.

THE TESTS HAVE BEEN MADE IN ACCORDANCE WITH
See page no. 5 and 7.

The performance of the apparatus tested and the observations made during the tests have been recorded in the tables with test results and oscillograms.

THE DOCUMENTS FORMING PART OF THIS REPORT ARE

Table with test results Nos.: Page No.: 8 to 11

Oscillogram Nos.:

Drawing Nos.: Page No.: 12 to 16

Oscygram Nos.: Page No.: 17 to 20

Photograph Nos.:

Copyright: Publication or reproduction of the contents of this report in any other form than by a complete copy to the letter, is not allowed without our written consent.



Skien, 4. of January 1996
Place and Date

[Signature]
SATS Observer
[Signature]
SATS Manager

SATS

Scandinavian Association for Testing Switchgear

c/o EFI - Norwegian Electric Power Research Institute
Sem Sælandsøy, 11 7034 Trondheim NORWAY
Telephone: +47-7-597200 Telex: 55 513 efi n Telefax: +47-7-597250

REPORT OF PERFORMANCE No. 96-B03

TITLE:

Temperature rise test
on high-voltage
switch disconnecter
type NAL 24 and
switch-fuse combination
type NALF 24.

Copyright: Publication or reproduction of the contents of this report in any other form than by a complete copy to the letter, is not allowed without the written consent from SATS.

Trondheim 1996-01-09
Place and Date

[Signature]
SATS Secretariat Approval

ВЯРНО С
ОРИГИНАЛ

116

Contents

- Front sheet..... Page No.: 1
- Information sheet (SATS)..... Page No.: 2
- Contents..... Page No.: 3 (This page)
- Preface, Chapter 1..... Page No.: 4
- Test object, Chapter 2..... Page No.: 4
- Conclusion, Chapter 3..... Page No.: 4
- Temperature rise tests, Chapter 4..... Page No.: 5
- Measurement of the resistance of the main circuit, Chapter 5..... Page No.: 7
- Tables with test results..... Page No.: 8 to 11
- Drawings..... Page No.: 12 to 16
- Drawings with added informations by the test laboratory..... Page No.: 17 to 20

1. Preface

The tests were witnessed by SATS observer, Mr. Arne Nesse, EFI (Norwegian Electric Power Research Institute).

Parts of the tests were also witnessed by:

Mr. Sten Thygesen, ABB Distribution, Skien, Norway

The tests have been performed at ABB Distribution AS, Electrotechnical and Mechanical Laboratory, Skien, Norway.

2. Test objects

- High-voltage switch disconnector type NAL 24, serial no. 238222.
- High-voltage earthing switch type E 24, serial no. 238222.
- High-voltage switch-fuse combination type NALF 24, serial no. 238218.

The high-voltage earthing switch type E 24 was mounted on the lower side, (hinge side), of the high-voltage switch type NAL 24. The high-voltage earthing switch is then an integrated part of the high-voltage switch and in this combination called NALE 24. However the temperature rise test is not relevant for earthing switches and no temperature rise test has been carried out on the E 24.

The test objects were manufactured by ABB Distribution AS, Skien, Norway.

All fuses used during tests are manufactured by ABB Distribution AS, Skien, Norway.

3. Conclusion

The test object passed the temperature rise tests successfully according to the IEC Publication 265-1 (1983), IEC Publication 420 (1990-1) and IEC Publication 694 (1980).



ВЕРНО С
ОРИГИНАЛА

Handwritten signature

4. Temperature-rise tests

4.1 Test object

The test object was a high-voltage switch disconnector type NAL 24. See Chapter 5.4 for serial numbers.

4.1.1 Publication

IEC Publication 265-1, Second edition 1983, § 6.3, with reference to IEC Publication 694, First edition 1980, § 6.3.

4.1.2 Test procedure

The test object was mounted in vertical (normal service) position in the test rack. The three phases of the test object were connected in series with an AC single phase power supply.

The connections were made by means of Cu bars 2 // 5 x 40 mm.

The test was running until the steady state of the temperature was achieved, i.e. temperature less than 1 K per hour.

The test was performed with a test current of 630 A.

The ambient temperature was measured at the same height as the test object, and 1 meter from the test object with three equally distributed TC's type K.

4.1.3 Test results

The test object passed the test successfully with temperature rise below the limit given in table V of IEC Publication 694, see page no. 8 and 9.

4.2 Test object

The test object was a high-voltage switch-fuse combination type NALF 24, with fuses type CER 24 KV, 63 A inserted.

4.2.1 Publication

IEC Publication 420, Second edition 1990-11, § 6.3, with reference to IEC Publication 694, First edition 1980, § 6.3.



FIG. RUA/PFT/96-B03/005

FIG. RUA/PFT/96-B03/005

Handwritten signature and number '119' at the bottom right of the page.


4.2.2 Test procedure

The test object was mounted in vertical (normal service) position in the test rack. The three phases of the test object were connected in series with an AC single phase power supply.

The connections were made by means of 50 mm² Copper uninsulated PN cable. The test was carried out with a test current of 63 A, corresponding to a nominal power loss of 147 W in each of the fuses according to the datasheet from the manufacturer.

4.2.3 Test results

The test object passed the test successfully with temperature rise below the limit given in table V of IEC Publication 694, see page no. 10 and 11.



5. Measurement of the resistance of the main circuit

5.1 Test objects

The test objects were a high-voltage switch disconnector type NAL 24 and a high-voltage switch-fuse combination type NALF 24, with fuses CEF 24 KV, 63 A inserted. The test objects were mounted in vertical position in the test rack.

5.2 Publication

IEC Publication 694, First edition 1990, § 6.4.

5.3 Test procedure

The resistance was measured between terminals of each phase before and after the temperature rise test, see Chapter 4. Voltage drop was measured at 50 A DC. The measurement of NALF 24 also includes a measurement of the resistance of the fuse in each phase. Measuring point, see page no. 19 and 20.

5.4 Test results

After the test objects had cooled down to the ambient temperature, the differences between the measurements were negligible:

Test object	Resistance in mΩ before temperature rise test			Resistance in mΩ after temperature rise test		
	Phase L1	Phase L2	Phase L3	Phase L1	Phase L2	Phase L3
NAL 24 No. 238222 See page no. 19	0.07	0.09	0.10	0.08	0.09	0.10
NALF 24 No. 238216 See page no. 20	24.0	25.0	25.0	24.0	25.0	24.0
Fuses only See page no. 20	23.9	24.9	24.9	23.9	24.9	24.9

File: NALFTESTV06-B03.DOC

ВАРНО С
ОПТИМАЛА



Handwritten signature and initials.



TEMPERATURE RISE TEST TABLE WITH TEST RESULTS									
Report no.: 96-B03		Test no.: 1 of 2		Sheet no.: 1 of 2					
Test object: Switch-disconnector NAL 24						Date: 24.11.92			
Temporary connections						Fuse type: W (At rated current)			
Type: 2 // Cu Bars 5 x 40 mm						Power loss: 5 hrs			
Length between terminals: 2 m						Total test duration: 22.7 °C			
Length of source connections: 1.2 m						Amb. temperature Before test: 22.8 °C			
Location of measuring points: See page no. 17						After test: 22.8 °C			
Measuring Point no.	Identification of measuring point	Temp. rise limit acc. to standard [K]	Temp. rise at steady state cond. [K]	Remarks	Test current: 630 A				
					1	2	3	4	5
1	Conn. terminal L1	65	42.5						
2	Hinge, cont. knife L1	65	44.8						
3	Contact knife L1	65	46.3						
4	Peak contact L1	65	45.2						
5	Conn. terminal L1	+/- 5	40.8						
6	Conn. bars L2	65	40.6						
7	1 m from terminal L3	65	37.1						
8	Conn. terminal L3	65	42.9						
9	Hinge, cont. knife L2	65	47.9						
10	Contact knife L2	65	44.6						
11	Peak contact L2	65	46.6						
12	Conn. terminal L2	65	44.2						
13	Conn. terminal L3	65	44.1						
14	Hinge, cont. knife L3	65	48.1						
15	Cont. knife L3	65	43.9						
16	Peak contact L3	65	45.7						
17	Conn. terminal L3	+/- 5	40.4						
18	Conn. bar L3	65	38.0						
19	1 m from terminal L3	+/- 5	41.9						
20	Conn. bar L1	65	41.4						

Notes:



TC: Type K

File: RUSANTTESTV06-B03.DOC


Model	ABB 124V P-235
Technology	ABB
Product name	ABB Distribution AS
Part No.	NHP 343379
Material	For CFC sauringeridaa halstessi
Part No.	1/10
Product name	ABB
Part No.	NHP 343602
Product name	ABB Distribution AS
Part No.	15005
Part No.	A3/15
Product name	HÄLSKISTE P-235, DRÖMSHEDEN DAM
Part No.	E 21 / FE 21



Model	ABB 124V P-235
Technology	ABB
Product name	ABB Distribution AS
Part No.	NHP 343379
Material	For CFC sauringeridaa halstessi
Part No.	1/10
Product name	ABB
Part No.	NHP 343602
Product name	ABB Distribution AS
Part No.	15005
Part No.	A3/15
Product name	HÄLSKISTE P-235, DRÖMSHEDEN DAM
Part No.	E 21 / FE 21




ВЕРНОС
 ОПИГНАЛА
 122




ВЯРНО С

ОПРИКАТА




ly 123



Location of measuring point








Location of measuring points



ВАРНО С
ОРИГИНАЛ

124



Measurement of the resistance (NALE)

Measurement of the resistance (NALF)



ВЕРНО С
ОРИГИНАЛА

125

Примоченне ТС 14

pol pl english



Instytut
Elektrotechniki
Electrotechnical Institute

About Institute Structure Activity Offer Conferences Publications Projects Partners News Contact


Home > Activity > Laboratory testing >

- About PCA
- Accreditation
- Accredited Organizations
- International Cooperation
- Links



Polskie Centrum Akredytacji

PL | EN



- Library
- Doctoral studies
- UE Directives
- HCZT
- Information
- MCUPdII
- Foundation New Electrotechnics

Details



AB 074

certificate validity: 21.11.2018 r. accreditation from: 17.09.1996 r.

Name of organization: Instytut Elektrotechniki
ul. Pożaryskiego 28; 04-703 Warszawa

Name laboratory: Laboratorium Badawcze Aparatury Rozdzielczej

Address: ul. Pożaryskiego 28

Place: 04-703 Warszawa

(22) 112-53-01
(22) 112-53-10
zwarcia@iei.waw.pl

www.iei.waw.pl

CE

CREATED BY VISUALTEAM




ВЕРНО С
ОРИГИНАЛА

126

ZAKRES AKREDYTACJI LABORATORIUM BADAWCZEGO Nr AB 074

wydany przez
POLSKIE CENTRUM AKREDYTACJI
01-382 Warszawa, ul. Szczotkarska 42

Wydanie nr 9, Data wydania: 6 grudnia 2011 r.

 AB 074	Nazwa i adres <p style="text-align: center;">INSTYTUT ELEKTROTECHNIKI LABORATORIUM BADAWCZE APARATURY ROZDZIELCZEJ ul. Pożaryskiego 28 04-703 Warszawa</p>
Kod Identyfikacji dziedzina/obiektu badań:	Dziedzina/obiekt badań:
E/6; E/19 H/6 J/6 N/6	Badania elektryczne wyrobów i wyposażenia elektrycznego i elektronicznego, środków ochrony osobistej Badania ogniowe wyrobów i wyposażenia elektrycznego i elektronicznego Badania mechaniczne wyrobów i wyposażenia elektrycznego i elektronicznego Badania właściwości fizycznych wyrobów i wyposażenia elektrycznego i elektronicznego

Wersja strony: A

KIEROWNIK
DZIAŁU AKREDYTACJI
LABORATORIÓW BADAWCZYCH

TADEUSZ MATRAS



Laboratorium Badawcze Aparatury Rozdzielczej ul. Pożaryskiego 28; 04-703 Warszawa		
Osoby autoryzujące sprawozdania z badań: mgr inż. Robert Franaszek – Kierownik Zespołu Laboratoriów IEL mgr inż. Michał Babiuch – Kierownik ds. Technicznych mgr inż. Janusz Domański – Kierownik Sekcji Aparatury Niskonapięciowej		
Badane objekty / Grupa obiektów	Badane cechy i metody badawcze/ pomiarowe	Normy i/lub udokumentowane procedury badawcze
Wyłaczniki wysokonapięciowe prądu przemiennego	Wytrzymałość elektryczna izolacji	PN-EN 62271-100:2009 pkt 6.2 PN-EN 62271-1:2009
	Graniczne przyrosty temperatury	PN-EN 62271-100:2009 pkt 6.5
	Rezystancja obwodu głównego	PN-EN 62271-100:2009 pkt 6.4
	Obciążalność zwarciova	PN-EN 62271-100:2009 pkt 6.6
	Niezawodność działania i trwałość mechaniczna	PN-EN 62271-100:2009 pkt 6.101
	Zdolność łączeniowa	PN-EN 62271-101:2010, pkt 6.102 ÷ pkt 6.107 PN-EN 62271-101:2010/A1:2011 PN-EN 62271-100:2009 pkt 6.102 ÷ 6.107
	Zdolność łączenia zwarć 1-fazowych	PN-EN 62271-100:2009 pkt 6.108
	Zdolność łączeniowa w warunkach zwarć pobliskich	PN-EN 62271-101:2010 pkt 6.109 PN-EN 62271-101:2010/ A1:2011 PN-EN 62271-100:2009, pkt 6.109
	Zdolność łączeniowa przy niezgodności faz	PN-EN 62271-100:2009 pkt 6.110
	Zdolność łączenia prądu pojemnościowego	PN-EN 62271-101:2010, pkt 6.111 PN-EN 62271-101:2010/A1:2011 PN-EN 62271-100:2009 pkt 6.111
	Zdolność łączenia małego prądu indukcyjnego	PN-EN 62271-110:2009 pkt 6.114
	Zdolność łączenia obciążenia indukcyjnego	pkt 6.115
	Odłączniki i uziemniki wysokonapięciowe	Wytrzymałość elektryczna izolacji
Rezystancja obwodu głównego		pkt 6.4
Graniczne przyrosty temperatury		pkt 6.5
Obciążalność zwarciova		pkt 6.6
Niezawodność działania i trwałość mechaniczna		pkt 6.102
Zdolność załączania uziemników		pkt 6.101
Rozłączniki wysokonapięciowe prądu przemiennego do 52 kV	Wytrzymałość elektryczna izolacji	PN-EN 60265-1:2001, pkt 6.2
	Rezystancja obwodu głównego	pkt 6.4
	Graniczne przyrosty temperatury	pkt 6.5
	Obciążalność zwarciova	pkt 6.6
	Stopnie ochrony IP	pkt 6.7
	Zdolność łączeniowa	pkt 6.101
	Działanie mechaniczne, trwałość mechaniczna	pkt 6.102

Wersja strony: A

Badane objekty / Grupa obiektów	Badane cechy i metody badawcze/ pomiarowe	Normy i/lub udokumentowane procedury badawcze
Wysokonapięciowe zestawy rozłączników z bezpiecznikami	Wytrzymałość elektryczna izolacji	PN-EN 62271-105:2005, pkt 6.2
	Graniczne przyrosty temperatury	pkt 6.5
	Rezystancja obwodu głównego	pkt 6.4
	Obciążalność zwarciova	pkt 6.6
	Zdolność łączeniowa	pkt 6.101
	Działanie mechaniczne	pkt 6.102
	Odporność bezpieczników na wstrząsy	pkt 6.103
Bezpieczniki wysokonapięciowe	Wytrzymałość elektryczna izolacji	PN-EN 60282-1:2010, pkt 6.4 PN-IEC 60282-2:1999, pkt 8.4
	Graniczne przyrosty temperatury	PN-EN 60282-1:2010, pkt 6.5 PN-IEC 60282-2:1999, pkt 8.5
	Zdolność wyłączeniowa	PN-EN 60282-1:2010, pkt 6.6 PN-IEC 60282-2:1999, pkt 8.6
	Charakterystyki czasowo-prądowe	PN-EN 60282-1:2010, pkt 6.7 PN-IEC 60282-2:1999, pkt 8.7
	Działanie wybijaaków	PN-EN 60282-1:2010, pkt 6.8
Wkładki bezpiecznikowe wysokiego napięcia do zabezpieczania obwodów silników	Wytrzymałość elektryczna izolacji	PN-EN 60282-1:2010, pkt 6.4
	Graniczne przyrosty temperatury	pkt 6.5
	Zdolność wyłączeniowa	pkt 6.6
	Charakterystyki czasowo-prądowe	pkt 6.7
Styczniki wysokonapięciowe prądu przemiennego	Wytrzymałość elektryczna izolacji	PN-EN 60470:2002, pkt 6.2
	Graniczne przyrosty temperatury	pkt 6.5
	Rezystancja obwodu głównego	pkt 6.4
	Obciążalność zwarciova	pkt 6.6
	Stopnie ochrony IP	pkt 6.7
	Rozdzielnice prądu przemiennego w osłonach metalowych na napięcia znamionowe powyżej 1 kV do 52 kV i w osłonach izolacyjnych na napięcia znamionowe wyższe niż 1 kV do 38 kV	Wytrzymałość elektryczna izolacji
Graniczne przyrosty temperatury		pkt 6.5
Rezystancja obwodu głównego		pkt 6.4
Obciążalność zwarciova		pkt 6.6
Zdolność łączeniowa		pkt 6.101
Działanie mechaniczne		pkt 6.102
Stopnie ochrony IP		pkt 6.7
Zdolność do izolowania, prąd upływowy		pkt 6.104.2
Odporność na działanie łuku przy zwarciach wewnętrznych		pkt 6.106, Załącznik A

Wersja strony: A

Badane obiekty / Grupa obiektów	Badane cechy i metody badawcze/ pomiarowe	Normy i/lub udokumentowane procedury badawcze
Rozdzielnice z izolacją gazową w osłonach metalowych na napięcia znamionowe wyższe niż 52 kV	Wytrzymałość elektryczna izolacji	PN-EN 62271-203:2007 pkt 6.2
	Graniczne przyrosty temperatury	pkt 6.5
	Rezystancja obwodu głównego	pkt 6.4
	Obciążalność zwarciova	pkt 6.6
	Zdolność łączeniowa	pkt 6.101
	Działanie mechaniczne	pkt 6.102
	Stopnie ochrony IP	pkt 6.7
	Odporność na działanie łuku przy zwarciach wewnętrznych	pkt 6.105
Izolatory różnych typów wysokiego i niskiego napięcia	Wymiary liniowe i tolerancje	PN-EN 60383-1:2005 pkt 5 PN-IEC 61109:2010 PN-E-91062-1/-2:1998 pkt 5.5.1
	Wytrzymałość elektryczna izolacji	PN-EN 60137:2010 pkt 7.1-7.3 PN-EN 60383-1:2005 pkt 13 ÷15 PN-IEC 61109:2010 PN-E-91062-1:1998, pkt 5.5.7 PN-E-91062-2:1998 pkt 5.5.7
	Graniczne przyrosty temperatury	PN-EN 60137:2010, pkt 7.5 PN-IEC 61109:2010
	Wytrzymałość zwarciova	PN-EN 60137:2010 pkt 7.6 PN-IEC 61109:2010 PN-E-91062-2:1998 pkt 5.5.9
Stacje transformatorowe wysokiego napięcia na niskie napięcie	Wytrzymałość elektryczna izolacji	PN-EN 62271-202:2010 PN-G-42021:1997 pkt 6.2
	Graniczne przyrosty temperatury	pkt 6.3
	Wytrzymałość zwarciova	pkt 6.4
	Funkcjonalność	pkt 6.5
	Stopnie ochrony IP	pkt 6.6
	Odporność na działanie łuku przy zwarciach wewnętrznych	pkt 6.8, Załącznik A
Transformatory	Rezystancja uzwojeń	PN-EN 60076-11:2006 PN-EN 60076-1:2001+A1:2007 pkt 10.2
	Przekładnia i grupa połączeń	pkt 10.3
	Impedancja zwarciova i straty obciążeniowe	pkt 10.4
	Straty i prąd stanu jałowego	pkt 10.5
	Harmoniczne prądu stanu jałowego	pkt 10.6
	Impedancja składowej zerowej	pkt 10.7
	Skuteczność działania przełącznika zaczepów	PN-EN 60076-1:2001+A1:2007 PN-EN 60214:2001 PN-EN 60214-1:2007
	Graniczne przyrosty temperatury	PN-EN 60076-2:2011
	Wytrzymałość elektryczna izolacji	PN-EN 60076-3:2002 PN-EN 60076-3:2002/Ap1:2004 PN-EN 60076-4:2004

Wersja strony: A

C4





ACCREDITATION DOCUMENT

Accreditation no PROD 016

SINTEF Energi AS, SATS Certification

Sem Sælands vei 11

7465 Trondheim

The accreditation includes certification of products within the scope specified on the following page(s) in this document.

Accreditation in accordance with NS-EN ISO/IEC 17065 (2012) is granted with the reference to Parliamentary Proposition no. 106 (1989/90) and Norwegian Accreditation's status laid down in Royal Decree of 7 October 1993. The accreditation was initially granted 05.11.2004.

The accreditation requires regular surveillance, and is valid until 27.10.2019.

The decision of accreditation made by Norwegian Accreditation implies that the organisation fulfils the requirements for accreditation within the scope. The certification body itself is responsible for certifications performed.

NORWEGIAN ACCREDITATION

CG
27/10/14
Date

Sem Sælands
Norwegian Accreditation



ВЯРНО С
ОРИГИНАЛ

CG



Accreditation document
Accreditation no. **PROD 016**
Scope of accreditation

The administrative/geographic unit:

SINTEF Energy AS
Sem Sælands vei 11
7465 Trondheim

Is accredited for certification of the following products.

Product / Normative doc.	Area of competence / description	Ref. system / ISO Guide 87	Remarks
STL General Guide	Short-Circuit Testing Liaison General Guide		QA SATS 011 Type Test Certification Procedure, QA SATS 030 Type Conformity Certification Procedure. Accreditation scope: Version 7 of the STL-Guide regarding performing reports and certificates listed in paragraph 5.

The accreditation is limited to product certification of high voltage electrical transmission and distribution power equipment.
SATS Certification is a member of STL (Short-Circuit Testing Liaison)


Cy
27/10-19
Date

T. A. Sand
Norwegian Accreditation



ВЕРНО С
ОРИГИНАЛА

27 132



ACCREDITATION DOCUMENT

TEST 040

ABB Laboratories, Skien, ABB AS, NEFI High Power Laboratory
Stulenvegen 71
N-3721 SKIEN
Norway

The scope of accreditation is in accordance with the specifications on the following pages in this document.

The accreditation was initially granted 10.07.1995. The accreditation is given according to "Law on the free exchange of goods in the European Economic Area" of 14.04.2013. The organisation complies with the requirements in NS-EN ISO/IEC 17025 (2005)

The accreditation requires regular surveillance, and is valid until 01.03.2017.

The decision of accreditation made by Norwegian Accreditation implies that the organisation has been found to fulfil the requirements for accreditation within the scope. The organisation itself is responsible for the results of performed measurements.

NORWEGIAN ACCREDITATION

16.01.2015

Date

Norwegian Accreditation



ВЯРНО С
ОРИГИНАЛА

133

Administrative/geographical unit:
NEFI High Power Laboratory
Stulenvégen 71
N-3721 SKIEN; Norway

Permanent facility

P05 Electrical testing

Object	Parameter	Reference standard	Identity of internal method	Comments
Electrical equipment	Current-measurement RMS: 1A - 100kA Peak: 2,5A - 300 kA	Internal method	NEFI Dok. 8-21	
Electrical equipment	Voltage measurement AC: 10V-100kV peak DC: 10V-100kV	Internal method	NEFI Dok. 8-22	
High-voltages fuses: Current limiting fuses	Breaking tests	IEC 60282-1	NEFI Dok. 8-61	§ 6.6
Low-voltage switchgear and controlgear: General rules	General rules for IEC 60947 series. See IEC 60947-3 for testing parameters.	IEC 60947-1	NEFI Dok. 8-62	
Low-voltage switchgear and controlgear: Switches, disconnectors, switch- disconnectors and fuse-combination units	Testing of dielectric properties. Making and breaking capacities Dielectric verification. Leakage current. Operational performance test. Short-time withstand current test. Short-circuit making capacity test. Fuse protected short- circuit withstand.	IEC 60947-3	NEFI Dok. 8-63	8.3.3.2, 8.3.3.3, 8.3.3.4, 8.3.3.5, 8.3.4.1, 8.3.5.1, 8.3.5.2, 8.3.6.2
Low-voltage switchgear and controlgear assemblies: General rules	General rules for IEC 61439 series. Power-frequency withstand voltage. Testing of main circuit. Testing of the protective circuit	IEC 61439-1	NEFI Dok. 8-64	§10.9.2, §10.11.5.3, §10.11.5.6
Low-voltage switchgear and controlgear assemblies: Power switchgear and controlgear assemblies	See IEC 61439-1 for testing parameters.	IEC 61439-2	NEFI Dok. 8-65	

16.01.2015

Date

Norwegian Accreditation



ВЕРНО С
ОРИГИНАЛА

154

Administrative/geographical unit:
NEFI High Power Laboratory
Stulenvegen 71
N-3721 SKIEN; Norway

Permanent facility

P05 Electrical testing

Object	Parameter	Reference standard	Identity of internal method	Comments
High-voltage switchgear and controlgear: Common specifications	Common specifications for IEC 62271 series. Power-frequency voltage tests. Voltage test as condition check. Measuring of the resistance of circuits. Short-time withstand current and peak withstand current tests.	IEC 62271-1	NEFI Dok. 8-67	§6.2.6.1
				§6.2.11
				§6.4
				§6.6
High-voltage switchgear and controlgear: High-voltage alternating-current circuit-breakers	Dielectric tests. (See IEC 62271-1 for testing parameters). Measurement of the resistance of the main circuit. Short-time withstand current and peak withstand current tests.	IEC 62271-100	NEFI Dok. 8-68	§6.2
				§6.4
				§6.6
High-voltage switchgear and controlgear: Alternating current disconnectors and earthing switches	Dielectric tests. (See IEC 62271-1 for testing parameters). Measurement of the resistance of circuits. Short-time withstand current and peak withstand current tests. Tests to prove the short-circuit making performance of earthing switches. (Limited to 250 MVA)	IEC 62271-102	NEFI Dok. 8-69	§6.2
				§6.4
				§6.6
				§6.101
High-voltage switchgear and controlgear: Switches for rated voltages above 1 kV up to and including 52 kV	Dielectric tests. (See IEC 62271-1 for testing parameters). Measurement of the resistance of circuits. Short-time withstand current and peak withstand current tests. Making and breaking tests.	IEC 62271-103	NEFI Dok. 8-70	§6.2
				§6.4,
				§6.6,
				§6.101

16.01.2015

Date

Norwegian Accreditation



ВЯРНО С
ОРИГИНАЛ



Administrative/geographical unit:
NEFI High Power Laboratory
Stulenvegen 71
N-3721 SKIEN; Norway

Permanent facility

P05 Electrical testing

Object	Parameter	Reference standard	Identity of internal method	Comments
High-voltage switchgear and controlgear; High-voltage alternating current switch-fuse combinations for rated voltages above 1kV and up to and including 52kV	Dielectric tests. (See IEC 62271-1 for testing parameters). Measurement of the resistance of circuits. Making and breaking tests.	IEC 62271-105	NEFI Dok. 8-71	§6.2 §6.4, §6.101, §6.104
High-voltage switchgear and controlgear; AC metal-enclosed switchgear and controlgear for rated voltage above 1 kV and up to and including 52 kV	Dielectric tests. (See IEC 62271-1 for testing parameters). Measuring of the resistance of circuits. Short-time withstand current and peak withstand current tests. Verification of making and breaking capacities. Internal arcing test Annex AA; Method to verify the internal arc classification	IEC 62271-200	NEFI Dok. 8-72	§6.2 §6.4, §6.6, §6.101, §6.106
High-voltage switchgear and controlgear; High-voltage / low-voltage prefabricated substations	Short-time withstand current and peak withstand current tests. Internal arcing test Annex AA; Internal arc fault - Method to verify the internal arc classification (IAC)	IEC 62271-202	NEFI Dok. 8-73	§6.6 §6.102

16.01.2015

Date

Norwegian Accreditation



ВЕРНО С
ОРИГИНАЛ

Handwritten initials and number 136

Приложение ТС 15
към Технически спецификации
за от процедура PPD 15-031

ДЕКЛАРАЦИЯ
за доставка на резервни части

Долуподписаният **Ехиязар Гарабед Узунян**, в качеството ми на управител на **ИНТЕРКОМПЛЕКС ООД**, със седалище и адрес на управление: **гр. Пловдив бул. Пещерско шосе 201**, вписано в Търговския регистър към Агенцията по вписванията с ЕИК **115096057**, във връзка с обявената процедура за възлагане на обществена поръчка от **ЧЕЗ РАЗПРЕДЕЛЕНИЕ БЪЛГАРИЯ АД**

Наименование на обекта на обществената поръчка:
„Доставка на товари прекъсвачи СрН /ТПМЗ/“, реф № **PPD 15-051**

ДЕКЛАРИРАМ:

1. Производителят, „АВВ“ – Полша, гарантира, че ще осигурява резервни части за товарите прекъсвачи, съгласно приложения списък за период не по-малък от 20 години.
2. Правя настоящата декларация на основание предоставените ми документи от производителя - „АВВ“ – Полша, приложени към настоящата документация.

Известно ми е, че при деклариране на неверни данни, нося наказателна отговорност по чл. 313 от НК.

07.08.2015 година

Декларатор:

Ехиязар Узунян



138

Warszawa, date: 2015-06-16

Manufacturer's Declaration

To: ABB Bulgaria EOOD
9 Christofor Columbus Blvd.fl.3
1592,Sofia,Bulgaria

We, ABB Sp.z.o.o., located in 1 Zeganska St. 04-713 Warszawa, producer of indoor switch disconnectors NAL(F) type do hereby confirm guaranteed delivery of the spare parts for period of 20 years.

Company:

Name:

In the Capacity of:

Signed:

ABB
ABB Sp. z o.o.
ul. Bitwy Warszawskiej 1920 r. nr 18
02-387 Warszawa
NIP 526-030-44-84 / REGON 010017168
ODDZIAŁ W WARSZAWIE
ul. Żegańska 1 04-713 Warszawa
tel. (02) 22 02 000 / (22) 51 52 689

ABB Sp. z o.o.
Siedziba spółki
ul. Żegańska 1
04-713 Warszawa
tel.: 22 22 02 000, 22 02 001
fax: 22 22 02 031, 22 02 231

Sąd Rejonowy dla m.st. Warszawy
w Warszawie, XIII Wydział
Gospodarczy Krajowego Rejestru
Sądowego, nr KRS: 0000004745

NIP: 526-030-44-84, PL 5260304484
Nr GIOS: E00085JGWBW
Kapitał zakładowy: 350 655 734,00 zł
www.abb.pl



ВЕРНО С
ОРИГИНАЛ

Варшава, дата: 2015-06-16

Декларация на производител

До: АББ България ЕООД
бул. Христофор Колумб № 9, ет. 3
1592 София, България

Ние, АББ Sp.z.o.o., разположени на адрес: ул. Зеганска № 1, 04-713 Варшава, производител на товари прекъсвачи за вътрешен монтаж тип NAL(F), с настоящото потвърждаваме, че гарантираме доставката на резервни части за период от 20 години.

Фирма: фирмен печат на АББ - Полша

Име:

В качеството на:

Подпис: не се чете