

## СТОКА И БАЗОВИ ЕДИНИЧНИ ЦЕНИ

№	Наименование на материала	Марка	Ед. цена, лева без ДДС
1	2	3	4
1.	Вентилен отвод ZnO, 10Kv/10kA/клас 2	бр.	119,00
2.	Вентилен отвод ZnO, 20Kv/10kA/клас 1	бр.	70,00
3.	Вентилен отвод ZnO, 20Kv/10kA/клас 2	бр.	155,00

**Забележки:**

1. Посочените единични цени в колона 4 ще се използват като максимални единични цени /базови/ при договаряне на единичните цени на стоката за изпълнение на договори за конкретни поръчки.
2. Договорената единична цена за всяка позиция от стоката при последваща процедура – процедура на договаряне без обявление за сключване на конкретен договор, не може да бъде по-висока от единичната цена за съответната позиция стока от сключеното рамково споразумение.
3. Посочените цени са в лева, без ДДС, включват всички преки и непреки разходи, включително транспортни и организационни, свързани с изпълнението на всички дейности.

ВЪЗЛОЖИТЕЛ:

ИЗПЪЛНИТЕЛ:

**ПРОЕКТ НА КОНКРЕТЕН ДОГОВОР**

Днес, ..... 2015 г. (дата на сключване), в град София, Република България, между страните:

(1) „ЧЕЗ РАЗПРЕДЕЛЕНИЕ БЪЛГАРИЯ“ АД, със седалище и адрес на управление: Република България, гр. София 1784, Столична община, район „Младост“, бул. „Цариградско шосе“ № 159, БенчМарк Бизнес Център, вписано в Търговски регистър при Агенцията по вписванията с ЕИК: 130277958, ИН по ЗДС: BG 130277958, Банкова сметка: код: UNCRBGSF; сметка: BG43UNCR76301002ERPVBUL; при банка: Уникредит Булбанк, представлявано от ....., наричано за краткост „ВЪЗЛОЖИТЕЛ“, от една страна

и

(2) ....., наричано за краткост „ИЗПЪЛНИТЕЛ“ от друга страна,

в резултат на проведена (открита) процедура за възлагане на обществена поръчка с реф. № PPD ..... и предмет: ..., сключено Рамково споразумение № .../ ... г. и на основание чл. 41 от ЗОП, се сключи настоящият договор за следното:

### 1. ПРЕДМЕТ НА ДОГОВОРА

1.1. Съгласно условията на настоящия договор и последващите поръчки за доставка, **Изпълнителят** се задължава да достави и продаде, а **Възложителят** да приеме и купи стоки, представляващи: ....., описани по вид и количество в Приложение 1 от настоящия договор и отговарящи на техническите изисквания (характеристики) от Приложение 2 на рамковото споразумение. За целите на договора и за краткост описаните стоки от **Приложение 1**, ще бъдат наричани по-долу „СТОКА“.

1.2. Стоката, предмет на настоящия договор, се доставя и купува по поръчки, генерирани през SAP и отправени от **ВЪЗЛОЖИТЕЛЯ** до **ИЗПЪЛНИТЕЛЯ**. **ВЪЗЛОЖИТЕЛЯТ** не е длъжен да поръчва стока по предмета на договора всеки месец, нито да поръча, приеме и закупи цялото прогнозно количество от стоката през срока на действие на договора. **ВЪЗЛОЖИТЕЛЯТ** ще поръчва само толкова стока, колкото му е необходима според неговата готовност. В поръчката се включват данни за вида на стоката, конкретните количества, единична и обща цена, срок и място за доставка. Местата за доставка на стоката по предмета на договора са складове на **ВЪЗЛОЖИТЕЛЯ**, находящи се на територията на страната в следните населени места: гр. София, гр. Враца, гр. Левски и гр. Дупница.

1.3. Предаването на стоката се извършва в посочения в поръчката склад с приемно - предавателен протокол, двустранно подписан от страните по този договор или от техни надлежно упълномощени представители. Приемно-предавателният протокол се изготвя в 3 (три) еднообразни екземпляра в съответствие с образеца от Приложение 3 към договора, като един остава за **ИЗПЪЛНИТЕЛЯ** и два се предават на **ВЪЗЛОЖИТЕЛЯ**, заедно с документите, описани в Приложение 5 към т. 4.2 от настоящия договор.

1.4. (1) Протоколът по т. 1.3. се подписва и от подизпълнителя, ако в поръчката по т. 1.2 са включени стоки, за доставка на които **ИЗПЪЛНИТЕЛЯТ** е сключил договор за подизпълнение, съгласно т. 4.10. от договора.

(2) т. 1.4, ал. (1) не се прилага, ако **ИЗПЪЛНИТЕЛЯТ** представи на **ВЪЗЛОЖИТЕЛЯ** доказателства, че договорът за подизпълнение е прекратен, или доставката на стока или част от нея не е възложена на подизпълнителя.

1.5. Собствеността и рискът от погиването и повреждането на стока преминават върху **ВЪЗЛОЖИТЕЛЯ** с подписването на приемно-предавателния протокол по т. 1.3 по-горе.

### 2. ЦЕНА И НАЧИН НА ПЛАЩАНЕ

2.1. (1) Единичните цени на стоката, предмет на договора, са описани в **Приложение 1**, неразделна част от него.

Единичната цена за всеки вид стока, посочена в Приложение 1 към настоящия договор, не може да бъде по-висока от базовата единична цена за съответната стока по сключеното рамково споразумение.

(2) При надлежно и своевременно осъществяване предмета на договора **ВЪЗЛОЖИТЕЛЯТ** ще заплаща на **ИЗПЪЛНИТЕЛЯ** поръчаната по реда на т. 1.2 и приета по реда на т. 1.3 стока по единични цени от Приложение 1. При фактурирането се начислява дължимият в момента ДДС според законодателството на Република България. Единичните цени, по които се плаща стоката, са определени до франко складове на **ВЪЗЛОЖИТЕЛЯ** в следните градове, посочени в т. 1.2 по-горе, като включват всички разходи: транспорт, такси, застраховки, опаковка, документация и всички други съпътстващи доставката на стоката разходи.

2.2. **ВЪЗЛОЖИТЕЛЯТ** се задължава да заплаща поръчаната по реда на т. 1.2. и приета по реда на т. 1.3. стока чрез банкови преводи по банкова сметка на **ИЗПЪЛНИТЕЛЯ**, извършени в срок до 60 (шестдесет) календарни дни, считано от датата на издаване и предоставяне от **ИЗПЪЛНИТЕЛЯ** на

**ВЪЗЛОЖИТЕЛЯ** на оригинална фактура за стойността на конкретната доставка и документите, посочени в т. 4.2 от договора, които придружават стоката. Във фактурата трябва да са посочени: № и дата на договора, № и дата на рамковото споразумение, № и дата на приемно-предавателния протокол по т. 1.3 и № на поръчката за доставка. **ИЗПЪЛНИТЕЛЯТ** е длъжен да представи на **ВЪЗЛОЖИТЕЛЯ** издадената фактура и документите, които придружават стоката, най-късно в срок до 5 (пет) дни, считано от датата на издаването на фактурата, като при забава за представяне на фактура и придружаващите стоката документи, срокът за плащане се удължава съответно със срока на забавата.

**2.3.** Максималната стойност на договора е в размер на ..... (.....) лева без ДДС. Независимо от това дали срокът на договора по т. 3.1 е изтекъл, при достигане на максималната стойност по тази точка, договорът се прекратява автоматично, без която и да е от страните да дължи уведомление или предизвестие на другата страна.

**2.4.** **ВЪЗЛОЖИТЕЛЯТ** извършва окончателното плащане по договор за обществена поръчка, за който има сключени договори за подизпълнение, след като получи от **ИЗПЪЛНИТЕЛЯ** доказателства, че е заплатил на подизпълнителите всички работи, приети по реда на т. 5.7.

**2.5.** Условието по т.2.4. не се прилага в случаите по т. 5.8.

### 3. СРОКОВЕ

**3.1.** Договорът се сключва за срок от ..... (.....) месеца, считано от датата на влизането му в сила.

**3.2.** Съответните срокове за доставка на съответните максимални количества от стоката са посочени в Приложение 2 към договора.

**3.3.** Срокът за доставка по предходната т. 3.2 тече от датата на поръчката по т. 1.2.

**3.4.** **ВЪЗЛОЖИТЕЛЯТ** има право да поръча едновременно от всички видове стоки, предмет на договора.

**3.5.** Независимо от това колко вида стоки са поръчани едновременно, **ИЗПЪЛНИТЕЛЯТ** е длъжен да достави поръчаните му стоки в уговорения срок от датата на поръчката, ако за всеки от поръчаните видове стоки е спазено съответното максималното количество, посочено в т. 3.2. от настоящия договор.

**3.6.** В случай, че в поръчката са включени количества, по-големи от договорените по т. 3.2., за количеството над максималното, това обстоятелство ще бъде посочено текстово в съответната поръчка изпратена към **ИЗПЪЛНИТЕЛЯ**. С потвърждението на поръчката, **ИЗПЪЛНИТЕЛЯТ** влихва в същата очаквана дата за доставка, която се отнася само за количествата над максималните, посочени в т. 3.2, като **ИЗПЪЛНИТЕЛЯТ** е длъжен да достави уговореното максимално количество по т. 3.2 в 30-дневен срок от датата на поръчката.

### 4. ПРАВА И ЗАДЪЛЖЕНИЯ НА ИЗПЪЛНИТЕЛЯ

**4.1.** **ИЗПЪЛНИТЕЛЯТ** е длъжен да достави стоката във вид, качество и с технически показатели, отговарящи на техническите изисквания, определени в Приложение 2 от Рамково споразумение № ...../....., сключено между същите страни, и в съответствие с регламентите, определени в настоящия договор.

**4.2.** **ИЗПЪЛНИТЕЛЯТ** е длъжен да достави стоката, комплектована с документите, описани в Приложение 5, неразделна част от настоящия договор.

**4.3.** **ИЗПЪЛНИТЕЛЯТ** се задължава да уведоми писмено **ВЪЗЛОЖИТЕЛЯ** най-малко два дни преди изпращането на стоката за очакваната дата на пристигането ѝ в местоизпълнението /местоназначението/, посочено в съответната поръчка, чрез факс съобщение или съобщение на електронна поща. Неизпълнението на това задължение освобождава **ВЪЗЛОЖИТЕЛЯ** от забава за приемането на стоката.

**4.4.** **ИЗПЪЛНИТЕЛЯТ** отговаря пред **ВЪЗЛОЖИТЕЛЯ**, ако трети лица предявят правото си на собственост или други права по отношение на стоката, които могат да бъдат противопоставени на **ВЪЗЛОЖИТЕЛЯ**.

**4.5.** **ИЗПЪЛНИТЕЛЯТ** е длъжен да върне на **ВЪЗЛОЖИТЕЛЯ** платената цена заедно с лихвите, както и да заплати разносните по договора в случаите, когато се докаже, че продадената стока принадлежи изцяло или отчасти на трето лице, като в тези случаи **ВЪЗЛОЖИТЕЛЯТ** има право да развали договора по т. 9.1., ал. (1).

**4.6.** **ИЗПЪЛНИТЕЛЯТ** се задължава да определи свой представител за предаване на стоката по т. 1.1. с приемно-предавателния протокол по т. 1.3.

**4.7.** **ИЗПЪЛНИТЕЛЯТ** е длъжен да замени дефектната или неотговаряща на изискванията стока, констатирано в съответствие с т. 5.2. или т. 6.5. на договора, в сроковете, определени в договора.

**4.8.** **ИЗПЪЛНИТЕЛЯТ** има право да получи цената на поръчаната, реално доставена и приета стока, съгласно условията на настоящия договор.

**4.9.** При изпълнението на настоящият договор **ИЗПЪЛНИТЕЛЯТ** няма да използва/ще използва следния/те подизпълнител/и ..... (попълва се при сключване на договора, ако участникът, определен за изпълнител е декларирал в заявлението си, че при изпълнение на договора ще използва подизпълнители) за изпълнение на..... (посочват се

видовете работи, които ще се изпълняват от подизпълнителя/ите), представляващи .....(.....)% от общата стойност на поръчката (попълва се съобразно декларацията от заявлението на участника).

**4.10. ИЗПЪЛНИТЕЛЯТ** сключва договор за подизпълнение с подизпълнителите, посочени в офертата, и в срок до три дни от датата на сключване изпраща оригинален екземпляр от договора за подизпълнение на **ВЪЗЛОЖИТЕЛЯ**.

**4.11. ИЗПЪЛНИТЕЛЯТ** няма право да възлага изпълнението на една или повече от работите, включени в предмета на договора, на лица, които не са посочени като негови подизпълнители в т. 4.9 по-горе, и с които не е сключен и представен на **ВЪЗЛОЖИТЕЛЯ** договор за подизпълнение.

**4.12. ИЗПЪЛНИТЕЛЯТ** има право да замени подизпълнителя/ите по т. 4.9, когато:

а) За подизпълнителя/ите е налице или възникне обстоятелство чл. 47, ал. 1 и ал. 5 от ЗОП;

б) Подизпълнителят/ите не отговарят на нормативно изискване за изпълнение на работите, включени в предмета на договора за подизпълнение;

в) Договорът за подизпълнение е прекратен по вина на подизпълнителя/ите, включително ако подизпълнителя/ите превъзлагат една или повече работи, включени в предмета на договора за подизпълнение.

**4.13. ИЗПЪЛНИТЕЛЯТ** е длъжен да прекрати договор за подизпълнение, ако по време на изпълнението му възникне обстоятелство по чл. 47, ал. 1 и ал. 5 от ЗОП, както и ако подизпълнителят превъзлага една или повече работи, включени в предмета на договора за подизпълнение.

**4.14.** В случаите по т. 4.12 и т. 4.13 **ИЗПЪЛНИТЕЛЯТ** сключва нов договор за подизпълнение или допълнително споразумение към договор за подизпълнение и изпраща оригинален екземпляр на **ВЪЗЛОЖИТЕЛЯ** в срок до три дни от датата на сключване, заедно с доказателства за липса на обстоятелствата по чл. 47, ал. 1 и ал. 5 от ЗОП за подизпълнителя.

**4.15.** Сключване на договор за подизпълнение или на допълнително споразумение към договор за подизпълнение не освобождава **ИЗПЪЛНИТЕЛЯ** от отговорността му за изпълнение на настоящия договор. Използването на подизпълнител/и не изменя задълженията на **ИЗПЪЛНИТЕЛЯ** по договора. **ИЗПЪЛНИТЕЛЯТ** отговаря за действията на подизпълнителя/ите като за свои действия.

**4.16.** Приложимите клаузи на договора са задължителни за изпълнение от подизпълнителя/ите.

**4.17.** Подизпълнителите нямат право да превъзлагат една или повече от дейностите, които са включени в предмета на договора, за подизпълнение.

**4.18.** Доставка на стоки, материали или оборудване, необходими за изпълнението на обществената поръчка, не се счита за наемане на подизпълнител, когато такава доставка не включва монтаж, както и сключването на договори за услуги, които не са част от настоящия договор за обществена поръчка, съответно - от договора за подизпълнение.

## **5. ПРАВА И ЗАДЪЛЖЕНИЯ НА ВЪЗЛОЖИТЕЛЯ**

**5.1. ВЪЗЛОЖИТЕЛЯТ** се задължава да определи свой представител за приемане на стоката по т. 1.1. с приемно-предавателния протокол по т. 1.3.

**5.2. (1) ВЪЗЛОЖИТЕЛЯТ** провежда входящ контрол за качество на доставената стока с цел установяване на съответствието ѝ с изискванията, посочени в настоящия договор и приложенията към него. За проведения входящ контрол **ВЪЗЛОЖИТЕЛЯТ** изготвя протокол.

**(2)** При установяване на недостатъци по време на входящия контрол, **ВЪЗЛОЖИТЕЛЯТ** е длъжен писмено да уведоми **ИЗПЪЛНИТЕЛЯ** в срок до 10 /десет/ дни от датата на протокола по ал. (1). В писменото уведомление по предходното изречение **ВЪЗЛОЖИТЕЛЯТ** описва недостатъците (дефектите) на доставената стока и начина за отстраняването им. **ИЗПЪЛНИТЕЛЯТ** е длъжен да прегледа уведомлението с констатациите на **ВЪЗЛОЖИТЕЛЯ** за недостатъци (дефекти) на стоката и да го уведоми писмено (по факс или на електронна поща) за това дали приема констатациите - съответно предложеният начин за отстраняване на недостатъците (дефектите) или не ги приема. **ИЗПЪЛНИТЕЛЯТ** следва да изпълни задължението си за уведомяване по предходното изречение в срок до 1 /един/ работен ден от датата на получаване на уведомлението на **ВЪЗЛОЖИТЕЛЯ** за резултатите от входящия контрол. В случай, че **ИЗПЪЛНИТЕЛЯТ** не уведоми **ВЪЗЛОЖИТЕЛЯ** за решението си относно констатациите от входящия контрол в срока по предходното изречение, се счита, че не ги приема, вследствие на което **ВЪЗЛОЖИТЕЛЯТ** пристъпва към съставянето на констативен протокол по ал. (3). В случай че **ИЗПЪЛНИТЕЛЯТ** приеме констатациите и предложенията на **ВЪЗЛОЖИТЕЛЯ**, констативен протокол по ал. (3) не се съставя, а **ИЗПЪЛНИТЕЛЯТ** е длъжен да отстрани констатираните недостатъци (дефекти) в срок до 15 /петнадесет/ календарни дни, считано от датата на писменото им приемане. В случай, че **ИЗПЪЛНИТЕЛЯТ** не приеме констатациите и предложенията на **ВЪЗЛОЖИТЕЛЯ**, последният го уведомява писмено за дата, час и място за съставяне на констативен протокол по ал. (3). Писменото уведомление за съставянето на констативен протокол по ал. (3) се изпраща на **ИЗПЪЛНИТЕЛЯ** не по-късно от три дни преди посочената в уведомлението дата за съставяне на протокола.

**(3)** При отказ на **ИЗПЪЛНИТЕЛЯ** да приеме констатациите на **ВЪЗЛОЖИТЕЛЯ** относно недостатъците (дефектите) на стоката и начина на тяхното отстраняване по предходната алинея, страните по

СЧ / 10



договора съставят и подписват констативен протокол, в който се описват установените недостатъци, начинът и срокът за тяхното отстраняване. Срокът за отстраняване на недостатъците (дефектите) на стоката не може да бъде по-дълъг от 15 /петнадесет/ календарни дни.

(4) Неявявяването на **ИЗПЪЛНИТЕЛЯ** за съставяне и подписване на констативния протокол по предходната алинея не го освобождава от отговорност. В този случай констативният протокол се съставя само от представители на **ВЪЗЛОЖИТЕЛЯ** и се изпраща на **ИЗПЪЛНИТЕЛЯ** по факс или електронна поща за изпълнение. В този случай срокът за отстраняване на недостатъците, посочен в констативния протокол, започва да тече от датата на изпращането на протокола на **ИЗПЪЛНИТЕЛЯ**.

(5) При съставянето на констативния протокол по ал. (3), респективно по ал. (4), страните отчитат уговореното в т. 5.3. от договора.

5.3. При установяване на недостатъци (дефекти) на стоката по реда на т. 5.2. или т. 6.5. от договора **ВЪЗЛОЖИТЕЛЯТ** има следните алтернативни права:

(1) да иска замяна на дефектната или неотговаряща на изискванията стока с нова за сметка на **ИЗПЪЛНИТЕЛЯ**; или

(2) да задържи стоката и да иска отбив от цената; или

(3) да откаже да приеме стоката или да върне приетата, но дефектна или неотговаряща на изискванията стока, съответно да не я заплати или ако вече е заплатена, да иска връщането на платената за нея цена.

5.4. При доставка на дефектна стока или стока, която не отговаря на изискванията на **ВЪЗЛОЖИТЕЛЯ**, констатирано в съответствие с т. 5.2. или т. 6.5., и в случай, че **ИЗПЪЛНИТЕЛЯТ** не отстрани недостатъците, съответно не замени дефектната стока с качествена в уговорените срокове, то **ВЪЗЛОЖИТЕЛЯТ** има право да предприеме действия за отстраняване на недостатъците от трета страна или да ги отстрани сам, за сметка на **ИЗПЪЛНИТЕЛЯ**. В този случай **ВЪЗЛОЖИТЕЛЯТ** има право на неустойката по т. 7.2.

5.5. В случаите на т. 5.3., **ВЪЗЛОЖИТЕЛЯТ** може да приеме неотговарящата на изискванията или дефектна стока на отговорно пазене, като вземе всички възможни мерки за безопасното ѝ съхранение за максимален срок от един месец.

5.6. **ВЪЗЛОЖИТЕЛЯТ** е длъжен, съгласно условията на този договор, да изплати на **ИЗПЪЛНИТЕЛЯ** договорената цена за поръчаната, реално доставена и приета стока.

5.7. **ВЪЗЛОЖИТЕЛЯТ** приема изпълнението на дейност по договора за обществена поръчка, за която **ИЗПЪЛНИТЕЛЯТ** е сключил договор за подизпълнение, в присъствието на **ИЗПЪЛНИТЕЛЯ** и на подизпълнителя.

5.8. При приемането на работата **ИЗПЪЛНИТЕЛЯТ** може да представи на **ВЪЗЛОЖИТЕЛЯ** доказателства, че договорът за подизпълнение е прекратен, или работата или част от нея не е извършена от подизпълнителя.

## 6. ГАРАНЦИИ И РЕКЛАМАЦИИ

6.1. При подписване на настоящия договор **ИЗПЪЛНИТЕЛЯТ** представя гаранция за изпълнение на стойност от ..... (.....) лева под формата на паричен депозит по сметка на **ВЪЗЛОЖИТЕЛЯ**, както следва: SWIFT (BIC): UNCRBGSF; Банкова сметка (IBAN) в лева: BG43 UNCR 7630 1002 ERPB UL; при банка: Уникредит Булбанк или под формата на безусловна и неотменяема банкова гаранция, издадена в полза на **ВЪЗЛОЖИТЕЛЯ** със срок на валидност ..... /...../ месеца.

6.2. (1) Гаранцията за изпълнение ще компенсират **ВЪЗЛОЖИТЕЛЯ** за всякакви вреди и загуби, причинени вследствие виновно неизпълнение/забава на договора (задължения по договора) от страна на **ИЗПЪЛНИТЕЛЯ**, както и за произтичащите от тях неустойки. В случай, че претърпените вреди на **ВЪЗЛОЖИТЕЛЯ** са в по-голям размер от размера на гаранцията за изпълнение по предходната точка, **ВЪЗЛОЖИТЕЛЯТ** има право да потърси обезщетение по общия съдебен ред пред компетентния български съд.


(2) За неуредените условия по отношение на гаранцията за изпълнение и в частност за попълването и при усвояване на суми от нея се прилага съответно Раздел 6 (в частност т. 6.5) от рамковото споразумение.

6.3. (1) Гаранцията за изпълнение или неинкасираната част от нея ще бъде освободена от **ВЪЗЛОЖИТЕЛЯ** и върната на **ИЗПЪЛНИТЕЛЯ** в срок до 30 /тридесет/ календарни дни след изтичане на срока на договора, съответно след прекратяването му на друго основание, ако изпълнението е надлежно, освен ако не е усвоена поради неизпълнение.

(2) За срока, през който гаранцията за изпълнение е престояла законосъобразно при **ВЪЗЛОЖИТЕЛЯ**, последният не дължи лихва.

6.4. Гаранционният срок на закупената стока е ..... месеца, считано от датата на подписването на приемно-предавателния протокол за приемането ѝ в склада на **ВЪЗЛОЖИТЕЛЯ** при спазване на указанията за съхранение, монтаж и експлоатация на производителя.

6.5. (1) По всяко време от действието на договора, **ВЪЗЛОЖИТЕЛЯТ** има право да проверява доставената стока, която не е в режим на експлоатация, за наличие на скрити недостатъци.



Проверката по предходното изречение се извършва от служители на **ВЪЗЛОЖИТЕЛЯ**, притежаващи съответната техническа компетентност, и се удостоверява със съставянето на констативен протокол. При откриване на скрити недостатъци на доставената стока по реда на настоящата точка, същите се считат за гаранционни дефекти и **ИЗПЪЛНИТЕЛЯТ** е длъжен да ги отстрани в съответствие с гаранционните условия, при условие, че са спазени условията за съхранение на стоката.

(2) За гаранционни дефекти на стоката, освен скритите недостатъци по т. 6.5, ал. 1, се считат и всички дефекти на стоката, които са се проявили по време на експлоатацията ѝ и не са резултат от неправилни действия на **ВЪЗЛОЖИТЕЛЯ** и/или негови служители и са в рамките на гаранционния срок по т. 6.4.

(3) При констатиране на дефекти (неизправности) на стоката в рамките на гаранционния срок, **ВЪЗЛОЖИТЕЛЯТ** е длъжен да уведоми писмено **ИЗПЪЛНИТЕЛЯ** в 10 /десет/ дневен срок от откриването им. В писменото уведомление по предходното изречение **ВЪЗЛОЖИТЕЛЯТ** описва недостатъците (дефектите) на стоката и начинът за отстраняването им. **ИЗПЪЛНИТЕЛЯТ** е длъжен да прегледа уведомлението с констатациите на **ВЪЗЛОЖИТЕЛЯ** за недостатъци (дефекти) на стоката и да го уведоми писмено (по факс или на електронна поща) за това дали приема констатациите - съответно предложеният начин за отстраняване на недостатъците (дефектите) или не ги приема. **ИЗПЪЛНИТЕЛЯТ** следва да изпълни задължението си за уведомяване по предходното изречение в срок до 5 /пет/ работни дни от датата на получаване на уведомлението на **ВЪЗЛОЖИТЕЛЯ** за констатирания дефект на стоката в рамките на гаранционния срок. В случай, че **ИЗПЪЛНИТЕЛЯТ** не уведоми **ВЪЗЛОЖИТЕЛЯ** за решението си по отношение на предявената reklamacija в срока по предходното изречение, се счита, че не я приема, вследствие на което **ВЪЗЛОЖИТЕЛЯТ** пристъпва към съставянето на констативен протокол. За съставянето и съдържанието на констативния протокол се прилагат съответно т. 5.2, ал. (2), (3), (4) и (4). При съставянето на констативния протокол страните отчитат уговореното в т. 6.6.

6.6. В рамките на гаранционния срок по т. 6.4, всички разходи по отстраняване на дефекти и/или замяна на стоката с нова, са за сметка на **ИЗПЪЛНИТЕЛЯ**.

6.7. Ако в рамките на гаранционния срок се констатират фабрични дефекти, които не могат да бъдат отстранени от **ИЗПЪЛНИТЕЛЯ** в срок до 15 /петнадесет/ календарни дни от датата, на която неизправната стока му е предадена за ремонт, **ИЗПЪЛНИТЕЛЯТ** е длъжен да замени дефектната стока с нова в срок до 1 (един) месец, считано от изтичането на 15-дневния срок за ремонт на стоката.

## 7. ОТГОВОРНОСТИ

7.1. При забава за изпълнение на задължения по този договор, с изключение на случаите по т. 8.1 на договора, **ИЗПЪЛНИТЕЛЯТ** дължи на **ВЪЗЛОЖИТЕЛЯ** неустойка в размер на 0,2% знав секи пълен ден забава, но не повече от 10% общо върху стойността на неизпълненото задължение.

7.2. За всеки отделен случай на неизпълнение на задълженията в рамките на гаранционния срок (с изключение на случаите по т. 8.1), **ИЗПЪЛНИТЕЛЯТ** дължи на **ВЪЗЛОЖИТЕЛЯ** неустойка, равна на 10% от стойността на реално доставената, но дефектна (неизправна) стока, по отношение на която е възникнало неизпълненото гаранционно задължение.

7.3. **ВЪЗЛОЖИТЕЛЯТ** има право да претендира неустойка в размер на 50% от стойността на гаранцията за изпълнение на договора, посочена в т. 6.1, в следните случаи:

- (1) при прекратяване на договора по т. 9.1., ал. (2);
- (2) при отказ на **ИЗПЪЛНИТЕЛЯ** да изпълни поръчка за доставка при условията на този договор;
- (3) при прекратяване на договора по т. 9.1., ал. (3) и ал. (4).

7.4. При забава за плащане, **ВЪЗЛОЖИТЕЛЯТ** дължи на **ИЗПЪЛНИТЕЛЯ** обезщетение в размер на законната лихва за забава (равна на основния лихвен процент (ОЛП), обявен от БНБ, плюс 10%), начислена върху стойността на закъснялото плащане за периода на забавата, като стойността на обезщетението не може да бъде повече от 10% общо от стойността на забавеното плащане.

7.5. Неустойките по настоящия договор се заплащат в срок до 10 (десет) календарни дни, считано от датата на писмената претенция за тях от изправната до неизправната страна. **ВЪЗЛОЖИТЕЛЯТ** има право, ако в определения срок за плащане на дължимата неустойка **ИЗПЪЛНИТЕЛЯТ** не изпълни задължението си, да се удовлетвори за сумата на неустойката от гаранцията за изпълнение на договора в съответствие с т. 6.2 по-горе или да я прихване от следващо дължимо плащане по договора.

7.6. В случай, че не е уговорено друго, неустойките се начисляват върху стойността на закъснялото/неизпълнено задължение без ДДС.

7.7. В случаите, когато посочените по-горе неустойки не покриват действителния размер на претърпените от **ВЪЗЛОЖИТЕЛЯ** вреди, той може да търси от **ИЗПЪЛНИТЕЛЯ** по съдебен ред разликата до пълния размер на претърпените вреди и пропуснатите ползи.

7.8. В случай, че **ИЗПЪЛНИТЕЛЯТ** не изпълни задължението си да изпрати на **ВЪЗЛОЖИТЕЛЯ** оригинален екземпляр от договор за подизпълнение/допълнително споразумение към договор за подизпълнение по т. 4.10 и/или 4.14 от настоящия договор в срок до три дни от датата на сключване

на договора, съответно споразумението към него, то той дължи на **ВЪЗЛОЖИТЕЛЯ** неустойка в размер на 2 000.00 лева.

7.9. При нарушаване на задължение по раздел 11 по-долу, виновната страна дължи на изправната страна неустойка за всеки конкретен случай на нарушение в размер на 50% от гаранцията за изпълнение, заедно с обезщетяване на всички вреди над сумата на неустойката, настъпили вследствие нарушаване на задълженията по раздел 11 от договора.

## 8. НЕПРЕОДОЛИМА СИЛА ИЛИ НЕПРЕДВИДИМИ СЪБИТИЯ

8.1 В случаи на непреодолима сила по смисъла на чл. 306 от Търговския закон или на непредвидими събития и доколкото тези събития се отразяват върху изпълнението на задълженията на двете страни по договора, сроковете за изпълнение трябва да бъдат удължени за времето, през което е траела непреодолимата сила или непредвидимите събития. Страните се споразумяват за непредвидими събития да се считат издадени или изменени нормативни или ненормативни актове на държавни или общински органи, настъпили по време на изпълнение на договора, които се отразяват на изпълнението на задълженията, на която и да е от страните.

8.2 Двете страни трябва взаимно да се уведомяват писмено за началото и края на тези събития, както следва:

8.2.1. за непреодолимата сила известието трябва да бъде потвърдено от Търговската камара на страната, в която е настъпило, и да бъде изпратено на другата страна до 14 (четирнадесет) дни след започването му.

8.2.2. за непредвидимите събития – в 14-дневен срок от издаждането или изменението на нормативен или ненормативен акт на държавен или общински орган.

8.3 В случай на непреодолима сила или непредвидимо събитие в страната на **ИЗПЪЛНИТЕЛЯ** и/или **ВЪЗЛОЖИТЕЛЯ** и ако то доведе до закъснение в изпълнението на задълженията на някоя от страните за повече от 1 (един) месец, всяка от страните има право да прекрати договора по т. 9.3.

## 9. РАЗВАЛЯНЕ И ПРЕКРАТЯВАНЕ НА ДОГОВОРА

9.1. **ВЪЗЛОЖИТЕЛЯТ** има право:

(1) да развали договора в случаите на т. 4.5. от договора;

(2) да прекрати договора с 10-дневно писмено предизвестие отправено до **ИЗПЪЛНИТЕЛЯ** при забава на **ИЗПЪЛНИТЕЛЯ** с повече от 30 дни, без да са налице обстоятелствата по т. 8.1, като в този случай **ВЪЗЛОЖИТЕЛЯТ** има право на неустойката по т. 7.3., ал. (1);

(3) да прекрати договора с 30-дневно писмено предизвестие до **ИЗПЪЛНИТЕЛЯ**, при повторна доставка на партида дефектна стока или на стока, неотговаряща на изискванията на **ВЪЗЛОЖИТЕЛЯ**, посочени в договора и в приложенията към него, когато това обстоятелство е установено по реда на точка 5.2. от настоящия договор, като в този случай **ИЗПЪЛНИТЕЛЯТ** дължи неустойката по т. 7.3., ал. (3). Настоящата клауза се прилага и в случаите, когато:

а) двете доставени партиди дефектна стока и/или стока, неотговаряща на изискванията на **ВЪЗЛОЖИТЕЛЯ**, не са поредни;

б) в рамките на срока на договора е установено един или повече пъти по реда на т. 6.5. и един или повече пъти по реда на т. 5.2. (кумулятивно), че доставена стока е дефектна и/или не отговаря на изискванията на **ВЪЗЛОЖИТЕЛЯ**, посочени в договора и в приложенията към него.

(4) да прекрати договора без предизвестие, в случай, че по реда на т. 6.5 към **Изпълнителя** са отправени три или повече претенции (които не е задължително да са последователни) за гаранционни дефекти на доставената стока, дори същите да са били отстранени. В този случай **Изпълнителят** дължи неустойката по т. 7.3., ал. (3).

9.2. Настоящият договор може да се прекратява по взаимно писмено съгласие по всяко време, като двете страни уреждат взаимоотношенията си до момента на прекратяването.

9.3. В случаите на т. 8.3., всяка от страните има право да прекрати договора с 10-дневно писмено предизвестие до другата страна.

9.4. Договорът се прекратява и в следните случаи:

(1) по т. 2.3; и

(2) по т. 3.1.

9.5. Извън хипотезите по предходните точки, настоящият договор се прекратява или разваля и на следните основания:

(1) в изрично посочените случаи в рамковото споразумение, които не се съдържат в настоящия договор;

(2) на общо основание при условията и по реда на чл. 87 от Закона за задълженията и договорите (ЗЗД);

(3) при разваляне или прекратяване на рамковото споразумение, въз основа на което се сключва настоящия договор, като направените поръчки до момента на прекратяването съответно развалянето се довършват и заплащат при условията на договора.

## 10. РЕШАВАНЕ НА СПОРОВЕ

10.1. Всички спорове, възникнали във връзка с тълкуването и/или изпълнението на договора, се решават чрез преговори и постигане на взаимно изгодни договорености, материализирани в писмена форма за валидност.

10.2. Всички спорове, породени от този договор или отнасящи се до него, включително споровете, породени или отнасящи се до неговото тълкуване, недействителност, изпълнение или прекратяване, както и споровете за попълване празноти в него или приспособяването му към нововъзникнали обстоятелства, за които не е постигнато съгласие по реда на предходната точка, ще бъдат разрешавани по общия гражданскоправен ред, от компетентния съд в Република България със седалище в гр. София.

10.3. Отнасянето на спора за решаване от компетентния съд не ще се счита за причина за спирането на изпълнението на други задължения по настоящия договор, които нямат отношение към предмета на спора.

10.4. Решение от компетентен съд или изменение на законодателството, което прави някое от условията на този договор невалидно, недействително или неизпълнимо, ще се отнася само до това условие и няма да прави целия договор или някакво друго условие от него невалиден, недействителен или неизпълним и всички други условия на договора ще останат в пълна сила и ефект, така както са уговорени от страните. Страните поемат задължението да положат всички усилия, за да се договорят за заместващо условие на невалидното, недействителното или неизпълнимото условие с валидно, действително и изпълнимо условие, което най-близко отразява целта на невалидното, недействителното или неизпълнимото условие.

## 11. КОНФИДЕНЦИАЛНОСТ

11.1. Страните се задължават да пазят и да не допускат разпространяването на информацията определена за конфиденциална, получена от всяка от страните по повод сключването или по време на срока на действие на този договор, както и да използват тази информация единствено за целите на изпълнението. Страните ще считат за конфиденциална информацията съдържаща се в договора и информацията във връзка с начина на изпълнението му, както и всяка информация която се съдържа на хартиен или магнитен носител и е създадена или предоставена на някоя от страните във връзка с изпълнението на договора. Конфиденциална е и всяка информация, която е станала достъпна на някоя от страните по повод изпълнението на договора и която представлява ноу-хау, схеми на складове съответно схеми за достъп и охрана или фирмена тайна на другата страна, или която е определена изрично при предоставянето ѝ от съответната страна за конфиденциална. Конфиденциална е и информацията свързана с лични данни, станали известни на някоя от страните във връзка със сключването или изпълнението на договора.

11.2. Страните се съгласяват, че въпреки прекратяването на този договор поради каквато и да е причина, клаузите свързани с конфиденциалност, ще са в сила и задълженията във връзка с тях ще бъдат валидни за период от 2 (две) години след прекратяване на договора.

11.3. Клаузите за конфиденциалност не се прилагат когато някоя от страните е длъжна да предостави информация по договора на компетентен държавен орган, който е поискал тази информация във връзка с правомощията му по закон. При предоставяне на информация по тази точка, страната която я дава е длъжна незабавно да уведоми писмено другата страна.

## 12. ЗАКЛЮЧИТЕЛНИ РАЗПОРЕДБИ

12.1. Договорът влиза в сила считано от датата на подписването му от страните.

12.2. (1) При празноти в настоящия конкретен договор, сключен въз основа на рамково споразумение, субсидиарно ще се прилага уговореното в рамковото споразумение, доколкото то не противоречи на смисъла и съдържанието на настоящия конкретен договор.


(2) При противоречие на уговореното в рамковото споразумение и приложенията към него с уговореното в конкретния договор (и приложенията към него), сключен въз основа на настоящото рамково споразумение, с предимство ще се ползва и прилага уговореното в настоящия конкретен договор за обществена поръчка.

12.3. По отношение на този договор и за неуредените в него въпроси е приложимо действащото в Република България законодателство.

12.4. Всички съобщения и уведомления на страните по настоящия договор ще се извършват само в писмена форма, като условие за действителност. Тази форма ще се счита за спазена, ако съобщението е изпратено по e-mail или факс, доколкото съществува техническа възможност за установяване на момента на получаване на съобщението/уведомлението чрез генериране на известие за доставяне от техническото средство на изпращане.

12.5. (1) При преобразуване на изпълнителя в съответствие със законодателството на държавата, в която е установен, настоящият договор остава в сила, ако са налице едновременно следните условия:

1. Правоприемникът сключи договор за продължаване на настоящия договор за изпълнение;
2. Договорът за продължаване не променя настоящия договор за изпълнение;



14

3. Правоприемникът отговаря на условията на чл. 43, ал. 7 изречение второ от ЗОП.

(2) Ако правоприемникът не отговаря на предходната ал. 1, т. 3, настоящият договор се прекратява по право, като **ИЗПЪЛНИТЕЛЯТ**, съответно правоприемникът дължи обезщетение по общия исков ред.

12.6. Неразделна част от настоящия договор са следните приложения:

**Приложение 1:** Стока и цени;

**Приложение 2:** Количества със срокове за доставка и опаковка /определят се в последваща процедура на договаряне без обявление/;

**Приложение 3:** Образец на приемно-предавателен протокол /определят се в последваща процедура на договаряне без обявление/;


**Приложение 4:** Образец на опаковъчен лист /определят се в последваща процедура на договаряне без обявление/;

**Приложение 5:** Придружаващи доставката документи /определят се в последваща процедура на договаряне без обявление/;

Договорът е изготвен в два еднообразни екземпляра на български език – по един за всяка от страните, които след като се запознаха със съдържанието му и го приеха го подписаха, както следва:

ВЪЗЛОЖИТЕЛ:

ИЗПЪЛНИТЕЛ:



A handwritten signature in black ink, consisting of a stylized, cursive script.

**ТЕХНИЧЕСКО ПРЕДЛОЖЕНИЕ**

за участие в открита процедура за сключване на рамково споразумение с  
наименование:

„Доставка на вентилни отводи СрН”  
реф. № PPD 15-034

ДО: „ЧЕЗ РАЗПРЕДЕЛЕНИЕ БЪЛГАРИЯ” АД, ГР. СОФИЯ, УЛ. „ЦАР  
СИМЕОН” № 330


ОТ: “ВАК-02” ООД – гр. Самоков

Адрес на управление: гр. Самоков, ул. “Христо Йончев”, № 7А  
Тел.: 02/ 978 52 20; факс: 02/ 992 84 54; e-mail: [office@vak-02.com](mailto:office@vak-02.com)  
Единен идентификационен код: 131008947,


Представяван от Ивайло Арангелов Конярски – Управител  
Упълномощен представител за тази процедура (ако е предвидено) .....,  
с приложено пълномощно № ....., дата .....  
Тел.: 02/ 978 52 20; факс: 02/ 992 84 54; e-mail: [office@vak-02.com](mailto:office@vak-02.com)

**УВАЖАЕМИ ГОСПОДА,**

1. Запознат съм и приемам изискванията на Възложителя, като представям техническите спецификации от раздел IV на документацията с попълнени всички изисквани стойности за всички позиции от стоката по предмета на поръчката.
2. Представям всички изисквани данни и документи, посочени в Приложение 2 от настоящото техническо предложение. Запознат съм с изиксването, че представените документи трябва да бъдат на български език или с превод на български език, придружени с оригиналните документи, с изключение на каталозите и протоколите от типовите изпитвания, които могат да се представят и само на английски език.
3. Запознат съм, че представените от нас технически документи (протоколи от изпитания, каталози и др) са доказателство за декларираните от мен технически данни и параметри в техническите спецификации на стоката.
4. Потвърждавам, че представяните от нас стоки, описани в Техническото ни предложение ще отговарят на посочените от възложителя стандарти или на еквивалентни. В случай, че даден материал отговаря на стандарт, еквивалентен на посочения се задължаваме да го отразим в отделен документ и да представим доказателства за еквивалентността на двата стандарта.
5. Всички стойности, попълнени в колона „Гарантирано предложение” на приложените таблици от Технически спецификации от раздел IV от документацията за участие са точни и истински.
6. Предлагам гаранционен срок за предлаганите стоки - 24 месеца / не по-малко от 24 месеца/, от датата на приемо – предавателен протокол за получаване на стоката от Възложителя.
7. Запознат съм, че видовете стоки и ориентировъчни количества за доставка ще бъдат посочени от Възложителя при провеждане на процедура на договаряне без обявление.
8. Приемем, че в срок до .....( не повече от 10 дни) от датата на подписване на договор с възложителя, ще сключа договор с посочения/те в офертата







подизпълнител/и (попълва се, ако участникът е декларирал, че ще използва подизпълнител/и).

9. Запознат съм, че в процедурата на договаряне без обявление, изборът на изпълнител ще бъде направен по критерий "най-ниска цена".



10. Запознат съм, че максималният срок за изпълнение на конкретен договор ще бъде определен от Възложителя в поканата за договаряне.

**Приложения:**

1. Технически изисквания и спецификации за изпълнение на поръчката – раздел IV от документацията за участие – попълнени на съответните места;
2. Изисквани документи от Технически изисквания и спецификации

Дата 10.08.2015 г.

**ПОДПИС и ПЕЧАТ:**  
Ивайло Конярски  
Управител





#### IV. ТЕХНИЧЕСКИ ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА

**Наименование на материала:** Вентилен отвод метало-оксиден тип без искрови разрядници, 10 kV, 10 kA, клас 2

**Съкратено наименование на материала (40 знака):** Вентилен отвод ZnO, 10 kV / 10 kA / клас 2

**Област:** В – Въздушни електропроводни линии СрН  
от

Н – Трансформаторни постове

**Категория:** 20 – Защита  
от пренапрежения

**Мерна единица:** Брой

**Аварийни запаси:** Да

#### Характеристика на материала:

Метало-оксиден (ZnO) вентилен отвод без искрови разрядници, за монтиране на закрито и открито, с трайно работно напрежение min 10,8 kV, с номинален разряден ток 10 kA, с разряден клас на линията 2, с полимерна изолационната обвивка, с принадлежности (аксесоари) за свързване между тоководещи части и земя. Конфигурацията на стрехите на полимерната изолационна обвивка съответстват на изискванията на IEC/TS 60815-3.

#### Използване:

Вентилният отвод е предназначен за използване в електроразпределителни мрежи с номинално напрежение 10 kV с изолирана неутрала, със заземена през дългогасителна бобина неутрала, със заземена през активно съпротивление неутрала или с комбинирано заземяване на неутралата през дългогасителна бобина и активно съпротивление.




#### Съответствие на предлаганото изделие със стандартизационните документи:

Вентилният отвод трябва да отговаря на приложимите български и международни стандарти, включително на посочените по-долу и на техните валидни изменения и поправки или еквиваленти:

- БДС EN 60099-4:2014 „Вентилни отводи. Част 4: Металооксидни вентилни отводи без разрядници за електрически системи за променливо напрежение (IEC 60099-4:2014)”; и
- IEC/TS 60815-3:2008 „Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 3: Polymer insulators for a.c. systems”.

#### Изисквания към документацията и изпитванията:

№ по ред	Наименование	Приложение № (или текст)
1.	Точно обозначение на типа, производителя и страна на произход	№ 2.1 (тип: AZC_15_ /AZC150)
2.	Техническо описание, гарантирани параметри, волт-секундна характеристика, използвани материали и принадлежности (аксесоари)	№ 2.1



№ по ред	Наименование	Приложение № (или текст)
3.	Чертежи с размери и надлъжен разрез	№ 2.2
4.	Протоколи от типови изпитвания на английски или български език, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	№ 2.3
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4 – заверено копие	№ 2.4
6.	Изисквания за транспортиране и манипулиране	№ 2.5
7.	Инструкции за монтиране и за експлоатация и обслужване	№ 2.5
8.	Експлоатационна дълготрайност, год.	№ 2.6 (20 год.)

*Забележка: Всички оригинални документи трябва да бъдат на български език или с превод на български език. Каталогите и изпитвателните протоколи могат да бъдат и само на английски език.*

#### Технически данни:

##### 1. Характеристики на работната среда:

№ по ред	Характеристика	Стойност
1.1	Място на монтиране	На открито/закрито
1.2	Максимална околна температура	+ 40°C
1.3	Минимална околна температура	Минус 25°C
1.4	Относителна влажност	До 100 %
1.5	Надморска височина	До 1000 m
1.6	Други работни условия	Съгласно т. 5.4.1 от БДС EN 60099-4

##### 2. Параметри на електроразпределителната мрежа:

№ по ред	Параметър	Стойност
2.1	Номинално напрежение	10 000 V
2.2	Най-високо напрежение на съоръженията	12 000 V
2.3	Най-високо напрежение на системата	10 800 V
2.4	Номинална честота	50 Hz
2.5	Брой на фазите	3

2.6	Заземяване на звездния център	<ul style="list-style-type: none"> <li>• През дъгогасителна бобина;</li> <li>• изолиран звезден център;</li> <li>• през активно съпротивление; или</li> <li>• през дъгогасителна бобина комбинирана с активно съпротивление.</li> </ul>
2.7	Максимална стойност на временните пренапрежения (при земно съединение) / максимална продължителност на временните пренапрежения:	-
2.7a	1.1 заземяване през дъгогасителна бобина; или 1.2 изолиран звезден център	11,8 kV/2 часа
2.7b	1.3 заземяване през активно съпротивление; или 1.4 през дъгогасителна бобина комбинирана с активно съпротивление	10,8 kV/3 s
2.8	Изоляционно ниво:	-
2.8a	Обявено издържано мълниев импулсно напрежение (върхова стойност)	75 kV
2.8b	Обявено краткотрайно (1 min) издържано напрежение с промишлена честота (50 Hz) (ефективна стойност)	28 kV
2.9	Ток на късо съединение в мястото на монтиране на вентилния отвод - максимален ток при трифазно късо съединение	15 kA

### 3. Свързване в системата и защитавани съоръжения:

№ по ред	Наименование	Изискване
3.1	Свързване в системата	Между фаза и земя
3.2	Защитавани съоръжения	<ul style="list-style-type: none"> <li>• Разпределителни трансформатори 10/0,4 kV, свързани директно към въздушна електропроводна линия (ВЛ) или чрез присъединена към ВЛ кабелна линия;</li> <li>• кабелни линии 10 kV;</li> <li>• входове на разпределителните уредби;</li> <li>• КРУ в елегазова изолационна среда (GIS)</li> </ul>

### 4. Технически характеристики:

№ по ред	Характеристика	Изискване	Гарантирано предложение
4.1	Обявено издържано напрежение при атмосферни пренапрежения 1,2/50 μs	min 75 kV	120 kV

4.2	Обявено издържано 1 min напрежение с промишлена честота 50 Hz при мокра изолация	min 28 kV	46 kV
4.3	Ниво на частичните разряди при 1,05 U <sub>c</sub>	max 10 pC	10 pC
4.4	Материал, от който е изработено нелинейното съпротивление (варистора)	ZnO	ZnO
4.5	Материал, от който е изработена изолационната обвивка	Полимер	Полимер - Силиконов каучук
4.6	Материал, от който са изработени принадлежностите (аксесоарите)	Неръждаема стомана	Неръждаема стомана
4.7	Якост на опън	min 1 kN	1 kN
4.8	Якост на усукване	min 50 Nm	50 Nm
4.9	Якост на огъване	min 200 Nm	250 Nm

### 5. Принадлежности (аксесоари):

№ по ред	Наименование	Изискване	Гарантирано предложение
5.1	Аксесоари за присъединяване на вентилния отвод към тоководещи части и към заземителния контур	Резбови съединения (шпилки) с резба M12, съоръжени съответно с две гайки и две подложни шайби и средства срещу самоотвиване	Резбови съединения (шпилки) с резба M12, съоръжени съответно с две гайки и две подложни шайби и средства срещу самоотвиване
5.2	Възможност на резбовите съединения за присъединяване на две кабелни обувки	Да	Да

### 6. Технически параметри:

№ по ред	Параметър	Изискване	Гарантирано предложение
6.1	Трайно работно напрежение, U <sub>c</sub>	min 10,8 kV	12,7 kV
6.2	Обявено напрежение, U <sub>r</sub>	min 13,5 kV	15 kV
6.3	Номинален разряден ток, I <sub>n</sub> ( 8/20 μs )	10 kA	10 kA
6.4	Силнотоков импулс (4/10 μs)	100 kA	100 kA
6.5	Разряден клас на линията	2	2
6.6	Устойчивост на ток на късо съединение	min 20 kA/0,2 s	20 kA/0,2 s
6.7	Остатъчно напрежение при номинален разряден ток I <sub>n</sub> , U <sub>res</sub>	max 42 kV	42 kV
6.8	Устойчивост на продължителен токов импулс	min 250 A/2000 μs	500 A/2000 μs

г

а

6.9	Стойност на временните пренапрежения съгласно приложение D на БДС EN 60099-4:	-	-
6.9a	с продължителност 3 s	min 14 kV	15 kV
6.9b	с продължителност 100 s	min 13 kV	14 kV
6.9c	с продължителност 7200 s	min 11,8 kV	12,5 kV
6.10	Изоляционно разстояние по повърхността	min 370 mm	555 mm
6.11	Височина без аксесоарите за присъединяване	max 350 mm	231 mm
6.12	Тегло, kg	Да се посочи	1,8 kg

**Наименование на материала:** Вентилен отвод метало-оксиден тип без искрови разрядници, 20 kV, 10 kA, клас 1

**Съкратено наименование на материала:** Вентилен отвод ZnO, 20 kV / 10 kA / клас 1

**Област:** В – Въздушни електропроводни линии СрН      **Категория:** 20 – Защита от  
Н – Трансформаторни постове      пренапрежения

**Мерна единица:** Брой      **Аварийни запаси:** Да

**Характеристика на материала:**

Метало-оксиден (ZnO) вентилен отвод без искрови разрядници, за монтиране на закрито и открито, с трайно работно напрежение min 21,6 kV, с номинален разряден ток 10 kA, с разряден клас на линията 1, с полимерна изолационната обвивка, с принадлежности (аксесоари) за свързване между тоководещи части и земя. Конфигурацията на стрехите на полимерната изолационна обвивка съответстват на изискванията на IEC/TS 60815-3.

**Използване:**

Вентилният отвод е предназначен за използване в електроразпределителни мрежи с номинално напрежение 10 kV с изолирана неутрала, със заземена през дъгогасителна бобина неутрала, със заземена през активно съпротивление неутрала или с комбинирано заземяване на неутралата през дъгогасителна бобина и активно съпротивление в райони с интензивност на мълниеносната дейност до 100 часа годишно.

**Съответствие на предлаганото изделие със стандартизационните документи:**

Вентилният отвод трябва да отговаря на приложимите български и международни стандарти, включително на посочените по-долу и на техните валидни изменения и поправки или еквиваленти:

- БДС EN 60099-4:2014 „Вентилни отводи. Част 4: Металооксидни вентилни отводи без разрядници за електрически системи за променливо напрежение (IEC 60099-4:2014)”; и
- IEC/TS 60815-3:2008 „Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 3: Polymer insulators for a.c. systems”.

**Изисквания към документацията и изпитванията:**

№ по ред	Наименование	Приложение № (или текст)
1.	Точно обозначение на типа, производителя и страна на произход	№ 2.1 (тип: AZBD_27_ /AZBD270)
2.	Техническо описание, гарантирани параметри, волт-секундна характеристика, използвани материали и принадлежности (аксесоари)	№ 2.1
3.	Чертежи с размери и надлъжен разрез	№ 2.2
4.	Протоколи от типови изпитвания на английски или български език, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	№ 2.3
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4 – заверено копие	№ 2.4
6.	Изисквания за транспортиране и манипулиране	№ 2.5
7.	Инструкции за монтиране и за експлоатация и обслужване	№ 2.5
8.	Експлоатационна дълготрайност, год.	№ 2.6 (20 год.)

*Забележка: Всички оригинални документи трябва да бъдат на български език или с превод на български език. Каталогите и изпитвателните протоколи могат да бъдат и само на английски език.*

**Технически данни:**

**1. Характеристики на работната среда:**

№ по ред	Характеристика	Стойност
1.1	Място на монтиране	На открито/закрито
1.2	Максимална околна температура	+ 40°C
1.3	Минимална околна температура	Минус 25°C
1.4	Относителна влажност	До 100 %
1.5	Надморска височина	До 1000 m
1.6	Интензивност на мълниеносната дейност	До 100 часа годишно
1.7	Други работни условия	Съгласно т. 5.4.1 от БДС EN 60099-4

**2. Параметри на електроразпределителната мрежа:**

№ по ред	Параметър	Стойност
2.1	Номинално напрежение	20 000 V
2.2	Най-високо напрежение на съоръженията	24 000 V
2.3	Най-високо напрежение на системата	21 600 V

*Handwritten signature*

*Handwritten signature and stamp*

№ по ред	Параметър	Стойност
2.4	Номинална честота	50 Hz
2.5	Брой на фазите	3
2.6	Заземяване на звездния център	<ul style="list-style-type: none"> <li>• През дъгогасителна бобина;</li> <li>• изолиран звезден център;</li> <li>• през активно съпротивление; или</li> <li>• през дъгогасителна бобина комбинирана с активно съпротивление.</li> </ul>
2.7	Максимална стойност на временните пренапрежения (при земно съединение) / максимална продължителност на временните пренапрежения:	
2.7a	1.5 заземяване през дъгогасителна бобина; или 1.6 изолиран звезден център	23,7 kV/2 часа
2.7b	1.7 заземяване през активно съпротивление; или 1.8 през дъгогасителна бобина комбинирана с активно съпротивление	21,6 kV/3 s
2.8	Изоляционно ниво:	
2.8a	Обявено издържано мълниев импулсно напрежение (върхова стойност)	125 kV
2.8b	Обявено краткотрайно (1 min) издържано напрежение с промишлена честота (50 Hz) (ефективна стойност)	50 kV
2.9	Ток на късо съединение в мястото на монтиране на вентилния отвод - максимален ток при трифазно късо съединение	15 kA

### 3. Свързване в системата и защитавани съоръжения:

№ по ред	Наименование	Изискване
3.1	Свързване в системата	Между фаза и земя
3.2	Защитавани съоръжения	<ul style="list-style-type: none"> <li>• Разпределителни трансформатори 20/0,4 kV, свързани директно към въздушна електропроводна линия (ВЛ) или чрез присъединена към ВЛ кабелна линия;</li> <li>• кабелни линии 20 kV;</li> <li>• входове на разпределителните уредби;</li> <li>• КРУ в елегазова изолационна среда (GIS)</li> </ul>

9

БАНК - 02 001

#### 4. Технически характеристики:

№ по ред	Характеристика	Изискване	Гарантирано предложение
4.1	Обявено издържано напрежение при атмосферни пренапрежения 1,2/50 $\mu$ s	min 125 kV	150 kV
4.2	Обявено издържано 1 min напрежение с промишлена честота 50 Hz при мокра изолация	min 50 kV	56 kV
4.3	Ниво на частичните разряди при 1,05 $U_c$	max 10 pC	10 pC
4.4	Материал, от който е изработено нелинейното съпротивление (варистора)	ZnO	ZnO
4.5	Материал, от който е изработена изолационната обвивка	Полимер	Полимер - Силиконов каучук
4.6	Материал, от който са изработени принадлежностите (аксесоарите)	Неръждаема стомана	Неръждаема стомана
4.7	Якост на опън	min 1 kN	15 kN
4.8	Якост на усукване	min 50 Nm	70 Nm
4.9	Якост на огъване	min 200 Nm	350 Nm

#### 5. Принадлежности (аксесоари):

№ по ред	Наименование	Изискване	Гарантирано предложение
5.1	Аксесоари за присъединяване на вентилния отвод към тоководещи части и към заземителния контур	Резбови съединения (шпилки) с резба M12, съоръжени съответно с две гайки и две подложни шайби и средства срещу самоотвиване	Резбови съединения (шпилки) с резба M12, съоръжени съответно с две гайки и две подложни шайби и средства срещу самоотвиване
5.2	Възможност на резбовите съединения за присъединяване на две кабелни обувки	Да	Да

#### 6. Технически параметри:

№ по ред	Параметър	Изискване	Гарантирано предложение
6.1	Трайно работно напрежение, $U_c$	min 21,6 kV	22 kV
6.2	Обявено напрежение, $U_T$	min 27 kV	27 kV
6.3	Номинален разряден ток, $I_n$ ( 8/20 $\mu$ s )	10 kA	10 kA
6.4	Силнотоксов импулс (4/10 $\mu$ s)	100 kA	100 kA
6.5	Разряден клас на линията	1	1

6.6	Устойчивост на ток на късо съединение	min 20 kA/0,2 s	20 kA/0,2 s
6.7	Остатъчно напрежение при номинален разряден ток $I_n, U_{res}$	max 80 kV	76,6 kV
6.8	Устойчивост на продължителен токов импулс	min 250 A/2000 $\mu$ s	250 A/2000 $\mu$ s
6.9	Стойност на временните пренапрежения съгласно приложение D на БДС EN 60099-4:	-	-
6.9a	с продължителност 3 s	min 28 kV	31 kV
6.9b	с продължителност 100 s	min 25 kV	25,3 kV
6.9c	с продължителност 7200 s	min 23,7 kV	24 kV
6.10	Изоляционно разстояние по повърхността	min 540 mm	750 mm
6.11	Височина без аксесоарите за присъединяване	max 350 mm	270 mm
6.12	Тегло, kg	Да се посочи	2,7 kg

**Наименование на материала:** Вентилен отвод метало-оксиден тип без искрови разрядници, 20 kV, 10 kA, клас 2

**Съкратено наименование на материала:** Вентилен отвод ZnO, 20 kV / 10 kA / клас 2

**Област:** В – Въздушни електропроводни линии СрН  
от

**Категория:** 20 – Защита

Н – Трансформаторни постове

пренапрежения

**Мерна единица:** Брой

**Аварийни запаси:** Да

**Характеристика на материала:**

Метало-оксиден (ZnO) вентилен отвод без искрови разрядници, за монтиране на закрито и открито, с трайно работно напрежение min 21,6 kV, с номинален разряден ток 10 kA, с разряден клас на линията 2, с полимерна изоляционната обвивка, с принадлежности (аксесоари) за свързване между тоководещи части и земя. Конфигурацията на стрехите на полимерната изоляционна обвивка съответстват на изискванията на IEC/TS 60815-3.


**Използване:**

Вентилният отвод е предназначен за използване в електроразпределителни мрежи с номинално напрежение 20 kV с изолирана неутрала, със заземена през дългогасителна бобина неутрала, със заземена през активно съпротивление неутрала или с комбинирано заземяване на неутралата през дългогасителна бобина и активно съпротивление в райони с интензивност на мълниеносната дейност над 100 часа годишно или с преобладаващ брой потребители с повишени изисквания за осигуреност на електроснабдяването.

**Съответствие на предлаганото изделие със стандартизационните документи:**

Вентилният отвод трябва да отговаря на приложените български и международни стандарти, включително на посочените по-долу и на техните валидни изменения и поправки или еквиваленти:

*[Handwritten signature]*

*[Handwritten signature]*  




- БДС EN 60099-4:2014 „Вентилни отводи. Част 4: Металооксидни вентилни отводи без разрядници за електрически системи за променливо напрежение (IEC 60099-4:2014)”; и
- IEC/TS 60815-3:2008 „Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 3: Polymer insulators for a.c. systems”.

**Изисквания към документацията и изпитванията:**

№ по ред	Наименование	Приложение № (или текст)
1.	Точно обозначение на типа, производителя и страна на произход	№ 2.1 (тип: AZC_27_ /AZC270)
2.	Техническо описание, гарантирани параметри, волт-секундна характеристика, използвани материали и принадлежности (аксесоари)	№ 2.1
3.	Чертежи с размери и надлъжен разрез	№ 2.2
4.	Протоколи от типови изпитвания на английски или български език, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	№ 2.3
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4 – заверено копие	№ 2.4
6.	Изисквания за транспортиране и манипулиране	№ 2.5
7.	Инструкции за монтиране и за експлоатация и обслужване	№ 2.5
8.	Експлоатационна дълготрайност, год.	№ 2.6 (20 год.)

Забележка: Всички оригинални документи трябва да бъдат на български език или с превод на български език. Каталозите и изпитвателните протоколи могат да бъдат и само на английски език.

**Технически данни:**

**1. Характеристики на работната среда:**

№ по ред	Характеристика	Стойност
1.1	Място на монтиране	На открито/закрито
1.2	Максимална околна температура	+ 40°C
1.3	Минимална околна температура	Минус 25°C
1.4	Относителна влажност	До 100 %
1.5	Надморска височина	До 1000 m
1.6	Интензивност на мълниеносната дейност	Над 100 часа годишно
1.7	Други работни условия	Съгласно т. 5.4.1 от БДС EN 60099-4

## 2. Параметри на електроразпределителната мрежа:

№ по ред	Параметър	Стойност
2.1	Номинално напрежение	20 000 V
2.2	Най-високо напрежение на съоръженията	24 000 V
2.3	Най-високо напрежение на системата	21 600 V
2.4	Номинална честота	50 Hz
2.5	Брой на фазите	3
2.6	Заземяване на звездния център	<ul style="list-style-type: none"> <li>• През дъгогасителна бобина;</li> <li>• изолиран звезден център;</li> <li>• през активно съпротивление; или</li> <li>• през дъгогасителна бобина комбинирана с активно съпротивление.</li> </ul>
2.7	Максимална стойност на временните пренапрежения (при земно съединение) / максимална продължителност на временните пренапрежения:	
2.7a	1.9 заземяване през дъгогасителна бобина; или 1.10 изолиран звезден център	23,7 kV/2 часа
2.7b	1.11 заземяване през активно съпротивление; или 1.12 през дъгогасителна бобина комбинирана с активно съпротивление	21,6 kV/3 s
2.8	Изоляционно ниво:	
2.8a	Обявено издържано мълниевое импулсно напрежение (върхова стойност)	125 kV
2.8b	Обявено краткотрайно (1 min) издържано напрежение с промишлена честота (50 Hz) (ефективна стойност)	50 kV
2.9	Ток на късо съединение в мястото на монтиране на вентилния отвод - максимален ток при трифазно късо съединение	15 kA

## 3. Свързване в системата и защитавани съоръжения:

№ по ред	Наименование	Изискване
3.1	Свързване в системата	Между фаза и земя
3.2	Защитавани съоръжения	<ul style="list-style-type: none"> <li>• Разпределителни трансформатори 20/0,4 kV, свързани директно към въздушна електропроводна линия (ВЛ) или чрез присъединена към ВЛ кабелна линия;</li> <li>• кабелни линии 20 kV;</li> <li>• входове на разпределителните уредби;</li> </ul>

		• КРУ в элегазова изолационна среда (GIS)
--	--	---

#### 4. Технически характеристики:

№ по ред	Характеристика	Изискване	Гарантирано предложение
4.1	Обявено издържано напрежение при атмосферни пренапрежения 1,2/50 $\mu$ s	min 125 kV	150 kV
4.2	Обявено издържано 1 min напрежение с промишлена честота 50 Hz при мокра изолация	min 50 kV	56 kV
4.3	Ниво на частичните разряди при 1,05 U <sub>c</sub>	max 10 pC	10 pC
4.4	Материал, от който е изработено нелинейното съпротивление (варистор)	ZnO	ZnO
4.5	Материал, от който е изработена изолационната обвивка	Полимер	Полимер - Силиконов каучук
4.6	Материал, от който са изработени принадлежностите (аксесоарите)	Неръждаема стомана	Неръждаема стомана
4.7	Якост на опън	min 1 kN	1 kN
4.8	Якост на усукване	min 50 Nm	50 Nm
4.9	Якост на огъване	min 200 Nm	250 Nm

#### 5. Принадлежности (аксесоари):

№ по ред	Наименование	Изискване	Гарантирано предложение
5.1	Аксесоари за присъединяване на вентилния отвод към тоководещи части и към заземителния контур	Резбови съединения (шпилки) с резба M12, съоръжени съответно с две гайки и две подложни шайби и средства срещу самоотвиване	Резбови съединения (шпилки) с резба M12, съоръжени съответно с две гайки и две подложни шайби и средства срещу самоотвиване
5.2	Възможност на резбовите съединения за присъединяване на две кабелни обувки	Да	Да

*Handwritten signature*

*Handwritten signature*


*Handwritten signature and stamp*


6. Технически параметри:

№ по ред	Параметър	Изискване	Гарантирано предложение
6.1	Трайно работно напрежение, $U_C$	min 21,6 kV	22 kV
6.2	Обявено напрежение, $U_T$	min 27 kV	27 kV
6.3	Номинален разряден ток, $I_n$ ( 8/20 $\mu$ s )	10 kA	10 kA
6.4	Силнотокков импулс (4/10 $\mu$ s)	100 kA	100 kA
6.5	Разряден клас на линията	2	2
6.6	Устойчивост на ток на късо съединение	min 20 kA/0,2 s	20 kA/0,2 s
6.7	Остатъчно напрежение при номинален разряден ток $I_n$ , $U_{res}$	max 75 kV	75 kV
6.8	Устойчивост на продължителен токов импулс	min 250 A/2000 $\mu$ s	500 A/2000 $\mu$ s
6.9	Стойност на временните пренапрежения съгласно приложение D на БДС EN 60099-4:	-	-
6.9a	с продължителност 3 s	min 28 kV	28,5 kV
6.9b	с продължителност 100 s	min 26 kV	26 kV
6.9c	с продължителност 7200 s	min 23,7 kV	23,7 kV
6.10	Изоляционно разстояние по повърхността	min 540 mm	760 mm
6.11	Височина без аксесоарите за присъединяване	max 425 mm	276 mm
6.12	Тегло, kg	Да се посочи	2,7 kg

9

17






# dervasil


## 2008-2010

Medium voltage networks  
Lightning arresters & Insulators



Степне group

ПРОЦОРЕНА




## Our experience

With 20 years know-how in the field of Medium Voltage network protection, DERVASIL designs and manufactures lightning arresters with zinc oxide varistors and synthetic housings.

## Our products


DERVASIL offers:

- » A range of latest generation arresters:
  - 5 kA or 10 kA arresters with fault indicator or disconnecter.
  - Arresters for power follow current breaking.
  - D.C. voltage arresters.
- DERVASIL arresters do not have internal spark gaps. They exhibit stable characteristics, with practically constant, very short response times (30 to 50 ns), and better behaviour under pollution.
- Direct injection of Silicone Rubber ensures both absolute sealing, exceptional resistance to pollution and excellent behaviour without explosion in case of short-circuit
- They have been tested in accordance with the latest version of IEC Standard 60099-4.
- » New range of composite insulators: suspension insulators, tension insulators and support insulators.




## Our R & D department

DERVASIL has comprehensive calculation and testing equipment for the design of lightning arresters. Our facilities are available to customers for specific applications.



## Our quality and environmental system

DERVASIL is ISO 9001 and ISO 14001 system certified. Our production process is approved by EDF and incorporates all routine tests required by IEC Standard 60099-4.



ДЕРВАСИЛ  
ДЕРВАСИЛ

Handwritten signature and a circular stamp containing the text "BAK-02" OCH

# HIGH RELIABILITY ARRESTERS

## AZB / EZB / AZC SERIES

### Polymeric Glass Filled Tube

Direct injection of Silicone Rubber over the internal module. This ensures both sealing of the varistor/tube interface and the geometry of external insulation to guarantee length of leakage distance.

Polymeric Glass Filled Tube, up-sized greatly to withstand service and mounting mechanical strength requirements.


#### Use of Silicone Rubber:

- The stability of the SiO molecule gives to Silicone Rubber excellent inherent resistance to UV radiation, pollution and flame without the need for of special additives.
- When new, Silicone material is already very hydrophobic. It has moreover the property of restoring this hydrophobic characteristic after strong electrical discharge activity due to salt fogs and pollution.

The contacts between metal oxide varistors are provided by spring washers, which are specially designed to distribute lightning current impulses on the varistor surface and to increase arrester energy capability.

Identification and traceability ensured by engraved marking.

Substantial connecting electrodes to fix power arc feet during internal short-circuit and thus to avoid arrester breaking down.



ВЯНОСОРИГЕНАЈА



# Application Guide

This guide provides recommendations for selection and application of DERVASIL lightning arresters to be used for overvoltage protection.

## DERVASIL Lightning Arrester Technology:

DERVASIL lightning arrester is a combination of zinc oxide varistors, internal fiber glass structure and Silicone rubber housing. DERVASIL offers two technologies.

### AZB / EZB / AZC series:

Zinc oxide varistors are connected in series with aluminium electrodes into polymeric tube. The Silicone rubber is directly injected into the tube and over the zinc oxide varistor stack. This ensures both sealing and geometry of external insulation. This construction provides both absolute sealing, exceptional resistance to pollution and excellent behaviour without explosion in case of short-circuits.

### AZBD / EZBD series:

Zinc oxide varistors are connected in series with aluminium electrodes to form a complete stack. This stack is tightly wrapped with glass filament impregnated with epoxy resin. This assembly is cured to form a rigid and mechanically strong rod. The Silicone rubber is directly injected over this rod and over aluminium electrodes to ensure both sealing and geometry of external insulation. This construction reduces external dimensions and weight and improves mechanical performance of lightning arresters.

## Basic characteristics of DERVASIL Lightning Arrester for three phase system

### Nominal discharge current $I_n$ and line discharge class:

In IEC 600099-4 the energy absorption capability of lightning arrester is linked to the nominal discharge current  $I_n$  and to the line discharge class. As a general rule, the following values of  $I_n$  and line class are suitable:

In system where line distances between arresters are below 5 km or for areas with low ground flash density and low earth resistance, 5 kA lightning arresters may be sufficient. For areas with high lightning flash density or high earth resistance, 10 kA class 1 lightning arrester are preferable.


For better protection level or for important installations 10 kA class 2 lightning arrester are recommended.

For specific applications as cable or capacitor bank protection, DERVASIL experts can determine good choice.


### Continuous Operating Voltage $U_c$ :

$U_c$  is the maximum permissible voltage which may be continuously applied between the lightning arrester terminals. As a general rule,  $U_c$  should be:

System with solidly grounded neutral  
 $U_c$  higher than  $0.58 \cdot U_n$  max system




System with low ohmic neutral  
 $U_c$  higher than  $0.87 \cdot U_n$  max system





System with high impedance grounded,  
compensated or ungrounded neutral  
 $U_c$  higher than  $U_n$  max system

$Z > 40$  ohms  
ou  
 $Z = \text{infini}$



### Rated Voltage $U_r$ :

$U_r$  is the maximum power frequency temporary voltage applied for 10s for which the lightning arrester is calculated in order to pass operating duty test (IEC 60099-4 standard).

$U_r$  is calculated by DERVASIL for each lightning arrester.

### Commonly Applied Voltage Rating of Dervasil Arrester (kV)

System Line to Line Voltage (kV)		Solidly Grounded Neutral	Low Ohmic Neutral	High impedance, compensated or Underground Neutral
Nominal	Maximum			
6.9	7.25	6	9	9
10	11	9	12	15
10	11.8	9	12	15
10.6	12	9	12	15
11	12	9	12	15
11.4	12	9	12	15
12	13.2	9	15	18
12.6	13.8	9	15	18
13.4	15	9	15	18
15	16.5	12	18	21
15	18	12	18	21
15.4	17.5	12	18	21
20	22	15	24	27
22	24	18	27	30
23	24.5	18	27	30
25	27.5	21	30	33
30	33	24	36	42
33	36	27	42	...
34.5	36.5	27	42	...

### Lightning Impulse Protective Level


The lightning impulse protective level (LIPL) of lightning arrester is the maximum residual voltage at nominal discharge current  $I_n$ .

When lightning impulse wave reaches equipment to be protected, current discharge flows through lightning arrester and connecting cables.


Overtension on equipment is the sum of lightning arrester residual voltage and induced voltage in cables. To warranty good protection, Protective Level of lightning arrester must be much lower than lightning impulse withstand voltage of the equipment.

To take into account live ageing of insulation material, we recommend:

LIPL lower than  $0.6 \cdot U_{IL}$ .



Following Basic Insulation Levels (BIL) are defined by IEC 60071-1 according nominal voltage of the system.



Un (kV)	3.6	7.2	12	17.5	24	36
BIL (kV)	40	60	75	95	125	170
LIPL of Lightning Arrester	24	36	45	57	75	102

## Basic characteristics of DERVASIL Lightning Arrester for DC voltage

Continuous Operating Voltage  $U_{cdc}$  :

$U_{cdc}$  is the maximum permissible voltage which may be continuously applied between the lightning arrester terminals.

European standard EN 50163 defines several voltage values:

$U_{max1}$  : Highest permanent voltage

$U_{max2}$  : Highest non-permanent voltage present for maximum 300s

As general rules we recommend  $U_{cdc}$  higher than  $U_{max2}$

Following table gives  $U_{max1}$ ,  $U_{max2}$ , recommended  $U_{cdc}$  and lightning arrester type for most frequent DC network :

Nominal Voltage (V)	$U_{max1}$ (V)	$U_{max2}$ (V)	Recommended $U_{cdc}$ (V)	Recommended Lightning Arrester
600	720	770	1000	AZE 010T
750	900	950	1200	AZE 012T
1500	1800	1950	2400	AZE 020T
3000	3600	3900	4000	AZE 040T

БЕЛГОСООБЩЕСТВА

Handwritten signature and stamp.



# A C medium voltage network protection 10 kA arrester - Class 2

## AZC series General characteristics

Tested in accordance with I.E.C 60099-4 standard.



Zinc oxide varistors.

Silicone rubber housing.

Outdoor and indoor use.



High resistance to vibrations.

High resistance to vandalism.



## Physical characteristics

Arrester type	Leakage distance (mm)	Height H (mm)	Unit weight (kg)	Insulation withstand of housing (kV)		Mounting clearances	
				Lightning impulse 1.2/50 $\mu$ s	50 Hz 60s Wet	A min (mm)	B min (mm)
AZC_03	400	185	1.2	100	37	110	130
AZC_06	400	185	1.4	100	37	110	130
AZC_09	400	185	1.5	100	37	140	160
AZC_12	400	185	1.6	100	37	140	160
AZC_15	555	231	1.8	120	46	180	200
AZC_18	555	231	2.1	120	46	180	200
AZC_21	710	254	2.3	130	51	240	260
AZC_24	710	254	2.4	130	51	240	260
AZC_27	760	276	2.7	150	56	270	290
AZC_30	1 000	345	3.0	190	70	320	340
AZC_33	1 000	345	3.1	190	70	340	360
AZC_39	1 000	345	3.2	190	70	340	360
AZC_42	1 000	345	3.4	190	70	360	380




# A.C medium voltage network protection 10 kA arrester - Class 2



## Electrical and mechanical characteristics

Nominal discharge current:	10 kA 8/20 $\mu$ s impulse
Line discharge class:	2
High current withstand:	2 x 100 kA 4/10 $\mu$ s impulses
Long duration current withstand:	18 x 500 A 2000 $\mu$ s impulses
Energy absorption capacity	5.5 kJoule/kV of $U_c$ for 2 x 2000 $\mu$ s impulses
	4.6 kJoule/kV of $U_c$ for one 4/10 $\mu$ s impulse
Rated frequency	48 to 62 Hz
Service temperature	- 40°C to + 40°C (+ 60°C short duration)
Specified continuous load (SCL)	100 N.m
Specified short term load (SSL)	250 N.m
Max tension strength	1 kN
Max torsion strength	50 N.m
Pollution area I.E.C 60815	3
Short circuit rating after over voltage failure as Appendix 0 of I.E.C 60099-4	20000 A for 0.2s / 600 A for 1s

## Temporary over voltage capability



AZC line arrester does not have spark gaps in series. The zinc oxide varistors are designed to withstand the continuous phase to ground voltage of network. They are capable of bearing increased operational voltages over a long period. The temporary over voltage characteristics give the duration T and corresponding TOV with respect to continuous voltage  $U_c$ .

The curve E = 0 is valid for arresters without energy preloading. The other curve is valid for arresters, which are already absorbed impulses corresponding to their maximum energy absorption capability.

## Protective characteristics

Arrester type	$U_r$ Rated voltage (kVrms)	$U_c$ Continuous operating voltage (kVrms)	Residual voltage wave 1/4 $\mu$ s at 10 kA (kV)	Residual voltage wave 8/20 $\mu$ s (kV)					Residual voltage wave 30/80 $\mu$ s 125 A - 500 A (kV)	
				2.5 kA	5 kA	10 kA Nominal discharge current	20 kA	40 kA	7.8	8.5
AZC_03	3	2.55	11.7	9.3	9.9	10.6	11.9	13.8	7.8	8.5
AZC_06	6	5.1	18.7	14.9	16.0	17.0	19.1	22.1	12.6	13.6
AZC_09	9	8.4	29.8	23.8	25.4	27.1	30.4	35.2	20.0	21.7
AZC_12	12	10.2	36.9	29.4	31.4	33.5	37.6	43.6	24.7	26.8
AZC_15	15	12.7	48.0	38.3	40.9	42.0	49.0	56.7	32.2	34.8
AZC_18	18	15.3	55.0	43.9	46.9	50.0	56.2	65.0	36.9	40.0
AZC_21	21	17.5	66.1	52.7	56.4	60.1	67.5	78.1	44.4	48.0
AZC_24	24	19.5	73.2	58.3	62.4	66.5	74.7	86.5	49.1	53.1
AZC_27	27	22.0	84.3	67.2	71.9	75.0	86.0	99.6	56.6	61.2
AZC_30	30	24.4	91.3	72.8	77.9	83.0	93.2	107.9	61.3	66.3
AZC_33	33	27.0	102.4	81.7	87.4	93.1	104.6	121.0	68.7	74.4
AZC_39	39	32.0	120.6	96.2	102.8	109.6	123.1	142.5	80.9	87.6
AZC_42	42	35.0	127.0	101.0	108.0	115.5	129.2	149.6	84.9	91.9

BRNO COPEPWAJA

15

5

ESPANOL

Basic configurations	34
Optional bracket	35
Application examples	35
Surge counter with leakage current meter	36
Insulating cap	37

ВЕРНО СОПРОВОЖДАЕТСЯ



ВЕРНО СОПРОВОЖДАЕТСЯ

*[Handwritten signature]*

ВЕРНО СОПРОВОЖДАЕТСЯ





Basic configurations





Bracket	L (mm)
EZX 1	100
EZX 2	150
EZX 3	210


Arrester rated voltage Ur (kVrms)	3	6	9	12	15	18	21	24	27	30	33	36
Bracket reference	EZX 1			EZX 2			EZX 3					




Arrester rated voltage Ur (kVrms)	3	6	9	12	15	18	21	24	27	30	33	36
Bracket reference	AZ 50 50											




Arrester rated voltage Ur (kVrms)	3	6	9	12	15	18	21	24	27	30	33	36
Bracket reference	AZPTR											



Optional bracket



Shown with AZS-2 arrester





Bracket AZNEMA



Available options with basic configurations including EZX, AZ 50-50 or AZPTR brackets.

Application examples



Vertical position on transformer tank with 2 AZPTR brackets



Vertical position on cross arm with AZPTR and AZNEMA brackets




Horizontal position on transformer support with AZ 50 - 50 brackets



ВЫПОЛНЕНИЕ


Horizontal position with AZ 50 - 50 brackets



## ZC-B1M Surge counter with leakage current meter for Dervasil lightning arrester

### Technical description




ZC-B1M Surge counter is a device to record the number of lightning and switching surge discharges. ZC-B1M Surge counter can be used with class 1 & 2 DERVASIL lightning arresters and also similar arresters of other manufacturers. Number of discharges is recorded by 5-digit cyclometer and readings can be taken through the inspection window. Leakage current of lightning arrester is measured by 0-3mA scale reading milliammeter. ZC-B1M Surge counter does not need any auxiliary power supply



### Performance

ZC-B1M Surge counter operates on lightning impulse current (8/20 $\mu$ s wave) more than 100A and can operate perfectly if the interval of multiple lightning strokes is more than 0.2s. Potential across the ZC-B1M Surge counter is less than 50V crest under normal operating conditions. Residual voltage at 10kA(8/20 $\mu$ s wave) of the ZC-B1M Surge counter is less than 3 kV and has negligible effect on the protection level of the lightning arrester. Discharge current capability is 100kA (4/10 $\mu$ s wave) and 1000A (2ms rectangular wave)

### Dimensions




### Installation

ZC-B1M Surge counter is connected between the earth terminal of the lightning arrester and the earth. It should be mounted as close as possible to the lightning arrester and length of connecting wires should be as short as possible. The connecting wire used between surge counter and lightning arrester should be an insulated wire with impulse withstand voltage more than 5 kV.

ВІСНОВОК ПРАКТИКА







# Insulating cap for Dervasil lightning arrester

## Technical description

The Dervasil insulating cap (Polyamid molded) is especially designed to feet on lightning arrester.




Reference : CAP M10



*M*  
ВЕРНО СОПРИБЕЖАЛА

*[Signature]*  
37

*[Handwritten mark]*



*[Handwritten mark]*



This documentation is not as per agreement.  
Items represented are proposed while stock lasts.  
DERVASIL reserve the right to stop production  
or modify specifications without prior notice.

**Non-contractual pictures**

ВЕРНО СОПРЕГОВОРЕНА

*[Handwritten signature]*  
Com ST


*[Handwritten signature]*  
*[Handwritten signature]*  
*[Circular stamp]*

Distributed by :

Orion Pharma, rue de Valenciennes 12000 Saint-Denis de la Réunion, France  
Téléphone : 00262 298 33 33 33 (0) 29 77 33 33  
E-mail : [orion@orion-pharma.com](mailto:orion@orion-pharma.com)

*[Handwritten signature]*


Nicotine group



# dervasil


## 2008-2010

Medium voltage networks  
Lightning arresters & Insulators




same group





## Our experience


With 20 years know-how in the field of Medium Voltage network protection, DERVASIL designs and manufactures lightning arresters with zinc oxide varistors and synthetic housings.



## Our products

DERVASIL offers:

- » A range of latest generation arresters:
  - 5 kA or 10 kA arresters with fault indicator or disconnecter.
  - Arresters for power follow current breaking.
  - D.C. voltage arresters.
- DERVASIL arresters do not have internal spark gaps. They exhibit stable characteristics, with practically constant, very short response times (30 to 50 ns), and better behaviour under pollution.
- Direct injection of Silicone Rubber ensures both absolute sealing, exceptional resistance to pollution and excellent behaviour without explosion in case of short-circuit
- They have been tested in accordance with the latest version of IEC Standard 60099-4.
- » New range of composite insulators: suspension insulators, tension insulators and support insulators.



## Our R & D department

DERVASIL has comprehensive calculation and testing equipment for the design of lightning arresters. Our facilities are available to customers for specific applications.



## Our quality and environmental system

DERVASIL is ISO 9001 and ISO 14001 system certified. Our production process is approved by EDF and incorporates all routine tests required by IEC Standard 60099-4.



БЪРНО СЪУПЪРНИКА  
*[Handwritten signature]*

*[Handwritten signature]*  
GAMORD  
*[Handwritten signature]*

# Application Guide

This guide provides recommendations for selection and application of DERVASIL lightning arresters to be used for overvoltage protection.

## DERVASIL Lightning Arrester Technology:

DERVASIL Lightning arrester is a combination of zinc oxide varistors, internal fiber glass structure and Silicone rubber housing. DERVASIL offers two technologies.

### AZB / EZB /AZC series:

Zinc oxide varistors are connected in series with aluminium electrodes into polymeric tube. The Silicone rubber is directly injected into the tube and over the zinc oxide varistor stack. This ensures both sealing and geometry of external insulation. This construction provides both absolute sealing, exceptional resistance to pollution and excellent behaviour without explosion in case of short-circuits.

### AZBD / EZBD series:

Zinc oxide varistors are connected in series with aluminium electrodes to form a complete stack. This stack is tightly wrapped with glass filament impregnated with epoxy resin. This assembly is cured to form a rigid and mechanically strong rod. The Silicone rubber is directly injected over this rod and over aluminium electrodes to ensure both sealing and geometry of external insulation. This construction reduces external dimensions and weight and improves mechanical performance of lightning arresters.

## Basic characteristics of DERVASIL Lightning Arrester for three phase system

### Nominal discharge current $I_n$ and line discharge class:

In IEC 600099-4 the energy absorption capability of lightning arrester is linked to the nominal discharge current  $I_n$  and to the line discharge class. As a general rule, the following values of  $I_n$  and line class are suitable:

In system where line distances between arresters are below 5 km or for areas with low ground flash density and low earth resistance, 5 kA lightning arresters may be sufficient. For areas with high lightning flash density or high earth resistance, 10 kA class 1 lightning arrester are preferable.


For better protection level or for important installations 10 kA class 2 lightning arrester are recommended.

For specific applications as cable or capacitor bank protection, DERVASIL experts can determine good choice.


### Continuous Operating Voltage $U_c$ :

$U_c$  is the maximum permissible voltage which may be continuously applied between the lightning arrester terminals. As a general rule,  $U_c$  should be:

System with solidly grounded neutral  
 $U_c$  higher than  $0.58 \cdot U_n$  max system




System with low ohmic neutral  
 $U_c$  higher than  $0.87 \cdot U_n$  max system



System with high impedance grounded,  
 compensated or ungrounded neutral  
 $U_c$  higher than  $U_n$  max system

$Z > 40 \text{ ohms}$   
 ou  
 $Z = \text{infini}$



### Rated Voltage $U_r$ :

$U_r$  is the maximum power frequency temporary voltage applied for 10s for which the lightning arrester is calculated in order to pass operating duty test (IEC 60099-4 standard).  
 $U_r$  is calculated by DERVASIL for each lightning arrester.

### Commonly Applied Voltage Rating of Dervasil Arrester (kV)

System Line to Line Voltage (kV)		Solidly Grounded Neutral	Low Ohmic Neutral	High impedance, compensated or Underground Neutral
Nominal	Maximum			
6.9	7.25	6	9	9
10	11	9	12	15
10	11.8	9	12	15
10.6	12	9	12	15
11	12	9	12	15
11.4	12	9	12	15
12	13.2	9	15	18
12.6	13.8	9	15	18
13.4	15	9	15	18
15	16.5	12	18	21
15	18	12	18	21
15.4	17.5	12	18	21
20	22	15	24	27
22	24	18	27	30
23	24.5	18	27	30
25	27.5	21	30	33
30	33	24	36	42
33	36	27	42	...
34.5	36.5	27	42	...

### Lightning Impulse Protective Level

The lightning impulse protective level (LIPL) of lightning arrester is the maximum residual voltage at nominal discharge current  $I_n$ .

When lightning impulse wave reaches equipment to be protected, current discharge flows through lightning arrester and connecting cables.

Overvoltage on equipment is the sum of lightning arrester residual voltage and induced voltage in cables. To warranty good protection, Protective Level of lightning arrester must be much lower than lightning impulse withstand voltage of the equipment. To take into account live ageing of insulation material, we recommend:


LIPL lower than  $0.6 \cdot BIL$

БСТННОСОРЕПННАТА

34



Following Basic Insulation Levels (BIL) are defined by IEC 60071-1 according nominal voltage of the system.



Un (kV)	3.6	7.2	12	17.5	24	36
BIL (kV)	40	60	75	95	125	170
LIPL of Lightning Arrester	24	36	45	57	75	102

## Basic characteristics of DERVASIL Lightning Arrester for DC voltage

Continuous Operating Voltage  $U_{cdc}$  :

$U_{cdc}$  is the maximum permissible voltage which may be continuously applied between the lightning arrester terminals.

European standard EN 50163 defines several voltage values:

$U_{max1}$  : Highest permanent voltage

$U_{max2}$  : Highest non-permanent voltage present for maximum 300s

As general rules we recommend  $U_{cdc}$  higher than  $U_{max2}$

Following table gives  $U_{max1}$ ,  $U_{max2}$ , recommended  $U_{cdc}$  and lightning arrester type for most frequent DC network :

Nominal Voltage (V)	$U_{max1}$ (V)	$U_{max2}$ (V)	Recommended $U_{cdc}$ (V)	Recommended Lightning Arrester
600	720	770	1000	AZE 010T
750	900	950	1200	AZE 012T
1500	1800	1950	2400	AZE 020T
3000	3600	3900	4000	AZE 040T

БЕЛГОСОПРЕДПРИЯТИЯ

7  
7  
7



# A.C medium voltage network protection 10 kA arrester - Class 1

## AZBD series General characteristics

Tested in accordance with I.E.C 60099-4 standard.

Zinc oxide varistors.

Silicone rubber housing.



Outdoor and indoor use.

High resistance to vibrations.

High resistance to vandalism.




High mechanical resistance.

Can be used as cable support.



## Physical characteristics

Arrester type	Leakage distance (mm)	Height H (mm)	Unit weight (kg)	Insulation withstand of housing (kV)		Mounting clearances	
				Lightning impulse 1.2/50 $\mu$ s	50 Hz 60s Wet	A min (mm)	B min (mm)
AZBD_03	230	140	1.2	100	37	110	130
AZBD_06	230	140	1.4	100	37	110	130
AZBD_09	315	170	1.5	100	37	140	160
AZBD_12	375	180	1.6	100	37	140	160
AZBD_15	500	195	1.8	120	46	180	200
AZBD_18	540	230	2.1	120	46	180	200
AZBD_21	660	245	2.3	130	51	240	260
AZBD_24	660	245	2.4	130	51	240	260
AZBD_27	750	270	2.7	150	56	270	290
AZBD_30	830	305	3.0	190	70	320	340
AZBD_33	960	320	3.1	190	70	340	360
AZBD_36	960	320	3.2	190	70	340	360
AZBD_39	1 050	380	3.2	190	70	340	360
AZBD_42	1 050	360	3.2	190	70	360	380




# A.C medium voltage network protection 10 kA arrester - Class 1



## Electrical and mechanical characteristics

Nominal discharge current:	10 kA 8/20 $\mu$ s impulse
Line discharge class:	1
High current withstand:	2 x 100 kA 4/10 $\mu$ s impulses
Long duration current withstand:	18 x 250 A 2000 $\mu$ s impulses
Energy absorption capacity	1.8 kJoule/kV of $U_c$ for one x 2000 $\mu$ s impulse 4.6 kJoule/kV of $U_c$ for one 4/10 $\mu$ s impulse
Rated frequency	48 to 62 Hz
Service temperature	- 40°C to + 40°C (+ 60°C short duration)
Specified continuous load (SCL)	200 N.m
Specified short term load (SSL)	350 N.m
Max tension strength	15 kN
Max torsion strength	70 N.m
Pollution area I.E.C 60815	3
Short circuit rating after over voltage failure as Appendix 0 of I.E.C 60099-4	20000 A for 0.2s / 600 A for 1s

## Temporary over voltage capability



AZBD line arrester does not have spark gaps in series. The zinc oxide varistors are designed to withstand the continuous phase to ground voltage of network. They are capable of bearing increased operational voltages over a long period. The temporary over voltage characteristics give the duration T and corresponding TOV with respect to continuous voltage  $U_c$ .

The curve  $E = 0$  is valid for arresters without energy preloading. The other curve is valid for arresters, which are already absorbed impulses corresponding to their maximum energy absorption capability.

## Protective characteristics


Arrester type	$U_r$ Rated voltage (kVrms)	$U_c$ Continuous operating voltage (kVrms)	Residual voltage wave 1/4 $\mu$ s at 10 kA (kV)	Residual voltage wave 8/20 $\mu$ s (kV)					Residual voltage wave 30/80 $\mu$ s 125 A 500 A (kV)	
				2.5 kA	5 kA	10 kA Nominal discharge current	20 kA	40 kA	125 A	500 A
AZBD 03	3	2.55	11.1	8.7	9.3	10.1	11.3	13.6	7.2	7.8
AZBD 06	6	5.1	22.8	17.6	19.0	20.7	23.2	26.9	14.7	15.9
AZBD 09	9	8.4	36.9	28.5	30.8	33.5	37.5	43.6	23.8	25.8
AZBD 12	12	10.2	40.9	31.6	34.2	37.2	41.7	48.4	26.4	28.6
AZBD 15	15	12.7	48.0	37.1	40.1	43.6	48.8	56.7	31.0	33.6
AZBD 18	18	15.3	64.6	49.9	54.0	58.7	65.7	76.3	42.7	46.3
AZBD 21	21	17.5	73.2	56.5	61.2	63	74.5	86.5	47.2	51.2
AZBD 24	24	19.5	73.2	56.5	61.2	63	74.5	86.5	47.2	51.2
AZBD 27	27	22.0	84.3	65.1	70.5	76.6	85.8	99.6	54.4	59.0
AZBD 30	30	24.4	102.4	79.1	85.7	93.1	104.3	121.0	66.1	71.7
AZBD 33	33	27.0	102.4	79.1	85.7	93.1	104.3	121.0	66.1	71.7
AZBD 36	36	29.0	109.5	84.6	91.5	99.5	111.4	129.4	70.6	76.6
AZBD 39	39	32.0	109.5	84.6	91.5	99.5	111.4	129.4	70.6	76.6
AZBD_42_	42	35.0	127.6	98.6	106.7	116.0	129.9	150.8	82.4	89.3

ЗАПИСЬ КОМПЕТЕНЦИЙ


*[Handwritten signature]*



## Optional bracket



Shown with AZB--2 arrester





Bracket AZNEMA



Available options with basic configurations including EZX, AZ 50-50 or AZPTR brackets.

## Application examples



Vertical position on transformer tank with 2 AZPTR brackets




Vertical position on cross arm with AZPTR and AZNEMA brackets



Horizontal position on transformer support with AZ 50 - 50 brackets



Horizontal position with AZ 50 - 50 brackets







# Insulating cap for Dervasil lightning arrester

## Technical description

The Dervasil insulating cap (Polyamid molded) is especially designed to feet on lightning arrester.



Reference : CAP M10

BRPH COPIEPIKAJA

37

# Lightning arrester specification



## QUESTIONS REGARDING THE NETWORK

• Rated Voltage ..... Un = ..... Kv

• Monophased  Biphased  Triphased

• How is the neutral?  
 Solidly grounded  
 Distributed  
 High resistor grounded or compensated  
 Isolated

• Network type  
Urban  Yes  No  
Rural  Yes  No  
Percentage cables / Over head lines = .....  
Earth line  Yes  No

## APPLICATION QUESTIONNAIRE

• Calculation according different types of network  
Uc = lightning arrester maximum operating voltage  
Un = system nominal voltage

• Solidly grounded neutral ..... Uc = 0,58 x 1,1 x Un  
• Low ohmic neutral ..... Uc = 0,87 x 1,1 x Un  
• High impedance grounded or compensated or isolated neutral ..... Uc = 1,1 x Un

• Arrester Class  
 In = 5kA  
 In = 10kA class 1  
 In = 10kA class 2

Residual voltage at In... Ures = ..... kV  
Temporary over voltage withstand.....  
TOV = ..... kV  
Duration..... = ..... s

• Leakage distance ..... d = ..... mm


• Accessories  
 Disconnecter  
 Fault indicator  
 Surge counter

ВЕРНО СОВМЕЩАЕТСЯ

43

13

k = Surtension Temporaire / Uc AZC type  
TOV / Uc



Energie absorbée/ Preloaded Energy =  
capacité max/ max Capability

T (s) Durée de la Surtension  
TOV duration

9


ВРЕМЯ СОРБЦИИ

*[Handwritten signature]*

*[Handwritten signature]*

*B*

$k = \text{Surtension Temporaire} / U_c$   
 $\text{TOV} / U_c$   
**TOV CURVES FOR AZBD**



*S*


БСРНО СОРЕТРЕАЖА

*[Handwritten signature]*

ТАК-ОП ДИП  
*[Handwritten signature]*



Declaration constituent material



**dervasil**

**Materials Data Sheet**

Product	Lightning Arrester	AZBD - AZC
Date	15/04/2011	
Version	1	

Composition part	Material group	Materials	% in mass	End of live
------------------	----------------	-----------	-----------	-------------

Active Part				
Varistors	Ceramic	ZnO	51,0%	Recycling Incineration
Wrapping Tube	Plastics	Epoxy	3,9%	process

Housing and filling				
	Polymer	Silicone	22,7%	Incineration process

Termination / Conductors				
Connecting electrodes	Aluminium alloy		10,6%	Recycling
End Cap Terminals	Stanless steel	304	7,8%	Recycling

Packaging				
	Cardboard	Cardboard	3,9%	Recycling

100,0%

БЕЛГОСРЕДПРОВАД

AZBD - AZC

Декларация за съответствие на материала



Данни за материалите

Продукт	Вентилен отвод	AZBD - AZC
Дата	15/04/2011	
Версия	1	

Съставна част	Група материали	Материали	% в маса	Край на жизнен цикъл
---------------	-----------------	-----------	----------	----------------------

Активна част				Процес на рециклиране и изгаряне
Варистори	Керамични	ZnO	51.0 %	
Облицована тръба	Пластмасови	Епоксидна	3.9 %	

Корпус и пълнеж				Процес на изгаряне
	Полимер	Силикон	22.7 %	

Клема / Проводници				Рециклиране
Свързващи електроди	Алуминиева сплав		10.6 %	
Краен цокъл на клемите	Неръждаема стомана	304	7.8 %	

Опаковка				Рециклиране
	Картон	Картон	3.9 %	

100 %

AZBD - AZC



## DECLARATION DECLARATION

CLIENT/CUSTOMER : CEZ

Nous, DERVASIL  
We,

2 route de POPENOT, 42800 ST JOSEPH (France)

Déclarons sous notre seule responsabilité, que les produits :  
*declare under our sole responsibility that the products :*

**PARAFOUDRES**  
**LIGHTNING ARRESTERS types:**

**AZBD\_27\_ / AZBD 270**

auxquels se réfère cette déclaration,  
*to which this declaration relates*

sont conformes à la (aux) norme(s) ou autres(s) documents normatif(s) :  
*correspond to required products for tender of CEZ and are in conformity with the following standard(s) or other normative document(s) :*

EN 60099-4, IEC/TS 60815-3

St JOSEPH, le/The 16/07/2013

M.DZIRI Responsable Qualité Environnement  
Quality Environment Manager

Nom & signature du signataire autorisé  
*Name and signature or equivalent marking of authorized person*

C. GAZZOLA

Directeur  
General Manager

Nom & signature du signataire autorisé  
*Name and signature or equivalent marking of authorized person*

Cette Déclaration de Conformité est conforme à la norme européenne EN45014 "Critères généraux pour les déclarations de conformité des fournisseurs". Les bases pour ces critères ont été trouvées dans la documentation internationale, et particulièrement dans : ISO/IEC Guide 22, 1982 "Information sur les déclarations de conformité des fabricants avec les normes et autres spécifications techniques".

This Declaration of Conformity is suitable to the European Standard EN 45014 "General criteria for supplier's declaration of conformity". The basis for the criteria has been found in international documentation, particularly in ISO/IEC Guide 22, 1982 "Information on manufacturer's declaration of conformity with standards or other technical specifications".

DECLARATION OF CONFORMITY





## ДЕКЛАРАЦИЯ

**КЛИЕНТ: CEZ**

Ние, DERVASIL  
2 route de POPENOT, 42800 ST JOSEPH (Франция)

Декларираме на своя собствена отговорност, че продуктите:



**Вентилни отдоди тип AZBD\_27\_/AZBD 270**

за които се отнася тази декларация,

Отговарят на изискваните продукти за търга на ЧЕЗ и са в съответствие със следните стандарти или други нормативни документи:

EN 60099-4, IEC/TS 60815-3

St JOSEPH, 16/07/2013

BAK-02  
2013  
CAMOROS



dervasil



**DECLARATION  
DECLARATION**

**CLIENT/CUSTOMER : CEZ**

Nous, DERVASIL  
*We,*

2 route de POPENOT, 42800 ST JOSEPH (France)

Déclarons sous notre seule responsabilité, que les produits :  
*declare under our sole responsibility that the products :*

**PARAFOUDRES  
LIGHTNING ARRESTERS types:**

**AZC\_15\_ / AZC 150**

auxquels se réfère cette déclaration,  
*to which this declaration relates*

sont conformes à la (aux) norme(s) ou autres(s) documents normatif(s) :  
*correspond to required products for tender of CEZ and are in conformity with the following standard(s) or other normative document(s) :*

EN 60099-4, IEC/TS 60815-3

St JOSEPH, le/The 16/07/2013

M.DZIRI Responsable Qualité Environnement  
Quality Environment Manager

Nom & signature du signataire autorisé  
*Name and signature or equivalent marking of authorized person*

C. GAZZOLA

Directeur  
General Manager

Nom & signature du signataire autorisé  
*Name and signature or equivalent marking of authorized person*

Cette Déclaration de Conformité est conforme à la norme européenne EN45014 "Critères généraux pour les déclarations de conformité des fournisseurs". Les bases pour ces critères ont été trouvées dans la documentation internationale, et particulièrement dans : ISO/IEC Guide 22, 1982 "Information sur les déclarations de conformité des fabricants avec les normes et autres spécifications techniques".

This Declaration of Conformity is suitable to the European Standard EN 45014 "General criteria for supplier's declaration of conformity". The basis for the criteria has been found in international documentation, particularly in ISO/IEC Guide 22, 1982 "Information on manufacturer's declaration of conformity with standards or other technical specifications".

БІРНО СЕРТІФІКАЦІЯ



## ДЕКЛАРАЦИЯ

**КЛИЕНТ: CEZ**

Ние, DERVASIL  
2 route de POPENOT, 42800 ST JOSEPH (Франция)


Декларираме на своя собствена отговорност, че продуктите:

**Вентилни отдоди тип AZC\_15\_/AZC 150**

за които се отнася тази декларация,  
Отговарят на изискваните продукти за търга на ЧЕЗ и са в съответствие със следните  
стандарти или други нормативни документи:

EN 60099-4, IEC/TS 60815-3

St JOSEPH, 16/07/2013





dervasil



**DECLARATION  
DECLARATION**

**CLIENT/CUSTOMER : CEZ**

Nous, DERVASIL

We,

2 route de POPENOT, 42800 ST JOSEPH (France)

Déclarons sous notre seule responsabilité, que les produits :

*declare under our sole responsibility that the products :*

**PARAFONDRES**

**LIGHTNING ARRESTERS types:**

**AZC\_27\_ / AZC 270**

auxquels se réfère cette déclaration,

*to which this declaration relates*

sont conformes à la (aux) norme(s) ou autres(s) documents normatif(s) :

*correspond to required products for tender of CE and are in conformity with the following standard(s) or other normative document(s) :*

EN 60099-4, IEC/TS 60815-3

St JOSEPH, le/The 16/07/2013

M.DZIRI Responsable Qualité Environnement  
Quality Environment Manager

Nom & signature du signataire autorisé  
*Name and signature or equivalent marking of authorized person*

C. GAZZOLA

Directeur  
General Manager

Nom & signature du signataire autorisé  
*Name and signature or equivalent marking of authorized person*

Cette Déclaration de Conformité est conforme à la norme européenne EN45014 "Critères généraux pour les déclarations de conformité des fournisseurs". Les bases pour ces critères ont été trouvées dans la documentation internationale, et particulièrement dans : ISO/IEC Guide 22, 1982 "Information sur les déclarations de conformité des fabricants avec les normes et autres spécifications techniques".

This Declaration of Conformity is suitable to the European Standard EN 45014 "General criteria for supplier's declaration of conformity". The basis for the criteria has been found in international documentation, particularly in ISO/IEC Guide 22, 1982 "Information on manufacturer's declaration of conformity with standards or other technical specifications".

33PPOCOPEPHEAJA



A handwritten signature in black ink, located at the top right of the page.

## ДЕКЛАРАЦИЯ

**КЛИЕНТ: CEZ**

Ние, DERVASIL  
2 route de POPENOT, 42800 ST JOSEPH (Франция)

Декларираме на своя собствена отговорност, че продуктите:

**Вентилни отдоди тип AZC\_27\_/AZC 270**

за които се отнася тази декларация,  
Отговарят на изискваните продукти за търга на ЧЕЗ и са в съответствие със следните  
стандарты или други нормативни документи:

EN 60099-4, IEC/TS 60815-3


St JOSEPH, 16/07/2013

A handwritten signature in black ink, located at the bottom left of the page.

A handwritten signature in black ink, located at the bottom right of the page.  
A circular stamp with the text "ВАК - 02" ООД" at the top and "САМОКОВ" at the bottom. In the center of the stamp is a lightning bolt symbol. The stamp is partially obscured by a handwritten signature.



№ модели	№	EXPLORATION	VISA	DATE
A				



Arrester module type	Height (mm) H	Minimum leakage distance (mm)	Ur Rated Voltage (kV rms)	Uc Continuous operating Voltage (kV rms)	Weight (kg)
AZC 030	185,0±1,3	400	3	2,55	1,2
AZC 060	185,0±1,3	400	6	5,1	1,4
AZC 090	185±2,3	400	9	8,4	1,5
AZC 120	185±2,3	400	12	10,2	1,6
AZC 150	231,0±3,3	555	15	12,7	1,8
AZC 180	231,0±3,3	555	18	15,3	2,1
AZC 210	254,0±4,3	710	21	17,5	2,3
AZC 240	254,0±4,3	710	24	19,5	2,4
AZC 270	276,0±5,3	760	27	22,0	2,7
AZC 300	345,0±5,3	1000	30	24,4	3,0
AZC330	345,0±5,3	1000	33	27,0	3,1
AZC 360	345,0±6,3	1000	36	29,0	3,2
AZC 390	345,0±6,3	1060	39	32,0	3,2

PROJET	5	2	N. 10
DESIGN	4	2	TYPE-CABLE
SALES	3	1	C. 21
REF.	2	2	NOMELLE. 1. 10
N. PLAN	1	2	REG. N. 05
Reference			Dispositif
Observation			

**Gamme AZC xx0**

SICAME

dct viall  
groupe SICAME

INDUSTRIE - 42000 ST. JUSTE  
tel : 04.77.35.20.00 Fax : 04.77.35.22.00


DESIGNER PAR : MD  
DATE : 25/06/2009  
VERIFIE PAR :  
N. 10 - 10000000 - 200000

**99B000302A**

ВЫПОСОБИТЕЛЬ

*[Handwritten signature]*


3 <sup>e</sup> MODEL	REEL	DESCRIPTION	VMA	DATE
	A	cadet		
	B	Ajust de l'arbre	MD	20/03/00
120	C	Ajust profilés AZBD-0	MD	02/03/00
	D	Ajust AZBD 180 Pologne	MD	02/03/01



Marking  
AZBD\_2  
Uc :  
Ur : 10 KA  
In : 10 KA  
08/0001

3	1	AZBD			
4	2	Type (liste des types)	091103	1000 AZ	
5	3	Série (liste des séries)	090000	1000	
6	4	Modèle (liste des modèles)	101143	1000 AZ	
7	5	Version (liste des versions)	000000	1000 AZ	
8	6	Matériau	000000	1000 AZ	
9	7	Norme	000000	1000 AZ	
10	8	Revisé	000000	1000 AZ	
11	9	Autres	000000	1000 AZ	
12	10	Autres	000000	1000 AZ	

# Gamme AZBD - - 0



groupe SICAME

INDUSTRIE DE FRANCE

99B000224D

Arrester module type	Height (mm)	Minimum leakage distance (mm)	Ur	Uc	Weight (kg)
AZBD 030	140,0±1,0	230	3	2,55	1,2
AZBD 060	140,0±1,4	230	6	5,1	1,4
AZBD 090	170,0±2,4	315	9	8,4	1,5
AZBD 120	180,0±2,4	375	12	10,2	1,6
AZBD 150	195,0±3,0	500	15	12,7	1,8
AZBD 180	230,4±3,4	540	18	15,3	2,1
AZBD 210	245,0±4,4	660	21	17,5	2,3
AZBD 240	245,0±4,4	660	24	19,5	2,4
AZBD 270	270,0±5,0	750	27	22	2,7
AZBD 300	305,0±6,0	830	30	24,4	3,0
AZBD 330	320,0±6,4	960	33	27	3,1
AZBD 360	320,0±6,4	960	36	29	3,2
AZBD 390	360,0±7,4	1050	39	32	3,2
AZBD 420	360,0±7,4	1050	42	35	3,2
AZBD 450	360,0±7,4	1050	45	36	3,3
AZBD 180 Pologne	202,0±3,4	525	18	16	3,4

INDUSTRIE DE FRANCE

*[Handwritten signature]*

**dervasil**

**AZC ARRESTER - TYPE TESTS TABLE ACCORDING IEC 600099-4**

AZC arresters have same housing and same rating than AZB arresters  
 AZC arresters are fitted with Varistor OTOWA type TV4136FE2

TYPE TEST DESIGNATION	Clause s of IEC 60099- 4 (2004- 05)	Test reports	Sample to be tested according IEC 60099- 4	Validation for AZC
<b>INSULATION WITHSTAND TEST ON THE ARRESTER HOUSING</b>	10.8.2	CESI A5/003636	Longest housing i.e AZB 36	Dry Impulse level of tested sample= 190 kVpeak Wet Power frequency withstand of tested sample = 70.7 kV AZC arresters has same housing and same rating than AZB arresters <b>Test report is valid for AZC arresters</b>
<b>RESIDUAL VOLTAGE TEST</b>	10.8.3	OTOWA F1-44006008- 1	ZnO varistor type TV4136FE2f or AZC arrester Ur=6.25kV	IEC 60099-4 standard allows to perform test on arrester varistor. AZC.arresters are fitted with Varistor OTOWA type TV4136FE2 <b>Test report is valid for AZC arresters</b>
<b>LONG DURATION CURRENT IMPULSE WITHSTAND TEST</b>	10.8.4	OTOWA F1-44006008- 1	ZnO varistor type TV4136FE2f or AZC arrester Ur=6.25kV	IEC 60099-4 standard allows to perform test on arrester varistor. AZC.arresters are fitted with Varistor OTOWA type TV4136FE2 <b>Test report is valid for AZC arresters</b>

ВЕРНО СОБРЕГЕНАЈА

<b>HIGH CURRENT IMPULSE OPERATING DUTY TEST</b> - ACCELERATED AGEING TEST	10.8.5	OTOWA F1- 44006008-1	ZnO varistor type TV4136FE2f or AZC arrester Ur=6.25kV	IEC 60099-4 standard requires to perform test on varistor. AZC arresters are fitted with Varistor OTOWA type TV4136FE2	<b>Test report is valid for AZC</b>
	8.5.2				
<b>- HIGH CURRENT AND SWITCHING SURGE OPERATING DUTY TEST</b>	8.5.3	OTOWA F1- 44006008	ZnO varistor type TV4136FE2f or AZC arrester Ur=6.25kV	IEC 60099-4 standard requires to perform test on arrester section	<b>Test report is valid for AZC</b>
<b>SHORT CIRCUIT TEST</b>	10.8.7 Annex N	CESI A5/022760	Surge Arrester AZB36 Ur=36 kV	IEC 60099-4 standard requires to perform test on arrester with longest housing and highest rated voltage. AZC arresters has same housing and same rating than AZB arresters Tested sample has same design (housing shape & material, internal parts, varistor) than AZC	<b>Test report is valid for AZC</b>
<b>INTERNAL PARTIAL DISCHARGE TEST</b>	10.8.8	CESI A5/003599	Surge Arrester AZB36 Ur=36 kV	IEC 60099-4 standard requires to perform test on arrester with longest housing and highest rated voltage. AZC arresters has same housing and same rating than AZB arresters Tested sample has same design (housing shape & material, internal parts, varistor) than AZC	<b>Test report is valid for AZC</b>
<b>TEST OF BENDING MOMENT</b>	10.8.9	CESI A4/509502	Surge Arrester AZB36 Ur=36 kV	IEC 60099-4 standard requires to perform test on arrester with longest housing and highest rated voltage. AZC arresters has same housing and same rating than AZB arresters Tested sample has same design (housing shape & material, internal parts, varistor) than AZC	<b>Test report is valid for AZC</b>

BYWNO COREPENAMA

*(Handwritten signature and stamp)*

**dervasil**

**AZC ARRESTER - TYPE TESTS TABLE ACCORDING IEC 60099-4**

<b>MOISTURE INGRESS TEST</b>	10.8.13	CESI A4/509306	Surge Arrester AZB36 Ur=36 kV	IEC 60099-4 standard requires to perform test on arrester with longest housing and highest rated voltage. AZC arresters has same housing and same rating than AZB arresters Tested sample has same design (housing shape & material, internal parts, varistor) than AZC  <b>Test report is valid for AZC</b>
<b>WEATHER AGEING TEST</b>	10.8.14 Serie A: 1000h	CESI .AT- A5/022740	Surge Arrester AZB27 Ur=27 kV	Test was performed on arrester with minimum specific distance AZB27.. AZC arresters has same housing and same rating than AZB arresters  <b>Test report is valid for AZC</b>

St Joseph on  
May 28th, 2013


**dervasil**  
SAS au capital de 907 190 €  
Route de Popendorf - 42800 SAINT-JOSEPH  
Tél. 04 77 75 28 98 - Fax 04 77 63 22 80  
RC St-Etienne 423 136 877 - Cocc NAF 312A

БІЛГҮСӨНӨРӨНӨ

**AZC ВЕНТИЛЕН ОТВОД – ТАБЛИЦА ЗА ТИПОВЕ ТЕСТОВЕ СЪГЛАСНО IEC 600099-4**

Вентилните отводи AZC имат еднакъв корпус и категория като вентилните отводи AZB  
 Вентилните отводи AZC са оборудвани с Варистор OTOWA тип TV4136FE2

ПРЕДНАЗНАЧЕНИЕ НА ИЗПИТАНИЕТО	Клаузи от IEC 60099-4 (2004-05)	Доклад от изпитанието	Мостра за тестване съгласно IEC 600099-4	Утвърждаване за AZC
ИЗПИТАНИЕ НА ИЗОЛАЦИОННАТА УСТОЙЧИВОСТ НА КОРПУСА НА ВЕНТИЛНИЯ ОТВОД	10.8.2	CESI A5/003636	Най-дълъг. корпус - AZB 36	Ниво на импулса при сухо състояние на тестваната мостра = 190 kVpeak Устойчивост при промишлена честота и влажно състояние на тестваната мостра = 70.7 kV Вентилните отводи AZC имат еднакъв корпус и категория като вентилните отводи AZB <b>Този доклад е валиден за вентилни отводи AZC</b>
ИЗПИТАНИЕ НА ОСТАТЪЧНО НАПРЕЖЕНИЕ	10.8.3	OTOWA F1-44006008-1	Варистор ZnO тип TV4136FE2f или вентилен отвод AZC Uf=6.25kV	Стандартът IEC 60099-4 позволява да се прави изпитание върху варистора на вентилния отвод. Вентилните отводи AZC са оборудвани с Варистор OTOWA тип TV4136FE2 <b>Този доклад е валиден за вентилни отводи AZC</b>
ИЗПИТАНИЕ ЗА УСТОЙЧИВОСТ НА ДЪЛГОТРАЕН ТОКОВ ИМПУЛС	10.8.4	OTOWA F1-44006008-1	Варистор ZnO тип TV4136FE2f или вентилен отвод AZC Uf=6.25kV	Стандартът IEC 60099-4 позволява да се прави изпитание върху варистора на вентилния отвод. Вентилните отводи AZC са оборудвани с Варистор OTOWA тип TV4136FE2 <b>Този доклад е валиден за вентилни отводи AZC</b>



**AZC ВЕНТИЛЕН ОТВОД – ТАБЛИЦА ЗА ТИПОВЕ ТЕСТОВЕ СЪГЛАСНО IEC 60099-4**

<p><b>ИЗПИТАНИЕ ПРИ РАБОТЕН РЕЖИМ С ВИСОКО-ТОКОВ ИМПУЛС</b> - Изпитание с ускорено стареене</p>	10.8.5	OTOWA F1-44006008-1	Варистор ZnO тип TV4136FE2f или вентилен отвод AZC U <sub>r</sub> =6.25kV	Стандартът IEC 60099-4 изисква да се правят изпитания върху варистора. Вентилните отводи AZC са оборудвани с Варистор OTOWA тип TV4136FE2 <b>Този доклад е валиден за AZC</b>
	8.5.2			Стандартът IEC 60099-4 изисква да се правят изпитания върху сектор от вентилния отвод. <b>Този доклад е валиден за AZC</b>
<p>- Изпитание при режим с високо-токов импулс и комутационно пренапрежение</p>	8.5.3	OTOWA F1- 44006008	Варистор ZnO тип TV4136FE2f или вентилен отвод AZC U <sub>r</sub> =6.25kV	
	10.8.7 Приложен ие N	CESI A5/022760	Вентилен отвод AZB36 U <sub>r</sub> =36 kV	Стандартът IEC 60099-4 изисква да се провеждат изпитания върху вентилния отвод с най-дълъг корпус и най-високо номинално напрежение. Вентилните отводи AZC имат еднакъв корпус и категория като вентилните отводи AZB. Изпитваната мостра има същия дизайн като AZC (форма на корпуса и материал, вътрешни части, варистор) <b>Този доклад е валиден за AZC</b>
<p><b>ИЗПИТАНИЕ С ВЪТРЕШНО ЧАСТИЧНО РАЗРЕЖДАНЕ</b></p>	10.8.8	CESI A5/003599	Вентилен отвод AZB36 U <sub>r</sub> =36 kV	Стандартът IEC 60099-4 изисква да се провеждат изпитания върху вентилния отвод с най-дълъг корпус и най-високо номинално напрежение. Вентилните отводи AZC имат еднакъв корпус и категория като вентилните отводи AZB. Изпитваната мостра има същия дизайн като AZC (форма на корпуса и материал, вътрешни части, варистор) <b>Този доклад е валиден за AZC</b>
	10.8.9	CESI A4/509502	Вентилен отвод AZB36 U <sub>r</sub> =36 kV	Стандартът IEC 60099-4 изисква да се провеждат изпитания върху вентилния отвод с най-дълъг корпус и най-високо номинално напрежение. Вентилните отводи AZC имат еднакъв корпус и категория като вентилните отводи AZB. Изпитваната мостра има същия дизайн като AZC (форма на корпуса и материал, вътрешни части, варистор) <b>Този доклад е валиден за AZC</b>

**AZC ВЕНТИЛЕН ОТВОД – ТАБЛИЦА ЗА ТИПОВЕ ТЕСТОВЕ СЪГЛАСНО IEC 600099-4**

<p><b>ИЗПИТАНИЕ С ПРОНИКВАНЕ НА ВЛАГА</b></p>	<p>10.8.13</p>	<p>CESI A4/509306</p>	<p>Вентилен отвод AZB36 U<sub>T</sub>=36 kV</p>	<p>Стандартът IEC 60099-4 изисква да се провеждат изпитания върху вентилния отвод с най-дълъг корпус и най-високо номинално напрежение. Вентилните отводи AZC имат еднакъв корпус и категория като вентилните отводи AZB Изпитваната мостра има същия дизайн като AZC (форма на корпуса и материал, вътрешни части, варистор)</p> <p align="center"><b>Този доклад е валиден за AZC</b></p>
<p><b>ИЗПИТАНИЕ С АТМОСФЕРНО СТАРЕЕНЕ</b></p>	<p>10.8.14 Серия A: 1000h</p>	<p>CESI AT- A5/022740</p>	<p>Вентилен отвод AZB27 U<sub>T</sub>=27 kV</p>	<p>Изпитанието е извършено върху вентилния отвод при минимално специфично разстояние AZB27.. Вентилните отводи AZC имат еднакъв корпус и категория като вентилните отводи AZB</p> <p align="center"><b>Този доклад е валиден за AZC</b></p>

*(Handwritten mark)*

*(Handwritten mark)*

*(Handwritten signature and stamp)*



# Test Report

# CESI

0030

AS/003636

Approved

Page 1

Client Dervasil - Saint Joseph - (France)

Tested equipment Housing for polymer housed metal-oxide surge arrester type AZB 36

Tests carried out Insulation withstand tests

Standards/Specifications IEC 60099-4 (2004-05)

Test date from February 07, 2005 to February 07, 2005

The results reported in this document relate only to the tested equipment.  
Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 13

No. of pages annexed 4

Issue date May 04, 2005

Prepared BU PeC - L. Podavitte

Verified BU PeC - R. Malgesini

Approved BU PeC - M. de Nigris

*L. Podavitte*  
*R. Malgesini*

**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prova o Componenti  
Il Responsabile del Laboratorio

CESI  
Centro Elettrotecnico  
Sperimentale Italiano  
Giacinto Motta spa

Via R. Rubano 54  
20134 Milano - Italia  
Telefono +39 02212541  
Fax +39 022125440  
http://www.cesi.it

Capitale sociale 8.050.000 Euro  
interamente versato  
Codice fiscale e numero  
iscrizione CC-AA 00763560100

Registro Imprese di Milano  
Sezione Ord. 0410  
n. R.E.A. 423223  
P.I. 1100763560100

REPUBBLICA ITALIANA

Tests witnessed by: \_\_\_\_\_



Identification of the object:

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.  
CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.  
These drawings, identified by CESI and numbered A5021441 No. 1-3-4-5 , have been returned to the Client.

The data necessary to permit repetition of the tests are contained in the document marked: ---

- dielectric tests with impulse voltage : peak voltage: ± 3 %; time parameters: ± 10 %
- dielectric tests with impulse current : peak value: ± 3 %; time parameters: ± 10 %
- dielectric tests with alternating voltage : voltage (rms): ± 3 %
- dielectric tests with direct voltage : voltage: ± 3 %

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values

Laboratory information




Receipt date of the sample February 01, 2005

Test location CESI – Via Rubattino 54 – Milan

CESI testing team Mr L. Podavitte , Mr I. Guacci, Mr M. Gregori

Test laboratory P180


Activity code 26892R



content	page	test date
Rated characteristics of the test object	4	
Panoramic view of the test object	5	
Panoramic view of the test arrangement	6	
Reference standard	7	
Test carried out	7	
Test procedure	8	
Summary of test result	8	
Dry lightning impulse withstand tests	9	February 07,2005
Wet power frequency withstand tests	10	February 07,2005
Technical data of the test circuit	11-13	

*[Signature]*  
**Pages annexed:**  
 oscillograms n.4 pages

*[Signature]*  
**Test Report**



**CESI**

Approved

Rated characteristics of the tested object assigned by the Client

Metal-oxide surge arrester

Manufacturer	Dervasil
Year of manufacture	2004



Geometrical characteristics measured on the test sample

Height	345 mm
Number of sheds	12
Shed diameter	119 mm
Shed spacing	25 mm
Arcing distance	370 mm
Creepage (leakage) distance	1020 mm
Core diameter	59 mm

Other characteristics

Housing material	Silicone rubber
Housing color	grey

Name and signature of Client's witness:



Stamp: **БІЛРО СЕРТИФІКАЦІЯ**  
Stamp: **СЕРТИФІКАЦІЯ**

*[Handwritten signature]*  
0030

Photograph of the test object




Photo no. 1

*[Handwritten signature]*

ОБЩЕСТВО С ОГРАНИЧЕННОЙ ОТВЕТСТВЕННОСТЬЮ  
«ЦЕСИ»

*[Handwritten signature]*  
*[Handwritten signature]*  
*[Handwritten signature]*



*[Handwritten signature]*

Photograph of the test arrangement




Photo no. 2

*[Handwritten mark]*

ИНТЕРНЕТОВАЯ  
СЕРВИСНАЯ СЛУЖБА

*[Handwritten signature]*

*[Handwritten signature]*


Reference Standard

IEC 60099-4 (2004-05): "Metal-oxide surge arrester without gaps for a.c. system", clause 8.2

Test carried out and identification of the test objects

Test carried out	Number of test objects	Test object identification
Dry lightning impulse withstand tests	1	IWT1
Wet power frequency withstand tests	1	IWT1

BRVEG COPHTWANA



Test procedure

Dry lightning impulse withstand test

The test sample has been submitted to fifteen voltage impulses for each polarity having waveshape 1,2/50 µs and peak value equal to 190,0 kVpeak .The test has been performed in dry condition.

Wet power frequency withstand test

The power frequency voltage has been applied for 60 second on the sample at the value equal to 70,71 kVrms .The test has been performed in wet condition (as defined by IEC st. 60060-1 (1989))

Summary of test results

Dry lightning impulse withstand test

Non flashover occurred during any of the impulse application


Wet power frequency withstand test

Non flashover occurred

The test result is positive

ВЕРНО СОПРЕКВНАЈА







**Dry lightning impulse withstand voltage test**

Test No.: 1


Test object: Housing for polymer housed metal-oxide surge arrester  
 Test circuit: A0002  
 Arrangement: see photograph pag n.6

Atmospheric conditions and correction factor			
b	$t_d/t_w$	h	$K_t$
kPa	°C	g / m <sup>3</sup>	
101,83	11 (6)	4,49	0,968

Date: February 07, 2005

test condition	polarity	impulse generator charging voltage kV	voltage		oscillogram No.	(x) flashover															
			required U kV <sub>peak</sub>	applied U x K <sub>t</sub> kV <sub>peak</sub>																	
negative		93,0	190,0	183,4	A	0	0	0	0	0	0	0	0	0	0	0	0	0			
					B	03															
					C	183,5	183,6	183,6	183,6	183,6	183,6	183,6	183,5	183,5	183,6	183,8	183,8	183,8	183,8	183,8	183,8
					D																
positive		93,0	190,0	183,4	A	0	0	0	0	0	0	0	0	0	0	0	0	0			
					B	04															
					C	182,5	183,5	184,0	183,6	183,8	183,6	183,6	183,8	183,8	183,8	183,8	183,8	183,8	183,8	183,8	183,8
					D																

**Test Report**



**CESI**

Approved

**Wet power frequency withstand voltage test**

Test No.: 2

Test object: Housing for polymer housed metal-oxide surge arrester  
 Test circuit: A0058-A0059  
 Arrangement: see photograph pag n.6

Atmospheric conditions and correction factor			
b	$t_a/t_w$	h	$K_1$
kPa	°C	g/m <sup>3</sup>	
101,03	12/5	2,99	1,0

	Precipitation conditions			Water temperature °C	Water resistivity Ω * m
	Precipitation rate (mm/min)				
	top	center	bottom		
vertical	1,2	1,2	1,2	11	100
horizontal	1,2	1,2	1,2		


Date: February 07, 2005

test condition	voltage		test voltage		test duration	Test result	Notes
	required U	applied U x K <sub>c</sub>	V <sub>1</sub>	V <sub>2</sub>			
kV <sub>rms</sub>	U	U x K <sub>c</sub>	V <sub>1</sub>	V <sub>2</sub>	s		
70,71	70,71	70,71	20,20	--	60	withstand	

*[Handwritten signature]*

*[Handwritten signature]*  
continued


Approved



**CESI**

**Test Report**

Circuit A0002



Impulse generator

- No. of stages: 2
- C<sub>g</sub>: 250 nF
- R<sub>t</sub>: 280 Ω (140 x 2)
- R<sub>f</sub>: 320 Ω (140+60+40+80)
- C<sub>c</sub>: 0,6 nF

Voltage measuring system CESI No. 9792

- D - divider PASSONI & VILLA type RC series CESI No. 6700; scale factor 25662,7
- HV - high voltage capacitance 600 pF
- lv - low voltage unit CESI No. 6704
- K - coaxial cable
- S - attenuation and termination unit CESI No. 14924
- OSC - digital oscilloscope type TEKTRONIX TDS 430A CESI No. 14232


Measured waveshape			
	polarity	time	oscillogram
		μs	No.
front	negative	1,04	01
tail		54,8	02

Check of the test circuit			
	Charging voltage V <sub>c</sub>	Measured voltage V <sub>m</sub>	η V <sub>m</sub> / (V <sub>c</sub> · n <sub>stages</sub> )
polarity	kV/stage	kV	
negative	72,0	142,0	0,986

ВНИМО СОПРЕВЕРЯЈА

*(Handwritten signatures and stamps)*

Circuit A0058




Power frequency test circuit

- R - regulation group PIVI composed by:
  - single-phase voltage converter PIVI; power 210 kVA; voltage 380 V/0+610 V
  - booster transformer PIVI; power 200 kVA; voltage 600 V /6 kV
- R<sub>lv</sub> - protection resistor TELEMA; R= 2 Ω
- TA - current transformer type CGS; ratio 50 A/5 A; CESI No. 03399
- I - direct reading digital amperometer
- TV<sub>1</sub> - voltage transformer type ALSTOM; ratio 6 kV/100 V
- V<sub>1</sub> - digital voltmeter AGILENT 34401A; CESI No. 23082
- T - booster transformer CGE mod. KOC; secondary winding power 700 kVA; voltage 6 kV /350 kV; No. of units 1; ratio 3500
- RE - variable reactor PIVI; power 600 kVA( not used)

Tripping of the circuit breaker S

I <sub>N</sub>	k <sub>TA</sub>	instantaneous tripping			time delayed tripping		
		setting			setting		
		s <sub>1</sub>	s <sub>1</sub> 3 I <sub>N</sub>	t <sub>1</sub>	s <sub>2</sub>	s <sub>2</sub> 3 I <sub>N</sub>	t <sub>2</sub>
5	10	1	5	0,05	0,5	2,5	0,05

Circuit A0059



Power frequency measuring circuit

TA - current transformer type CGS; ratio 50 A/5 A; CESI No. 03399

I. - direct reading digital amperometer

TV<sub>1</sub> - voltage transformer type ALSTOM; ratio 6 kV/100 V

V<sub>1</sub> - digital voltmeter AGILENT 34401A CESI No. 23082

D - voltage divider / type RC series; voltage / kV; HV capacitance / pF; CESI No. /; low voltage arm CESI No. / scale factor /.

V<sub>3</sub> - voltmeter CESI No. Not used

TV<sub>2</sub> - voltage transformer type SCARPA & MAGNANO; ratio 130/100 V; CESI No.5133

V<sub>2</sub> - digital voltmeter AGILENT 34401A CESI No. 23083

Functional check of the test circuit


Date: February 07, 2005

Low voltage				High voltage				k <sub>1</sub>
V <sub>1</sub>	V <sub>IV</sub>	I	I <sub>IV</sub>	V <sub>2</sub>	V <sub>HV</sub>	V <sub>3</sub>	V <sub>HV</sub>	
V	V	A	A	V	kV	V	kV	V <sub>HV</sub> / V <sub>1</sub>
14,27	856,2	--	1,0	38,34	48,83	--	--	3492

BRUNO COPPINI A.J.A.

*[Handwritten signature]*

**CESI** A5/003636, n.1



Vp[kV] T1/Tp[us] T2/Tc[us]

-142.585 1.038 54.855


ВЕРИФИКАЦИЯ  
ПРОЦЕДУРА

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

**CESI** A5/003636, n.2




<b>Vp[kV]</b>	<b>T1/Tp[us]</b>	<b>T2/Tc[us]</b>
<b>-142.585</b>	<b>1.038</b>	<b>54.855</b>

ВНИМАНИЕ  
ПОКАЗЫВАЮТ

*[Handwritten signatures and stamps]*

**CESI** A5/003636, n.3



Vp[kV] T1/Tp[us] T2/Tc[us]

**-183.552 1.075 55.292**


ВАРНО С ДИФЕРЕНЦАЛА

*[Handwritten signature]*  
СЕРТИФИКАТ  
СЕРИЯ  
СЕРТИФИКАТ  
СЕРИЯ



2

CESI A5/003636, n.4



Vp[KV]	T1/Tp[µs]	T2/Tc[µs]
182.538	1.017	56.066

УПРАВЛЕНИЕ

# DERVASIL

## Lightning Arrester

### Class 2

Report No.	F1-44006002-1
------------	---------------

## TEST REPORT


### METAL-OXIDE ARRESTER BLOCKS

<b>TYPE</b>	TV4136FE2
<b>U<sub>c</sub></b>	5kV
<b>NOMINAL DISCHARGE CURRENT</b>	10kA class2


OTOWA Electric Industrial Co., LTD  
7-18, Meishincho-3chome, Amagasaki-city,  
Hyogo Pref., 661-0021 Japan  
TEL: +81 66429-3541 FAX: +81 66426-0535

OTOWA ELECTRIC INDUSTRIAL CO., LTD  
1

*B*



**Photo 1. Test sample**



**Photo 2. Test equipment**

*A*

ЗАКОННОСТЬ

*CG*  
*CG*  
*CG*

### SPECIFICATION OF TEST BLOCKS

Type	Dimensions (mm)		Rated Voltage (kV)	MCOV (kV)	Current with stand	
	Diameter	Height	IEC	IEC	4/10 $\mu$ s	2ms
TV4136FE2	41 $\pm$ 0.8	36 $\pm$ 1.0	6.25	5.00	100kA	500A

Nominal discharge current  $I_n$ : 10kA(8/20  $\mu$  s)

Referent current  $I_{ref}$ : 2mA

### CONTENTS

1. Reference voltage measurements
2. Residual voltage test
  - 2-1 Nominal discharge current test
  - 2-2 Steep current impulse test
3. Long duration current impulse withstand test
4. Accelerated ageing test
5. Operating duty tests (IEC-60099-4-2004)
6. Temporary over-voltage tests (TOV)

3  
INTECHNICAL


*[Handwritten mark]*

**1. Reference voltage measurements.**

The test was made on 3 blocks with AC 60Hz.

Type	Sample	Resistive component of current = 2mA peak
		Reference voltage Uref (kVrms)
TV4136FE2	1	6.34
	2	6.38
	3*1	6.36

※ 1 : OSC Fig.1-1



**Fig. 1-1**

*[Handwritten mark]*

4  
УПРАВЛЕНИЕ ПО ТЕХНИЧЕСКОМУ НАДЗОРУ

*[Handwritten signature]*  
*[Handwritten signature]*  
*[Handwritten signature]*  
*[Circular stamp]*

*[Handwritten mark]*


**2. Residual Voltage test**

**2-1. Nominal discharge current test**

The residual voltage test with nominal discharge current impulse (8/20  $\mu$  s) was made on 3 blocks.

Positive current impulses in the range from 1.5kA to 20kA were applied on each block.

Type	Sample	Residual voltage (kV)									
		1.5 kA		2.5kA		5.0kA		10 kA		20kA	
		I kA	V kV	I kA	V kV	I kA	V kV	I kA	V kV	I kA	V kV
TV4136FE-2K	1	1.53	13.9	2.5	14.2	5.7	15.2	10.1	16.2	21.4	17.7
	2	1.54	13.9	2.5	14.3	5.6	15.3	10.0	16.3	21.3	18.3
	3*2	1.50	13.8	2.5	14.3	5.6	15.3	10.0	16.3	21.6	17.1
Impulse shape		※ 2 : OSC Fig.2-1 8.4/19.2 $\mu$ s									



X: 10  $\mu$  s/div Y: 4.1kA/div

**Fig. 2-1**

*[Handwritten signature]*


*[Handwritten signature]*  
*[Handwritten signature]*  
*[Handwritten signature]*

*[Handwritten mark]*

**2-2. Steep current impulse test**

The residual voltage test with steep current impulse ( $1/20 \mu s$ ) was made on the 3 blocks. A positive 10kA current impulse was applied on each block

Type	Sample	Residual voltage (kV)	
		I kA	V kV
TV4136FE-2K	1	10.2	17.8
	2	10.2	18.0
	3*3	10.2	17.8
Impulse shape	※ 3 : OSC Fig.2-2 1.0 / 2.4 $\mu s$		



X: 1  $\mu s$ /div Y: 2kA/div

**Fig. 2-2**

*[Handwritten mark]*

*[Handwritten signature]*

ВУЗН6 СОРЕНБНАТА

*[Handwritten signature]*

*6*

**8. Long duration current impulse withstand test**

The long duration current impulse withstand test was made on 3 blocks in accordance with clause 7.4 of IEC 600099-4.


The lightning current impulse (8/20  $\mu$ s) residual voltage was measured before and after the test. Each long duration current impulse test consists of 18 discharge operations divided into six groups of three operations.

Intervals between operations were 60 s and between groups such that the sample cools to near ambient temperature.

Test sample No. (4136GB25)		4	5	6
Measurement of residual voltage before test (Pre-Test V10kA)	Current (kA)	10.3	10.3	10.3
	Voltage (kV)	15.4	15.4	15.5
Long duration current impulses	Current (A)*5	504-508	503-507	503-508
	Duration (ms)	2.0	2.0	2.0
	Residual voltage (kV)	12.2~12.3	12.2~12.4	12.2~12.5
Number of impulse	Total / Group	18/3	18/3	18/3
Injection energy (kJ)		12.2	12.2	12.2
Measurement of residual voltage after test (Post-Test V10kA)	Current (A)	10.3	10.3	10.3
	Voltage (kV)	15.4	15.4	15.5
Percentage change (%)		$\pm 0$	$\pm 0$	$\pm 0$
Test result		passed	passed	passed

ambient temperature: 18 ~ 20 °C

※ 5 : OSC Fig.3-1



X: 500  $\mu$ s/div Y: 202A/div

**Fig. 8-1**

*Handwritten signature*

*Handwritten signature*  
 7  
 КОПЕЧЕНАНА

*Handwritten signature*



*[Handwritten mark]*

**4. Accelerated ageing test**


Accelerated ageing test was made on 5kV MCOV blocks (TV4136FE2) in accordance with clause 7.5.2 of IEC 60099-4.

3 blocks were stressed at 5.75(1.15xUc) kV for 1000 hours at temperature of  $115 \pm 2^\circ\text{C}$ .

The watts loss was measured after 2 hours and 1000 hours on each block.

Test results shows that watts loss of each block measured after 1000 hours are lower than those measured after 2 hours, or continuous decrease in watts loss was demonstrated on each block.

Test sample No.		7	8	9
2 hour after energization ambient temperature :115°C	Applied Voltage (kVrms)	5.75	5.75	5.75
	Power loss (W)	4.6	4.8	4.9
1000 hour after energization ambient temperature :115°C	Applied Voltage (kVrms)	5.75	5.75	5.75
	Power loss (W)	2.6	2.5	2.7



**Fig.4-1**

APPROVED

*[Handwritten signature]*

*[Handwritten mark]*

*[Handwritten signature]*

## 5. Switching surge operating duty tests

Operating duty tests was made on 3 samples consisting of 5kV  $U_c$  (IEC) blocks in accordance with clause 7.5 of IEC 60099-4(1998).

### 1) Measurement of residual voltage

At first part of the operating duty test, a lightning impulse (8/20 $\mu$ s) residual voltage measurement was made with nominal discharge current.

### 2) Conditioning

The samples was exposed to the conditioning test consisting of twenty 8/20 lightning current impulses. The impulses were applied while the sample was energized at power frequency voltage stress of 1.2 $U_c$ . The lightning current impulses were applied in 4 groups of 5 impulses. The interval between the impulses was 50 to 60 seconds and the interval between groups was 25 to 30 minutes. The polarity of the current impulse was same as that of the half cycle of power frequency voltage during which it occurs and was applied 60 electrical degrees before the peak of the power frequency voltage.

### 3) High current impulse test

The samples were subjected to one high current impulse of 100 kA (4/10 $\mu$ s) at ambient temperature. Then the test samples were preheated up to 60 degree centigrade in an oven. Then the samples were subjected to the second high current impulse of 100kA (4/10 $\mu$ s).

### 4) Long duration impulse tesut

The samples were subjected to two long duration impulse of 500A (2ms) at ambient temperature. The time intervals between impulses shall be 50s to 60s. Within about 100ms after second impulse, the power frequency voltage of  $U_r$  and the elevated continuous operating voltage ( $U_c$ ) were applied for a time period of 10s and 30min respectively to prove thermal stability. After the test samples were cooled down to the temperature close to ambient conditions, the measurement of residual voltage was made.

### 5) Results

The thermal stability was observed on each sample.

The residual voltage measured after the test did not change more than 5% from the value measured before the test on each sample.

No damage was observed on each sample after the test.

Therefore, the samples passed the high current impulse operating duty test.

ЯРДӨС СӨРӨГӨНӨ

**Table 5-1 Result of operating duty test**

Test sample No.		1	2	3	
Conditioning with lightning current impulse (10kA, 8/20 $\mu$ s)	Applied voltage [kVrms]	6.2	6.2	6.2	
	Current of impulse [kA]	<sup>*9</sup> 10.0-10.3	10.0-10.4	10.0-10.4	
	Number of impulses: Total /per group	20/5	20/5	20/5	
	Time between: the impulses / the group	25-30 min / 60sec	25-30 min / 62sec	25-30 min / 59sec	
High current impulse (100kA, 4/10 $\mu$ s)	First current impulse [kA]	<sup>*10</sup> 101.6	101.7	101.3	
	Second current impulse [kA]	100.5	100.7	100.2	
Long duration current impulse (500A, 2ms)	First current impulse [A]	<sup>*11</sup> 505	510	505	
	Second current impulse [A]	500	505	500	
	Elevated Ur (10 sec) applied voltage [kVrms]	<sup>*12</sup> 6.4	6.4	6.4	
	Elevated Uc (30 min)	Applied voltage [kVrms]	5.1	5.1	5.1
		Leakage current [mA] (1min $\rightarrow$ 30min)	<sup>*13</sup> 13.75-0.3	5.3-0.6	2.8-0.1
Residual voltage (at 10kA, 8/20 $\mu$ s)	Initial	Current [kA]	9.84	10.24	9.92
		Voltage [kV]	15.80	16.00	15.90
	Final	Current [kA]	10.05	10.05	10.09
		Voltage [kV]	16.66	16.60	16.66
	Percent change		+5.44%	+3.75%	+4.78%

<sup>\*9</sup> : Chart & OSC (Fig.5-1)

<sup>\*10</sup> : OSC (Fig.5-2)

<sup>\*11</sup> : OSC (Fig.5-3)

<sup>\*12</sup> : Chart (Fig.5-4)

<sup>\*13</sup> : Chart (Fig.5-5)


NSPPO CORPUSHAJA

10


*b*

**Fig.5-1 Nominal discharge current at rated duty-cycle voltage: Sample No.3**

Chart (1st impulse)




OSC of discharge current (1st impulse)




x: 10 $\mu$ s/div

y: 5kA/div

Chart (20th impulse)



OSC of discharge current (20th impulse)



x: 10 $\mu$ s/div

y: 5kA/div


*g*

СЕРТИФИКАТ

*Handwritten signatures and stamps*


*B*

**Fig.5-2 OSC of discharge High current (1st impulse): Sample No.8**  
(ambient temperature)



x: 5 $\mu$ s/div  
y: 20.2kA/div

**Fig.5-3 OSC of discharge High current (2nd impulse): Sample No.8**  
(preheat: 60 degree centigrade)



x: 5 $\mu$ s/div  
y: 20.2kA/div

*CG*


59 PRO COPIE PETAJA

*u*


*A. Konefi*

*B*

**Fig.5-4 Elevated  $U_r$  voltage, 10sec (after high current impulse): Sample No.3**



**Fig.5-5 Elevated  $U_c$  voltage, 30min: Sample No.3**



*B*

АННОСОПТРИВАКА

*A. Kovic*

**Client** DERVASIL  
Saint Joseph - FRANCE

**Tested equipment** Polymer housed metal-oxide surge arresters without gaps for a.c. systems

**Tests carried out** Short-circuit tests

**Standards/Specifications** IEC 60099-4 (2001)

**Test date** from March 15, 2004 to March 15, 2004

The results reported in this document relate only to the tested equipment.  
 Partial reproduction of this document is permitted only with the written permission from CESI

**No. of pages** 21 **No. of pages annexed** 8

**Issue date** May 12, 2005

**Prepared** PeC - P. BECCARINI

**Verified** PeC - D. GIORDANI

**Approved** PeC - M. de NIGRIS

**CESI**  
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
 Business Unit  
 Prova di Componenti  
 Il Responsabile del Laboratorio

**CESI** Centro Elettrotecnico Sperimentale Italiano Giacinto Molitola spa  
 Via R. Robustiano 54 20134 Milano - Italia  
 Telefono +39 022126.1 Fax +39 0221255449  
 http://www.cesi.it

Capitale sociale € 650.000.000 Euro interamente versato  
 Codice fiscale e numero Registro Imprese di Milano  
 02703550160 P.I. 02703550160

STRIPPO COPIE MEATA

Tests witnessed by

Mr. Gazzola  
Mr. Rousset

DERVASIL - Saint Joseph - FRANCE  
DERVASIL - Saint Joseph - FRANCE

Identification of the object      Effected.

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawings identified by CESI and numbered:

- A5/021441 No.1 to 10,
- A5/021444 No.1,
- A5/021445 No.1

have been returned to the Client.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: A4/008123

The measurement uncertainties of the test results reported in the document are the following:  
voltage:  $\pm 5\%$  ; current:  $\pm 5\%$  ; time:  $\pm 5\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

Receipt date of the sample      March 15, 2004

Activity code      41285B

ИЗДАНИЕ КОМПЕТЕНЦИА



Contents	Page	Test date
<p><b>Rated characteristics of the tested object assigned by the Client</b></p>	4	
<p><b>Test arrangement</b></p>	5	
<p><b>Tests performed</b></p>	6	March 15, 2004
<p>High-current short-circuit tests with 20,5 kA for 0,20 s</p>	7	March 15, 2004
<p>High-current short-circuit tests with 12,4 kA for 0,20 s</p>	8	March 15, 2004
<p>High-current short-circuit tests with 6,00kA for 0,20 s</p>	9	March 15, 2004
<p>Low-current short-circuit tests with 603 A for 1,00 s</p>	10	
<p><b>Test circuit</b></p>	11 to 21	
<p><b>Photos</b></p>		
<p><b>Pages annexed</b></p>		
<p><b>Oscillograms (No.8)</b></p>		

**CESI**

**Rated characteristics of the tested object assigned by the Client**

<b>Metal-oxide surge arrester</b>	
Manufacturer	DERVASIL – Saint Joseph - FRANCE
Type	AZB 36
Drawing	99B524923A
Rated voltage (Ur)	36kV
Maximum continuous operating voltage (Uc)	29kV
Rated frequency	50/60 Hz
Nominal discharge current (8/20 $\mu$ s impulse shape)	10kA
Line discharge class	1
Pressure relief class	
High current	for 0,20 s ; 20,0 kA
Low current	for 1,00 s ; 0,60 kA


*cy*

*bp*

REPRO COPIE FHT LJA  
*M*

*U. K...*


D8000 - Test arrangement



- 1 : Surge arrester
- 2 : Flexible conductor
- 3 : Rigid conductor
- 4 : Support
- 5 : Circular enclosure

- A : 1,00 m
- B : 0,40 m
- C : 1,80 m

The arrester to be tested was fixed on a support at 0,40 m to ground in the middle of a circular enclosure of 1,80 m in diameter.  
 The live side of the supply was connected to the upper end of the arrester while the return circuit, earthed, was connected to the lower end.



**High-current short-circuit tests with 20,5 kA for 0,20 s**

Test circuit: See D0046 Power factor: <0,15 Frequency: 50 Hz

Test arrangement : See D8000

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source. The short-circuit current of the auxiliary low power source has been set at about 2,00 A.

The voltage applied to the arrester was risen in order to get a current equal to 50 mA peak (i.e. 55.kVpk) and kept at this value till arrester failure.

The pre-failure process duration was 6 minutes.

The short-circuit test was performed 4 minutes after the completion of the pre-failure process.

Condition of the apparatus before the tests: new

Date: March 15, 2004

Test No.	Oscillogram No.	Arrester under test No.	Duration S	Test voltage KV	Test current		Photos	Notes
					Peak value kA	rms value kA		
1	7	PVIII	0,20	37,0	47,3	20,5	Before the test No. 1 After the test No. 2-3	No. -

Oscillogram No.	Sheets	Prospective test current	
		rms value kA	Peak value kA
4	1	20,5	57,5

**Condition of the apparatus after the tests:**

The arrester remained connected to the supply and return circuits. Moderate damages to the housing of the arrester. No pieces were projected inside or outside the circular enclosure. No flame was noted after the test.

**High-current short-circuit tests with 12,4 kA for 0,20 s**

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

Test arrangement : See D8000

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source. The short-circuit current of the auxiliary low power source has been set at about 2,00 A.

The voltage applied to the arrester was risen in order to get a current equal to 50 mA peak (i.e. 55kVpk) and kept at this value till arrester failure.

The prefailure process duration was 6 minutes and 20 seconds.

The short-circuit test was performed 7 minutes after the completion of the prefailure process.

Condition of the apparatus before the tests: new

Date: March 15, 2004

Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
9	1	12,4 kA	kA
			35,1

Test No.	Oscillogram No.	Arrester under test No.	Duration s	Test voltage kV	Test current		Photos		Notes
					Peak value kA	rms value kA	Before the test No.	After the test No.	
2	10	PV	0,20	37,0	25,3	12,4	4	5 to 7	-

Condition of the apparatus after the tests:

The arrester remained connected to the supply and return circuits.

Strong damages to the housing of the arrester.

No block fragment was projected inside or outside the circular enclosure.

One silicon rubber housing piece was found inside the circular enclosure.

No flame was noted after the test



**High-current short-circuit tests with 6,00kA for 0,20 s**

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

Test arrangement : See D8000

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source. The short-circuit current of the auxiliary low power source has been set at about 2,0 A.

The voltage applied to the arrester was risen in order to get a current equal to 50 mA peak (i.e. 55 kVpk) and kept at this value till arrester failure.

The prefailure process duration was 4 minutes and 20 seconds.

The short-circuit test was performed 4 minutes after the completion of the prefailure process.

Condition of the apparatus before the tests: new

Date: march 3,2004

Test No.	Oscillogram No.	Arrester under test	Duration	Test voltage	Test current		Photos	Notes
					Peak value	rms value		
3	12	PVI	0,20	37,0 kV	14,8 kA	6,00 kA	Before the test No. -	After the test No. 8 - 9

Oscillogram No.	Sheets	Prospective test current	
		rms value	Peak value
11	1	6,00 kA	17,4 kA

Condition of the apparatus after the tests:

The arrester remained connected to the supply and return circuits.

Moderate damages to the housing of the arrester.

No pieces were projected inside or outside the circular enclosure.

No flame was noted after the test.

**CESI**

**Test Report**

**Low-current short-circuit tests with 603 A for 1,00 s**

Test circuit : See D0046 Power factor : <0,15 Frequency: 50 Hz

Test arrangement : See D8000

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary/ low power source.

The short-circuit current of the auxiliary low power source has been set at about 2,00 A.

The voltage applied to the arrester was risen in order to get a current equal to 50 mA peak (i.e. 55 kVpk) and kept at this value till arrester failure.

The prefailure process duration was 4 minutes and 30 seconds.

The short-circuit test was performed 4 minutes after the completion of the prefailure process.

Condition of the apparatus before the tests: new

Date: March 15, 2004

Test No.	Oscillogram No.	Arrester under test No.	Duration S	Test voltage kV	Test current		Photos		Notes
					Peak value kA	rms value A	Before the test No.	After the test No.	
4	14	PVII	1,00	37,0	1,22	603	-	10 - 11	-

Condition of the apparatus after the tests:

The arrester remained connected to the supply and return circuits.

Light damages to the housing of the arrester.

No pieces were projected inside or outside the circular enclosure.

No flame was noted after the test.

Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
13	1	603	1,70

**Test Report**




Approved

A5/022760

Page 9

Test circuit D0046



Symbols used in this diagram are the same as those on the oscillograms.

*07*

*BF*

REPRODUCTION PROHIBITED

*gr*

*H. Konec*






Photo No.1

*[Handwritten signature]*

*[Handwritten signature]*





Photo No.2

D1093IG

РАРНО СОРБЕНТА ІА

*af*  
*af*  
*[Signature]*



*[Handwritten Signature]*

Photo No.3

ИЗ ПРОЦЕДУРЫ  
*[Handwritten Signature]*

*[Handwritten Signature]*  
*[Circular Stamp]*

*[Handwritten Signature]*






Photo No.4

D10931G


 РЕСПУБЛИКАНСКАЯ  
 КОМПАНИЯ






Photo No.5

D1093IG

ВЫПРОБОВАТЕЛЬНАЯ

*[Handwritten signature]*

*[Handwritten signature]*



*[Handwritten signature]*







Photo No.6

D1093IG



  
 БУРО СОСРЕДНОВАЛА

*[Handwritten signature]*




Photo No.7

*[Handwritten signature]*

*[Handwritten signature]*

ВІСНОКОВИТІНАНА

*[Handwritten signature]*  
*[Handwritten signature]*




Photo No.8

DI0931G

*Handwritten mark*

ВЕРНО КОМПЕТЕНТНО

*Handwritten signature*

*Handwritten initials*






Photo No.9

010931G

*[Handwritten signature]*

ВЯРУЮ СОБЛЮДАЮ

*[Handwritten signature]*

*[Circular stamp]*

*[Handwritten signature]*

*Handwritten signature*




Photo No.10

*Handwritten mark resembling the number 5*

DI093IG

*Handwritten signature*

ВІСНОСОПРІЄВІА

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

*[Handwritten signature]*




Photo No.11

*[Handwritten signature]*

D1093IG

*[Handwritten signature]*

ВНПРОСОПНЕННАЯ


*[Handwritten signature]*

*[Handwritten signature]*

*B*

(0)

(0)



Sec: 1SEC Osc: 0 Meas: HF1-1

29,113  
CESI P141 A4/008123-0004


*u*

ВСТРОИТЕЛЬСКИЙ  
125 ВА

*[Handwritten signature]*

I. peak = 47,31 kA  
dT = 5,0 mSec  
dT = 204,5 mSec

*Handwritten signature*



*Handwritten signature*  
0-30 kV

ВЯРНО СОУДИТНАЛНА


1 25 kA

*Handwritten signature*  
VENTILAY

CESI P141 A4/008123-0007

Sec: 1SEC Osc: 0 Meas: HF1 - 1

I<sub>peak</sub> = 35,12 kA  
I<sub>rms</sub> = 12,39 kA



U30 kV

НАРЕД СОБИТИЈА

115 kA


VENT 4V

37,488

CESI P141 A41008123-0009

Sec: TSEC Osc: O Meas: HF1-1

dT = 4,7 mSec  
dT = 201,2 mSec  
I.peak = 25,32 kA



U 30 KV

I 15 kA


ООО ПО СЕРВИСАЖА

VENT 0,10 V

CESI P141 A4/008123-0010

Sec: 1SEC Osc: 0 Mess: HF1-1

I. peak= 17,38 kA  
I. rms= 6,00 kA



35,626 60,000 80,000 100,000 120,000 140,000 160,000 180,000 200,000 220,000 240,000 252,446  
2,000 [msec/div.]  
Sec: 1SEC Osc: O Meas: HF1 - 1

4

U 30 kV

ИНСТРУКЦИЯ ПО ЭКСПЛУАТАЦИИ

16 kA

VENT 4 V


CESI P141 A4/008123-0011

114



dT = 3,5 mSec  
dT = 201,5 mSec  
I<sub>peak</sub> = 14,76 kA

*[Handwritten signature]*



U 30 kV

ИНТЕРКОММУНАЛЬНАЯ

16 kA


*[Handwritten signature]*  
VENT 0,20 X

CESI P141 A4/008123-0012

Scale: 1SEC Osc: O Meas: HF1 - 1

I.peak= 1,70 kA  
I.rms= 602,97 A

*Handwritten mark*



Set: tSEC Osc: O Meas: HF1 - 1

CESI P141 A4/008123-0013

*Handwritten mark*


ГОПРОСОУБСТВЕНАЯ

10.70 kA

*Handwritten signature*

dt= 1,002 Sec  
dt= 12,7 mSec  
I.peak= 1,22 kA

*B*



U 30 kV

I 0,70 kA

Ultima pagina  
Last page

VENT 500 V

10,000 [msec/div.]  
100,000 200,000 300,000 400,000 500,000 600,000 700,000 800,000 900,000 1,000,000 1,093,629

Set: 1SEC Osc: 0 Meas: MF

CESI P141 A4/008123-0014

*A. K...*

Client Dervasil - Saint Joseph - (France)

Tested equipment Housing for polymer housed metal-oxide surge arrester type AZB 36

Tests carried out Partial discharge test

Standards/Specifications IEC 60099-4 (2004-05)

Test date from February 09, 2005 to February 09, 2005

The results reported in this document relate only to the tested equipment. Partial reproduction of this document is permitted only with the written permission from CESI.



No. of pages 11

No. of pages annexed 3

Issue date May 04, 2005

Prepared BU PeC - M. Gregori *Mario Gregori*

Verified BU PeC - R. Malgesini *R. Malgesini*

Approved BU PeC - M. de Nigris

**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile del Laboratorio *[Signature]*

CESI  
Centro Elettrotecnico  
Sperimentale Italiano  
Giacinto Motta spa

Via R. Rubattino 54  
20134 Milano - Italia  
Telefono +39 022125.1  
Fax +39 0221255440  
<http://www.cesi.it>

Capitale sociale 8 550 000 Euro  
Interamente Versato  
Codice fiscale e numero  
iscrizione CCIAA 00793580150

Registro Imprese di Milano  
Sezione Ordinaria  
N. R.E.A. 428222  
P.I. IT00793580150

REPUBBLICA ITALIANA

*[Handwritten signature]*  
118

Tests witnessed by:---

Identification of the object:

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object. These drawings, identified by CESI and numbered A5021441 No. 1 to 10 - A5021444 No.1 - A5021445No. 1, have been returned to the Client.

The data necessary to permit repetition of the tests are contained in the document marked: ---

- dielectric tests with impulse voltage : peak voltage: ± 3 %; time parameters: ± 10 %
- dielectric tests with impulse current : peak value: ± 3 %; time parameters: ± 10 %
- dielectric tests with alternating voltage : voltage (rms): ± 3 %
- dielectric tests with direct voltage : voltage: ± 3 %

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values

Laboratory information

Receipt date of the sample February 01, 2005


Test location CESI - Via Rubattino 54 - Milan

CESI testing team Mr L. Podavitte

Test laboratory P177


Activity code 26892R

КОНТРОЛЬНАЯ КОПИЯ

content	page	test date
Test object characteristics	4	 February 09, 2005
Panoramic view of the test object	5	
Reference standard	6	
Test procedure	7	
Summary of test result	7	
Test setting for the partial discharge test	8	
Measurement of partial discharges	9	
Technical data of the test circuit	10 - 11	
Pages annexed: oscillograms n. 03 pages		

**CESI**

**Test Report**



Handwritten signature and a circular stamp.

Rated characteristics of the tested object assigned by the Client

Metal-oxide surge arrester

Manufacturer	Dervasil – Saint Joseph - (France)
Block manufacturer	Epcos
Year of manufacture	2005

Electrical characteristics

Nominal discharge current ( $I_n$ )	10 kA
Line discharge class	1
Rated voltage ( $U_r$ )	36 kV
Continuous operating voltage ( $U_c$ )	29 kV
Rated frequency	50-60 Hz

Geometrical characteristics measured on the test sample

Total height ( only surge arrester)	345 mm
Number of sheds	12
Shed diameter	119 mm
Shed spacing	25 mm
Core diameter	59 mm

Other characteristics

Housing material	silicone rubber
Housing color	grey

Name and signature of Client's witness:

Photograph of the test object




Photo no. 1

BRVOCOPHTHAKA

Handwritten signature and stamp area. Includes a large handwritten signature, a circular stamp, and the number '122'.

Handwritten mark or signature.



Reference Standard

IEC 60099-4 (2004-05): "Metal-oxide surge arrester without gaps for a.c. system", clause 10.8.8

Test carried out and identification of the test objects

Test carried out	Number of test objects	Test object identification
Partial discharge test	1	PD1

M

INSTRUMENTATION DIVISION

J

ly

*(Signature)*

123

**Test procedure**

The application voltage has been increased up to rated voltage ( $U_r$ ) and maintained for 10 sec.

The voltage has been decreased to 1,05 times the continuous operating voltage ( $U_o$ ) and the partial discharge level has been measured according to the reference standard (IEC 60270).

**Summary of test results**

The partial discharge level found was less than 1 pC (background noise).

**The test result is to be considered positive.**

Test setting for the test




Photo no. 2

ROPHO CDUHCWDARA

*[Handwritten signature]*  
*[Handwritten signature]*  
*[Handwritten signature]*

**Measurement of partial discharges**

Test circuit: A0127  
 Measurement circuit: A0022 "direct" calibration: 55 pC/mV see oscillogram. no.01 - background noise  $\leq 1$  pC see oscillogram no.02  
 Arrangement: see pag. 8

Atmospheric conditions and correction factor		
b	$t_a/t_w$	h
kPa	$^{\circ}\text{C}$	$\text{g}/\text{m}^3$
99,70	18(12)	7,39
		Relative umidity
		%
		48,2

Date: February 09, 2005

Test sample	Applied voltage	Duration of voltage application	Temperature of the test object	Partial discharge measurement		Oscillogram	Notes
				voltage increase Q max	voltage decrease Q max		
	KV <sub>ms</sub>	s	$^{\circ}\text{C}$	pC	pC	No.	
MI	36,00	2-10	18	---	---	---	
MI	30,45	60	18		$\leq 1$	03	

continued

*[Handwritten signature]*

**Test Report**


**CESI**

Approved

Page 9

A5/003599

Circuit A0127




Power-frequency high voltage circuit.

- F - wide band rejection filter TELEC; 380 V; 100 A
- G - Faraday cage
- S - single phase circuit breaker SACE; 600 V; 800 A
- R - regulator CORMES; power 66 kVA; voltage 380 V/0+220 V
- TA - current transformer CGS, ratio 150-300 A/5 A
- I - analogic amperometer
- TV<sub>1</sub> - voltage transformer; ratio 440 V/ 100 V
- V<sub>1</sub> - analogic voltmeter
- T - booster transformer PIVI; power 250 kVA; voltage 200-400 V/250 kV
- TV<sub>2</sub> - voltage transformer PIVI; ratio 250 kV/ 100 V
- V<sub>2</sub> - direct reading digital voltmeter FLUKE; CESI No. 06393

*[Handwritten signature and stamp]*

Circuit A0022

Partial discharges measurement  
Direct circuit - Scheme 1a



- P - calibrator CESI; CESI No. 346
- C<sub>k</sub> - coupling capacitor 0,3 nF
- Z<sub>m</sub> - coupling impedance
- RS - partial discharge detector HAEFELY TRENCH type TE 571; CESI No. 13281
- OSC - (not used)

HAEFELY TRENCH TETTEX

PD-DETECTOR

Info: 1

Measurement name:

Comment:

1st PD Range: 100 pC

Noise Suppression: 5 %

Test Measuring Time: 15 s

Start date: 00.00.00


Start time: 00:00

2nd PD Range: Not applied

Lockout Time: 7.3 usec

Voltage Range: 15 kV


Remarks:



CESI PeC A5003599 oscillogram n. 1

СЕРТИФИКАТ

*Handwritten mark*



*Handwritten mark*

CESI PeC A5003599

oscillogram n. 2


ARABIA COPERTURA

*Handwritten mark*

*Handwritten signature*



*[Handwritten mark]*



*[Handwritten mark]*

CESI PeC A5003599      oscillogram n. 3

ВНЕСЕНО В РЕГИСТР

*[Handwritten mark]*

*[Handwritten signature]*

client Dervasil - Saint Joseph (France)

equipment under test Polymer housed metal-oxide surge arrester  
type AZB-36

tests performed Bending moment test

normative documents IEC 60099-4 (2004-05), Clause 10.8.9

receipt date of the sample June 14, 2004

test date from June 17, 2004 to July 16, 2004

no. of pages 21 no. of pages annexed 22

the test results relate only to the sample tested  
this document shall not be reproduced except in full without the written approval of CESI

first issue date July 20, 2004

prepared PeC/TEST - M. Gregori *Mario Gregori*

verified PeC/TEST - A. Sironi *Albert Sironi*

approved PeC/TEST - M. de Nigris

**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove Componenti  
Il Responsabile del Laboratorio *[Signature]*

CESI  
Centro Elettrotecnico  
Sperimentale Italiano  
Giacinto Motta SpA

Via R. Rubattino 54  
20134 Milano - Italia  
Telefono +39 022125.1  
Fax +39 0221255440  
www.cesi.it

Capitale sociale 8 550 000 Euro  
Integramente versato  
Codice fiscale e numero  
Iscrizione CCIAA 00793590150

Registro Imprese di Milano  
Sezione Ordinaria  
N. R.E.A. 429222  
P.I. IT00793590150

BAPMO COOPERATIVA

*[Signature]*

tests witnessed by: /

identification of the object: The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.

The drawing identified by CESI and numbered A4/509437 n. 01, one page, is annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3\%$  ; time parameters:  $\pm 10\%$
- dielectric tests with impulse current : peak value:  $\pm 3\%$  ; time parameters:  $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

CESI testing team: Mr F. Mazzarella


test laboratory: P177 surge arrester laboratory

activity code: 41285B

keywords: 12015R, 23810H, 31020W, 46030U, 53001D

TESTING SERVICES  
CESI

Handwritten signature and stamp area with the number 133.

contents	page	test date
Test object characteristics	4	 June 17, 2004
Reference standard	5	
Test procedure	6	
Summary of test result	7	
Initial measurement	8 ÷ 10	
Test setting for bending application	11 ÷ 12	
Bending application	13	
Water immersion test	13	June 18, 2004 July 13 ÷ 16, 2004
Verification test	14 ÷ 17	July 16, 2004
Technical data of the test circuit	18 ÷ 21	

**Pages annexed:**

- oscillograms n.21 pages
- Dervasil Drawing no.99B524923A; CESI n: A4/509437 n. 01, one page



**Test Report**

AT-A4/5009502

*(Handwritten signatures and marks)*

Test object characteristics

type: Polymer housed metal-oxide surge arrester section

electrical characteristics (claimed by the client)

manufacturer's name	DERVASIL
nominal discharge current - $I_N$ (kA)	10
rated voltage - $U$ (kV)	36
continuous operating voltage - $U_c$ (kV)	29
reference current - $I_{ref}$ (mA)	5
line discharge class	-
rated frequency - (Hz)	50
dynamic cantilever (N*m)	200
year of manufacture	2004

geometrical characteristics (measured on the test sample)

height (mm)	339
number of sheds	11
shed diameter (mm)	115
core diameter (mm)	59,4

other characteristics

housing material	polymeric
housing color	grey

ВЕРИФИКАЦИОННО СЕРТИФИКАЦИОННО СЪОБЩЕНИЕ  
 ВЪВЕДЕНИЕ ВЪВЕДЕНИЕ

*[Handwritten signature]*  
 135

Reference Standard

IEC 60099-4 (2004-05) edition 2.0 at clause 10.8.9.3 for polymer housed surge arresters without enclosure gas volume.

" Metal-oxide surge arrester without gaps for a.c. system"

Test carried out

test carried out	number of sample tested
initial measurements	3
bending application	
water immersion	
test evaluation	

Test object identification

test object names	identification of test sample (given by the client)
polymer housed metal-oxide surge arrester	BM1 - BM2 - BM3

Handwritten signature and stamp area. Includes a stamp with the text "COPIE" and a handwritten number "130" in the bottom right corner.

## Test procedure

The test consisted of the following steps:

## Initial measurement

- Watt losses has been measured at  $0,8 \cdot U_c$
- Internal partial discharge have been measured.  
The application voltage has been increased up to rated voltage ( $U_c$ ) and maintained for 10 sec. Then the voltage has been decreased to 1,05 times the continuous operating voltage ( $U_c$ ) and the partial discharge level has been measured according to the reference standard.
- The lightning impulse residual voltage has been measured at the nominal discharge current  $I_N$

## Bending application

The test sample has been mounted in upright position. The specified load of 200 N\*m (corresponding to 588 N applied to the free terminal on the sample having 339 height) was applied perpendicular to the axis. The load was increased at constant speed, maintained at the specified value for about 60 to 90 seconds and then decreased to zero.

## Water immersion test

The sample has been immersed in a vessel, in boiling deionized water with 1 Kg/m<sup>3</sup> of NaCl for 42 hours. At the end the samples remained in the vessel until the water cooled to 50°C.

## Verification test at ambient temperature

- The visual inspection was carried out
- Watt losses measurement at  $0,8 \cdot U_c$  has been repeated
- Partial discharge measurement has been repeated at  $1,05 \cdot U_c$
- The lightning impulse residual voltage test has been repeated at nominal discharge current  $I_N$

**Summary of test result**

**Visual inspection**

The visual inspection of the polymer housed metal oxide surge arrester after test has revealed no sign of physical damage.

**Bending application**

The force-deflection curve does not show significant discontinuity. The permanent deflection is not significant.

**Electrical measurement**

- variation of watt losses at  $0,8 \cdot U_c$

sample	before test		after test		variation %
	voltage	power	voltage	power	
	kV	W	kV	W	
BM1	24,25	0,394	24,03	0,459	+16,50
BM2	23,82	0,408	23,66	0,389	-4,65
BM3	24,12	0,438	24,02	0,429	-2,05

The variation of watt losses before and after the test was less than 20% (maximum allowed variation according to reference standard is 20%).

- variation of lightning impulse residual voltage at  $I_n$

sample	before test		after test		variation %
	discharge current	residual voltage	discharge current	residual voltage	
	kA	kV	kA	kV	
BM1	10,0	99,42	10,0	100,4	1,0
BM2	10,0	99,61	10,0	100,8	1,2
BM3	10,0	100,2	10,0	101,2	1,0

The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%).

- Measured partial discharge level was less than 1 pC (background noise) before and after the test.

**All acceptance criteria are satisfied. Therefore the test result is positive**

*[Handwritten signature]*

UNOWO C OPIREKLAJA

*[Handwritten signature]*  
*[Circular stamp]*



Power frequency voltage-current characteristics - before bending moment.

test object: Polymer housed metal-oxide surge arrester  
test circuit: A019

date: June 17, 2004

sample no. BM1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	24,25	0,327	0,510	0,233	0,394	---

sample no. BM2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
2	23,82	0,327	0,490	0,238	0,408	---

sample no. BM3						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	24,12	0,306	0,489	0,233	0,438	---

REPUBBLICA ITALIANA

*M*

*[Handwritten signature]*  
*[Handwritten signature]*  
*[Handwritten signature]*

**Measurement of partial discharges - before bending moment**

test object: Polymer housed metal-oxide surge arrester

test circuit: A012

measurement circuit: A022 ("direct" calibration: 50 pC.)

arrangement: ---

atmospheric conditions		
b	t	h
kPa.	°C	g / m <sup>3</sup>
--	25	--

date: June 17, 2004

test condition	applied voltage	duration of voltage application	temperature of the test object	partial discharge measurement		oscillogram	note
				voltage increase	voltage decrease		
	kV <sub>meas</sub>	sec	°C	CRO readout	CRO readout	Q max	Q max
BIM1	36,0	10	25	mV	mV	pC	pC
	30,5	measure	25	--	--	≤ 1	≤ 1
BIM2	36,0	10	25	--	--	≤ 1	--
	30,5	measure	25	--	--	≤ 1	≤ 1
BIM3	36,0	10	25	--	--	≤ 1	--
	30,5	measure	25	--	--	≤ 1	≤ 1

Note: background noise ≤ 1 pC



TESTING CONFIDENTIAL

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

Bending moment test,

lightning impulse residual voltage measurement - before bending moment



test object: Polymer housed metal-oxide surge arrester  
test circuit: A014

date: June 17, 2004

sample no.	requested current	charging voltage kV	oscillogram no.	current waveshape $\mu s$	discharge current kA	residual voltage kV
BM1	$I_N$	63 x 2	4	8,2/19,6	10,0	99,42
BM2	$I_N$	63 x 2	5	8,2/19,6	10,0	99,61
BM3	$I_N$	63 x 2	6	8,2/19,6	10,0	100,2

	oscilloscope settings		
	sampling division $\mu s$	input $V_{div}$	attenuation
current	5	0,5	50:5
voltage	5	0,8	50:5

Test setting for bending application.




ОБЪЕКТОВЫЙ КОД  
ОБЪЕКТОВЫЙ КОД

*[Handwritten mark]*

*[Handwritten signature]*  
142

Test setting for bending application.



ВЕРНО СОБРАНА  
1

*[Handwritten signature]*  
143

**Bending application:**

Test date: June 28, 2004

The test sample was mounted in upright position. The specified load (corresponding to the maximum bending moment of 200 N\*m) was applied perpendicular to the axis to the free end of the surge arrester. The load was increased at constant speed, maintained at the specified value for about 60 to 90 seconds and then decreased to zero.

A view of the test arrangement is shown in the photos pages n. 11 - 12 .

The curve of the load&deflection versus time is shown in the oscillogram n.07 (sample BM1) - n.08 (sample BM2) - n. 09 (sample BM3)

The curve of the load versus deflection is shown in the oscillogram n.10 (sample BM1) - n.11 (sample BM2) - 12 (sample BM3).

**water immersion test:**

Test date: July 13 + 16, 2004

The sample has been immersed in a vessel, in boiling deionized water with 1.Kg/m<sup>3</sup> of NaCl for 4 2 hours. At the end the samples remained in the vessel until the water cooled to 50°C and maintained at this temperature in the vessel until verification tests.

ВИПРОСОРЕТНИЦА

**visual examination:**

test date: July 16, 2004

The surge arrester has been visually inspected;

No sign of physical damage was detected.

TESTING SERVICES

Power frequency voltage-current characteristics --after bending moment.

test object: Polymer housed metal-oxide surge arrester  
test circuit: A019

date: June 16, 2004

sample no. BM1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
13	24,03	0,323	0,300	0,223	0,459	---

sample no. BM2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
14	23,66	0,316	0,293	0,216	0,389	---

sample no. BM3						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
15	24,02	0,321	0,291	0,2176	0,429	---



**Measurement of partial discharges - after bending moment**

test object: Polymer housed metal-oxide surge arrester

test circuit: A012

measurement circuit: A022 ("direct" calibration: 50 pC - see oscillogram no.16)

arrangement: ---

atmospheric conditions	
b	h
kPa	g / m <sup>3</sup>
---	---

date: June 16, 2004

test condition	applied voltage	duration of voltage application	temperature of the test object	partial discharge measurement		oscillogram no.	note
				voltage increase	voltage decrease		
	kV <sub>rms</sub>	sec.	°C	CRO readout mV	Q max pC		
BM1	36,0	10	25	--	≤ 1		
	30,5	measure	25	--	≤ 1	18	
BM2	36,0	10	25	--	≤ 1		
	30,5	measure	25	--	≤ 1	19	
BM3	36,0	10	25	--	≤ 1		
	30,5	measure	25	--	≤ 1	20	

Note: background noise ≤ 1 pC - see oscillogram no.17

АТ-А4/5009502

147

Bending moment test

lightning impulse residual voltage measurement - after bending moment:

test object: Polymer housed metal-oxide surge arrester  
test circuit: A014

date: June 16, 2004


sample no.	requested current	charging voltage kV	oscillogram no.	current waveshape $\mu s$	discharge current kA	residual voltage kV
BM1	$I_N$	63 x 2	21	8,2/19,6	10,0	100,4
BM2	$I_N$	63 x 2	22	8,2/19,6	10,0	100,8
BM3	$I_N$	63 x 2	23	8,2/19,6	10,0	101,2

	oscilloscope settings		
	sampling division $\mu s$	input $V_{div}$	attenuation
current	5	0,5	50:5
voltage	5	0,8	50:5

ВЕРИФИЦИРОВАННО

*[Handwritten signature and stamp]*

**circuit A019**



**power frequency supply**


RE : programmable supply CESI no. 23702-32191 ; type Larcet A.C. Power Source 5000 P.Š.  
 PC : personal computer  
 T : transformer type Specialtrásfo ; power 30 kVA ; voltage 200 V/15-30 kV

current shunt (R) CESI no. 11537 ;  $R = 867,8 \Omega$   
 oscilloscope CESI no.9090  
 type Tektronix RTD 710A

voltage divider (D) CESI no. 11120  $k = 1010$   
 electro optical system CESI no.11519/520 ; attenuation 50:5  
 oscilloscope CESI no.30223-30224  
 type Data Precision DATA 6100

*[Handwritten signature and stamp]*

**circuit A014**



**impulse generator**

plant P177

no. of stages 2

$C_g$  2,49  $\mu F$

$L_c$  18  $\mu H$

S spark gap

current shunt (R) CESI no. 6042;  $R = 0,002\Omega$  ; 100 kA

electro optical system CESI no. 11517/518

oscilloscope CESI no. 13217

type Tektronix TDS 540A

voltage divider (D) CESI no. 13027  $k = 2029$

electro optical system CESI no. 11521/522


oscilloscope CESI no. 13217

type Tektronix TDS 540A

ALPHATECHNOLOGICAL

Handwritten signature and stamp. The stamp is circular and contains the text "CESI" and "TESTING SERVICES".

**circuit A012**



**power frequency test circuit**

- R : regulator type CORMES; power 66 kVA ; voltage 380 V/0 - 0,22 kV
- TA : current transformer CGS; ratio 150-300/5
- I<sub>1</sub> : amperemeter direct reading INDEX.
- TV<sub>1</sub> : voltage transformer CGS ; ratio 220-440/100
- V<sub>1</sub> : voltmeter direct reading TSE
- R<sub>bt</sub> : protection resistor --- Ω
- T : booster transformer PIVI ; power 250 kVA ; voltage 200-400 V/250 kV
- TV<sub>2</sub> : voltage transformer type CGS ; CESI no. 287; ratio 30000/100
- V<sub>2</sub> : voltmeter CESI no. 6393


БЯПРО С ОПИТНАЈА

*[Handwritten signature]*

**circuit A022**

partial discharges measurement

direct circuit  
scheme 1a



$C_k$  : coupling capacitor 0,3 nF

$Z_m$  : coupling impedance



$P$  : calibrator no.Ceși 3466

$RS$  : partial discharge detector HAEFELY TRENCH, Type TE 571, no. CESI 13281

CRO: oscilloscope ( not used )

ВЕРНО СОВЕРШЕНА

*Handwritten mark*





*Handwritten mark*

CESI TEST A4/509502 oscillogram n. 1

ИНТЕРНОВАЦИОНАЛНА

*Handwritten signature and stamp*

*[Handwritten mark]*



*[Handwritten mark]*



РОСНОСОБРЕЩАЈА

CEST TEST A4/509502 oscillogram n. 2

*[Handwritten signature]*

*[Handwritten signature]*






CESI TEST A4/509502 oscillogram n. 3

СЕРТИФИКАТ

B




af

CESI TEST A4/509502 oscillogram n. 4

ВІСНО СОРНИЦІА

*M. Kras*

*[Handwritten mark]*




CESI TEST A4/509502 oscillogram n. 5

AVANTIUM

*[Handwritten signature]*

*[Handwritten mark]*




*[Handwritten mark]*

CESI TEST A4/509502 oscillogram n. 6

*[Handwritten signature]*

*[Handwritten signature]*



CESI TEST A4/509502 oscillogram n. 7


VERBALE

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*



АРХИВНО С ОРИГ. А4/509502 осциллограм n. 8  
 CESI TEST


*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

Handwritten mark at the top of the page.



Legend:  
 — Load [N]  
 - - - Defl [mm]


CESI TEST A4/509502 oscillogram n. 9

Stamp: **ARMANDO TESTA**

Handwritten signature and initials.

Handwritten mark on the right side of the page.

Handwritten initials on the right side of the page.




CESI TEST A4/509502 oscillogram n. 10

ВИАТМЕКОМБИНИ  
 1996

*[Handwritten signature]*






Load [N] Deflection [mm]  
 CESI TEST A4/509502 oscillogram n. 11

АВТОСОБЕДИНАНА

*[Handwritten signature]*





CESI TEST A4/509502 oscillogram n. 12

ARABIA COVETTRAJA

*(Handwritten signature)*

B





0.000

CESI TEST A4/509502 oscillogram n. 13

ВЛ В ОРИГИНАЛА

Handwritten signature and stamp area.

*B*



*BY*

CESI TEST A4/509502 oscillogram n. 14.



ВЕРНО СОСЛОВАЯ

*BY*

*M. Krap*

106

3




Handwritten signature or initials.


**CESI TEST** A4/509502 oscillogram n. 15  
ВИРНО СОРТИЦАЛА

Handwritten signature and a circular stamp.

oscillogram no.16




oscillogram no.17




CESI TEST A4/509502


ВІСНОСОПРІТІВНА



oscillogram no.18



oscillogram no.19



CESI TEST A4/509502


*[Handwritten mark]*

АНТИКОРРУПЦИЈА

*[Handwritten signature]*



oscillogram no.20




oscillogram no.--

CESI TEST A4/509502

ВЯЧНО С ОРГАНІЗАЦІЇ



*Handwritten mark*




CESI TEST A4/509502 oscillogram n. 21

*Handwritten signature*

ВЕРНО СОВЕТОВАЛА

*Handwritten signature*  
*Handwritten signature*

B



CESI TEST A4/509502 oscillogram n. 22

*[Handwritten mark]*

ВНИМАТЕЛЬНО ЧИТАЙТЕ

*[Handwritten signature]*


*[Handwritten signature]*

*[Handwritten signature]*

172

3

Tek Stop Single Seq 10.0MS/s



97


91

CESI TEST A4/509502 oscillogram n. 23


91

RECEIVED  
M. King

10. Plans / Drawings



ECHELLE 1:2



**CESI**

PROTOCOLLO DATA

41509437.1 3 30.03.2004

Firma: *Marco Geronzi*

N° MOD.	IND.	DESIGNATION	VISA	DATE
A		cedula		

N° PLAN	Intitulé	Designation	Reference	Notice	Observation

**MODULE AZB 36**



route de FOURENOT - 42800 ST JOSEPH  
SA : 0477/523.98, Fax : 0477/523.99

DESIGNE PAR : <b>LD</b>	POURQUOI : <b>AS</b>
DATE : 09/03/2004	RECHAPE : <b>HL</b>
VERIFIE PAR :	DATE :
PLAN - DEVIANT N° : 22400 N°	
<b>99B524923A</b>	

ВЕРИФИКАЦИОНА

*[Signature]* 27

client Dervasil - Saint Joseph (France)

equipment under test Polymer housed metal-oxide surge arrester  
type AZB 36

tests performed Moisture ingress test

normative documents IEC 60099-4 (2004-05), Clause 10.8.13

receipt date of the sample May 03, 2004

test date from June 17, 2004 to July 16, 2004

no. of pages 24 no. of pages annexed 7

the test results relate only to the sample tested  
this document shall not be reproduced except in full without the written approval of CESI

first issue date July 20, 2004

prepared PeC/TEST - M. Gregori *Mario Gregori*

verified PeC/TEST - A. Sironi *Alberto Sironi*

approved PeC/TEST - M. de Nigris

**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile del Laboratorio

CESI  
Centro Elettrotecnico  
Sperimentale Italiano  
Giacinto Motta SpA

Via R. Rubattino 54  
20134 Milano - Italia  
Telefono +39 022125.1  
Fax +39 022125440  
www.cesi.it

Capitale Sociale 8 550 000 Euro  
interamente versato  
Codice fiscale a numero  
iscrizione CCIAA 00793580150

Registro Impresa di Milano  
Sezione Ordinaria  
N. R.E.A. 429222  
P.I. IT00793580150

PROCOMPENSAZIONE

tests witnessed by: /

**identification of the object:** The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.

The drawing identified by CESI and numbered A4/509437 n. 01, one page, is annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with impulse current : peak value:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

**laboratory information**


CESI testing team: Mr L. Podavitte

test laboratory: P177 surge arrester laboratory



activity code: 41285B

keywords: 12015R, 23810H, 31020W, 46030U, 53001D

ALPHACOM SYSTEMS

contents	page	test date
Test object characteristics Photograph of polymer housed metal-oxide surge-arrester Reference standard Test procedure Summary of test result Initial measurement Preconditioning test Water immersion test Verification test Technical data of the test circuit	4 5 6 7 8 9 ÷ 11 12 ÷ 15 16 17 ÷ 20 21 ÷ 24	 June 17, 2004 June 21 ÷ 25, 2004 July 13 ÷ 16, 2004 July 16, 2004
Pages annexed: - oscillograms n.6 pages - Dervasil Drawing no.99B524923A; CESI n. A4/509437 n. 01, one page		

ВЕРНО СОРВАНУВА

**Test Report**



AT-A4/509306

Test object characteristics

type: Polymer housed metal-oxide surge arrester section

electrical characteristics (claimed by the client)

manufacturer's name	DÉRVASIL
nominal discharge current - $I_n$ [kA]	10
rated voltage - $U_r$ [kV]	36
continuous operating voltage - $U_c$ [kV]	29
reference current - $I_{ref}$ [mA]	5
line discharge class	1
rated frequency - [Hz]	50
torque load [N*m]	30
static cantilever [N]	300
year of manufacture	2004

geometrical characteristics (measured on the test sample)

height [mm]	339
number of sheds	11
shed diameter [mm]	115
core diameter [mm]	59,4

other characteristics

housing material	polymeric
housing color	grey


ΒΡΗΤΙΚΟ ΣΟΦΙΣΤΕΥΜΑ

*[Handwritten signatures and stamps]*



3

Photograph of polymer housed metal-oxide surge arrester.



cc

cc

Handwritten signature or mark.

Handwritten initials.

Handwritten signature and a circular stamp.

**Reference Standard**

IEC 60099-4 (2004-05) edition 2.0 Clause 10.8.13  
" Metal-oxide surge arrester without gaps for a.c. system"

**Test carried out**

test carried out	number of sample tested
initial measurement	1
mechanical preconditioning	
Water Immersion test	
verification test	

**Test object identification**

test object names	identification of test sample (given by the client)
polymer metal-oxide surge arrester	MI

*Handwritten mark*

*Handwritten mark*

*Handwritten signature and stamp*

**Test procedure on samples MI****Initial measurement**

- Watt losses has been measured at  $0,8 \cdot U_c = 23,2 \text{ kV}_{rms}$
- Internal partial discharge have been measured.  
The application voltage has been increased up to rated voltage ( $U_r$ ) and maintained for 10 sec.  
The voltage has been decreased to 1,05 times the continuous operating voltage ( $U_c$ ) and the partial discharge level has been measured according to the reference standard.
- The lightning impulse residual voltage has been measured at nominal discharge current  $I_N$

**Terminal torque pre-conditioning**

- The terminal torque at the value, specified by the manufacturer (30 N\*m), has been applied for 30 second.

**Thermomechanical preconditioning**

- The specimens have been submitted to two 48h thermal cycles of heating and cooling (see fig.6 of the reference standard) while mechanically loaded. The temperature was ranging from +60°C to -40°C. The mechanical load consisted of a cantilever load at the value specified by the manufacture (i.e, 300 N applied to the free terminal). The direction of the load was changed every 24 hours as specified on fig.6 of the reference standard.

**Water immersion test**

- The sample has been immersed in a vessel, in boiling deionized water with 1 Kg/m<sup>3</sup> of NaCl for 42 hours. At the end the samples remained in the vessel until the water cooled to 50°C.

**Verification test at ambient temperature**

- Visual inspection
- Watt losses at  $0,8 \cdot U_c$  has been repeated
- Partial discharge has been repeated at  $1,05 \cdot U_c$
- The lightning impulse residual voltage has been repeated at nominal discharge current  $I_N$

ВЕРНО СОПРЯЖАНА

Visual inspection and summary of test result

- The visual inspection of the polymer housed metal oxide surge arrester after test has revealed no sign of physical damage.
- variation of watt losses at  $0,8 \cdot U_c$

sample	before test		after test		variation %
	voltage	power	voltage	power	
	kV	W	kV	W	
MI	24,11	0,497	23,90	0,435	- 12,47

The variation of watt losses before and after the test was less then 20% (maximum allowed variation according to reference standard is 20%).

- variation of lightning impulse residual voltage at  $I_W$

sample	before test		after test		variation %
	discharge current	residual voltage	discharge current	residual voltage	
	kA	kV	kA	kV	
MI	10,0	101,4	10,0	101,9	0,5

The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%).

- Measured partial discharge level was less than 1 pC (background noise) before and after the test.

All acceptance criteria are satisfied. The test result is positive.

**Power loss measurement - before preconditioning.**

test object: Polymer housed metal-oxide surge arrester  
test circuit: A019

date: June 17, 2004

oscill.	voltage	sample no. MI			power	3rd harmonic amplitude
		current	current	current		
no.	kV	mA <sub>gr</sub>	mA <sub>gr</sub>	mA <sub>rms</sub>	W	μA
1	24,11	0,306	0,49	0,235	0,497	---

TESTING SERVICES  
BROOKLYN, NY

**Measurement of partial discharges - before preconditioning**

test object: Polymer housed metal-oxide surge arrester

test circuit: A012

measurement circuit: A022 ("direct" calibration : 50 pC.)

arrangement: ---

atmospheric conditions		
b	t	h
kPa	°C	g / m <sup>3</sup>
---	25	---

date: June 17, 2004.

test condition	applied voltage	duration of voltage application	temperature of the test object	partial discharge measurement				oscillogram	note
				voltage increase	voltage decrease	CRO readout	Q max		
	kV <sub>max</sub>	sec.	°C	mV	mV	mV	pC		
MI (36 kV)	36,0	10	25	---	---	---	---		
	30,5	measure	25				≤ 1		

Note: background noise ≤ 1 pC

ВЕРНО СОПРОВОЖДАЕТСЯ

*[Handwritten signature]*  
 182



Test Report

AT-A4/509306

Moisture ingress test.

lightning impulse residual voltage measurement: - before preconditioning

test object: Polymer housed metal-oxide surge arrester  
test circuit: A014

date: June 17, 2004

sample	requested current	charging voltage	oscillogram	current waveshape	discharge current	residual voltage
nó.		kV	nó.	$\mu s$	kA	kV
M1	I <sub>w</sub>	63,0 x 2	2	8;2/19,6	10,0	101,4

	oscilloscope settings		
	sampling division	input	attenuation
	$\mu s$	V <sub>div</sub>	
current	5	0,5	50:5
voltage	5	1,0	50:5

**Preconditioning test:**

- **Terminal torque pre - conditioning**

test date: June 21, 2004

- The terminal torque at the value, specified by the manufacturer (30 N\*m), has been applied for 30 second.

- **Thermomechanical preconditioning**

test date: June 21.+ June 25, 2004.

sample	applied load	lower temperature	upper temperature	duration of temperature application	cycles, n,	load direction
no.	N	°C	°C	h		degree
MI	300	--	60	24	1	0
MI	300	- 25	--	24	1	180
MI	300	--	+ 45	24	2	270
MI	300	- 40	--	24	2	90


*Handwritten signature*

*Handwritten signature and stamp*



*B*

Test setting for terminal torque pre - conditioning



*J*


*M*

*y*

*M. Kovacs*  
187

*B.*

Test setting for thermomechanical pre - conditioning



*Q*


*Q*

*M. K...*

188

Temperature cycle about thermomechanical pre - conditioning

Moisture ingress test



start date: 21/06/2004


water immersion test:

development

Test date: July 13+16, 2004

The sample has been immersed in a vessel, in boiling deionized water with 1 Kg/m<sup>3</sup> of NaCl for 42 hours. At the end of boiling, the specimens remained in the vessel until the water cools to approximately 50°C and maintained at this temperature in the vessel until verification tests started.

ВІСНОВОК С ОФІСНОЮ ПРАКТИКОЮ



**visual examination:**

test date: July 16, 2004

The housing of the specimen has been inspected visually.

No visible damage or permanent deformation were noted.

Handwritten initials or signature on the right side of the page.

ВНПРОСОУЛТНАЈА

Handwritten signature and a circular stamp at the bottom right of the page.



Power loss measurement - after preconditioning.

test object: Polymer housed metal-oxide surge arrester  
test circuit: A019

date: July 16, 2004

oscill. no.	voltage kV	sample no. MI			power W	3rd harmonic amplitude $\mu$ A
		current + mA <sub>cr</sub>	current - mA <sub>cr</sub>	current mA <sub>rms</sub>		
3'	23,9	0,312	0,286	0,213	0,435	"

УПРАВЛЕНИЕ  
ТЕСТОВЫМИ СЛУЖБАМИ  
ИЗМЕРЕНИЙ

**Measurement of partial discharges - after preconditioning**

test object: Polymer housed metal-oxide surge arrester  
 test circuit: A012  
 measurement circuit: A022 ("direct" calibration: 50 pC/mV, see oscillogram n.04)  
 arrangement: ----

atmospheric conditions			
b.	t	h	
kPa	°C	g / m <sup>3</sup>	
---	27	---	---

date: July 16, 2004

test condition	applied voltage	duration of voltage application	temperature of the test object	partial discharge measurement				oscillogram	note
				voltage increase	voltage decrease	CRO readout	Q max		
	kV <sub>rms</sub>	sec.	°C	CRO readout	Q max	mV	pC	no.	
MI (36)	36,0	10	27	---	≤ 1	---	---	---	
	30,5	measure	27				≤ 1	.06	

Note: background noise ≤ 1 pC, see oscillogram n.05



Test Report

AT-A4/509306

p.19

*[Handwritten signatures and stamps]*

**Moisture Ingress test.**

lightning impulse residual voltage measurement - after preconditioning

test object: Polymer housed metal-oxide surge arrester  
test circuit: A014

date: July 16, 2004


sample	requested current	charging voltage	oscillogram	current waveshape	discharge current	residual voltage
no.		kV	no.	$\mu s$	kA	kV
MI	$I_N$	63,0 x 2	07	8,2/19,6	10,0	101,9

	oscilloscope settings		
	sampling division	input	attenuation
	$\mu s$	V <sub>div</sub>	
current	5	0,5	50:5
voltage	5	1,0	50:5

ВЕРНО КОМПЬЮТЕРНО



**circuit A019**



**power frequency supply**

RE : programmable supply CESI no. 23702-32191 ; type Larcet A.C. Power Source 5000 P.S.

PC : personal computer

T : transformér type Specialtrafo ; power 30 kVA ; voltage 200 V/15-30 kV

current shunt (R) CESI no. 11537 ;  $R = 811,94 \Omega$  ;

oscilloscope CESI no.9090

type Tektronix RTD 710A

voltage divider (D) CESI no. 11120  $k = 1010$

electro optical system CESI no.11519/520 ; attenuation 50:5


oscilloscope CESI no.9090

type Tektronix RTD 710A

СЕРТИФИКАЦИЯ  
ИЗДАНИЕ 01

Handwritten signature and stamp.

**circuit A014**



**impulse generator**

plant P177

no. of stages 1

$C_g$  4,98  $\mu F$

$L_c$  8  $\mu H$

S spark gap

current shunt (R) CESI no. 6042;  $R = 0,002\Omega$  ; 100 kA

electro optical system CESI no. 11517/518

oscilloscope CESI no. 13217

type Tektronix TDS 540A

voltage divider (D) CESI no. 13027  $k = 2029$

electro optical system CESI no.11521/522

oscilloscope CESI no.13217

type Tektronix TDS 540A


ВРНО СОВЕТСКАЯ

*[Handwritten signature]*

*[Handwritten signature]*

196

**circuit A012**



**power frequency test circuit**

- R : regulator type CORMES; power 66 kVA ; voltage 380 V/0 - 0,22 kV
- TA : current transformer CGS; ratio 150-300/5
- I<sub>1</sub> : amperometer direct reading INDEX
- TV<sub>1</sub>: voltage transformer CGS ; ratio 220-440/100
- V<sub>1</sub> : voltmeter direct reading TSE
- R<sub>pt</sub> : protection resistor --- Ω
- T : booster transformer PIVI ; power 250 kVA ; voltage 200-400 V/250 kV
- TV<sub>2</sub>: voltage transformer type CGS ; CESI no. 287; ratio 30000/100
- V<sub>2</sub> : voltmeter CESI no. 6393


РПНПО СЕРТИФИКАЦИЯ

Handwritten signature and stamp area.

**circuit A022**

partial discharges measurement

direct circuit  
scheme 1a



$C_k$  : coupling capacitor 0,3 nF



$Z_m$  : coupling impedance

P : calibrator no.Cesi 3466

RS : partial discharge detector HAEFELY TRENCH, Type TE 571, no. CESI 13281

CRO: oscilloscope ( not used )

3




CESI TEST A4/509306 oscillogram n. 1

ВЕРНО СОБРАНА

*[Handwritten signature]*

*[Handwritten signature]*  
*[Handwritten signature]*

*Handwritten mark*





*Handwritten mark*

CESI TEST A4/509306 oscillogram n. 2

ВІСНОК ДІЯЛЬНОСТІ

*Handwritten signature and stamp*

13




CESI TEST A4/509306 oscillogram n. 3


ВЕРНО СОПРЯЖА

*[Handwritten signature]*

oscillogram no.04.



oscillogram no.05




CESI TEST A4/509306

REPRODUCTION




oscillogram no.06



CESI TEST A4/509306

ИМПРО С ОПЕТИНАЈА

*Handwritten mark*



*Handwritten mark*



CESI TEST A4/509306 oscillogram n. 7

ВЕРИФИКАЦИОНА

*Handwritten signatures and stamps*

204

10. Plans / Drawings




PROTOCOLLO DATA  
**CESI**  
 : 4150848711 + 3 AGO 2004  
 Firma: *Nicola Geronzi*

N° MOD. IND.	DESIGNATION	VERA	DATA
A	catolico		

**MODULE AZB 36**

N° PLAN	ref/rd absc	Designation	Reference	Notice	Observation
TOURNAGES SIMILAIRES : <input type="checkbox"/> TRAITEMENT : <input type="checkbox"/> GALVANISATION A CHAUD SELON SA USURE <input type="checkbox"/> AUTRES (voir dessin)					



Usine de FORTENOT - 43900 ST JEANNE  
 Tel : 0477352928 Fax : 0477352929

PLANT - DRAWING N° - 99B524923A  
**99B524923A**

DESIGNER PAR : LD	FORMAT : A3
DATE : 09/03/2004	EGRÈSSE : H
VERIFIE PAR :	ZAGE : JJ

client **Dervasil - Saint Josaph (France)**

equipment under test **Polymer housed metal-oxide surge arresters Type AZB 27**

tests performed **Weather ageing test - Test series A**

normative documents **IEC Standard 60099-4 Edition 2.0 (2004-05).**

receipt date of the sample **May 24, 2004**

test date **from July 8, 2004 to August 24, 2004**

no. of pages **22** no. of pages annexed **8**

the test results relate only to the sample tested  
 this document shall not be reproduced except in full without the written approval of CESI

first issue date **May 12, 2005**

prepared **PeC/TEST - G. Fedeli**

verified **PeC/TEST - A. Sironi**

approved **PeC/TEST - M. de Nigris**

*G. Fedeli*  
*A. Sironi*

**CESI**  
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
 Business Unit  
 Prove di Componenti  
 Il Responsabile del Laboratorio

CESI  
 Centro Elettrotecnico  
 Sperimentale Italiano  
 Giacinto Ilotta SpA

Via R. Rubattino 54  
 20134 Milano - Italia  
 Telefono +39 0221251  
 Fax +39 0221255440  
 www.cesi.it

Capitale sociale 8.550.000 Euro  
 interamente versato  
 Codice fiscale e numero  
 iscrizione CCIAA 03708580160

Registro Imprese di Milano  
 Sezione Circolari  
 N. R.E.A. 429222  
 P.I. IT00783590160

CENTRO COPIE/STAMPATE

*M. de Nigris*  
*P. K...*

tests witnessed by: /

identification of the object: Performed

The Manufacturer guarantees that the tested surge arrester is manufactured according to the submitted drawings.

CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawings identified by CESI and numbered A5/021441 no.1 to 10 have been returned to the Client.

The data necessary to permit repetition of the tests are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with impulse current : peak value:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3 \%$
- dielectric tests with direct voltage : voltage:  $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

CESI testing team: G. Fedeli

test laboratory: P188

activity code: 41285B

keywords: 12015R 23801L 31020W 44060J 53001D

ASPHO CONSTRUCTION


contents	page	test date
Test object	4	
Test carried out and test procedure	8	
Summary of test result	9	
Initial measurements	11	05/12/04
Weather ageing test. Test circuit	13	
Weather ageing test. Test arrangement	14	
Weather ageing test. Pictures after the test	16	07/08/04 to 08/24/04
Final measurements	21	08/30/04
Reference documents annexed:  Oscillograms (8 pages), CESI no. A4/510342		

B

ATKINS CONSULTANTS

*[Handwritten signature]*

*[Handwritten signature]*



AT-A5/022740

Test Report

**Test object**

Type: Two polymer housed metal-oxide surge arrester type AZB 27.  
The test objects were identified by Cesi as sample W1 and sample W2.

electrical characteristics (claimed by the client)

manufacturer's name	DERVASIL - Saint Joseph (France)
nominal discharge current - $I_N$ [kA]	10,0
rated voltage - $U_n$ [kV]	27,0
continuous operating voltage - $U_c$ [kV]	22,0
line discharge class	1
rated frequency - [Hz]	50

Dimensional characteristics of the test objects, claimed by the Client:

total height [mm]	272,4
sheds diameter [mm]	119
core diameter [mm]	59,4

APPROVED BY:

3

Dimensional characteristics of the test objects measured by Cesi

total height [mm]	270
creepage distance [mm]	711
arching distance [mm]	297
number of sheds [n]	9
sheds diameter [mm]	116
core diameter [mm]	59,5
sheds spacing [mm]	25
sheds projection [mm]	30

9


ВЕРНО С ОРИГИНАЛОМ  
ИЛИ КОПИИ

9  
A. Kous



*B*

Picture of the test object W1



*CC*

*CC*

*CC*

ИЗДАНИЕ  
ИЗДАНИЕ

*g*


*A. Koval*

*g*

*200*



Picture of the test object W2



ВЯЧНО С ОРГАНІЗАЦІЄЮ  
[Signature]

## Test carried out and test procedure

Test has been carried out according with IEC Standard 60099-4 (2004-05) edition 2.0 "Metal-oxide surge arrester without gaps for a.c. system", at clause 10.8.14 .

## Initial measurement

- The reference voltage have been measured at reference current equal to  $5 \text{ mA}_{pk}$
  - Internal partial discharge have been measured.
- The application voltage has been increased up to rated voltage ( $U_r$ ) and maintained for 10 sec. The voltage has been decreased to 1,05 times the continuous operating voltage ( $U_c$ ) and the partial discharge level has been measured according to the reference standard.

## Weather ageing test. Test series A: 1000 hours

Note: During the weather ageing test, the test objects were tested in parallel with a Dervasil insulator.

The test samples have been assembled in the test room in vertical position spaced each-other and from the chamber walls in order to avoid electrical field disturbance.  
Test objects have been cleaned with deionized water before starting the test.

The surge arresters have been energized at  $U_{test} = 22 \text{ kV}_{rms}$  and kept for a total duration of 1000 hours in the test room filled with salt fog.

The water flow rate was  $0,4 \pm 0,1 \text{ l/h} \cdot \text{m}^3$

At the beginning the salinity of the water solution was  $10 \text{ Kg/m}^3$ . Then it has been decreased to  $5 \text{ Kg/m}^3$  after 591 hours, and to  $2,5 \text{ Kg/m}^3$  after 610 hours (see the paragraph "summary of test result").

The salt fog was not directly sprayed against the test specimens.

A scheme and a view of the test configuration are shown at pages 14 and 15.

The test sample has been visually inspected after about 500 hours and at test completion.  
Photos were taken at the end of the test.

## Final measurement

The initial measurement were repeated.

Summary of test result

Test series A: 1000 hours

The external flashovers occurred during the test are noted in table below. The test salinity had to be changed twice.

sample W1	sample W2	test salinity	salinity change
1 <sup>st</sup> Flashover after 565 h		10 g/l	
2 <sup>nd</sup> Flashover after 591 h		10 g/l	from 10 to 5 g/l
3 <sup>rd</sup> Flashover after 595 h		5 g/l	
	1 <sup>st</sup> Flashover after 610 h	5 g/l	from 5 to 2,5 g/l
	2 <sup>nd</sup> Flashover after 976 h	2,5 g/l	
	3 <sup>rd</sup> Flashover after 981 h	2,5 g/l	

Visual inspection

Note: Sheds are numbered starting from the live side.

- After 500 hours

No tracking, shed puncture or significant erosions have been evidenced by the visual inspection carried out after 500

- After 1000 hours

Sample W1:

An overall view of the object after 1000 hours is shown in the photo at page 16.

No tracking, significant erosion or puncture was observed.

Shallow and diffuse erosions were visible on all circumference of the core between sheds n.2 and n.3 and, in less diffused way, also on the core between sheds n.3 and n.4 (see photo at page 17).

Sample W2:

An overall view of the object after 1000 hours is shown in the photo at page 18.

No tracking, significant erosion or puncture was observed.

Shallow erosions on the cores between sheds n.2-3, sheds n.4-5 and sheds n.6-7 (see photo at page 19).

Shallow and diffuse erosions were visible on all circumference of core between sheds n.8 and n.9 (see photo at page 20).

Variation of the reference voltage

Type	before test	after test	variation %
	kV	kV	
W1	27,26	27,9	+ 2,3
W2	28,03	28,4	+ 1,3

Acceptance criteria: satisfied

Partial discharge level

Type	before test	after test
	pC	pC
W1	<1	<1
W2	<1	<1

Acceptance criteria: satisfied

Conclusion: the acceptance criteria specified by the standard are satisfied. The test result is positive.

ВЕРНО СОБЛЮЩАКА

Measurement of the reference voltage - initial

test object: Polymer housed metal-oxide surge arresters  
test circuit: /

date: May 12, 2004

sample W1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	27,26	4,94	4,82	1,04	25,18	/

date: May 12, 2004

sample W2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
2	28,03	3,95	5,04	1,37	23,80	/

*[Handwritten signature]*

**Measurement of partial discharges - initial**

test object: Polymer housed metal-oxide surge arresters

test circuit: /

measurement circuit: /

arrangement: ----

atmospheric conditions			
b	t	h	
kPa	°C	g / m <sup>3</sup>	
/	24	/	/

date: May 13, 2004

sample W1

test condition	applied voltage	duration of voltage application	temperature of the test object	voltage increase Q max	voltage decrease Q max	oscillogram	note
rated voltage	kV <sub>rms</sub> 27	sec 10	°C 24	pC /	pC /	no. /	/
22 x 1,05	23,1	/	24	/	≤ 1	/	/

sample W2

test condition	applied voltage	duration of voltage application	temperature of the test object	voltage increase Q max	voltage decrease Q max	oscillogram	note
rated voltage	kV <sub>rms</sub> 27	sec 10	°C 24	pC /	pC /	no. /	/
22 x 1,05	23,1	/	24	/	≤ 1	/	/


ИЗДАНИЕ 01.05.2004



Test Report

AT-A5/022740

**Weather ageing test.**



**power frequency test circuit (plant P188)**

- R : regulator type M.E.S.A.; power 66 kVA ; output voltage 220 V ; CESI no. 29991
- TA : current reducer ; ratio 150A / 5A
- TV<sub>1</sub>: voltage reducer ; ratio 220V / 100V
- V<sub>1</sub> : direct reading voltmeter
- T : booster transformer PIVI type TMO/230 ; power 50 kVA ; ratio 220 V / 30 kV ;  
primary current 227 A ; secondary current 1,67 A ; CESI no. 38675
- TV<sub>2</sub>: voltage reducer CGS type VSO 534 ; CESI no. 287 ; ratio 30/0,1 kV
- V<sub>2</sub> : voltmeter ANALOGIC Type DP100 ; CESI no. 9533

**check of the test circuit**


date: August 8, 2004

low voltage				high voltage k = 300		k <sub>1</sub>
V <sub>1</sub>	V <sub>bt</sub>	I <sub>1</sub>	I <sub>bt</sub>	V <sub>2</sub>	V <sub>AT</sub>	V <sub>AT</sub> /V <sub>1</sub>
V	V	A	A	V	kV	
/	/	/	/	50,1	15,0	/
/	/	/	/	73,3	22,0	/
/	/	/	/	/	/	/

*[Handwritten signature]*



Weather ageing test. Test arrangement  
Plant: pollution test room planimetry



Test room volume: 360m<sup>3</sup>

B: bushing


N: spray nozzles. Number of spray nozzles: 4

W1, W2: test objects

БІЛГІ СОРУПНА

3

Picture of the test arrangement




ВСПОСОБИТЕЛНА

*[Handwritten signature]*

*[Handwritten signature]*  
*[Circular stamp]*

Picture of the test sample W1 after the test



*[Handwritten signature]*

*[Handwritten signature]*


*[Handwritten signature]*

ЯНУАРИ СОРБИРАНА

*[Handwritten signature]*  
*[Circular stamp]*

*B*

Picture of the test sample W1 after the test



*Q*

*h*


ВАРНО СОРБЕНЦИЈА

*Q*

*M. Kovac*

3

Picture of the test sample W2 after the test



CP

04

ВНТРО СОРНІТІАЖА

9

M. Koval  
223

Picture of the test sample W2 after the test



*CS*

ВАРНО СОПРУЖАВА

*M. Konec*

224

Picture of the test sample W2 after the test



*[Handwritten signature]*

ВЕРНО СОПРЯВЛЕНО

*[Handwritten signature]*

*[Handwritten signature]*

B

Measurement of the reference voltage - Final

test object: Polymer housed metal-oxide surge arresters  
test circuit: /

date: August 30, 2004

sample W1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	27,9	4,88	5,04	/	/	/

date: August 30, 2004

sample W2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
4	28,4	4,32	5,04	/	/	/

*[Handwritten mark]*

*[Handwritten signatures and stamps]*

BRNHO U OPIFHUAJM



**Measurement of partial discharges - Final**

test object: Polymer housed metal-oxide surge arresters

test circuit: /

measurement circuit: /

arrangement: ----

atmospheric conditions			
b	t	h	
kPa	°C	g / m <sup>3</sup>	
/	25	/	/

date: August 30, 2004

Sample W1

test condition	applied voltage	duration of voltage application	temperature of the test object	voltage increase Q max	voltage decrease Q max	oscillogram	note
rated voltage	kV <sub>rms</sub> 27	sec 10	°C 25	pC /	pC /	no. /	/
22 x 1,05	23,1	/	25	/	≤ 1	7	/

Sample W2

test condition	applied voltage	duration of voltage application	temperature of the test object	voltage increase Q max	voltage decrease Q max	oscillogram	note
rated voltage	kV <sub>rms</sub> 27	sec 10	°C 25	pC /	pC /	no. /	/
22 x 1,05	23,1	/	25	/	≤ 1	8	/



Note: background noise ≤ 1 pC, see oscillogram n.5  
"defect" calibration: 50 pC - see oscillogram n.6



**Test Report**

AT-A5/022740



oscillogram no.01



CESI TEST A4510342

ВІРНО СОРТИЦАЛА

oscillogram no.02



CESI TEST A4510342


ВАННО СОФИМЕНАЈА

*[Handwritten signature]*

*[Handwritten signature]*

*B*

oscillogram no.03



30 Aug 2004  
13:52:48

*g*


CESI TEST A4510342

ВІСНОВОК ОПИТУВАННЯ

*g*  
*U. Kosep*  
*U*

*B*

oscillogram no.04



*Q*


CESI TEST A4510342

ВЕРИФІКАЦІЯ

*[Signature]*

*B*

oscillogram no.05



*B*


CESI TEST A4510342

ВЫХО С ОПИТОВАНА

*A. Kuznetsov*

*B*

oscillogram no.06




CESI TEST A4510342

ВМНО С О Р Т И Л И Я

*Handwritten signature*

oscillogram no.07



CESI TEST A4510342


БЯРНО СОУПІВНА МА

230



B

oscillogram no.08



CESI TEST A4510342

ВЕРНО С ОРИГИНАЛА

*[Handwritten signature]*  
*[Handwritten signature]*  
*[Handwritten signature]*

235

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ВЕНТИЛЕН ОТВОД ТИП AZC  
150 И ВЕНТИЛЕН ОТВОД ТИП AZC 270**

1. Изпитание на изолационната устойчивост на корпуса на вентилния отвод
2. Изпитание на остатъчно напрежение
3. Изпитание за устойчивост на дълготраен токов импулс
4. Изпитание при работен режим с високо-токов импулс:
  - Изпитание с ускорено стареене
  - Изпитание при режим с високо-токов импулс и комутационно пренапрежение
5. Изпитание на късо съединение
6. Изпитание с вътрешно частично разреждане
7. Изпитание на огъващ момент
8. Изпитание с проникване на влага
9. Изпитание с атмосферно стареене


Съставил:



A handwritten signature in black ink is written over a circular stamp. The signature is stylized and appears to be 'A. Kovacs'. The stamp is partially obscured by the signature.



A handwritten signature in black ink, consisting of a single large, sweeping stroke.



A handwritten signature in black ink is written over a circular stamp. The signature is stylized and appears to be 'A. Kovacs'. The stamp is partially obscured by the signature.

Manufacturer: DERVASIL..... Surge Arrester Type: . AZBD.....

**dervasil**

TEST DESIGNATION	Clauses of IEC 60099-4 (2006-07)	Laboratory	Laboratory accreditation	Validity of accreditation	Test Report Number	Test dates	Report date	Requested Sample to be tested according IEC 60099-4	Tested Samples	Comments
DRY LIGHTNING IMPULSE WITHSTAND VOLTAGE TEST	8.2.6	EGU (Czech Rep)	CAI N°110/2006	30.4.2011	9422/08	13.11.2008	20.11.2008	on Longuest housing i.e AZBD 42	AZBD 42 Ur = 42 kV Uc = 35 kV	
	8.2.8	EGU (Czech Rep)	CAI N°110/2006	30.4.2011	9422/08	13.11.2008	20.11.2008	on Longuest housing i.e AZBD 42	AZBD 42 Ur = 42 kV Uc = 35 kV	
	8.3	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A8007148	1.4.2008	23.9.2008	As authorized by IEC test has been performed on Metal Oxide Resistor Ur = 6 kV	Metal oxide resistor for arrester type AZBD Ur= 6 IV	
LONG DURATION CURRENT IMPULSE WITHSTAND TEST	10.8.4	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A8018267	1.4.2008	3.9.2008	As authorized by IEC test has been performed on Surge Arrester section Ur = 9 kV	AZBD 090 Ur = 9 kV Uc = 8,4 kV	Energy max of choc = 15,98 kJ which corresponds to 1,9 kJ/kv Uc

ATTESTAZIONE

237

HIGH CURRENT IMPULSE OPERATING DUTY TEST	10.8.5	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A8018272	1.4.2008	3.9.2008	As authorized by IEC test has been performed on Surge Arrester section with disconnector and support Ur = 9 kV	AZBD 090 Ur = 9 kV Uc = 8,4 kV	Energy max of choc = 33,1 kJ which corresponds to 3,94 kJ/kv Uc
DISCONNECTOR TEST	8.6.3.1	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A5/8453	8.3.2005	14.3.2005		Disconnector	
INTERNAL PARTIAL DISCHARGE TEST	10.8.8	EGU (Czech Rep)	CAI N°110/2006	30.4.2011	9422/08	13.10.2008	20.11.2008	on Longuest housing i.e AZBD 42	AZBD 42 Ur = 42 kV Uc = 35 kV	
TEST OF BENDING MOMENT	10,8,9	Dervasil Lab			N°224	28/10/2008	28.10.2008	on Longuest housing i.e AZBD 42	AZBD 42 Ur = 42 kV Uc = 35 kV	Cantilever load 350 Nm - Torque load 70 Nm
MOISTURE INGRESS TEST	10,8,13	VNL (Hungaria)	NAT-1-1251/2007	8.7.2011						


BYPROCOPMILSIA

*[Handwritten signature and stamp]*

*[Handwritten signature]*


WEATHER AGEING TEST	10.8.14.2. 1	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A5/022740	12.5.2005	24.8.2004	Longest with minimum specific creepage distance	Surge Arrester AZB27 Ur=27 kV Uc = 22 kV	AZB and AZBD have same profile housing, same leakage distance and injected silicone rubber housing. This test is also valid for AZBD arresters
---------------------	-----------------	-----------------	-----------------------	----------	-----------	-----------	-----------	---	--	--

St Joseph on  
May 28th, 2013

 **dervasil**  
SAS au capital de 907 190 €  
Route de Popenot - 42800 SAINT-JOSEPH  
Tél. 04 77 75 29 98 - Fax 04 77 63 22 80  
RC St-Etienne 423 136 977 - Codo NAF 312 A


ВЕРНО СОБРАНА





dervasil

Производител: DERVASIL..... Тип вентилен отвод: AZBD.....

Клаузи от IEC 60099-4 (2006-07)	Лаборатория	Акредитация на лабораторията	Дата на акредитацията	Номер на протокола	Дата на изпитване	Дата на протокола	Изискваните мостри да бъдат изпитани съгласно IEC 600099-4	Изпитани мостри	Коментари
ИЗПИТАНИЕ ЗА УСТОЙЧИВОСТ НА ИМПУЛСНО АТМОСФЕРНО ПРЕНАПРЕЖЕНИЕ В СУХО СЪСТОЯНИЕ	EGU (Czech Rep)	CAI N°110/2006	30.4.2011	9422/08	13.11.2008	20.11.2008	върху най-дългия корпус - AZBD 42	AZBD 42 Ur = 42 kV Uc = 35 kV	
ИЗПИТАНИЕ С НАПРЕЖЕНИЕ С ПРОМИШЛЕНА ЧЕСТОТА ВЪВ ВЛАЖНО СЪСТОЯНИЕ	EGU (Czech Rep)	CAI N°110/2006	30.4.2011	9422/08	13.11.2008	20.11.2008	върху най-дългия корпус - AZBD 42	AZBD 42 Ur = 42 kV Uc = 35 kV	
ИЗПИТАНИЕ НА ОСТАТЪЧНО НАПРЕЖЕНИЕ	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A8007148	1.4.2008	23.9.2008	Като оторизиран от IEC извършено изпитване на метало-окисен резистор Ur = 6 kV	метало-окисен резистор за вентилен отвод тип AZBD Ur= 6 kV	

*(Handwritten signature and stamp)*


*(Handwritten signature)*



ИЗПИТАНИЕ ЗА УСТОЙЧИВОСТ НА ДЪЛГОТРАЕН ТОКОВ ИМПУЛС	10.8.4	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A8018267	1.4.2008	3.9.2008	Като оторизиран от IEC извършено изпитване на вентилен отвод раздел Ur = 9 kV	AZBD 090 Ur = 9 kV Uc = 8,4 kV	Максимална енергия = 15,98 kJ което съответства на 1,9 kJ/kV Uc
ИЗПИТАНИЕ ПРИ РАБОТЕН РЕЖИМ С ВИСОКО-ТОКОВ ИМПУЛС	10.8.5	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A8018272	1.4.2008	3.9.2008	Като оторизиран от IEC извършено изпитване на вентилен отвод раздел с разединител Ur = 9 kV	AZBD 090 Ur = 9 kV Uc = 8,4 kV	Максимална енергия = 33,1 kJ което съответства на 3,94 kJ/kV Uc
ИЗПИТАНИЕ С РАЗЕДИНИТЕЛ	8.6.3.1	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A5/8453	8.3.2005	14.3.2005		разедините л	
ИЗПИТАНИЕ С ВЪТРЕШНО ЧАСТИЧНО РАЗРЕЖДАНЕ	10.8.8	EGU (Czech Rep)	CAI N°110/2006	30.4.2011	9422/08	13.10.2008	20.11.2008	върху най- дългия корпус - AZBD 42	AZBD 42 Ur = 42 kV Uc = 35 kV	
ИЗПИТАНИЕ НА ОГЪВАЩ МОМЕНТ	10,8,9	Dervasil Lab			N°224	28/10/2008	28.10.2008	върху най- дългия корпус - AZBD 42	AZBD 42 Ur = 42 kV Uc = 35 kV	товар на огъване 350 Nm - товар на усукване 70 Nm
ИЗПИТАНИЕ С ПРОНИКВАНЕ НА ВЛАГА	10,8,13	VNL (Hungar ia)	NAT-1- 1251/2007	8.7.2011						

241

ИЗПИТАНИЕ С АТМОСФЕРНО СТАРЕЕНЕ	10.8.14.2. 1	CESI (Italy)	SINCERT 018B rev04	1.6.2010	A5/022740	12.5.2005	24.8.2004	Най-дълъг с минимално разстояние на специфичен път на утечка	Вентилен отвод AZB27 U <sub>g</sub> =27 kV U <sub>c</sub> = 22 kV	Вентилен отвод тип AZB и AZBD имат същия корпус, същото изолационно о разстояние по повърхност а и обвивка от силиконов каучук. Това изпитание също е валидно за отводи AZBD.
------------------------------------	-----------------	-----------------	-----------------------	----------	-----------	-----------	-----------	--	---	--

St Joseph on  
May 28th, 2013

 **dervasil**  
SAS au capital de 907 190 €  
Route de Poponet - 42800 SAINT-JOSEPH  
Tél. 04 77 75 29 98 - Fax 04 77 83 22 80  
RC St-Etienne 423 136 877 - Code NAF 312A



247



*[Handwritten signature]*

REÇU  
Le 01 DEC. 2008  
Répondu le .....

**EGU – HV Laboratory a. s.**  
High voltage testing laboratory  
Podnikatelská 267, 190 11 Praha 9, Běchovice

		<b>ACCREDITED TESTING LABORATORY No.: 1029</b> Accredited by Czech Accreditation Institute, o.p.s.
L 1029		

**CUSTOMER:**  
DERVASIL  
Route de Popenot  
42800 Saint Joseph  
France

**ORDER No.:**  
CG080905 mod 1


**DATE OF TEST:**  
The 13<sup>th</sup> of October 2008  
The 13<sup>th</sup> of November 2008

**TEST No.:**  
9422/08

**TEST REPORT**  
No.: 9422/08

<b>TEST OBJECT:</b>	SURGE ARRESTERS
<b>MANUFACTURER:</b>	DERVASIL, FRANCE
<b>TEST STANDARDS:</b>	IEC 60060-1:1989, IEC 60099-4:2006-07 Ed. 2.1

*[Handwritten signature]*



**TEST PERFORMED BY:**  
Marek Brosch  
*[Signature]*

**DIRECTOR OF EGU - HV Laboratory a.s.:**  
Václav Sklenička  
*[Signature]*

**COPIES:** 3+1

**PAGES:** 11

Test report is confidential and must not be passed over or transferred to any third party without written approval of the customer. Test results relate only to the tests given in presented report and do not substitute any other documents. The report shall not be reproduced except in full without written approval of the testing laboratory.

**In Prague 9 - Běchovice: 2008-11-20**

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

ВЕРНО С ОРИГИНАЛА

**TEST OBJECT**

**SURGE ARRESTERS AZB-D 42**

Drawing No.: No. 99B000210B (see Figure 1)

Characteristics of arresters are :

Ur = 42 kV

Uc = 35 kV

In = 10 kA class 1

The creepage distance: 1045 mm

The arcing distance: 365 mm

Insulation withstand characteristics are :

190 kV dry lightning impulse withstand voltage

70 kV wet power-frequency voltage

**DATE OF DELIVERY**


2008-10-10 and 2008-10-22

**SCHEDULE OF TESTS**

1. Internal partial discharge test
2. Dry lightning impulse withstand voltage test
3. Wet power-frequency voltage test

surge arrester #1 sn 08/0006  
surge arrester #2 sn D42 0030  
surge arrester #2 sn D42 0030

СЕРТИФИКАТ 2/11



**TEST PROCEDURE**


**1. Internal partial discharge test**

The test was carried out according to IEC 60099-4, clause 10.8.8.

The test voltage was increased to the rated voltage of the arrester, held 2 s to 10 s, and then decreased to 1,05 times the continuous operating voltage of the arrester.

The test arrangement is given on Figure 3.

*Testing and measuring equipment:*



- IR – induced regulator ČKD Praha, 6/0-3 kV, 50 kVA
- T – test transformer Fischer-Köln, 3-6/250 kV, 250 kVA
- IVT – instrument voltage transformer Škoda, 380/√3 kV / 100/√3 V, serial No. 917355
- PD measuring system Tettex, type 2801, serial No. 123989
- universal voltmeter Siemens, type MU 15, serial No. 879953
- digital stop-watch Speedo, type Speedo
- measuring system for atmospheric condition COMET, type D4130, serial No. 04900257

**2. Dry lightning impulse withstand voltage test**

Test was carried out in compliance with IEC 60099-4, clause 8.2.6 and in compliance with IEC 60060-1, clause 20.1.2.

Fifteen (15) full lightning impulses of positive polarity was applied to the arrester followed by fifteen (15) full lightning impulses of negative polarity.


The impulse withstand voltage of 190 kV was applied to the arrester.

The wave shape of the test lightning impulse is given in Figure 2.

The test arrangement is given on Figure 4.


20080314/11

Handwritten signature



Handwritten signature

**Testing and measuring equipment:**



impulse generator TuR Dresden 750 kV, 30 kJ  
 Rd1/Rd2 - resistive divider Haefely, type R 800, serial No. 554333  
 digital voltmeter Haefely, type 64 M, serial No. 604160  
 measuring system Haefely Trench, type HiAS 743, serial No. 080649-01  
 measuring system for atmospheric condition COMET, type D4130, serial No. 04900257  
 yard stick, type 30-847, serial No. 101


**3. Wet power frequency voltage test**

Test was carried out in compliance with IEC 60099-4, clause 8.2.8 and in compliance with IEC 60060-1, clause 17.

The one minute wet power-frequency withstand voltage ( $U_{WAC}$ ) was applied according to IEC 60060-1, clause 17.1.


The test arrangement is given on Figure 5.

**Testing and measuring equipment:**



G - synchronous generator BEZ Bratislava 6 kV, 1300 kVA, 50 Hz  
 T - test transformer Fischer-Köln, 3-6/250 kV, 250 kVA  
 IVT - instrument voltage transformer Škoda, 380/√3 kV / 100/√3 V, serial No. 917355  
 universal voltmeter Siemens, type MU 15, serial No. 879953  
 measuring system for atmospheric condition COMET, type D4130, serial No. 04900257  
 conductivity meter ino Lab Con Level 1, serial No. 99440007  
 yard stick, type 30-847, serial No. 101  
 digital stop-watch Speedo, type Speedo

REPNO CORP TMAA/11



**UNCERTAINTY OF MEASUREMENT**


QUANTITY	UNCERTAINTY (k=2)	
	<i>Lightning impulse voltage</i>	U <sub>m</sub>
	T <sub>1</sub>	2,6 %
	T <sub>2</sub>	2,2 %
<i>Power-frequency voltage</i>	1,7 %	
<i>Partial discharges</i>	8,0 %	
<i>Air pressure</i>	0,04 kPa	
<i>Temperature</i>	0,7 °C	
<i>Relative humidity</i>	4 %	
<i>Time</i>	0,2 %	
<i>Length (1 – 5 000 mm)</i>	620 μm	
<i>Conductivity (0,1 μS/cm – 500 mS/cm)</i>	1,3 %	

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k = 2, which for a Normal (Gaussian) distribution corresponds to a coverage probability of approximately 95 %.

**LIST OF SYMBOLS**

- b air pressure (kPa),
- t air temperature (°C),
- RH relative air humidity (%),
- U test voltage (kV), corresponding to actual atmosphere,
- Q internal partial discharge (pC),
- U<sub>WLI</sub> specified dry lightning impulse withstand voltage (kV),
- ri average value of rainfall intensity (mm/min):  
 - v.c. - vertical component,  
 - h.c. - horizontal component,
- ρ water resistivity (Ωm),
- U<sub>WAC</sub> specified wet power-frequency withstand voltage (kV), corresponding to standard reference atmosphere (test duration - 60 s).

5/11  
 КИРОВО СОРБИТИВНАЈА



**TEST RESULTS**

**1. Internal partial discharge test**

Table 1

sample	#1	
	b (kPa)	99,3
t (°C)	16,7	
RH (%)	56,7	
U (kV)	Q (pC)	
	↓	↑
0	0,5	0,5
35	2	2
36,8	3	3
42	6	6

Measured values of partial discharges on arrester are less than 10 pC specified by IEC 60099-4 clause 10.8.8.

Surge arrester #1, drawing No. 99B000210B passed the internal partial discharge test according to IEC 60099-4, clause 10.8.8.


**2. Dry lightning impulse withstand voltage test**

Table 2

sample	#2	
	+	-
Polarity		
b (kPa)	99,2	99,2
t (°C)	16,3	16,3
RH (%)	44,6	44,6
U <sub>WLI</sub> (kV)	190	190
No. of flashovers	0	0

No internal and external disruptive discharges were occurred during the test with the specified dry lightning impulse withstand voltage 190 kV (corrected value 179 kV).

Surge arrester #2, drawing No. 99B000210B passed the dry lightning impulse withstand voltage test according to IEC 60099-4, clause 8.2.6.



6/11  
 ВЕРНО СОПРИБИНАЈА

*[Handwritten signature]*


3. Wet power frequency voltage test

Table 3

sample		#2
b (kPa)		99,2
t (°C)		15,9
RH (%)		54,6
ri	v.c.	1,0
(mm/min)	h.c.	1,0
ρ (Ωm)		103
U <sub>WAC</sub> (kV)		70

No flashover and no puncture was occurred during the test with the specified wet power frequency withstand voltage 70 kV.

Surge arrester #2, drawing No. 99B000210B passed the wet power frequency voltage tests according to IEC 60099-4, clause 8.2.8.



7/11  
 ВЪРНОСОПРЕГЪНАНА

*[Handwritten signature]*





Figure 1  
Surge arrester, drawing No. 99B000210B




8/11

RYHO COVPTNHAJA



LI / SURGE ARRESTER


13/11/2008 08:32:55



LI full  
 Upk : 179.340 kV  
 T1 : 1.153 us  
 T2 : 48.737 us

LI / SURGE ARRESTER

13/11/2008 08:41:42




LI full  
 Upk : -179.864 kV  
 T1 : 1.188 us  
 T2 : 48.730 us


Figure 2  
Wave shape of lightning impulse voltage

ALPHADOC COMPANY


9/11

*[Handwritten signature]*  
*[Handwritten initials]*






**Figure 3**  
**Surge arrester, drawing No. 99B000210B,**  
**test arrangement under internal partial discharge test**



**Figure 4**  
**Surge arrester, drawing No. 99B000210B,**  
**test arrangement under the dry lightning impulse voltage test**



10/11  
ВНПНО С ОФТИЦИЈАЈА









Figure 5  
Surge arrester, drawing No. 99B000210B,  
test arrangement under the wet power frequency voltage test



11/11  
ВНПР СОУПРВНАМА

*A. Konec*

13



14

15

16

ВЕРНО СОПРЯЖАЮТ

Handwritten signature and initials, including the name "А. Кнеп" and a circular stamp.

Client **DERVASIL**

Address of the Client **Route de Popenot F-42800 Saint Joseph (FRANCE)**

Tested samples/items **Metal-oxide resistor block for polymer-housed metal-oxide surge arrester type AZBD**

Tests carried out **Residual voltage test**

Standards/Specifications **IEC 60099-4 – Edition 2.1 (2006-07)**

Tests date **from April 01, 2008 to April 02, 2008**

The results reported in this document relate only to the tested samples/items.  
 Partial reproduction of this document is permitted only with the written permission from CESI.

PUBBLICATO A8007148 (PAD - 1098393)

No. of pages **15**

No. of pages annexed **19**

Issue date **September 23, 2008**

Prepared **LAP - Gregori Marco**  
A8007148.5029 AUT

Verified **LAP - Sironi Alberto, LAP - Arneodo Giorgio**  
A8007148.5025 VER A8007148.503476 VER

Approved **LAP - Nicolini Roberto**  
A8007148.81164 AFP

**CESI** S.p.A.  
 Energy Division

Technical Area Components  
 "Testing Laboratories"  
 Manager

D10001G rev.04

CESI  
 Centro Elettrotecnico  
 Sperimentale Italiano  
 Giacinto Motta spa

Via R. Rubattino 54  
 20134 Milano - Italia  
 Telefono +39 022125.1  
 Fax +39 0221255440  
 http://www.cesi.it

Capitale sociale 8.650.000 Euro  
 interamente versato  
 Codice fiscale e numero  
 iscrizione CCIAA 00793580160

Registro Imprese di Milano  
 Sezione Ordinaria  
 N. R.E.A. 429222  
 P.I. IT00793580150

БІЛГӨС ОРЯДАЛА

255

Tests witnessed by:

Identification of the object:

Not requested

The data necessary to permit repetition of the tests are contained in the document marked: -----

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3 \%$  time parameters:  $\pm 10 \%$
- dielectric tests with impulse current : peak value:  $\pm 3 \%$  time parameters:  $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3 \%$  time parameters:  $\pm 3,5 \%$
- dielectric tests with direct voltage : voltage:  $\pm 3 \%$  time parameters:  $\pm 3,5 \%$
- partial discharge measurement : up to 10 pC:  $\pm 1 \text{ pC}$  above 10 pC:  $\pm 10 \%$
- atmospheric conditions : temperature:  $\pm 2 \text{ }^\circ\text{C}$  pressure:  $\pm 0,133 \text{ kPa}$  humidity:  $\pm 10 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory information

Receipt date of the sample

March 05, 2008

Test location

CESI – Via Rubattino 54 – Milan

CESI testing team

Mr L. Podavitte – Mr I. Guacci

Test laboratory

P177

Activity code

AE08LAP016

ИЗДАНИЕ  
ИЗМЕНЕНИЯ

Handwritten signatures and stamps, including a circular stamp with the number 004 and the number 156.

content	page	test date
Test object characteristics	4	
Photograph of the test sample	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Lighting impulse residual voltage test	from page 8 to 9	April 01, 2008
Switching impulse residual voltage test	10	April 01, 2008
Steep current impulse residual voltage test (measurement of inductive error)	11	April 02, 2008
Steep current impulse residual voltage test	12	April 02, 2008
Technical data	from page 13 to 15	

Pages annexed:

oscillograms n. 19 pages

**CESI**

**Test Report**


257

Test object characteristics

type: Metal-oxide resistor block for polymer-housed metal-oxide surge arrester type AZBD

electrical characteristics (assigned by the client)

Manufacturer's name	DERVASIL – SAINT JOSEPH (FRANCE)
Nominal discharge current – $I_n$ [kA]	10
Rated voltage – $U_r$ [kV]	6,0
Reference current - $I_{ref}$ [mA]	5,0
Line discharge class	1
Standard rated frequency - [Hz]	50/60
year of manufacture	2008

Handwritten signature and a circular stamp. The signature appears to be 'A. Konec'. The stamp contains some illegible text and the number '258' is written at the bottom right.



Picture of the test object




Photo no. 1

Metal-oxide resistor block for polymer-housed metal-oxide surge arrester type AZBD

*[Handwritten signature]*  
*[Handwritten signature]*


Reference Standard

IEC 60099-4 – Edition 2.1 (2006-07) - Clause 8.3  
“Metal-oxide surge arresters without gaps for a.c. system”

Test carried out	Number of sample tested
Lightning impulse residual voltage test	3
Switching impulse residual voltage test	
Steep current impulse residual voltage test	

Test object identification

Test object name	Identification of test sample (given by CESI)
Metal-oxide resistor block for polymer-housed metal-oxide surge arrester type AZBD	RV1-RV2-RV3



Handwritten signature and circular stamp, likely indicating approval or completion of the report.

Test procedure

The following tests have been carried out on the same three samples

a) Lightning impulse residual voltage test

- wave-shape 8/20  $\mu$ s
- peak current  $I_n = 10$  kA,  $0,5 I_n = 5$  kA &  $2 I_n = 20$  kA

b) Switching impulse residual voltage test

- wave-shape front time in the range 30 $\mu$ s to 100 $\mu$ s, tail time twice the virtual time
- peak current 125 A & 500 A (according to table 4 of the reference standard)

c) Steep current impulse residual voltage test

- wave-shape front time equal to 1  $\mu$ s, tail time less than 20  $\mu$ s
- peak current  $I_n = 10$  kA
- note Correction of the inductive error

The inductive error was determined replacing the surge arrester section with a metal part having the same dimensions and measuring the voltage across the metal part in this condition..  
 Being the inductive error (peak value) in the range 2% to 20% of the measured residual voltage (peak value) the correction was applied by subtracting the impulse voltage shape measured on the surge arrester section and the impulse voltage shape on the metal part.

Test result

See pages 8 & 9

Handwritten signature and a circular stamp with illegible text.

Residual voltage tests

Lightning impulse residual voltage test.

Test circuit: A0120

Date: April 01, 2008


Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape $\mu s$	Discharge current kA	Residual voltage kV	Lightning impulse protection level kV
RV1	$0,5 \times I_n$	21,8	07	8,7/18,9	5,00	15,11	16,18
	$I_n$	30,0	01	8,7/18,9	10,11	16,14	
	$2,0 \times I_n$	45,4	04	8,7/18,9	20,15	17,68	
RV2	$0,5 \times I_n$	21,8	08	8,7/18,9	5,02	15,09	
	$I_n$	29,8	02	8,7/18,9	10,04	16,18	
	$2,0 \times I_n$	45,4	05	8,7/18,9	20,07	17,69	
RV3	$0,5 \times I_n$	21,8	09	8,7/18,9	5,02	15,08	
	$I_n$	29,8	03	8,7/18,9	10,05	16,10	
	$2,0 \times I_n$	45,4	06	8,7/18,9	20,00	17,59	

	Requested current	Oscilloscope settings		
		sampling division $\mu s$	input $V_{div}$	Attenuation
Current	$0,5 \times I_n$	5	0,5	20:10
	$I_n$		1,0	50:10
	$2 \times I_n$		1,0	50:10
Voltage	$0,5 \times I_n$	5	1,0	20:5
	$I_n$		1,0	20:5
	$2 \times I_n$		1,0	20:5

Notes:

*[Handwritten signature and stamp]*

### Lightning impulse protection level



ВНИМАТЕЛЬНО  
ПРОСМОТРЕТЬ

*[Handwritten signatures and stamps]*

Residual voltage tests

Switching impulse residual voltage test.

Test circuit: A0122

Date: April 01, 2008

Sample	Requested current	Charging Voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage	Switching impulse protection level
No.	A	kV	No.	$\mu$ s	A	kV	kV
RV1	125	12,4	10	31/72	128	11,96	12,74
	500	18,3	13	33/71	510	12,74	
RV2	125	12,3	11	31/72	130	11,97	
	500	18,3	14	33/71	511	12,67	
RV3	125	12,3	12	31/72	128	12,05	
	500	18,1	15	33/71	497	12,52	

	Oscilloscope settings		
	sampling division	Input	attenuation
	$\mu$ s	V <sub>div</sub>	
125A current	20	0,5	10:10
Voltage		1,0	20:5
250A current		0,5	50:10
Voltage		0,5	20:5

Notes:

ВЕРНО С ОРИГИНАЛА

Residual voltage tests

Steep current impulse residual voltage test.

Measurement of the inductive error

Test circuit: A0121B

Date: April 02, 2008

Sample	Charging voltage	Oscillogram	Current waveshape	Discharge current	Peak voltage	Inductive error
No.	kV	No.	$\mu$ s	kA	V	%
aluminium blocks	34,5	16	0,98/2,2	10,00	550	2+20 (1)

Oscilloscope settings			
	sampling division	input	attenuation
	$\mu$ s	V <sub>div</sub>	
Current	1	2	x 10
Voltage		---	---

Notes: (1) correction is required

Handwritten signature and circular stamp.

### Residual voltage tests

### Steep current impulse residual voltage test.

Test circuit: A0121B

Date: April 02, 2008

Sample	Charging voltage	Oscillogram	Current waveshape	Discharge current	Corrected residual voltage	Steep current impulse protection level
No.	kV	No.	$\mu$ s	kA	kV	kV
RV1	34,5	17	0,98/2,2	10,10	17,21	17,21
RV2	34,5	18		10,01	17,15	
RV3	34,5	19		10,06	17,21	


Oscilloscope settings			
	sampling division	input	attenuation
	$\mu$ s	V <sub>div</sub>	
Current	1	2	x10
Voltage		5,0	---

Notes:

ВЕРНО СОПРЯЖЕНАЯ



Circuit A0120



**Impulse generator**

- No. of stages 1
- Cg 4,98  $\mu$ F
- Lc 10  $\mu$ H
- S - Spark-gap

**Voltage measuring system.**


- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

**Current measuring system**

- Sh - Current shunt CESI No.6042; R= 2 m $\Omega$ ; peak current= 250 kA
- Electro optical system CESI No.11517/518;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

*[Handwritten signature and initials]*

Circuit A0122



**Impulse generator**

- No. of stages 1
- Cg 2,49 $\mu$ F
- Lc 120  $\mu$ H
- S - Spark-gap

**Voltage measuring system.**


- D - Voltage divider SAGI; CESI No.13027
- Electro optical system CESI No 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

**Current measuring system**

- Sh - Current shunt CESI No.6037; R= 20 m $\Omega$ ; peak current= 250 kA
- Electro optical system CESI No11517/518
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

*[Handwritten signatures and stamps]*

Circuit A0121B



Impulse generator

No. of stages 1  
 Cg 0,500  $\mu$ F


S - Spark-gap

Voltage measuring system.

D - Voltage divider SAGI; CESI No.11120  
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)





Current measuring system

Sh - Current Pearson CESI No.6042; 0,01 V x A  
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)



*[Handwritten signature]*  
*[Handwritten initials]*

6



9

ВІСНО СОНКУЩАНА

9

Handwritten signature and a circular stamp.

Client **DERVASIL**

Address of the Client **Route de Popenot F- 42800 Saint Joseph (FRANCE)**

Tested samples/items **Polymer-housed metal-oxide surge arrester type AZBD090**

Tests carried out **Long-duration current impulse withstand test**

Standards/Specifications **IEC 60099-4 – Edition 2.1 (2006-07)**

Tests date **from April 01, 2008 - to April 02, 2008**

The results reported in this document relate only to the tested samples/items.  
 Partial reproduction of this document is permitted only with the written permission from CESI.

PUBBLICATO A8018267 (PAD - 1093286)

No. of pages **21** No. of pages annexed **28**

Issue date **September 03, 2008**

Prepared **LAP - Gregori Marco**  
A5518267 3029 AUT

Verified **LAP - Arneodo Giorgio, LAP - Sironi Alberto**  
A5518267 303475 VER A5518267 3025 VER

Approved **LAP - Nicolini Roberto**  
A5518267 821814 AUT

**CESI** S.p.A.  
 Energy Division

Technical Area Components  
 "Testing Laboratories"

Manager

D10001G rev 04

CESI  
 Centro Elettrotecnico  
 Sperimentale Italiano  
 Giacinto Motta spa  
 Via R. Rubattino 54  
 20134 Milano - Italia  
 Telefono +39 022125.1  
 Fax +39 0221255440  
 http://www.cesi.it

Capitale sociale 8 550 000 Euro  
 interamente versato  
 Codice fiscale e numero  
 iscrizione CCIAA 00793580150

Registro Imprese di Milano  
 Sezione Ordinaria  
 N. R.E.A. 429222  
 P.I. IT00793580150

REPUBBLICA ITALIANA

Tests witnessed by:

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object. These drawings identified by CESI and numbered A8024793 no. 1 to 3 are annexed to this document..

The data necessary to permit repetition of the tests are contained in the document marked: ---

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: ± 3 % time parameters: ± 10 %
- dielectric tests with impulse current : peak value: ± 3 % time parameters: ± 10 %
- dielectric tests with alternating voltage : voltage (rms): ± 3 % time parameters: ± 3,5 %
- dielectric tests with direct voltage : voltage: ± 3 % time parameters: ± 3,5 %
- partial discharge measurement : up to 10 pC: ± 1 pC above 10 pC: ± 10 %
- atmospheric conditions : temperature: ± 2 °C pressure: ± 0,133 kPa humidity: ± 10 %

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory information

Receipt date of the sample June 19, 2008

Test location CESI – Via Rubattino 54 – Milan

CESI testing team Mr L. Podavitte – Mr I. Guacci

Test laboratory P177

Activity code AE08LAP012

ВЕРСИОННАЯ ТАБЛИЦА

Handwritten signatures and initials, including a large signature and the number 272.

content	page a	test date
Test object characteristics	4	
Picture of the test sample	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Visual inspection and summary of the test result	8	
Power frequency voltage characteristics	9	June 23, 2008
Lightning impulse residual voltage measurement before the test	10	June 23, 2008
Switching impulse residual voltage test	11	June 24, 2008
Voltage correction factor and energy calculations	12	June 24, 2008
Long duration current impulse withstand test	from page 13 to 15	June 24, 2008
Lightning impulse residual voltage measurement after the test	16	June 25, 2008
Additional long duration current impulse	17	June 25, 2008
Technical data of the test circuit	from page 18 to 21	

**Pages annexed:**

oscillograms n. 24 pages

DERVASIL drawing no. 99B000210B; CESI no. A8024793/1 - n.1 page

DERVASIL drawing no. 99B000224A; CESI no. A8024793/3 - n.1 page

DERVASIL technical document no. 99B000226A; CESI no. A8024793/2- n.1 page

DERVASIL technical document no. 99B000224A; CESI no. A8024794 - n.1 page

**CESI**

**Test Report**

Approved

Test object characteristics

type: Polymer-housed metal-oxide surge arrester type AZBD090

electrical characteristics (assigned by the client)

Manufacturer's name	DERVASIL – Saint Joseph (France)
Nominal discharge current – $I_n$ [kA]	10
Rated voltage – $U_r$ [kV]	1,07 x $U_{ref}$
Continuous operating voltage - $U_c$ [kV]	0,89 x $U_{ref}$
Reference current - $I_{ref}$ [mA]	5,0
Line discharge class	1
Standard rated frequency - [Hz]	50/60
year of manufacture	2008

ВЕРНО С ОПРИГНАЛА





Picture of the test object




Photo no. 1

polymer housed metal oxide surge arrester

ВЕРНО СОРТИРУАНА

*[Handwritten signature]*  
*[Handwritten signature]*  
*[Handwritten signature]*

### Reference Standard

IEC 60099-4 (2006-07) – Edition 2.1 - Clause 10.8.4  
“Metal-oxide surge arresters without gaps for a.c. system”

Test carried out	Number of sample tested
Long-duration current impulse withstand test	3

### Test object identification

Test object name	Identification of test sample (given by CESI)
Polymer-housed metal-oxide surge arrester type AZBD090	LD1-LD2-LD3

ВЕРНО СОФИГЕНАЈА

**Test procedure**


The test procedure consisted of the following sequence:

- a) Measurement of the power frequency reference voltage at the reference current
- b) Measurement of the lightning impulse residual voltage at nominal discharge current
- c) Measurement of the switching impulse residual voltage at the lowest current peak prescribed by the standard in table 4 that is 125 A
- d) Calculation of the specified energy associated to each long duration current impulse according to clause 8.4.2 of the reference standard
- e) Application of eighteen long duration current impulses with the specified energy and a virtual duration of 2000  $\mu$ s in six groups of three operations each.
  - intervals between operations of the same group: 60 seconds
  - interval between different groups: as required to cool down the samples to near ambient temperature
- f) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value
- g) After cooling down to near ambient temperature cooling down to near ambient temperature application of a nineteenth impulse to check the sample integrity

**Test result**

The visual inspection of the sample after the test has revealed no sign of physical damage.  
The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%).  
The oscillographic record of the 19<sup>th</sup> impulse did not reveal any sign of internal discharge.

**The acceptance criteria are fulfilled. The test result is positive**



Handwritten signature and stamp. The stamp is circular and contains the text 'ИЗРНО СОРПЕТНАЈА' and '277'.

Summary of test results

Variation of lightning impulse residual voltage at  $I_n$

Sample	before test		after test		Variation %
	discharge current kA	residual voltage kV	discharge current kA	residual voltage kV	
LD1	10,10	31,69	10,15	31,81	+ 0,38
LD2	10,08	31,97	10,13	31,92	- 0,16
LD3	10,05	31,72	10,09	31,78	+ 0,19

Visual inspection after the test

The visual inspection of the surge arrester sections after the test has revealed no sign of physical damage

13

Long-duration current impulse withstand test.

Reference voltage test.

Test circuit: A0019

Date: June 23, 2008

Sample No. LD1						
Oscillogram	Voltage	current	current	current	power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	13,45	5,04	4,32	1,50	13,47	---

Sample No. LD2						
oscillogram	Voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
2	13,57	5,02	4,06	1,49	13,50	---

Sample No. LD3						
oscillogram	Voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	13,49	5,03	4,42	1,52	12,73	---

Handwritten signatures and initials: *07*, *04*, *A. Kovalev*

ВНЕШНО СЕРТИФИКАЦИЯ

Long-duration current impulse withstand test.

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: June 23, 2008

Sample	Requested current	Charging Voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.		kV	No.	$\mu$ s	kA	kV
LD1	$I_n$	45,3	4	8,7/20,0	10,10	31,69
LD2		45,4	5		10,08	31,97
LD3		45,3	6		10,05	31,72

Oscilloscope settings			
	Sampling division	Input	attenuation
	$\mu$ s	$V_{div}$	
Current	5	1,0	50:10
Voltage	5	1,0	50:5

Notes:

APPROVED

Long-duration current impulse withstand test.

Switching impulse residual voltage test.

Test circuit: A0122

Date: June 24, 2008

Sample	Requested current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.	A	kV	No.	μs	A	kV
LD1	125	24,7	7	31/79	129	23,80
LD2		24,8	8		128	23,88
LD3		24,7	9		125	23,73

	Oscilloscope settings		
	sampling division	input	attenuation
	μs	V <sub>div</sub>	
Current	20	0,5	10:10
Voltage	20	1,0	20:5

Notes:

ВІСНОВОК

Long-duration current impulse withstand test.

Voltage correction factor and energy calculations

Date: June 24, 2008

Sample	U <sub>ref</sub> [1]	KU <sub>r</sub> [2]	KU <sub>c</sub> [3]	U <sub>r</sub> ' [4]	U <sub>c</sub> ' [5]
No.	kV			kV	kV
LD1	13,45	1,07	0,89	14,392	11,971
LD2	13,57			14,520	12,077
LD3	13,49			14,433	12,006

- [1] U<sub>ref</sub> : measured reference voltage
- [2] KU<sub>r</sub> : maximum guaranteed factor for calculation of U<sub>r</sub>'
- [3] KU<sub>c</sub> : maximum guaranteed factor for calculation of U<sub>c</sub>'
- [4] U<sub>r</sub>' : corrected rated voltage [4] = [1] × [2]
- [5] U<sub>c</sub>' : corrected continuous operating voltage [5] = [1] × [3]

Sample	U <sub>r</sub> '	U <sub>L</sub>	U <sub>res</sub>	T	Z	W	W'
No.	kV	kV d.c.	kV	μs	Ω	kJ	kJ/kV
LD1	14,392	46,054	23,73	2000	70,521	15,024	1,044
LD2	14,520	46,464			71,148	15,165	1,044
LD3	14,434	46,189			70,727	15,071	1,044

- U<sub>res</sub> : switching impulse residual voltage
- U<sub>L</sub>, T, Z : see table 5 of IEC 60099-4 at clause 8.4.2
- W := U<sub>res</sub> × (U<sub>L</sub> - U<sub>res</sub>) × (T / Z)

РД 010 СОРВЕТНУАЛ



B

### Long-duration current impulse withstand test.

Test circuit: A0017

Date: June 24, 2008

Sample	Impulse	Charging voltage $U_c$	Oscillogram	Peak current $I$	Residual voltage $U_{res}$	Energy $E$
No.	No.	kV	No.	A	kV	kJ
LD1	1	51,4		286	24,36	15,54
	2	51,4		286	24,56	15,67
	3	51,4	10	286	24,68	15,73
	4	51,4		288	24,43	15,69
	5	51,4		287	24,63	15,72
	6	51,4		286	24,73	15,71
	7	51,4		288	24,50	15,70
	8	51,4		286	24,62	15,69
	9	51,4	13	284	24,78	15,70
	10	51,4		289	24,56	15,98
	11	51,4		286	24,66	15,68
	12	51,4		286	24,78	15,74
	13	51,4		286	24,51	15,63
	14	51,4		286	24,66	15,68
	15	51,4		284	24,73	15,67
	16	51,4		286	24,49	15,66
	17	51,4		284	24,67	15,64
	18	51,4	16	285	24,80	15,69

Notes:

Measured waveshape	
virtual duration	virtual total duration
$\mu s$	$\mu s$
2000	2560

Oscilloscope settings			
	sampling division	Input	Attenuation
	$\mu s$	$V_{div}$	
Current	500	0,5	10:10
Voltage	500	1,0	10:5

TEST REPORT

*[Handwritten Signature]*

Continued

Continued

Date: June 24, 2008

Sample No.	Impulse No.	Charging voltage $U_c$ kV	Oscillogram No.	Peak current I A	Residual voltage $U_{res}$ kV	Energy E kJ
LD2	1	51,4		286	24,63	15,71
	2	51,4		284	24,90	15,68
	3	51,4	11	283	24,96	15,69
	4	51,4		286	24,68	15,70
	5	51,4		283	24,85	15,68
	6	51,4		285	24,92	15,78
	7	51,4		284	24,74	15,69
	8	51,4		284	24,87	15,73
	9	51,4	14	283	24,99	15,76
	10	51,4		284	24,74	15,67
	11	51,4		283	24,87	15,70
	12	51,4		283	24,98	15,73
	13	51,4		284	24,71	15,70
	14	51,4		284	24,90	15,75
	15	51,4		283	24,98	15,74
	16	51,4		285	24,78	15,75
	17	51,4		284	24,92	15,75
	18	51,4	17	284	25,00	15,75

Notes:

Measured waveshape	
virtual duration	virtual total duration
$\mu s$	$\mu s$
2000	2560

Oscilloscope settings			
	sampling division	input	Attenuation
	$\mu s$	V <sub>div</sub>	
Current	500	0,5	10:10
Voltage	500	1,0	10:5

ВНЕСЕНО В РЕГИСТР

*[Handwritten signatures and stamps]*

Continued

Continued

Date: June 24, 2008

Sample	Impulse	Charging voltage	Oscillogram	Peak current	Residual voltage	Energy
No.	No.	$U_c$ kV	No.	$I$ A	$U_{res}$ kV	$E$ kJ
LD3	1	51,4		287	24,54	15,67
	2	51,4		286	24,68	15,68
	3	51,4	12	286	24,83	15,70
	4	51,4		286	24,56	15,67
	5	51,4		287	24,73	15,78
	6	51,4		286	24,83	15,82
	7	51,4		286	24,61	15,66
	8	51,4		286	24,72	15,78
	9	51,4	15	284	24,85	15,71
	10	51,4		287	24,62	15,76
	11	51,4		284	24,77	15,68
	12	51,4		283	24,86	15,71
	13	51,4		286	24,58	15,70
	14	51,4		284	24,73	15,66
	15	51,4		284	24,88	15,71
	16	51,4		286	24,64	15,71
	17	51,4		284	24,77	15,71
	18	51,4	18	285	24,91	15,81

Notes:

Measured waveshape	
Virtual duration	virtual total duration
$\mu s$	$\mu s$
2000	2560

Oscilloscope settings			
	sampling division	input	Attenuation
	$\mu s$	$V_{div}$	
Current	500	0,5	10:10
Voltage	500	1,0	10:5

Continued

ВЕРИФИЦИРОВАННО  
 КОМПЬЮТЕРНОМ СПОСОБОМ

Long-duration current impulse withstand test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: June 25, 2008

Sample	Requested Current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.		kV	No.	$\mu$ s	kA	kV
LD1	I <sub>n</sub>	31,4	22	8,7/20,0	10,15	31,81
LD2		31,3	23		10,13	31,92
LD3		31,4	24		10,09	31,78

Oscilloscope settings			
	sampling division	input	attenuation
	$\mu$ s	V <sub>div</sub>	
Current	5	1,0	50:10
Voltage	5	1,0	20:5

Notes:

ВЕРНО СОРТИРОВАНО

*[Handwritten signature and stamp]*

Long -duration current impulse withstand test.

check of the integrity of the internal parts with a nineteenth shot at ambient temperature

Test circuit: A0017

Date: June 24, 2008

Sample	Impulse	Charging voltage $V_c$	Oscillogram	Peak current $I$	Residual voltage $V_r$	Energy $E$
No.	No.	kV	No.	A	kV	kJ
LD1	19	51,4	19	286	24,52	15,64
LD2	19	51,4	20	285	24,80	15,64
LD3	19	51,4	21	288	24,69	15,72

Notes:


Measured waveshape	
virtual duration	virtual total duration
$\mu s$	$\mu s$
2000	2560

Oscilloscope settings			
	sampling division	input	attenuation
	$\mu s$	$V_{div}$	
Current	500	0,5	10:10
Voltage	500	1,0	10:5

*[Handwritten signature]*  
continued

ИСТОЧНИК КОПИРОВАНИЯ

Circuit A0019



**Power frequency supply**

- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

**Current measuring system**

- R - Current shunt CESI No.31120; R= 941,4  $\Omega$
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090

**Voltage measuring system**

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522; attenuation 50:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090


ИНСТРУКЦИЯ  
 К ЭЛЕКТРОСОУЩЕСТВЛЯЮЩЕЙ

*(Handwritten signature and initials)*

200

3

Circuit A0120



**Impulse generator**

- No. of stages 1
- Cg 4,98  $\mu$ F
- Lc 10  $\mu$ H
- S - Spark-gap

**Voltage measuring system.**

- D - Voltage divider SAGI; CESI No.13027
- Electro optical system CESI No.11521/522;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)


**Current measuring system**

- Sh - Current shunt CESI No.6042; R= 2 m $\Omega$ ; peak current= 250 kA
- Electro optical system CESI No.11517/518;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

*[Handwritten signature and stamp]*

ВЕРНО КОПИРОВАНА

Circuit A0122



**Impulse generator**

- No. of stages 1.
- Cg 2,49  $\mu$ F
- Lc 100  $\mu$ H
- S - Spark-gap

**Voltage measuring system.**

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

**Current measuring system**


- Sh - Current shunt CESI No.6037; R= 20 m $\Omega$ ; peak current= 250 kA
- Electro optical system CESI No 11517/519
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

ИНФОРМАЦИОННАЯ

*[Handwritten signature and stamp]*



Circuit A0017



Impulse generator

- $C_1 \dots C_{10}$  - capacitors 37,5  $\mu F$
- $C_{12}$  - capacitors 18,75  $\mu F$
- $L_1 \dots L_{11}$  - inductors 666  $\mu H$
- $L_{12}$  - inductor ( 600+500 )  $\mu H$
- $S$  : - spark gap





Voltage measuring system.

- $D$  - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- $Sh$  - Current shunt CESI No.6042;  $R=2 \text{ m } \Omega$
- Electro optical system CESI No 11521/11522.
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

12



ОБЩЕСТВО С ОГРАНИЧЕННОЙ ОТВЕТСТВЕННОСТЬЮ

13

14

Handwritten signature and stamp.

Client **DERVASIL**

Address of the Client **Route de Popenot F-42800 Saint Joseph (FRANCE)**

Tested samples/items **Polymer-housed metal-oxide surge arrester type AZBD092 assembled with additional thermal insulation and fitted with disconnectors**

Tests carried out **High current impulse operating duty test**

Standards/Specifications **IEC 60099-4 – Edition 2.1 (2006-07)**

Tests date **from April 01, 2008 to April 02, 2008**

The results reported in this document relate only to the tested samples/items.  
 Partial reproduction of this document is permitted only with the written permission from CESI.

PUBBLICATO A8018272 (PAD - 1093292)

No. of pages **25** No. of pages annexed **46**

Issue date **September 03, 2008**

Prepared **LAP - Gregori Marco**  
AS018272 369 AUT

Verified **LAP - Sironi Alberto, LAP - Arneodo Giorgio**  
AS018272 323 VER AS018272 30475 VFA

Approved **LAP - Nicolini Roberto**  
AS018272 321914 APP

**CESI** S.p.A.  
 Energy Division  
 Technical Area Components  
 "Testing Laboratories"  
 Manager

D1000IG rev.04

CESI  
 Centro Elettrotecnico  
 Sperimentale Italiano  
 Giacinto Motta spa  
 Via R. Rubattino 54  
 20134 Milano - Italia  
 Telefono +39 02212511  
 Fax +39 0221255440  
 http://www.cesi.it

Capitale sociale 8 550 000 Euro  
 interamente versato  
 Codice fiscale e numero  
 Iscrizione CCIAA 00793580150

Registro Imprese di Milano  
 Sezione Ordinaria  
 N. R.E.A. 429222  
 P.I. IT00793580150

REPUBBLICA ITALIANA

Tests witnessed by:

-----

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings. CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object. These drawings identified by CESI and numbered A8024793 no. 1 to 2 are annexed to this document..

The data necessary to permit repetition of the tests are contained in the document marked: ----

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3 \%$ ; time parameters:  $\pm 10 \%$
- dielectric tests with impulse current : peak value:  $\pm 3 \%$ ; time parameters:  $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3 \%$  time:  $\pm 3,5 \%$
- dielectric tests with direct voltage : voltage:  $\pm 3 \%$  time:  $\pm 3,5 \%$
- atmospheric conditions : temperature:  $\pm 2 \text{ }^\circ\text{C}$ ; pressure:  $\pm 0,133 \text{ kPa}$ ; humidity:  $\pm 10 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory information

Receipt date of the sample June 19, 2008

Test location CESI - Via Rubattino 54 - Milan

CESI testing team Mr L. Podavitte

Test laboratory P177

Activity code AE08LAP016

*(Handwritten signature and stamp)*

ВЕРНО И ОФИЦИАЛЬНО

content	page	test date
Test object characteristics	4	
Picture of the test object	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Visual inspection and summary of test result	8	
High current operating duty test	from page 9 to 17	from June 23 to June 30, 2008
Technical data	from page 18 to 25	
<p><b>Pages annexed:</b></p> <p>Oscillograms n. 43 pages</p> <p>DERVASIL drawing no. 99B000210B; CESI no. A8024793/1 - n.1 page</p> <p>DERVASIL drawing no. 99B000226A; CESI no. A8024793/2 - n.1 page</p> <p>DERVASIL technical document no. 99B000224A; CESI no. A8024794 - n.1 page</p>		

ВЕРНО СОПРОВОЖДАЕТСЯ

*[Handwritten signature]*

*[Circular stamp]*

*[Handwritten signature]*

**CESI**

**Test Report**

**Test object characteristics**

**type:** Polymer-housed metal-oxide surge arrester type AZBD092 assembled with additional thermal insulation and fitted with disconnectors


electrical characteristics (assigned by the client)

Manufacturer's name	DERVASIL – SAINT JOSEPH (FRANCE)
Nominal discharge current – $I_n$ [kA]	10
Rated voltage – $U_r$ [kV]	1,03 x $U_{ref}$
Continuous operating voltage - $U_o$ [kV]	0,83 x $U_{ref}$
Reference current - $I_{ref}$ [mA]	5,0
Line discharge class	1
Standard rated frequency - [Hz]	50/60
year of manufacture	2008

**NOTE:**

The thermal model was supplied by the manufacturer

The verification of the thermal equivalency according to annexe B was not carried out by CESI



Handwritten signature: V. Kovalev  
 Stamp: ВЕРНО СОПРЯЖАЛІА

Picture of the test object




Photo no. 1

Polymer-housed metal-oxide surge arrester

*[Handwritten signature]*  
*[Handwritten signature]*

Reference standard

IEC 60099-4 (2006-07) – Edition 2.1 – Clause 10.8.5

“ Metal-oxide surge arresters without gaps for a.c. system “

Test carried out

test carried out	number of sample tested
High current impulse operating duty test	3

Test object identification

test object names	identification of test sample (assigned by the CESI)
Polymer-housed metal-oxide surge arrester type AZBD092 assembled with additional thermal insulation	OD1-OD2-OD3

Handwritten signature and a circular stamp, possibly containing a date or reference number, located in the bottom right corner of the page.



**Test procedure**

The test procedure consisted of the following sequence:

- a) Measurement of the power frequency reference voltage at the reference current
- b) Measurement of the lightning impulse residual voltage at the nominal discharge current
- c) Calculation of the voltage correction factors according to the reference standard
- d) Conditioning 1: application of twenty impulses  $8/20 \mu\text{s}$  at the nominal discharge current superimposed to the power frequency voltage at 1,2 times  $U_c$  in four groups of five impulses
  - interval between impulses of the same group: 50-60 seconds
  - interval between groups: 30 minutes
  - polarity of the impulses: same as that of the half cycle of power frequency voltage during which it occurred (positive)
  - synchronization of the impulses: 60 electrical degrees before the peak of the power frequency.
- e) Conditioning 2: application of one high current impulse  $4/10 \mu\text{s}$  at 100 kA
- f) Heating in an oven at the temperature of  $60^\circ\text{C}$  till thermal equilibrium
- g) Application of a second high current impulse  $4/10 \mu\text{s}$  at 100 kA. A time shorter than 100 ms after the application of the second high current shot energization at  $U_r$  for 10 sec. and then at  $U_c$  for 30 min. to verify the thermal stability.
- h) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value with two impulses at 50 sec to 60 sec. time interval in between

**TEST RESULT**

The visual inspection of the sample after the test has revealed no sign of physical damage.

The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%).


The oscillographic record of the two last lightning impulse at nominal discharge current did not reveal any sign of internal discharge.

The thermal stability was achieved

The disconnectors did not operate

**The acceptance criteria are fulfilled. The test result is positive**

ВЕРНО КОПИРОВАНО



Variation of lightning impulse residual voltage at  $I_n$

Sample	before test		after test		Variation
	discharge current	residual voltage	discharge current	residual voltage	
	kA	kV	kA	kV	%
OD1	10,09	32,27	10,11	33,1	+ 2,57
OD2	10,12	32,02	9,90	33,4	+ 4,20
OD3	10,02	32,00	10,08	33,1	+ 3,40

Visual inspection after the test

The visual inspection of the polymer-housed metal-oxide surge arrester after the test has revealed no sign of physical damage

ИЗДАНО ПО ЗАКАЗУ РАЙОННОГО  
УПРАВЛЕНИЯ СОРБЕНТАМИ

13

High current impulse operating duty test.

Reference voltage test

Test circuit: A0019

Date: June 23, 2008

Sample No. OD1						
Oscillogram	voltage	current	current	current	power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	13,60	5,06	4,62	1,56	14,31	--

Sample No. OD2						
Oscillogram	voltage	current	current	Current	power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
2	13,55	5,04	4,22	1,50	13,53	--

Sample No. OD3						
Oscillogram	voltage	current	current	Current	power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	13,50	5,08	4,38	1,53	13,76	--

ВНИМО СОПРОВОЖДАЕТСЯ

Handwritten signature and official stamp of a representative.

High current impulse operating duty test.

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: June 23, 2008

Sample	Requested current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual Voltage
No.		kV	No.	$\mu$ s	kA	kV
OD1	I <sub>n</sub>	45,8	4	8,7/19,2	10,09	32,27
OD2		45,8	5		10,12	32,02
OD3		45,5	6		10,02	32,00

Oscilloscope settings			
	sampling division	input	Attenuation
	$\mu$ s	V <sub>div</sub>	
Current	5	1,0	50:10
Voltage	5	1,0	50:5

Notes:

REPRIODUCIBILITATEA

Voltage correction factor and energy calculations

Date: June 24, 2008

Sample	$U_{ref}$ [1]	$KU_r$ [2]	$KU_c$ [3]	$U_r'$ [4]	$U_c'$ [5]	$U'$ [6]
No.	kV			kV	kV	kV
OD1	13,60	1,03	0,83	14,008	11,288	13,546
OD2	13,55			13,957	11,247	13,496
OD3	13,50			13,905	11,205	13,446

- [1]  $U_{ref}$  : measured reference voltage
- [2]  $KU_r$  : factor claimed by the manufacturer for calculation of  $U_r'$
- [3]  $KU_c$  : factor claimed by the manufacturer for calculation of  $U_c'$
- [4]  $U_r'$  : corrected rated voltage [4] = [1] × [2]
- [5]  $U_c'$  : corrected continuous operating voltage [5] = [1] × [3]
- [6]  $U'$  : corrected voltage to be applied during the conditioning [6] = 1,2 × [5]

ВНЕШНИЙ КОМПЕТЕНТНЫЙ ЦЕНТР

High current impulse operating duty test.

Conditioning: application of twenty 8/20  $\mu$ s current impulses (first part)

Test circuit: A0015

Date: June 26, 2008

Imp. No.	Osc. No.	Sample No. OD1		Osc. No.	Sample No. OD2		Osc. No.	Sample No. OD3	
		charging kV	peak current kA		Charging kV	peak current kA		charging kV	peak current kA
1	7	60,4	10,0		60,4	10,0		60,4	10,0
2		60,4	10,0		60,4	10,0		60,4	10,0
3		60,4	10,0		60,4	10,0		60,4	10,0
4		60,4	10,0		60,4	10,0		60,4	10,0
5	8	60,4	10,0	9	60,4	10,0	10	60,4	10,0
6		60,4	10,0		60,4	10,0		60,4	10,0
7		60,4	10,0		60,4	10,0		60,4	10,0
8		60,4	10,0		60,4	10,0		60,4	10,0
9		60,4	10,0		60,4	10,0		60,4	10,0
10	11	60,4	10,0	12	60,4	10,0	13	60,4	10,0
11		60,4	10,0		60,4	10,0		60,4	10,0
12		60,4	10,0		60,4	10,0		60,4	10,0
13		60,4	10,0		60,4	10,0		60,4	10,0
14		60,4	10,0		60,4	10,0		60,4	10,0
15		60,4	10,0		60,4	10,0		60,4	10,0
16		60,4	10,0		60,4	10,0		60,4	10,0
17		60,4	10,0		60,4	10,0		60,4	10,0
18		60,4	10,0		60,4	10,0		60,4	10,0
19		60,4	10,0		60,4	10,0		60,4	10,0
20	14	60,4	10,0	15	60,4	10,0	16	60,4	10,0

Power frequency voltage applied to the test sample during current impulse applications [kV]	Sample No. OD1	Sample No. OD2	Sample No. OD3
		13,546	13,496

	Oscilloscope settings		
	sampling division	Input	attenuation
	ms	V <sub>div</sub>	
Current	10	1,0	50:10
Voltage	10	1,0	50:5

Notes:

High current impulse operating duty test.

Conditioning: Application of the first impulse 100 kA 4/10  $\mu$ s high current impulses (second part)

Test circuit: A0121

Date: June 27, 2008

Sample	Impulse	Charging voltage	Oscillogram	Discharge current	Residual Voltage	current waveshape	Energy
No.	No.	kV	No.	kA	kV	$\mu$ s	kJ
OD1	1	93,5 x 2	17	98,0	53,1	4,5/9,8	33,1
OD2	1	93,5 x 2	18	98,5	52,1		33,0
OD3	1	93,5 x 2	19	99,0	53,8		33,0

Oscilloscope settings			
	sampling division	input	attenuation
	$\mu$ s	V <sub>div</sub>	
Current	2	2,0	300:10

Notes: opposite polarity 4,6 %

*B*

### High current impulse operating duty test.

Application of the second high current impulse, of the rated voltage  $U_r'$  and evaluation of thermal stability

Test circuit: A0123 – A0020 – A0131

Sample No.: ODI

Preheating temperature: 61 °C

Date: June 30, 2008

*[Handwritten mark]*

### Second high current impulse application

Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Energy kJ	Current waveshape $\mu$ s
20	94,0 x 2	---	99,0	---	4,5/9,8

### Corrected rated voltage $U_r'$ application

Oscillogram No.	Time s	Voltage kV	Current + mA <sub>cr</sub>	Current - mA <sub>cr</sub>	Power W
21	0	14,008	96,0	130,0	327
22	10		61,0	96,0	

### Corrected continuous operating voltage $U_c'$ application to evaluate the thermal stability

Oscillogram No.	Time min	Voltage kV	Current + mA <sub>cr</sub>	Current - mA <sub>cr</sub>	Power W
23	0	11,288	1,51	2,96	10,35
	5		1,20	1,12	3,03
	10		1,18	1,08	2,83
24	15		1,16	1,05	2,50
	20		1,12	1,03	2,21
	25		1,11	1,02	2,14
25	30		1,10	1,01	2,05

continued

*[Handwritten signature and stamp]*

306



continued

Sample No.: OD2

Preheating temperature: 61 °C

Date: June 30, 2008

Second high current impulse application

Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Energy kJ	Current $\mu$ s
26	94,0 x 2	---	99,0	---	4,5/9,8

Corrected rated voltage  $U_r$  application

Oscillogram No.	Time s	Voltage kV	Current + mA <sub>cr</sub>	Current - mA <sub>cr</sub>	Power W
27	0	13,957	105,0	156,0	260
28	10		48,0	71,0	

Corrected continuous operating voltage  $U_c$  application to evaluate the thermal stability

Oscillogram No.	Time min	Voltage kV	Current + mA <sub>cr</sub>	Current - mA <sub>cr</sub>	Power W
29	0	11,247	2,50	3,01	10,80
	5		1,24	1,12	2,81
	10		12,0	1,07	2,40
30	15		1,18	1,06	2,18
	20		1,17	1,02	2,12
	25		1,15	1,01	2,00
	31		30	1,13	0,99

continued

*[Handwritten signatures and stamps]*

continued

Sample No.: OD3

Preheating temperature: 61 °C

Date: June 30, 2008

Second high current impulse application

Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Energy kJ	Current $\mu$ s
32	94,0 x 2	---	103,0	---	4,5/9,8

Corrected rated voltage  $U_r$  application

Oscillogram No.	Time s	Voltage kV	Current + mA <sub>cr</sub>	Current - mA <sub>cr</sub>	Power W
33	0	13,905	60,0	80,0	185
34	10		46,0	70,0	

Corrected continuous operating voltage  $U_c$  application to evaluate the thermal stability

Oscillogram No.	Time min	Voltage kV	Current + mA <sub>cr</sub>	Current - mA <sub>cr</sub>	Power W
35	0	11,205	2,30	2,80	9,51
	5		1,30	1,18	3,51
	10		1,26	1,16	3,27
36	15		1,24	1,10	3,09
	20		1,22	1,06	2,72
	25		1,21	1,03	2,54
37	30		1,18	1,01	2,40

continued

High current impulse operating duty test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: June 30, 2008


Sample	Requested current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.		kV	No.	$\mu$ s	kA	kV
OD1	I <sub>n</sub>	45,8	38	8,7/19,0	9,95	33,0
		45,9	39		10,11	33,1
45,9		40	9,90		33,4	
OD2		46,0	41		9,90	33,4
		46,1	42		10,16	33,4
OD3		46,1	43		10,08	33,1

Oscilloscope settings			
	sampling division	input	attenuation
	$\mu$ s	V <sub>div</sub>	
Current	5	1,0	50:10
Voltage	5	1,0	20:5

Notes:

ВЕРНО КОПИРОВАНА

Circuit A0019



Power frequency supply

- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI N°.31120;  $R = 941,4 \Omega$
- Electro optical system CESI N°.-.; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI N°. 6318

Voltage measuring system


- D - Voltage divider SAGI; CESI N°.11120
- Electro optical system CESI N°.11520/11524; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI N°.6318

ВЕРНО КОПИРОВАНА

*[Handwritten signature and stamp]*

B

Circuit A0120



**Impulse generator**

- No. of stages 1
- Cg 4,98  $\mu$ F
- Lc 10  $\mu$ H
- S - Spark-gap

**Voltage measuring system.**


- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No. 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

**Current measuring system**

- Sh - Current shunt CESI No.6042; R= 2 m $\Omega$ ; peak current= 250 kA
- Electro optical system CESI No. 11517/518
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

ВІДПОВІДАЛЬНИК

Circuit A0122



**Impulse generator**

- No. of stages 1
- Cg 4,98  $\mu$ F
- Lc 100  $\mu$ H
- S - Spark-gap

**Voltage measuring system.**


- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522; attenuation 5:5
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

**Current measuring system**

- Sh - Current shunt CESI No.6042; R= 2 m $\Omega$ ; peak current= 250 kA
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

ВЕРНО КОПИРОВАНА

Circuit A0015



Impulse generator

No. of stages: 1

- C<sub>g</sub> - Capacitor 4,98 μF
- L - Inductance of the circuit
- L<sub>c</sub> - Inductor 10 μH
- S - Spark gap

One resistor block has been added

Power frequency supply

- RE - Regulator type specialtrasfo; power 20 kVA; voltage 380 V/ 220 V
- T - Transformer type Pivi; power 30 kVA; voltage 220 V/ 15 kV
- B - Blocking gap

Current measuring system

- Sh<sub>1</sub> - Current shunt CESI No.6042; R = 0,002 Ω
- Electro optical system CESI No.11517/11518; attenuation 20:5
- OSC - Oscilloscope type Tektonix 540A; CESI No.13217 (on channel No.1)


Voltage measuring system

- D - Voltage divider SAGI ; CESI No.1120; k = 1010
- Electro optical system CESI No.11520/11521; attenuation 50:5
- OSC - Oscilloscope type Tektonix 540A; CESI No.13217 (on channel No.2)

ВНИМАТЕЛЬНО ЧИТАЙТЕ

*[Handwritten signature and stamp]*

Circuit A0121



**Impulse generator**

No. of stages 2  
 Cg 3,32  $\mu$ F

S - Spark-gap

Three blocks in series have been added

**Voltage measuring system.**

D - Voltage divider SAGI; CESI No.11120  
 - Electro optical system CESI No11517/518  
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

**Current measuring system**

Sh - Current shunt CESI No.6042; R= 2 m $\Omega$ ; peak current= 250 kA  
 - Electro optical system CESI No11521/522  
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)


ВЫПОЛНЕНО

*[Handwritten signature and stamp]*



B

Circuit A0123



to circuit A0020

*[Handwritten signature]*

Impulse generator circuit

No. of stages 2


$C_g$  3,32  $\mu F$

S - spark-gap

ВИПРОСОБИТЛАННА

*[Handwritten signature]*

Circuit A0020



Impulse generator circuit A0124

I - Circuit-breaker

Impulsive current measuring system

Sh<sub>1</sub> - Current shunt CESI No.6039; R= 20 mΩ

- Electro optical system CESI No.11517/518; attenuation 5:5

OSC<sub>1</sub> - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

Power frequency circuit A0130

Voltage measuring system.

D - Voltage divider SAGI; CESI No.11120

- Electro optical system CESI No.8009/8015; attenuation 50:5

OSC<sub>1</sub> - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

OSC<sub>2</sub> - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090 (on channel No.2)

Power frequency current measuring system

Sh<sub>2</sub> (TOV) - Current shunt CESI R= 500 Ω - Electro optical system CESI No.8011/8017

OSC<sub>2</sub> - Oscilloscope type TEKTRONIX TDS 744A; CESI No.13937 (on channel No.1)


*[Handwritten signatures and stamps]*

*[Circular stamp]*

*[Handwritten signature]*

B

Circuit A0131



Power-frequency circuit

from 380Vac power supply

- R<sub>1</sub> single-phase voltage regulator CORMES; power 20 kVA; voltage 380/0 ÷ 220 Vac
- R<sub>2</sub> single-phase voltage regulator CORMES; power 10 kVA; voltage 380/0 ÷ 220 Vac
- T<sub>1</sub> voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200-400 V/15-30 kV

REPUBLIQUE DE COTE D'IVOIRE  
LABORATOIRE NATIONAL DE METROLOGIE

*[Handwritten signature and stamp]*

Client **DERVASIL F-42800 Saint Joseph – France**

Tested equipment **Disconnectors for polymer housed metal-oxide surge arresters**

Tests carried out **Time-versus current curve**

Standards/Specifications **Specification ENEL DY1018 (11-2003)**

Test date **from March 8, 2005 to March 8, 2005**

The results reported in this document relate only to the tested equipment.  
 Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages **15** No. of pages annexed **28**

Issue date **March 14, 2005**

Prepared **BU PeC/TEST - M. Levati**

Verified **BU PeC/TEST - R. Malgesini**

Approved **BU PeC/TEST - M. de Nigris**

**CESI**  
 CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
 Business Unit  
 Prove ai Componenti  
 Il Responsabile del Laboratorio

CESI  
 Centro Elettrotecnico  
 Sperimentale Italiano  
 Giacinto Motta spa

Via R. Rubattino 64  
 20134 Milano - Italia  
 Telefono +39 0221251  
 Fax +39 0221255440  
 http://www.cesi.it

Capitale sociale € 550.000 Euro  
 interamente versato  
 Codice fiscale e numero  
 iscrizione CCIAA 09793580150

Registro Imprese di Milano  
 Sezione Ordinaria  
 N. R.E.A. 420222  
 P.I. IT00793580150

REPUBBLICA ITALIANA

318

Tests witnessed by /

Identification of the object requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawing, identified by CESI and numbered A5/009432 No. 1, is annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: -

The measurement uncertainties of the test results reported in this document comply with the following limits:

voltage : ± 5 % ; current : ± 5 % ; time : ± 5 %

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum estimated values referred to that type of measurement.

Receipt date of the sample March 7, 2005

Test location CESI - Via Rubattino 54 - Milan


Activity code 31757A

Contents	Page	Test date
Rated characteristics of the surge arrester for which the disconnectors are designed to be used	4	---
Disconnector operation test – Arrangements and test modalities	5	---
Test results	5	---
Single-phase current tests results	6 4 8	March 8, 2005
Time current versus curve	9	---
Test circuit M0015	10	---
Photographs of test arrangement	11	---
Photographs of some samples after the test	11 4 12	---
Laboratory informations	13 + 15	---

Pages annexed:

- Oscillogram from test report MF-A5/008453 (total pages: 27)

- drawing no. A5/009432 (1 page)



Handwritten signature and stamp

Approved

CESI


Handwritten signature

Test Report




Rated characteristics of the surge arrester for witch the disconnectors are designed to be used

Manufacturer	DERVASIL F-42800 Saint Joseph (France)
Duty cycle voltage rating	up to 17,5 kV
Frequency	50 Hz
Classifying current	5 kA & 10 kA
Classification	distribution normal & heavy duty



ВЕРНО С ОФЕРТНАЈА



Disconnecter operation test

Arrangements and test modalities

The disconnectors were tested with-out the surge arrester and with an insulating bracket also supplied by the manufacturer

The bolted junction from the disconnector and the flexible conductor was performed applying a torque force of 20 Nm for 30s.

The applied voltage was about 16750 V

The test voltage was applied for 400 ms and after 400 ms with-out voltage, the test voltage was reapplied due to verify the effective disconnection

Five samples of disconnectors were tested for each of the four current values stated by the Standard.

Test results

In all the tests the disconnectors operated and the separation was permanent and effective. The operation times (time to first movement) are reported in the table from page 6 to page 8 and in the diagram to page 9. A view of some disconnector after the test is shown in the photos from page 11 to page 12.

The test result is positive

*[Handwritten mark]*

*[Handwritten signature]*  
*[Circular stamp]*

ВЯРНО С О Р В Е Т Я П А Я  
А П Р Е Л Ъ 2 0 0 8



Single-phase current tests results

Test circuit: M0015

Reference number of the oscillograms: MP-A5/008453

Calibration of the test circuit						
Test	Oscillogram	Prospective current		Power factor	Supply voltage	Frequency
		rms value	peak value			
No.	No./sheet	A	A	-	V	Hz
T1	3/1	613	1560	0,07	16770	50

Date: March 8, 2005

Test	Oscillogram	Sample tested	voltage	current	time to first movement	restart of the current	Photo of one sample after the test	Test result
No.	No./sheet	No.	V	A	ms	yes / not	no.	
1	5/2	1	16630	599	14,5	not	3	positive
2	6/2	2	16580	603	4,9	not		positive
3	7/2	3	16620	597	10,3	not		positive
4	8/2	4	16620	592	15,0	not		positive
5	9/2	5	16540	594	6,6	not		positive

ВИПРОСОБНИКА

*[Handwritten signatures and stamps]*

continued

continued

Test circuit:

M0015

Reference number of the oscillograms:

MP-A5/008453

Test	Oscillogram	Prospective current		Power factor	Supply voltage	Frequency
		rms value	peak value			
No.	No./sheet	A	A	-	V	Hz
T2	11/1	200	525	0,05	16530	50

Date: March 8, 2005

Test	Oscillogram	Sample tested	voltage	current	time to first movement	restart of the current	Photo of one sample after the test	Test result
No.	No./sheet	No.	V	A	ms	yes / not	no.	
6	12/2	6	16530	198	23,6	not	4	positive
7	13/2	7	16580	199	29,7	not		positive
8	14/2	8	16500	196	17,1	not		positive
9	15/2	9	16510	197	36,5	not		positive
10	16/2	10	16500	198	28,2	not		positive

ВВЕДЕНО В ОБРАТНУЮ

Handwritten signature and circular stamp with illegible text inside.

continued

continued

Test circuit: M0015

Reference number of the oscillograms: MP-A5/008453

Calibration of the test circuit						
Test	Oscillogram	Prospective current		Power factor	Supply voltage	Frequency
		rms value	peak value			
No.	No./sheet	A	A	-	V	Hz
T3	17/1	19,72	53,0	0,03	16730	50

Date: March 8, 2005


Test	Oscillogram	Sample tested	voltage	current	time to first movement	restart of the current	Photo of one sample after the test	Test result
No.	No./sheet	No.	V	A	ms	yes / not	no.	
11	18/2	11	16710	19,5	82,6	not	5	positive
12	20/1	12	16670	19,6	387	not		positive
13	21/*	13	16760	19,77	147	not		positive
14	22/*	14	16680	19,8	230	not		positive
15	24/1	15	16680	19,8	149	not		positive

\* manca l'oscillogramma

REPUBBLICA ITALIANA

13

5716



ВИПРОСОБНИЦА

VNIIT

me current versus time


*Handwritten signature*

A57008453

CFSI

Test Report

Test circuit M0015



The symbols used in this diagram are the same as those on the oscillograms.

ВРНО СОПРІЗНАЛА

*[Handwritten signatures and a circular stamp]*

327

Photographs of test arrangement




Photo no. 1



Photo no. 2

АЛМАТЫ АЭРОКОСМИЧЕСКОЕ ПРИБОРОСТРОИТЕЛЬНОЕ ПРЕДПРИЯТИЕ

Photographs of some samples after the test




Photo no. 3




Photo no. 4

ВІДНО СОБІТОВАДА

*[Handwritten signature]*

Laboratory information

Requested values and test circuit parameters

Test No.	Requested values					$X_{AT}$	$X_{bt}$	Synchronizer position	Time of the test
	voltage	r.m.s. current	peak current	$I^2t$	duration				
	V	A	A	$MA^2s$	s	$\Omega$	$\Omega$	$^{\circ}$	-
T1	16650	600	-	-	0,1	20,0x2	-	37	13:00
1 to 5	"	600	-	-	0,1	20,0x2	-	127	13:10
T2	"	200	-	-	0,1	71,2x2	-	37	14:00
6 to 10	"	200	-	-	0,5	71,2x2	-	127	14:05
T3	"	20	-	-	0,1	x2	-	37	15:00
11 to 15	"	20	-	-	5,0	225,4x2	-	127	15:05

РАСПОС ПЕРИЗНАЈА



Laboratory information

Test laboratory: P102 / MP1  
 CESI testing team: C. Assi  
 C. Carniel  
 G. Vassallo

Date: March 8, 2005

Characteristics of supply circuit

Tests		Supply	OTE MV		OTE LV	
from	to		K	position	K	position
T1	15	23 kV Lambrate	4,2	-		

Characteristics of measuring system

Measure	Transducer		KRENZ		TRANSISCOPE
	ref.	position	TRC No.	channel No.	channel No.
I	G1		1	1	
U	N1 - N2		1	2	
V	A1 - A3		1	3	

Symbols assigned in 'ref.' column refer to the measuring equipment listed in page "Laboratory P102 - MP1. Measuring system characteristics."

Other measuring equipment:  
 Ohmmeter CESI number: /

APPROCCORRIBUATA

A large handwritten signature is present over a circular stamp. The signature appears to be 'G. Vassallo'.

Laboratory P102 – MPI  
Measuring system characteristics


Ref.	Type	CBSI No.
A1	Voltage transformer TV2 – R-T	5534
A2	Voltage transformer TV2 – S-R	5535
A3	Resistive dividers for TV2	14142
B1	Resistive divider K= 206,5	11465
B2	Resistive divider K= 206,5	11466
B3	Resistive divider K= 206,5	11467
B4	Resistive divider K= 206,5	11468
C1	Current transformer TA2 – R	17060
C2	Current transformer TA2 – S	17061
C3	Current transformer TA2 – T	17059
C4	Resistive burden for TA2	5562
D1	Current transformer 4000 A / 5 A	14466
D2	Resistive burden for TA3	17072
E1	Shunt 40 $\mu\Omega$ – 100 kA – R	8231
E2	Shunt 40 $\mu\Omega$ – 100 kA – S	8232
E3	Shunt 40 $\mu\Omega$ – 100 kA – T	8230
F1	Shunt 1,6 m $\Omega$ – 5 kA – R	7964
F2	Shunt 1,6 m $\Omega$ – 5 kA – S	7968
F3	Shunt 1,6 m $\Omega$ – 5 kA – T	7966
G1	Shunt 1,6 m $\Omega$ – 5 kA – additional	7965
G2	Shunt 1,6 m $\Omega$ – 5 kA – additional	7963
G3	Shunt 1,6 m $\Omega$ – 5 kA – additional	7967
H1	Shunt 80 $\mu\Omega$ – 100 kA	5524
H2	Shunt 80 $\mu\Omega$ – 100 kA	5525
H3	Shunt 80 $\mu\Omega$ – 100 kA	5526
J1	Electro-optical link for thermocouple T	13372
J2	Electro-optical link for thermocouple T	14556
J3	Electro-optical link for thermocouple J	17074
J4	Electro-optical link for thermocouple J	17076
J5	Electro-optical link for thermocouple J	17078
J6	Electro-optical link for thermocouple K	22463
J7	Electro-optical link for thermocouple K	22465
J8	Electro-optical link for thermocouple K	22467
J9	Electro-optical link for thermocouple K	22469

Ref.	Type	CBSI No.
K1	Shunt 160 $\mu\Omega$ – 30 kA	5559
K2	Shunt 160 $\mu\Omega$ – 30 kA	5560
K3	Shunt 160 $\mu\Omega$ – 30 kA	5561
L1	Shunt 111 m $\Omega$	9754
L2	Shunt 111 m $\Omega$	9758
L3	Shunt 111 m $\Omega$	9759
=	KREBZ TRC1	13119
=	KREBZ TRC2	13120
M1	Voltage transformer 24 kV / 100 V	3387
N1	Divider RC 30 kV	14677
N2	Divider RC 30 kV	14678
N3	Divider RC 30 kV	14679
N4	Divider RC 30 kV	11990
N5	Divider RC 30 kV	11991
N6	Divider RC 30 kV	11992
P1	Schering bridge	696
P2	Resistive box	8451

Measuring software: SAD – P102	Software release: 4.2 – 31/12/2002	Hardware: VAX 4200 with VMS 5.4
--------------------------------	------------------------------------	---------------------------------

Prepared by: G. Zuccala


Date: 01/05/2004



ВРЕМЯ СОПРИБУЖАНА

$I_p = 1.56 \text{ kA}$   
 $I = 613.21 \text{ A}$   
 $D_c = 94.96 \text{ ms}$   
 $I_{rt} = 53.78 \text{ kA}^2\text{s}$   
 $U_b = 16.77 \text{ kV}$   
 $C_f = 0.07$   
 $F = 50.3 \text{ Hz}$

*Handwritten signature*




*Handwritten signature*

I 391  
*Handwritten signature*

CESI MP-A5/008453 n.3

$I_p = 883.92 \text{ A}$   
 $I = 599.10 \text{ A}$   
 $D_c = 409.68 \text{ ms}$   
 $I_{zt} = 142.80 \text{ kA}^2\text{s}$   
 $U_a = 16.39 \text{ kV}$   
 $U_b = 16.63 \text{ kV}$   
 $C_f = 0.77$   
 $F = 49.9 \text{ Hz}$



$29.2 \text{ ms/div}$   
 $1314 \text{ ns}$

ВЕРНО СОГЛАСОВАНО

$I$  391. A  
 [Signature]

CESI MP-A5/008453 n.5

Dt=14.44ns

U  
16.7 kV

УПРАВЛЕНИЕ

U  
1. kV

1.991 A

53. 67. 81. 95. 109. 116ms  
1.4ms/div


CESI MP-A5/008453 n.5

*Handwritten mark*

*Handwritten signature*

*Handwritten signature*

$I_p = 878.57 \text{ A}$   
 $I = 603.29 \text{ A}$   
 $D_c = 409.53 \text{ ms}$   
 $I_{zt} = 145.50 \text{ kA}^2\text{s}$   
 $U_a = 16.37 \text{ kV}$   
 $U_b = 16.58 \text{ kV}$   
 $C_f = 0.81$   
 $F = 50.3 \text{ Hz}$



$29.2 \text{ ms/div}$   
 $1314 \text{ ms}$

U 16.7 kV

U 10. kV

I 391. A

0.

292.

584.

876.

1168.


1314ms

РОССОБТЕКНИКА

CESI MP-A5/008453 n.6

Dt=4.89ms

*B*



2.3ms/div

V  
16.7 kV

I  
391. A

sat

38.

61.

84.

107.

130.


142ms

INSTRUMENTS DIVISION

*[Handwritten Signature]*

CESI MP-A5/008453 n.6

Ip=911.39 A  
 I=597.34 A  
 Dc=409.83 ms  
 It=144.55 kA<sup>2</sup>s  
 Ua=16.39 kV  
 Ub=16.62 kV  
 Cf=0.68  
 F=50.0 Hz



29.2ms/div  
 1314ms


ВНПРОСФПРПНАНА

338  
 CESI MP-A5/008453 n.7  
 0.



Dt=10.31ms

*Handwritten mark*



2.2ms/div

137ms

126.

104.

82.

60.

38.

ВІПРОСОРУВЕННЯ


U 1 kV

I 391 A

*Handwritten signatures and notes*

CESI MP-A5/008453 n.7

$I_p = 880.10 \text{ A}$   
 $I = 592.50 \text{ A}$   
 $D_c = 409.68 \text{ ms}$   
 $I_{\Sigma t} = 141.73 \text{ kA}^2\text{s}$   
 $U_a = 16.35 \text{ kV}$   
 $U_b = 16.62 \text{ kV}$   
 $C_f = 0.75$   
 $F = 49.9 \text{ Hz}$




ВЛНДБ СОС ПЕНАЛІА  
 У 10. kV

I 391. A  
 0. 292. 584. 876. 1168. 1314ms  
 29.2ms/div  
 1314ms

CESI MP-A5/008453 n.8

Dt=14.99ms

*B*



ВСТУП С ОУЧТ В ПЛАН


*[Handwritten signature]*

*[Handwritten signature]*

CESI MP-A5/008453 n.8

341

$I_p = 855.26 \text{ A}$   
 $I = 594.65 \text{ A}$   
 $D_c = 409.82 \text{ ms}$   
 $I_{\tau t} = 139.96 \text{ kA}^2\text{s}$   
 $U_a = 16.30 \text{ kV}$   
 $U_b = 16.54 \text{ kV}$   
 $C_f = 0.85$   
 $F = 49.8 \text{ Hz}$



ДИПРО СОРЯТИЗЛАНА


I 391 A  
 U 10 kV  
 U 16.7 kV

0. 292. 584. 876. 1168. 1314ms  
 29.2ms/div  
 1314ms

CESI MP-A5/008453 n.9

Dt=6.64ms

CB



1.8ms/div

47. 65. 83. 101. 119. 128ms

U 16.7 kV

U 1. kV

I 391. A

ВЫВОД ПО ПИТАНИЮ


*[Handwritten signature]*

*[Handwritten signature]*


CESI MP-A5/008453 n.9

343

$I_p = 525.46 \text{ A}$   
 $I = 200.60 \text{ A}$   
 $D_c = 94.72 \text{ ms}$   
 $I_{rt} = 6.56 \text{ kA}^2\text{s}$   
 $U_b = 16.53 \text{ kV}$   
 $C_f = 0.05$   
 $F = 50.0 \text{ Hz}$





ВІСНОВОК ПРАЦІ

  
 [Circular stamp with illegible text]

CESI MP-A5/008453 n.11

IP=287.17 A  
 I=198.20 A  
 DC=409.51 ms  
 I<sub>rt</sub>=15.75 kA<sup>2</sup>s  
 U<sub>a</sub>=16.25 kV  
 U<sub>b</sub>=16.53 kV  
 Cf=0.82  
 F=49.9 Hz



29.2ms/div  
 1314ms

1168.

876

584.

292.

0.

CESI MP-A5/008453 n.12


365

ВІПРОСОПІТАЛА

*[Handwritten signature]*

506

Dt = 23.65ms



2.2ms/div

141ms

130.

108.

86.

64.

42.

АННОСОПРЕЖИМА

U 1 kV


I 156. A

*[Handwritten signature]*  
*[Handwritten initials]*

CESI MP-A5/008453 n.12



Ip=292.20 A  
 I=198.69 A  
 Dc=399.95 ms  
 Irt=15.83 kA<sup>2</sup>s  
 Ua=16.35 kV  
~~Ua~~ Ua=16.58 kV  
 Cf=0.77  
 F=50.0 Hz



29.2ms/div  
 1314ms

CESI MP-A5/008453 n.13

Dt=29.7ms

sat

2.2ms/div

136ms

125.

103.

81.

59.

37.

U  
16.7 kV

U  
1 kV

I  
156. A


BRITISH COLUMBIA UNIVERSITY

*[Handwritten signature]*

*[Handwritten signature]*

CESI MP-A5/008453 n.13

$I_p = 284.87 \text{ A}$   
 $I = 196.47 \text{ A}$   
 $D_c = 409.66 \text{ ms}$   
 $I_{zt} = 15.67 \text{ kA}^2\text{s}$   
 $U_a = 16.17 \text{ kV}$   
 $U_b = 16.50 \text{ kV}$   
 $C_f = 0.82$   
 $F = 50.0 \text{ Hz}$



$29.2 \text{ ms/div}$   
 $1314 \text{ ns}$


LABORATOIRE  
 DE RECHERCHES  
 EN ELECTRICITE

I 156. A  
 [Signature]

CESI MP-A5/008453 n.14

Dt=17.1ms

*B*




АТЛАНТИКА

*G*

CESI MP-A5/008453 n.14

$I_p = 288.09 \text{ A}$   
 $I = 196.96 \text{ A}$   
 $D_c = 409.13 \text{ ms}$   
 $I_{zt} = 15.42 \text{ kA}^2\text{s}$   
 $U_a = 16.26 \text{ kV}$   
 $U_b = 16.51 \text{ kV}$   
 $C_f = 0.79$   
 $F = 49.6 \text{ Hz}$

*B*



$29.2 \text{ ms/div}$   
 $1314 \text{ ms}$

ВІДПОВІДАЛЬНИЙ


I 156. A

*A. Konec*

CESI MP-A5/008453 n. 15

Dt=36.56ms

B



2.5ms/div

147ms

135.

110.

85.

60.

35.

U 16.7 kV

U 1. kV

I 156. A


ИЗРНО С ОРГУНИЦАЈА

CESI MP-A5/008453 n.15

35x

$I_p = 287.62 \text{ A}$   
 $I = 197.71 \text{ A}$   
 $D_c = 399.85 \text{ ms}$   
 $I_{rt} = 15.58 \text{ kA}^2\text{s}$   
 $U_a = 16.29 \text{ kV}$   
 $U_b = 16.50 \text{ kV}$   
 $C_f = 0.81$   
 $F = 50.0 \text{ Hz}$

*B*



$29.2 \text{ ms/div}$   
 $1314 \text{ ns}$


ВЕРНО СОБРАНО

*g*  
*U. Kengell*  
 (Signature and stamp)

CESI MP-A5/008453 n.16

B

Dt=28.2ms



2.4ms/div

U 16.7 kV

U 1 kV

I 156 A

35.

59.

83.

107.

131.

143ms

ВЕРНО СОВЕРШЕНА


*Handwritten signature*

CESI MP-A5/008453 n.16



$I_p = 52.97 \text{ A}$   
 $I = 19.72 \text{ A}$   
 $D_c = 94.65 \text{ ms}$   
 $I_{rt} = 70.12 \text{ A}^2\text{s}$   
 $U_b = 16.73 \text{ kV}$   
 $C_f = 0.03$   
 $F = 49.9 \text{ Hz}$

*B*



5. ms/div

225ms

200.

150.

100.

50.

0.

ВЕРНО СОРТИРОВАНА

U 10. kV

I 15.6 A


*A. Konec*

CESI MP-A5/008453 n.17



Dt=82.65ms

*Handwritten initials*



2.9ms/div

174ms

160.

131.

102.

73.

44.

U 16.7 kV

U 1. kV

I 15.6 A


ВЕРНО СОВЕРШЕНА

*Handwritten signature*

CESI MP-A5/008453 n.18

Dt=387.5ms

*B*



I 15.6 A

U 16.7 kV

U 1 kV

ВЕРНО СОПРЯЖАЛА

sat

10. ms/div  
1311ms

1261.

1161.

1061.

961.

861.


CESI MP-A5/008453 n.20

*[Signature]*

*[Signature]*

*[Signature]*

$I_p = 32.04 \text{ A}$   
 $I = 19.64 \text{ A}$   
 $D_c = 439.45 \text{ ms}$   
 $I_{rt} = 162.64 \text{ A}^2\text{s}$   
 $U_a = 16.56 \text{ kV}$   
 $\cancel{I_{rt}} = 16.71 \text{ kV}$   
 $C_f = 0.55$   
 $F = 50.1 \text{ Hz}$




$29.2 \text{ ms/div}$   
 $1314 \text{ ns}$

0. 292. 584. 876. 1168.

CESI MP-A5/008453 n.24

N° modif.	IND.	DESIGNATION	VISA	DATE
	A	création		
031	B	modification embout fileté	LD	04/03/05



**CESI**

PROTOCOLLO DATA

A 5/009432 n.1 14 MAR. 2005

Firma: *[Signature]*

Fournitures conforme avec la spécification Dervasil SP0809  
 Fournisseur LAMCO  
 terminal material : brass

N° PLAN	repère	nbre	Désignation	Référence	Motifre	Observation
TOLERANCES GENERALES :			TRAITEMENT : <input type="checkbox"/> GALVANISATION A CHAUD SELON SA 0223 <input type="checkbox"/> AUTRE (voir nota)			

# DECONNECTEUR

CE DOCUMENT NE PEUT ETRE REPRODUIT OU COMMUNIQUE SANS ACCORD  
 ECRIT DE LA SOCIETE DERSASIL

CODE ARTICLE :



**dervasil**  
**groupe SICAME**

DESSINE PAR : LD

FORMAT :  
A4

DATE : 11/01/2005

ECHELLE :  
1/1

VERIFIE PAR : CG


PAGE :  
1/1

PLAN N° - DRAWING N° - PLANO N°

route de POPENOT - 42800 ST JOSEPH  
 tel : 04.77.75.29.98. fax : 04.77.83.22.80.

**99B000053B**

*[Handwritten signature]*  
 360



**dervasil**

TECHNICAL SERVICE

*B*

TEST REPORT

N° 224

MC 98 002 IND. A

MAJ : 25/03/98

**PRODUCT: Lightning Arrester AZBD 42**

**TESTS CARRIED OUT: BENDING TEST**

STANDARD: IEC 60099-4 - § 10.8.9

N° SAMPLES : 0019, 0020, 0021, 0022, 0023,

*[Handwritten mark]*

TEST DATE: 28/10/2008

TEST PLACE:

- DERVASIL Laboratory

TEST PERFORMED BY: M. DZIRI

*[Handwritten signature]*

CONCLUSION : Lightning Arrester AZBD 420 passed bending test

TECHNICAL DIRECTOR

*[Handwritten signature]*

*[Handwritten initials]*

*[Handwritten signature]*



### 1 - Identification of Samples

Lightning arrestes 0019, 0020, 0021, 0022, 0023 are manufactured with :  
ZnO blocks lot 7641 Otowa 5 kV  
Moulding : HTV Silicone

Height : 360 mm  
Leakage distance :1045 mm  
Arcing distance : 365 mm

### 2 - Test Equipment:

10 kg weights  
Dial Torque Wrench20-100 Nm

### 3 - Test Procedure

#### 3.1 Mechanical test

Following strengths were applied successively to sample  
Cantilever load : 1000 N.corresponding to 350 Nm  
Torque Load : 70 Nm.

Test	Result
Cantilever load 1000N 1min	No permanent distorsion
Torque load 70 Nm	No permanent distorsion

#### 3.2 Electrical tests

Levels of Partial Discharges have been measured before and after mechanical tests. No variations occurred.






### 4 - Breaking tests


Sample 0020 was tested until breaking

Weight (kg)	Cantilever load (Nm)	
1200	420	RAS
1300	450	RAS
1400	490	RAS
1500	520	RAS
1600	560	RAS
1700	590	RAS
1800	630	RAS
1900	660	Breaking after 20s



ВЕРНО СОДЕРЖИТСЯ

*Handwritten signatures and initials*



**dervasil**

TECHNICAL SERVICE

*B*

TEST REPORT

N° 228

MC 98 002 IND. A

MAJ : 25/03/98

**PRODUCT: Lightning Arrester AZBD 42**

**TESTS CARRIED OUT: MOISTURE INGRESS TEST**

STANDARD: IEC 60099-4 - § 10.8.13.

N° SAMPLES : 0023

*J*

TEST DATE: 19/01/2009 to 23/01/2009

TEST PLACE:

- DERVASIL Laboratory for themomechanical test
- FERRAZ Laboratory for initial and final verification

TEST PERFORMED BY: M. DZIRI

CONCLUSION : Lightning Arrester AZBD 420 passed moisture ingress test

TECHNICAL DIRECTOR



B

### 1 - Identification of Samples

Lightning arrester 0023 is manufactured with :

ZnO blocks lot 7641 Otowa 5 kV

Moulding : HTV Silicone

Height : 360 mm

Leakage distance : 1045 mm

Arcing distance : 365 mm

### 2 - Test Equipment:

10 kg weights

Dial Torque Wrench 20-100 Nm

HV generator

Oven WEISSTECKNIC for thermal cycle

Handwritten signature


### 3 - Test Procedure

#### 3.1 Initial measurement

- Measurement of Watt Loss at  $U_c = 35$  kV
- Measurement of Discharge Partial level at  $1.05 * U_c = 36.75$  kV
- Measurement of residual voltage at 2500 A (8/20  $\mu$ s wave )

#### 3.2 Torque preconditionning

Torque Load at 70 Nm has been applied during 30s to sample







Handwritten signature and stamp



### 3.3 Thermomechanical preconditionning


Sample has been submitted to two 48 h thermal cycles of heating and cooling under mechanical load of 100 kg. Direction of load was changed every 24 h





### 3.4 Water immersion

Sample has been immersed in a vessel, in boiling deionized water with 1 kg/ of NaCl, for 42h. After end sample remains in water at 50°C.



09

### 3.5 Final measurement

- Visual inspection
- Measurement of Watt Loss at  $U_c = 35 \text{ kV}$
- Measurement of Discharge Partial level at  $1.05 * U_c = 36.75 \text{ kV}$
- Measurement of residual voltage at 2500 A (8/20 $\mu\text{s}$  wave )

## 4 - Test Results

	Before test		After test		Variation
Watt loss	35 kV	0.692 W	35 kV	0.802 W	15.9%
Residual Voltage	2500 A	98 kV	2500 A	98 kV	0%
Partial discharge level		< 6pC		< 6pc	

Visual inspection after test: no damages

09

Handwritten signature and stamp

367

client Dervosil - Saint Joseph (France)

equipment under test Polymer housed metal-oxide surge arresters Type AZB 27

tests performed Weather ageing test - Test series A

normative documents IEC Standard 60099-4 Edition 2.0 (2004-05).

receipt date of the sample May 24, 2004

test date from July 8, 2004 to August 24, 2004

no. of pages 22 no. of pages annexed 8

*Handwritten signature*

the test results relate only to the sample tested  
this document shall not be reproduced except in full without the written approval of CESI

first issue date May 12, 2005

prepared PeC/TEST - G. Fedeli

*Giulio Fedeli*

verified PeC/TEST - A. Sironi

*Alberto Sironi*

approved PeC/TEST - M. de Nigris

**CESI**  
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO  
Business Unit  
Prove e Componenti  
Il Responsabile del Laboratorio

*Handwritten signature*

CESI  
Centro Elettrotecnico  
Sperimentale Italiano  
Giacinto Motte SpA

Via R. Robottino 54  
20134 Milano - Italia  
Telefono +39 0221291  
Fax +39 022125440  
www.cesi.it

Capitale sociale € 550 000 Euro  
Integramente versato  
Codice fiscale e numero  
Iscrizione CCIAA 00793580150

Reg. Imprese di Milano  
Sez. n. 020100001  
N. R.E.A. 420222  
P.I. 00793580150

REPUBBLICA ITALIANA

*Handwritten signature*

tests witnessed by: /

identification of the object: Performed

The Manufacturer guarantees that the tested surge arrester is manufactured according to the submitted drawings.

CESI checked that these drawings adequately represent in shape and dimensions the essential details and the parts of the tested object.

These drawings identified by CESI and numbered A5/021441 no.1 to 10 have been returned to the Client.

The data necessary to permit repetition of the tests are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3\%$  ; time parameters:  $\pm 10\%$
- dielectric tests with impulse current : peak value:  $\pm 3\%$  ; time parameters:  $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3\%$
- dielectric tests with direct voltage : voltage:  $\pm 3\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

CESI testing team: G. Fedeli

test laboratory: P188

activity code: 41285B

keywords: 12015R 23801L 31020W 44060J 53001D

ВІСНОК ОРГАНІЗАЦІЇ

contents	page	test date
Test object	4	
Test carried out and test procedure	8	
Summary of test result	9	
Initial measurements	11	05/12/04
Weather ageing test. Test circuit	13	
Weather ageing test. Test arrangement	14	
Weather ageing test. Pictures after the test	16	07/08/04 to 08/24/04
Final measurements	21	08/30/04
Reference documents annexed:		
Oscillograms (8 pages), CESI no. A4/510342		

*[Handwritten signature]*

*[Handwritten signature]*

AT-A5/022740



**Test Report**



**Test object**

Type: Two polymer housed metal-oxide surge arrester type AZB 27.  
The test objects were identified by Cesi as sample W1 and sample W2.

electrical characteristics (claimed by the client)

manufacturer's name	DERVASIL - Saint Joseph (France)
nominal discharge current - $I_N$ [kA]	10,0
rated voltage - $U_n$ [kV]	27,0
continuous operating voltage - $U_c$ [kV]	22,0
line discharge class	1
rated frequency - [Hz]	50

Dimensional characteristics of the test objects, claimed by the Client:

total height [mm]	272,4
sheds diameter [mm]	119
core diameter [mm]	59,4

ВЕРНО СОДЕРЖИТСЯ

Handwritten signatures and a circular stamp, likely indicating approval or certification.

B

Dimensional characteristics of the test objects measured by Cesi

total height [mm]	270
creepage distance [mm]	711
arching distance [mm]	297
number of sheds [n]	9
sheds diameter [mm]	116
core diameter [mm]	59,5
sheds spacing [mm]	25
sheds projection [mm]	30


*[Handwritten signature]*

ARMANDO COPPINI S.p.A.

*[Handwritten signature]*  
*[Handwritten signature]*

*B*

Picture of the test object WI



*09*

ВЕРНО СОРТИРОВАНА


*02*

*Handwritten signature*

*09*

*B*

Picture of the test object W2



*09*

ВНПГО СОРПТБИТАНА

*09*  
*W*  
*A. Konec*

**Test carried out and test procedure**

Test has been carried out according with IEC Standard 60099-4 (2004-05) edition 2.0 "Metal-oxide surge arrester without gaps for a.c. system", at clause 10.8.14 .

**Initial measurement**

- The reference voltage have been measured at reference current equal to 5 mA<sub>pk</sub>

- Internal partial discharge have been measured.

The application voltage has been increased up to rated voltage (U<sub>r</sub>) and maintained for 10 sec.

The voltage has been decreased to 1,05 times the continuous operating voltage (U<sub>c</sub>) and the partial discharge level has been measured according to the reference standard.

**Weather ageing test. Test series A: 1000 hours**

Note: During the weather ageing test, the test objects were tested in parallel with a Dervasil insulator.

The test samples have been assembled in the test room in vertical position spaced each-other and from the chamber walls in order to avoid electrical field disturbance.

Test objects have been cleaned with deionized water before starting the test.

The surge arresters have been energized at U<sub>test</sub> = 22 kV<sub>rms</sub> and kept for a total duration of 1000 hours in the test room filled with salt fog.

The water flow rate was 0,4 ± 0,1 l/h\*m<sup>3</sup>

At the beginning the salinity of the water solution was 10 Kg/m<sup>3</sup>. Than it has been decreased to 5 Kg/m<sup>3</sup> after 591 hours, and to 2,5 Kg/m<sup>3</sup> after 610 hours (see the paragraph "summary of test result").

The salt fog was not directly sprayed against the test specimens.

A scheme and a view of the test configuration are shown at pages 14 and 15.

The test sample has been visually inspected after about 500 hours and at test completion. Photos were taken at the end of the test.

**Final measurement**

The initial measurement were repeated.

ВІПРОСІВНИЦЯ

Summary of test result

Test series A: 1000 hours

The external flashovers occurred during the test are noted in table below. The test salinity had to be changed twice.

sample W1	sample W2	test salinity	salinity change
1 <sup>st</sup> Flashover after 565 h		10 g/l	
2 <sup>nd</sup> Flashover after 591 h		10 g/l	from 10 to 5 g/l
3 <sup>rd</sup> Flashover after 595 h		5 g/l	
	1 <sup>st</sup> Flashover after 610 h	5 g/l	from 5 to 2,5 g/l
	2 <sup>nd</sup> Flashover after 976 h	2,5 g/l	
	3 <sup>rd</sup> Flashover after 981 h	2,5 g/l	

Visual inspection

Note: Sheds are numbered starting from the live side.

- After 500 hours

No tracking, shed puncture or significant erosions have been evidenced by the visual inspection carried out after 500

- After 1000 hours

Sample W1:

An overall view of the object after 1000 hours is shown in the photo at page 16.

No tracking, significant erosion or puncture was observed.

Shallow and diffuse erosions were visible on all circumference of the core between sheds n.2 and n.3 and, in less diffused way, also on the core between sheds n.3 and n.4 (see photo at page 17).

Sample W2:

An overall view of the object after 1000 hours is shown in the photo at page 18.

No tracking, significant erosion or puncture was observed.

Shallow erosions on the cores between sheds n.2-3, sheds n.4-5 and sheds n.6-7 (see photo at page 19).

Shallow and diffuse erosions were visible on all circumference of core between sheds n.8 and n.9 (see photo at page 20).

Stamp: БИРНО СОРБИТИЈА

Handwritten signature and circular stamp.

Variation of the reference voltage

Type	before test	after test	variation
	kV	kV	%
W1	27,26	27,9	+ 2,3
W2	28,03	28,4	+ 1,3

Acceptance criteria: satisfied

Partial discharge level

Type	before test	after test
	pC	pC
W1	<1	<1
W2	<1	<1

Acceptance criteria: satisfied

Conclusion: the acceptance criteria specified by the standard are satisfied. The test result is positive.

ВНЕСНО СОВЕТНИКА

Measurement of the reference voltage - initial

test object: Polymer housed metal-oxide surge arresters  
test circuit: /

date: May 12, 2004

sample W1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	27,26	4,94	4,82	1,04	25,18	/

date: May 12, 2004

sample W2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
2	28,03	3,95	5,04	1,37	23,80	/

WZPNO CONSTRUKTARA

*[Handwritten signature]*



**Measurement of partial discharges - initial**

test object: Polymer housed metal-oxide surge arresters

test circuit: /

measurement circuit: /

arrangement: ---

atmospheric conditions		
b	t	h
kPa	°C	g / m <sup>3</sup>
/	24	/


date: May 13, 2004

**sample W1**

test condition	applied voltage	duration of voltage application	temperature of the test object	voltage increase Q max	voltage decrease Q max	oscillogram	note
	kV <sub>rms</sub>	sec	°C	pC	pC	no.	
rated voltage	27	10	24	/	/	/	/
22 x 1,05	23,1	/	24	/	≤ 1	/	/

**sample W2**

test condition	applied voltage	duration of voltage application	temperature of the test object	voltage increase Q max	voltage decrease Q max	oscillogram	note
	kV <sub>rms</sub>	sec	°C	pC	pC	no.	
rated Voltage	27	10	24	/	/	/	/
22 x 1,05	23,1	/	24	/	≤ 1	/	/



AT-A5/022740


**Test Report**

*B*

*Rg*

*879*

**Weather ageing test.**



**power frequency test circuit (plant P188)**

- R : regulator type M.E.S.A.; power 66 kVA ; output voltage 220 V ; CESI no. 29991
- TA : current reducer ; ratio 150A / 5A
- TV<sub>1</sub> : voltage reducer ; ratio 220V / 100V
- V<sub>1</sub> : direct reading voltmeter
- T : booster transformer PIVI type TMO/230 ; power 50 kVA ; ratio 220 V / 30 kV ;  
primary current 227 A ; secondary current 1,67 A ; CESI no. 38675
- TV<sub>2</sub> : voltage reducer CGS type VSO 534 ; CESI no. 287 ; ratio 30/0,1 kV
- V<sub>2</sub> : voltmeter ANALOGIC Type DP100 ; CESI no. 9533

**check of the test circuit**


date: August 8, 2004

low voltage				high voltage k = 300		k <sub>1</sub>
V <sub>1</sub>	V <sub>bt</sub>	I <sub>1</sub>	I <sub>bt</sub>	V <sub>2</sub>	V <sub>AT</sub>	V <sub>AT</sub> / V <sub>1</sub>
V	V	A	A	V	kV	
/	/	/	/	50,1	15,0	/
/	/	/	/	73,3	22,0	/
/	/	/	/	/	/	/

*[Handwritten signatures and marks]*

*B*

**Weather ageing test. Test arrangement  
Plant: pollution test room planimetry**



*B*

Test room volume: 360m<sup>3</sup>

B: bushing

N: spray nozzles. Number of spray nozzles: 4

W1, W2: test objects

SEPRO COVERTHAMA


*g*

*U*

*A. Konep*

*B*

Picture of the test arrangement



*8*

*9*

*9*

ВАЖНО С ОРИГИНАЛА


*9*

*11*

*[Signature]*

*m*

Picture of the test sample W1 after the test



*07*


*07*

*07*

*Al. Kovacs*

*B*

Picture of the test sample WI after the test




*OK*

*OK*  
*OK*  
*OK*

CDI TESTING SERVICES

Picture of the test sample W2 after the test



CC

CC

CC

CC




CC

TESTING SERVICES

*[Handwritten signature]*

*B*

Picture of the test sample W2 after the test



*CP*

*CP*

*CP*


*M. Konecni*

ARMIERUNG



B

Picture of the test sample W2 after the test



04

03

00

ВІСНОК ОПИТУВАННЯ

04

07

08

09

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

00

Measurement of the reference voltage - Final

test object: Polymer housed metal-oxide surge arresters

test circuit: /

date: August 30, 2004

sample W1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	27,9	4,88	5,04	/	/	/

date: August 30, 2004

sample W2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
4	28,4	4,32	5,04	/	/	/

BRZHO CONFIDENTIAL

*[Handwritten signatures and initials]*

**Measurement of partial discharges - Final**

test object: Polymer housed metal-oxide surge arresters

test circuit: /

measurement circuit: /

arrangement: ---

atmospheric conditions		
b	t	h
kPa	°C	g / m <sup>3</sup>
/	25	/

date: August 30, 2004

**Sample W1**

test condition	applied voltage	duration of voltage application	temperature of the test object	voltage increase Q max	voltage decrease Q max	oscillogram	note
rated voltage	kV <sub>rms</sub> 27	sec 10	°C 25	pC /	pC /	no. /	/
22 x 1,05	23,1	/	25	/	≤ 1	7	/

**Sample W2**

test condition	applied voltage	duration of voltage application	temperature of the test object	voltage increase Q max	voltage decrease Q max	oscillogram	note
rated voltage	kV <sub>rms</sub> 27	sec 10	°C 25	pC /	pC /	no. /	/
22 x 1,05	23,1	/	25	/	≤ 1	8	/

Note: background noise ≤ 1 pC, see oscillogram n.5

"direct" calibration: 50 pC - see oscillogram n.6




AT-A5/022740


**Test Report**

oscillogram no.01

BUF. A1



BUF. A2



CESI TEST A4510342



UNCLASSIFIED

*[Handwritten signature]*

*[Handwritten initials]*

*[Handwritten initials]*

oscillogram no.02



CESI TEST A4510342

СЕРТИФИКАТ

*Handwritten signature*


*Large handwritten signature*

*Handwritten signature*

*Handwritten signature*

*B*

oscillogram no.03



30 Aug 2004  
13:52:48

*Handwritten signature*

CESI TEST A4510342


РАУНО ООПРЕДЕЛЕНИЯ

*Handwritten signature*

B

oscillogram no.04

30 Aug 2004  
13:46:22



d

ep

2+


CESI TEST A4510342

РАДНО СОПРЪЖАВА

*[Handwritten signature]*

*B*

oscillogram no.05



*B*


CESI TEST A4510342

*Handwritten signature and initials*



B

oscillogram no.06



107


CESI TEST A4510342

ВІСНОК ОПИТУВАННЯ

*[Handwritten signature]*

B

oscillogram no.07



09

AS 19

*[Signature]*


CESI TEST A4510342

ИЗПРОСОПРЕНАЈА

B

oscillogram no.08

08



CESI TEST A4510342

ИНТЕРКОММУНАЛЬНИЙ


*[Handwritten signature]*

B

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ВЕНТИЛЕН ОТВОД  
ТИП AZVD 270**


1. Изпитание с вътрешно частично разреждане
2. Изпитание за устойчивост на импулсно атмосферно пренапрежение в сухо състояние
3. Изпитание с напрежение с промишлена честота във влажно състояние
4. Изпитание на остатъчно напрежение
5. Изпитание за устойчивост на дълготраен токов импулс
6. Изпитание при работен режим с високо-токов импулс
7. Изпитание с разединител
8. Изпитание на огъващ момент
9. Изпитание с проникване на влага
10. Изпитание с атмосферно стареене

Съставил:

  
M. Konev

A

09

  
M. Konev

DATech Deutsche Akkreditierungsstelle Technik in der TGA GmbH  
Signatory of the Multilateral Agreement of EA and ILAC for the mutual recognition

represented in the

# Deutschen AkkreditierungsRat



## Akkreditierung

The TGA GmbH, represented by the DATech Deutsche Akkreditierungsstelle Technik in der TGA GmbH, confirms that the Testing Laboratory

Centro Elettrotecnico Sperimentale Italiano Giacinto Motta S.p.A.  
(CESI S.p.A.)

Via Rubattino, 54

20134 Milano  
Italy

is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out testing in the fields of

High-Voltage Equipment and their Components,  
Transformers and their Components,  
Low-Voltage Switching Devices and Switchgears,  
Electromagnetic Compatibility (EMC)

according to the annexed list of standards and specifications.


The accreditation is valid until: 2013-12-17

The annex is deemed part of this certificate and comprises 6 pages.

DAR-Registration No.: DAT-PL-284/08-00

Frankfurt/Main, 2008-12-18

Correctness of the English translation confirmed: Frankfurt/Main, 2008-12-18


  
i.V. Dipl.-Ing. (FH) R. Egnér  
Head of the Accreditation Body

Member in EA, ILAC, IAF

Translation for information purposes only. The German Accreditation Certificate is authoritative

See notes overleaf

ВЕРИТЕЛЬНОСТЬ



13  
Германска служба за акредитация-Техник (DATech) в TGA GmbH  
подписала многостранно споразумение за акредитация между EA и ILAC  
за взаимно признаване

представена от

# Deutschen AkkreditierungsRat

(Германски акредитационен съвет)

## Акредитация

TGA GmbH представена от Германска служба за акредитация-Техник (DATech) в  
TGA GmbH, потвърждава, че Лабораторията за тестване,

Centro Elettrotecnico Sperimentale Italiano Giacinto Motta S.p.A.  
(CESI S.p.A)

Via Rubattino, 54  
20134 Milano  
Italy

е правоспособна съгласно условията на DIN EN ISO/IEC 17025:2005, да извърши  
тестване в областта на

Високоволтово оборудване и неговите компоненти,  
Трансформатори и техните компоненти,  
Нисковолтови устройства за превключване и КРУ,  
Електромагнитна съвместимост  
съгласно приложения списък на стандарти и спецификации.

Сертификата за акредитацията е валиден до: 2013-12-17

Приложението се счита за част от настоящия сертификат, и се състои от 6 страници.

DAR-Регистрационен номер: DAT-PL-284/08-00

Франкфурт/Майн, 2008-12-18

Правилността на превода на Английски език потвърдена: Франкфурт/Майн, 2008-12-18

Handwritten signature and circular stamp of the German Accreditation Body (DAR). The stamp contains the text "Deutscher Akkreditierungsrat" and "Frankfurt am Main".



Český institut pro akreditaci, o.p.s.  
130 00 Praha 3, Olšanská 54/3

vydává

# OSVĚDČENÍ O AKREDITACI

č. 147 / 2011

EGU - HV Laboratory a.s.  
se sídlem Podnikatelská 267, 190 11 Praha, Běchovice, IČ 25634330,  
zapsaný u Městského soudu v Praze, oddíl B, vložka 5128

pro zkušební laboratoř č. 1029  
High voltage testing laboratory

Předmět akreditace:

Zkoušky vysokým napětím, měření radiového rušení, napět'ové a dielektrické zkoušky elektrických předmětů a zařízení a mechanické zkoušky izolátorů v rozsahu uvedeném v příloze tohoto osvědčení.

Toto osvědčení o akreditaci vydal Český institut pro akreditaci, o.p.s. na základě posouzení splnění akreditačních požadavků podle

ČSN EN ISO/IEC 17025:2005

a po zjištění, že zkušební laboratoř je odborně způsobilá objektivně a nezávisle vykonávat činnosti uvedené v rozsahu předmětu akreditace.

Adresát tohoto osvědčení je oprávněn používat při své činnosti v rozsahu tohoto osvědčení a po dobu jeho platnosti vedle svého názvu označení „zkušební laboratoř akreditovaná ČIA č. 1029“, pod podmínkou, že bude vždy postupovat v souladu s příslušnými předpisy vztahujícími se k činnosti akreditované zkušební laboratoře, a to zejména ČSN EN ISO/IEC 17011, čl. 8.1, ČSN EN ISO/IEC 17025, zákona č. 22/1997 Sb., o technických požadavcích na výrobky, ve znění pozdějších předpisů, včetně navazujících předpisů vydaných Českým institutem pro akreditaci, o.p.s.

Prokáže-li se, že adresát tohoto osvědčení neplní akreditační požadavky rozhodně pro jeho vydání a nedodrží závazky podmiňující akreditaci, může Český institut pro akreditaci, o.p.s. účinnost tohoto osvědčení pozastavit nebo osvědčení o akreditaci zrušit.

Toto osvědčení je vydáno v souladu s ustanovením § 16 odst. 1 zákona č. 22/1997 Sb., o technických požadavcích na výrobky a v souladu s ustanovením § 151 zákona č. 500/2004 Sb., správní řád

Toto osvědčení je platné do 18.03.2016

V Praze dne 04.04.2011



Ing. Jiří Růžička, MBA  
ředitel

Českého institutu pro akreditaci, o.p.s.

ilac-MRA

NATIONAL ACCREDITATION BODY

Czech Accreditation Institute  
Public Service Company  
110 00 Praha 1 - Nové Město, opletalova 4l  
issues this

# CERTIFICATE OF ACCREDITATION

No. 147/2011

EGU – HV Laboratory a.s.  
with offices at Podnikatelská 267, 190 11 Praha 9, Běchovice, ID No. 25634330  
registered at the City Court in Prague, Section B, insert 5128

for test laboratory no. 1029  
High voltage testing laboratory

Scope of accreditation:

High voltage testing, radio interference measurement, voltage and dielectric testing of electrical items and equipment and mechanical tests of insulators to the extent listed in the appendix to this certificate.

This Certificate of Accreditation was issued by the Czech Accreditation Institute, Public Service Company, based on an assessment of fulfilment of accreditation criteria in accordance with

ČSN EN ISO/IEC 17025:2005

and after having found that the certification body had been qualified for objective and independent certification to the extent of the scope of accreditation.

In its activities, performed within the scope and for the period of validity of this Certificate, the holder of this Certificate is entitled to use the identification "ČIA Accredited Test Laboratory No. 1029" next to its name provided it shall always proceed in accordance with relevant regulations applicable to the activity of an accredited test laboratory, especially ČSN EN ISO/IEC 17011, Article 8.1, ČSN EN ISO/IEC 17025, Act No. 22/1997 Coll., on technical requirements for products, as amended, including associated regulations issued by the Czech Accreditation Institute, p.s.c.

If it is proven that the holder of this Certificate does not meet accreditation requirements decisive for its issuance, and is not meeting obligations upon which accreditation is contingent, the Czech Accreditation Institute, p.s.c. may suspend this or cancel this Certificate of Accreditation.

This Certificate has been issued in accordance with Section 16(1) of Act No. 22/1997 Coll., on technical requirements for products, and in accordance with Section 151 of Act No. 500/2004 Coll., the Administrative Code.

This Certificate is valid until **18 March 2016**

In Prague on 04 April 2011

SECURITY SEAL

Ing. Jiří Růžička, MBA  
Director  
Czech Accreditation Institute, p.s.c.

RECEIVED COPY

102



Чешки Институт по акредитация  
Компания за обществени услуги  
110 00 Прага 1- Nove Mesto, Opletalova 41  
издава настоящия

**Сертификат за акредитация**

Номер 147/2011

EGU – Лаборатория В.Н a.s.

с офис на odnikatelska 267,190 11 Praha 9, Beshovice, ID No. 25634330  
регистрирана в Градски съд на Прага, Секция В, вписване 5128  
за тестова лаборатория номер. 1029

Лаборатория за изпитвания високо напрежение

Обхват на акредитацията:

Изпитвания високо напрежение, измерване на радио-интерференция, напреженови и диелектрични изпитвания на електрически изделия и оборудване и механични тестове на изолятори до степен, посочена в приложението към този сертификат.

Този сертификат за акредитация е издаден от Чешкия институт по акредитация, Компания за обществени услуги, въз основа на покриване на критериите за акредитация в съответствие с

ČSN EN ISO/IEC 17025:2005

и след като е установено, че сертифициращата организация е била квалифицирана за обективно и независимо сертифициране до степента на обхвата на акредитация.

В дейностите си, изпълнявани в рамките на обхвата и за периода на валидност на настоящия сертификат, притежателя на настоящия сертификат има право да използва идентификацията, "CIA Акредитирана лаборатория за изпитания No. 1029" до своето име, при условие, че винаги ще процедира съгласно съответните правила, приложими към дейността на акредитирана лаборатория за изпитвания, особено ČSN EN ISO/IEC 17011, член 8.1, ČSN EN ISO/IEC 17025, Наредба Номер 22/1997 Coll, за технически изисквания към продукти, в променената версия, включително съответни правила издадени от Чешкия институт по акредитация (Czech Accreditation Institute, p.s.c).

Ако се докаже че притежателя на настоящия сертификат не отговаря на респаваци за издаването изисквания по акредитацията, и не отговаря на задълженията по акредитацията, Чешкия институт по акредитация (Czech Accreditation Institute, p.s.c.) може да прекрати или анулира настоящия сертификат за акредитация.

Сертификатът е издаден в съответствие с Раздел 16(1) на Наредба Номер 22/1997 Coll, за технически изисквания към продукти и в съответствие с Раздел 151 на Наредба Номер 500/2004 Coll, административен код.

Сертификатът е валиден до **18 Март 2016**

Прага, 04 Април 2011

ЗАЩИТЕН ПЕЧАТ

Инж. Йиржи Ружичка, MBA  
Директор

Чешки институт за акредитация, (Czech Accreditation Institute, p.s.c.)




# Operating, storage and installation instructions Lightning Arresters AZC --0

DERVASIL offers a range of latest generation lightning arresters with silicone rubber housing and metal oxide varistors. :

- 10 kA Lightning arresters Class 2

These arresters do not have internal spark gaps. They exhibit stable characteristics, with practically constant, very short response times (30 to 50 ns).

Direct injection of silicone rubber over the internal varistors ensures both absolute sealing, excellent behaviour without explosion in case of short-circuit. They have been tested in accordance with last version of IEC standard 60099-4.



## MOUNTING GUIDE

88906631 0A

DERVASIL

Compagnie de production pour les besoins d'énergie électrique

INSTRUCTION DE MONTAGE AZC -- 0  
MOUNTING GUIDE AZC -- 0

10004 10  
10 kA


5	Clips filetés / Threaded clips	2
4	Arrière capote / Back cap / arrière capote / Back cap	2
3	Écrouille / Washer	2
2	Variste MOX	4
1	Écrou / Nut	2
Rep.	Designation	Qty

Section de câble admissible pour la conception 25 / 168 mm<sup>2</sup>  
Acceptable section of cable for construction 25 / 168 mm<sup>2</sup>

10003 10  
25 kA

DERVASIL - route de papouze - 8200 St Joseph - FRANCE - Tél. : +33 (0)4 77 83 22 11 - Fax. : +33 (0)4 77 83 22 10

*[Handwritten signature]*



*B* Operating, storage and installation instructions  
Lightning Arresters AZC --0

### PACKING

Lightning arresters are packed in stable cardboard boxes. Each cardboard box contains:

- 3 lightning arresters fitted with threaded studs.
- 3 plastic bags with nuts and washes
- 1 mounting guide

### TRANSPORT AND STORAGE


Secure lightning arresters against crushing, falling or sliding during transport and storage  
Respect safety precautions for proper handling during transport and storage  
Store lightning arresters in their cardboard box and in clean and ventilated room

### INSPECTION

After opening of boxes, check:

- Lightning arrester marking must correspond to the bought product
- Presence of all components according to this guide
- Cleanness of threaded rods to avoid any seizing during installation of lightning arrester
- Cleanness of external silicone housing which must be without cuts or holes.

*A* *U*  
*A. Kosep*



**Operating, storage and installation instructions  
Lightning Arresters AZC --0**

**RECOMMENDATIONS AND MAINTENANCE**

**PERSONNEL IN CHARGE OF INSTALLATION MUST BE PROFESSIONAL AND SAFE WORKING TRAINED.**

**ONLY PERSONNEL WHO HAVE UNDERSTOOD OPERATING AND INSTALLATION INSTRUCTIONS MAY BE ALLOWED TO MOUNT LIGHTNING ARRESTERS**

**AVOID ANY USE OF SHARP TOOLS WHICH COULD DAMAGE LIGHTNING ARRESTER HOUSING, NOTABLY DURING BOX OPENING.**

**MINIMUM CLEARANCE DISTANCE BETWEEN ARRESTERS AND BETWEEN ARRESTERS AND EARTH ARE SPECIFIED ON THE TABLE PAGE 1. THESE DISTANCES MUST BE USED FOR LIGHTNING ARRESTER MOUNTING.**

**FOR LIGHTNING ARRESTER TYPR AZB \_\_ 2, CONNECT ALWAYS DISCONNECTOR TO THE EARTH WITH FLEXIBLE CABLE TO AVOID BLOCKAGE OF DISCONNECTOR OPERATING.**


**TO CONNECT AND TO MOUNT LIGHTNING ARRESTER, DO NOT EXCEED SPECIFIED TORQUE.**

**AFTER LIGHTNING ARRESTER INSTALLATION, CLEAN SILICONE HOUSING WITH SOFT AND CLEAN CLOTH.**

**LIGHTNING ARRESTERS INSTALLED ACCORDING TO THIS GUIDE DO NOT REQUIRE ANY PREVENTIVE MAINTENANCE.  
REPLACE LIGHTNING ARRESTERS IF FAULT INDICATOR OR DISCONNECTOR OPERATE OR AFTER FLASHOVER.**

**ENVIRONMENT ASPECT**

**The lightning arresters DERVASIL do not contain any dangerous material for environment. After use they must be destroyed in an approved center.**




# Operating, storage and installation instructions Lightning Arresters AZC --0

## INSTALLATION EXAMPLE


Always mount lightning arresters as close as possible to the apparatuses to be protected

### TRANSFORMER PROTECTION

Vertical position on transformer tank




Horizontal position




### CABLE PROTECTION

Horizontal position



DERVASIL Route de Popenot 42800 Saint Joseph FRANCE  
Téléphone : +33 (0)4 77 83 22 81 – Fax : +33 (0)4 77 83 22 80  
Email : [info@dervasil.com](mailto:info@dervasil.com)  
Web : [www.dervasil.com](http://www.dervasil.com)

This documentation is not as per agreement.  
DERVASIL reserves the right to modify without prior notice.  
Non-contractuel pictures and drawings




# Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZC --0

DERVASIL предлага диапазон от най-последно поколение вентилни отводи със силиконов гумен корпус и металооксидни варистори. :

- 10 kA Вентилни отводи Клас 2

Тези вентилни отводи нямат вътрешни искрови междини. Те показват стабилни характеристики с частична константа, много кратки времена за реакция (30 до 50 ns). Пряко инжектиране на силиконова гума над вътрешните варистори гарантира абсолютно уплътняване, отлично поведение без експлозия при късо съединение. Тествани са в съответствие с последната версия на IEC стандарта 60099-4.



## РЪКОВОДСТВО ЗА МОНТАЖ

39B00031CA

DERVASIL



Composants de protection pour les réseaux d'énergie électrique

INSTRUCTION DE MONTAGE AZC -- 0  
MOUNTING GUIDL AZC -- 0

Figure 10  
25 / 148 mm

5	siège isolant / stressed stud	2
4	borne câble / cable grip washer / Sierra case	2
3	écrouille / Washer 3	2
2	écrouille AZC01	1
1	écrou / Nut 6	2
Rep	Designation	Qté

Section de câble admissible pour la conception 25 / 148 mm  
Acceptable section of cable for conception 25 / 148 mm





Figure 10  
25 / 148 mm

DERVASIL - route de Pignac - 42000 St Amant - FRANCE - Tél. : +33 (0)7 77 83 22 81 - Fax : +33 (0)7 77 83 22 80

*[Handwritten signature and stamp]*



## Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZC --0

### **ОПАКОВКА**

Вентилните отводи са опаковани в стабилни картонени кутии. Всяка картонена кутия съдържа:

- 3 вентилни отвода закрепени с резбовани щифтове.
- 3 пластмасови чувала с гайки и шайби
- 1 ръководство за монтаж

### **ТРАНСПОРТИРАНЕ И СЪХРАНЕНИЕ НА СКЛАД**

Да се защитят вентилните отводи срещу удар, падане или плъзгане по време на транспортиране и съхранение

Спазвайте предпазните мерки за безопасност за подходящи манипулации по време на транспортирането и съхранението


Съхраняване на вентилните отводи в техните картонени кутии и в чисто и проветрено помещение.

### **ИНСПЕКЦИЯ**

След отваряне на кутии, проверете:

- Маркировката на вентилните отводи трябва да съответства на закупения продукт
- Наличието на всички компоненти съгласно това ръководство
- Почистването на резбованите щанги за избягване на всякакво заяждане по време на монтажа на вентилните отводи
- Почистване на външния силиконов корпус, който трябва да бъде без нарязвания или отвори.

*(Handwritten signature and stamp)*  
409



**Инструкции за експлоатация, монтаж, обслужване  
и съхранение на склад  
Вентилни отводи AZC --0**

**ПРЕПОРЪКИ И ПОДДРЪЖКА**

**ПЕРСОНАЛЪТ, ОТГОВОРЕН ЗА МОНТАЖА, ТРЯБВА ДА БЪДЕ ПРОФЕСИОНАЛЕН И ОБУЧЕН ЗА БЕЗОПАСНА РАБОТА. САМО ПЕРСОНАЛ, КОЙТО Е РАЗБРАЛ ИНСТРУКЦИИТЕ ЗА ЕКСПЛОАТАЦИЯ И МОНТАЖ, МОЖЕ ДА МОНТИРА ВЕНТИЛНИ ОТВОДИ**

**ДА СЕ ИЗБЯГВА ИЗПОЛЗВАНЕТО НА ОСТРИ ИНСТРУМЕНТИ, КОИТО МОГАТ ДА ПОВРЕДЯТ КОРПУСА НА ВЕНТИЛНИТЕ ОТВОДИ, ОСОБЕНО ПО ВРЕМЕ НА ОТВАРЯНЕ НА КУТИЯТА.**

**МИНИМАЛНАТА МЕЖДИНА МЕЖДУ ВЕНТИЛНИТЕ ОТВОДИ И МЕЖДУ ВЕНТИЛНИТЕ ОТВОДИ И ЗАЗЕМЯВАНЕТО Е ОПРЕДЕЛЕНА НА ТАБЛИЦАТА НА СТРАНИЦА 1. ТЕЗИ РАЗСТОЯНИЯ ТРЯБВА ДА СЕ ИЗПОЛЗВАТ ЗА МОНТАЖ НА ВЕНТИЛНИТЕ ОТВОДИ.**

**ЗА ВЕНТИЛНО ОТВОДИ ТИП AZC \_\_ 2, ВИНАГИ СВЪРЗВАЙТЕ РАЗЕДИНИТЕЛЯ КЪМ ЗЕМЯ С ГЪВКАВ КАБЕЛ, ЗА ДА ИЗБЕГНЕТЕ БЛОКИРАНЕТО НА РАБОТАТА НА РАЗЕДИНИТЕЛЯ.**

**ЗА СВЪРЗВАНЕ И МОНТАЖ НА ВЕНТИЛНИ ОТВОДИ ДА НЕ СЕ ПРЕВИШАВА ОПРЕДЕЛЕНИЯ ВЪРТЯЩ МОМЕНТ.**

**СЛЕД МОНТАЖА НА ВЕНТИЛНИТЕ ОТВОДИ, ПОЧИСТЕТЕ СИЛИКОНОВИЯ КОРПУС С МЕКА И ЧИСТА КЪРПА.**


**ВЕНТИЛНИТЕ ОТВОДИ, КОИТО СА МОНТИРАНИ СЪГЛАСНО ТОВА РЪКОВОДСТВО, НЕ ИЗИСКВАТ НИКАКВО ПРОФИЛАКТИЧНО ТЕХНИЧЕСКО ОБСЛУЖВАНЕ. ЗАМЕНЕТЕ ВЕНТИЛНИТЕ ОТВОДИ, АКО Е ПОВРЕДЕН ИНДИКАТОРЪТ ИЛИ РАЗЕДИНИТЕЛЯТ РАБОТИ ИЛИ СЛЕД ПРЕМОСТВАНЕ**

**ЕКОЛОГИЧЕН АСПЕКТ**

Вентилните отводи DERVASIL не съдържат никакви материали, опасни за околната среда. След използване те трябва да бъдат разрушени в одобрен център.

*[Handwritten signatures and initials]*






**Инструкции за експлоатация, монтаж, обслужване  
и съхранение на склад  
Вентилни отводи AZC --0**

**ПРИМЕР ЗА МОНТАЖ**


**Винаги монтирайте вентилните отводи колкото е възможно по-близо до оборудването, за да бъде то защитено**

**ЗАЩИТА НА ТРАНСФОРМАТОРА**

**Вертикално положение на казана на трансформатора**




**Хоризонтално положение**



**КАБЕЛНА ЗАЩИТА**


**Хоризонтално положение**



DERVASIL Route de Popenot 42800 Saint Joseph FRANCE  
Téléphone : +33 (0)4 77 83 22 81 – Fax : +33 (0)4 77 83 22 80  
Email : [info@dervasil.com](mailto:info@dervasil.com)  
Web : [www.dervasil.com](http://www.dervasil.com)

Тази документация не се издава по взаимно съгласие.  
**DERVASIL** си запазва правото на промени без предварително уведомление.  
Не съдържа снимки и чертежи по договор

*[Handwritten signature]*  
444




**Operating, storage and installation instructions**  
**Lightning Arresters AZBD- - - 0**

**storage**


DERVASIL offers a range of latest generation lightning arresters with silicone rubber housing and metal oxide varistors. :

- 10 kA Lightning arresters Class 1


These arresters do not have internal spark gaps. They exhibit stable characteristics, with practically constant, very short response times (30 to 50 ns). Direct injection of silicone rubber over the internal varistors ensures both absolute sealing, excellent behaviour without explosion in case of short-circuit. They have been tested in accordance with last version of IEC standard 60099-4.



**MOUNTING GUIDE**



*[Handwritten signatures and stamps]*



**Operating, storage and installation instructions  
Lightning Arresters AZBD- - - 0**

**PACKING**

Lightning arresters are packed in stable cardboard boxes. Each cardboard box contains:

- 3 lightning arresters fitted with threaded studs.
- 3 plastic bags with nuts and washes
- 1 mounting guide

**TRANSPORT AND STORAGE**


Secure lightning arresters against crushing, falling or sliding during transport and storage  
Respect safety precautions for proper handling during transport and storage  
Store lightning arresters in their cardboard box and in clean and ventilated room

**INSPECTION**

After opening of boxes, check:

- Lightning arrester marking must correspond to the bought product
- Presence of all components according to this guide
- Cleanness of threaded rods to avoid any seizing during installation of lightning arrester
- Cleanness of external silicone housing which must be without cuts or holes.

*[Handwritten signature]*



**Operating, storage and installation instructions  
Lightning Arresters AZBD- - - 0**

**RECOMMENDATIONS AND MAINTENANCE**

**PERSONNEL IN CHARGE OF INSTALLATION MUST BE PROFESSIONAL AND SAFE WORKING TRAINED.**

**ONLY PERSONNEL WHO HAVE UNDERSTOOD OPERATING AND INSTALLATION INSTRUCTIONS MAY BE ALLOWED TO MOUNT LIGHTNING ARRESTERS**

**AVOID ANY USE OF SHARP TOOLS WHICH COULD DAMAGE LIGHTNING ARRESTER HOUSING, NOTABLY DURING BOX OPENING.**

**MINIMUM CLEARANCE DISTANCE BETWEEN ARRESTERS AND BETWEEN ARRESTERS AND EARTH ARE SPECIFIED ON THE TABLE PAGE 1. THESE DISTANCES MUST BE USED FOR LIGHTNING ARRESTER MOUNTING.**

**FOR LIGHTNING ARRESTER TYPR AZB \_\_ 2, CONNECT ALWAYS DISCONNECTOR TO THE EARTH WITH FLEXIBLE CABLE TO AVOID BLOCKAGE OF DISCONNECTOR OPERATING.**


**TO CONNECT AND TO MOUNT LIGHTNING ARRESTER, DO NOT EXCEED SPECIFIED TORQUE.**

**AFTER LIGHTNING ARRESTER INSTALLATION, CLEAN SILICONE HOUSING WITH SOFT AND CLEAN CLOTH.**

**LIGHTNING ARRESTERS INSTALLED ACCORDING TO THIS GUIDE DO NOT REQUIRE ANY PREVENTIVE MAINTENANCE.  
REPLACE LIGHTNING ARRESTERS IF FAULT INDICATOR OR DISCONNECTOR OPERATE OR AFTER FLASHOVER.**

**ENVIRONMENT ASPECT**

**The lightning arresters DERVASIL do not contain any dangerous material for environment.  
After use they must be destroyed in an approved center.**





# Operating, storage and installation instructions Lightning Arresters AZBD- - - 0


## INSTALLATION EXAMPLE

Always mount lightning arresters as close as possible to the apparatuses to be protected

### TRANSFORMER PROTECTION




### CABLE PROTECTION



DERVASIL Route de Popenot 42800 Saint Joseph FRANCE  
 Téléphone : +33 (0)4 77 83 22 81 – Fax : +33 (0)4 77 83 22 80  
 Email : [info@dervasil.com](mailto:info@dervasil.com)  
 Web : [www.dervasil.com](http://www.dervasil.com)

This documentation is not as per agreement.  
**DERVASIL reserves the right to modify without prior notice.**  
 Non-contractuel pictures and drawings

Handwritten signature and a circular stamp with illegible text.




# Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZBD— 0

DERVASIL предлага диапазон от най-последно поколение вентилни отводи със силиконов гумен корпус и металооксидни варистори.


- 10 kA Вентилни отводи Клас 1

Тези вентилни отводи нямат вътрешни искрови междини. Те показват стабилни характеристики с частична константа, много кратки времена за реакция (30 до 50 ns).

Пряко инжектиране на силиконова гума над вътрешните варистори гарантира абсолютно уплътняване, отлично поведение без експлозия при късо съединение. Тествани са в съответствие с последната версия на IEC стандарта 60099-4



## РЪКОВОДСТВО ЗА МОНТАЖ



*[Handwritten signature]*



## Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZBD— 0

### ОПАКОВКА

Вентилните отводи са опаковани в стабилни картонени кутии. Всяка картонена кутия съдържа:

- 3 вентилни отвода, закрепени с резбовани щифтове.
- 3 найлонови торби с гайки и шайби
- 1 инструкция за монтаж

### ТРАНСПОРТИРАНЕ И СЪХРАНЕНИЕ НА СКЛАД

Да се защитят вентилните отводи срещу удар, падане или плъзгане по време на транспортиране и съхранение. Спазвайте предпазните мерки за безопасност за подходящи манипулации по време на транспортирането и съхранението. Съхранявайте вентилните отводи в техните картонени кутии и в чисто и проветрено помещение.

### ИНСПЕКЦИЯ

След отваряне на кутиите, проверете:

- Маркировката на вентилните отводи трябва да съответства на закупения продукт
- Наличието на всички компоненти съгласно това ръководство
- Почистване на резбованите щанги за избягване на всякакво заяждане по време на монтажа на вентилните отводи
- Почистване на външния силиконов корпус, който трябва да бъде без нарязвания или отвори.



Инструкции за експлоатация, монтаж, обслужване  
и съхранение на склад  
Вентилни отводи AZBD— 0

**ПРЕПОРЪКИ И ПОДДРЪЖКА**

**ПЕРСОНАЛЪТ, ОТГОВОРЕН ЗА МОНТАЖА, ТРЯБВА ДА БЪДЕ ПРОФЕСИОНАЛЕН И ОБУЧЕН ЗА БЕЗОПАСНА РАБОТА. САМО ПЕРСОНАЛ, КОЙТО Е РАЗБРАЛ ИНСТРУКЦИИТЕ ЗА ЕКСПЛОАТАЦИЯ И МОНТАЖ, МОЖЕ ДА МОНТИРА ВЕНТИЛНИ ОТВОДИ**

**ДА СЕ ИЗБЯГВА ИЗПОЛЗВАНЕТО НА ОСТРИ ИНСТРУМЕНТИ, КОИТО МОГАТ ДА ПОВРЕДЯТ КОРПУСА НА ВЕНТИЛНИТЕ ОТВОДИ, ОСОБЕНО ПО ВРЕМЕ НА ОТВАРЯНЕ НА КУТИЯТА.**

**МИНИМАЛНАТА МЕЖДИНА МЕЖДУ ВЕНТИЛНИТЕ ОТВОДИ И МЕЖДУ ВЕНТИЛНИТЕ ОТВОДИ И ЗАЗЕМЯВАНЕТО Е ОПРЕДЕЛЕНА НА ТАБЛИЦАТА НА СТРАНИЦА 1. ТЕЗИ РАЗСТОЯНИЯ ТРЯБВА ДА СЕ ИЗПОЛЗВАТ ЗА МОНТАЖ НА ВЕНТИЛНИТЕ ОТВОДИ.**

**ЗА ВЕНТИЛНО ОТВОДИ ТИП AZB \_\_ 2, ВИНАГИ СВЪРЗВАЙТЕ РАЗЕДИНИТЕЛЯ КЪМ ЗЕМЯ С ГЪВКАВ КАБЕЛ, ЗА ДА ИЗБЕГНЕТЕ БЛОКИРАНЕТО НА РАБОТАТА НА РАЗЕДИНИТЕЛЯ.**

**ЗА СВЪРЗВАНЕ И МОНТАЖ НА ВЕНТИЛНИ ОТВОДИ ДА НЕ СЕ ПРЕВИШАВА ОПРЕДЕЛЕНИЯ ВЪРТЯЩ МОМЕНТ.**

**СЛЕД МОНТАЖА НА ВЕНТИЛНИТЕ ОТВОДИ, ПОЧИСТЕТЕ СИЛИКОНОВИЯ КОРПУС С МЕКА И ЧИСТА КЪРПА.**

**ВЕНТИЛНИТЕ ОТВОДИ, КОИТО СА МОНТИРАНИ СЪГЛАСНО ТОВА РЪКОВОДСТВО, НЕ ИЗИСКВАТ НИКАКВО ПРОФИЛАКТИЧНО ТЕХНИЧЕСКО ОБСЛУЖВАНЕ. ЗАМЕНЕТЕ ВЕНТИЛНИТЕ ОТВОДИ, АКО Е ПОВРЕДЕН ИНДИКАТОРЪТ ИЛИ РАЗЕДИНИТЕЛЯТ РАБОТИ ИЛИ СЛЕД ПРЕМОСТВАНЕ**

**ЕКОЛОГИЧЕН АСПЕКТ**

Вентилните отводи DERVASIL не съдържат никакви материали, опасни за околната среда. След използване те трябва да бъдат разрушени в одобрен център.






# Инструкции за експлоатация, монтаж, обслужване и съхранение на склад Вентилни отводи AZBD— 0

## ПРИМЕР ЗА МОНТАЖ


Винаги монтирайте вентилните отводи колкото е възможно по-близо до оборудването, за да бъде то защитено

## ЗАЩИТА НА ТРАНСФОРМАТОРА

Вертикално положение на казана на трансформатора




Хоризонтално положение



## КАБЕЛНА ЗАЩИТА

Хоризонтално положени



DERVASIL Route de Popenot 42800 Saint Joseph FRANCE  
Téléphone : +33 (0)4 77 83 22 81 - Fax : +33 (0)4 77 83 22 80  
Email : [info@dervasil.com](mailto:info@dervasil.com) Web : [www.dervasil.com](http://www.dervasil.com)

Тази документация не се издава по взаимно съгласие.


DERVASIL си запазва правото на промени без предварително уведомление.  
Не съдържа снимки и чертежи по договор

B



QUALITY DEPART.

SPECIFICATION OF PURCHASE  PACKING CARDBOARD BOX AND PALLET	SP Indice A
	DATE : 09/06/2005
	PAGE : 1 / 5



**MATERIAL:** Cardboard  
TC 900 thickness 14.4 mm

**WEIGHT:** 11 kG

**RECYCLABLE :**  
Standard EN13430

**Max Charge :** 400 kG

**LIST OF UPDATE**

Revision	Date	Description of modifications
A	12/09/00	Creation of the specification

This document is an element of the knowledge of the company, and for this reason it can not be distributed to the outside

	Date	Function	Name	Visa
Writing	09/06/2005	R & D	DUSSOL L	
Verification	09/06/2005	Purchase	MOUNIER S	
Approval	09/06/2005	Director	GAZZOLA C	

ВІДПОВІДАЛЬНИК


420

B



QUALITY DEPART.

SPECIFICATION OF PURCHASE  PACKING CARDBOARD BOX AND PALLET	SP Indice A
	DATE : 09/06/2005
	PAGE : 2 / 5



Handwritten signature or mark.

Handwritten text, possibly a date or reference number.

Handwritten signature and a circular stamp.


Handwritten mark at the bottom right corner.



QUALITY DEPART.

SPECIFICATION OF PURCHASE	SP Indice A
	DATE : 09/06/2005
	PAGE : 3 / 5

PACKING CARDBOARD BOX AND PALLET



**MATERIAL:** Cardboard TC 700  
thickness 14.6 mm - 9 PLOTS

**HEIGHT :** 140 mm

**WEIGHT:** 2 kG

**RECYCLABLE :** Standard EN13430

**Max Charge :** 600 kG

PALLET

ВІСНОК КОМПАНІЇ

422



B



**dervasil**

QUALITY DEPART.

SPECIFICATION OF PURCHASE  PACKING CARDBOARD BOX AND PALLET	SP Indice A
	DATE : 09/06/2005
	PAGE : 4 / 5



PT. DERTIKOR S.A.  
RUPRO CORP/PTILAMA

*[Handwritten signature]*  
*[Handwritten initials]*  
*[Handwritten signature]*

*B*




QUALITY DEPART.

SPECIFICATION OF PURCHASE  PACKING CARDBOARD BOX AND PALLET	SP Indice A
	DATE : 09/06/2005
	PAGE : 5 / 5

STEEL STRAPPING


*C*



BERNIS CODOTWILAJA

*[Handwritten signature and scribbles]*

СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ	SP Indice A
	ДАТА: 09/06/2005
	СТРАНИЦА: 1 / 5







**МАТЕРИАЛ:** Картон  
 ТС 900 дебелина 14.4 mm  
**ТЕГЛО:** 11 kg  
**ГОДНИ ЗА РЕЦИКЛИРАНЕ:**  
 Стандарт EN13430  
**Максимално зареждане:** 400 kg

**СПИСЪК НА АКТУАЛИЗАЦИИТЕ**

Редакция	Дата	Описание на промените
A	12/09/00	Изготвяне на спецификация

Този документ е елемент от ноу-хау на компанията и поради тази причина той не може да бъде разпространяван извън нея

	Дата	Функция	Име	Подпис
Вписване	09/06/2005	R & D	DUSSOL L	
Верификация	09/06/2005	Покупка	MOUNIER S	
Одобрил	09/06/2005	Директор	GAZZOLA C	




*M*



ОТДЕЛ ПО КАЧЕСТВОТО

СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ	SP Indice A
	ДАТА: 09/06/2005
	СТРАНИЦА: 2 / 5



*8*

*Q*

*A. Konec*

*Q*

026






ОТДЕЛ ПО КАЧЕСТВОТО

B

СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ	SP Indice A
	ДАТА: 09/06/2005
	СТРАНИЦА: 3 / 5



МАТЕРИАЛ: Картон ТС 700  
дебелина 14.6 mm - 9 PLOTS

ВИСОЧИНА : 140 mm

ТЕГЛО: 2 kg

ПОДЛЕЖИ НА РЕЦИКЛИРАНЕ :  
Стандарт EN13430



Максимален заряд :600 kg

ПАЛЕТ

Handwritten signatures and initials, including a large signature that appears to be 'P. Kovacs' and another signature to the right.

B

СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ	SP Indice A
	ДАТА: 09/06/2005
	СТРАНИЦА: 4 / 5




*[Handwritten signature]*  
*[Handwritten signature]*  
*[Handwritten signature]*

13

СПЕЦИФИКАЦИЯ ЗА ПОКУПКА НА ОПАКОВЪЧНИ КУТИИ И ПАЛЕТИ	SP Indice A
	ДАТА: 09/06/2005
	СТРАНИЦА: 5 / 5

СТОМАНЕНА ЛЕНТА

09



05 04  
A. Konev

Πρωτοκολλο

B

groupe sicame



dervasil

SAS au capital de 907 190 €

COMPOSANTS DE PROTECTION POUR LES RÉSEAUX D'ÉNERGIE ÉLECTRIQUE

Direction - Services commerciaux - Usine  
Route de Popenot  
42800 SAINT JOSEPH

Tél. (33) 04 77 75 29 98  
Fax (33) 04 77 83 22 80  
E-mail : Info@dervasil.com

J

VREF.

NREF.

Certificate

EMETTEUR :

*To whom it may concerns*

We undersign, DERVASIL S.A.S, subsidiary of SICAME S.A, French manufacturer for hardware and accessories for electrical lines and network since 1955 with headquarters located at 19230 POMPADOUR CEDEX / France represented by Stéphane Pradella, Area manager, certify that :

The Medium Voltage Lightning Arresters manufactured by our company in France DERVASIL S.A.S Types AZC and AZBD

are manufactured according to ISO 9001-2008, AFAQ certified and qualified by type tests performed in independent laboratories.

Dervasil MV Arresters are conforming to international standards EN 60099-4 and IEC/TS 60815-3.

Dervasil ( Ferraz) Arresters with silicone housing are now installed on French network for more than 20 years and are still giving full service satisfaction.

Therefore, we can certify a lifetime of more than 20 years.

St Joseph on  
May 28th, 2013



SAS au capital de 907 190 €  
Route de Popenot - 42800 SAINT-JOSEPH  
Tél. 04 77 75 29 98 - Fax 04 77 83 22 80  
RC St-Etienne 423 136 977 - Code NAF 312 A

Handwritten signature

Stamp: REPUBLIC OF CYPRUS  
Handwritten signature

Handwritten signature

u30

B

DERVASIL

Управление

Route De Popenot

42800 Saint-Joseph

Тел.(33) 04 77 75 29 98

Факс.(33) 04 77 83 22 80

E-mail : info@dervasil.com

Сертификат

До тези, за които се отнася.

Ние долуподписаните, DERVASIL S.A.S., филиал на SICAME S.A, френски производител на оборудване/части и аксесоари за електрически мрежи от 1955г. със седалище в 19230 Rompadour CEDEX/Франция представлявано от Stéphane PRADELLA, Регионален мениджър, потвърждаваме че:

Вентилните отводи за средно напрежение типове AZC и AZBD, произведени във Франция от DERVASIL S.A.S

са в съответствие с ISO 9001 – 2008, сертифицирани от AFAQ и проверени с протоколи от изпитвания на независими лаборатории.

Вентилните отводи за средно напрежение на Dervasil са в съответствие с международния стандарт EN 60099-4 и IEC/TS 60815-3.

Вентилните отводи на Dervasil (Ferraz) със силиконова обвивка, които са били инсталирани във френската електрическа мрежа от преди повече от 20 години са все още в употреба и дават удовлетворителни резултати.

Следователно декларираме експлоатационната дълготрайност повече от 20 години (минимум 20 години).

St Joseph

28.05.2013

431