

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Rated operational voltage: Ue (V)	415	
	Rated control supply voltage of closing mechanism: Uc (V)	-	
	Rated control supply voltage of shunt releases: Uc (V)	-	
	Rated control supply voltage undervoltage releases: Uc (V)	-	
	Ambient temperature 10-40 °C :	28°C	P
	Number of operating cycles per hour	120	P
	Number of cycles without current (total) (closing mechanism energized at the rated Uc)		N/A
	Number of cycles without current (without releases)	1000	P
	Applied voltage: closing mechanism (V)		N/A
	10% of total cycles for circuit-breaker with fitted shunt release: (50% at the beginning- and 50% at the end of the test.) Energized at the rated Uc		N/A
	Applied voltage: shunt releases (V)		N/A
	10% of total cycles for circuit-breaker with undervoltage releases: (50% at the beginning- and 50% at the end of the test.) Energized at the minimum rated Uc		N/A
	10 cycles without applied voltage at the undervoltage releases. (Shall not possible to close the circuit-breaker.)		N/A
	Applied voltage: undervoltage releases (V)		N/A
	Electrical components do not exceed the value indicated in tab. 7.		N/A
8.3.3.3.4	Operational performance capability with current.		
	Rated current: In (A)	125	
	Maximum rated operational voltage: Ue (V)	415	
	Conductor cross-sectional area (mm ²) :	50	P ✓
	Number of operating cycles per hour	120	P
	Number of cycles with current (total) (closing mechanism energized at the rated Uc)	1000	P
	Applied voltage: closing mechanism (V)		N/A

TRF No. IEC60947_2F

ВЯРНО С ОРИГИНАЛА


IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	For circuit-breaker fitted with adjustable releases, test shall be made with the overload setting at maximum and short-circuit setting at minimum.		N/A
	Conditions, make/break operations:		
	- test voltage $U/U_e = 1,0$ (V)L1:L2:L3:	420 420 420	P
	- test current $I/I_e = 1,0$ (A)L1:L2:L3:	128 128 128	P
	- power factor/time constant:	0,78	P
	- frequency: (Hz)	50	P
	- on-time (ms):	400	P
	- off-time (s):	30	P
	Electrical components do not exceed the value indicated in tab. 7.		P
8.3.3.3.5	Additional test of operational performance capability without current for withdrawable circuit-breaker.		
	Number of operations cycles : 100		N/A
	After test, the isolating contacts, withdrawable mechanism and interlocks shall be suitable for further service.		N/A
8.3.3.4	Overload performance		
	this test applies to circuit-breaker of rated current up to and including 630 A		
	Type designation or serial number	HDB2	
	Sample no:	I-2	
	Rated current I_n (A)	125	
	Rated operational voltage: U_e (V)	415	
	Rated control supply voltage of closing mechanism: U_c (V)	-	
	Rated control supply voltage of shunt releases: U_c (V)	-	
	Rated control supply voltage undervoltage releases: U_c (V)	-	
	Ambient temperature 10-40 °C :	30°C	P
	Number of operating cycles per hour	120	P
	Maximum rated operational voltage: U_e (V)	415	P

TRF No. IEC60947_2F

ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Number of cycles with current (total) (closing mechanism energized at the rated U_c)	12	P
	Applied voltage: closing mechanism (V)		N/A
	For circuit-breaker fitted with adjustable releases, test shall be made with the overload/short-circuit settings at maximum.		N/A
	Conditions, overload operations:		
	- test voltage $U/U_e = 1,05$ (V) L1: L2: L3:	440 440 440	P
	- test current AC/DC: $I/I_e = 6,0/2,5$ (A) L1: L2: L3:	752 752 752	P
	- power factor/time constant:	0,46	P
	- Number of cycles manually opened: 9	9	P
	- Number of cycles automatically opened by an overload release: 3	3	P
	- frequency: (Hz)	50	P
	- on-time max 2s:	<2s	P
8.3.3.5	Verification of dielectric withstand		
	- equal to twice the rated operational voltage with a minimum of 1000 V for 5 seconds	1000V	P
	- no breakdown or flashover		P
	For circuit-breaker suitable for isolation, the leakage current shall be measured through each pole with the contacts in the open position, at a test voltage of $1,1 U_e$, and shall not exceed 2 mA.	457V $3,11 \times 10^{-3}$ mA (maximum)	P
8.3.3.6	Verification of temperature-rise		
	- the values of temperature-rise do not exceed those specified in tab. 7.		P
	Temperature rise of main circuit terminals ≤ 80 K (K) :	60	P
	conductor cross-sectional area (mm^2) :	50	P
	test current I_e (A) :	125	P
8.3.3.7	Verification of overload releases		
	Test current: 1.45 times the value of their current setting at the reference temperature: (A)	181	P

TRF No. IEC60947_2F




ВЯРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Conventional tripping time: <1h when $I_n < 63A$, <2h when $I_n > 63A$	56s	P
8.3.3.8	Verification of undervoltage and shunt releases		
	Circuit-breaker fitted with undervoltage releases. The release shall not operate at 70% of the minimum control supply voltage -		N/A
	and shall operate at 35% of the maximum control supply voltage.		N/A
	Circuit-breaker fitted with shunt releases. The release shall operate at 70% of the minimum rated control supply voltage. Test made at room temperature.		N/A
8.3.3.9	Verification of the main contact position for circuit-breakers for isolation		
	actuating force for opening (N)	20	—
	test force with blocked main contacts for 10 s (N) . :	60	—
	Dependent power operation		N/A
	Supply voltage of 110% of rated voltage (V).....:		N/A
	Three attempts of 5 s to operate the equipment at intervals of 5 min.		N/A
	Independent power operation		N/A
	Three attempts to operate the equipment by the stored energy.		N/A
	Lock ability of driving mechanism in OFF-position at test force and blocked main contacts		N/A
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P

8.3.4	TEST SEQUENCE II (Ics): 1 sample: 4P, 125A		
8.3.4.1	Test of rated service short-circuit breaking capacity		
	Test sequence of operation: O – t – CO – t – CO		
	Type designation or serial number	HDB2	
	Sample no:	II-1	
	Rated current: I_n (A)	125	
	Rated operational voltage: U_e (V)	415	
	Rated service short-circuit breaking capacity: (kA)	7,5	


TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Rated control supply voltage of closing mechanism: Uc (V)		
	Rated control supply voltage of shunt release: Uc (V)		
	For circuit-breaker fitted with adjustable releases, test shall be made with the current and time settings at maximum.		N/A
	closing mechanism energized with 85% at the rated Uc: (V)		N/A
	The circuit-breaker is mounted complete on its own support or an equivalent support.		P
	Test made in free air:		P
	Distances of the metallic screen's: (all sides)	Back: 0mm Front: 0mm Top: 45mm Bottom: 45mm Left: 10mm Right: 10mm	P
	The characteristics of the metallic screen:		
	- woven wire mesh		N/A
	- perforated metal		P
	- expanded metal		N/A
	- ratio hole area/total area: 0,45-0,65	0,50	P
	- size of hole: <math><30\text{mm}^2</math>	25	P
	- finish: bare or conductive plating	Bare	P
	Test made in specified individual enclosure: Details of these tests, including the dimensions of the enclosure:		N/A
	Fuse "F": copper wire: diameter 0,8 mm, 50 mm long		P
	Circuit is earthed at: (load-star- or supply-star point)	supply-star	P
	Conductor cross-sectional area (mm ²) :	50	P
	If terminals unmarked: line connected at: (underside/upside)		N/A
	Tightening torques: (Nm)	2,0	N/A
	Test sequence of operation: O - t - CO - t - CO		P
	- test voltage U/Ue = 1,05 (V).....L1:	438	P
L2:	438	
L3:	438	


TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	- r.m.s. test current AC/DC: (kA)L1:L2:L3:	7,6 7,7 7,6	P
	power factor/time constant :	0,47	P
	- Factor "n"	1,7	P
	- peak test current (kA) :	10,8	P
	Test sequence "O"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	6,9 2,1 4,3	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	157 27,5 85,8	P
	Pause, t: (min)	3	P
	Test sequence "CO"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	6,0 4,1 3,6	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	114 78,1 49,7	P
	Pause, t: (min)	3	P
	Test sequence "CO"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	3,0 5,5 2,9	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	49,3 110 48,1	P
	Melting of the fusible element	No	P
	Holes in the PE-sheet for test sequence "O"	No	P
	Cracks observed	No	P
8.3.4.2	Operational performance capability with current.		
	Rated current: I _n (A)	125	
	Maximum rated operational voltage: U _e (V)	415	
	Conductor cross-sectional area (mm ²) :	50	
	Number of operating cycles per hour	120	P

TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА


IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Number (5% of the number given in column 4, tab. 8) of cycles with current (total) (closing mechanism energized at the rated U _c)	50	P
	Applied voltage: closing mechanism (V)		N/A
	For circuit-breaker fitted with adjustable releases, test shall be made with the overload setting at maximum and short-circuit setting at minimum.		N/A
	Conditions, make/break operations:		
	- test voltage U/U _e = 1,0 (V)L1:	420	P
L2:	420	
L3:	420	
	- test current I/I _e = 1,0 (A)L1:	128	P
L2:	128	
L3:	128	
	- power factor/time constant:	0,78	P
	- frequency: (Hz)	50	P
	- on-time (ms):	300	P
	- off-time (s):	30	P
8.3.4.3	Verification of dielectric withstand		
	- equal to twice the rated operational voltage with a minimum of 1000 V	1000V	P
	- no breakdown or flashover		P
	- the leaking current for circuit-breaker suitable for isolation: (<2mA / 1.1 U _e)	457V 6,23x10 ⁻³ mA(maximum)	P
8.3.4.4	Verification of temperature-rise		
	- the values of temperature-rise do not exceed those specified in tab. 7.		P
	Temperature rise of main circuit terminals. ≤ 80 K (K) :	59	P
	conductor cross-sectional area (mm ²) :	50	P
	test current I _e (A) :	125	P
8.3.4.5	Verification of overload releases		
	Test current: 1.45 times the value of their current setting at the reference temperature: (A)	181	P
	Conventional tripping time: <1h when I _n < 63A, <2h when I _n > 63 A	4min15s	P

TRF No. IEC60947_2F

ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II (Ics): -1 sample: 4P, 63A		
8.3.4.1	Test of rated service short-circuit breaking capacity		
	Test sequence of operation: O – t – CO – t – CO		
	Type designation or serial number	HDB2	
	Sample no:	II-2	
	Rated current: In (A)	63	
	Rated operational voltage: Ue (V)	415	
	Rated service short-circuit breaking capacity: (kA)	7,5	
	Rated control supply voltage of closing mechanism: Uc (V)		
	Rated control supply voltage of shunt release: Uc (V)		
	For circuit-breaker fitted with adjustable releases, test shall be made with the current and time settings at maximum.		N/A
	closing mechanism energized with 85% at the rated Uc: (V)		N/A
	The circuit-breaker is mounted complete on its own support or an equivalent support.		P
	Test made in free air:		P
	Distances of the metallic screen's: (all sides)	Back: 0mm Front: 0mm Top: 45mm Botton: 45mm Left: 10mm Right: 10mm	P
	The characteristics of the metallic screen:		
	- woven wire mesh		N/A
	- perforated metal		P
	- expanded metal		N/A
	- ratio hole area/total area: 0,45-0,65	0,50	P
	- size of hole: <30mm ²	25	P
	- finish: bare or conductive plating	Bare	P
	Test made in specified individual enclosure: Details of these tests, including the dimensions of the enclosure:		N/A
	Fuse "F": copper wire: diameter 0,8 mm, 50 mm long		P


TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Circuit is earthed at: (load-star- or supply-star point)	supply-star	P
	Conductor cross-sectional area (mm ²):	16	N/A
	If terminals unmarked: line connected at: (underside/upside)		N/A
	Tightening torques: (Nm)	2,0	N/A
	Test sequence of operation: O - t - CO - t - CO		P
	- test voltage U/Ue = 1,05 (V).....L1:L2:L3:	438 438 438	P
	- r.m.s. test current AC/DC: (kA).....L1:L2:L3:	7,6 7,7 7,6	P
	power factor/time constant :	0,47	P
	- Factor "n"	1,7	P
	- peak test current (kA) :	10,8	P
	Test sequence "O"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	5,8 2,1 4,0	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	99,5 25,8 48,4	P
	Pause, t: (min)	3	P
	Test sequence "CO"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	1,3 3,2 5,5	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	17,9 35,9 77,3	P
	Pause, t: (min)	3	P
	Test sequence "CO"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	2,4 4,1 1,7	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	28,4 51,2 16,7	P


TRF No. IEC60947_2F



ВЯРНО С ОРИГИНАЛА


IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Melting of the fusible element	No	P
	Holes in the PE-sheet for test sequence "O"	No	P
	Cracks observed	No	P
8.3.4.2	Operational performance capability with current.		
	Rated current: In (A)		
	Maximum rated operational voltage: Ue (V)		
	Conductor cross-sectional area (mm ²):		
	Number of operating cycles per hour		N/A
	Number (5% of the number given in column 4, tab. 8) of cycles with current (total) (closing mechanism energized at the rated U _c)		N/A
	Applied voltage: closing mechanism (V)		N/A
	For circuit-breaker fitted with adjustable releases, test shall be made with the overload setting at maximum and short-circuit setting at minimum.		N/A
	Conditions, make/break operations:		
	- test voltage U/U _e = 1,0 (V)L1:L2:L3:	- - -	N/A
	- test current I/I _e = 1,0 (A)L1:L2:L3:	- - -	N/A
	- power factor/time constant:		N/A
	- frequency: (Hz)		N/A
	- on-time (ms):		N/A
	- off-time (s):		N/A
8.3.4.3	Verification of dielectric withstand		
	- equal to twice the rated operational voltage with a minimum of 1000 V	1000V	P
	- no breakdown or flashover		P
	- the leaking current for circuit-breaker suitable for isolation: (<2mA / 1.1 U _e)	457V 5,55x10 ⁻³ mA(maximum)	P
8.3.4.4	Verification of temperature-rise		
	- the values of temperature-rise do not exceed those specified in tab. 7.		N/A

TRF No. IEC60947_2F



ВЯРНО С ОРИГИНАЛА


IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Temperature rise of main circuit terminals. ≤ 80 K (K) :		N/A
	conductor cross-sectional area (mm ²) :		N/A
	test current I _e (A) :		N/A
8.3.4.5	Verification of overload releases		
	Test current: 1.45 times the value of their current setting at the reference temperature: (A)	91,4	P
	Conventional tripping time: <1h when I _n < 63A, <2h when I _n > 63 A	1min27s	P



ВЯРНО С ОРИГИНАЛА


TRF No. IEC60947_2F

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5	TEST SEQUENCE III (Icu) -1 sample: 4P, 125A		
	Rated ultimate short-circuit breaking		
	Except where the combined test sequence applies, this test sequence applies to circuit-breaker of utilization category A and to circuit-breaker of utilization B having a rated ultimate short-circuit breaking capacity higher than the rated short-time withstand current.		
	For circuit-breakers of utilization B having a rated short-time withstand current equal to their rated ultimate short-circuit breaking capacity, this test sequence need not be made, since, in this case, the ultimate short-circuit breaking capacity, is verified when carrying out test sequence IV.		
	For integrally fused circuit-breakers, test sequence V applies in place of this sequence.		
	Type designation or serial number	HDB2	
	Sample no:	III-1	
	Rated current: In (A)	125	
	Rated operational voltage: Ue (V)	415	
	Rated ultimate short-circuit breaking capacity: (kA)	10	
	Rated control supply voltage of closing mechanism: Uc (V)		
	Rated control supply voltage of shunt release: Uc (V)		
	This test sequence need not be made when Icu = Ics		
8.3.5.1	The operation of overload releases shall be verified at twice the value of their current setting on each pole separately.		
	The operating time shall not exceed the max. value stated by the manufacturer for twice the current setting at the reference temperature, on a pole singly.		
	Time specified by the manufacturer:	≤8min	P
	- Operation time: (s)L1:	1min57s	P
L2:	2min36s	
L3:	1min56s	
L4 :	1min46s	
8.3.5.2	Test of rated ultimate short-circuit breaking capacity		
	The test sequence of operations is O – t – CO		
	For circuit-breaker fitted with adjustable releases, test shall be made with the current and time settings at maximum.		N/A




IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	closing mechanism energized with 85% at the rated Uc: (V)		N/A
	The circuit-breaker is mounted complete on its own support or an equivalent support.		P
	Test made in free air:		P
	Distances of the metallic screen's: (all sides)	Back: 0mm Front: 0mm Top: 45mm Bottom: 45mm Left: 10mm Right: 10mm	P
	The characteristics of the metallic screen:		
	- woven wire mesh		N/A
	- perforated metal		P
	- expanded metal		N/A
	- ratio hole area/total area: 0,45-0,65	0,50	P
	- size of hole: <30mm ²	25	P
	- finish: bare or conductive plating	Bare	P
	Test made in specified individual enclosure: Details of these tests, including the dimensions of the enclosure:	<i>Am</i>	N/A
	Fuse "F": copper wire: diameter 0,8 mm, 50 mm long		P
	Circuit is earthed at: (load-star- or supply-star point)	Supply-star	P
	Conductor cross-sectional area (mm ²) :	50	P
	If terminals unmarked: line connected at: (underside/upside)		N/A
	Tightening, torques: (Nm)	3,5	P
	Test sequence of operation: O – t – CO		P
	- test voltage U/Ue = 1,05 (V)L1:	440	P
L2:	440	
L3:	440	
	- r.m.s. test current AC/DC: (kA)L1:	10,3	P
L2:	10,3	
L3:	10,3	
	power factor/time constant :	0,47	P
	- Factor "n"	1,7	P
	- peak test current (kAmax) :	16,7	P

TRF No. IEC60947_2F



ВЯРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Test sequence "O"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	6,73 7,82 5,69	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	162 311 75,6	P
	Pause, t: (min)	3	P
	Test sequence "CO"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	6,18 5,52 7,25	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	88,4 91,5 230	P
	Melting of the fusible element	No	P
	Holes in the PE-sheet for test sequence "O"	No	P
	Cracks observed	No	P
8.3.5.3	Verification of dielectric withstand		
	- equal to twice the rated operational voltage with a minimum of 1000 V for 5 seconds	1000	P
	- no breakdown or flashover		P
	- the leaking current for circuit-breaker suitable for isolation: (<6mA / 1,1 U _e)	457V 7,03x10 ⁻³ mA(maximum)	P
8.3.5.4	Verification of overload releases		
	The operation of overload releases shall be verified at 2,5 times the value of their current setting on each pole separately.		
	The operating time shall not exceed the max. value stated by the manufacturer for twice the current setting at the reference temperature, on a pole singly.		
	Time specified by the manufacturer:		N/A
	- Operation time: (s)L1:L2:L3:L4:	51s 1min07s 46s 41s	P



IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5	TEST SEQUENCE III (Icu) -1 sample: 4P, 63A		
	Rated ultimate short-circuit breaking		
	Except where the combined test sequence applies, this test sequence applies to circuit-breaker of utilization category A and to circuit-breaker of utilization B having a rated ultimate short-circuit breaking capacity higher than the rated short-time withstand current.		
	For circuit-breakers of utilization B having a rated short-time withstand current equal to their rated ultimate short-circuit breaking capacity, this test sequence need not be made, since, in this case, the ultimate short-circuit breaking capacity, is verified when carrying out test sequence IV.		
	For integrally fused circuit-breakers, test sequence V applies in place of this sequence.		
	Type designation or serial number	HDB2	
	Sample no:	III-1	
	Rated current: In (A)	63	
	Rated operational voltage: Ue (V)	415	
	Rated ultimate short-circuit breaking capacity: (kA)	10	
	Rated control supply voltage of closing mechanism: Uc (V)		
	Rated control supply voltage of shunt release: Uc (V)		
	This test sequence need not be made when Icu = Ics		
8.3.5.1	The operation of overload releases shall be verified at twice the value of their current setting on each pole separately.		
	The operating time shall not exceed the max. value stated by the manufacturer for twice the current setting at the reference temperature, on a pole singly.		
	Time specified by the manufacturer:	≤8min	P
	- Operation time: (s) L1:	1min11s	P
 L2:	56s	
 L3:	48s	
 L4 :	47s	
8.3.5.2	Test of rated ultimate short-circuit breaking capacity		
	The test sequence of operations is O – t – CO		
	For circuit-breaker fitted with adjustable releases, test shall be made with the current and time settings at maximum.		N/A


TRF No. IEC60947_2F

ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	closing mechanism energized with 85% at the rated Uc: (V)		N/A
	The circuit-breaker is mounted complete on its own support or an equivalent support.		P
	Test made in free air:		P
	Distances of the metallic screen's: (all sides)	Back: 0mm Front: 0mm Top: 45mm Bottom: 45mm Left: 10mm Right: 10mm	P
	The characteristics of the metallic screen:		
	- woven wire mesh		N/A
	- perforated metal		P
	- expanded metal		N/A
	- ratio hole area/total area: 0,45-0,65	0,50	P
	- size of hole: <30mm ²	25	P
	- finish: bare or conductive plating	Bare	P
	Test made in specified individual enclosure: Details of these tests, including the dimensions of the enclosure:		N/A
	Fuse "F": copper wire: diameter 0,8 mm, 50 mm long		P
	Circuit is earthed at: (load-star- or supply-star point)	Supply-star	P
	Conductor cross-sectional area (mm ²) :	16	P
	If terminals unmarked: line connected at: (underside/upside)		N/A
	Tightening, torques: (Nm)	3,5	P
	Test sequence of operation: O – t – CO		P
	- test voltage U/Ue = 1,05 (V)L1:L2:L3:	438 438 438	P
	- r.m.s. test current AC/DC: (kA)L1:L2:L3:	10,3 10,3 10,3	P
	power factor/time constant :	0,47	P
	- Factor "n"	1,7	P
	- peak test current (kAmax) :	18,9	P


IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Test sequence "O"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	8,1 2,1 5,9	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	179 37,2 88,9	P
	Pause, t: (min)	3	P
	Test sequence "CO"		
	- max. let-through current: (kA _{peak})L1:L2:L3:	1,1 5,8 5,8	P
	- Joule integral I ² dt (kA ² s)L1:L2:L3:	5,9 59,4 59,3	P
	Melting of the fusible element	No	P
	Holes in the PE-sheet for test sequence "O"	No	P
	Cracks observed	No	P
8.3.5.3	Verification of dielectric withstand		
	- equal to twice the rated operational voltage with a minimum of 1000 V for 5 seconds	1000	P
	- no breakdown or flashover		P
	- the leaking current for circuit-breaker suitable for isolation: (<6mA / 1,1 U _e)	458V 10,33x10 ⁻³ mA(maximum)	P
8.3.5.4	Verification of overload releases		
	The operation of overload releases shall be verified at 2,5 times the value of their current setting on each pole separately.		
	The operating time shall not exceed the max. value stated by the manufacturer for twice the current setting at the reference temperature, on a pole singly.		
	Time specified by the manufacturer:		N/A
	- Operation time: (s)L1:L2:L3:L4 :	52s 41s 40s 32s	P

TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5	TEST SEQUENCE III (Icu) -1 sample: 4P, 125A		
	Rated ultimate short-circuit breaking – tested on the four pole and its adjacent pole		
	Except where the combined test sequence applies, this test sequence applies to circuit-breaker of utilization category A and to circuit-breaker of utilization B having a rated ultimate short-circuit breaking capacity higher than the rated short-time withstand current.		
	For circuit-breakers of utilization B having a rated short-time withstand current equal to their rated ultimate short-circuit breaking capacity, this test sequence need not be made, since, in this case, the ultimate short-circuit breaking capacity, is verified when carrying out test sequence IV.		
	For integrally fused circuit-breakers, test sequence V applies in place of this sequence.		
	Type designation or serial number	HDB2	
	Sample no:	III-3	
	Rated current: In (A)	125	
	Rated operational voltage: Ue (V)	415	
	Rated ultimate short-circuit breaking capacity: (kA)	10	
	Rated control supply voltage of closing mechanism: Uc (V)		
	Rated control supply voltage of shunt release: Uc (V)		
	This test sequence need not be made when Icu = Ics		
8.3.5.1	The operation of overload releases shall be verified at twice the value of their current setting on each pole separately.		
	The operating time shall not exceed the max. value stated by the manufacturer for twice the current setting at the reference temperature, on a pole singly.		
	Time specified by the manufacturer:	≤8min	P
	- Operation time: (s)L3:	1min13s	P
L4:	1min06s	
8.3.5.2	Test of rated ultimate short-circuit breaking capacity		
	The test sequence of operations is O – t – CO		
	For circuit-breaker fitted with adjustable releases, test shall be made with the current and time settings at maximum.		N/A




IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	closing mechanism energized with 85% at the rated Uc: (V)		N/A
	The circuit-breaker is mounted complete on its own support or an equivalent support.		P
	Test made in free air:		P
	Distances of the metallic screen's: (all sides)	Back: 0mm Front: 0mm Top: 45mm Bottom: 45mm Left: 10mm Right: 10mm	P
	The characteristics of the metallic screen:		
	- woven wire mesh		N/A
	- perforated metal		P
	- expanded metal		N/A
	- ratio hole area/total area: 0,45-0,65	0,50	P
	- size of hole: <math><30\text{mm}^2</math>	25	P
	- finish: bare or conductive plating	Bare	P
	Test made in specified individual enclosure: Details of these tests, including the dimensions of the enclosure:		N/A
	Fuse "F": copper wire: diameter 0,8 mm, 50 mm long		P
	Circuit is earthed at: (load-star- or supply-star point)	Supply-star	P
	Conductor cross-sectional area (mm ²):	50	P
	If terminals unmarked: line connected at: (underside/upside)		N/A
	Tightening, torques: (Nm)	3,5	P
	Test sequence of operation: O – t – CO		P
	- test voltage U/Ue = 1,05 (V)L3:	256	P
L4:	-	
	- r.m.s. test current AC/DC: (kA)L3:	6,13	P
L4:	-	
	power factor/time constant :	0,68	P
	- Factor "n"	1,53	P
	- peak test current (kA _{max}):	8,7	P
	Test sequence "O"		
	- max. let-through current: (kA _{peak})L3:	7,8	P
L4:	-	

TRF No. IEC60947_2F

ВЯРНО С ОРИГИНАЛА


524

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	- Joule integral I^2dt (kA ² s)L3:L4:	203 -	P
	Pause, t: (min)	3	P
	Test sequence "CO"		
	- max. let-through current: (kA _{peak})L3:L4:	8,9 -	P
	- Joule integral I^2dt (kA ² s)L3:L4:	243 -	P
	Melting of the fusible element	No	P
	Holes in the PE-sheet for test sequence "O"	No	P
	Cracks observed	No	P
8.3.5.3	Verification of dielectric withstand		
	- equal to twice the rated operational voltage with a minimum of 1000 V for 5 seconds	1000	P
	- no breakdown or flashover		P
	- the leaking current for circuit-breaker suitable for isolation: (<6mA / 1,1 U _e)	458V 5,83x10 ⁻³ mA(maximum)	P
8.3.5.4	Verification of overload releases		
	The operation of overload releases shall be verified at 2,5 times the value of their current setting on each pole separately.		
	The operating time shall not exceed the max. value stated by the manufacturer for twice the current setting at the reference temperature, on a pole singly.		
	Time specified by the manufacturer:		N/A
	- Operation time: (s)L3:L4:	53s 50s	P



IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5	TEST SEQUENCE III (Icu) -1 sample: 4P, 63A		
	Rated ultimate short-circuit breaking - tested on the four pole and its adjacent pole		
	Except where the combined test sequence applies, this test sequence applies to circuit-breaker of utilization category A and to circuit-breaker of utilization B having a rated ultimate short-circuit breaking capacity higher than the rated short-time withstand current.		
	For circuit-breakers of utilization B having a rated short-time withstand current equal to their rated ultimate short-circuit breaking capacity, this test sequence need not be made, since, in this case, the ultimate short-circuit breaking capacity, is verified when carrying out test sequence IV.		
	For integrally fused circuit-breakers, test sequence V applies in place of this sequence.		
	Type designation or serial number	HDB2	
	Sample no:	III-10	
	Rated current: In (A)	63	
	Rated operational voltage: Ue (V)	415~	
	Rated ultimate short-circuit breaking capacity: (kA)	10	
	Rated control supply voltage of closing mechanism: Uc (V)		
	Rated control supply voltage of shunt release: Uc (V)		
	This test sequence need not be made when Icu = Ics		
8.3.5.1	The operation of overload releases shall be verified at twice the value of their current setting on each pole separately.		
	The operating time shall not exceed the max. value stated by the manufacturer for twice the current setting at the reference temperature, on a pole singly.		
	Time specified by the manufacturer:		N/A
	- Operation time: (s)L3:	48s	N/A
L4:	57s	
8.3.5.2	Test of rated ultimate short-circuit breaking capacity		
	The test sequence of operations is O – t – CO		
	For circuit-breaker fitted with adjustable releases, test shall be made with the current and time settings at maximum.		N/A
	closing mechanism energized with 85% at the rated Uc: (V)		N/A


TRF No. IEC60947_2F



ВЯРНО С ОПРИТНАТА


IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	The circuit-breaker is mounted complete on its own support or an equivalent support.		P
	Test made in free air:		P
	Distances of the metallic screen's: (all sides)	Back: 0mm Front: 0mm Top: 45mm Bottom: 45mm Left: 10mm Right: 10mm	P
	The characteristics of the metallic screen:		
	- woven wire mesh		N/A
	- perforated metal		P
	- expanded metal		N/A
	- ratio hole area/total area: 0,45-0,65	0,50	P
	- size of hole: <30mm ²	25	P
	- finish: bare or conductive plating	Bare	P
	Test made in specified individual enclosure: Details of these tests, including the dimensions of the enclosure:		N/A
	Fuse "F": copper wire: diameter 0,8 mm, 50 mm long		P
	Circuit is earthed at: (load-star- or supply-star point)	Supply-star	P
	Conductor cross-sectional area (mm ²):	16	P
	If terminals unmarked: line connected at: (underside/upside)		N/A
	Tightening, torques: (Nm)	3,5	P
	Test sequence of operation: O – t – CO		P
	- test voltage U/Ue = 1,05 (V)L3:L4:	256 -	P
	- r.m.s. test current AC/DC: (kA)L3:L4:	6,13 -	P
	power factor/time constant :	0,68	P
	- Factor "n"	1,53	P
	- peak test current (kAmax) :	8,7	P
	Test sequence "O"		
	- max. let-through current: (kApeak)L3:L4:	5,1 -	P
	- Joule integral I ² dt (kA ² s)L3:L4:	50,4 -	P

TRF No. IEC60947_2F



ВЯРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Pause, t: (min)	3	P
	Test sequence "CO"		
	- max. let-through current: (kA _{peak})L3:L4:	2,1 -	P
	- Joule integral I ² dt (kA ² s)L3:L4:	6,5 -	P
	Melting of the fusible element	No	P
	Holes in the PE-sheet for test sequence "O"	No	P
	Cracks observed	No	P
8.3.5.3	Verification of dielectric withstand		
	- equal to twice the rated operational voltage with a minimum of 1000 V for 5 seconds	1000	P
	- no breakdown or flashover		P
	- the leaking current for circuit-breaker suitable for isolation: (<6mA / 1,1 U _e)	458V 7,91x10 ⁻³ mA(maximum)	P
8.3.5.4	Verification of overload releases		
	The operation of overload releases shall be verified at 2,5 times the value of their current setting on each pole separately.		
	The operating time shall not exceed the max. value stated by the manufacturer for twice the current setting at the reference temperature, on a pole singly.		
	Time specified by the manufacturer:		N/A
	- Operation time: (s)L3:L4:	32s 40s	P



ВАРНО С ОРИГИНАЛА

TRF No. IEC60947_2F

IEC 60947-2

TABLE: TEMPERATURE RISE MEASUREMENTS


temperature rise dT of part:		phase	dT (K)	required dT (K)
For clause 8.3.3.6 (125A, 4P)				
1	Terminals for external connections	Max for all	60	80
2	Enclosure	Max for all	38	50
3	Non-metallic handle	Max for all	6	35
For clause 8.3.4.4 (125A, 4P)				
1	Terminals for external connections	Max for all	59	80

TABLE: THREADED PART TORQUE TEST

threaded part identification	diameter of thread (mm)	column number (I, II, or III)	applied torque (Nm)
Terminal screw	6,8	II	3,5
supplementary information:			

TABLE: GLOW WIRE TEST

Part	Colour	Thick (mm)	Temp. °C	burning after t (s)	drops	support burning	Comments
Enclosure	Grey	2,5	960	2	No	No	OK
Non-metallic mechanical parts	Brown	2,0	960	-	No	No	OK
	Red	2,0	650	-	No	No	OK
	White	2,5	960	-	No	No	OK
Handle	Black	2,0	650	-	No	No	OK
supplementary information:							





ВЯРНО С ОРИГИНАЛА


Handwritten signature

IEC 60947-2

Photos of samples: 4P



Handwritten signature



ВЯРНО С ОРИГИНАЛА



Photos of samples:

TRF No. IEC60947_2F


Handwritten signature

Handwritten signature

IEC 60947-2



Photos of samples:





ВЯРНО С ОРИГИНАЛА

TRF No. IEC60947_2F

214

[Handwritten signature]

IEC 60947-2



[Handwritten signature]



ВЯРНО С ОРИГИНАЛА

TRF No. IEC60947_2F

[Handwritten signature]

[Handwritten signature]

СПИСЪК НА ПРОВЕДЕНИТЕ ИЗПИТВАНИЯ

I.Списък на проведените изпитвания за миниатюрен автоматичен прекъсвач HDB9H.

1. Общ преглед
 - 1.1. Проверка на маркировката
 - 1.1.1. Незаличимост на маркировката
 - 1.2. Проверка на механизмите
 - 1.3. Проверка на винтовете, тоководещи части и проводници
 - 1.4. Проверка на защитата от къси съединения
 - 1.5. Проверка на топлинната устойчивост
 - 1.5.1 Проверка на устойчивостта при повишена топлина и огън
 - 1.6. Изпитване на устойчивост срещу ръжда
 - 1.7. Проверка на диелектричните свойства
 - 1.8. Проверка при повишена температура
 - 1.9. Провеждане на 28-дневни изпитвания
2. Изпитване на механичната и електрическата издръжливост
 - 2.1. Работа при намалени стойности на късо съединение
Проверка на прекъсвача след изпитване на късо съединение
 - 2.2. Изпитване на късо съединение за издръжливост на прекъсвачи използвани в IT системи
 - 2.2.1. Проверка на прекъсвача след изпитване на късо съединение
3. Изпитване на изключващите характеристики
 - 3.1 Устойчивост на механични удари и въздействия
 - 3.2. Работа на късо съединение при 1500 A
 - 3.2.1. Проверка на прекъсвача след изпитване на късо съединение
 - 3.3. Обслужване при късо съединение (I_{cs})
 - 3.3.1. Проверка на прекъсвача след изпитване на късо съединение
 - 3.4. Работа при нормални стойности на късо съединение (I_{cn})
 - 3.4.1. Проверка на прекъсвача след изпитване на късо съединение

II.Списък на проведените изпитвания за миниатюрен автоматичен прекъсвач HDB2.

1. Изпитване за незаличимост на маркировката
2. Изпитване за издръжливост на винтовете, тоководещите части и проводниците
3. Изпитване за издръжливост на крайните външни проводници
4. Изпитване за защита срещу късо съединение
5. Изпитване за диелектрични свойства и изолационни възможности
 - 5.1. Устойчивост на влага
 - 5.2. Изолационно съпротивление на главната верига
 - 5.3. Диелектрична якост на главната верига
 - 5.4. Диелектрична якост на помощните и контролни вериги
 - 5.5. Стойност на изпитваното напрежение
 - 5.6. Проверка импулсно съпротивление
6. Изпитване при повишение на температурата и измерване загубата на мощност



(

(

- 
7. Провеждане на 28-дневно изпитване
 8. Изпитване на изключващи характеристики
 - 8.1. Изпитване на времетокови характеристики
 - 8.2. Изпитване на незабавно изключване и правилно отваряне на контактите
 - 8.3. Изпитване на еднополюсното натоварване на изключващите характеристики
 - 8.4. Изпитване на влиянието на околната температура върху изключващите характеристики
 9. Изпитване на механична и електрическа издръжливост
 10. Изпитване на късо съединение
 11. Механично натоварване
 - 11.1. Механичен удар
 - 11.2. Съпротивление срещу механично натоварване и удари
 12. Изпитване на устойчивост на топлина
 13. Устойчивост на необичайна топлина и пожар
 14. Изпитване на устойчивост срещу ръжда

гр. София
14.07.2015 г.

Ангел Ангелов
/управител/



(

(



Handwritten mark

Certificate



for European Product Safety


Intertek

Reference No. 1209410

Moulded Case Circuit-breakers

Type designation	HDB2	<i>M</i>
Certificate holder	Delixi Electric Ltd. Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province 325604, CHINA	
The product complies with the standard(s)	EN 60947-2:2006 and A1	
Date of expiry	8 February 2017	
EU Directive information	The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.	

ВЕРНО С ОРИГИНАЛА



Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	<i>Bo Berglöf</i> Bo Berglöf	Date	8 February 2012 Page 1 of 3

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

Handwritten signature

Handwritten signature

521



Intertek
Appendix

Reference No. 1209410


Technical data


Type designation/ HDB2
Trade mark / 
Rated Voltage (V) / 240V
Rated Current (A) / 63, 80, 100, 125A
Frequency (Hz) / 50/60Hz
IP-class / 20
Poles No. / 1
Product information / $I_{cs}= 7500A, I_{cu}= 10000A$




Type designation/ HDB2
Trade mark / 
Rated Voltage (V) / 415V
Rated Current (A) / 63, 80, 100, 125A
Frequency (Hz) / 50/60Hz
IP-class / 20
Poles No. / 2
Product information / $I_{cs}= 7500A, I_{cu}= 10000A$

ВЯРНО С ОРИГИНАЛА

Type designation/ HDB2
Trade mark / 
Rated Voltage (V) / 415V
Rated Current (A) / 63, 80, 100, 125A
Frequency (Hz) / 50/60Hz
IP-class / 20
Poles No. / 3
Product information / $I_{cs}= 7500A, I_{cu}= 10000A$



This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Intertek
Appendix

Reference No. 1209410


Type designation/	HDB2
Trade mark /	
Rated Voltage (V) /	415
Rated Current (A) /	63, 80, 100, 125
Frequency (Hz) /	50/60
IP-class /	20
Poles No. /	4
Product information /	$I_{cs} = 7500A, I_{cu} = 10000A$

Manufacturing site(s) Delixi Electric Ltd.
Delixi High Tech Industrial Park,
Liushi Town, Yueqing City,
Zhejiang Province 325604,
CHINA

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.


Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed



Bo Berglöf

Date 8 February 2012

ВЯРНО С ОРИГИНАЛА



This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



(

((

Превод от английски на български език

Интертек
(Лого)

СЕРТИФИКАТ

С
Интертек
(Лого)

за Европейска Безопасност на Продуктите

Референтен № 1209410

Прекъсвачи с лят корпус

(Лого обозначение

HDB2

Притежател на сертификата Деликси Електрик Лтд.
Деликси Индустириален Парк за Високи Технологии
Люши Таун, Ююегинг Сити,
Провинция Джъдзян 325604,
КИТАЙ

Продуктът съответства на EN 60947-2:2006 и A1
стандарт (и)

Валидност до 8 февруари 2017

Информация за ЕС Директива Продуктът отговаря на разпоредбите за маркировката CE,
(съгласно Директива за ниско напрежение 2006/95 / ЕО



Допълнителна информация в Допълнение.

Сертифицираща Орган Интертек Семко АБ, Продуктово Сертифициране Място Киста-Стокхолм

Подписал Подпис /не се чете/
Бо Бергльоф

Дата 8 Февруари 2012
Страница 1 от 3

Този сертификат е издаден в съответствие с правилата и условията, заложиени в Допълнение.



527

Интертек
(Лого)

С
Интертек
(Лого)

Допълнение

Референтен № 1209410

Технически данни

Типово обозначение/	HDB2
Търговска марка /	Химел (Лого)
Номинално напрежение(V) /	240V
Номинален ток (A) /	63, 80, 100, 125A
Честота (Hz) /	50/60Hz
IP-клас /	20
Брой полюси /	1
Продуктова информация /	Ics=7500A, Icu=10000A

Типово обозначение/	HDB2
Търговска марка /	Химел (Лого)
Номинално напрежение(V) /	415V
Номинален ток (A) /	63, 80, 100, 125A
Честота (Hz) /	50/60Hz
IP-клас /	20
Брой полюси /	2
Продуктова информация /	Ics=7500A, Icu=10000A

Типово обозначение/	HDB2
Търговска марка /	Химел (Лого)
Номинално напрежение(V) /	415V
Номинален ток (A) /	63, 80, 100, 125A
Честота (Hz) /	50/60Hz
IP-клас /	20
Брой полюси /	3
Продуктова информация /	Ics=7500A, Icu=10000A

Този сертификат е за изключително ползване от Клиент на Интертек и се предоставя в съответствие с договора за сертифициране между Интертек и неговия Клиент. Отговорността и задълженията на Интертек се ограничават до реда и условията на споразумението. Интертек не поема отговорност за всяка страна, различна от Клиента в съответствие със споразумението, за всяка загуба, разход или вреди, причинени от използването на този сертификат. Само на Клиентът се разрешава да позволи копиране или разпространение на този сертификат и то само в своята цялост. Използването на сертификатна марка Интертек е ограничено до условията, посочени в споразумението. Всяко по-нататъшно използване на името Интертек за продажба или реклама на тествания материал, продукт или услуга, първо трябва да се одобрява писмено от Интертек. Началните фабрични оценки и проследяване на услугите са за целите на осигуряването на подходящо използване на марката за сертифициране в съответствие с настоящото споразумение, те не са за целите на контрола на качеството на продукцията и не освобождават Клиента от задълженията му в това отношение.

Подпис /не се четет/

Страница 2 от 3

C

C

Интертек
(Лого)

С
Интертек
(Лого)

Допълнение

Референтен № 1209410

Технически данни

Типово обозначение /	HDB2
Търговска марка /	Химел (Лого)
Номинално напрежение (V) /	415V
Номинален ток (A) /	63, 80, 100, 125A
Честота (Hz) /	50/60
IP-клас /	20
Брой полюси /	4
Продуктова информация /	Ics=7500A, Icu=10000A

Производствен обект(и) / Деликси Електрик Лтд.
Деликси Индустриален Парк за Високи Технологии
Люши Таун, Июегинг Сити,
Провинция Джъдзян 325604,
КИТАЙ

Този сертификат, който включва контрол на производството, се счита за достатъчна подкрепа за ЕО Декларация за съответствие и СЕ маркировка на продукта в съответствие с Директива за ниско напрежение 73/23 / ЕИО и 93/68 / ЕИО.

()


Сертифициращ Орган Интертек Семко АБ, Продуктово Сертифициране Място Киста-Стокхолм

Подписал

Подпис /не се четел/
Бо Бергльоф

Дата 8 Февруари 2012

Този сертификат е за изключително ползване от Клиент на Интертек и се предоставя в съответствие с договора за сертифициране между Интертек и неговия Клиент. Отговорността и задълженията на Интертек се ограничават до реда и условията на споразумението. Интертек не поема отговорност за всяка страна, различна от Клиента в съответствие със споразумението, за всяка загуба, разход или вреди, причинени от използването на този сертификат. Само на Клиентът се разрешава да позволи копиране или разпространение на този сертификат и то само в своята цялост. Използването на сертификатна марка Интертек е ограничено до условията, посочени в споразумението. Всяко по-нататъшно използване на името Интертек за продажба или реклама на тествания материал, продукт или услуга, първо трябва да се одобрява писмено от Интертек. Началните фабрични оценки и проследяване на услугите са за целите на осигуряването на подходящо използване на марката за сертифициране в съответствие с настоящото споразумение, те не са за целите на контрола на качеството на продукцията и не освобождават Клиента от задълженията му в това отношение.



Страница 3 от 3

531

①

②

WJA



Ref Certif. No

SE-65958

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product
Produit

Moulded case circuit-breakers

Name and address of the applicant
Nom et adresse du demandeur

Delixi Electric Ltd,
Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
Zhejiang Province 325604, CHINA

Name and address of the manufacturer
Nom et adresse du fabricant

Same as above

Name and address of the factory
Nom et adresse de l'usine

Same as applicant

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Ue= 240V~(1-pole), 415V~(2-, 3-, 4-poles)
In= 63, 80, 100, 125A, Icu= 10000A, Ics= 7500A

Trademark (if any)
Marque de fabrique (si elle existe)



Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

Handwritten mark resembling the letter 'A'.

Model / Type Ref.
Ref. De type

HDB2

Additional information (if necessary may also be reported on page 2)
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2^{ème} page)

A sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 60947-2:2006 and A1

As shown in the Test Report Ref. No. which forms part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

SH11090550-001, 002, 003, 004

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00



Signature:


Handwritten signature of Bo Berglöf.

Bo Berglöf

Date: 8 February 2012

Large handwritten signature at the bottom left.

Large handwritten signature at the bottom right.



533

(

(

IEC IECEE
CB
SCHEME
(Лого)

Реф. Сертификат No.
SE-65958

СИСТЕМА ПО СТАНДАРТА IEC ЗА ВЗАИМНО РАЗПОЗНАВАНЕ НА ТЕСТОВИ
СЕРТИФИКАТИ ЗА ЕЛЕКТРООБОРУДВАНЕ (IECEE) CB СХЕМА

CB ТЕСТОВИ СЕРТИФИКАТ

Продукт	Прекъсвачи с лят корпус
Име и адрес на ищеца	Деликси Електрик Лтд. Деликси Индустиален Парк за Високи Технологии Люши Таун, Июегинг Сити, Провинция Джъдзян 325604, КИТАЙ
Име и адрес на производителя	Същите както по-горе
Име и адрес на фабриката Забележка: При повече от една фабрика, моля докладвайте на страница 2	Същите като на ищеца
Оценки и основни характеристики	Ue=240V~(1-полюс), 415V~(2-,3-,4-полюса) In=63, 80, 100, 125A, Icu=10000A, Ics=7500A
Търговска марка (ако има такава)	Химел (Лого)
Вид на използваните от производителя - лаборатории за изпитване	
Модел/Тип Реф.	HDB2
Допълнителна информация (при необходимост може да се отчете също на страница 2)	-
Проба от продукта беше тествана и е установено, че съответства на	IEC 60947-2:2006 и A1
Както е показано в Тестови Доклад Реф. №, който формира част от този Сертификат	SH11090550-001, 002, 003, 004

Този CB Тестови Сертификат е издаден от Националния Сертифициращ Орган


Интертек Семко АБ
Кутия 1103
СЕ-164 22 Киста, Швеция
Вътр. +46 8 750 00 00

Дата: 8 Февруари 2012

Интертек (Лого)

Подпис /не се чете/

Бо Бергльоф



(

(



Test Verification of Conformity

On the basis of the referenced test report(s), the sample(s) of the below product has been found to comply with the relevant harmonized standard(s) to the directive(s) listed on this verification at the time the tests were carried out.

The manufacturer may indicate compliance to only the said directives by signing a DoC himself and may affix the CE marking to products identical to the tested sample(s) if the product complies with all CE marking directives that has the product in their scope. In addition, the manufacturer shall file and keep the documentation according to the rules of the applicable directive(s) and shall consider changes of the standards as they may occur. Additional requirements, additional directives and local laws may be applicable.

Applicant Name & Address : DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
Zhejiang Province, China 325604

Manufacturing site Name & Address : Same as applicant

Product(s) Tested : Moulded case circuit-breakers

Ratings and principal characteristics : $U_o = 240V \sim (1\text{-pole}), 415V \sim (2\text{-}, 3\text{-}, 4\text{-poles})$
 $I_n = 63, 80, 100, 125A$
 $I_{cu} = 10000A, I_{cs} = 7500A$

Model(s) : HDB2


Brand name : 

Relevant Standard(s) / Specification(s) / Directive(s) : EN 60 947-2:2006 +A1:2009
the Low Voltage Directive 2006/95/EC

Verification Issuing Office Name & Address : Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North), Shanghai
200233, China



Verification Number : SH11090550-V1

Report Number(s) : SH11090550-001, 002, 003, 004



NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.




Oliver Wei
Manager
February 15, 2012

597

(

(

Интертек
(Лого)

Интертек Услуги за Изпитване Шанхай
Сграда №86, 1198 Куинжоу Роуд (Север),
Каохейжинг Дивелъпмънт Зоун,
Шанхай 200233, Китай
Тел: 86 21 6127 8200 Факс: 86 21 6495 6263

Тестово Удостоверение за Съответствие

На базата на съотнесените тестови доклад(и), пробата(ите) на долуописания продукт отговарят на съответните хармонизирани стандарт(и) на директивите, описани в това удостоверение по време на проведените изпитвания.

Производителят може да показва съответствие само на посочените директиви чрез собственоръчно подписване на документ и може да нанесе СЕ маркировката на продукти, идентични на изследваните проби, ако продуктът отговаря и попада в обхвата на всички директиви за СЕ маркировка. В допълнение, производителят трябва да подаде и съхранява документацията в съответствие с правилата на приложимата директива и с мисъл за промени в стандартите, тъй като те могат да се появят. Могат да бъдат приложими допълнителни изисквания, допълнителни директиви и местни закони.

Име на ищеца и Адрес : ДЕЛИКСИ ЕЛЕКТРИК ЛТД
Деликси Индустириален Парк за Високи Технологии,
Люши Таун, Июегинг Сити, Провинция Джъдзян, Китай 325604

Производствен обект Име и Адрес : Същите като на ищеца

Тестван(и) продукт(и) : Прекъсвачи с лят корпус

Оценки и основни характеристики: $U_e=240V\sim(1\text{-полюс}), 415V\sim(2\text{-},3\text{-},4\text{-полюса})$
 $I_n=63, 80, 100, 125A,$
 $I_{cu}=10000A, I_{cs}=7500A$

Модел(и) : HDB2

Марка име: Химел (Лого)

Съотносим(и) Стандарт(и) / Спецификация(и) / Директива (и): EN 60 947-2:2006 + A1:2009
Директивата за ниско напрежение 2006/95 / ЕО

Име на офис и Адрес на издаващият Удостоверението: Интертек Услуги за Изпитване Шанхай
Сграда №86, 1198 Куинжоу Роуд (Север),
Каохейжинг Дивелъпмънт Зоун,
Шанхай 200233, Китай

Номер Удостоверение : SH11090550-V1

Доклад Номер(а) : SH11090550-001, 002, 003, 004

ЗАБЕЛЕЖКА 1: Това удостоверение е част от пълният тестови доклад и трябва да бъде четено във връзка с него.

Това удостоверение е за изключително ползване от Клиент на Интертек и се предоставя в съответствие с договора за сертифициране между Интертек и неговия Клиент. Отговорността и задълженията на Интертек се ограничават до реда и условията на споразумението. Интертек не поема отговорност за всяка страна, различна от Клиента в съответствие със споразумението, за всяка загуба, разход или вреди, причинени от използването на този сертификат. Само на Клиентът се разрешава да копира или разпространява това удостоверение и то само в своята цялост. Използването на сертификатна марка Интертек е ограничено до условията, посочени в Удостоверението. Всяко по-нататъшно използване на името Интертек за продажба или реклама на тествания материал, продукт или услуга, първо трябва да се одобрява писмено от Интертек. Наблюденията и резултатите от тестовете от това Удостоверение се отнасят само до тестваната проба. Това Удостоверение само по себе си не заключава, че материалът, продуктът или услугата са или някога са били под Интертек сертифицираща програма.

Знак за съответствие
(Лого)



Подпис /не се чете/
Оливър Вей
Мениджър
15 Февруари 2012

539

ИНСТРУКЦИЯ ЗА ТРАНСПОРТИРАНЕ

1. Продуктите, производство на компанията Деликси Електрик Лтд следва да бъдат транспортирани в оригиналните опаковки на производителя, небрежното опаковане може да доведе до повреда по време на транспортирането.

2. Стоката се транспортира с обикновен сухопътен транспорт на европалета и трябва да бъде правилно позиционирана и добре укрепена в транспортното средство.



3. Върху стоката да не се товарят други стоки.

Транспортната компания, осъществяваща транспорта на стоките, следва да има грижата на добър стопанин до предаване на продуктите до крайната точка на транспортиране.

Забележка: Пренасяйте прекъсвачите внимателно. Не изпускайте или хвърляйте прекъсвачите. Това може да доведе до повреди.

гр. София
14.07.2015 г.

Ангел Ангелов




541

(

(

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	test impulse voltage (see table 12 part 1)		
	test impulse voltage for isolating (see table 14 part 1)		
M.8.4.1.2	Verification of rated impulse withstand voltage with respect to the monitored circuit		
M.8.4.1.2.1	Test for terminal type MRCD		N/A
M.8.4.1.2.2	Tests for MRCDs of through-conductor type		N/A
M.8.4.1.3	Verification of rated impulse withstand voltage of the voltage source circuit (if applicable)		N/A
M.8.5	Verification of the operation of the test device at the limits of the rated voltage		
	For MRCDs having an adjustable time-delay the test is made at the maximum setting of time-delay:	_____ s	
M.8.5.a	Setting I Δ n or minimum setting of I Δ n	_____ A	
	Test voltage (1,1 x U _e max)	_____ V	
	Number of operations	25	
	Interval time	5 s	
	Tripping	<input type="checkbox"/> Yes / <input type="checkbox"/> No	N/A
M.8.5.b	Setting I Δ n or minimum setting of I Δ n	_____ A	
	Test voltage (0,85 x U _e max)	_____ V	
	Number of operations	3	
	Interval time	5 s	
	Tripping	<input type="checkbox"/> Yes / <input type="checkbox"/> No	N/A
M.8.5.c	Setting I Δ n or minimum setting of I Δ n	_____ A	
	Test voltage (1,1 x U _e max)	_____ V	
	Number of operations	1	
	Operating means of the test device held in close position	5 s	
	Tripping	<input type="checkbox"/> Yes / <input type="checkbox"/> No	N/A
M.8.6	Verification of the limiting value of non-operating current under overcurrent conditions , in case of a single phase load.		
M.8.6	Circuit diagram	Fig. M4 _____	
	Setting I Δ n or minimum setting of I Δ n if adjustable	_____ A	


TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current equal to the lower value of: <input type="checkbox"/> 6 x I _n or <input type="checkbox"/> 80 % of the maximum short-circuit release current setting	_____ A	
	Test voltage: <input type="checkbox"/> rated voltage or <input type="checkbox"/> any convenient voltage	_____ V	
	Test frequency	_____ Hz	
	Power factor (0,5)	_____	
	Current flow time	2 s	
	Interval time	60 s	
	Calibration plot number	_____	
	No tripping / change of state		N/A
M.8.7	Resistance against unwanted tripping due to surge currents resulting from impulse voltages		
M.8.7.2	Verification of the resistance to unwanted tripping in case of loading of the network capacitance		N/A
B.8.6.1	Current surge test for RMCDs (0,5 μs / 100kHz ring wave test)		
	One pole of the MRCD is submitted to 10 applications of a surge current according to the following requirements:		
	- peak value: 200 A + 10/0%		
	- virtual front time: 0,5 μs ± 30%		
	- period of the following oscillatory wave: 10 μs ± 20%		
	- each successive peak: about 60% of the preceding peak		
	The polarity shall be inverted after every two applications		
	The interval between two consecutive applications shall be about 30 s		
	During the test the MRCD shall not trip:	-	N/A
M.8.7.3	Verification of the resistance to unwanted tripping in case of flashover without follow-on current.		
B.8.6.2	Verification of behaviour at surge current up to 250 A (8/20 μs surge current test)		N/A

TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	One pole of the MRCD is submitted to 10 applications of a surge current according to the following requirements:		
	- peak value: 250 A + 10/0%		
	- virtual front time: 8 μ s \pm 20%		
	- virtual time to half value: 20 μ s \pm 20%		
	- peak of reverse current:: less than 30% of peak value		
	The polarity shall be inverted after every two applications		
	The interval between two consecutive applications shall be about 30 s		
	During the test the MRCD shall not trip:		N/A
M.8.8	Verification of the behaviour in case of an earth fault current comprising a d.c. component.		
M.8.8.2	Type A MRCD		
	For MRCDs the operation of which depends on a voltage source the test are made at 1,1 and 0,85 times the rated voltage of the voltage source (Us).		
M.8.8.2.2	Verification of operation in case of a continuous rise of a residual pulsating direct current		
	Rated voltage		
B.8.7.2.1	- steady increase from zero to: 1,4 I Δ n for I Δ n > 0,015 A with 1,4 I Δ n/30 A/s (mA)		
	- steady increase from zero to: 2 I Δ n for I Δ n \leq 0,015 A with 2 I Δ n/30 A/s (mA)	_____ mA	
	- angle = 0 (+/-) :		
	- angle = 90 (+/-) :		
	- angle = 135 (+/-) :		
	No value exceeds the relevant specified limiting values		N/A
M.8.8.2.3	Verification of operation in case of a suddenly appearing residual pulsating direct current		
B.8.7.2.2	Verification of the correct operation in case of suddenly appearing residual pulsating direct currents by closing S2 (angle = 0°)		
	Rated voltage	_____ V	
	RCCB's with I Δ n > 0,015 A:		


TRF No. IEC60947-2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	- maximum break time (ms) at: 1,4 I Δ n (+/-) :		
	- maximum break time (ms) at: 2,8 I Δ n (+/-) :		
	- maximum break time (ms) at: 7 I Δ n (+/-) :		
	- maximum break time (ms) at: 14 I Δ n (+/-) :		
	No value exceeds the relevant specified limiting value		N/A
	RCCB's with I Δ n \leq 0,015 A:		N/A
	- maximum break time (ms) at: 2 I Δ n (+/-) :		
	- maximum break time (ms) at: 4 I Δ n (+/-) :		
	- maximum break time (ms) at: 10I Δ n (+/-) :		
	- maximum break time (ms) at: 20 I Δ n (+/-) :		
	No value exceeds the relevant specified limiting value		N/A
M.8.8.2.4	Verification of operation with load at reference temperature		
	Rated voltage	_____ V	
B.8.7.2.1	- steady increase from zero to: 1,4 I Δ n for I Δ n > 0,015 A with 1,4 I Δ n/30 A/s (mA)	_____ mA	
	- steady increase from zero to: 2 I Δ n for I Δ n \leq 0,015 A with 2 I Δ n/30 A/s (mA)	_____ mA	
	- angle = 0 (+/-) :		
	- angle = 90 (+/-) :		
	- angle = 135 (+/-) :		
	No value exceeds the relevant specified limiting values		N/A
M.8.8.2.5	Verification of operation of a residual pulsating direct current superimposed by a smooth direct current of 6 mA.		
	Rated voltage	_____ V	
B.8.7.2.1	- steady increase from zero to: 1,4 I Δ n for I Δ n > 0,015 A with 1,4 I Δ n/30 A/s (mA) + 6 mA	_____ mA	
	- steady increase from zero to: 2 I Δ n for I Δ n \leq 0,015 A with 2 I Δ n/30 A/s (mA) + 6 mA	_____ mA	
	- angle = 0 (+/-) :		
	No value exceeds the relevant specified limiting values		N/A
M.8.8.3	Type B MRCD		


TRF No. IEC60947_2F



ВЯРНО С СРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
M.8.8.3.2	Verification of operation in case of a slowly rising residual smooth direct current		
	Rated voltage ($1,1 \cdot U_n$)	_____ V	
B.8.7.2.1	- steady increase from zero to: $2 I_{\Delta n}$ A with $1,4 I_{\Delta n}/30$ A/s (mA)	_____ mA	
	- angle = $90 (+/-)$:		
	Operation shall occur between 0,5 and $2I_{\Delta n}$		N/A
	Rated voltage ($0,85 \cdot U_n$)	_____ V	
B.8.7.2.1	- steady increase from zero to: $2 I_{\Delta n}$ A with $1,4 I_{\Delta n}/30$ A/s (mA)		
	- angle = $90 (+/-)$:		
	Operation shall occur between 0,5 and $2I_{\Delta n}$		N/A
M.8.8.3.3	Verification of operation in case of a suddenly appearing residual smooth direct current		
B.8.7.2.2	Verification of the correct operation in case of suddenly appearing a smooth residual direct currents by closing S2		
	Rated voltage ($1,1 \cdot U_n$)	_____ V	
	RCCB's with $I_{\Delta n} > 0,015$ A:		
	- maximum break time (ms) at: $2 I_{\Delta n} (+/-)$:		
	- maximum break time (ms) at: $4 I_{\Delta n} (+/-)$:		
	- maximum break time (ms) at: $10 I_{\Delta n} (+/-)$:		
	- maximum break time (ms) at: $20 I_{\Delta n} (+/-)$:		
	No value exceeds the relevant specified limiting value		N/A
B.8.7.2.2	Verification of the correct operation in case of suddenly appearing a smooth residual direct currents by closing S2		
	Rated voltage ($0,85 \cdot U_n$)	_____ V	
	RCCB's with $I_{\Delta n} > 0,015$ A:		
	- maximum break time (ms) at: $2 I_{\Delta n} (+/-)$:		
	- maximum break time (ms) at: $4 I_{\Delta n} (+/-)$:		
	- maximum break time (ms) at: $10 I_{\Delta n} (+/-)$:		
	- maximum break time (ms) at: $20 I_{\Delta n} (+/-)$:		
	No value exceeds the relevant specified limiting value		N/A


TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
M.8.8.3.4	Verification of operation in case of a slowly rising residual current resulting from a fault in a circuit fed by a three-pulse star or a six-pulse connection.		
	Rated voltage (1,1*Un)	_____ V	
B.8.7.2.1	- steady increase from zero to: 2 IΔn A with 1,4 IΔn/30 A/s (mA)	_____ mA	
	- angle = 90 (+/-) :		
	Operation shall occur between 0,5 and 2IΔn		N/A
	Rated voltage (0,85*Un)	_____ V	
B.8.7.2.1	- steady increase from zero to: 2 IΔn A with 1,4 IΔn/30 A/s (mA)	_____ mA	
	- angle = 90 (+/-) :		
	Operation shall occur between 0,5 and 2IΔn		N/A
M.8.8.3.5.	Verification of operation in case of a slowly rising residual current resulting from a fault in a circuit fed by two-pulse bridge connection line-to-line.		
	Rated voltage (Un)	_____ V	
B.8.7.2.1	- steady increase from zero to: 2 IΔn A with 1,4 IΔn/30 A/s (mA)	_____ mA	
	- angle = 0 (+/-) :		
	Operation shall occur between 0,5 and 1,4IΔn		N/A
M.8.8.3.6	Verification of operation with load at the reference temperature		
M.8.8.3.6- M.8.8.3.2	Verification of operation in case of a slowly rising residual smooth direct current		
	Rated voltage (1,1*Un)	_____ V	
B.8.7.2.1	- steady increase from zero to: 2 IΔn A with 1,4 IΔn/30 A/s (mA)	_____ mA	
	- angle = 90 (+/-) :		
	Operation shall occur between 0,5 and 2IΔn		N/A
	Rated voltage (0,85*Un)	_____ V	
B.8.7.2.1	- steady increase from zero to: 2 IΔn A with 1,4 IΔn/30 A/s (mA)	_____ mA	
	- angle = 90 (+/-) :		
	Operation shall occur between 0,5 and 2IΔn		N/A
M.8.8.3.6- M.8.8.3.4	Verification of operation in case of a slowly rising residual current resulting from a fault in a circuit fed by a three-pulse star or a six-pulse connection		
	Rated voltage (1,1*Un)	_____ V	


TRF No. IEC60947_2F



ВЯРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
B.8.7.2.1	- steady increase from zero to: 2 I Δ n A with 1,4 I Δ n/30 A/s (mA)	_____ mA	
	- angle = 90 (+/-) :		
	Operation shall occur between 0,5 and 2I Δ n		N/A
	Rated voltage (0,85*Un)	_____ V	
B.8.7.2.1	- steady increase from zero to: 2 I Δ n A with 1,4 I Δ n/30 A/s (mA)	_____ mA	
	- angle = 90 (+/-) :		
	Operation shall occur between 0,5 and 2I Δ n		N/A
M.8.8.3.6- M.8.8.3.5.	Verification of operation in case of a slowly rising residual current resulting from a fault in a circuit fed by two-pulse bridge connection line-to-line.		
	Rated voltage (Un)	_____ V	
B.8.7.2.1	- steady increase from zero to: 2 I Δ n A with 1,4 I Δ n/30 A/s (mA)	_____ mA	
	- angle = 0 (+/-) :		
	Operation shall occur between 0,5 and 1,4I Δ n		N/A
M.8.9.	Verification of the behaviour of MRCDs with separate sensing means in case of a failure of the sensing means connection		
M.8.9.2	Test method 1		
	Rated voltage of the sensing means		
	Interval time Required <5 sec		N/A
M.8.9.3	Test method 2		
	Test shall be carried out as follows: - The test device is activated - The sensing means are disconnected and the test device is activated. The MRCD shall not operate		
	Rated voltage of the sensing means		
	Test device activated MRCD shall operate		N/A
	Rated voltage of the sensing means		
	Sensing device disconnected and Test device activated MRCD shall not operate		N/A
M.8.10	Verification of temperature-rise of terminal type MRCDs		
M.8.10.2	Tambient: _____ °C		


TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.2.5	Main circuits		
	Conventional thermal current I_{th}	_____ A	
	Conventional thermal current for enclosure I_{the}	_____ A	
	Conventional thermal current for the neutral pole	_____ A	
	Cabling characteristics		
	Cable	_____ mm ²	
	Bar / number / length	_____ mm / ___ / _____ m	
	Arrangement	<input type="checkbox"/> 3 phase - <input type="checkbox"/> poles on serie	
	Tightening torque	_____ Nm	
	Neutral pole (if applicable)		
	Cable	_____ mm ²	
	Bar / number / length	_____ mm / ___ / _____ m	
	Tightening torque	_____ Nm	
	Terminals(see table 2)		
	Manual operating means		
	Parts which need not be touched but not hand held		
	Parts which need not be touched during normal operation		
M.8.11	Verification of mechanical and electrical endurance		
	For MRCDs having more than one output rating, two tests shall be made: – a test at the highest rated current at the corresponding voltage; – a test at the highest rated voltage at the corresponding current.		
	500 off-load operations controlled by the test device		
	Rated voltage:	_____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Result:	after _____ operations,	N/A
	500 off load operations by passing the rated residual operating current $I_{\Delta n}$ through one current path		
	Rated voltage:	_____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Rated residual current	_____ mA	
	Result:	after _____ operations,	N/A
	500 on-load operations controlled by the test device		


TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Rated voltage:	_____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Test current	_____ A	
	Power factor	_____	
	Test circuit		
	Result:	after _____ operations,	N/A
	500 on-load operations by passing the rated residual operating current $I_{\Delta n}$ through one current path.		
	Rated voltage:	_____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Test current	_____ A	
	Power factor	_____	
	Test circuit		
	Rated residual current	_____ mA	
	Result:	after _____ operations,	N/A
	Show no damage		N/A
	High voltage test: twice rated voltage	Test voltage: _____ V	N/A
	A residual current is sudden appear on the MRCD of $I_{\Delta n}$ (_____ mA) Required : no value exceeds the specified limiting value of Table B1 (300 ms) or Table B2 (500 ms) and a non actuating time of 60 ms		N/A
M.8.12.	Verification of the behaviour of MRCDs in case of failure of the voltage source for MRCDs classified under M.3.2.2.1		
M.8.12.2	Determination of the limiting value of the voltage source		
	Source voltage (Us)	Max Us: _____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
		Min Us: _____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Adjustable residual current setting	_____ mA (lowest)	
	Adjustable time-delay setting	_____ s	
	Time period of voltage decreasing	30 s or a period enough with respect to delayed opening	
	Min voltage to automatic opening ($U > 0,85 \times U_s$)		

TRF No. IEC60947_2F




ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	A residual current is sudden appear on the MRCD of $I_{\Delta n}$ (____ mA) at a value just above highest measured value Required : no value exceeds the specified limiting value of Table B1: 300 ms		N/A
	It's not possible to switch "ON" by manual operating means at a lower value than the lower measured value.		N/A
M.8.12.3	Verification of automatic opening in case of voltage source failure		
	Source voltage (Us)	Max Us: ____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
		Min Us: ____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Adjustable residual current setting	____ mA (lowest)	
	Adjustable time-delay setting	____ s	
	Time period	Max 1 s or max. 1 s+time delay setting	
	Time period to automatic opening		
	No value exceeds the relevant specified limiting value		N/A

M.8.13	Verification of the behaviour of MRCDs with voltage source as classified under M.3.2.2.2 in case of failure of the voltage source.		
	Source voltage (Us)	Max Us: ____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
		Min Us: ____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Adjustable residual current setting	____ mA (lowest)	
	Adjustable time-delay setting	____ s	
	Switch off and reclosed Sa or S1 and reduced the source voltage to 70 %	70% Us = ____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	N/A
	Time period to automatic opening		N/A
MII	Test sequence MII		
M.8.14	Verification of the behaviour of the MRCD under short-circuit conditions		
	Type designation or serial number		
	Sample no:		


TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
M.8.14.3	Verification of the rated conditional short-circuit current (I_{cc})		
	Verification of the coordination between the MRCD and the SCPD		
	Test circuit according to figure:		
	Point of test circuit which is directly earthed:		
	Grid distance "a" (mm):		
	Silver wire diameter (mm):		
	Used SCPD during the tests		
	Prospective current (A):		
	Prospective current obtained (A):		
	Power factor / ratio n :		
	Power factor / ratio n obtained:		
	Plot no.	CM	
	Test sequence: O-t-O		
	I^2t (kA ² s); I_p (kA):	First O: I_p : _____ kA I^2t : _____ kA ² s Plot no. _____	
		Second O: I_p : _____ kA I^2t : _____ kA ² s Plot no.: _____	
	If tested at separate testing station see report	No.: _____ of _____ testing station	
	During tests no endangering of operator, no permanent arcing, no flashover and no melting of fuse F		N/A
	After the tests no damage impairing further use		N/A
8.3.3.5	Dielectric strength test of the main circuit at test voltage of $2 U_n$ for 1 min:		
	Test voltage		N/A
B.8.10.3.2	The RCCB shall trip with a test current of $1,25 I_{\Delta n}$ (ms) in minimum setting:	I test: _____ mA trip time: _____ ms	N/A
M.8.12.3	Verification of automatic opening in case of voltage source failure		

TRF No. IEC60947_2F




ВЕРНО С ОРИГИНАЛА

329

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Source voltage (Us)	Max Us: _____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
		Min Us: _____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Adjustable residual current setting	_____ mA (lowest)	
	Adjustable time-delay setting	_____ s	
	Time period	Max 1 s or max. 1 s+time delay setting	
	Time period to automatic opening		N/A
	No value exceeds the relevant specified limiting value		N/A
	The polyethylene sheet shows no holes		N/A
M.8.14.4	Verification of rated short-time withstand current (I_{ow})		
	Test circuit according to figure:		
	Point of test circuit which is directly earthed:		
	Grid distance "a" (mm):		
	Prospective current (A):		
	Prospective current obtained (A):		
	Power factor / ratio n :		
	Power factor / ratio n obtained:		
	Plot no.		
	Test sequence: O		
	I^2t (kA ² s); I_p (kA):	I_p : _____ kA I^2t : _____ kA ² s Test duration: _____ ms Plot no. _____	
	If tested at separate testing station see report	No.: _____ of _____ testing station	
	During tests no endangering of operator, no permanent arcing, no flashover and no melting of fuse F		N/A
	After the tests no damage impairing further use		N/A
8.3.3.5	Dielectric strength test of the main/circuit at test voltage of $2 U_n$ for 1 min:		


TRF No. IEC60947_2F



ВЕРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Test voltage	-	N/A
B.8.10.3.2	The RCCB shall trip with a test current of 1,25 I _{Δn} (ms) in minimum setting:	I test: _____ mA trip time: _____ ms	N/A
M.8.12.3	Verification of automatic opening in case of voltage source failure		
	Source voltage (Us)	Max Us: _____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
		Min Us: _____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Adjustable residual current setting	_____ mA (lowest)	
	Adjustable time-delay setting	_____ s	
	Time period	Max 1 s or max. 1 s+time delay setting	
	Time period to automatic opening		N/A
	No value exceeds the relevant specified limiting value		N/A
	The polyethylene sheet shows no holes		N/A
M.8.14.5	Verification of the rated conditional residual short-circuit current (I _{Δc})		
	Test circuit according to figure:		
	Point of test circuit which is directly earthed:		
	Grid distance "a" (mm):		
	Silver wire diameter (mm):		
	Used SCPD during the tests		
	Prospective current (A):		
	Prospective current obtained (A):		
	Power factor / ratio n:		
	Power factor / ratio n obtained:		
	Plot no.		
	Test sequence: O-t-O		


TRF No. IEC60947_2F



ВЯРНО С ОРИГИНАЛА

IEC 60947-2			
Clause	Requirement + Test	Result - Remark	Verdict
	I^2t (kA ² s); I_p (kA):	First O: I_p : _____ kA I^2t ; _____ kA ² s Plot no. _____	
		Second O: I_p : _____ kA I^2t ; _____ kA ² s Plot no.: _____	
	If tested at separate testing station see report	No.: _____ of _____ testing station	
	During tests no endangering of operator, no permanent arcing, no flashover and no melting of fuse F		N/A
	After the tests no damage impairing further use		N/A
8.3.3.5	Dielectric strength test of the main circuit at test voltage of $2 U_n$ for 1 min:		
	Test voltage	-	N/A
B.8.10.3.2	The RCCB shall trip with a test current of $1,25 I_{\Delta n}$ (ms) in minimum setting:	I test: _____ mA trip time: _____ ms	N/A
M.8.12.3	Verification of automatic opening in case of voltage source failure		
	Source voltage (Us)	Max Us: _____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
		Min Us: _____ V <input type="checkbox"/> ac <input type="checkbox"/> dc	
	Adjustable residual current setting	_____ mA (lowest)	
	Adjustable time-delay setting	_____ s	
	Time period	Max 1 s or max. 1 s+time delay setting	
	Time period to automatic opening		N/A
	No value exceeds the relevant specified limiting value		N/A
	The polyethylene sheet shows no holes		N/A
M.8.14.6	Verification of rated residual short-time withstand current ($I_{\Delta w}$)		
	Test circuit according to figure		

TRF No. IEC60947_2F



ВЯРНО С ОРИГИНАЛА