

**PRODUCT** : Preinsulated junction sleeves.

Test report	: Electrical ageing
Report number	: 9309060
Product brand	: SICAME
Product type	: MJPB 25 CG
Project n°	: E 0900330
Batch number	: 08-93

Demandeur of the test : SICAME DER  
Starting date of the test : 08/09/1993  
Report emission date : 19 SEP. 2000  
According to standard : HN 33-E-61 (August 1985)  
This report contains : 7 Pages Annexe(s)

Conclusion : The SICAME preinsulated junction sleeves type MJPB 25 CG conform to the HN 33-E-61 standard (August 1985).

This is an English translation.  
The original French test report is the only reference version.

На основании чл. 2  
от 33ЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

SICAME DER	EQUIPEMENT USED DURING ELECTRICAL AGEING TEST STANDARD : HN 33-E-61	SUP ER 1130 INDEX B
---------------	---	------------------------

Test number : 9309060  
Product brand : SICAME  
Product type : MJPB 25 CG

A - Computer

IBM PS2 N'UT : 88 93 06 Hard disc 112 MEGABYTES  
Analogical / digital card  
Digital / Analogical card  
RS232 card on OS2

IBM 4029 020 N'UT : 92 03 30 laser printer

B - Electrical ageing machines

N'4 N'UT : 85 01 26

Transformer 1200A/7V or 1200A/10V thyristor  
units used for the primary transformers. Thermal  
regulation by eurotherm.

Program planner cycles : 1 second.  
Minimum accuracy : 1 min programming. Stabilised  
continuous current source - SAEME - 0 to 30 Amps  
measured by shunt 3.3 Megohms. Current adaptor  
except n' 3

C - Electrical and thermal measurements machines

Scanner N'1 N'UT : 91 03 31

Temperature scanners multi-channel.  
Constant copper thermocouples  
(type T). Scale used : - 200 to + 300° C,  
1° C accuracy.

Numeric calibrator N'UT : 88 05 14 AOIP JN 5303B (tension drop)

Buzzer SICAME N'UT : 92 04 20

D - Other materials


Digital caliper N' UT : 92 00 91 DIGIROCH

Electronic torque wrench N'UT : 92 03 31 POWELL DUFFRYN  
Accuracy 1%

Calibrated ruler N'UT : 93 00 83 ROCH

На основании чл. 2  
от 33ЛД

T



SICAME	ELECTRIC AGEING TEST ACCORDING TO HN 33E61		SUPER 620
DER	STANDARD ON SICAME	CONNECTORS TYPE	INDICE C
		MJPB25CG	

TEST : 9309060

DATE : 08/09/93

A - PROCEDURE

Installation of testing bench

The testing bench is arranged in the interior in one local protected from air, in such a way that the ageing test takes place in a calm atmosphere.

The following minimal distances are observed :

- between 2 parallel conductors : 20 cm;
- between any conductor and any vertical wall of the local : 30 cm;
- between the horizontal plane of the connectors on one hand and the horizontal surfaces of the local on the other hand : 60 cm.

B - SETTING OF THE TEST

The loop of the test is formed by four identical groups composed of one conductor of section S1, one connector, one conductor of section S2.

S1: 25mm<sup>2</sup>Alu  
S2: 25mm<sup>2</sup>Alu

S1: Diam. over cent. Cable: 6.18 mm      Diam. over sheath : 8.92 mm  
Nb of strands : 7

S2: Diam. over cent. cable: 6.18 mm      Diam. over sheath : 8.92 mm  
Nb of strands : 7

The crimping die is E140 (5 mm).  
Test according to HN 33E61      standard.

C - REFERENCE LENGTH CALCULUS

The loop of the test includes a reference conductor of L' length of the center cable S2 : 25mm<sup>2</sup>Alu .

L1 = 182      mm      L2 = 182      mm      h = 50      mm

Theoretical reference length      L' = 414      mm

Potential plugs

Each connector is mounted between two potential plugs, which are welded, and are necessary to the measures of resistance. The potential plugs are placed at a lambda distance, reckoned up to the ends of the connector.

Main lambda = 150      mm      Tap lambda = 150      mm

St      На основании чл. 2  
от 33ЛД

ВЯРНО С ОПИРАНАТА



ELECTRIC AGEING TEST				TEST NUMBER: 9309060		
CONNECTOR SICAME TYPE MJPB25CG				STANDARD: HN 33E61		
NUMBER OF CONNECTORS TESTED : 4				MAIN CABLE SECTION : 25mm <sup>2</sup> Alu		
CONNECTOR 1				TAP CABLE SECTION : 25mm <sup>2</sup> Alu		
				NUMBER OF CYCLES REQUIRED: 200		
N° CYCLE	T AMB (°C)	T REF (°C)	T RAC (°C)	R0 E-6 Ohm	R E-6 Ohm	K
0	20.7	119.8	67.9	487.504	368.000	0.755
25	20.7	120.6	70.4	487.428	371.900	0.763
50	20.8	120.2	67.4	487.515	372.300	0.764
75	21.0	119.6	66.4	487.364	372.500	0.764
100	20.6	121.7	71.1	486.940	372.700	0.765
125	21.8	120.6	68.1	487.312	372.700	0.765
150	20.9	120.4	70.9	487.414	372.500	0.764
175	20.9	120.8	74.9	487.119	372.900	0.766
200	20.8	120.7	69.1	486.533	373.700	0.768

TEST RESULTS :

- K; VALUE LESS THAN 1
- CONNECTOR TEMPERATURE LOWER THAN TEMPERATURE OF REFERENCE CABLE
- $DK = K(200) - K(25) = 0.0051$  LESS THEN 0.05

LEGEND :

- T AMB °C ---> AMBIENT TEMPERATURE IN °C
- T REF °C ---> REFERENCE CABLE TEMPERATURE IN °C
- T RAC °C ---> CONNECTOR TEMPERATURE DURING HEATING CYCLE IN °C
- R0 E-6 OHM ---> RESISTANCE OF REFERENCE CABLE AT 20°C (MILLI-OHM)
- R E-6 OHM ---> RESISTANCE OF CONNECTOR AT 20°C (MILLI-OHM)
- K ---> COEFFICIENT OF R/R0

SUP ER 360  
INDEX A

На основание чл. 2  
от ЗЗЛД

ВАРНО С ОПИТИНАТА



2011

ELECTRIC AGEING TEST				TEST NUMBER: 9309060		
SICAME CONNECTOR TYPE NJPB25CG				STANDARD HN 33E61		
NUMBER OF CONNECTOR TESTED: 4				MAIN CABLE SECTION : 25mm <sup>2</sup> Alu		
CONNECTOR 2				TAP CABLE SECTION : 25mm <sup>2</sup> Alu		
				NUMBER OF CYCLES REQUIRED: 200		
N CYCLE	T AMB (°C)	T REF (°C)	T RAC (°C)	R0 E-6 Ohm	R E-6 Ohm	K
0	20.7	119.8	65.7	487.504	366.700	0.752
25	20.7	120.6	71.2	487.428	371.200	0.762
50	20.8	120.2	70.3	487.515	371.800	0.763
75	21.0	119.6	68.1	487.364	372.100	0.764
100	20.6	121.7	71.2	486.940	372.300	0.765
125	21.8	120.6	70.7	487.312	372.500	0.764
150	20.9	120.4	72.5	487.414	372.400	0.764
175	20.9	120.8	73.3	487.119	372.300	0.764
200	20.8	120.7	72.1	486.533	373.100	0.767

## TEST RESULTS :

- K; VALUE LESS THAN 1
- CONNECTOR TEMPERATURE LOWER THAN TEMPERATURE OF REFERENCE CABLE
- $DK = K(200) - K(25) = 0.0054$  LESS THAN 0.05

## LEGEND :

- T AMB °C ---> AMBIENT TEMPERATURE °C
- T REF °C ---> REFERENCE CABLE TEMPERATURE °C
- T RAC °C ---> CONNECTOR TEMPERATURE DURING HEATING CYCLE IN °C
- R0 E-6 OHM ---> RESISTANCE OF REFERENCE CABLE AT 20°C (MILLI-OHM)
- R E-6 OHM ---> RESISTANCE OF CONNECTOR AT 20°C (MILLI-OHM)
- K ---> COEFFICIENT OF R/R0

SUP ER 370  
INDEX B

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОПИТИНАТА

ООД  
КОВ

<b>ELECTRIC AGEING TEST</b>				<b>TEST NUMBER : 9309060</b>		
<b>SICAME CONNECTOR TYPE NJPB25CG</b>				<b>STANDARD : HN 33E61</b>		
<b>NUMBER OF CONNECTORS TESTED : 4</b>				<b>MAIN CABLE SECTION : 25mm<sup>2</sup>Alu</b>		
<b>CONNECTOR 3</b>				<b>TAP CABLE SECTION : 25mm<sup>2</sup>Alu</b>		
				<b>NUMBER OF CYCLES REQUIRED:200</b>		
<b>N° CYCLR</b>	<b>T AMB (°C)</b>	<b>T REF (°C)</b>	<b>T RAC (°C)</b>	<b>R0 E-6 Ohm</b>	<b>R E-6 Ohm</b>	<b>K</b>
0	20.7	119.8	59.4	487.504	370.900	0.761
25	20.7	120.6	60.8	487.428	373.900	0.767
50	20.8	120.2	60.2	487.515	373.800	0.767
75	21.0	119.6	60.1	487.364	374.300	0.768
100	20.6	121.7	63.3	486.940	374.900	0.770
125	21.8	120.6	61.3	487.312	375.400	0.770
150	20.9	120.4	63.1	487.414	375.400	0.770
175	20.9	120.8	63.5	487.119	375.600	0.771
200	20.8	120.7	61.8	486.533	375.800	0.772

**TEST RESULTS :**

- K; VALUE LESS THAN 1
- CONNECTOR TEMPERATURE LOWER THAN TEMPERATURE OF REFERENCE CABLE
- $DK = K(200) - K(25) = 0.0053$  LESS THAN 0.05


**LEGEND :**

- T AMB °C → AMBIENT TEMPERATURE °C
- T REF °C → REFERENCE CABLE TEMPERATURE °C
- T RAC °C → CONNECTOR TEMPERATURE DURING HEATING CYCLE IN °C
- R0 E-6 OHM → RESISTANCE OF REFERENCE CABLE AT 20°C (MILLY-OHM)
- R E-6 OHM → RESISTANCE OF CONNECTOR AT 20°C (MILLY-OHM)
- K → COEFFICIENT OF R/R0

SUP ER 380  
INDEX A

На основание чл. 2  
от ЗЗЛД

ВЪРНО С СЕРТИФИКАТА



ELECTRIC AGEING TEST				TEST NUMBER : 9309060		
SICAME CONNECTOR TYPE MJPB25CG				STANDARD : HN 33E61		
NUMBER OF CONNECTORS TESTED : 4				MAIN CABLE SECTION : 25mm <sup>2</sup> Alu		
CONNECTOR 4				TAP CABLE SECTION : 25mm <sup>2</sup> Alu		
				NUMBER OF CYCLES REQUIRED:200		
N <sup>o</sup> CYCLE	T AMB (°C)	T REF (°C)	T RAC (°C)	R0 E-6 Ohm	R E-6 Ohm	K
0	20.7	119.8	57.6	487.504	369.800	0.759
25	20.7	120.6	59.6	487.428	372.600	0.764
50	20.8	120.2	59.9	487.515	373.700	0.767
75	21.0	119.6	53.4	487.364	374.000	0.767
100	20.6	121.7	59.2	486.940	374.300	0.769
125	21.8	120.6	58.8	487.312	374.600	0.769
150	20.9	120.4	60.8	487.414	373.800	0.767
175	20.9	120.8	61.3	487.119	374.300	0.768
200	20.8	120.7	59.4	486.533	375.500	0.772

## TEST RESULTS :

- K; VALUE LESS THAN 1
- CONNECTOR TEMPERATURE LOWER THAN TEMPERATURE OF REFERENCE CABLE
- DK = K(200) - K(25) = 0.0074 LESS THAN 0.05

## LEGEND :

- T AMB °C ---> AMBIENT TEMPERATURE °C
- T REF °C ---> REFERENCE CABLE TEMPERATURE °C
- T RAC °C ---> CONNECTOR TEMPERATURE DURING HEATING CYCLE IN °C
- R0 E-6 OHM ---> RESISTANCE OF REFERENCE CABLE AT 20°C (MILLI-OHM)
- R E-6 OHM ---> RESISTANCE OF CONNECTOR AT 20°C (MILLI-OHM)
- K ---> COEFFICIENT OF R/R0

SUP ER 390  
INDEX A

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПРИТНАТА




СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРВ 25


1. № на тест 9309060 - Тест за стареене под въздействие на електричеството.

Съставил

На основание чл. 2  
от ЗЗЛД



ВЪЗНЕСЕ С ОРМИНАЛА







**sicame**

Laboratoire d'essais

Direction Etudes et Recherches

PRODUCT: Preinsulated junction sleeves

Test report	: Dielectric
Report number	: 9304220
Product brand	: SICAME
Product type	: MJPB 16-4
Project n°	: E 0900324
Batch number	: 2-92

Demandeur of the test: DER SICAME

Starting date of the test : 21/09/1993

Report emission date : 06 SEP. 2000

According to standard : NF C 33-021 (January 1993)

This report contains : 3 Pages 0 Annex(es)



Conclusion

: The SICAME preinsulated junction sleeves type MJPB 16-4 conform to the NF C 33-021 standard of January 1993 sub-clause 2.4.1.

This is an english translation. The original french test report is the only reference version.

На основании чл. 2  
от ЗЗЛД


This document cannot be reproduced even partially without the authorization of SICAME-SA.



309

SICAME DER	DIELECTRIC TEST EQUIPMENT ACCORDING TO STANDARD: NF C 33-021	SUP ER 1460 INDICE B
---------------	---	-------------------------

Test number : 9304220  
 Product brand : SICAME  
 Product type : MJPB 16-4



A - Computer equipment

IBM PS2 (Inv N': 89 90 84) Hard disk 60 MB  
 Analog/Digital interface card  
 Digital/Analog interface card  
 RS232 on OS2

IBM 4029 020 (Inv N': 92 03 30) Laser printer

B - Equipment for Dielectric test

Dielectric test equipment (Inv N': 91 02 69) Bouchet 10 kV - 100 mA  
 3 settable thresholds  
 (10 mA, 100 mA delay)

C - General Equipment

Digital caliper (Inv N': 92 00 91)

Calibrated Ruler (Inv N': 93 00 83)

Stopwatch (Inv N': 92 02 82)

ROCH


HANHART

Electro-hydraulic compression tool ED50 (5 tons) N'UT: 91 01 29

Die E140 nominal width 5 mm




ВЯРНО С ОРИГИНАЛАТА



На основание чл. 2  
от ЗЗЛД

SICAME DER	DIELECTRIC TEST ACCORDING TO STANDARD: NF C 33-021	SUP ER 740 INDICE B
---------------	---	------------------------

Test number : 9304220 Date: 21/09/1993 Ambient Temperature : 23.5°C  
 Manufacturer : SICAME Humidity : 42 %  
 Product : MJPB 16-4

#### A- Test Procedure

Two samples of the batch are crimped on appropriate cable and put in water.

The assembly is placed in a water tank, the water level is 30 cm above the uppermost part of the connector.  
 After the assembly has been immersed for 30 minutes, the assembly is subjected to the dielectric test. The potential difference applied between the water and the conductor being 6 kV - 50 Hz, for the duration of 1 minute.


The potential difference is applied at a rate of 1 kV/s.  
 The maximum leakage current for the interruption (triggering of circuit breaker) of the HT supply is 10 mA.

#### B- Results

CONNECTOR N°	Cable sizes used (mm <sup>2</sup> )		OBSERVATIONS
1	16 Alu / 4 Cu		
2	16 Alu / 4 Cu		
N° CONNECTOR	6kV/1mn After 30 min in water	Trigginging value with I=10mA (KV)	
1	OK	> 10	
2	OK	> 10	

Generals observations:

ВЪРНО С ОПРИГНАЛАТА




На основание чл. 2  
от ЗЗЛД




# sicame

Laboratoire d'essais  
Direction Etudes et Recherches



Test report	: Endurance test under mechanical and thermal stresses
Test number	: 00 11 311 indice 1
Product brand	: SICAME
Product type	: MJPB 16-4




Demander of the test	: DER
Starting date of the test	: 06/11/2000
Report emission date	: 26 FEV. 2003
According to standard	: NF C 33-021 § 2.9 (june 98)
This report contains	: 5 page et 0 annex
Conclusion	: The preinsulated junction sleeves type MJPB 16-4 conform to the requirements of NF C 33-021 § 2.9 (june 98) standard.

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

ВЯРНО С ОРИГИНАЛАТА



**1. Equipment used during test.**

**1.1 Equipment used :**



N° U.T.	Designation	Characteristic
93 05 48	Crimping machine	50 kN
94 03 10	Traction bench 3 tons	Class 1
95 00 87	Electrical ageing machine n°9	/
92 04 55	Scanner	Accuracy $\pm 2^{\circ}\text{C}$
91 02 69	Dielectrimeter Bouchet	Accuracy 0,5 mA and 200V
92 02 82	Stop watch	Accuracy 1s
99 00 41	Conductimeter	Accuracy $30\mu\text{S}/\text{cm}$
95 01 75	Calibrated ruler	Accuracy $\pm 1\text{ mm}$

**1.2 Cables :**

Sections	16/4
Nature	Aluminium
From	Malaisia
Identification n°	9901
Conditioned on	01/07/1999 (1h00 at $120^{\circ}\text{C}$ )

**2. Product tested.**

Désignation : MJPB 16-4  
 Number : 4  
 Project number : E 0900324  
 Identification : 1, 2, 3 and 4  
 Reception date at the laboratory : on the 06/11/2000



На основание чл. 2  
от ЗЗЛД

### 3. Test.

Preinsulated junction sleeves are tested according to NF C 33-021 § 2.9 (june 98) standard.

#### 3.1 Test procedure.

The test is carried out on 4 joint sleeves.

The free length of core between two adjacent joint sleeves is  $(1,0 \pm 0,1)$  m and the free length of core between the anchoring and the extremity joint sleeves is at least 1 m.

The test consists in performing heat cycles combined with the mechanical stresses on the conductors connected by a joint sleeve. These mechanical stresses are applied on the stripped cores extremity by an appropriate anchoring equipment. The number of cycles is 500.

Thermocouples are placed to the central conductive part of the two joint sleeves located at both ends of the test assembly.

The reference temperature is measured in the middle of a stripped of  $(1,0 \pm 0,1)$  m located at the outer side of the anchoring equipments, not less than 1 m from any supporting or connecting components.

Thermal cycles of a duration of 90 min are applied to the test assembly.

For the first 45 minutes of the cycle, the temperature rise is created by current flowing. The reference temperature of the conductor is maintained at  $(90 \pm 3)^{\circ}\text{C}$ . This temperature is reached within 5 min to 15 min at the beginning of the cycle.

For the last 45 min, the test assembly is naturally cooled down to  $(25 \pm 3)^{\circ}\text{C}$ . The temperature is then maintained at this value until the end of the cycle.



Once in 24 h, at the end of the  $90^{\circ}\text{C}$  heating period, the two temperatures reached by the two joint sleeves are recorded.

An increasing tensile strength is applied for about 1 min up to a value equal to 60 % of the minimum strength indicated in the standard.

This strength is then maintained for 10 min using a manual or automatic continuous control. The assembly is left to self stabilize mechanically for 24 h without any control.

After stabilization, thermal cycles are applied. At the end of the first cycle, the tensile strength is set at 33 % of the minimum strength indicated in the standard.

Then, at least once in 24 h, tensile strength is adjusted at 33 % of the minimum strength indicated in the standard.



На основание чл. 2  
от ЗЗЛД

3.2 Preparation

A 9 mm wide dies for groove E140 is used.

4. Requirements and results.

- Cycles :

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 25°C Between 25 % et 75 % HR	22°C 39 %HR
Rate of the tensile (N/min)	720 in 1 min	720
Strength value maintained for 10 min (N)	720	720
After 24 h, the strength is set at 33 % of the minimum strength (N)	400	400
Thermal stress	45 min at 90°C	45 min at 90°C
Number of cycles	500	500

- Temperature measurements :

Date	Cycle	Reference temperature (°C)	Connector 2 temperature (°C)	Connect. temperature (°C)
06/11/2000	1	90,1	48,1	51,0
07/11/2000	14	90,1	48,2	51,3
08/11/2000	28	90,2	48,3	51,6
09/11/2000	42	89,9	47,9	51,8
10/11/2000	56	89,8	47,9	51,9
13/11/2000	100	90,0	48,3	51,8
14/11/2000	114	90,3	48,2	51,3
15/11/2000	128	90,2	48,5	51,7
16/11/2000	142	89,7	49,0	51,6
17/11/2000	156	89,9	49,3	51,2
20/11/2000	200	90,5	49,6	51,4
21/11/2000	214	90,2	49,5	51,0
22/11/2000	228	90,1	49,2	51,3
23/11/2000	242	90,4	49,4	51,6
24/11/2000	256	90,1	49,3	51,7
27/11/2000	300	89,7	49,6	51,9
28/11/2000	314	90,1	49,8	52,4
29/11/2000	328	90,4	49,5	52,1
30/11/2000	342	89,9	49,0	51,6
01/12/2000	356	90,0	49,5	51,9
04/12/2000	400	90,3	49,5	52,0

ВЯРНО С ОРИГИНАЛА



На основание чл. 2 от ЗЗЛД

31

Date	Cycle	Reference temperature (°C)	Connector 2 temperature (°C)	Connector 4 temperature (°C)
05/12/2000	414	90,4	49,5	51,3
06/12/2000	428	89,6	49,6	51,8
07/12/2000	442	89,9	49,7	51,7
08/12/2000	456	90,5	49,3	51,4
11/12/2000	500	90,3	49,6	51,6

↳ Connectors temperatures are always lower than reference temperature.


• Mechanical and flashover tests :

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	21°C 41 % HR
Water resistivity	< 200 Ωm	78,7 Ωm
6 kV during 1 min in metallic balls	No flashover	Connector n°1 : No flashover Connector n°3 : No flashover
1 kV during 1 min in water after 30 min in water	No flashover	Connector n°1 : No flashover Connector n°3 : No flashover
Rate of the tensile (N/min)	Between 1000 et 5000	Connector n°1 : 3000 Connector n°2 : 3000 Connector n°3 : 3000 Connector n°4 : 3000
Strength value maintained for 1 min (N)	600	Connector n°1 : 600 Connector n°2 : 600 Connector n°3 : 600 Connector n°4 : 600
Strength value applied without breakdown (N)	1200	Connector n°1 : 1200 Connector n°2 : 1200 Connector n°3 : 1200 Connector n°4 : 1200

↳ No flashover and no slippage are observed.

5. Conclusion

Tested connectors conform to the requirements of NF C 33-021 § 2.9 (june 98) standard.



На основание чл. 2  
от ЗЗЛД




**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРВ 16-4**

1. № на тест 9304220 - Диелектричен тест;
2. № на тест 0011311 - Тест за издръжливост под механичен и топлинен натиск.

Съставил:

На основание чл. 2  
от ЗЗЛД





# sicame

Laboratoire d'essais  
Direction Etudes et Recherches

PRODUCT: Preinsulated junction sleeves

Test report	: Dielectric
Report number	: 9309320
Product brand	: SICAME
Product type	: MJPB 16-6
Project n°	: E 0900324
Batch number	: 2-92

Demander of the test: DER SICAME

Starting date of the test : 21/09/1993

Report emission date : 06 SEP. 2000

According to standard : NF C 33-021 (January 1993)


This report contains : 3 Pages 0 Annex(es)

Conclusion : The SICAME preinsulated junction sleeves type MJPB 16-6 conform to the NF C 33-021 standard of January 1993 sub-clause 2.4.1.

This is an english translation. The original french test report is the only reference version.

На основании чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



8/18

SICAME DER	DIELECTRIC TEST EQUIPMENT ACCORDING TO STANDARD: NF C 33-021	SUP ER 1160 INDICE B
---------------	---	-------------------------

Test number : 9309320  
Product brand : SICAME  
Product type : MJPB 16-6

A - Computer equipment

IBM PS2 (Inv N': 89 90 84) Hard disk 60 MB  
Analog/Digital interface card  
Digital/Analog interface card  
RS232 on OS2

IBM 4029 020 (Inv N': 92 03 30) Laser printer

B - Equipment for Dielectric test

Dielectric test equipment (Inv N': 91 02 69) Bouchet 10 kV - 100 mA  
3 settable thresholds  
(10 mA, 100 mA delay)


C - General Equipment

Digital caliper (Inv N': 92 00 91)  
Calibrated Ruler (Inv N': 93 00 83)  
Stopwatch (Inv N': 92 02 82)  
Electro-hydraulic compression tool ED50 (5 tons) N'UT: 91 01 29  
Die E140 nominal width 5 mm

ROCH

HANHART

ВЯРНО С ОПРИГНАЛАТА



На основание чл. 2  
от ЗЗЛД

SICAME DER	DIELECTRIC TEST ACCORDING TO STANDARD: NF C 33-021	SUP ER 720 INDICE B
---------------	---	------------------------

Test number : 9309320 Date: 21/09/1993 Ambient Temperature : 23.5°C  
 Manufacturer : SICAME Humidity : 42 %  
 Product : MJPB 16-6

A- Test Procedure

Two samples of the batch are crimped on appropriate cable and put in water.

The assembly is placed in a water tank, the water level is 30 cm above the uppermost part of the connector. After the assembly has been immersed for 30 minutes, the assembly is subjected to the dielectric test. The potential difference applied between the water and the conductor being 6 kV - 50 Hz, for the duration of 1 minute.

The potential difference is applied at a rate of 1 kV/s. The maximum leakage current for the interruption (triggering of circuit breaker) of the HT supply is 10 mA.

B- Results

CONNECTOR N°	Cable sizes used (mm <sup>2</sup> )		OBSERVATIONS
1	16 Alu / 6 Cu		
2	16 Alu / 6 Cu		
N° CONNECTOR	6kV/1mn After 30 min in water	Triggening value with I=10mA (KV)	OBSERVATIONS
1	OK	> 10	
2	OK	> 10	

Generals observations:

ВЯРНО С ОРИГИНАЛА



На основание чл. 2  
от ЗЗЛД



# sicame

Laboratoire d'essais  
Direction Etudes et Recherches

Test report	: Endurance test under mechanical and thermal stresses
Test number	: 00 11 370 indice 1
Product brand	: SICAME
Product type	: MJPB 16-6


Demandeur of the test	: DER
Starting date of the test	: 06/11/2000
Report emission date	: 26 FEV, 2003
According to standard	: NF C 33-021 § 2.9 (june 98)
This report contains	: 5 page et 0 annex
Conclusion	: The preinsulated junction sleeves type MJPB 16-6 conform to the requirements of NF C 33-021 § 2.9 (june 98) standard.

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

ВЪРНО С ОРИГИНАЛАТА



**1. Equipment used during test.**

**1.1 Equipment used :**



N° U.T.	Designation	Characteristic
93 05 48	Crimping machine	50 kN
94 03 10	Traction bench 3 tons	Class 1
95 00 87	Electrical ageing machine n°9	/
92 04 55	Scanner	Accuracy $\pm 2^{\circ}\text{C}$
91 02 69	Dielectrimer Bouchet	Accuracy 0,5 mA and 200V
92 02 82	Stop watch	Accuracy 1s
99 00 41	Conductimeter	Accuracy $30\mu\text{S/cm}$
95 01 75	Calibrated ruler	Accuracy $\pm 1\text{ mm}$

**1.2 Cables :**

Sections	16/6
Nature	Aluminium
From	Malaisia
Identification n°	9901
Conditioned on	01/07/1999 (1h00 at $120^{\circ}\text{C}$ )

**2. Product tested.**

Désignation : MJPB 16-6  
 Number : 4  
 Project number : E 0900324  
 Identification : 1, 2, 3 and 4  
 Reception date at the laboratory : on the 06/11/2000



### 3. Test.

Preinsulated junction sleeves are tested according to NF C 33-021 § 2.9 (june 98) standard.

#### 3.1 Test procedure.

The test is carried out on 4 joint sleeves.

The free length of core between two adjacent joint sleeves is  $(1,0 \pm 0,1)$  m and the free length of core between the anchoring and the extremity joint sleeves is at least 1 m.

The test consists in performing heat cycles combined with the mechanical stresses on the conductors connected by a joint sleeve. These mechanical stresses are applied on the stripped cores extremity by an appropriate anchoring equipment. The number of cycles is 500.

Thermocouples are placed to the central conductive part of the two joint sleeves located at both ends of the test assembly.

The reference temperature is measured in the middle of a stripped of  $(1,0 \pm 0,1)$  m located at the outer side of the anchoring equipments, not less than 1 m from any supporting or connecting components.

Thermal cycles of a duration of 90 min are applied to the test assembly.

For the first 45 minutes of the cycle, the temperature rise is created by current flowing. The reference temperature of the conductor is maintained at  $(90 \pm 3)^{\circ}\text{C}$ . This temperature is reached within 5 min to 15 min at the beginning of the cycle.

For the last 45 min, the test assembly is naturally cooled down to  $(25 \pm 3)^{\circ}\text{C}$ . The temperature is then maintained at this value until the end of the cycle.


Once in 24 h, at the end of the  $90^{\circ}\text{C}$  heating period, the two temperatures reached by the two joint sleeves are recorded.

An increasing tensile strength is applied for about 1 min up to a value equal to 60 % of the minimum strength indicated in the standard.

This strength is then maintained for 10 min using a manual or automatic continuous control. The assembly is left to self stabilize mechanically for 24 h without any control.

After stabilization, thermal cycles are applied. At the end of the first cycle, the tensile strength is set at 33 % of the minimum strength indicated in the standard.

Then, at least once in 24 h, tensile strength is adjusted at 33 % of the minimum strength indicated in the standard.



На основание чл. 2  
от ЗЗЛД

**3.2 Preparation**

A 9 mm wide dies for groove E140 is used.

**4. Requirements and results.**

- Cycles :

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 25°C Between 25 % et 75 % HR	22°C 39 %HR
Rate of the tensile (N/min)	720 in 1 min	720
Strength value maintained for 10 min (N)	720	720
After 24 h, the strength is set at 33 % of the minimum strength (N)	400	400
Thermal stress	45 min at 90°C	45 min at 90°C
Number of cycles	500	500

- Temperature measurements :

Date	Cycle	Reference temperature (°C)	Connector 2 temperature (°C)	Connect. temperature (°C)
06/11/2000	1	90,1	48,1	51,0
07/11/2000	14	90,1	48,2	51,3
08/11/2000	28	90,2	48,3	51,6
09/11/2000	42	89,9	47,9	51,8
10/11/2000	56	89,8	47,9	51,9
13/11/2000	100	90,0	48,3	51,8
14/11/2000	114	90,3	48,2	51,3
15/11/2000	128	90,2	48,5	51,7
16/11/2000	142	89,7	49,0	51,6
17/11/2000	156	89,9	49,3	51,2
20/11/2000	200	90,5	49,6	51,4
21/11/2000	214	90,2	49,5	51,0
22/11/2000	228	90,1	49,2	51,3
23/11/2000	242	90,4	49,4	51,6
24/11/2000	256	90,1	49,3	51,7
27/11/2000	300	89,7	49,6	51,9
28/11/2000	314	90,1	49,8	52,4
29/11/2000	328	90,4	49,5	52,1
30/11/2000	342	89,9	49,0	51,6
01/12/2000	356	90,0	49,5	51,9
04/12/2000	400	90,3	49,5	52,0

**ВЪРНО С ОБЪЕКТАТА**

На основание чл. 2 от ЗЗЛД



Date	Cycle	Reference temperature (°C)	Connector 2 temperature (°C)	Connector 4 temperature (°C)
05/12/2000	414	90,4	49,5	51,3
06/12/2000	428	89,6	49,6	51,8
07/12/2000	442	89,9	49,7	51,7
08/12/2000	456	90,5	49,3	51,4
11/12/2000	500	90,3	49,6	51,6

↳ Connectors temperatures are always lower than reference temperature.


• Mechanical and flashover tests :

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	21°C 41 % HR
Water resistivity	< 200 Ωm	78,7 Ωm
6 kV during 1 min in metallic balls	No flashover	Connector n°1 : No flashover Connector n°3 : No flashover
1 kV during 1 min in water after 30 min in water	No flashover	Connector n°1 : No flashover Connector n°3 : No flashover
Rate of the tensile (N/min)	Between 1000 et 5000	Connector n°1 : 3000 Connector n°2 : 3000 Connector n°3 : 3000 Connector n°4 : 3000
Strength value maintained for 1 min (N)	600	Connector n°1 : 600 Connector n°2 : 600 Connector n°3 : 600 Connector n°4 : 600
Strength value applied without breakdown (N)	1200	Connector n°1 : 1200 Connector n°2 : 1200 Connector n°3 : 1200 Connector n°4 : 1200

↳ No flashover and no slippage are observed.

5. Conclusion

Tested connectors conform to the requirements of NF C 33-021 § 2.9 (june 98) standard.



На основании чл. 2  
от 33ЛД

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРВ 16-6**

1. № на тест 9309320 - Диелектричен тест – тест;
2. № на тест 0011370 - Тест за издръжливост под механичен и топлинен натиск.

На основание чл. 2  
от ЗЗЛД

Съставил:





**sicame**

Laboratoire d'essais

Direction Etudes et Recherches

PRODUCT: Preinsulated junction sleeves

Test report	: Dielectric
Report number	: 9101320
Product brand	: SICAME
Product type	: MJPB 16-10
Project n°	: E 0900324
Batch number	: 2-92

Demander of the test: DER SICAME

Starting date of the test : 21/09/1993

Report emission date : 06 SEP. 2000

According to standard : NF C 33-021 (January 1993)


This report contains : 3 Pages 0 Annex(es)

Conclusion : The SICAME preinsulated junction sleeves type MJPB 16-10 conform to the NF C 33-021 standard of January 1993 sub-clause 2.4.1.

This is an english translation. The original french test report is the only reference version.

На основании чл. 2 от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



SICAME DER	DIELECTRIC TEST EQUIPMENT ACCORDING TO STANDARD: NF C 33-021	SUP ER 1200 INDICE B
---------------	---	-------------------------

Test number : 9101320  
Product brand : SICAME  
Product type : MJPB 16-10

A - Computer equipment

IBM PS2 (Inv N': 89 90 84) Hard disk 60 MB  
Analog/Digital interface card  
Digital/Analog interface card  
RS232 on OS2

IBM 4029 020 (Inv N': 92 03 30) Laser printer

B - Equipment for Dielectric test

Dielectric test equipment (Inv N': 91 02 69) Bouchet 10 kV - 100 mA  
3 settable thresholds  
(10 mA, 100 mA delay)

C - General Equipment

Digital caliper (Inv N': 92 00 91)

Calibrated Ruler (Inv N': 93 00 83)

ROCH

Stopwatch (Inv N': 92 02 82)

HANHART

Electro-hydraulic compression tool ED50 (5 tons) N'UT: 91 01 29

Die E140 nominal width 5 mm

ВЯРНО С ОРИГИНАЛАТА

"ВАК-02" ООД  
Superv  
САМОКОВ

На основание чл. 2  
от ЗЗЛД

SICAME	DIELECTRIC TEST ACCORDING TO STANDARD: NF C 33-021	SUP ER 720
DER		INDICE B

Test number : 9101320 Date: 21/09/1993 Ambient Temperature : 23.5 °C  
 Manufacturer : SICAME Humidity : 42 %  
 Product : MJPB 16-10

#### A- Test Procedure

Two samples of the batch are crimped on appropriate cable and put in water.

The assembly is placed in a water tank, the water level is 30 cm above the uppermost part of the connector.  
 After the assembly has been immersed for 30 minutes, the assembly is subjected to the dielectric test. The potential difference applied between the water and the conductor being 6 kV - 50 Hz, for the duration of 1 minute.


The potential difference is applied at a rate of 1 kV/s.  
 The maximum leakage current for the interruption (triggering of circuit breaker) of the HT supply is 10 mA.

#### B- Results

CONNECTOR N°	Cable sizes used (mm <sup>2</sup> )		OBSERVATIONS
1	16 Alu / 10 Cu		
2	16 Alu / 10 Cu		
N° CONNECTOR	6kV/1mm After 30 min in water	Trigging value with I=10mA (KV)	
1	OK	> 10	
2	OK	> 10	

Generals observations:

ВЯРЖО С ОРНИНАТА



На основание чл. 2  
от ЗЗЛД



# sicame

Laboratoire d'essais  
Direction Etudes et Recherches



Test report	: Endurance test under mechanical and thermal stresses
Test number	: 00 11 100 indice 1
Product brand	: SICAME
Product type	: MJPB 16-10

Demander of the test	: DER
Starting date of the test	: 06/11/2000
Report emission date	: 26 FEV. 2003
According to standard	: NF C 33-021 § 2.9 (june 98)
This report contains	: 5 page et 0 annex
Conclusion	: The preinsulated junction sleeves type MJPB 16-10 conform to the requirements of NF C 33-021 § 2.9 (june 98) standard.

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



# 1. Equipment used during test.

## 1.1 Equipment used :


N° U.T.	Designation	Characteristic
93 05 48	Crimping machine	50 kN
94 03 10	Traction bench 3 tons	Class 1
95 00 87	Electrical ageing machine n°9	/
92 04 55	Scanner	Accuracy $\pm 2^{\circ}\text{C}$
91 02 69	Dielectrimeter Bouchet	Accuracy 0,5 mA and 200V
92 02 82	Stop watch	Accuracy 1s
99 00 41	Conductimeter	Accuracy 30 $\mu\text{S}/\text{cm}$
95 01 75	Calibrated ruler	Accuracy $\pm 1$ mm

## 1.2 Cables :

Sections	16/10
Nature	Aluminium
From	Malaisia
Identification n°	9901
Conditioned on	01/07/1999 (1h00 at 120°C)

## 2. Product tested.

Désignation : MJPB 16-10  
 Number : 4  
 Project number : E 0900324  
 Identification : 1, 2, 3 and 4  
 Reception date at the laboratory : on the 06/11/2000



На основание чл. 2  
от ЗЗЛД

### 3. Test.

Preinsulated junction sleeves are tested according to NF C 33-021 § 2.9 (june 98) standard.

#### 3.1 Test procedure.

The test is carried out on 4 joint sleeves.

The free length of core between two adjacent joint sleeves is  $(1,0 \pm 0,1)$  m and the free length of core between the anchoring and the extremity joint sleeves is at least 1 m.

The test consists in performing heat cycles combined with the mechanical stresses on the conductors connected by a joint sleeve. These mechanical stresses are applied on the stripped cores extremity by an appropriate anchoring equipment. The number of cycles is 500.

Thermocouples are placed to the central conductive part of the two joint sleeves located at both ends of the test assembly.

The reference temperature is measured in the middle of a stripped of  $(1,0 \pm 0,1)$  m located at the outer side of the anchoring equipments, not less than 1 m from any supporting or connecting components.

Thermal cycles of a duration of 90 min are applied to the test assembly.

For the first 45 minutes of the cycle, the temperature rise is created by current flowing. The reference temperature of the conductor is maintained at  $(90 \pm 3)^{\circ}\text{C}$ . This temperature is reached within 5 min to 15 min at the beginning of the cycle.

For the last 45 min, the test assembly is naturally cooled down to  $(25 \pm 3)^{\circ}\text{C}$ . The temperature is then maintained at this value until the end of the cycle.


Once in 24 h, at the end of the  $90^{\circ}\text{C}$  heating period, the two temperatures reached by the two joint sleeves are recorded.

An increasing tensile strength is applied for about 1 min up to a value equal to 60 % of the minimum strength indicated in the standard.

This strength is then maintained for 10 min using a manual or automatic continuous control. The assembly is left to self stabilize mechanically for 24 h without any control.

After stabilization, thermal cycles are applied. At the end of the first cycle, the tensile strength is set at 33 % of the minimum strength indicated in the standard.

Then, at least once in 24 h, tensile strength is adjusted at 33 % of the minimum strength indicated in the standard.



На основание чл. 2  
от ЗЗЛД



**3.2 Preparation**

A 9 mm wide dies for groove E140 is used.

**4. Requirements and results.**


- Cycles :

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 25°C Between 25 % et 75 % HR	22°C 39 %HR
Rate of the tensile (N/min)	720 in 1 min	720
Strength value maintained for 10 min (N)	720	720
After 24 h, the strength is set at 33 % of the minimum strength (N)	400	400
Thermal stress	45 min at 90°C	45 min at 90°C
Number of cycles	500	500

- Temperature measurements :

Date	Cycle	Reference temperature (°C)	Connector 2 temperature (°C)	Connecto. temperature (°C)
06/11/2000	1	90,1	48,1	51,0
07/11/2000	14	90,1	48,2	51,3
08/11/2000	28	90,2	48,3	51,6
09/11/2000	42	89,9	47,9	51,8
10/11/2000	56	89,8	47,9	51,9
13/11/2000	100	90,0	48,3	51,8
14/11/2000	114	90,3	48,2	51,3
15/11/2000	128	90,2	48,5	51,7
16/11/2000	142	89,7	49,0	51,6
17/11/2000	156	89,9	49,3	51,2
20/11/2000	200	90,5	49,6	51,4
21/11/2000	214	90,2	49,5	51,0
22/11/2000	228	90,1	49,2	51,3
23/11/2000	242	90,4	49,4	51,6
24/11/2000	256	90,1	49,3	51,7
27/11/2000	300	89,7	49,6	51,9
28/11/2000	314	90,1	49,8	52,4
29/11/2000	328	90,4	49,5	52,1
30/11/2000	342	89,9	49,0	51,6
01/12/2000	356	90,0	49,5	51,9
04/12/2000	400	90,3	49,5	52,0

ВАРНО С ОРИГИНАЛАТА



На основание чл. 2  
от ЗЗЛД

Date	Cycle	Reference temperature (°C)	Connector 2 temperature (°C)	Connector 4 temperature (°C)
05/12/2000	414	90,4	49,5	51,3
06/12/2000	428	89,6	49,6	51,8
07/12/2000	442	89,9	49,7	51,7
08/12/2000	456	90,5	49,3	51,4
11/12/2000	500	90,3	49,6	51,6

↳ Connectors temperatures are always lower than reference temperature.


• Mechanical and flashover tests :

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	21°C 41 % HR
Water resistivity	< 200 Ωm	78,7 Ωm
6 kV during 1 min in metallic balls	No flashover	Connector n°1 : No flashover Connector n°3 : No flashover
1 kV during 1 min in water after 30 min in water	No flashover	Connector n°1 : No flashover Connector n°3 : No flashover
Rate of the tensile (N/min)	Between 1000 et 5000	Connector n°1 : 3000 Connector n°2 : 3000 Connector n°3 : 3000 Connector n°4 : 3000
Strength value maintained for 1 min (N)	600	Connector n°1 : 600 Connector n°2 : 600 Connector n°3 : 600 Connector n°4 : 600
Strength value applied without breakdown (N)	1200	Connector n°1 : 1200 Connector n°2 : 1200 Connector n°3 : 1200 Connector n°4 : 1200

↳ No flashover and no slippage are observed.

## 5. Conclusion


Tested connectors conform to the the requirements of NF C 33-021 § 2.9 (june 98) standard.



На основание чл. 2  
от ЗЗЛД


**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРВ 16-10**

1. № на тест 9101320 - Диелектричен тест;
2. № на тест 0011100 - Тест за издръжливост под механичен и топлинен натиск.



На основание чл. 2  
от ЗЗЛД

Съставил:





Laboratoire d'essais  
 Direction études et recherches

TEST REPORT : Dielectric test.

PRODUCT: Preinsulated junction sleeves.

Report number	: 2501424
Product brand	: SICAME
Product type	: MJPB 10
Project n°	: E 0900332
Batch number	: 98M708380

*[Handwritten signature]*

*[Handwritten signature]*



*[Handwritten signature]*

Demandeur of the test: SICAME D.E.R.  
 Starting date of the test : 28/01/1999  
 Report emission date : 28/01/1999  
 According to standard : NF C 33-021 (june 1998)  
 This report contains : 3 Pages Annexe(s)

Conclusion : The SICAME preinsulated junction sleeves type MJPB 10 conforms of standard NF C 33-021 (june 1998) | 2.4.

На основании чл. 2  
 от 33ЛД

This document cannot be reproduced even partially without the authorisation of SICAME SA.



SICAME	DIELECTRIC TEST EQUIPMENT	SUP ER 1160
DER	ACCORDING TO SPECIFICATION: NF C 33-021	INDICE B

Test number : 2501424  
 Product brand : SICAME  
 Product type : NJPB 10

A - Computer equipment

IBM PS2 (Inv N°: 88 93 06) Hard disk 115 MB  
 Analog/Digital interface card  
 Digital/Analog interface card  
 Disk Operating System: DOS 6.1 IBM  
 IBM 4029 020 (Inv N°: 92 03 30) Laser printer

B - Equipment for Dielectric test

Dielectric unit (Inv N°: 91 02 69).


C - General Equipment

crimping machine (Inv N°: 93 05 48)  
 Calibrated Ruler (Inv N°: 95 01 75)  
 Stopwatch (Inv N°: 92 02 82)

ROCH  
 HANHART

На основание чл. 2  
 от ЗЗЛД

ВЯРНО С ОРИГИНАЛАТА



SICAME . DER	DIELECTRIC TEST ACCORDING TO SPECIFICATION: NF C 33-021	SUP ER 720 INDICE B
-----------------	--	------------------------

Test number : 2501424 Date: 28/01/1999 Ambient Temperature : 22.9°C  
 Manufacturer : SICAME Humidity : 37 %  
 Product : MJPB 10

A- Test Procedure

Two samples of the batch are crimped on appropriate cable and put in water.

The assembly is placed in a container of water, the water level must be 30 cm above the uppermost part of the connector. After the assembly has been immersed for 30 minutes, the assembly is subject to the dielectric test. The potential difference applied between the water and the conductor being 6 kV - 50 Hz, for the duration of 1 minute.

The potential difference is applied at a rate of 1 kV/s. The maximum leakage current for the interruption (triggering of circuit breaker) of the HT supply is 10 mA.


B- Results

CONNECTOR N°	Cable sizes used (mm²)		OBSERVATIONS
1	10 Cu / 10 Cu		
2	10 Cu / 10 Cu		
N° CONNECTOR	6kV/1mn After 30 min in water	Tripping value with I=10mA (KV)	OBSERVATIONS
1	OK	> 10	
2	OK	> 10	


Generals observations:

На основание чл. 2  
от ЗЗЛД

ВАРНО С ОБЩИНАТА




**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРВ 10.**



1. № на тест: 2501424 - Диелектричен тест.



На основание чл. 2  
от ЗЗЛД

Съставил:



6

6





Laboratoire d'essais  
 Direction études et recherches

TEST REPORT : Dielectric test.

PRODUCT: Preinsulated junction sleeves.

Report number	: 2501222
Product brand	: SICAME
Product type	: MJPB 25-6
Project n°	: E 0900332
Batch number	: 98M708380

*[Handwritten signature]*

*[Handwritten signature]*



*[Handwritten signature]*

Demander of the test: SICAME D.E.R.  
 Starting date of the test : 28/01/1999  
 Report emission date : 28/01/1999  
 According to standard : NF C 33-021 (june 1998)  
 This report contains : 3 pages Annexe(s)

Conclusion : The SICAME preinsulated junction sleeves type MJPB 25-6 conforms of standard NF C 33-021 (june 1998) ] 2.4.

На основании чл. 2  
 от 33ЛД

This document cannot be reproduced even partially without the authorisation of SICAME SA.





SICAME	DIELECTRIC TEST EQUIPMENT	SUP ER / 1160
DER	ACCORDING TO SPECIFICATION: NF C 33-021	INDICE B

Test number : 2501222  
Product brand : SICAME  
Product type : MJPB 25-6

A - Computer equipment

IBM PS2 (Inv N°: 88 93 06) Hard disk 115 MB  
Analog/Digital interface card  
Digital/Analog interface card  
Disk Operating System: DOS 5.1 IBM

IBM 4029 020 (Inv N°: 92 03 30) Laser printer

B - Equipment for Dielectric test

Dielectric unit (Inv N°: 91 02 69).

C - General Equipment

crimping machine (Inv N°: 93 05 48)

Calibrated Ruler (Inv N°: 95 01 75)

Stopwatch (Inv N°: 92 02 82)

ROCH  
HANHART

На основании чл. 2  
от ЗЗЛД

ВЯРНО С ОРМІНАЦІЯ



SICAME DER	DIELECTRIC TEST ACCORDING TO SPECIFICATION: NF C 33-021	SUP ER 720 INDICE B
---------------	--	------------------------

Test number : 2501222 Date: 28/01/1999 Ambient Temperature : 22.9 °C  
 Manufacturer : SICAME Humidity : 37 %  
 Product : MJPH 25-6

#### A- Test Procedure

Two samples of the batch are crimped on appropriate cable and put in water.

The assembly is placed in a container of water, the water level must be 30 cm above the uppermost part of the connector. After the assembly has been immersed for 30 minutes, the assembly is subject to the dielectric test. The potential difference applied between the water and the conductor being 6 kV - 50 Hz, for the duration of 1 minute.

The potential difference is applied at a rate of 1 kV/s. The maximum leakage current for the interruption (triggering of circuit breaker) of the HT supply is 10 mA.


#### B- Results

CONNECTOR N°	Cable sizes used (mm <sup>2</sup> )		OBSERVATIONS
1	25 Alu / 6 Cu		
2	25 Alu / 6 Cu		
N° CONNECTOR	6kV/1mn After 30 min in water	Tripping value with I=10mA (KV)	
1	OK	> 10	
2	OK	> 10	


#### Generals observations:

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛАТА




СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МРВ 25-6



1. № на тест: 2501422 - Диелектричен тест.

На основание чл. 2  
от ЗЗЛД

Съставил:



TEST REPORT : Dielectric test.

PRODUCT: Preinsulated junction sleeves.

Report number	: 2501425
Product brand	: SICAME
Product type	: MJPB 25-10
Project n°	: E 0900332
Batch number	: 98M708380

Demandeur of the test: SICAME D.E.R.  
Starting date of the test : 28/01/1999  
Report emission date : 28/01/1999  
According to standard : NF C 33-021 (june 1998)  
This report contains : 3 Pages Annexe(s)

Conclusion : The SICAME preinsulated junction sleeves type MJPB 25-10 conforms of standard NF C 33-021 (june 1998) ] 2.4.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorisation of SICAME SA.

ВАРНО С ОРМИНАТА



SICAME DER	DIELECTRIC TEST EQUIPMENT ACCORDING TO SPECIFICATION: NF C 33-021	SUP ER 1160 INDICE B
---------------	--	-------------------------

Test number : 2501425  
 Product brand : SICAME  
 Product type : MJPB 25-10

A - Computer equipment

IBM PS2 (Inv N°: 88 93 06) Hard disk 115 MB  
 Analog/Digital interface card  
 Digital/Analog interface card  
 Disk Operating System: DOS 6.1 IBM  
 IBM 4029 020 (Inv N°: 92 03 30) Laser printer

B - Equipment for Dielectric test

Dielectric unit (Inv N°: 91 02 69).


C - General Equipment

crimping machine (Inv N°: 93 05 48)  
 Calibrated Ruler (Inv N°: 95 01 75)  
 Stopwatch (Inv N°: 92 02 82)

На основании чл. 2  
от ЗЗЛД

ВЯРНО С ОПИТИНАТА

На основание чл. 2  
от ЗЗЛД



SICAME DER	DIELECTRIC TEST ACCORDING TO SPECIFICATION: NF C 33-021	SUP ER 720 INDICE B
---------------	--	------------------------

Test number : 2501425 Date: 28/01/1999 Ambient Temperature : 22.9 °C  
 Manufacturer : SICAME Humidity : 37 %  
 Product : MJPB 25-10

A- Test Procedure

Two samples of the batch are crimped on appropriate cable and put in water.

The assembly is placed in a container of water, the water level must be 30 cm above the uppermost part of the connector. After the assembly has been immersed for 30 minutes, the assembly is subject to the dielectric test. The potential difference applied between the water and the conductor being 6 kV - 50 Hz, for the duration of 1 minute.

The potential difference is applied at a rate of 1 kV/s. The maximum leakage current for the interruption (triggering of circuit breaker) of the HT supply is 10 mA.

B- Results

CONNECTOR N°	Cable sizes used (mm²)		OBSERVATIONS
1	25 Alu / 10 Cu		
2	25 Alu / 10 Cu		
N° CONNECTOR	6kV/1mm After 30 min in water	Tripping value with I=10mA (KV)	
1	OK	> 10	
2	OK	> 10	

Generals observations:


ВАРНО С ОПИТНАТА

На основание чл. 2  
от ЗЗЛД

*[Handwritten signature]*


**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪБЕДИНИТЕЛ ТИП МЈРВ 25-10**

1. № на тест 2501425 - Диелектричен тест;



На основание чл. 2  
от ЗЗЛД

Съставил:





Laboratoire d'essais  
 Direction études et recherches

TEST REPORT : Dielectric test.

PRODUCT: Preinsulated junction sleeves.

Report number	: 6601465
Product brand	: SICAME
Product type	: MJPB 25-16
Project n°	: E 0900332
Batch number	: 98M708380

Demandeur of the test: SICAME D.E.R.  
 Starting date of the test : 28/01/1999  
 Report emission date : 28/01/1999  
 According to standard : NF C 33-021 (june 1998)  
 This report contains : 3 Pages Annexe(s)

Conclusion : The SICAME preinsulated junction sleeves type MJPB 25-16 conforms of standard NF C 33-021 (june 1998) J 2.4.

На основание чл. 2  
 от ЗЗЛД

This document cannot be reproduced even partially without the authorisation of SICAME SA.

ВЯРНО С ОРИГИНАЛАТА





SICAME DER	DIELECTRIC TEST EQUIPMENT ACCORDING TO SPECIFICATION: NF C 33-021	SUP ER 1160 INDICE B
---------------	--	-------------------------

Test number : 6601465  
Product brand : SICAME  
Product type : MJPB 25-16

A - Computer equipment

IBM PS2 (Inv N°: 88 93 06) Hard disk 115 MB  
Analog/Digital interface card  
Digital/Analog interface card  
Disk Operating System: DOS 6.1 IBM

IBM 4029 020 (Inv N°: 92 03 30) Laser printer

B - Equipment for Dielectric test

Dielectric unit (Inv N°: 91 02 69).

C - General Equipment

crimping machine (Inv N°: 93 05 48)  
Calibrated Ruler (Inv N°: 95 01 75)  
Stopwatch (Inv N°: 92 02 82)

На основание чл. 2  
от ЗЗЛД

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОРИГИНАЛА

SICAME DER	DIELECTRIC TEST ACCORDING TO SPECIFICATION: NF C 33-021	SUP ER 720 INDICE B
---------------	--	------------------------

Test number : 6601465 Date: 28/01/1999 Ambient Temperature : 22.9 °C  
 Manufacturer : SICAME Humidity : 37 %  
 Product : MJPB 25-16

A- Test Procedure

Two samples of the batch are crimped on appropriate cable and put in water.


The assembly is placed in a container of water, the water level must be 30 cm above the uppermost part of the connector. After the assembly has been immersed for 30 minutes, the assembly is subject to the dielectric test. The potential difference applied between the water and the conductor being 6 kV - 50 Hz, for the duration of 1 minute.

The potential difference is applied at a rate of 1 kV/s. The maximum leakage current for the interruption (triggering of circuit breaker) of the HT supply is 10 mA.

B- Results

CONNECTOR N°	Cable sizes used (mm <sup>2</sup> )		OBSERVATIONS
1	25 Alu / 16 Alu		
2	25 Alu / 16 Alu		
N° CONNECTOR	6kV/1mm After 30 min in water	Tripping value with I=10mA (KV)	
1	OK	> 10	
2	OK	> 10	

Generals observations:



На основание чл. 2  
от ЗЗЛД



СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЛРВ 25-16

1. № на тест: 6601465 - Диелектричен тест.

На основание чл. 2  
от ЗЗЛД

Състави





**sicame**

Laboratoire d'essais  
Direction études et recherches

TEST REPORT : Dielectric test.

PRODUCT: Preinsulated junction sleeves.

Report number	: 9901410
Product brand	: SICAME
Product type	: MJPB 35-25
Project n°	: E 0900332
Batch number	: 98M708380

*[Handwritten signature]*

*[Handwritten signature]*

Demander of the test: SICAME D.E.R.  
 Starting date of the test : 28/01/1999  
 Report emission date : 28/01/1999  
 According to standard : NF C 33-021 (june 1998)  
 This report contains : 3 Pages Annexe(s)

Conclusion : The SICAME preinsulated junction sleeves type MJPB 35-25 conforms of standard NF C 33-021 (june 1998) ] 2.4.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorisation of SICAME SA.

ВЪРНО С ОРИГИНАЛА



*[Handwritten signature]*

SICAME DER	DIELECTRIC TEST EQUIPMENT ACCORDING TO SPECIFICATION: NF C 33-021	SUP ER 1160 INDICE B
---------------	--	-------------------------

Test number : 9901410  
Product brand : SICAME  
Product type : MJPB 35-25

A - Computer equipment

IBM PS2 (Inv N°: 88 93 06) Hard disk 115 MB  
Analog/Digital interface card  
Digital/Analog interface card  
Disk Operating System: DOS 5.1 IBM

IBM 4029 020 (Inv N°: 92 03 30) Laser printer

B - Equipment for Dielectric test

Dielectric unit (Inv N°: 91 02 69).

C - General Equipment

crimping machine (Inv N°: 93 05 48)  
Calibrated Ruler (Inv N°: 95 01 75)  
Stopwatch (Inv N°: 92 02 82)

На основание чл. 2  
от ЗЗЛД

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОПРИТЕЛНАТА

2° ООД

САМОКОВ

SICAME DER	DIELECTRIC TEST ACCORDING TO SPECIFICATION: NF C 33-021	SUP ER 720 INDICE B
---------------	--	------------------------

Test number : 9901410 Date: 28/01/1999 Ambient Temperature : 22.9°C  
 Manufacturer : SICAME Humidity : 37 %  
 Product : MJPB 35-25

A- Test Procedure

Two samples of the batch are crimped on appropriate cable and put in water.

The assembly is placed in a container of water, the water level must be 30 cm above the uppermost part of the connector. After the assembly has been immersed for 30 minutes, the assembly is subject to the dielectric test. The potential difference applied between the water and the conductor being 5 kV - 50 Hz, for the duration of 1 minute.

The potential difference is applied at a rate of 1 kV/s. The maximum leakage current for the interruption (triggering of circuit breaker) of the HT supply is 10 mA.

B- Results

CONNECTOR N°	Cable sizes used (mm²)		OBSERVATIONS
1	35 Alu / 25 Alu		
2	35 Alu / 25 Alu		
N° CONNECTOR	5kV/1mn After 30 min in water	Tripping value with I=10mA (KV)	OBSERVATIONS
1	OK	> 10	
2	OK	> 10	

Generals observations:

На основании чл. 2 от ЗЗЛД

ВЯРНО С ОПИГАНАТА

2° ООД  
САМОКОВ  
3TV

СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ ЗА МАНШОН ТИП МЈРВ 35/25

1. № на тест: 9901410 - Диелектричен тест.

На основание чл. 2  
от ЗЗЛД

Състави:



SICAME

R & D DEPARTMENT

MECHANICAL TESTS

PRE-INSULATED JUNCTION SLEEVES

- MJPT 35 (CG) -> 9212290
- MJPT 50-25 (CG) -> 9212300
- MJPT 50-35 (CG) -> 9212310
- MJPT 50 (CG) -> 9212320
- MJPT 70-35 (CG) -> 9212330
- MJPT 70-50 (CG) -> 9212340
- MJPT 150 (CG) -> 9212350
- MJPT 150 (CG) -> 9212370
- MJPT 150-70 (CG) -> 9212380

PRE-INSULATED LUGS

- . BIMETALLIC LUGS
  - CPTAU70A -> 9502080
  - CPTAU150A -> 9502100
- . ALUMINIUM LUGS
  - CPTA70A -> 9502090

SUP ER 160  
INDICE A

LABORATOIRE SICAME	
ESSAI	
FOLIO 1/10	VISA B

ВАРНО С ОПРЕДЕЛЕНАТА





EQUIPMENT USED DURING MECHANICAL TESTS

A - Computer

HP 9826 N°UT : 88 91 93  
HP 3497A N°UT : 88 05 58 Data recording  
HP 7470 N°UT : 88 91 90 Plotter  
IBM PS2 N°UT : 88 93 06 Hard disk 112 Megabytes  
Analog/digital card - Digital/analog card  
DOS system used  
IBM 4029 020 N°UT : 92 03 30 Laser printer

B - Electrical and thermal measurement equipment

HP 3456 N°UT : 88 05 17 Voltmeter

C - Equipment for mechanical tests

Traction bench (for junction sleeves) N°UT : 89 01 34  
10 Tons HP 9826 driven  
Load cell N°UT 920245 - FGP INSTRUMENTATION -  
LHOMARGY DY 36 N° UT 92 04 23 (for pre insulated lugs)  
Digital caliper N°UT : 93 06 07 - MITUTOYO -  
Electronic torque wrench N°UT : 92 03 31 - POWELL DUFFRYN -  
Précision 1%  
Standard ruler N°UT : 93 00 83 -ROCH-  
Power supply FONTAINE N°UT : 92 02 79  
Compression tool ED50 (5 tons) N°UT : 91 01 29  
Pneumatic compression head U13 (13 tons) N°UT : 91 00 55  
E215 die with 9 mm for 150 et 150-70 sleeves and lugs  
E173 die with 9 mm for other sleeves and lugs

LABORATOIRE SICAME	
ESSAI	
FOLIO 2/10	VISA B

ВЪРНО С ОРНИФИКАЦИЯ



SICAME	MECHANICAL TEST	SUP ER 730
DER	ACCORDING TO STANDARD : HN 33S66	INDEX A

Test number : 9212290 Date: 04/12/92 Ambient temperature : 22 °C  
 Product brand : CEGERS Humidity : 45 %  
 Product type : MJPT 35-35

**A - SETTING OF THE TEST**

A junction is set up with a core area adapted to the capacity of the sleeve.  
 A static load is applied on the conductive part of the cable.  
 It must be continuously increasing (the load increase must have a value between 1000 & 5000 N/mm) up to 50% of the minimum load value indicated in the standard.  
 The load is maintained during 1 minute.  
 Then, the load increase is repeated up to the breaking of the junction or the sliding of the conductor.

**B - TEST RESULTS**

N° of the sleeve	Value of the tensile strength required during 1 mn (N)	Breaking value (N)	Comments
1	1250	3820	wire breaking
2	1250	3960	wire breaking

General comments : Satisfactory

LABORATOIRE SICAME	
ESSAI 92.12.290	
FOLIO 3/10	VISA [Signature]

ВЯРНО С ОРНИВАНАТА



SICAME	MECHANICAL TEST	SUP ER 730
DER	ACCORDING TO STANDARD : EN 33566	INDEX A

Test number : 9212300 Date: 04/12/92 Ambient temperature : 22 °C  
 Product brand : CEGERS Humidity : 45 %  
 Product type : MJPT 50-25

A - SETTING OF THE TEST



A junction is set up with a core area adapted to the capacity of the sleeve.  
 A static load is applied on the conductive part of the cable.  
 It must be continuously increasing (the load increase must have a value between 1000 & 5000 N/mn) up to 50% of the minimum load value indicated in the standard.  
 The load is maintained during 1 minute.  
 Then, the load increase is repeated up to the breaking of the junction or the sliding of the conductor.

B - TEST RESULTS

N° of the sleeve	Value of the tensile strength required during 1 mn (N)	Breaking value (N)	Comments
1	900	3120	wire breaking
2	900	2940	wire breaking

General comments : Satisfactory

LABORATOIRE SICAME	
ESSAI 9212300	
FOLIO 4/10	VISA LB



SICAME	MECHANICAL TEST ACCORDING TO STANDARD : EN 33566	SUP ER 730
DER		INDEX A

Test number : 9212310 Date: 04/12/92 Ambient temperature : 22 °C  
Product brand : CEGERS Humidity : 45 %  
Product type : MJPT 50-35

A - SETTING OF THE TEST

A junction is set up with a core area adapted to the capacity of the sleeve.  
A static load is applied on the conductive part of the cable.  
It must be continuously increasing (the load increase must have a value between 1000 & 5000 N/mm) up to 50% of the minimum load value indicated in the standard.  
The load is maintained during 1 minute.  
Then, the load increase is repeated up to the breaking of the junction or the sliding of the conductor.

B - TEST RESULTS

N° of the sleeve	Value of the tensile strength required during 1 mm (N)	Breaking value (N)	Comments
1	1250	4410	wire breaking
2	1250	4300	wire breaking

General comments : Satisfactory

LABORATOIRE SICAME	
ESSAI 9212310	
FOLIO 5/10	VISA UB

ВІСНОВОК



SICAME	MECHANICAL TEST	SUP ER 730
DER	ACCORDING TO STANDARD : HN 33S66	INDEX A

Test number : 9212320 Date: 04/12/92 Ambient temperature : 22 °C  
 Product brand : CEGERS Humidity : 45 %  
 Product type : NJPT 50-50

A - SETTING OF THE TEST

A junction is set up with a core area adapted to the capacity of the sleeve.  
 A static load is applied on the conductive part of the cable.  
 It must be continuously increasing (the load increase must have a value between 1000 & 5000 N/mm) up to 50% of the minimum load value indicated in the standard.  
 The load is maintained during 1 minute.  
 Then, the load increase is repeated up to the breaking of the junction or the sliding of the conductor.

B - TEST RESULTS

N° of the sleeve	Value of the tensile strength required during 1 mm (N)	Breaking value (N)	Comments
1	1750	5860	wire breaking
2	1750	5960	wire breaking

General comments : Satisfactory

LABORATOIRE SICAME  
 ESSAI 9212320  
 FOLIO 6/10 VISA 03

ВЯРНО С ОРНИМАЦИЈА



Handwritten initials or signature at the bottom right corner.

SICAME	MECHANICAL TEST ACCORDING TO STANDARD : HN 33S66		SUP ER 730
DER			INDEX A
Test number	: 9212330	Date: 04/12/92	Ambient temperature : 22 °C
Product brand	: CEGERS		Humidity : 45 %
Product type	: MJPT 70-35		

A - SETTING OF THE TEST

A junction is set up with a core area adapted to the capacity of the sleeve.

A static load is applied on the conductive part of the cable. It must be continuously increasing (the load increase must have a value between 1000 & 5000 N/mn) up to 50% of the minimum load value indicated in the standard.

The load is maintained during 1 minute.

Then, the load increase is repeated up to the breaking of the junction or the sliding of the conductor.

B - TEST RESULTS

N° of the sleeve	Value of the tensile strength required during 1 mn (N)	Breaking value (N)	Comments
1	1250	4250	wire breaking
2	1250	4350	wire breaking

General comments : Satisfactory

LABORATOIRE SICAME	
ESSAI 9212330	
FOLIO 7/10	VISA CB

ВЯРНО С ОРМЪТА НАСТА



SICAME	MECHANICAL TEST	SUPER 730
DER	ACCORDING TO STANDARD : HN 33866	INDEX A

Test number : 9212340 Date: 04/12/92 Ambient temperature : 22 °C  
 Product brand : CEGERS Humidity : 45 %  
 Product type : MJPT 70-50

A - SETTING OF THE TEST

A junction is set up with a core area adapted to the capacity of the sleeve.  
 A static load is applied on the conductive part of the cable.  
 It must be continuously increasing (the load increase must have a value between 1000 & 5000 N/mn) up to 50% of the minimum load value indicated in the standard.  
 The load is maintained during 1 minute.  
 Then, the load increase is repeated up to the breaking of the junction or the sliding of the conductor.

B.- TEST RESULTS

N° of the sleeve	Value of the tensile strength required during 1 mn (N)	Breaking value (N)	Comments
1	1750	4950	wire breaking
2	1750	5400	wire breaking

General comments : Satisfactory

LABORATOIRE SICAME	
ESSAI 92.12.340	
FOLIO 8/10	VISA UB

ВАРНО С ОПИТИВАНАТА



SICAME	MECHANICAL TEST ACCORDING TO STANDARD : HN 33S66	SUP ER 730
DER		INDEX A

Test number : 9212350 Date: 04/12/92 Ambient temperature : 22 °C  
 Product brand : CEGERS Humidity : 45 %  
 Product type : MJPT 70-70

A - SETTING OF THE TEST

A junction is set up with a core area adapted to the capacity of the sleeve.  
 A static load is applied on the conductive part of the cable.  
 It must be continuously increasing (the load increase must have a value between 1000 & 5000 N/mm) up to 50% of the minimum load value indicated in the standard.  
 The load is maintained during 1 minute.  
 Then, the load increase is repeated up to the breaking of the junction or the sliding of the conductor.

B - TEST RESULTS

N° of the sleeve	Value of the tensile strength required during 1 mm (N)	Breaking value (N)	Comments
1	2500	8570	wire breaking
2	2500	8620	wire breaking

General comments : Satisfactory

LABORATOIRE SICAM  
 ESSAI 9212350  
 FOLIO 3/10 VISA UB

ВАРНО С ОРГАНИЗАЦИЯ



264



SICAME	MECHANICAL TEST	SUP ER 730
DER	ACCORDING TO STANDARD : RN 33866	INDEX A

Test number : 9212370 Date: 04/12/92 Ambient temperature : 22 °C  
 Product brand : CEGERS Humidity : 45 %  
 Product type : MJPT 150-150

A - SETTING OF THE TEST

A junction is set up with a core area adapted to the capacity of the sleeve.  
 A static load is applied on the conductive part of the cable.  
 It must be continuously increasing (the load increase must have a value between 1000 & 5000 N/mn) up to 50% of the minimum load value indicated in the standard.  
 The load is maintained during 1 minute.  
 Then, the load increase is repeated up to the breaking of the junction or the sliding of the conductor.


B - TEST RESULTS

N° of the sleeve	Value of the tensile strength required during 1 mn (N)	Breaking value (N)	Comments
1	5500	13560	wire breaking
2	5500	14010	wire breaking

General comments : Satisfactory

LABORATOIRE SICAME	
ESSAI 9212370	
FOLIO	YISA
10/10	LB

ВЯРНО С ОПИТИВАНАТА





Laboratoire d'essais  
de la **D**irection **E**tudes et **R**echerches

**Rapport d'essai** : Essai de montage à basse température  
**Test report** : *Installation test at low temperature*

Rapport d'essai n°	: 12 04 124	Test report n.	: 12 04 124
Constructeur	: SICAME	Product brand	: SICAME
Référence produit	: MJPT 35	Product type	: MJPT 35
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: Du 17 au 18 avril 2012	Date of the test	: 17 to 18 April 2012
Date d'émission du rapport	: 15 mai 2012	Réport emission date	: 15 May 2012

Essais réalisés suivant : NF EN 50483-4 (07/2009), § 8.2.4  
*Tests carried out in accordance with*

Ce rapport comprend : 9 pages  
*This report contains*

**Conclusion** : Les manchons de jonction préisolés SICAME de type MJPT 35 soumis à essai satisfont aux exigences du § 8.2.4 de la norme NF EN 50483-4 (07/2009).  
*For declaring the conformity, it has not been explicitly taken into account the uncertainty associated with the result.*

**Conclusion** : *The tested SICAME insulated splicing sleeves MJPT 35 comply with the requirements of clause 8.2.4 of NF EN 50483-4 (07/2009) standard. To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved*

На основание чл. 2  
от ЗЗЛД

L'accréditation de la section essais du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation. Ce rapport ne concerne que les produits référencés ci-dessus. La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.

01/24/09



Accreditation 1-1069. Scope on request.  
The Cofrac testing section accreditation ensures the competence of the Laboratory staff for the tests for which the laboratory has qualified. This report applies only to the products as listed above. With the authorization of Sicame S.A., this report may only be reproduced in its totality.

ACCREDITATION  
N° 1-1069  
PORTÉE  
DISPONIBLE SUR  
www.cofrac.fr

cofrac



B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 89 00 - Fax (33) 05 55 73 83 12 - Email : info@sicame.fr



200

**1 Echantillons soumis à essai / Samples under test**


Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT 35


Matière de la jupe / over molding material : KEPITAL

Fabricant / Manufacturer : SICAME

Numéro de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700610  
*Samples in accordance with drawing n. E0700610*




Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>





Nombre d'échantillons / Number of samples : 2

Repérage / Identification : 1, 2

Date de réception au laboratoire : 3 avril 2012  
*Reception date at the laboratory : 03 April 2012*



На основание чл. 2  
от ЗЗЛД



**2 Caractéristiques du matériel / Equipment used during test**

**2.1 Appareillage utilisé / Equipment used**

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
99 01 48	Thermomètre indicateur <i>Indicating thermometer</i>	Précision ± 2°C <i>Accuracy ± 2°C</i>
97 02 02	Règlet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
10 03 21	Chambre froide <i>Low temperature chamber</i>	Précision 1°C <i>Accuracy 1°C</i>
99 00 41	Conductimètre <i>Conductimeter</i>	Précision 30 µS/cm <i>Accuracy 30µS/cm</i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision 1°C <i>Accuracy 1°C</i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectrimeter BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОПИГНАТА

## 2.2 Câbles / Cables

N° Lot / Identification	08006		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	35 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme / Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	
	<input checked="" type="checkbox"/> Rétreinte Compacted	<input type="checkbox"/> Non rétreinte Non compacted	<input type="checkbox"/> Souple Flexible
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde Circular	<input type="checkbox"/> Sectorale Sector-shaped	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	7,05 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 Cross-linked polyethylene, TIX-5 type		
Ø sur isolant / Ø on insulation	10,45 mm		
Conditionnement Conditioned on	1h00 à 120°C 1h00 at 120°C		
Référence du câble HD626 HD626 conductor reference	6 E-1		
Charge de rupture minimale Minimum breaking load	4 200 N		

## 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.4 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur deux manchons pour chaque section.

Les raccords, le conducteur et les outillages sont au préalable pré-conditionnés jusqu'à la température d'essai (-10 ± 3) °C, ensuite ils sont assemblés à cette température dans la chambre froide.

Au moins 3h à température ambiante après la sortie de la chambre froide, les manchons sont soumis à :

- l'essai de tenue diélectrique dans l'eau, conformément au § 8.2.3 :

L'ensemble, raccord et conducteurs, est placé au fond d'un bac d'eau. Pendant le déplacement de l'ensemble, il peut être maintenu pour s'assurer qu'il n'y ait pas de courbure du conducteur ou de mouvement inutile des éléments. Le raccord est placé horizontalement. La profondeur de l'eau est mesurée à partir de la partie supérieure du raccord. Les conducteurs émergent suffisamment de l'eau pour éviter un claquage. Le courant de fuite maximum est égal à (10 ± 0,5) mA. La résistivité de l'eau est ≤ 200 Ωm. L'eau est à température ambiante. On effectue la montée progressive en tension à une vitesse d'environ 1 kV/s. Après une durée d'immersion de 30 min, une tension alternative de 6 kV est appliquée à l'échantillon pendant 60 s.

Vis

На основание чл. 2  
от ЗЗЛД

ВЪРЖО С ОПИТИНАТА

• l'essai mécanique, conformément au § 8.2.2. :

L'ensemble est soumis à un effort de traction appliqué sur l'âme conformément à la figure 8 de la norme. Les efforts de traction sont appliqués sur les âmes, la montée en charge est conforme à la NF EN 50483-1, § 9.1.4. (vitesse entre 1000 N/min et 5000 N/min)

Un effort de traction est appliqué sur l'âme jusqu'à atteindre les valeurs exprimées en % de la CRM du Tableau 1 :

Tableau 1 – Efforts initiaux exigés pour le marquage

Système de torsade	Sections	Efforts	Essai
Système autoporté	4 mm <sup>2</sup> à 16 mm <sup>2</sup> Cuivre	10 % de la CRM pendant 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> à 25 mm <sup>2</sup> Aluminium	20 % de la CRM pendant 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	Pleine traction : 20 % de la CRM pendant 60 s  Traction allégée : 5 % de la CRM pendant 60 s	<input type="checkbox"/> <input type="checkbox"/>
Système à neutre porteur	Phases : 16 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	30 % de la CRM pendant 60 s	<input type="checkbox"/>
	Neutre : 25 mm <sup>2</sup> à 95 mm <sup>2</sup> alliage d'aluminium	60 % de la CRM pendant 60 s	<input type="checkbox"/>

Un marquage est réalisé sur le câble à l'endroit où il sort du raccord.

Les efforts sont ensuite augmentés jusqu'aux valeurs exprimées en % de la CRM du Tableau 2 :

Tableau 2 – Efforts d'essai

Système de torsade	Sections	Efforts	Essai
Système autoporté	4 mm <sup>2</sup> à 16 mm <sup>2</sup> Cuivre	20 % de la CRM pendant 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> à 25 mm <sup>2</sup> Aluminium	1 200 N ou 40 % de la CRM, la plus grande des deux valeurs pendant 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	Pleine traction : 85 % de la CRM pendant 60 s  Traction allégée : 10% de la CRM pendant 60 s	<input type="checkbox"/> <input type="checkbox"/>
Système à neutre porteur	Phases : 16 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	60 % de la CRM pendant 60 s	<input type="checkbox"/>
	Neutre : 25 mm <sup>2</sup> à 95 mm <sup>2</sup> alliage d'aluminium	95 % de la CRM pendant 60 s	<input type="checkbox"/>

На основание чл. 2  
от ЗЗЛД

ВЪРХО С ОФИЦИАЛНАТА

Connectors are tested in accordance with NF EN 50483-4 (07/2009) §8.2.4 standard.

Two samples are tested of each equal cross section.

The connectors, conductor and tools are further pre-conditioned until they reach the test temperature of  $(-10 \pm 3) ^\circ\text{C}$  before they are assembled. Assembly is made in the cold temperature chamber, at  $(-10 \pm 3) ^\circ\text{C}$ .

At least 3 h after having been removed from the cold chamber, the sleeves are subjected to :

- dielectrical voltage test in water, according to clause 8.2.3:

The assembly, of connector and cores, is placed at the bottom of a water tank. During the movement of the assembly it may be supported to ensure no bending of the core or unnecessary movement of the component parts. The connector is placed horizontally. The depth of water is measured from the upper part of the connector. The cores are sufficiently above the water level to prevent flashover. The maximum leakage current is equal to  $(10 \pm 0,5) \text{ mA}$ . The resistivity of the water is  $\leq 200 \Omega\text{m}$ . The water is at ambient temperature. The a.c. voltage is applied to a rate of approximately 1 kV/s. After 30 min under water, the voltage test is applied to the sample with 6 kV a.c. for 60 s.

- mechanical testing, according to clause 8.2.2:

The assembly is subjected to a tensile load applied to the conductor in accordance with Figure 8 of the standard.




Tensile test loads are applied to conductors, the rate of increase is in accordance with § 9.1.4 of NF EN 50483-1. (speed between 1000 N/min and 5000 N/min)

A tensile test load is applied to the conductor until it reaches the values of Table 1:

Table 1 – Initial loads required for marking

Bundle System	Cross sections	Loads	Test
Self supporting system	4 mm <sup>2</sup> to 16 mm <sup>2</sup> Copper	10 % of MBL for 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> to 25 mm <sup>2</sup> Aluminium	20 % of MBL for 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	Full tension : 20 % of MBL for 60 s  Partial tension : 5 % of MBL for 60 s	<input type="checkbox"/> <input type="checkbox"/>
Neutral messenger system	Phases : 16 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	30 % of MBL for 60 s	<input type="checkbox"/>
	Neutral : 25 mm <sup>2</sup> to 95 mm <sup>2</sup> Aluminium alloy	60 % of MBL for 60 s	<input type="checkbox"/>

The cable is marked at the point at which it leaves the connector.



На основание чл. 2  
от ЗЗЛД



The load then is increased up to the values of Table 2:

Table 2 – Test loads

Bundle System	Cross sections	Loads	Test
Self supporting system	4 mm <sup>2</sup> to 16 mm <sup>2</sup> Copper	20 % of MBL for 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> to 25 mm <sup>2</sup> Aluminium	1200 N or 40 % of MBL whichever is the greater for 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	Full tension : 85 % of MBL for 60 s  Partial tension : 10 % of MBL for 60 s	<input type="checkbox"/> <input type="checkbox"/>
Neutral messenger system	Phases : 16 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	60 % of MBL for 60 s	<input type="checkbox"/>
	Neutral : 25 mm <sup>2</sup> to 95 mm <sup>2</sup> Aluminium alloy	95 % of MBL for 60 s	<input type="checkbox"/>

3.1 Exigences supplémentaires du demandeur de l'essai  
Additional requirements of the applicant for the test

Néant  
None

3.2 Conditions ambiantes / Ambient conditions

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
Ambient conditions when performing the test are as follows:

	Exigences Requirements	Relevés Results
Température ambiante et humidité Ambient temperature and humidity conditions	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	22 °C 30 %HR
Temps de conditionnement Conditioning time	-	1 h 23 min
Température de la chambre froide Low temperature chamber	(-10 ± 3)°C	-11,0 °C
Temps à température ambiante après la sortie de la chambre froide Ambient temperature time after out of cold chamber	> 3 h	3 h 21 min
Température de l'eau Water temperature	Température ambiante Ambient temperature	21,5 °C
Résistivité de l'eau Water resistivity	≤ 200 Ωm	34,01 Ωm
Temps d'immersion (minutes) Immersion time (minutes)	30	30
Vitesse de montée en tension Voltage increase rate	≈ 1 kV/s	≈ 1 kV/s

На основании чл. 2  
от ЗЗЛД

ВАРНО С ОПИТИВАНАТА



3.3 Configuration des échantillons / Samples configuration

Echantillon n° Sample n.	Section / Cross section (mm <sup>2</sup> )		Système de torsade Bundle system
1	35	35	Système autoporté Self supporting system
2			

4 Résultats / Results

Echantillon n° Sample n.	6 kV pendant 1 min 6 kV for 1 min	
	Exigences Requirements	Résultats Results
1	Pas de claquage No breakdown	Pas de claquage No breakdown
2		Pas de claquage No breakdown

Echantillon n° Sample n.	Vitesse de montée programmée Planned increase rate (N/min)	
	Exigences Requirements	Résultats Results
1	1000 ≤ ... ≤ 5000	3000
2		3000

*[Handwritten signature]*

*[Handwritten signature]*

Echantillon n° Sample n.	Effort pour marquage pendant 1 minute Strength for marking during 1 min (N)		Effort pendant 1 minute Strength during 1 min (N)	
	Exigences Requirements	Résultats Results	Exigences Requirements	Résultats Results
1	20 % CRM MBL ↔ 600	600	40 % CRM MBL ↔ 1200	1200
2		600		1200

5 Conclusion / Conclusion


Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
No breakdown or flashover occurred (tripping of voltage generator).

Aucun glissement ou rupture ne s'est produit.  
No slippage or breakage occurred.

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПРИГНАЛАТА

## 6 Courbes / Curves




FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

ВЪРНО С ОПИТНАТА

На основание чл. 2  
от ЗЗЛД


СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 35

1. № на тест: 9212290 - Механичен тест;
2. № на тест: 1204124 - Тест за инсталиране при ниска температура.



На основание чл. 2  
от ЗЗЛД

Съставил:





Laboratoire d'essais  
de la **D**irection **E**tudes et **R**echerches

Rapport d'essai : Essai de montage à basse température  
Test report : Installation test at low temperature

Rapport d'essai n°	: 12 04 121	Test report n.	: 12 04 121
Constructeur	: SICAME	Product brand	: SICAME
Référence produit	: MJPT 50	Product type	: MJPT 50
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: Du 17 au 18 avril 2012	Date of the test	: 17 to 18 April 2012
Date d'émission du rapport	: 15 mai 2012	Report emission date	: 15 May 2012

Essais réalisés suivant : NF EN 50483-4 (07/2009), § 8.2.4  
Tests carried out in accordance with

Ce rapport comprend : 9 pages  
This report contains

Conclusion : Les manchons de jonction préisolés SICAME de type MJPT 50 soumis à essai satisfont aux exigences du § 8.2.4 de la norme NF EN 50483-4 (07/2009).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

Conclusion : The tested SICAME insulated splicing sleeves MJPT 50 comply with the requirements of clause 8.2.4 of NF EN 50483-4 (07/2009) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основание чл. 2  
от ЗЗЛД

L'accréditation de la section essais du COFRAC atteste de la compétence des laboratoires pour les essais couverts par l'accréditation. Ce rapport ne concerne que les produits référencés ci-dessus. La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.

0 01394 01



Accreditation 1-1068, Scope on request.

The Cofrac testing section accreditation ensures the competence of the Laboratory staff for the tests for which the laboratory has qualified. This report applies only to the products as listed above. With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 69 00 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr

ACCREDITATION  
N° 1-1068  
PORTÉE  
DISPONIBLE SUR  
www.cofrac.fr

cofrac



**1 Echantillons soumis à essai / Samples under test**

Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT 50

Matière de la jupe / over molding material : KBPITAL

Fabricant / Manufacturer : SICAME


Numéro de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700610  
*Samples in accordance with drawing n. E0700610*

Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 2

Repérage / Identification : 1, 2

Date de réception au laboratoire : 3 avril 2012  
*Reception date at the laboratory : 03 April 2012*



ВЯРНО С ОРИГИНАЛА

На основание чл. 2  
от ЗЗЛД

## 2 Caractéristiques du matériel / Equipment used during test

### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
99 01 48	Thermomètre indicateur <i>Indicating thermometer</i>	Précision $\pm 2^{\circ}\text{C}$ <i>Accuracy <math>\pm 2^{\circ}\text{C}</math></i>
97 02 02	Réglet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
10 03 21	Chambre froide <i>Low temperature chamber</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
99 00 41	Conductimètre <i>Conductimeter</i>	Précision 30 $\mu\text{S}/\text{cm}$ <i>Accuracy 30 <math>\mu\text{S}/\text{cm}</math></i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectrimeter BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>

### 2.2 Câbles / Cables

N° Lot / Identification	07021		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	50 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	
	<input type="checkbox"/> Rétreinte <i>Compacted</i>	<input checked="" type="checkbox"/> Non rétreinte <i>Non compacted</i>	<input type="checkbox"/> Souple <i>Flexible</i>
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	9,00 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 <i>Cross-linked polyethylene, TIX-5 type</i>		
Ø sur isolant / Ø on insulation	11,45 mm		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Référence du câble HD626 HD626 conductor reference	4 E-1		
Charge de rupture minimale Minimum breaking load	3 000 N		

На основании чл. 2  
от ЗЗЛД

ВАРНО С ОПИТИВАТА

### 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.4 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur deux manchons pour chaque section.

Les raccords, le conducteur et les outillages sont au préalable pré-conditionnés jusqu'à la température d'essai ( $-10 \pm 3$ ) °C, ensuite ils sont assemblés à cette température dans la chambre froide.

Au moins 3h à température ambiante après la sortie de la chambre froide, les manchons sont soumis à :

- l'essai de tenue diélectrique dans l'eau, conformément au § 8.2.3 :

L'ensemble, raccord et conducteurs, est placé au fond d'un bac d'eau. Pendant le déplacement de l'ensemble, il peut être maintenu pour s'assurer qu'il n'y ait pas de courbure du conducteur ou de mouvement inutile des éléments. Le raccord est placé horizontalement. La profondeur de l'eau est mesurée à partir de la partie supérieure du raccord, Les conducteurs émergent suffisamment de l'eau pour éviter un claquage. Le courant de fuite maximum est égal à ( $10 \pm 0,5$ ) mA. La résistivité de l'eau est  $\leq 200 \Omega\text{m}$ . L'eau est à température ambiante. On effectue la montée progressive en tension à une vitesse d'environ 1 kV/s. Après une durée d'immersion de 30 min, une tension alternative de 6 kV est appliquée à l'échantillon pendant 60 s.

ВЯРНО С ОПИТИНАТА

На основание чл. 2  
от ЗЗЛД

- l'essai mécanique, conformément au § 8.2.2. :

L'ensemble est soumis à un effort de traction appliqué sur l'âme conformément à la figure 8 de la norme. Les efforts de traction sont appliqués sur les âmes, la montée en charge est conforme à la NF EN 50483-1, § 9.1.4. (vitesse entre 1000 N/min et 5000 N/min)

Un effort de traction est appliqué sur l'âme jusqu'à atteindre les valeurs exprimées en % de la CRM du Tableau 1 :

Tableau 1 – Efforts initiaux exigés pour le marquage

Système de torsade	Sections	Efforts	Essai
Système autoporté	4 mm <sup>2</sup> à 16 mm <sup>2</sup> Cuivre	10 % de la CRM pendant 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> à 25 mm <sup>2</sup> Aluminium	20 % de la CRM pendant 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	Pleine traction : 20 % de la CRM pendant 60 s	<input type="checkbox"/>
		Traction allégée : 5 % de la CRM pendant 60 s	<input type="checkbox"/>
Système à neutre porteur	Phases : 16 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	30 % de la CRM pendant 60 s	<input type="checkbox"/>
	Neutre : 25 mm <sup>2</sup> à 95 mm <sup>2</sup> alliage d'aluminium	60 % de la CRM pendant 60 s	<input type="checkbox"/>

Un marquage est réalisé sur le câble à l'endroit où il sort du raccord.

Les efforts sont ensuite augmentés jusqu'aux valeurs exprimées en % de la CRM du Tableau 2 :

Tableau 2 – Efforts d'essai

Système de torsade	Sections	Efforts	Essai
Système autoporté	4 mm <sup>2</sup> à 16 mm <sup>2</sup> Cuivre	20 % de la CRM pendant 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> à 25 mm <sup>2</sup> Aluminium	1 200 N ou 40 % de la CRM, la plus grande des deux valeurs pendant 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	Pleine traction : 85 % de la CRM pendant 60 s	<input type="checkbox"/>
		Traction allégée : 10% de la CRM pendant 60 s	<input type="checkbox"/>
Système à neutre porteur	Phases : 16 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	60 % de la CRM pendant 60 s	<input type="checkbox"/>
	Neutre : 25 mm <sup>2</sup> à 95 mm <sup>2</sup> alliage d'aluminium	95 % de la CRM pendant 60 s	<input type="checkbox"/>

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРМЕТНАТА



Connectors are tested in accordance with NF EN 50483-4 (07/2009) §8.2.4 standard.

Two samples are tested of each equal cross section.

The connectors, conductor and tools are further pre-conditioned until they reach the test temperature of  $(-10 \pm 3) ^\circ\text{C}$  before they are assembled. Assembly is made in the cold temperature chamber, at  $(-10 \pm 3) ^\circ\text{C}$ .

At least 3 h after having been removed from the cold chamber, the sleeves are subjected to :

- dielectrical voltage test in water, according to clause 8.2.3:

The assembly, of connector and cores, is placed at the bottom of a water tank. During the movement of the assembly it may be supported to ensure no bending of the core or unnecessary movement of the component parts. The connector is placed horizontally. The depth of water is measured from the upper part of the connector. The cores are sufficiently above the water level to prevent flashover. The maximum leakage current is equal to  $(10 \pm 0,5) \text{ mA}$ . The resistivity of the water is  $\leq 200 \Omega\text{m}$ . The water is at ambient temperature. The a.c. voltage is applied to a rate of approximately 1 kV/s. After 30 min under water, the voltage test is applied to the sample with 6 kV a.c. for 60 s.

- mechanical testing, according to clause 8.2.2:

The assembly is subjected to a tensile load applied to the conductor in accordance with Figure 8 of the standard.


Tensile test loads are applied to conductors, the rate of increase is in accordance with § 9.1.4 of NF EN 50483-1. (speed between 1000 N/min and 5000 N/min)

A tensile test load is applied to the conductor until it reaches the values of Table 1:

Table 1 – Initial loads required for marking

Bundle System	Cross sections	Loads	Test
Self supporting system	4 mm <sup>2</sup> to 16 mm <sup>2</sup> Copper	10 % of MBL for 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> to 25 mm <sup>2</sup> Aluminium	20 % of MBL for 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	Full tension : 20 % of MBL for 60 s  Partial tension : 5 % of MBL for 60 s	<input type="checkbox"/> <input type="checkbox"/>
Neutral messenger system	Phases : 16 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	30 % of MBL for 60 s	<input type="checkbox"/>
	Neutral : 25 mm <sup>2</sup> to 95 mm <sup>2</sup> Aluminium alloy	60 % of MBL for 60 s	<input type="checkbox"/>

The cable is marked at the point at which it leaves the connector.



На основание чл. 2  
от ЗЗЛД

The load then is increased up to the values of Table 2:

Table 2 – Test loads

Bundle System	Cross sections	Loads	Test
Self supporting system	4 mm <sup>2</sup> to 16 mm <sup>2</sup> Copper	20 % of MBL for 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> to 25 mm <sup>2</sup> Aluminium	1200 N or 40 % of MBL whichever is the greater for 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	Full tension : 85 % of MBL for 60 s  Partial tension : 10 % of MBL for 60 s	<input type="checkbox"/> <input type="checkbox"/>
Neutral messenger system	Phases : 16 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	60 % of MBL for 60 s	<input type="checkbox"/>
	Neutral : 25 mm <sup>2</sup> to 95 mm <sup>2</sup> Aluminium alloy	95 % of MBL for 60 s	<input type="checkbox"/>

3.1 Exigences supplémentaires du demandeur de l'essai  
Additional requirements of the applicant for the test


Néant  
None

3.2 Conditions ambiantes / Ambient conditions

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
Ambient conditions when performing the test are as follows:

	Exigences Requirements	Relevés Results
Température ambiante et humidité Ambient temperature and humidity conditions	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	22 °C 30 %HR
Temps de conditionnement Conditioning time	-	1 h 23 min
Température de la chambre froide Low temperature chamber	(-10 ± 3)°C	-11,0 °C
Temps à température ambiante après la sortie de la chambre froide Ambient temperature time after out of cold chamber	> 3 h	3 h 21 min
Température de l'eau Water temperature	Température ambiante Ambient temperature	21,5 °C
Résistivité de l'eau Water resistivity	≤ 200 Ωm	34,01 Ωm
Temps d'immersion (minutes) Immersion time (minutes)	30	30
Vitesse de montée en tension Voltage increase rate	≈ 1 kV/s	≈ 1 kV/s

На основание чл. 2  
от ЗЗЛД



### 3.3 Configuration des échantillons / Samples configuration

Echantillon n° Sample n.	Section / Cross section (mm <sup>2</sup> )		Système de torsade Bundle system
1	50	50	Système autoporté Self supporting system
2			

### 4 Résultats / Results

Echantillon n° Sample n.	6 kV pendant 1 min 6 kV for 1 min	
	Exigences Requirements	Résultats Results
1	Pas de claquage No breakdown	Pas de claquage No breakdown
2		Pas de claquage No breakdown

Echantillon n° Sample n.	Vitesse de montée programmée Planned increase rate (N/min)	
	Exigences Requirements	Résultats Results
1	1000 ≤ ... ≤ 5000	3000
2		3000


Echantillon n° Sample n.	Effort pour marquage pendant 1 minute Strength for marking during 1 min (N)		Effort pendant 1 minute Strength during 1 min (N)	
	Exigences Requirements	Résultats Results	Exigences Requirements	Résultats Results
1	20 % CRM MBL ↔ 600	600	40 % CRM MBL ↔ 1200	1200
2		600		1200

### 5 Conclusion / Conclusion



Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
No breakdown or flashover occurred (tripping of voltage generator).

Aucun glissement ou rupture ne s'est produit.  
No slippage or breakage occurred.

На основании чл. 2  
от ЗЗЛД



6 Courbes / Curves




FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

ВАРНО С ОРГАНИЗАЦИЯ

На основание чл. 2  
от ЗЗЛД

386



СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 50



1. № на тест: 9212320 – Механичен тест;
2. № на тест: 1204121 - Тест за инсталиране при ниска температура.

На основание чл. 2  
от ЗЗЛД

Съставил:





Laboratoire d'essais  
LABEP

**Rapport d'essai** : Essai d'endurance sur conducteur de phase  
**Test report** : Endurance test on phase conductor

<b>Rapport d'essai n°</b>	: 12 09 301	<b>Test report n.</b>	: 12 09 301
<b>Constructeur</b>	: SICAME	<b>Product manufacturer</b>	: SICAME
<b>Référence produit</b>	: MJPT70	<b>Product reference</b>	: MJPT70
<b>Demandeur de l'essai</b>	: SICAME S.A.	<b>Test applied by</b>	: SICAME S.A.
<b>Date d'essai</b>	: du 10 octobre au 13 novembre 2012	<b>Date of the test</b>	: 10 October to 13 November 2012
<b>Date d'émission du rapport</b>	: 15 novembre 2012	<b>Report issue date</b>	: 15 November 2012

**Essais réalisés suivant :** NF EN 50483-4 (07/2009), § 8.2.7  
**Tests carried out in accordance with**

**Ce rapport comprend :** 9 pages  
**This report contains**

**Conclusion** : Les manchons de jonction préisolés SICAME de type MJPT70 soumis à essai satisfont aux exigences du § 8.2.7 de la norme NF EN 50483-4 (07/2009).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

**Conclusion** : The tested SICAME insulated splicing sleeves MJPT70 comply with the requirements of clause 8.2.7 of NF EN 50483-4 (July 2009) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not explicitly involved


На основание чл. 2  
от ЗЗЛД

D 0400 03

La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.  
With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 89 00 - Fax (33) 05 55 73 63 12 - Email : Info@sicame.fr

ВЪРЖО С ОРНИМАЛАТА



28/1


**1 Echantillons soumis à essai / Samples under test**

Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT70

Fabricant / Manufacturer : SICAME

Numéro de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700640  
*Samples in accordance with drawing n. E0700640*




Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 4

Repérage / Identification : 1, 2, 3, 4

Date de réception au laboratoire : 25 septembre 2012  
*Reception date at the laboratory : 25 September 2012*

*Handwritten signature or scribble on the right side.*



На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПИТИНАТА

## 2 Caractéristiques du matériel / Equipment used during test

### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir avec matrices E173 <i>Compression tool with dies E173</i>	5 tonnes <i>5 tons</i>
02 01 76	Thermomètre indicateur <i>Indicating thermometer</i>	Précision $\pm 2^{\circ}\text{C}$ <i>Accuracy <math>\pm 2^{\circ}\text{C}</math></i>
97 02 02	Réglet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
12 03 03	Conductimètre <i>Conductimeter</i>	Précision 30 $\mu\text{S}/\text{cm}$ <i>Accuracy <math>30\mu\text{S}/\text{cm}</math></i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectrimeter BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>
95 00 87	Armoire électrique n°9 <i>Electrical rack n°9</i>	Transformateur 1200A/7V commandé par unité thyristor au primaire et régulateur de température PID <i>Transformer 1200A/7V thyristor control unit used in the primary circuit and PID temperature controller</i>
05 00 34	Enregistreur Eurotherm <i>Eurotherm data recorder</i>	Mesure et enregistrement de température par thermocouple type T <i>Measurement and recording of temperatures by T-type thermocouples</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>

ВЪРНО С ОРНИГАЛАТА

На основание чл. 2  
от ЗЗЛД



## 2.2 Câbles / Cables

N° Lot / Identification	11029		
Norme / Standard	WT-92/K-396		
Provenance / From	Pologne / Poland		
Section / Cross section	70 mm <sup>2</sup>		
Matériau de l'âme Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	<input type="checkbox"/> Souple Flexible
	<input checked="" type="checkbox"/> Rétreinte Compacted	<input type="checkbox"/> Non rétreinte Non compacted	
Forme d'âme Conductor shape	<input checked="" type="checkbox"/> Ronde Circular	<input type="checkbox"/> Sectorale Sector-shaped	
Nombre de brins Number of wires	19		
Ø sur âme Ø on conductor	10,0 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé Cross-linked polyethylene		
Ø sur isolant Ø on insulation	13,1 mm		
Conditionnement Conditioned on	1h00 à 110°C 1h00 at 110°C		
Référence du câble HD626 HD626 conductor reference	/		
Charge de rupture minimale (CRM) / Minimum Breaking Load (MBL)	11242 N		

## 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.7 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur quatre manchons pour chaque section.

La charge, pour le type de système approprié, doit être appliquée aux extrémités du conducteur et ajustée comme demandé durant l'essai.

Des cycles thermiques, d'une durée de 90 min, doivent être appliqués au montage d'essai.

500 cycles doivent être réalisés.

Pendant les 45 premières minutes de chaque cycle, le courant traversant l'ensemble doit créer l'élévation de température.

La température de référence du conducteur doit être maintenue à la température normale de service dans un intervalle de  $\pm 3$  K comme indiqué dans l'Annexe C de la EN 50483-1. Cette température est atteinte dans un temps de 5 min à 15 min en début de cycle.

Pendant les 45 dernières minutes, de chaque cycle, le montage en essai doit être refroidi à  $(25 \pm 3)$  °C. La température doit ensuite être maintenue à cette valeur, jusqu'à la fin du cycle.

A intervalle de 24h, à la fin de la période de chauffage à la température normale de service, les températures atteintes par les deux manchons doivent être enregistrées.

На основании чл. 2  
от 33ЛД

ВЫПУСК СЕРТИФИКАТА

289

Insulated splicing sleeves are tested in accordance with NF EN 50483-4 (07/2009) §8.2.7 standard.

The test is carried out on 4 Insulated splicing sleeves for each cross-section.

The load, for the appropriate type of system, shall be applied to the extremities of the core and varied as required throughout the test.

Thermal cycles, with duration of 90 min, shall be applied to the test assembly.

There shall be 500 cycles.

For the first 45 minutes of every cycle, current flowing through the assembly shall create the temperature rise.


The reference temperature of the conductor shall be maintained at the normal operating temperature within an interval of  $\pm 3$  °C as shown in Table B.1 of Annexe B. this temperature shall be reached within 5 min to 15 min at the beginning of the cycle.

For the last 45 min, of each cycle, the test assembly shall be cooled to  $(25 \pm 3)$  °C. The temperature shall then be maintained, at this value, until the end of the cycle.

At 24 h intervals, at the end of the normal operating temperature heating period, the temperatures reached by the two sleeves shall be recorded.

La figure 1 décrit un exemple typique de dispositif d'essai. La configuration peut différer de ce montage du moment qu'elle respecte les longueurs du conducteur de phase

Figure 1 shows a typical test arrangement. The test configuration can differ from this arrangement as long as it complies with the phase conductor.



ВЯРНО С ОПИТИМАНЕ

На основание чл. 2  
от ЗЗЛД

La variation de la charge mécanique et de la température est décrite sur le diagramme de la Figure 2.

Un effort de traction doit être appliqué jusqu'à une valeur égale à 35 % de la CRM du câble. Cette valeur doit être atteinte approximativement en 1 min.

La charge doit ensuite être maintenue pendant 10 min par un réglage permanent manuel ou automatique. On doit laisser l'ensemble se stabiliser mécaniquement pendant 24 h sans aucun réglage.

Une fois l'ensemble stabilisé les cycles thermiques doivent commencer. A la fin du premier cycle, l'effort de traction doit être réglé à 20 % de la CRM du câble.

Au moins une fois par 24 h, l'effort de traction doit être ajusté à 20 % de la CRM du câble.

*The variation in mechanical load and temperature is shown, diagrammatically, in Figure 2.*

*A tensile load shall be applied until a value equal to 35 % of the MBL is reached. This value shall be achieved in approximately 1 minute.*

*The load shall then be maintained for 10 min using a manual or automatic continuous adjustment. The assembly shall be left to self stabilize mechanically for 24 h without any adjustment.*

*Once the assembly has stabilized the thermal cycles shall be started. At the end of the first cycle, the tensile load shall be set at 20 % of MBL.*

*At least once every 24 h, the tensile load shall be adjusted to 20 % of the MBL.*





Figure 2 – Diagramme des cycles thermiques et des contraintes mécaniques appliqués sur le conducteur de phase

Figure 2 – Diagram of thermal cycles and mechanical stresses applied on phase conductor



На основание чл. 2  
от ЗЗЛД

**Tableau 1 – Effort de traction appliqué**  
*Table 1 – Applied tensile load*

20 % de la CRM du câble <i>20 % of MBL</i> 2248 N	35% de la CRM du câble <i>35 % of MBL</i> 3934 N
---	--

La température normale de service du câble est de 80° C.  
*The rated operating temperature of the cable is 80° C.*

A la fin de la période de chauffage, la température des manchons doit être inférieure à la température du conducteur de référence.

Les manchons de Classe 1 et de Classe 2 doivent satisfaire aux exigences de l'essai de tenue diélectrique dans l'air, 8.2.3.1.3.2.

Pour les manchons de Classe 1, l'ensemble formé par le raccord et les conducteurs doit être ensuite retiré des billes métalliques, sans contrainte mécanique, et doit satisfaire aux exigences de l'essai de tenue diélectrique dans l'eau, comme indiqué au 8.2.3.1.3.1, mais avec une tension de 1 kV.

Les quatre manchons doivent satisfaire aux exigences de l'essai mécanique du § 8.2.2.

*At the end of the heating period, the sleeves' temperatures shall be lower than the temperature of the reference core.*

*The Class 1 and the Class 2 sleeves shall meet the requirements of the Dielectrical Voltage Test in Air, Clause 8.2.3.1.3.2.*

*For Class 1 sleeves the assembly formed by the connector and the cores shall then taken out of the metallic balls, without any mechanical stress, and shall meet the requirements of the dielectrical voltage test in water, Clause 8.2.3.1.3.1 but with a voltage of 1 kV.*


*The four sleeves shall meet the requirements of the mechanical test Clause 8.2.2.*

**3.1 Conditions ambiantes / Ambient conditions**

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
*Ambient conditions when performing the test are as follows:*

	<b>Exigences</b> <i>Requirements</i>	<b>Relevés</b> <i>Results</i>
<b>Température ambiante et humidité</b> <i>Ambient temperature and humidity conditions</i>	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	20 °C 39 %HR
<b>Température de l'eau</b> <i>Water temperature</i>	-	20,2 °C
<b>Résistivité de l'eau</b> <i>Water resistivity</i>	≤ 200 Ωm	39,9 Ωm
<b>Temps d'immersion</b> <i>Immersion time</i>	≥ 30 min	31 min
<b>Vitesse de montée en tension</b> <i>Voltage increase rate</i>	≈ 1 kV/s	≈ 1 kV/s

На основании чл. 2  
от ЗЗЛД



3.2 Configuration des échantillons / Samples configuration

Echantillon n° Sample n.	Section / Cross section (mm <sup>2</sup> )	
	Câble principal Main cable	Câble dérivé Tap cable
1	70	70
2		
3		
4		

4 Résultats / Results

4.1 Tenue diélectrique

Echantillon n° Sample n.	4 kV pendant 1 minute dans les billes métalliques 4 kV for 1 minute in metallic balls	
	Résultats / Results	Exigences Requirements
1	Pas de claquage / No breakdown	Pas de claquage No breakdown
2	Pas de claquage / No breakdown	
3	Pas de claquage / No breakdown	
4	Pas de claquage / No breakdown	

Echantillon n° Sample n.	1 kV pendant 1 minute dans l'eau 1 kV for 1 minute in water	
	Résultats / Results	Exigences Requirements
1	Pas de claquage / No breakdown	Pas de claquage No breakdown
2	Pas de claquage / No breakdown	
3	Pas de claquage / No breakdown	
4	Pas de claquage / No breakdown	

4.2 Essais mécaniques

Echantillon n° Sample n.	Vitesse de montée programmée Planned increase rate (N/min)	
		Exigences Requirements (N/min)
1	3000	1000 ≤ ... ≤ 5000
2	3000	
3	3000	
4	3000	

ВЪРНО С ОПИТИНАТА

На основание чл. 2  
от ЗЗЛД

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	2248	20 % CRM MBL
2	2248	
3	2248	
4	2248	

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	9555	85 % CRM MBL
2	9555	
3	9555	
4	9555	

**5 Conclusion / Conclusion**

Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
*No breakdown or flashover occurred (tripping of voltage generator).*

Aucun glissement ou rupture ne s'est produit.  
*No slippage or breakage occurred.*

FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

ВЯРНО С ОПИТИВАТА

На основание чл. 2  
от ЗЗЛД

396



**sicame**

Laboratoire d'essais  
Direction Etudes et Recherches

Test report : Tensile test  
Test number : 07 01 081  
Product brand : SICAME  
Product type : MJPT 70

Demandeur of the test : SICAME Export  
Starting date of the test : 09/01/2007  
Report emission date : 16 JAN. 2007  
According to standard : NF C 33-021 § 2.3.2 (juin 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested preinsulated junction sleeves type MJPT 70 conform to the requirements of NF C 33-021 § 2.3.2 (juin 98) with a 85% maximum load of the cable tensile instead of 60% required by the standard and with cables of Vietnam.

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

ВЯРНО С ОРИГИНАЛА



**1. Equipment used during test.****1.1 Equipment used**

N° U.T.	Designation	Characteristic
93 05 48	Crimping machine	50 kN
94 03 10	Traction bench 3 tons	Class 1

**1.2 Cables :**

Section (mm <sup>2</sup> )	70
Nature	Aluminium
Standard	/
From	Vietnam
Identification n°	06082

**2. Product tested.**

Désignation : MJPT 70

Number : 2

Batch number : sample 1 : embossed date : 09/2006 (06M621000)  
Sample 2 : embossed date : 01/2004 (customer's one)

Marking : See annex 1

Identification : 1 and 2

Reception date at the laboratory : on the 08/01/2007 for the sample 1  
and on the 14/12/2006 for the sample 2

ВЪРНО С ОПРИГНАЛАТА

На основание чл. 2  
от ЗЗЛД



**3. Test.**

Preinsulated junction sleeves are tested according to NF C 33-021 § 2.3.2 (june 98) standard except that the stage of strength was of 65% of the minimum load during one hour instead of 50% of the minimum load during one minute and with a 85% maximum load of the cable tensile instead of 60% required for the guarantee.

**3.1 Test procedure.**

Connection is carried out using 5 mm wide dies for groove E 140 and 9 mm wide dies for grooves E 173 and E 215. The minimum strength to be applied is given in the standard. The length of the cores used complies with the length indicated in the standard.

The assembly is submitted to a tensile strength applied to the conductor. The strength is increased at a rate between 1000 N/min and 5000 N/min up to 65% of the minimum load required. This strength is applied for 1 hour.

The strength is then increased up to 85% of the maximum load of the cable and released.

**3.2 Preparation**

A 9 mm wide dies for groove E173 is used.

**4. Results.**


	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	22°C 46 % HR
Rate of the tensile (N/min)	Between 1000 et 5000	3000
Strength value maintained for 1 hour (N)	5415	Sample 1 : ok Sample 2 : ok
Strength value applied without breakdown : 85% of the maximum load of the cable (N)	8330	Sample 1 : ok Sample 2 : ok

*[Handwritten signature]*

**5. Requirement**

No slippage is observed.

*[Handwritten signature]*




На основание чл. 2  
от ЗЗЛД

*[Handwritten marks]* 397


SICAME LABORATORY

Test report number 0701081

Annex 1




ВЯРНО С ОРИГИНАЛА





**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 70**

1. № на тест 9212350 – Механичен тест;
2. № на тест 1209301 – Тест за издръжливост върху фазовия проводник;
3. № на тест 0701081 – Тест за якост на опън.



На основание чл. 2  
от ЗЗЛД

Съставил:





Laboratoire d'essais  
LABEP

**Rapport d'essai** : Essai d'endurance sur conducteur de phase  
**Test report** : Endurance test on phase conductor

Rapport d'essai n°	: 12 09 303	Test report n.	: 12 09 303
Constructeur	: SICAME	Product manufacturer	: SICAME
Référence produit	: MJPT95	Product reference	: MJPT95
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: du 10 octobre au 13 novembre 2012	Date of the test	: 10 October to 13 November 2012
Date d'émission du rapport	: 15 novembre 2012	Report issue date	: 15 November 2012

Essais réalisés suivant : NF EN 50483-4 (07/2009), § 8.2.7  
*Tests carried out in accordance with*

Ce rapport comprend : 9 pages  
*This report contains*

**Conclusion** : Les manchons de jonction préisolés SICAME de type MJPT95 soumis à essai satisfont aux exigences du § 8.2.7 de la norme NF EN 50483-4 (07/2009).  
*For declaring the conformity, it has not been explicitly taken into account the uncertainty associated with the result.*

**Conclusion** : The tested SICAME insulated splicing sleeves MJPT95 comply with the requirements of clause 8.2.7 of NF EN 50483-4 (July 2009) standard.  
*To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved*

На основании чл. 2  
от 33ЛД

D 0400 03

La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.  
*With the authorization of Sicame S.A., this report may only be reproduced in its totality.*

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 89 00 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr

ВЕРНО С ОРИГИНАЛОМ



400

**1 Echantillons soumis à essai / Samples under test**

Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT95

Fabricant / Manufacturer : SICAME


Numéro de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700640  
*Samples in accordance with drawing n. E0700640*

Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 4

Repérage / Identification : 1, 2, 3, 4

Date de réception au laboratoire : 25 septembre 2012  
*Reception date at the laboratory : 25 September 2012*



**ВЪРЖНО С ОРИГИНАЛАТА**

На основание чл. 2  
от ЗЗЛД

**2 Caractéristiques du matériel / Equipment used during test**

**2.1 Appareillage utilisé / Equipment used**

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir avec matrices E173 <i>Compression tool with dies E173</i>	5 tonnes <i>5 tons</i>
02 01 76	Thermomètre indicateur <i>Indicating thermometer</i>	Précision ± 2°C <i>Accuracy ± 2°C</i>
97 02 02	Règlet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision 1°C <i>Accuracy 1°C</i>
12 03 03	Conductimètre <i>Conductimeter</i>	Précision 30 µS/cm <i>Accuracy 30 µS/cm</i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectrimer BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>
95 00 87	Armoire électrique n°9 <i>Electrical rack n°9</i>	Transformateur 1200A/7V commandé par unité thyristor au primaire et régulateur de température PID <i>Transformer 1200A/7V thyristor control unit used in the primary circuit and PID temperature controller</i>
05 00 34	Enregistreur Eurotherm <i>Eurotherm data recorder</i>	Mesure et enregistrement de température par thermocouple type T <i>Measurement and recording of temperatures by T-type thermocouples</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>

ВАРНО С ОПИРАНАТА

На основание чл. 2 от ЗЗЛД

407

## 2.2 Câbles / Cables

N° Lot / Identification	11029		
Norme / Standard	WT-92/K-396		
Provenance / From	Pologne / Poland		
Section / Cross section	95 mm <sup>2</sup>		
Matériau de l'âme Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	<input type="checkbox"/> Souple Flexible
Forme d'âme Conductor shape	<input checked="" type="checkbox"/> Rétreinte Compacted	<input type="checkbox"/> Non rétreinte Non compacted	<input type="checkbox"/> Sectorale Sector-shaped
Nombre de brins Number of wires	19		
Ø sur âme Ø on conductor	13,1 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé Cross-linked polyethylene		
Ø sur isolant Ø on insulation	16,1 mm		
Conditionnement Conditioned on	1h00 à 110°C 1h00 at 110°C		
Référence du câble HD626 HD626 conductor reference	/		
Charge de rupture minimale (CRM) / Minimum Breaking Load (MBL)	11242 N		

## 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.7 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur quatre manchons pour chaque section.

La charge, pour le type de système approprié, doit être appliquée aux extrémités du conducteur et ajustée comme demandé durant l'essai.

Des cycles thermiques, d'une durée de 90 min, doivent être appliqués au montage d'essai.


500 cycles doivent être réalisés.

Pendant les 45 premières minutes de chaque cycle, le courant traversant l'ensemble doit créer l'élévation de température.

La température de référence du conducteur doit être maintenue à la température normale de service dans un intervalle de  $\pm 3$  K comme indiqué dans l'Annexe C de la EN 50483-1. Cette température est atteinte dans un temps de 5 min à 15 min en début de cycle.

Pendant les 45 dernières minutes, de chaque cycle, le montage en essai doit être refroidi à  $(25 \pm 3)$  °C. La température doit ensuite être maintenue à cette valeur, jusqu'à la fin du cycle.

A intervalle de 24h, à la fin de la période de chauffage à la température normale de service, les températures atteintes par les deux manchons doivent être enregistrées.



На основание чл. 2  
от ЗЗЛД

Insulated splicing sleeves are tested in accordance with NF EN 50483-4 (07/2009) §8.2.7 standard.

The test is carried out on 4 Insulated splicing sleeves for each cross-section.

The load, for the appropriate type of system, shall be applied to the extremities of the core and varied as required throughout the test.

Thermal cycles, with duration of 90 min, shall be applied to the test assembly.

There shall be 500 cycles.

For the first 45 minutes of every cycle, current flowing through the assembly shall create the temperature rise.


The reference temperature of the conductor shall be maintained at the normal operating temperature within an interval of  $\pm 3$  °C as shown in Table B.1 of Annexe B, this temperature shall be reached within 5 min to 15 min at the beginning of the cycle.

For the last 45 min, of each cycle, the test assembly shall be cooled to  $(25 \pm 3)$  °C. The temperature shall then be maintained, at this value, until the end of the cycle.

At 24 h intervals, at the end of the normal operating temperature heating period, the temperatures reached by the two sleeves shall be recorded.

La figure 1 décrit un exemple typique de dispositif d'essai. La configuration peut différer de ce montage du moment qu'elle respecte les longueurs du conducteur de phase

Figure 1 shows a typical test arrangement. The test configuration can differ from this arrangement as long as it complies with the phase conductor.



На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОРИГИНАЛАТА



La variation de la charge mécanique et de la température est décrite sur le diagramme de la Figure 2.

Un effort de traction doit être appliqué jusqu'à une valeur égale à 35 % de la CRM du câble. Cette valeur doit être atteinte approximativement en 1 min.

La charge doit ensuite être maintenue pendant 10 min par un réglage permanent manuel ou automatique. On doit laisser l'ensemble se stabiliser mécaniquement pendant 24 h sans aucun réglage.

Une fois l'ensemble stabilisé les cycles thermiques doivent commencer. A la fin du premier cycle, l'effort de traction doit être réglé à 20 % de la CRM du câble.

Au moins une fois par 24 h, l'effort de traction doit être ajusté à 20 % de la CRM du câble.

*The variation in mechanical load and temperature is shown, diagrammatically, in Figure 2.*

*A tensile load shall be applied until a value equal to 35 % of the MBL is reached. This value shall be achieved in approximately 1 minute.*

*The load shall then be maintained for 10 min using a manual or automatic continuous adjustment. The assembly shall be left to self stabilize mechanically for 24 h without any adjustment.*

*Once the assembly has stabilized the thermal cycles shall be started. At the end of the first cycle, the tensile load shall be set at 20 % of MBL.*

*At least once every 24 h, the tensile load shall be adjusted to 20 % of the MBL.*





Figure 2 – Diagramme des cycles thermiques et des contraintes mécaniques appliqués sur le conducteur de phase

Figure 2 – Diagram of thermal cycles and mechanical stresses applied on phase conductor



На основание чл. 2  
от ЗЗЛД

405

Tableau 1 – Effort de traction appliqué  
 Table 1 – Applied tensile load

20 % de la CRM du câble 20 % of MBL 2248 N	35% de la CRM du câble 35 % of MBL 3934 N
--	---

La température normale de service du câble est de 80° C.  
 The rated operating temperature of the cable is 80° C.

A la fin de la période de chauffage, la température des manchons doit être inférieure à la température du conducteur de référence.

Les manchons de Classe 1 et de Classe 2 doivent satisfaire aux exigences de l'essai de tenue diélectrique dans l'air, 8.2.3.1.3.2.

Pour les manchons de Classe 1, l'ensemble formé par le raccord et les conducteurs doit être ensuite retiré des billes métalliques, sans contrainte mécanique, et doit satisfaire aux exigences de l'essai de tenue diélectrique dans l'eau, comme indiqué au 8.2.3.1.3.1, mais avec une tension de 1 kV.

Les quatre manchons doivent satisfaire aux exigences de l'essai mécanique du § 8.2.2.

At the end of the heating period, the sleeves' temperatures shall be lower than the temperature of the reference core.

The Class 1 and the Class 2 sleeves shall meet the requirements of the Dielectrical Voltage Test in Air, Clause 8.2.3.1.3.2.

For Class 1 sleeves the assembly formed by the connector and the cores shall then taken out of the metallic balls, without any mechanical stress, and shall meet the requirements of the dielectrical voltage test in water, Clause 8.2.3.1.3.1 but with a voltage of 1 kV.


The four sleeves shall meet the requirements of the mechanical test Clause 8.2.2.

### 3.1 Conditions ambiantes / Ambient conditions

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
 Ambient conditions when performing the test are as follows:

	Exigences Requirements	Relevés Results
Température ambiante et humidité Ambient temperature and humidity conditions	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	20 °C 39 %HR
Température de l'eau Water temperature	-	20,2 °C
Résistivité de l'eau Water resistivity	≤ 200 Ωm	39,9 Ωm
Temps d'immersion Immersion time	≥ 30 min	31 min
Vitesse de montée en tension Voltage increase rate	≈ 1 kV/s	≈ 1 kV/s

На основании чл. 2  
от ЗЗЛД



3.2 Configuration des échantillons / Samples configuration

Echantillon n° Sample n.	Section / Cross section (mm²)	
	Câble principal Main cable	Câble dérivé Tap cable
1	95	95
2		
3		
4		

4 Résultats / Results


4.1 Tenue diélectrique

Echantillon n° Sample n.	4 kV pendant 1 minute dans les billes métalliques 4 kV for 1 minute in metallic balls	
	Résultats / Results	Exigences Requirements
1	Pas de claquage / No breakdown	Pas de claquage No breakdown
2	Pas de claquage / No breakdown	
3	Pas de claquage / No breakdown	
4	Pas de claquage / No breakdown	

Echantillon n° Sample n.	1 kV pendant 1 minute dans l'eau 1 kV for 1 minute in water	
	Résultats / Results	Exigences Requirements
1	Pas de claquage / No breakdown	Pas de claquage No breakdown
2	Pas de claquage / No breakdown	
3	Pas de claquage / No breakdown	
4	Pas de claquage / No breakdown	

4.2 Essais mécaniques

Echantillon n° Sample n.	Vitesse de montée programmée Planned increase rate (N/min)	
		Exigences Requirements (N/min)
1	3000	1000 ≤ ... ≤ 5000
2	3000	
3	3000	
4	3000	



На основание чл. 2  
от ЗЗЛД

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	2248	20 % CRM MBL
2	2248	
3	2248	
4	2248	

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	9555	85 % CRM MBL
2	9555	
3	9555	
4	9555	

**5 Conclusion / Conclusion**

Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
No breakdown or flashover occurred (tripping of voltage generator).

Aucun glissement ou rupture ne s'est produit.  
No slippage or breakage occurred.

FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

ВЕРНО С ОПИТИВАНАТА




На основание чл. 2  
от ЗЗЛД

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 95**

1. № на тест 1209303 - Тест за издръжливост върху фазовия проводник.

На основание чл. 2  
от ЗЗЛД

Съставил:





Laboratoire d'essais  
LABEP

**Rapport d'essai** : Essai de vieillissement électrique  
**Test report** : Electrical ageing test

<b>Rapport d'essai n°</b>	: 1201231	<b>Test report n.</b>	: 1201231
<b>Constructeur</b>	: SICAME	<b>Manufacturer</b>	: SICAME
<b>Référence produit</b>	: MJPT150	<b>Product reference</b>	: MJPT150
<b>Demandeur de l'essai</b>	: SICAME S.A.	<b>Test applied by</b>	: SICAME S.A.
<b>Date d'essai</b>	: Du 15 juin au 09 septembre 2012	<b>Date of the test</b>	: 15 <sup>th</sup> June to 09 <sup>th</sup> September 2012
<b>Date d'émission du rapport</b>	: 25 septembre 2012	<b>Report issue date</b>	: 25 <sup>th</sup> September 2012

**Essais réalisés suivant :** NF EN 50483-5 (07/2009)  
**Tests carried out in accordance with**

**Ce rapport comprend :** 11 pages  
**This report contains**

**Conclusion** : Les manchons de jonction préisolés SICAME de type MJPT150 soumis à essai satisfont aux exigences de la norme NF EN 50483-5 (07/2009)  
Pour déclarer la conformité, il n'a pas été tenu compte de l'incertitude associée au résultat.



**Conclusion** : The tested SICAME preinsulated splicing sleeves MJPT150 comply with the requirements of NF EN 50483-5 (July 2009) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основание чл. 2  
от ЗЗЛД

D 0400 03

La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.  
With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 89 00 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr



**1 Echantillons soumis à essai / Samples under test**

Type : Manchons de jonction préisolés  
Preinsulated splicing sleeves


Désignation / Designation : MJPT150  
Fabricant / Manufacturer : SICAME  
Numéro de lot / Batch number : M327850

Plage de section / Cross-section range : 150 mm<sup>2</sup>

Classe du produit selon NF EN 50483-1 (§9.3) Class of product in accordance with NF EN 50483-1 (§9.3)	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit Class A : connectors subjected to heat cycles and short-circuit tests
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique Class B : connectors subjected to heat cycles only
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau Class 1 : connectors subjected to dielectric test in water
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air Class 2 : connectors subjected to dielectric test in air

Nombre d'échantillons / Number of samples : 6  
Repérage / Identification : 1, 2, 3, 4, 5, 6

Date de réception au laboratoire : le 12 janvier 2012  
Reception date at the laboratory : on January, 12<sup>th</sup> 2012



ВАРНО С ОБИТОВАНАТА

На основание чл. 2  
от ЗЗЛД

## 2 Caractéristiques du matériel / Equipment used during test

### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristics
100203	Centrale d'acquisition <i>Measurement acquisition</i>	Thermocouples type J <i>Type J thermocouples</i>
930548	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrice <i>Die</i>	E215 largeur 9 mm <i>E215 width 9 mm</i>
970202	Réglet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
980196	Pince ampèremétrique <i>Handheld clamp meter</i>	2000 A
090460	Banc électrique BC6 <i>Electrical bench BC6</i>	-
039221	Banc de court-circuits <i>Short circuit bench</i>	-
790059		-
#12	Thermomètre indicateur <i>Indicating thermometer</i>	-

### 2.2 Câbles utilisés / Cables used

N° Lot / Identification	09003		
Norme / Standard	NF C 33-209		
Provenance / From	France		
Section / Cross section	150 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	<input type="checkbox"/> Souple <i>Flexible</i>
	<input checked="" type="checkbox"/> Rétreinte <i>Compacted</i>	<input type="checkbox"/> Non rétreinte <i>Non compacted</i>	
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nb de brins / N. of wires	19		
Ø sur âme / Ø conductor	14,5 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TLX-5 <i>Cross-linked polyethylene, TLX-5 type</i>		
Ø sur isolant / Ø insulation	18 mm		
Référence du câble HD626 / HD626 conductor reference	6 K-1		

На основание чл. 2  
от ЗЗЛД

ВЪРЖО С ОРГАНИЗАЦИЯТА



### 3 Méthode d'essai / Test method

Les modalités d'essai sont celles de la norme NF EN 50483-5 de juillet 2009.

*Test procedures are in accordance with NF EN 50483-5 (July 2009) standard.*

#### 3.1 Conditions de montage des échantillons / Conditions during installation of the samples

Les conditions ambiantes relevées lors du montage des raccords sont les suivantes :

*Ambient conditions when installing the connectors assembly are as follows :*

	Exigences <i>Requirements</i>	Relevés <i>Results</i>
Température ambiante et humidité <i>Ambient temperature and humidity conditions</i>	20 °C ≤ T° ≤ 26 °C 25 % ≤ HR ≤ 75 %	22,0 °C 42 %HR

Echantillon n° <i>Sample n.</i>	Section/ Cross section (mm²)	
	Câble principal <i>Main cable</i>	Câble dérivé <i>Tap cable</i>
1	150	150
2		
3		
4		
5		
6		

#### 3.2 Conditions d'essai / Test conditions

Le banc d'essai est situé dans le laboratoire, à l'abri des courants d'air éventuel.

La température climatisée du laboratoire est maintenu entre 20°C et 26°C.

Les parois verticales sont distantes de plus de 0,3 m de la boucle d'essai.

Les plans horizontaux sont éloignés de plus de 0,6 m du plan de la boucle d'essai.

Les égaliseurs sont soudés.


*The testing bench is located in the laboratory, with the shelter of the possible draught.*

*Ambient temperature of the air-conditioned laboratory is maintained in the range 20-26°C.*

*Vertical walls are distant of more than 0,3 m of the test loop.*

*Horizontal planes are distant of more than 0,6 m of the plan of the test loop.*

*Equalizers are produced by welding.*



На основании чл. 2  
от ЗЗЛД


413

3.3 Configuration de la boucle d'essai / Test loop configuration

Boucle d'essai selon NF EN 50483-5 / Test loop in accordance with NF EN 50483-5	
<input type="checkbox"/>	Boucle d'essai pour raccords de dérivation avec conducteur principal et dérivé ayant des sections et des résistances linéiques égales. <i>Test branch connectors with main and branch conductors having equal cross-sections and linear resistances.</i>
<input type="checkbox"/>	Boucle d'essai pour raccords de dérivation avec conducteur principal et dérivé ayant des sections et des résistances linéiques inégales. <i>Test loop for branch connectors with main branch and branch conductors having unequal cross-sections and linear resistances.</i>
<input checked="" type="checkbox"/>	Boucle d'essai pour raccords de jonction avec conducteurs ayant des sections et des résistances linéiques égales ou inégales. <i>Test loop for through connectors with conductors having equal or unequal cross-sections and linear resistances.</i>
<input type="checkbox"/>	Boucle d'essai pour cosses pré-isolées. <i>Test loop for pre-insulated lugs.</i>

Paramètres de la boucle d'essai / Test loop parameters	
Section du câble principal / Main cable cross section	: 150 mm <sup>2</sup>
Longueur l <sub>a</sub> / Length l <sub>a</sub>	: 250 mm
Longueur l <sub>b</sub> / Length l <sub>b</sub>	: 250 mm
Longueur l <sub>r</sub> / Length l <sub>r</sub>	: 512 mm
Nombre de cycles / Number of cycles	: 1000
Consigne de temperature / Temperature setting	: 98,0 °C
Courant de chauffe / Heating current	: 446 A
Durée de chauffe / Heating time	: 60 min
Durée de refroidissement / Cooling time	: 40 min
Courant continu de mesure / D.C measuring current	: 19 A

3.4 Premier cycle thermique / First heat cycle



ВАРНО С ОБНОВЛЕНА

На основание чл. 2  
от ЗЗЛД

3.5 Court-circuits / Short circuits

Raccord Connector	N°	Temps Time (s)	I <sub>rms</sub> (A)	I <sup>2</sup> .t (kA <sup>2</sup> .s)	Températures maximales / Maximum temperatures (°C)		
					Raccords / Connectors		Du câble (calculée) / of cable (calculated)
					N°1	N°2	
1, 2	1	1,109	16679	308,5	152,8	151,8	252,2
	2	1,120	16592	321,8	162,8	164,5	265,8
	3	1,108	16887	316,1	162,9	162,2	259,9
	4	1,108	16845	314,5	165,0	166,5	258,3
	5	1,110	16367	297,4	158,2	158,8	241,2
	6	1,119	16616	308,9	165,3	165,2	252,6
					N°3	N°4	
3, 4	1	1,160	15874	292,1	132,1	135,7	235,8
	2	1,077	16743	302,0	139,1	141,8	244,1
	3	1,110	16613	306,3	144,1	147,1	250,0
	4	1,136	16743	318,4	152,5	154,5	261,5
	5	1,130	16758	319,5	153,6	155,7	258,4
	6	1,145	16517	312,4	160,9	159,9	253,3
					N°5	N°6	
5, 6	1	1,140	16901	325,8	142,0	143,0	267,0
	2	1,100	16732	307,1	144,0	136,5	248,1
	3	1,129	16540	309,0	150,0	139,7	250,4
	4	1,156	16586	317,9	156,3	148,5	260,6
	5	1,150	16650	318,9	158,2	150,2	262,7
	6	1,128	16557	309,3	154,6	146,9	253,0

*[Handwritten signature]*

*[Handwritten signature]*

**ВЯРНО С ОРГАНИЗАЦИЯ**

На основание чл. 2  
от ЗЗЛД


445

### 4 Résultats / Results

#### 4.1 Tableau des résistances / Table of resistances

Résistances $R_j$ / $R_j$ resistances ( $\mu\Omega$ )						
Cycle	Raccord n° / Connector n.					
	1	2	3	4	5	6
0	11,2	12,2	12,2	12,4	11,6	11,9
200 av cc	11,6	12,5	12,7	12,9	12,0	12,3
200 ap cc	17,0	17,1	18,8	18,7	14,9	16,2
250	17,0	17,4	19,4	19,6	15,0	16,3
325	17,1	17,5	19,6	19,8	15,1	16,5
400	17,1	17,4	19,6	19,8	15,2	16,5
475	17,1	17,5	19,6	19,9	15,2	16,5
550	17,1	17,4	19,6	19,9	15,2	16,5
625	17,2	17,5	19,7	19,9	15,2	16,6
700	17,2	17,5	19,7	19,9	15,2	16,6
775	17,2	17,5	19,7	20,0	15,3	16,6
850	17,1	17,5	19,7	19,9	15,2	16,6
925	17,2	17,5	19,7	20,0	15,3	16,6
1000	17,2	17,5	19,7	20,0	15,2	16,6

Résistances  $R_j$




ВАРНО С ОБЯЗАННОСТ

На основание чл. 2  
от ЗЗЛД

4.2 Tableau des températures / Table of temperatures (°C)

Cycle	Températures maximales / Maximum temperatures (°C)						
	Raccord n° / Connector n.						Câble / Cable 150 mm²
	1	2	3	4	5	6	
0	-	-	-	-	-	-	-
200	85,5	83,4	79,5	82,8	80,9	82,2	98,2
200	-	-	-	-	-	-	-
250	89,6	87,5	86,2	85,9	85,8	84,8	98,1
325	89,6	88,5	87,0	86,0	86,1	85,5	98,1
400	89,6	88,4	86,8	86,1	85,9	85,6	98,2
475	90,4	88,7	88,3	86,0	86,0	85,0	98,2
550	90,1	88,6	87,5	86,2	86,4	86,1	98,2
625	90,3	88,4	87,4	86,1	86,1	85,5	98,0
700	90,3	88,4	87,7	86,5	86,3	85,8	98,1
775	90,3	88,8	88,2	86,5	86,5	85,9	98,2
850	90,8	88,7	87,8	86,6	86,5	86,3	98,1
925	90,5	88,9	87,4	86,5	86,4	86,0	98,0
1000	90,2	89,1	88,0	86,8	86,4	85,9	98,2

Températures à chaud



ВЯРНО С ОДИНАКОВИ

На основание чл. 2  
от ЗЗЛД

447

5 Résultats statistiques / Statistical results

5.1 Calculs statistiques / Statistical calculations

		Exigences Requirements
$\bar{R}_j$	11,905	-
$S_0$	0,439	-
$\delta$	0,06	$\leq 0,3$

	Raccord n° / Connector n.						Exigences Requirements
	1	2	3	4	5	6	
$\bar{R}_j$	17,14	17,47	19,64	19,89	15,19	16,53	-
$s(\bar{R}_j)$	17,64						-
$\beta$	0,17						$\leq 0,3$

5.2 Evaluation de la stabilité de la résistance / Assessment of resistance stability

Raccord n° Connector n.	$R_j$ ( $\mu\Omega$ )			Stabilité Stability	Exigences Requirements
	Min.	Moy. / Ave	Max		
1	17,0	17,1	17,2	0,96%	$\leq 15\%$
2	17,4	17,5	17,5	1,07%	
3	19,4	19,6	19,7	1,65%	
4	19,6	19,9	20,0	1,96%	
5	15,0	15,2	15,3	1,95%	
6	16,3	16,5	16,6	1,85%	

5.3 Rapports de résistance / Resistance factor ratios

Cycles	$\lambda_j$					
	1	2	3	4	5	6
0	-	-	-	-	-	-
250	1,52	1,43	1,59	1,58	1,29	1,37
325	1,53	1,44	1,61	1,60	1,30	1,39
400	1,53	1,43	1,61	1,60	1,31	1,39
475	1,53	1,44	1,61	1,60	1,31	1,39
550	1,53	1,44	1,61	1,60	1,31	1,39
625	1,53	1,44	1,62	1,61	1,31	1,39
700	1,53	1,44	1,62	1,61	1,31	1,39
775	1,53	1,44	1,62	1,61	1,32	1,40
850	1,53	1,44	1,62	1,61	1,31	1,39
925	1,53	1,44	1,62	1,61	1,32	1,39
1000	1,53	1,44	1,62	1,61	1,31	1,39
Exigences Requirements	$\leq 2$	$\leq 2$	$\leq 2$	$\leq 2$	$\leq 2$	$\leq 2$

На основание чл. 2  
от ЗЗЛД

ВАРНО С ОПИТИВАНАТА

5.4 Stabilité de la température / Temperature stability ( $\Delta\theta_j$ )

Cycles	$\Delta\theta_j$ (°C)					
	1	2	3	4	5	6
0	-	-	-	-	-	-
250	8,46	10,56	11,86	12,16	12,26	13,26
325	8,48	9,58	11,08	12,08	11,98	12,58
400	8,56	9,76	11,36	12,06	12,26	12,56
475	7,78	9,48	9,88	12,18	12,18	13,18
550	8,14	9,64	10,74	12,04	11,84	12,14
625	7,71	9,61	10,61	11,91	11,91	12,51
700	7,83	9,73	10,43	11,63	11,83	12,33
775	7,93	9,43	10,03	11,73	11,73	12,33
850	7,27	9,37	10,27	11,47	11,57	11,77
925	7,53	9,13	10,63	11,53	11,63	12,03
1000	8,00	9,10	10,20	11,40	11,80	12,30

Raccord n° Connector n.	Moy. Ave.	$\Delta\theta_j$ (°C)				Exigences / Requirements
		$\overline{\Delta\theta_j} - 10$	Min.	Max.	$\overline{\Delta\theta_j} + 10$	$\overline{\Delta\theta_j} - 10 \leq \Delta\theta_j \leq \overline{\Delta\theta_j} + 10$
1	8,0	-2,0	7,3	8,6	18,0	Conforme / Compliant
2	9,6	-0,4	9,1	10,6	19,6	
3	10,6	0,6	9,9	11,9	20,6	
4	11,8	1,8	11,4	12,2	21,8	
5	11,9	1,9	11,8	12,3	21,9	
6	12,5	2,5	11,8	13,3	22,5	

5.5 Température maximale  $\theta_j$  de chaque raccord / Maximum temperature  $\theta_j$  of each connector.


Raccord n° Connector n.	$\theta_j$ Max (°C)	$\theta_r$ (°C)	Exigences Requirements
1	90,8	98,2	$\theta_j$ Max $\leq \theta_r$
2	89,1		
3	88,3		
4	86,8		
5	86,5		
6	86,3		

ВЕРНО С ОПРИМНАТА

На основание чл. 2  
от ЗЗЛД

4/19

6 Photo de la boucle d'essai / Photo of the test loop



FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

*[Handwritten signature]*

ВЯРНО С ОРНИКАЦИЯТА

На основание чл. 2  
от ЗЗЛД

1.02





СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 150

1. № на тест: 9212370 - Механичен тест.
2. № на тест: 1201231 - Тест за стареене под въздействието на електричество.

Съставил:

На основание чл. 2  
от ЗЗЛД





Laboratoire d'essais  
de la Direction **Etudes et Recherches**

Rapport d'essai : Essai de montage à basse température  
Test report : Installation test at low temperature

Rapport d'essai n°	: 12 04 125	Test report n.	: 12 04 125
Constructeur	: SICAME	Product brand	: SICAME
Référence produit	: MJPT50-25	Product type	: MJPT50-25
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: Du 17 au 18 avril 2012	Date of the test	: 17 to 18 April 2012
Date d'émission du rapport	: 15 mai 2012	Report emission date	: 15 May 2012

Essais réalisés suivant : NF EN 50483-4 (07/2009), § 8.2.4  
Tests carried out in accordance with

Ce rapport comprend : 9 pages  
This report contains

Conclusion : Les manchons de jonction préisolés SICAME de type MJPT 50-25 soumis à essai satisfont aux exigences du § 8.2.4 de la norme NF EN 50483-4 (07/2009).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

Conclusion : The tested SICAME insulated splicing sleeves MJPT 50-25 comply with the requirements of clause 8.2.4 of NF EN 50483-4 (07/2009) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основание чл. 2  
от ЗЗЛД

L'accréditation de la section essais du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation. Ce rapport ne concerne que les produits référencés ci-dessus. La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.

Accreditation 1-1068. Scope on request.  
The Cofrac testing section accreditation ensures the competence of the Laboratory staff for the tests for which the laboratory has qualified. This report applies only to the products as tested above. With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 65 73 89 00 - Fax (33) 05 55 73 83 12 - Email : info@sicame.fr


ACCREDITATION  
N° 1-1068  
PORTÉE  
DISPONIBLE SUR  
www.cofrac.fr

cofrac



0 0194 03

ВАРНО С ОРГАНИЗАТА



**1 Echantillons soumis à essai / Samples under test**

Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT 50-25

Matière de la jupe / over molding material : KEPITAL

Fabricant / Manufacturer : SICAME


Numéro de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700610  
*Samples in accordance with drawing n. E0700610*

Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 2

Repérage / Identification : 1, 2

Date de réception au laboratoire : 3 avril 2012  
*Reception date at the laboratory : 03 April 2012*



На основании чл. 2  
от 33ЛД

ВЯРНО С ОРНИВАНАТА

## 2 Caractéristiques du matériel / Equipment used during test

### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
99 01 48	Thermomètre indicateur <i>Indicating thermometer</i>	Précision $\pm 2^{\circ}\text{C}$ <i>Accuracy <math>\pm 2^{\circ}\text{C}</math></i>
97 02 02	Règlet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
10 03 21	Chambre froide <i>Low temperature chamber</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
99 00 41	Conductimètre <i>Conductimeter</i>	Précision 30 $\mu\text{S/cm}$ <i>Accuracy 30 <math>\mu\text{S/cm}</math></i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectrimer BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>

### 2.2 Câbles / Cables

N° Lot / Identification	07021		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	50 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	
	<input type="checkbox"/> Rétreinte <i>Compacted</i>	<input checked="" type="checkbox"/> Non rétreinte <i>Non compacted</i>	<input type="checkbox"/> Souple <i>Flexible</i>
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	9,00 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 <i>Cross-linked polyethylene, TIX-5 type</i>		
Ø sur isolant / Ø on insulation	11,45 mm		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Référence du câble HD626 HD626 conductor reference	4 B-1		
Charge de rupture minimale Minimum breaking load	3 000 N		

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПРЕДЕЛЕНИЕ

N° Lot / Identification	08006		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	25 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme / Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	
	<input checked="" type="checkbox"/> Rétreinte Compacted	<input type="checkbox"/> Non rétreinte Non compacted	<input type="checkbox"/> Souple Flexible
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde Circular	<input type="checkbox"/> Sectorale Sector-shaped	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	6,05 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 Cross-linked polyethylene, TIX-5 type		
Ø sur isolant / Ø on insulation	9,00 mm		
Conditionnement Conditioned on	1h00 à 120°C 1h00 at 120°C		
Référence du câble HD626 HD626 conductor reference	6 E-1		
Charge de rupture minimale Minimum breaking load	4 200 N		

### 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.4 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur deux manchons pour chaque section. Les raccords, le conducteur et les outillages sont au préalable pré-conditionnés jusqu'à la température d'essai (-10 ± 3) °C, ensuite ils sont assemblés à cette température dans la chambre froide.

Au moins 3h à température ambiante après la sortie de la chambre froide, les manchons sont soumis à :

- l'essai de tenue diélectrique dans l'eau, conformément au § 8.2.3 :

L'ensemble, raccord et conducteurs, est placé au fond d'un bac d'eau. Pendant le déplacement de l'ensemble, il peut être maintenu pour s'assurer qu'il n'y ait pas de courbure du conducteur ou de mouvement inutile des éléments. Le raccord est placé horizontalement. La profondeur de l'eau est mesurée à partir de la partie supérieure du raccord. Les conducteurs émergent suffisamment de l'eau pour éviter un claquage. Le courant de fuite maximum est égal à (10 ± 0,5) mA. La résistivité de l'eau est ≤ 200 Ωm. L'eau est à température ambiante. On effectue la montée progressive en tension à une vitesse d'environ 1 kV/s. Après une durée d'immersion de 30 min, une tension alternative de 6 kV est appliquée à l'échantillon pendant 60 s.

На основании чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА

• l'essai mécanique, conformément au § 8.2.2. :

L'ensemble est soumis à un effort de traction appliqué sur l'âme conformément à la figure 8 de la norme. Les efforts de traction sont appliqués sur les âmes, la montée en charge est conforme à la NF EN 50483-1, § 9.1.4. (vitesse entre 1000 N/min et 5000 N/min)

Un effort de traction est appliqué sur l'âme jusqu'à atteindre les valeurs exprimées en % de la CRM du Tableau 1 :

**Tableau 1 – Efforts initiaux exigés pour le marquage**

Système de torsade	Sections	Efforts	Essai
Système autoporté	4 mm <sup>2</sup> à 16 mm <sup>2</sup> Cuivre	10 % de la CRM pendant 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> à 25 mm <sup>2</sup> Aluminium	20 % de la CRM pendant 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	Pleine traction : 20 % de la CRM pendant 60 s  Traction allégée : 5 % de la CRM pendant 60 s	<input type="checkbox"/> <input type="checkbox"/>
Système à neutre porteur	Phases : 16 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	30 % de la CRM pendant 60 s	<input type="checkbox"/>
	Neutre : 25 mm <sup>2</sup> à 95 mm <sup>2</sup> alliage d'aluminium	60 % de la CRM pendant 60 s	<input type="checkbox"/>

Un marquage est réalisé sur le câble à l'endroit où il sort du raccord.

Les efforts sont ensuite augmentés jusqu'aux valeurs exprimées en % de la CRM du Tableau 2 :

**Tableau 2 – Efforts d'essai**

Système de torsade	Sections	Efforts	Essai
Système autoporté	4 mm <sup>2</sup> à 16 mm <sup>2</sup> Cuivre	20 % de la CRM pendant 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> à 25 mm <sup>2</sup> Aluminium	1 200 N ou 40 % de la CRM, la plus grande des deux valeurs pendant 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	Pleine traction : 85 % de la CRM pendant 60 s  Traction allégée : 10% de la CRM pendant 60 s	<input type="checkbox"/> <input type="checkbox"/>
Système à neutre porteur	Phases : 16 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	60 % de la CRM pendant 60 s	<input type="checkbox"/>
	Neutre : 25 mm <sup>2</sup> à 95 mm <sup>2</sup> alliage d'aluminium	95 % de la CRM pendant 60 s	<input type="checkbox"/>

На основании чл. 2  
от ЗЗЛД

ВЯРНО С ОПЕРАЦИЯТА

Connectors are tested in accordance with NF EN 50483-4 (07/2009) §8.2.4 standard.  
Two samples are tested of each equal cross section.  
The connectors, conductor and tools are further pre-conditioned until they reach the test temperature of  $(-10 \pm 3) ^\circ\text{C}$  before they are assembled. Assembly is made in the cold temperature chamber, at  $(-10 \pm 3) ^\circ\text{C}$ .

At least 3 h after having been removed from the cold chamber, the sleeves are subjected to :

- dielectrical voltage test in water, according to clause 8.2.3:

The assembly, of connector and cores, is placed at the bottom of a water tank. During the movement of the assembly it may be supported to ensure no bending of the core or unnecessary movement of the component parts. The connector is placed horizontally. The depth of water is measured from the upper part of the connector. The cores are sufficiently above the water level to prevent flashover. The maximum leakage current is equal to  $(10 \pm 0,5) \text{ mA}$ . The resistivity of the water is  $\leq 200 \Omega\text{m}$ . The water is at ambient temperature. The a.c. voltage is applied to a rate of approximately  $1 \text{ kV/s}$ . After 30 min under water, the voltage test is applied to the sample with  $6 \text{ kV a.c.}$  for 60 s.

- mechanical testing, according to clause 8.2.2:

The assembly is subjected to a tensile load applied to the conductor in accordance with Figure 8 of the standard.


Tensile test loads are applied to conductors, the rate of increase is in accordance with § 9.1.4 of NF-EN 50483-1. (speed between 1000 N/min and 5000 N/min)

A tensile test load is applied to the conductor until it reaches the values of Table 1:

Table 1 – Initial loads required for marking

Bundle System	Cross sections	Loads	Test
Self supporting system	4 mm <sup>2</sup> to 16 mm <sup>2</sup> Copper	10 % of MBL for 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> to 25 mm <sup>2</sup> Aluminium	20 % of MBL for 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	Full tension : 20 % of MBL for 60 s  Partial tension : 5 % of MBL for 60 s	<input type="checkbox"/> <input type="checkbox"/>
Neutral messenger system	Phases : 16 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	30 % of MBL for 60 s	<input type="checkbox"/>
	Neutral : 25 mm <sup>2</sup> to 95 mm <sup>2</sup> Aluminium alloy	60 % of MBL for 60 s	<input type="checkbox"/>

The cable is marked at the point at which it leaves the connector.



На основании чл. 2  
от ЗЗЛД

The load then is increased up to the values of Table 2:

Table 2 – Test loads

Bundle System	Cross sections	Loads	Test
Self supporting system	4 mm <sup>2</sup> to 16 mm <sup>2</sup> Copper	20 % of MBL for 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> to 25 mm <sup>2</sup> Aluminium	1200 N or 40 % of MBL whichever is the greater for 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	Full tension : 85 % of MBL for 60 s  Partial tension : 10 % of MBL for 60 s	<input type="checkbox"/> <input type="checkbox"/>
Neutral messenger system	Phases : 16 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	60 % of MBL for 60 s	<input type="checkbox"/>
	Neutral : 25 mm <sup>2</sup> to 95 mm <sup>2</sup> Aluminium alloy	95 % of MBL for 60 s	<input type="checkbox"/>

3.1 Exigences supplémentaires du demandeur de l'essai  
Additional requirements of the applicant for the test


Néant  
None

3.2 Conditions ambiantes / Ambient conditions

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
Ambient conditions when performing the test are as follows:

	Exigences Requirements	Relevés Results
Température ambiante et humidité Ambient temperature and humidity conditions	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	22 °C 30 %HR
Temps de conditionnement Conditioning time	-	1 h 23 min
Température de la chambre froide Low temperature chamber	(-10 ± 3)°C	-11,0 °C
Temps à température ambiante après la sortie de la chambre froide Ambient temperature time after out of cold chamber	> 3 h	3 h 21 min
Température de l'eau Water temperature	Température ambiante Ambient temperature	21,5 °C
Résistivité de l'eau Water resistivity	≤ 200 Ωm	34,01 Ωm
Temps d'immersion (minutes) Immersion time (minutes)	30	30
Vitesse de montée en tension Voltage increase rate	≈ 1 kV/s	≈ 1 kV/s

На основании чл. 2  
от 33ЛД





3.3 Configuration des échantillons / Samples configuration

Echantillon n° Sample n.	Section / Cross section (mm <sup>2</sup> )		Système de torsade Bundle system
1	50	25	Système autoporté Self supporting system
2			

4 Résultats / Results

Echantillon n° Sample n.	6 kV pendant 1 min 6 kV for 1 min	
	Exigences Requirements	Résultats Results
1	Pas de claquage No breakdown	Pas de claquage No breakdown
2		Pas de claquage No breakdown

Echantillon n° Sample n.	Vitesse de montée programmée Planned increase rate (N/min)	
	Exigences Requirements	Résultats Results
1	1000 ≤ ... ≤ 5000	3000
2		3000

Echantillon n° Sample n.	Effort pour marquage pendant 1 minute Strength for marking during 1 min (N)		Effort pendant 1 minute Strength during 1 min (N)	
	Exigences Requirements	Résultats Results	Exigences Requirements	Résultats Results
1	20 % CRM MBL ⇔ 600	600	40 % CRM MBL ⇔ 1200	1200
2		600		1200

5 Conclusion / Conclusion

Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
No breakdown or flashover occurred (tripping of voltage generator).



Aucun glissement ou rupture ne s'est produit.  
No slippage or breakage occurred.

ВЯРНО С ОПИТИНАТА

На основание чл. 2  
от ЗЗЛД

1 11 2011 429

### 6 Courbes / Curves




FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

ВІДПОВІДЬ С ОРІГІНАЛОМ

На основании чл. 2  
от ЗЗЛД



**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 50-25**

1. № на тест: 9212300 - Механичен тест;
2. № на тест: 1204125 - Тест за инсталиране при ниска температура.



На основание чл. 2  
от ЗЗЛД

Съставил:



Handwritten signature and number 431



Laboratoire d'essais  
de la **Direction Etudes et Recherches**

Rapport d'essai : Essai de montage à basse température  
Test report : installation test at low temperature

Rapport d'essai n°	: 12 04 122	Test report n.	: 12 04 122
Constructeur	: SICAME	Product brand	: SICAME
Référence produit	: MJPT 50-35	Product type	: MJPT50-35
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: Du 17 au 18 avril 2012	Date of the test	: 17 to 18 April 2012
Date d'émission du rapport	: 15 mai 2012	Report emission date	: 15 May 2012

Essais réalisés suivant : NF EN 50483-4 (07/2009), § 8.2.4  
Tests carried out in accordance with

Ce rapport comprend : 9 pages  
This report contains

Conclusion : Les manchons de jonction préisolés SICAME de type MJPT 50-35 soumis à essai satisfont aux exigences du § 8.2.4 de la norme NF EN 50483-4 (07/2009).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

Conclusion : The tested SICAME insulated splicing sleeves MJPT 50-35 comply with the requirements of clause 8.2.4 of NF EN 50483-4 (07/2009) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основание чл. 2  
от ЗЗЛД

L'accréditation de la section essais du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation. Ce rapport ne concerne que les produits référencés ci-dessus. La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.

Accreditation 1-1068, Scope on request.


The Cofrac testing section accreditation ensures the competence of the Laboratory staff for the tests for which the laboratory has qualified. This report applies only to the products as listed above. With the authorization of Sicame S.A., this report may only be reproduced in its totality.

ACCREDITATION  
N° 1-1068  
PORTÉE  
DISPONIBLE SUR  
www.cofrac.fr

cofrac



B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 65 73 89 00 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr



**1 Echantillons soumis à essai / Samples under test**

Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT 50-35

Matière de la jupe / over molding material : KEPITAL

Fabricant / Manufacturer : SICAME


Numéro de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700610  
*Samples in accordance with drawing n. E0700610*

Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 2

Repérage / Identification : 1, 2

Date de réception au laboratoire : 3 avril 2012  
*Reception date at the laboratory : 03 April 2012*



**ВЪРНО С ОБЯЗАНИЯТА**

На основание чл. 2  
от ЗЗЛД

483

## 2 Caractéristiques du matériel / Equipment used during test

### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
99 01 48	Thermomètre indicateur <i>Indicating thermometer</i>	Précision ± 2°C <i>Accuracy ± 2°C</i>
97 02 02	Règlet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
10 03 21	Chambre froide <i>Low temperature chamber</i>	Précision 1°C <i>Accuracy 1°C</i>
99 00 41	Conductimètre <i>Conductimeter</i>	Précision 30 µS/cm <i>Accuracy 30µS/cm</i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision 1°C <i>Accuracy 1°C</i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectrimeter BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>

### 2.2 Câbles / Cables

N° Lot / Identification	07021		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	50 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	<input type="checkbox"/> Souple <i>Flexible</i>
	<input type="checkbox"/> Rétreinte <i>Compacted</i>	<input checked="" type="checkbox"/> Non rétreinte <i>Non compacted</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	9,00 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TLX-5 <i>Cross-linked polyethylene, TLX-5 type</i>		
Ø sur isolant / Ø on insulation	11,45 mm.		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Référence du câble HD626 HD626 conductor reference	4 B-1		
Charge de rupture minimale Minimum breaking load	3 000 N		

На основании чл. 2  
от 33ЛД

ВАРНО С ОРГАНИЗАЦИЯ

N° Lot / Identification	08006		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	35 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme / Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	<input type="checkbox"/> Souple Flexible
	<input checked="" type="checkbox"/> Rétreinte Compacted	<input type="checkbox"/> Non rétreinte Non compacted	
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde Circular	<input type="checkbox"/> Sectorale Sector-shaped	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	7,05 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 Cross-linked polyethylene, TIX-5 type		
Ø sur isolant / Ø on insulation	10,45 mm		
Conditionnement Conditioned on	1h00 à 120°C 1h00 at 120°C		
Référence du câble HD626 HD626 conductor reference	6 E-1		
Charge de rupture minimale Minimum breaking load	4 200 N		

### 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.4 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur deux manchons pour chaque section. Les raccords, le conducteur et les outillages sont au préalable pré-conditionnés jusqu'à la température d'essai (-10 ± 3) °C, ensuite ils sont assemblés à cette température dans la chambre froide.

Au moins 3h à température ambiante après la sortie de la chambre froide, les manchons sont soumis à :

- l'essai de tenue diélectrique dans l'eau conformément au § 8.2.3 :

L'ensemble, raccord et conducteurs, est placé au fond d'un bac d'eau. Pendant le déplacement de l'ensemble, il peut être maintenu pour s'assurer qu'il n'y ait pas de courbure du conducteur ou de mouvement inutile des éléments. Le raccord est placé horizontalement. La profondeur de l'eau est mesurée à partir de la partie supérieure du raccord. Les conducteurs émergent suffisamment de l'eau pour éviter un claquage. Le courant de fuite maximum est égal à (10 ± 0,5) mA. La résistivité de l'eau est ≤ 200 Ωm. L'eau est à température ambiante. On effectue la montée progressive en tension à une vitesse d'environ 1 kV/s. Après une durée d'immersion de 30 min, une tension alternative de 6 kV est appliquée à l'échantillon pendant 60 s.

На основании чл. 2  
от ЗЗЛД

ВЯРНО С ОПИТИВАНА

• l'essai mécanique, conformément au § 8.2.2. :

L'ensemble est soumis à un effort de traction appliqué sur l'âme conformément à la figure 8 de la norme. Les efforts de traction sont appliqués sur les âmes, la montée en charge est conforme à la NF EN 50483-1, § 9.1.4. (vitesse entre 1000 N/min et 5000 N/min)

Un effort de traction est appliqué sur l'âme jusqu'à atteindre les valeurs exprimées en % de la CRM du Tableau 1 :

Tableau 1 – Efforts initiaux exigés pour le marquage

Systeme de torsade	Sections	Efforts	Essai
Système autoporté	4 mm <sup>2</sup> à 16 mm <sup>2</sup> Cuivre	10 % de la CRM pendant 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> à 25 mm <sup>2</sup> Aluminium	20 % de la CRM pendant 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	Pleine traction : 20 % de la CRM pendant 60 s	<input type="checkbox"/>
Traction allégée : 5 % de la CRM pendant 60 s		<input type="checkbox"/>	
Système à neutre porteur	Phases : 16 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	30 % de la CRM pendant 60 s	<input type="checkbox"/>
	Neutre : 25 mm <sup>2</sup> à 95 mm <sup>2</sup> alliage d'aluminium	60 % de la CRM pendant 60 s	<input type="checkbox"/>

Un marquage est réalisé sur le câble à l'endroit où il sort du raccord.

Les efforts sont ensuite augmentés jusqu'aux valeurs exprimées en % de la CRM du Tableau 2 :

Tableau 2 – Efforts d'essai

Systeme de torsade	Sections	Efforts	Essai
Système autoporté	4 mm <sup>2</sup> à 16 mm <sup>2</sup> Cuivre	20 % de la CRM pendant 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> à 25 mm <sup>2</sup> Aluminium	1 200 N ou 40 % de la CRM, la plus grande des deux valeurs pendant 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	Pleine traction : 85 % de la CRM pendant 60 s	<input type="checkbox"/>
Traction allégée : 10% de la CRM pendant 60 s		<input type="checkbox"/>	
Système à neutre porteur	Phases : 16 mm <sup>2</sup> à 150 mm <sup>2</sup> Aluminium	60 % de la CRM pendant 60 s	<input type="checkbox"/>
	Neutre : 25 mm <sup>2</sup> à 95 mm <sup>2</sup> alliage d'aluminium	95 % de la CRM pendant 60 s	<input type="checkbox"/>

На основание чл. 2  
от ЗЗЛД

ВЪРЖО С ОПРИМАНАТА



Connectors are tested in accordance with NF EN 50483-4 (07/2009) §8.2.4 standard.

Two samples are tested of each equal cross section.

The connectors, conductor and tools are further pre-conditioned until they reach the test temperature of  $(-10 \pm 3) ^\circ\text{C}$  before they are assembled. Assembly is made in the cold temperature chamber, at  $(-10 \pm 3) ^\circ\text{C}$ .

At least 3 h after having been removed from the cold chamber, the sleeves are subjected to :

- dielectrical voltage test in water, according to clause 8.2.3:

The assembly, of connector and cores, is placed at the bottom of a water tank. During the movement of the assembly it may be supported to ensure no bending of the core or unnecessary movement of the component parts. The connector is placed horizontally. The depth of water is measured from the upper part of the connector. The cores are sufficiently above the water level to prevent flashover. The maximum leakage current is equal to  $(10 \pm 0,5) \text{ mA}$ . The resistivity of the water is  $\leq 200 \Omega\text{m}$ . The water is at ambient temperature. The a.c. voltage is applied to a rate of approximately 1 kV/s. After 30 min under water, the voltage test is applied to the sample with 6 kV a.c. for 60 s.

- mechanical testing, according to clause 8.2.2:

The assembly is subjected to a tensile load applied to the conductor in accordance with Figure 8 of the standard.


Tensile test loads are applied to conductors, the rate of increase is in accordance with § 9.1.4 of NF EN 50483-1. (speed between 1000 N/min and 5000 N/min)

A tensile test load is applied to the conductor until it reaches the values of Table 1:

Table 1 – Initial loads required for marking

Bundle System	Cross sections	Loads	Test
Self supporting system	4 mm <sup>2</sup> to 16 mm <sup>2</sup> Copper	10 % of MBL for 60 s	<input type="checkbox"/>
	16 mm <sup>2</sup> to 25 mm <sup>2</sup> Aluminium	20 % of MBL for 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	Full tension :	<input type="checkbox"/>
		20 % of MBL for 60 s	<input type="checkbox"/>
Neutral messenger system	Phases : 16 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	30 % of MBL for 60 s	<input type="checkbox"/>
	Neutral : 25 mm <sup>2</sup> to 95 mm <sup>2</sup> Aluminium alloy	60 % of MBL for 60 s	<input type="checkbox"/>

The cable is marked at the point at which it leaves the connector.



На основании чл. 2  
от 33ЛД

The load then is increased up to the values of Table 2:

Table 2 – Test loads

Bundle System	Cross sections	Loads	Test
Self supporting system	4 mm <sup>2</sup> to 16 mm <sup>2</sup> Copper	20 % of MBL for 60 s	<input checked="" type="checkbox"/>
	16 mm <sup>2</sup> to 25 mm <sup>2</sup> Aluminium	1200 N or 40 % of MBL whichever is the greater for 60 s	<input checked="" type="checkbox"/>
	35 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	Full tension : 85 % of MBL for 60 s	<input type="checkbox"/>
		Partial tension : 10 % of MBL for 60 s	<input type="checkbox"/>
Neutral messenger system	Phases : 16 mm <sup>2</sup> to 150 mm <sup>2</sup> Aluminium	60 % of MBL for 60 s	<input type="checkbox"/>
	Neutral : 25 mm <sup>2</sup> to 95 mm <sup>2</sup> Aluminium alloy	95 % of MBL for 60 s	<input type="checkbox"/>

3.1 Exigences supplémentaires du demandeur de l'essai  
Additional requirements of the applicant for the test

Néant  
None

3.2 Conditions ambiantes / Ambient conditions

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
Ambient conditions when performing the test are as follows:

	Exigences Requirements	Relevés Results
Température ambiante et humidité Ambient temperature and humidity conditions	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	22 °C 30 %HR
Temps de conditionnement Conditioning time	-	1 h 23 min
Température de la chambre froide Low temperature chamber	(-10 ± 3)°C	-11,0 °C
Temps à température ambiante après la sortie de la chambre froide Ambient temperature time after out of cold chamber	> 3 h	3 h 21 min
Température de l'eau Water temperature	Température ambiante Ambient temperature	21,5 °C
Résistivité de l'eau Water resistivity	≤ 200 Ωm	34,01 Ωm
Temps d'immersion (minutes) Immersion time (minutes)	30	30
Vitesse de montée en tension Voltage increase rate	≈ 1 kV/s	≈ 1 kV/s

На основании чл. 2  
от ЗЗЛД



3.3 Configuration des échantillons / Samples configuration

Echantillon n° Sample n.	Section / Cross section (mm <sup>2</sup> )		Système de torsade Bundle system
1	50	35	Système autoporté Self supporting system
2			

4 Résultats / Results

Echantillon n° Sample n.	6 kV pendant 1 min 6 kV for 1 min	
	Exigences Requirements	Résultats Results
1	Pas de claquage No breakdown	Pas de claquage No breakdown
2		Pas de claquage No breakdown


Echantillon n° Sample n.	Vitesse de montée programmée Planned increase rate (N/min)	
	Exigences Requirements	Résultats Results
1	1000 ≤ ... ≤ 5000	3000
2		3000

Echantillon n° Sample n.	Effort pour marquage pendant 1 minute Strength for marking during 1 min (N)		Effort pendant 1 minute Strength during 1 min (N)	
	Exigences Requirements	Résultats Results	Exigences Requirements	Résultats Results
1	20 % CRM MBL ↔ 600	600	40 % CRM MBL ↔ 1200	1200
2		600		1200

5 Conclusion / Conclusion



Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
No breakdown or flashover occurred (tripping of voltage generator).

Aucun glissement ou rupture ne s'est produit.  
No slippage or breakage occurred.



На основании чл. 2  
от 33ЛД

6 Courbes / Curves



FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

ВАРНО С ОБЩИНАТА

На основание чл. 2  
от ЗЗЛД

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 50-35**

1. № на тест: 9212310 – Механичен тест;
2. № на тест: 1204122 - Тест за инсталиране при ниска температура.

На основание чл. 2  
от ЗЗЛД

Съставил:




441

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 70-35**

1. № на тест: 9212330 – Механичен тест;

Съставил:

На основание чл. 2  
от ЗЗЛД





Laboratoire d'essais  
LABEP

Rapport d'essai : Essai d'endurance sur conducteur de phase  
Test report : Endurance test on phase conductor

Rapport d'essai n°	: 12 09 302	Test report n.	: 12 09 302
Constructeur	: SICAME	Product manufacturer	: SICAME
Référence produit	: MIPT70-50	Product reference	: MJPT70-50
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: du 10 octobre au 13 novembre 2012	Date of the test	: 10 October to 13 November 2012
Date d'émission du rapport	: 15 novembre 2012	Report issue date	: 15 November 2012

Essais réalisés suivant : NF EN 50483-4 (07/2009), § 8.2.7  
Tests carried out in accordance with

Ce rapport comprend : 9 pages  
This report contains

Conclusion : Les manchons de jonction préisolés SICAME de type MIPT70-50 soumis à essai satisfont aux exigences du § 8.2.7 de la norme NF EN 50483-4 (07/2009).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.



Conclusion : The tested SICAME insulated splicing sleeves MJPT70-50 comply with the requirements of clause 8.2.7 of NF EN 50483-4 (July 2009) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основании чл. 2  
от ЗЗЛД

D 0490 03

La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.  
With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 65 73 89 00 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr



443

**1 Echantillons soumis à essai / Samples under test**

Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT70-50

Fabricant / Manufacturer : SICAME


Número de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700640  
*Samples in accordance with drawing n. E0700640*

Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 4

Repérage / Identification : 1, 2, 3, 4

Date de réception au laboratoire : 25 septembre 2012  
*Reception date at the laboratory : 25 September 2012*



ВЯРНО С ОПРИТНАТА

На основание чл. 2  
от ЗЗЛД



## 2 Caractéristiques du matériel / Equipment used during test

### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
99 01 48	Thermomètre indicateur <i>Indicating thermometer</i>	Précision ± 2°C <i>Accuracy ± 2°C</i>
97 02 02	Réglet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
10 03 21	Chambre froide <i>Low temperature chamber</i>	Précision 1°C <i>Accuracy 1°C</i>
99 00 41	Conductimètre <i>Conductimeter</i>	Précision 30 µS/cm <i>Accuracy 30µS/cm</i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision 1°C <i>Accuracy 1°C</i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectrimeter BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>

### 2.2 Câbles / Cables

N° Lot / Identification	07021		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	50 mm²		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	<input type="checkbox"/> Souple <i>Flexible</i>
	<input type="checkbox"/> Rétreinte <i>Compacted</i>	<input checked="" type="checkbox"/> Non rétreinte <i>Non compacted</i>	
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	9,00 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 <i>Cross-linked polyethylene, TIX-5 type</i>		
Ø sur isolant / Ø on insulation	11,45 mm		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Référence du câble HD626 HD626 conductor reference	4 E-1		
Charge de rupture minimale Minimum breaking load	3 000 N		

На основание чл. 2  
от ЗЗЛД

ВЪРХНО С ОПИТИВАНАТА

995

N° Lot / Identification	11029		
Norme / Standard	WT-92/K-396		
Provenance / From	Pologne / Poland		
Section / Cross section	70 mm <sup>2</sup>		
Matériau de l'âme Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	<input type="checkbox"/> Souple Flexible
Forme d'âme Conductor shape	<input checked="" type="checkbox"/> Rétreinte Compacted	<input type="checkbox"/> Non rétreinte Non compacted	<input type="checkbox"/> Sectorale Sector-shaped
Nombre de brins Number of wires	19		
Ø sur âme Ø on conductor	10,0 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé Cross-linked polyethylene		
Ø sur isolant Ø on insulation	13,1 mm		
Conditionnement Conditioned on	1h00 à 110°C 1h00 at 110°C		
Référence du câble HD626 HD626 conductor reference	/		
Charge de rupture minimale (CRM) / Minimum Breaking Load (MBL)	11242 N		

### 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.7 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur quatre manchons pour chaque section.

La charge, pour le type de système approprié, doit être appliquée aux extrémités du conducteur et ajustée comme demandé durant l'essai.

Des cycles thermiques, d'une durée de 90 min, doivent être appliqués au montage d'essai.

500 cycles doivent être réalisés.

Pendant les 45 premières minutes de chaque cycle, le courant traversant l'ensemble doit créer l'élévation de température.

La température de référence du conducteur doit être maintenue à la température normale de service dans un intervalle de  $\pm 3$  K comme indiqué dans l'Annexe C de la EN 50483-1. Cette température est atteinte dans un temps de 5 min à 15 min en début de cycle.

Pendant les 45 dernières minutes, de chaque cycle, le montage en essai doit être refroidi à  $(25 \pm 3)$  °C. La température doit ensuite être maintenue à cette valeur, jusqu'à la fin du cycle.

A intervalle de 24h, à la fin de la période de chauffage à la température normale de service, les températures atteintes par les deux manchons doivent être enregistrées.

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПРИНАТА

Insulated splicing sleeves are tested in accordance with NF EN 50483-4 (07/2009) §8.2.7 standard.

The test is carried out on 4 Insulated splicing sleeves for each cross-section.

The load, for the appropriate type of system, shall be applied to the extremities of the core and varied as required throughout the test.

Thermal cycles, with duration of 90 min, shall be applied to the test assembly.

There shall be 500 cycles.

For the first 45 minutes of every cycle, current flowing through the assembly shall create the temperature rise.


The reference temperature of the conductor shall be maintained at the normal operating temperature within an interval of  $\pm 3$  °C as shown in Table B.1 of Annexe B, this temperature shall be reached within 5 min to 15 min at the beginning of the cycle.

For the last 45 min, of each cycle, the test assembly shall be cooled to  $(25 \pm 3)$  °C. The temperature shall then be maintained, at this value, until the end of the cycle.

At 24 h intervals, at the end of the normal operating temperature heating period, the temperatures reached by the two sleeves shall be recorded.

La figure 1 décrit un exemple typique de dispositif d'essai. La configuration peut différer de ce montage du moment qu'elle respecte les longueurs du conducteur de phase

Figure 1 shows a typical test arrangement. The test configuration can differ from this arrangement as long as it complies with the phase conductor.



На основании чл. 2  
от ЗЗЛД

ВАРЧО С. ОРНАТОВА

La variation de la charge mécanique et de la température est décrite sur le diagramme de la Figure 2.

Un effort de traction doit être appliqué jusqu'à une valeur égale à 35 % de la CRM du câble. Cette valeur doit être atteinte approximativement en 1 min.

La charge doit ensuite être maintenue pendant 10 min par un réglage permanent manuel ou automatique. On doit laisser l'ensemble se stabiliser mécaniquement pendant 24 h sans aucun réglage.

Une fois l'ensemble stabilisé les cycles thermiques doivent commencer. A la fin du premier cycle, l'effort de traction doit être réglé à 20 % de la CRM du câble.

Au moins une fois par 24 h, l'effort de traction doit être ajusté à 20 % de la CRM du câble.

*The variation in mechanical load and temperature is shown, diagrammatically, in Figure 2.*

*A tensile load shall be applied until a value equal to 35 % of the MBL is reached. This value shall be achieved in approximately 1 minute.*

*The load shall then be maintained for 10 min using a manual or automatic continuous adjustment. The assembly shall be left to self stabilize mechanically for 24 h without any adjustment.*

*Once the assembly has stabilized the thermal cycles shall be started. At the end of the first cycle, the tensile load shall be set at 20 % of MBL.*

*At least once every 24 h, the tensile load shall be adjusted to 20 % of the MBL.*





Figure 2 – Diagramme des cycles thermiques et des contraintes mécaniques appliqués sur le conducteur de phase

Figure 2 – Diagram of thermal cycles and mechanical stresses applied on phase conductor

На основании чл. 2  
от ЗЗЛД



*Handwritten signature or initials.*

*Handwritten marks and numbers at the bottom right of the page.*

**Tableau 1 – Effort de traction appliqué**  
*Table 1 – Applied tensile load*

20 % de la CRM du câble <i>20 % of MBL</i> 2248 N	35% de la CRM du câble <i>35 % of MBL</i> 3934 N
---	--

La température normale de service du câble est de 80° C.  
*The rated operating temperature of the cable is 80° C.*

A la fin de la période de chauffage, la température des manchons doit être inférieure à la température du conducteur de référence.

Les manchons de Classe 1 et de Classe 2 doivent satisfaire aux exigences de l'essai de tenue diélectrique dans l'air, 8.2.3.1.3.2.

Pour les manchons de Classe 1, l'ensemble formé par le raccord et les conducteurs doit être ensuite retiré des billes métalliques, sans contrainte mécanique, et doit satisfaire aux exigences de l'essai de tenue diélectrique dans l'eau, comme indiqué au 8.2.3.1.3.1, mais avec une tension de 1 kV.

Les quatre manchons doivent satisfaire aux exigences de l'essai mécanique du § 8.2.2.

*At the end of the heating period, the sleeves' temperatures shall be lower than the temperature of the reference core.*

*The Class 1 and the Class 2 sleeves shall meet the requirements of the Dielectrical Voltage Test in Air, Clause 8.2.3.1.3.2.*

*For Class 1 sleeves the assembly formed by the connector and the cores shall then taken out of the metallic balls, without any mechanical stress, and shall meet the requirements of the dielectrical voltage test in water, Clause 8.2.3.1.3.1 but with a voltage of 1 kV.*

*The four sleeves shall meet the requirements of the mechanical test Clause 8.2.2.*

**3.1 Conditions ambiantes / Ambient conditions**

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
*Ambient conditions when performing the test are as follows:*

	Exigences <i>Requirements</i>	Relevés <i>Results</i>
Température ambiante et humidité <i>Ambient temperature and humidity conditions</i>	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	20 °C 39 %HR
Température de l'eau <i>Water temperature</i>	-	20,2 °C
Résistivité de l'eau <i>Water resistivity</i>	≤ 200 Ωm	39,9 Ωm
Temps d'immersion <i>Immersion time</i>	≥ 30 min	31 min
Vitesse de montée en tension <i>Voltage increase rate</i>	≈ 1 kV/s	≈ 1 kV/s

На основание чл. 2  
от ЗЗЛД

ВАРНО С ОБИГНАНАТА

449

3.2 Configuration des échantillons / *Samples configuration*

Echantillon n° <i>Sample n.</i>	Section / <i>Cross section (mm²)</i>	
	Câble principal <i>Main cable</i>	Câble dérivé <i>Tap cable</i>
1	70	50
2		
3		
4		

4 Résultats / *Results*

4.1 Tenue diélectrique

Echantillon n° <i>Sample n.</i>	4 kV pendant 1 minute dans les billes métalliques <i>4 kV for 1 minute in metallic balls</i>	
	Résultats / <i>Results</i>	Exigences <i>Requirements</i>
1	Pas de claquage / <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>
2	Pas de claquage / <i>No breakdown</i>	
3	Pas de claquage / <i>No breakdown</i>	
4	Pas de claquage / <i>No breakdown</i>	

Echantillon n° <i>Sample n.</i>	1 kV pendant 1 minute dans l'eau <i>1 kV for 1 minute in water</i>	
	Résultats / <i>Results</i>	Exigences <i>Requirements</i>
1	Pas de claquage / <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>
2	Pas de claquage / <i>No breakdown</i>	
3	Pas de claquage / <i>No breakdown</i>	
4	Pas de claquage / <i>No breakdown</i>	

4.2 Essais mécaniques

Echantillon n° <i>Sample n.</i>	Vitesse de montée programmée <i>Planned increase rate</i>	
	(N/min)	Exigences <i>Requirements</i>
1	3000	1000 ≤ ... ≤ 5000
2	3000	
3	3000	
4	3000	

На основании чл. 2  
от ЗЗЛД

ВАРНО С ОПИТИВАНА

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	2248	20 % CRM MBL
2	2248	
3	2248	
4	2248	

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	9555	85 % CRM MBL
2	9555	
3	9555	
4	9555	

**5 Conclusion / Conclusion**

Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
No breakdown or flashover occurred (tripping of voltage generator).

Aucun glissement ou rupture ne s'est produit.  
No slippage or breakage occurred.

FIN DU RAPPORT D'ESSAI / END OF TEST REPORT


ВЯРНО С ОПИТИВАНАТА

На основание чл. 2  
от ЗЗЛД

459




**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 70-50**

1. № на тест: 9212340 – Механичен тест;
2. № на тест: 1209302 - Тест за издръжливост върху фазовия проводник.



На основание чл. 2  
от ЗЗЛД

Съставил:







Laboratoire d'essais  
LABEP

Rapport d'essai : Essai d'endurance sur conducteur de phase  
 Test report : Endurance test on phase conductor

Rapport d'essai n°	: 12 09 307	Test report n.	: 12 09 307
Constructeur	: SICAME	Product manufacturer	: SICAME
Référence produit	: MJPT95-70	Product reference	: MJPT95-70
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: du 10 octobre au 13 novembre 2012	Date of the test	: 10 October to 13 November 2012
Date d'émission du rapport	: 15 novembre 2012	Report issue date	: 15 November 2012

Essais réalisés suivant : NF EN 50483-4 (07/2009), § 8.2.7  
 Tests carried out in accordance with

Ce rapport comprend : 9 pages  
 This report contains

Conclusion : Les manchons de jonction préisolés SICAME de type MJPT95-70 soumis à essai satisfont aux exigences du § 8.2.7 de la norme NF EN 50483-4 (07/2009).  
 Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.


Conclusion : The tested SICAME insulated splicing sleeves MJPT95-70 comply with the requirements of clause 8.2.7 of NF EN 50483-4 (July 2009) standard.  
 To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основание чл. 2  
от ЗЗЛД

La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.  
 With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 89 00 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr

ВЯРНО С ОПРИТИНАТА



453

**1 Echantillons soumis à essai / Samples under test**

Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT9570

Fabricant / Manufacturer : SICAME


Numéro de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700640  
*Samples in accordance with drawing n. E0700640*

Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 4

Repérage / Identification : 1, 2, 3, 4

Date de réception au laboratoire : 25 septembre 2012  
*Reception date at the laboratory : 25 September 2012*



**ВІДПОВІДНО С ОФІЦІАЛЬНОСТЮ**

На основании чл. 2  
от ЗЗЛД

454

## 2 Caractéristiques du matériel / Equipment used during test

### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
99 01 48	Thermomètre indicateur <i>Indicating thermometer</i>	Précision ± 2°C <i>Accuracy ± 2°C</i>
97 02 02	Réglet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
10 03 21	Chambre froide <i>Low temperature chamber</i>	Précision 1°C <i>Accuracy 1°C</i>
99 00 41	Conductimètre <i>Conductimeter</i>	Précision 30 µS/cm <i>Accuracy 30µS/cm</i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision 1°C <i>Accuracy 1°C</i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectrimeter BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>

### 2.2 Câbles / Cables

N° Lot / Identification	07021		
Norme / Standard	NF C-33-209		
Provenance / From	France / France		
Section / Cross section	95 mm²		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	
	<input type="checkbox"/> Rétreinte <i>Compacted</i>	<input checked="" type="checkbox"/> Non rétreinte <i>Non compacted</i>	<input type="checkbox"/> Souple <i>Flexible</i>
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	13,1 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 <i>Cross-linked polyethylene, TIX-5 type</i>		
Ø sur isolant / Ø on insulation	16,1 mm		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Référence du câble HD626 HD626 conductor reference	4 E-1		
Charge de rupture minimale Minimum breaking load	3 000 N		

Visa du responsable de l'essai

На основании чл. 2  
от ЗЗЛД

ВЯРНО С ОПИРАНАТА

## 2.2 Câbles / Cables

N° Lot / Identification	I1029		
Norme / Standard	WT-92/K-396		
Provenance / From	Pologne / Poland		
Section / Cross section	70 mm <sup>2</sup>		
Matériau de l'âme Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	<input type="checkbox"/> Souple Flexible
Forme d'âme Conductor shape	<input checked="" type="checkbox"/> Rétreinte Compacted	<input type="checkbox"/> Non rétreinte Non compacted	<input type="checkbox"/> Sectorale Sector-shaped
Forme d'âme Conductor shape	<input checked="" type="checkbox"/> Ronde Circular	<input type="checkbox"/> Sectorale Sector-shaped	
Nombre de brins Number of wires	19		
Ø sur âme Ø on conductor	10,0 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé Cross-linked polyethylene		
Ø sur isolant Ø on insulation	13,1 mm		
Conditionnement Conditioned on	1h00 à 110°C 1h00 at 110°C		
Référence du câble HD626 HD626 conductor reference	/		
Charge de rupture minimale (CRM) / Minimum Breaking Load (MBL)	11242 N		

## 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.7 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur quatre manchons pour chaque section.

La charge, pour le type de système approprié, doit être appliquée aux extrémités du conducteur et ajustée comme demandé durant l'essai.

Des cycles thermiques, d'une durée de 90 min, doivent être appliqués au montage d'essai.

500 cycles doivent être réalisés.

Pendant les 45 premières minutes de chaque cycle, le courant traversant l'ensemble doit créer l'élévation de température.

La température de référence du conducteur doit être maintenue à la température normale de service dans un intervalle de  $\pm 3$  K comme indiqué dans l'Annexe C de la EN 50483-1. Cette température est atteinte dans un temps de 5 min à 15 min en début de cycle.

Pendant les 45 dernières minutes, de chaque cycle, le montage en essai doit être refroidi à  $(25 \pm 3)$  °C. La température doit ensuite être maintenue à cette valeur, jusqu'à la fin du cycle.

A intervalle de 24h, à la fin de la période de chauffage à la température normale de service, les températures atteintes par les deux manchons doivent être enregistrées.


На основании чл. 2  
от ЗЗЛД

ВІРНО С ОПИГНАНА

Insulated splicing sleeves are tested in accordance with NF EN 50483-4 (07/2009) §8.2.7 standard.  
 The test is carried out on 4 Insulated splicing sleeves for each cross-section.  
 The load, for the appropriate type of system, shall be applied to the extremities of the core and varied as required throughout the test.  
 Thermal cycles, with duration of 90 min, shall be applied to the test assembly.  
 There shall be 500 cycles.  
 For the first 45 minutes of every cycle, current flowing through the assembly shall create the temperature rise.  
 The reference temperature of the conductor shall be maintained at the normal operating temperature within an interval of  $\pm 3$  °C as shown in Table B.1 of Annexe B, this temperature shall be reached within 5 min to 15 min at the beginning of the cycle.  
 For the last 45 min, of each cycle, the test assembly shall be cooled to  $(25 \pm 3)$  °C. The temperature shall then be maintained, at this value, until the end of the cycle.  
 At 24 h intervals, at the end of the normal operating temperature heating period, the temperatures reached by the two sleeves shall be recorded.

La figure 1 décrit un exemple typique de dispositif d'essai. La configuration peut différer de ce montage du moment qu'elle respecte les longueurs du conducteur de phase

Figure 1 shows a typical test arrangement. The test configuration can differ from this arrangement as long as it complies with the phase conductor.



На основании чл. 2  
от ЗЗЛД

ВАРНО С ОРНИКАЦИЈА

La variation de la charge mécanique et de la température est décrite sur le diagramme de la Figure 2.

Un effort de traction doit être appliqué jusqu'à une valeur égale à 35 % de la CRM du câble. Cette valeur doit être atteinte approximativement en 1 min.

La charge doit ensuite être maintenue pendant 10 min par un réglage permanent manuel ou automatique. On doit laisser l'ensemble se stabiliser mécaniquement pendant 24 h sans aucun réglage.

Une fois l'ensemble stabilisé les cycles thermiques doivent commencer. A la fin du premier cycle, l'effort de traction doit être réglé à 20 % de la CRM du câble.

Au moins une fois par 24 h, l'effort de traction doit être ajusté à 20 % de la CRM du câble.

*The variation in mechanical load and temperature is shown, diagrammatically, in Figure 2.*

*A tensile load shall be applied until a value equal to 35 % of the MBL is reached. This value shall be achieved in approximately 1 minute.*

*The load shall then be maintained for 10 min using a manual or automatic continuous adjustment. The assembly shall be left to self stabilize mechanically for 24 h without any adjustment.*

*Once the assembly has stabilized the thermal cycles shall be started. At the end of the first cycle, the tensile load shall be set at 20 % of MBL.*

*At least once every 24 h, the tensile load shall be adjusted to 20 % of the MBL.*




Figure 2 – Diagramme des cycles thermiques et des contraintes mécaniques appliqués sur le conducteur de phase

Figure 2 – Diagram of thermal cycles and mechanical stresses applied on phase conductor

На основании чл. 2  
от 33ЛД

ВАРНО С ОРМОНАТА

**Tableau 1 – Effort de traction appliqué**  
*Table 1 – Applied tensile load*

20 % de la CRM du câble <i>20 % of MBL</i> 2248 N	35% de la CRM du câble <i>35 % of MBL</i> 3934 N
---	--

La température normale de service du câble est de 80° C.  
*The rated operating temperature of the cable is 80° C.*

A la fin de la période de chauffage, la température des manchons doit être inférieure à la température du conducteur de référence.

Les manchons de Classe 1 et de Classe 2 doivent satisfaire aux exigences de l'essai de tenue diélectrique dans l'air, 8.2.3.1.3.2.

Pour les manchons de Classe 1, l'ensemble formé par le raccord et les conducteurs doit être ensuite retiré des billes métalliques, sans contrainte mécanique, et doit satisfaire aux exigences de l'essai de tenue diélectrique dans l'eau, comme indiqué au 8.2.3.1.3.1, mais avec une tension de 1 kV.

Les quatre manchons doivent satisfaire aux exigences de l'essai mécanique du § 8.2.2.

*At the end of the heating period, the sleeves' temperatures shall be lower than the temperature of the reference core.*

*The Class 1 and the Class 2 sleeves shall meet the requirements of the Dielectrical Voltage Test in Air, Clause 8.2.3.1.3.2.*

*For Class 1 sleeves the assembly formed by the connector and the cores shall then taken out of the metallic balls, without any mechanical stress, and shall meet the requirements of the dielectrical voltage test in water, Clause 8.2.3.1.3.1 but with a voltage of 1 kV.*

*The four sleeves shall meet the requirements of the mechanical test Clause 8.2.2.*

**3.1 Conditions ambiantes / Ambient conditions**

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
*Ambient conditions when performing the test are as follows:*

	Exigences <i>Requirements</i>	Relevés <i>Results</i>
Température ambiante et humidité <i>Ambient temperature and humidity conditions</i>	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	20 °C 39 %HR
Température de l'eau <i>Water temperature</i>	-	20,2 °C
Résistivité de l'eau <i>Water resistivity</i>	≤ 200 Ωm	39,9 Ωm
Temps d'immersion <i>Immersion time</i>	≥ 30 min	31 min
Vitesse de montée en tension <i>Voltage increase rate</i>	≈ 1 kV/s	≈ 1 kV/s

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПРИГНАЛАТА

3.2 Configuration des échantillons / Samples configuration

Echantillon n° Sample n.	Section / Cross section (mm²)	
	Câble principal Main cable	Câble dérivé Tap cable
1	95	70
2		
3		
4		

4 Résultats / Results

4.1 Tenue diélectrique

Echantillon n° Sample n.	4 kV pendant 1 minute dans les billes métalliques 4 kV for 1 minute in metallic balls	
	Résultats / Results	Exigences Requirements
1	Pas de claquage / No breakdown	Pas de claquage No breakdown
2	Pas de claquage / No breakdown	
3	Pas de claquage / No breakdown	
4	Pas de claquage / No breakdown	

Echantillon n° Sample n.	1 kV pendant 1 minute dans l'eau 1 kV for 1 minute in water	
	Résultats / Results	Exigences Requirements
1	Pas de claquage / No breakdown	Pas de claquage No breakdown
2	Pas de claquage / No breakdown	
3	Pas de claquage / No breakdown	
4	Pas de claquage / No breakdown	

4.2 Essais mécaniques

Echantillon n° Sample n.	Vitesse de montée programmée Planned increase rate (N/min)	
		Exigences Requirements (N/min)
1	3000	1000 ≤ ... ≤ 5000
2	3000	
3	3000	
4	3000	

На основание чл. 2  
от ЗЗЛД

ВАРНО С ОРНИТНАТА

460



Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	2248	20 % CRM MBL
2	2248	
3	2248	
4	2248	

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	9555	85 % CRM MBL
2	9555	
3	9555	
4	9555	

**5 Conclusion / Conclusion**

Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
No breakdown or flashover occurred (tripping of voltage generator).

Aucun glissement ou rupture ne s'est produit.  
No slippage or breakage occurred.

FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОПРИТЕЛНАТА



461

СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 95-70

1. № на тест: 1209307 - Тест за издръжливост върху фазовия проводник.

Съставил:

На основание чл. 2  
от ЗЗЛД





Laboratoire d'essais  
de la **D**irection **E**tudes et **R**echerches

**Rapport d'essai** : Essai de vieillissement climatique  
**Test report** : *Climatic aging test*

<b>Rapport d'essai n°</b>	: 11 10 440	<b>Test report n.</b>	: 11 10 440
<b>Constructeur</b>	: SICAME	<b>Product brand</b>	: SICAME
<b>Référence produit</b>	: MJPT 150-70	<b>Product type</b>	: MJPT 150-70
<b>Demandeur de l'essai</b>	: SICAME S.A.	<b>Test applied by</b>	: SICAME S.A.
<b>Date d'essai</b>	: 08 juin au 02 aout 2012	<b>Date of the test</b>	: 8 June to 2 August 2012
<b>Date d'émission du rapport</b>	: 03 aout 2012	<b>Report emission date</b>	: 3 August 2012

**Essais réalisés suivant :** NF EN 50483-4 (07/2009), § 8.2.5.2  
**Tests carried out in accordance with**

**Ce rapport comprend :** 7 pages  
**This report contains**

**Conclusion** : Les manchons de jonction SICAME de type MJPT 150-70 soumis à essai satisfont aux exigences du § 8.2.5.2 de la norme NF EN 50483-4 (07/2009).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

**Conclusion** : *The tested SICAME insulated splicing sleeves MJPT 150-70 comply with the requirements of clause 8.2.5.2 of NF EN 50483-4 (July 2009) standard.*  
*To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved*

На основании чл. 2  
от 33ЛД



L'accréditation de la section essais du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation. Ce rapport ne concerne que les produits référencés ci-dessus. La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.

Accreditation 1-1068. Scope on request.  
The Cofrac testing section accreditation ensures the competence of the Laboratory staff for the tests for which the laboratory has qualification.  
This report applies only to the products as listed above. With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 89 00 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr

ACCREDITATION  
N° 1-1068  
PORTEE  
DISPONIBLE SUR  
www.cofrac.fr

cofrac



# 1 Echantillons soumis à essai / Samples under test

Type : Manchon de jonction  
*Insulation piercing connector*

Désignation / Designation : MJPT 150-70


Fabricant / Manufacturer : SICAME

Numéro de lot / Batch number : Tête de série / Head of series  
 Echantillons suivant le plan E0700650  
*Samples in accordance with drawing n. E0700650*

Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to electrical ageing cycles and short-circuits</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected only to electrical ageing cycles</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 2  
 Repérage / Identification : 1, 2

Date de réception au laboratoire : 04 mai 2012  
 Reception date at the laboratory : May, 4<sup>th</sup> 2012



На основание чл. 2  
 от ЗЗЛД

ВЪРНО С ОРМИНАЛА

## 2 Caractéristiques du matériel / Equipment used during test


### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir avec matrices E215 <i>Compression tool with dies E215</i>	5 tonnes <i>5 tons</i>
99 01 48	Thermomètre indicateur <i>Indicated thermometer</i>	Précision 2°C <i>Accuracy 2°C</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectrimeter BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
97 02 02	Réglet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision 1°C <i>Accuracy 1°C</i>
99 00 41	Conductimètre <i>Conductimeter</i>	Précision 30 µS/cm <i>Accuracy 30µS/cm</i>
12 03 03	Conductimètre <i>Conductimeter</i>	Précision 30 µS/cm <i>Accuracy 30µS/cm</i>
09 04 54	Weather-ometer (ATLAS 2)	Conforme à la norme XP C 20-540 <i>Compliant with XP C 20-540 standard</i>

### 2.2 Câbles / Cables

N° Lot / Identification	9955		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	70 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	<input type="checkbox"/> Non rétreinte <i>Non compacted</i>
	<input checked="" type="checkbox"/> Rétreinte <i>Compacted</i>	<input type="checkbox"/> Non rétreinte <i>Non compacted</i>	<input type="checkbox"/> Souple <i>Flexible</i>
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	12		
Ø sur âme / Ø on conductor	9,95 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 <i>Cross-linked polyethylene, TIX-5 type</i>		
Ø sur isolant / Ø on insulation	13,75 mm		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Référence du câble HD626 HD626 conductor reference	6 B-1		

ВЪРХО С ОПИТИНАТА



На основание чл. 2  
от ЗЗЛД

UAT

N° Lot / Identification	09003		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	150 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme / Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	<input type="checkbox"/> Rétreinte Compacted
		<input type="checkbox"/> Non rétreinte Non compacted	<input type="checkbox"/> Souple Flexible
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde Circular	<input type="checkbox"/> Sectorale Sector-shaped	
Nombre de brins / Number of wires	19		
Ø sur âme / Ø on conductor	14,45 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 Cross-linked polyethylene, TIX-5 type		
Ø sur isolant / Ø on insulation	17,95 mm		
Conditionnement Conditioned on	1h00 à 120°C 1h00 at 120°C		
Référence du câble HD626 HD626 conductor reference	6 E-1		

*[Handwritten signature]*

*[Handwritten signature]*

ВЯРНО С ОРНИТАЦИЯ



На основание чл. 2  
от ЗЗЛД

### 3 Méthode / Method

Les essais sur les raccords sont effectués selon les prescriptions du paragraphe 8.2.5.2 de la norme NF EN 50483-4 (07/2009). Les raccords de classe 1 sont testés dans l'eau.

Les connecteurs sont montés sur des conducteurs principaux des sections minimale et maximale et sur des conducteurs dérivés de la section minimale.

Les manchons de jonctions sont montés conformément aux instructions du constructeur.

L'ensemble formé par le manchon de jonction, maintenu d'une façon rigide et appropriée, est placé au fond d'un bac rempli d'eau sur 30 cm de hauteur mesurée au niveau de la partie supérieure du manchon de jonction, les extrémités des conducteurs émergeant suffisamment du bain pour éviter un contournement extérieur. La résistivité de l'eau ne dépasse pas 200 Ωm (NF EN 50483-1 de 07/2009, § 9.1.6) l'eau est à température ambiante.

Le générateur de tension utilisé est réglé pour déclencher sous un courant de fuite de (10,0 ± 0,5) mA (NF EN 50483-1 de 07/2009, § 9.1.5).

Après une durée d'immersion de 30 min, l'ensemble est soumis à un essai diélectrique sous une tension de 6 kV à fréquence industrielle (fréquence : 50 Hz) pendant 1 min. On effectue la montée progressive en tension à une vitesse d'environ 1 kV/s (NF EN 50483-1 § 9.1.7 de 07/2009).

*Connectors are tested in accordance with NF EN 50483-4 § 8.2.5.2 (07/2009) standard. Class 1 connectors are tested in water.*

*They are mounted on the smallest and largest cross-sections on the main core and to the smallest cross-section on the tap core.*

*They are installed in accordance with the manufacturer's instructions.*

*The assembly of connector and cores, maintained in a rigid and appropriate way, is placed at the bottom of a water tank. The water height is 30 cm measured from the upper part of the connector, and the cores are long enough out of the water to prevent flashover. The resistivity of the water is less than 200 Ωm (NF EN 50483-1 07/2009, § 9.1.6) and the water is at ambient temperature.*

*The voltage generator is tripping for a leakage current of (10.0 ± 0.5) mA (NF EN 50483-1 07/2009, § 9.1.5).*

*After 30 min under water, the voltage test is applied to the sample with a 6 kV a.c. voltage (frequency: 50 Hz) for 1 minute. The a.c. voltage is applied to a rate of approximately 1 kV/s (NF EN 50483-1 07/2009, § 9.1.7).*



Les échantillons sont ensuite soumis à l'essai climatique suivant :

*The samples are then submitted to the climatic ageing test following:*

Méthodes d'essai selon NF EN 50483-6 (§ 8.5)	
Test methods in accordance with NF EN 50483-6 (§ 8.5)	
<input checked="" type="checkbox"/>	Méthode 1 Method 1 § 8.5.1
<input type="checkbox"/>	Méthode 2 Method 2 § 8.5.2


Les échantillons sont installés de façon telle que l'axe du conducteur principal soit dans un plan horizontal et la lampe dans un plan vertical. Ces deux plans se coupent au milieu de la lampe et au milieu des échantillons. Le conducteur principal est orthogonal au plan ainsi défini.

*The samples are installed so that the axis of the main core is in a horizontal plane and the lamp in a vertical plane. These two planes are intersect in the middle of the lamp and in the middle of the samples. The main core is orthogonal in the described vertical plane.*



На основание чл. 2 от ЗЗЛД

467



Après les cycles de vieillissement climatique et après une période d'au moins 24h sans dépasser 72 h à l'atmosphère du laboratoire, les échantillons doivent satisfaire aux exigences des essais suivants.

- Les manchons de jonction Classe 1 et Classe 2 doivent satisfaire aux exigences de l'essai de tenue diélectrique dans l'air, comme indiqué au 8.2.3.1.3.2.

- Pour les manchons de classe 1, l'ensemble formé par le raccord et les conducteurs est ensuite retiré des billes métalliques, sans contrainte mécanique, et doit satisfaire aux exigences de l'essai de tenue diélectrique dans l'eau, comme indiqué au 8.2.3.1.3.1, mais avec une tension de 1 kV.

- Une inspection visuelle est réalisée afin de déterminer qu'il n'y a pas eu de dégradation des parties organiques pouvant nuire au bon fonctionnement de l'échantillon.

Le marquage permettant l'identification des échantillons doit être lisible quand il est examiné avec une vue normale ou corrigée, sans grossissement.

After the climatic ageing cycles and after a period of at least 24 h but not exceeding 72 h at the laboratory atmosphere, the samples shall meet the requirements of the following tests.


- The piercing connector Class 1 and Class 2 shall meet the requirements of the dielectrical voltage test in air, as given in 8.2.3.1.3.2.

- For piercing connector Class 1 the assembly formed by the connector and the cores shall be then taken out of the metallic balls, without any mechanical stress, and shall meet the requirements of the dielectrical voltage test in water as given in 8.2.3.1.3.1, but with a voltage of 1 kV.

- Visual inspection shall be carried out to determine that there has been no degradation of the organic parts which could affect the normal function of the sample.

The sample's identification marking shall be legible when examined with normal or corrected vision, without magnification.

ВЪРНО С ОПРИТНАТА



На основание чл. 2  
от ЗЗЛД

UFR



#### 4 Résultats / Results

##### 4.1 Configuration des échantillons / Samples configuration

Connecteur n° Connector n.	Section/ Cross section (mm²)	
	Câble principal Main cable	Câble dérivé Tap cable
1	150	70
2		

##### 4.2 Tenue diélectrique avant essai climatique / Dielectrical test before climatic ageing test

Les conditions ambiantes relevées lors du montage des manchons sont les suivantes :  
Ambient conditions during the installation of the sleeves are as follows:

	Exigences Requirements	Relevés Results
Température ambiante et humidité Ambient temperature and humidity conditions	15 °C ≤ T° ≤ 30 °C 25 % ≤ HR ≤ 75 %	22 °C 41 %HR
Température de l'eau Water temperature	Température ambiante Ambient temperature	23,7 °C
Résistivité de l'eau Water resistivity	≤ 200 Ωm	34,8 Ωm
Temps d'immersion Immersion time	30 min	30 min
Vitesse de montée en tension Voltage increase rate	≈ 1 kV/s	≈ 1 kV/s

Echantillon n° Sample n.	Avant essai climatique / Before climatic ageing test :	
	6 kV pendant 1 min dans l'eau 6 kV for 1 min in water	
	Exigences Requirements	Résultats Results
1	Pas de claquage No breakdown	Pas de claquage No breakdown
2		Pas de claquage No breakdown

ВЯРНО С ОПИТИВАНАТА



На основание чл. 2  
от ЗЗЛД

**4.3 Tenue diélectrique après essai climatique / Dielectrical test after climatic ageing test**

Les conditions ambiantes relevées sont les suivantes :  
*Ambient conditions are as follows:*

	Exigences <i>Requirements</i>	Relevés <i>Results</i>
Température ambiante et humidité <i>Ambient temperature and humidity conditions</i>	15 °C ≤ T° ≤ 30 °C 25 % ≤ HR ≤ 75 %	22 °C 47 %HR
Température de l'eau <i>Water temperature</i>	Température ambiante <i>Ambient temperature</i>	21,2 °C
Résistivité de l'eau <i>Water resistivity</i>	≤ 200 Ωm	23,6 Ωm
Temps d'immersion <i>Immersion time</i>	30 min	30 min
Vitesse de montée en tension <i>Voltage increase rate</i>	≈ 1 kV/s	≈ 1 kV/s

Echantillon n° <i>Sample n.</i>	Après essai climatique / <i>After climatic ageing test :</i>			
	6 kV pendant 1 min dans les billes métalliques <i>6 kV for 1 min in metallic balls</i>		1 kV pendant 1 min dans l'eau <i>1 kV for 1 min in water</i>	
	Exigences <i>Requirements</i>	Résultats <i>Results</i>	Exigences <i>Requirements</i>	Résultats <i>Results</i>
1	Pas de claquage <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>
2	Pas de claquage <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>

**5 Conclusion / Conclusion**

Aucun claquage ou contournement ne s'est produit.


Le marquage permettant l'identification des échantillons est lisible quand il est examiné avec une vue normale ou corrigée, sans grossissement.

*No breakdown or flashover occurred.*

*The marking allowing the samples identification is legible when examined with normal or corrected vision, without magnification.*

FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

ВЯРНО С ОРИГИНАЛА



На основание чл. 2  
от ЗЗЛД



Laboratoire d'essais  
LABEP

Rapport d'essai : Essai d'endurance sur conducteur de phase  
Test report : Endurance test on phase conductor

Rapport d'essai n°	: 12 09 370	Test report n.	: 12 09 370
Constructeur	: SICAME	Product manufacturer	: SICAME
Référence produit	: MJPT150-70	Product reference	: MJPT150-70
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: du 10 octobre au 13 novembre 2012	Date of the test	: 10 October to 13 November 2012
Date d'émission du rapport	: 15 novembre 2012	Report issue date	: 15 November 2012

Essais réalisés suivant : NF EN 50483-4 (07/2009), § 8.2.7  
Tests carried out in accordance with

Ce rapport comprend : 9 pages  
This report contains

Conclusion : Les manchons de jonction préisolés SICAME de type MJPT150-70 soumis à essai satisfont aux exigences du § 8.2.7 de la norme NF EN 50483-4 (07/2009).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.



Conclusion : The tested SICAME insulated splicing sleeves MJPT150-70 comply with the requirements of clause 8.2.7 of NF EN 50483-4 (July 2009) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основании чл. 2  
от 33ЛД

D 0490 ES

La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.  
With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 89 00 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr



474

**1 Echantillons soumis à essai / Samples under test**

Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT150-70

Fabricant / Manufacturer : SICAME

Numéro de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700640  
*Samples in accordance with drawing n. E0700640*

Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 4

Repérage / Identification : 1, 2, 3, 4

Date de réception au laboratoire : 25 septembre 2012  
*Reception date at the laboratory : 25 September 2012*



На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПРИМКАТА

1,70

## 2 Caractéristiques du matériel / Equipment used during test


### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
99 01 48	Thermomètre indicateur <i>Indicating thermometer</i>	Précision $\pm 2^{\circ}\text{C}$ <i>Accuracy <math>\pm 2^{\circ}\text{C}</math></i>
97 02 02	Régllet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
10 03 21	Chambre froide <i>Low temperature chamber</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
99 00 41	Conductimètre <i>Conductimeter</i>	Précision $30 \mu\text{S/cm}$ <i>Accuracy <math>30 \mu\text{S/cm}</math></i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>
91 02 69	Diélectrimètre BOUCHET (10 kV) <i>Dielectricimeter BOUCHET (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>

### 2.2 Câbles / Cables

N° Lot / Identification	07021		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	70 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	
	<input type="checkbox"/> Rétreinte <i>Compacted</i>	<input checked="" type="checkbox"/> Non rétreinte <i>Non compacted</i>	<input type="checkbox"/> Souple <i>Flexible</i>
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	13,1 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 <i>Cross-linked polyethylene, TIX-5 type</i>		
Ø sur isolant / Ø on insulation	16,1 mm		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Référence du câble HD626 HD626 conductor reference	4 B-1		
Charge de rupture minimale Minimum breaking load	3 000 N		

На основании чл. 2  
от 33ЛД



## 2.2 Câbles / Cables

N° Lot / Identification	11029		
Norme / Standard	WT-92/K-396		
Provenance / From	Pologne / Poland		
Section / Cross section	150 mm <sup>2</sup>		
Matériau de l'âme Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	
	<input checked="" type="checkbox"/> Rétreinte Compacted	<input type="checkbox"/> Non rétreinte Non compacted	<input type="checkbox"/> Souple Flexible
Forme d'âme Conductor shape	<input checked="" type="checkbox"/> Ronde Circular	<input type="checkbox"/> Sectorale Sector-shaped	
Nombre de brins Number of wires	19		
Ø sur âme Ø on conductor	16,1 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé Cross-linked polyethylene		
Ø sur isolant Ø on insulation	19,1 mm		
Conditionnement Conditioned on	1h00 à 110°C 1h00 at 110°C		
Référence du câble HD626 HD626 conductor reference	/		
Charge de rupture minimale (CRM) / Minimum Breaking Load (MBL)	11242 N		

## 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.7 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur quatre manchons pour chaque section.

La charge, pour le type de système approprié, doit être appliquée aux extrémités du conducteur et ajustée comme demandé durant l'essai.

Des cycles thermiques, d'une durée de 90 min, doivent être appliqués au montage d'essai.


500 cycles doivent être réalisés.

Pendant les 45 premières minutes de chaque cycle, le courant traversant l'ensemble doit créer l'élévation de température.

La température de référence du conducteur doit être maintenue à la température normale de service dans un intervalle de  $\pm 3$  K comme indiqué dans l'Annexe C de la EN 50483-1. Cette température est atteinte dans un temps de 5 min à 15 min en début de cycle.

Pendant les 45 dernières minutes, de chaque cycle, le montage en essai doit être refroidi à  $(25 \pm 3)$  °C. La température doit ensuite être maintenue à cette valeur, jusqu'à la fin du cycle.

A intervalle de 24h, à la fin de la période de chauffage à la température normale de service, les températures atteintes par les deux manchons doivent être enregistrées.




На основание чл. 2  
от ЗЗЛД

Insulated splicing sleeves are tested in accordance with NF EN 50483-4 (07/2009) §8.2.7 standard.  
 The test is carried out on 4 Insulated splicing sleeves for each cross-section.  
 The load, for the appropriate type of system, shall be applied to the extremities of the core and varied as required throughout the test.  
 Thermal cycles, with duration of 90 min, shall be applied to the test assembly.  
 There shall be 500 cycles.  
 For the first 45 minutes of every cycle, current flowing through the assembly shall create the temperature rise.  
 The reference temperature of the conductor shall be maintained at the normal operating temperature within an interval of  $\pm 3$  °C as shown in Table B.1 of Annexe B. this temperature shall be reached within 5 min to 15 min at the beginning of the cycle.  
 For the last 45 min, of each cycle, the test assembly shall be cooled to  $(25 \pm 3)$  °C. The temperature shall then be maintained, at this value, until the end of the cycle.  
 At 24 h intervals, at the end of the normal operating temperature heating period, the temperatures reached by the two sleeves shall be recorded.

La figure 1 décrit un exemple typique de dispositif d'essai. La configuration peut différer de ce montage du moment qu'elle respecte les longueurs du conducteur de phase

Figure 1 shows a typical test arrangement. The test configuration can differ from this arrangement as long as it complies with the phase conductor.



ВЪРХО С ОРНИМЕНТАТА

На основание чл. 2  
от ЗЗЛД

475

La variation de la charge mécanique et de la température est décrite sur le diagramme de la Figure 2.

Un effort de traction doit être appliqué jusqu'à une valeur égale à 35 % de la CRM du câble. Cette valeur doit être atteinte approximativement en 1 min.

La charge doit ensuite être maintenue pendant 10 min par un réglage permanent manuel ou automatique. On doit laisser l'ensemble se stabiliser mécaniquement pendant 24 h sans aucun réglage.

Une fois l'ensemble stabilisé les cycles thermiques doivent commencer. A la fin du premier cycle, l'effort de traction doit être réglé à 20 % de la CRM du câble.

Au moins une fois par 24 h, l'effort de traction doit être ajusté à 20 % de la CRM du câble.


*The variation in mechanical load and temperature is shown, diagrammatically, in Figure 2.*

*A tensile load shall be applied until a value equal to 35 % of the MBL is reached. This value shall be achieved in approximately 1 minute.*

*The load shall then be maintained for 10 min using a manual or automatic continuous adjustment. The assembly shall be left to self stabilize mechanically for 24 h without any adjustment.*

*Once the assembly has stabilized the thermal cycles shall be started. At the end of the first cycle, the tensile load shall be set at 20 % of MBL.*

*At least once every 24 h, the tensile load shall be adjusted to 20 % of the MBL.*



———— Variation de la charge mécanique / Mechanical Load Variation  
 - - - - - Température du conducteur / Conductor temperature  
 T Température normale de service / Normal Operating Temperature

Figure 2 – Diagramme des cycles thermiques et des contraintes mécaniques appliqués sur le conducteur de phase

Figure 2 – Diagram of thermal cycles and mechanical stresses applied on phase conductor

ВЯРНО С ОПРИТНАТА

На основание чл. 2  
от ЗЗЛД

600



**Tableau 1 – Effort de traction appliqué**  
*Table 1 – Applied tensile load*

20 % de la CRM du câble 20 % of MBL 2248 N	35% de la CRM du câble 35 % of MBL 3934 N
--	---

La température normale de service du câble est de 80° C.  
*The rated operating temperature of the cable is 80° C.*

A la fin de la période de chauffage, la température des manchons doit être inférieure à la température du conducteur de référence.

Les manchons de Classe 1 et de Classe 2 doivent satisfaire aux exigences de l'essai de tenue diélectrique dans l'air, 8.2.3.1.3.2.

Pour les manchons de Classe 1, l'ensemble formé par le raccord et les conducteurs doit être ensuite retiré des billes métalliques, sans contrainte mécanique, et doit satisfaire aux exigences de l'essai de tenue diélectrique dans l'eau, comme indiqué au 8.2.3.1.3.1, mais avec une tension de 1 kV.

Les quatre manchons doivent satisfaire aux exigences de l'essai mécanique du § 8.2.2.

*At the end of the heating period, the sleeves' temperatures shall be lower than the temperature of the reference core.*

*The Class 1 and the Class 2 sleeves shall meet the requirements of the Dielectrical Voltage Test in Air, Clause 8.2.3.1.3.2.*

*For Class 1 sleeves the assembly formed by the connector and the cores shall then taken out of the metallic balls, without any mechanical stress, and shall meet the requirements of the dielectrical voltage test in water, Clause 8.2.3.1.3.1 but with a voltage of 1 kV.*

*The four sleeves shall meet the requirements of the mechanical test Clause 8.2.2.*

**3.1 Conditions ambiantes / Ambient conditions**

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
*Ambient conditions when performing the test are as follows:*

	Exigences <i>Requirements</i>	Relevés <i>Results</i>
Température ambiante et humidité <i>Ambient temperature and humidity conditions</i>	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	20 °C 39 %HR
Température de l'eau <i>Water temperature</i>	-	20,2 °C
Résistivité de l'eau <i>Water resistivity</i>	≤ 200 Ωm	39,9 Ωm
Temps d'immersion <i>Immersion time</i>	≥ 30 min	31 min
Vitesse de montée en tension <i>Voltage increase rate</i>	≈ 1 kV/s	≈ 1 kV/s

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПИТИВАНАТА

3.2 Configuration des échantillons / Samples configuration

Echantillon n° Sample n.	Section / Cross section (mm²)	
	Câble principal Main cable	Câble dérivé Tap cable
1	150	70
2		
3		
4		

4 Résultats / Results

4.1 Tenue diélectrique

Echantillon n° Sample n.	4 kV pendant 1 minute dans les billes métalliques 4 kV for 1 minute in metallic balls	
	Résultats / Results	Exigences Requirements
1	Pas de claquage / No breakdown	Pas de claquage No breakdown
2	Pas de claquage / No breakdown	
3	Pas de claquage / No breakdown	
4	Pas de claquage / No breakdown	

Echantillon n° Sample n.	1 kV pendant 1 minute dans l'eau 1 kV for 1 minute in water	
	Résultats / Results	Exigences Requirements
1	Pas de claquage / No breakdown	Pas de claquage No breakdown
2	Pas de claquage / No breakdown	
3	Pas de claquage / No breakdown	
4	Pas de claquage / No breakdown	

4.2 Essais mécaniques

Echantillon n° Sample n.	Vitesse de montée programmée Planned increase rate	
	(N/min)	Exigences Requirements (N/min)
1	3000	1000 ≤ ... ≤ 5000
2	3000	
3	3000	
4	3000	

На основании чл. 2  
от ЗЗЛД

ВАРНО С ОБИКНОВАТА

478

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	2248	20 % CRM MBL
2	2248	
3	2248	
4	2248	

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	9555	85 % CRM MBL
2	9555	
3	9555	
4	9555	

**5 Conclusion / Conclusion**

Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
No breakdown or flashover occurred (tripping of voltage generator).

Aucun glissement ou rupture ne s'est produit.  
No slippage or breakage occurred.


FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

ВЯРНО С ОРИГИНАЛА

На основание чл. 2  
от ЗЗЛД

479


**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 150-70**



1. № на тест: 9212380 - Механичен тест;
2. № на тест: 1110440 - Тест за стареене под въздействие на климатичните условия;
3. № на тест: 1209370 - Тест за издръжливост върху фазовия проводник.

На основание чл. 2  
от ЗЗЛД

Съставил:



480



Laboratoire d'essais  
LABEP

Rapport d'essai  
Test report

: Essai d'endurance sur conducteur de phase  
: Endurance test on phase conductor

Rapport d'essai n°	: 12 09 309	Test report n.	: 12 09 309
Constructeur	: SICAME	Product manufacturer	: SICAME
Référence produit	: MJPT150-95	Product reference	: MJPT150-95
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: du 10 octobre au 13 novembre 2012	Date of the test	: 10 October to 13 November 2012
Date d'émission du rapport	: 15 novembre 2012	Report issue date	: 15 November 2012

Essais réalisés suivant : NF EN 50483-4 (07/2009), § 8.2.7  
Tests carried out in accordance with

Ce rapport comprend : 9 pages  
This report contains

**Conclusion** : Les manchons de jonction préisolés SICAME de type MJPT150-95 soumis à essai satisfont aux exigences du § 8.2.7 de la norme NF EN 50483-4 (07/2009).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

**Conclusion** : The tested SICAME insulated splicing sleeves MJPT150-95 comply with the requirements of clause 8.2.7 of NF EN 50483-4 (July 2009) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основание чл. 2  
от ЗЗЛД

03 0000 03

La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.  
With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 89 00 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr

ВЪРНО С ОРИГИНАЛА



*Handwritten signature*

481

**1 Echantillons soumis à essai / Samples under test**

Type : Manchon de jonction préisolé  
*Insulated splicing sleeve*

Désignation / Designation : MJPT150-95

Fabricant / Manufacturer : SICAME

Numéro de lot / Batch number : Tête de série / Head of series  
Echantillons suivant le plan E0700640  
*Samples in accordance with drawing n. E0700640*

Classes du produit selon NF EN 50483-1 (§ 9.3)	
<i>Classes of product in accordance with NF EN 50483-1 (§ 9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 4

Repérage / Identification : 1, 2, 3, 4

Date de réception au laboratoire : 25 septembre 2012  
*Reception date at the laboratory : 25 September 2012*



ВАРНО С ОРИГИНАЛА

На основание чл. 2  
от ЗЗЛД

САМОКОВ

182

## 2 Caractéristiques du matériel / Equipment used during test

## 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
99 01 48	Thermomètre indicateur <i>Indicating thermometer</i>	Précision $\pm 2^{\circ}\text{C}$ <i>Accuracy <math>\pm 2^{\circ}\text{C}</math></i>
97 02 02	Régllet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
10 03 21	Chambre froide <i>Low temperature chamber</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
99 00 41	Conductimètre <i>Conductimeter</i>	Précision $30 \mu\text{S/cm}$ <i>Accuracy <math>30 \mu\text{S/cm}</math></i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
03 02 56	Chronomètre <i>Stop watch</i>	Précision 1 s <i>Accuracy 1s</i>
94 03 09	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>
91 02 69	Diélectrimètre BOUCHÉT (10 kV) <i>Dielectrimeter BOUCHÉT (10 kV)</i>	Précision 0,5mA et 200V <i>Accuracy 0,5mA and 200V</i>

## 2.2 Câbles / Cables

N° Lot / Identification	07021		
Norme / Standard	NF C 33-209		
Provenance / From	France / France		
Section / Cross section	95 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	
	<input type="checkbox"/> Rétreinte <i>Compacted</i>	<input checked="" type="checkbox"/> Non rétreinte <i>Non compacted</i>	<input type="checkbox"/> Souple <i>Flexible</i>
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	13,1 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 <i>Cross-linked polyethylene, TIX-5 type</i>		
Ø sur isolant / Ø on insulation	16,1 mm		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Référence du câble HD626 HD626 conductor reference	4 B-1		
Charge de rupture minimale Minimum breaking load	3 000 N		

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПРИГИНАЛА

ms

CAMOKOB

483

2.2 Câbles / Cables

N° Lot / Identification	11029		
Norme / Standard	WT-92/K-396		
Provenance / From	Pologne / Poland		
Section / Cross section	150 mm <sup>2</sup>		
Matériau de l'âme Conductor material	<input type="checkbox"/> Cuivre Copper	<input checked="" type="checkbox"/> Aluminium	<input type="checkbox"/> Alliage d'aluminium Aluminium alloy
Type d'âme Conductor type	<input type="checkbox"/> Massive Solid	<input checked="" type="checkbox"/> Câblée Stranded	<input type="checkbox"/> Rétroiteinte Non rétroiteinte
Forme d'âme Conductor shape	<input checked="" type="checkbox"/> Ronde Circular	<input type="checkbox"/> Sectorale Sector-shaped	<input type="checkbox"/> Souple Flexible
Nombre de brins Number of wires	19		
Ø sur âme Ø on conductor	16,1 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé Cross-linked polyethylene		
Ø sur isolant Ø on insulation	19,1 mm		
Conditionnement Conditioned on	1h00 à 110°C 1h00 at 110°C		
Référence du câble HD626 HD626 conductor reference	/		
Charge de rupture minimale (CRM) / Minimum Breaking Load (MBL)	11242 N		

3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 8.2.7 de la norme NF EN 50483-4 (07/2009).

L'essai est effectué sur quatre manchons pour chaque section.

La charge, pour le type de système approprié, doit être appliquée aux extrémités du conducteur et ajustée comme demandé durant l'essai.

Des cycles thermiques, d'une durée de 90 min, doivent être appliqués au montage d'essai.


500 cycles doivent être réalisés.

Pendant les 45 premières minutes de chaque cycle, le courant traversant l'ensemble doit créer l'élévation de température.

La température de référence du conducteur doit être maintenue à la température normale de service dans un intervalle de  $\pm 3$  K comme indiqué dans l'Annexe C de la EN 50483-1. Cette température est atteinte dans un temps de 5 min à 15 min en début de cycle.

Pendant les 45 dernières minutes, de chaque cycle, le montage en essai doit être refroidi à  $(25 \pm 3)$  °C. La température doit ensuite être maintenue à cette valeur, jusqu'à la fin du cycle.

A intervalle de 24h, à la fin de la période de chauffage à la température normale de service, les températures atteintes par les deux manchons doivent être enregistrées.



На основание чл. 2  
от ЗЗЛД



Insulated splicing sleeves are tested in accordance with NF EN 50483-4 (07/2009) §8.2.7 standard.

The test is carried out on 4 Insulated splicing sleeves for each cross-section.

The load, for the appropriate type of system, shall be applied to the extremities of the core and varied as required throughout the test.

Thermal cycles, with duration of 90 min, shall be applied to the test assembly.

There shall be 500 cycles.

For the first 45 minutes of every cycle, current flowing through the assembly shall create the temperature rise.


The reference temperature of the conductor shall be maintained at the normal operating temperature within an interval of  $\pm 3$  °C as shown in Table B.1 of Annexe B. this temperature shall be reached within 5 min to 15 min at the beginning of the cycle.

For the last 45 min, of each cycle, the test assembly shall be cooled to  $(25 \pm 3)$  °C. The temperature shall then be maintained, at this value, until the end of the cycle.

At 24 h intervals, at the end of the normal operating temperature heating period, the temperatures reached by the two sleeves shall be recorded.

La figure 1 décrit un exemple typique de dispositif d'essai. La configuration peut différer de ce montage du moment qu'elle respecte les longueurs du conducteur de phase

Figure 1 shows a typical test arrangement. The test configuration can differ from this arrangement as long as it complies with the phase conductor.



На основание чл. 2  
от ЗЗЛД

ВАРНО С ОПРИТНАТА

САМОКОВ

485

La variation de la charge mécanique et de la température est décrite sur le diagramme de la Figure 2.

Un effort de traction doit être appliqué jusqu'à une valeur égale à 35 % de la CRM du câble. Cette valeur doit être atteinte approximativement en 1 min.

La charge doit ensuite être maintenue pendant 10 min par un réglage permanent manuel ou automatique. On doit laisser l'ensemble se stabiliser mécaniquement pendant 24 h sans aucun réglage.

Une fois l'ensemble stabilisé les cycles thermiques doivent commencer. A la fin du premier cycle, l'effort de traction doit être réglé à 20 % de la CRM du câble.

Au moins une fois par 24 h, l'effort de traction doit être ajusté à 20 % de la CRM du câble.


*The variation in mechanical load and temperature is shown, diagrammatically, in Figure 2.*

*A tensile load shall be applied until a value equal to 35 % of the MBL is reached. This value shall be achieved in approximately 1 minute.*

*The load shall then be maintained for 10 min using a manual or automatic continuous adjustment. The assembly shall be left to self stabilize mechanically for 24 h without any adjustment.*

*Once the assembly has stabilized the thermal cycles shall be started. At the end of the first cycle, the tensile load shall be set at 20 % of MBL.*

*At least once every 24 h, the tensile load shall be adjusted to 20 % of the MBL.*



— Variation de la charge mécanique / Mechanical Load Variation  
- - - - - Température du conducteur / Conductor temperature  
T Température normale de service / Normal Operating Temperature

Figure 2 – Diagramme des cycles thermiques et des contraintes mécaniques appliqués sur le conducteur de phase

Figure 2 – Diagram of thermal cycles and mechanical stresses applied on phase conductor .

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОПРИТНАТА

ms

САМОУБ  
LDP

**Tableau 1 – Effort de traction appliqué**  
*Table 1 – Applied tensile load*

20 % de la CRM du câble 20 % of MBL 2248 N	35% de la CRM du câble 35 % of MBL 3934 N
--	---

La température normale de service du câble est de 80° C.  
*The rated operating temperature of the cable is 80° C.*

A la fin de la période de chauffage, la température des manchons doit être inférieure à la température du conducteur de référence.

Les manchons de Classe 1 et de Classe 2 doivent satisfaire aux exigences de l'essai de tenue diélectrique dans l'air, 8.2.3.1.3.2.

Pour les manchons de Classe 1, l'ensemble formé par le raccord et les conducteurs doit être ensuite retiré des billes métalliques, sans contrainte mécanique, et doit satisfaire aux exigences de l'essai de tenue diélectrique dans l'eau, comme indiqué au 8.2.3.1.3.1, mais avec une tension de 1 kV.

Les quatre manchons doivent satisfaire aux exigences de l'essai mécanique du § 8.2.2.

*At the end of the heating period, the sleeves' temperatures shall be lower than the temperature of the reference core.*

*The Class 1 and the Class 2 sleeves shall meet the requirements of the Dielectrical Voltage Test in Air, Clause 8.2.3.1.3.2.*

*For Class 1 sleeves the assembly formed by the connector and the cores shall then taken out of the metallic balls, without any mechanical stress, and shall meet the requirements of the dielectrical voltage test in water, Clause 8.2.3.1.3.1 but with a voltage of 1 kV.*

*The four sleeves shall meet the requirements of the mechanical test Clause 8.2.2.*

### 3.1 Conditions ambiantes / Ambient conditions

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
*Ambient conditions when performing the test are as follows:*

	Exigences <i>Requirements</i>	Relevés <i>Results</i>
Température ambiante et humidité <i>Ambient temperature and humidity conditions</i>	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	20 °C 39 %HR
Température de l'eau <i>Water temperature</i>	-	20,2 °C
Résistivité de l'eau <i>Water resistivity</i>	≤ 200 Ωm	39,9 Ωm
Temps d'immersion <i>Immersion time</i>	≥ 30 min	31 min
Vitesse de montée en tension <i>Voltage increase rate</i>	≈ 1 kV/s	≈ 1 kV/s

На основание чл. 2  
от ЗЗЛД

ВАРНО С ОПРИГНАЛАТА

САМОКОВ

487

3.2 Configuration des échantillons / *Samples configuration*

Echantillon n° <i>Sample n.</i>	Section / <i>Cross section (mm²)</i>	
	Câble principal <i>Main cable</i>	Câble dérivé <i>Tap cable</i>
1	150	95
2		
3		
4		

4 Résultats / *Results*

4.1 Tenue diélectrique

Echantillon n° <i>Sample n.</i>	4 kV pendant 1 minute dans les billes métalliques <i>4 kV for 1 minute in metallic balls</i>	
	Résultats / <i>Results</i>	Exigences <i>Requirements</i>
1	Pas de claquage / <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>
2	Pas de claquage / <i>No breakdown</i>	
3	Pas de claquage / <i>No breakdown</i>	
4	Pas de claquage / <i>No breakdown</i>	

Echantillon n° <i>Sample n.</i>	1 kV pendant 1 minute dans l'eau <i>1 kV for 1 minute in water</i>	
	Résultats / <i>Results</i>	Exigences <i>Requirements</i>
1	Pas de claquage / <i>No breakdown</i>	Pas de claquage <i>No breakdown</i>
2	Pas de claquage / <i>No breakdown</i>	
3	Pas de claquage / <i>No breakdown</i>	
4	Pas de claquage / <i>No breakdown</i>	

4.2 Essais mécaniques

Echantillon n° <i>Sample n.</i>	Vitesse de montée programmée <i>Planned increase rate</i>	
	(N/min)	Exigences <i>Requirements</i>
1	3000	1000 ≤ ... ≤ 5000
2	3000	
3	3000	
4	3000	

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОРИГИНАЛА

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	2248	20 % CRM MBL
2	2248	
3	2248	
4	2248	

Echantillon n° Sample n.	Effort pendant 1 minute Strength during 1 min (N)	Exigences Requirements (N)
1	9555	85 % CRM MBL
2	9555	
3	9555	
4	9555	

### 5 Conclusion / Conclusion

Aucun claquage ou contournement ne s'est produit (déclenchement du générateur de tension).  
No breakdown or flashover occurred (tripping of voltage generator).

Aucun glissement ou rupture ne s'est produit.  
No slippage or breakage occurred.

FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОРИГИНАЛА

САМОКОВ

489

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
СЪЕДИНИТЕЛ ТИП МЈРТ 150-95**

1. № на тест: 1209309 - Тест за издръжливост върху фазовия проводник.

Съставил:

На основание чл. 2  
от ЗЗЛД



490



*[Handwritten signature]*

**CONTENTS**

	PAGES
<b>I) INTRODUCTION</b> .....	3
1.1 Subject .....	3
1.2 Tested products.....	3
1.3 Order of tests .....	3
 <b>II) STANDARD DOCUMENTS REFERRED TO IN THIS TEST REPORT</b> .....	 4
 <b>III) GENERAL CONDITIONS</b> .....	 4
 <b>IV) TESTS (*)</b> .....	 4
2.3.1 Mechanical tests - Crimping aptitude test .....	5
2.3.2 Mechanical tests - Tensile test .....	6
2.4 Dielectric and watertightness tests.....	9
2.5 Low temperature assembly test.....	12
2.6 Climatic ageing test.....	14
2.8 Electric ageing test.....	19
2.9 Endurance test under mechanical and thermal stresses.....	36

(\*) The numbers of paragraph are given in the standard NF C 33-021 dated June 1996.

**ВЯРНО С ОРИГИНАЛА**



*[Handwritten signature]*



1) INTRODUCTION

1.1 Subject

This document gathers the qualification tests of MJPT sleeves (K101, K103, K106, K110, K121, K123, K115, K116, K170 and K175). Tested products are of MICHAUD's manufacture.

Test procedures are the ones of the standard NF C 33-021 dated June 1998.

For each test, there is a test sheet gathering procedures and results.

1.2 Tested products

Tested products are preinsulated sleeves for aerial conductors according to the technical file «MJPT». These products are coming from an industrial series and have been delivered to Test Laboratory on 09/01/2006.

DESIGNATION	REFERENCE	N° OF BATCH
PREINSULATED SLEEVE (173) MJPT 16	K 101	05 50 51
PREINSULATED SLEEVE (173) MJPT 25	K 103	05 47 49
PREINSULATED SLEEVE (173) MJPT 35	K 106	05 35 13
PREINSULATED SLEEVE (173) MJPT 50	K 110	05 47 50
PREINSULATED SLEEVE (173) MJPT 70	K 121	05 50 20
PREINSULATED SLEEVE (173) MJPT 95	K 123	05 50 07
PREINSULATED SLEEVE (173) MJPT 54	K 115	05 50 65
PREINSULATED SLEEVE (173) MJPT 70	K 116	05 50 66
PREINSULATED SLEEVE (215) MJPT 95	K 170	05 47 46
PREINSULATED SLEEVE (215) MJPT 150	K 175	05 50 01

1.3 Order of test

Tests are performed on 8 sleeves MJPT 16, MJPT 25, MJPT 35, MJPT 50, MJPT 70, MJPT 95 (215), MJPT 54N and on 20 sleeves MJPT 95 (173), MJPT 150 and MJPT 70N.

NUMBER OF SAMPLES		TESTS
MJPT 16, MJPT 25, MJPT 35, MJPT 50, MJPT 70, MJPT 95 (215) AND MJPT 54N	MJPT 95 (173), MJPT 150 AND MJPT 70N	
/	1 and 2	2.3.1 Mechanical tests - Crimping aptitude test
1 and 2	3 and 4	2.3.2 Mechanical tests - Tensile test
3 up to 6	5 up to 8	2.4 Dielectric and watertightness tests 2.6 Climatic ageing test
7 and 8	9 and 10	2.5 Low temperature assembly test 2.4 Dielectric and watertightness tests 2.3.2 Mechanical tests - Tensile test
/	11 up to 16	2.8 Electric ageing test
/	17 up to 20	2.9 Endurance test under mechanical and thermal stresses 2.3.2 Mechanical tests - Tensile test

ВЪРНО С ОРИГИНАЛА



493

II) STANDARD DOCUMENTS REFERRED TO IN THIS REPORT

- French standards

- C 20-540 : June 2002,  
«Environmental test - Test methods - Climatic ageing test of equipment and synthetic materials for outdoor use».
- NF C 33-004 : June 1998,  
«Insulated cables and their accessories for power systems - Connecting equipment for overhead distributions and services of rated voltage 0,6/1kV with at least one insulated core - Electrical ageing test».
- NF C 33-021 : June 1998,  
«Insulated cables and their accessories for power systems - Preinsulated compression type connecting equipment for overhead distributions and services of rated voltage 0,6/1kV with bundle assembled cores».
- NF C 33-209 : July 1996,  
«Insulated or shielded cables for power systems - Bundle assembled cores for overhead systems of rated voltage 0,6/1kV».

III) GENERAL CONDITIONS

• Temperature

Tests are carried out at the room temperature of the test laboratory between 20°C and 26°C.



• Cores used

STANDARD	NAME OF MANUFACTURER	NOMINAL CROSS-SECTIONAL AREA (in mm <sup>2</sup> )	NUMBER OF STRANDS AND COMPOSITION OF CORE	Ø OVER INSULANT (in mm)	Ø OVER CORE (in mm)
NF C 33-209	NEXANS	150	19 strands aluminium	17,5	13,9
		95	19 strands aluminium	15,0	11,2
		70	12 strands aluminium	13,6	10,1
		70N	7 strands aluminium alloy	13,3	10,2
		54,6N	7 strands aluminium alloy	12,5	9,4
		50	7 strands aluminium	11,2	8,3
		35	7 strands aluminium	10,6	7,1
		25	7 strands aluminium	9,0	6,0
		16	7 strands aluminium	7,4	4,8

Before tests, cores are conditioned, according to § 2.2.2 of the standard NF C 33-021 as follows : they are put in an enclosure during 1 h at 120°C, then the door of enclosure is opened so that conductors come back to room temperature.

IV) TESTS

On the following pages, sheets of each performed test can be found.



<b>MICHAUD SA</b> TEST LABORATORY	<b>TEST REPORT</b> QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115, K116, K170 AND K175) N° 130-06-02-03	Date : 16/06/06 Page : 5/39
--------------------------------------	--	--------------------------------

<u>TEST DESCRIPTION</u> : 2.3.1 Mechanical tests – Crimping aptitude test	Page 1/1
---	----------

<u>DATE</u> : 22/02/2006 <u>PLACE</u> : MICHAUD test laboratory	<u>OPERATOR</u> : AC. BERNARD
--	-------------------------------

N° OF SAMPLES : 1 and 2 for sleeves MJPT 95 (173), MJPT 150 and MJPT 70N

TEST EQUIPMENTS  
- Measure equipment for traction / compression

PROCEDURES

Procedures and acceptance criteria are the ones of § 2.3.1 of standard NF C 33-021 dated June 1998.

Samples are fitted on aluminium cores stripped over the length indicated on the sleeve.


Then, they are crimped with the measure equipment for traction / compression, according to the installation instructions. Crimping is performed with 9mm width dies type E173 for sleeves MJPT 95 and MJPT 70N and type E215 for sleeves MJPT 150.

The crimping strength applied is 5 000 daN.

At the end of the test, the two half-dies must be in contact : a 0,05 mm thick wedge does not go in.

TEST RESULTS

TYPE OF SLEEVES	N° OF SAMPLE	PREVIOUS TEST	SECTION OF CONDUCTOR (in mm²)	COMMENTS AFTER CRIMPING	FOLLOWING TEST
MJPT 95 (173)	1	/	95mm² Al	Satisfactory : The 0,05 mm thick wedge does not go in	/
	2	/		Satisfactory : The 0,05 mm thick wedge does not go in	
MJPT 150	1	/	150mm² Al	Satisfactory : The 0,05 mm thick wedge does not go in	/
	2	/		Satisfactory : The 0,05 mm thick wedge does not go in	
MJPT 70N	1	/	70mm² Al alloy	Satisfactory : The 0,05 mm thick wedge does not go in	/
	2	/		Satisfactory : The 0,05 mm thick wedge does not go in	



495

<b>MICHAUD SA</b> TEST LABORATORY	<b>TEST REPORT</b> QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115, K116, K170 AND K175) N° 130-06-02-03	Date : 16/06/06 Page : 6/39
--------------------------------------	--	--------------------------------

<b>TEST DESCRIPTION :</b> 2.3.2 Mechanical tests - Tensile test	Page 1/3
---	----------

<b>DATE :</b> 10/01/2006, 11/01/2006, 13/01/2006, 03/04/2006, 09/05/2006, 13/06/2006 <b>PLACE :</b> MICHAUD test laboratory	<b>OPERATOR :</b> AC. BERNARD
---	-------------------------------

<b>N° OF SAMPLES :</b> 3, 4, 9, 10 and 17 up to 20 for sleeves MJPT 95 (173), MJPT 150 and MJPT 70N 1, 2, 7 and 8 for the other type of sleeves
--

<b>TEST EQUIPMENTS</b> - Measure equipment for traction / compression - Mechanical tensile strength and endurance bench
---

<b>PROCEDURES</b>
<p>Procedures and acceptance criteria are the ones of § 2.3.2 of standard NF C 33-021 dated June 1998.</p>
<p>Samples are fitted on 30cm length cores stripped over the length indicated on the sleeve. They are crimped with a pneumatic jack and adapted dies.</p>
<p>So as to assure a good crimping of the preinsulated sleeves, we check that a 0,05 mm thick wedge does not go in.</p>
<p>Then, the assembly sleeve - cores is installed between the clamping jaws of the tensile strength machine. Then, an increasing tensile strength is applied on the conductor core which progress is comprised between 1 000N/min and 5 000N/min up to the following F1 values and for the following duration :</p>
<ul style="list-style-type: none"> <li>• 500N for 1 minute for 16mm<sup>2</sup> Al conductor,</li> <li>• 900N for 1 minute for 25mm<sup>2</sup> Al conductor,</li> <li>• 1 300N for 1 minute for 35mm<sup>2</sup> Al conductor,</li> <li>• 1 800N for 1 minute for 50mm<sup>2</sup> Al conductor,</li> <li>• 2 500N for 1 minute for 70mm<sup>2</sup> Al conductor,</li> <li>• 3 375N for 1 minute for 95mm<sup>2</sup> Al conductor,</li> <li>• 5 300N for 1 minute for 150mm<sup>2</sup> Al conductor,</li> <li>• 10 300N for 1 minute for 54,6mm<sup>2</sup> Al alloy conductor,</li> <li>• 12 700N for 1 minute for 70mm<sup>2</sup> Al alloy conductor.</li> </ul>
<p>Then, the strength is raised until the following F2 values, then it is released :</p>
<ul style="list-style-type: none"> <li>• 1 200N for 16mm<sup>2</sup> Al conductor,</li> <li>• 1 800N for 25mm<sup>2</sup> Al conductor,</li> <li>• 2 500N for 35mm<sup>2</sup> Al conductor,</li> <li>• 3 500N for 50mm<sup>2</sup> Al conductor,</li> <li>• 5 000N for 70mm<sup>2</sup> Al conductor,</li> <li>• 6 750N for 95mm<sup>2</sup> Al conductor,</li> <li>• 10 500N for 150mm<sup>2</sup> Al conductor,</li> <li>• 15 800N for 54,6mm<sup>2</sup> Al alloy conductor,</li> <li>• 19 500N for 70mm<sup>2</sup> Al alloy conductor.</li> </ul>
<p>No slip shall be noticed.</p>

**ВЯРНО С ОРИГИНАЛА**



*Handwritten scribble*

*Handwritten mark*

TEST DESCRIPTION : 2.3.2 Mechanical tests - Tensile test

Page 2/3

TEST RESULTS

TYPE OF SLEEVES	N° OF SAMPLE	PREVIOUS TEST	SECTION OF CONDUCTOR (in mm <sup>2</sup> )	F1 STRENGTH APPLIED DURING THE STEP	F2 STRENGTH APPLIED (in N)	COMMENTS	FOLLOWING TEST
MJPT 16	1	/	16mm <sup>2</sup> Al	600	1 200	Satisfactory	/
	2		16mm <sup>2</sup> Al	600	1 200	Satisfactory	
	7	2.4	16mm <sup>2</sup> Al	600	1 200	Satisfactory	
	8		16mm <sup>2</sup> Al	600	1 200	Satisfactory	
MJPT 25	1	/	25mm <sup>2</sup> Al	900	1 800	Satisfactory	/
	2		25mm <sup>2</sup> Al	900	1 800	Satisfactory	
	7	2.4	25mm <sup>2</sup> Al	900	1 800	Satisfactory	
	8		25mm <sup>2</sup> Al	900	1 800	Satisfactory	
MJPT 35	1	/	35mm <sup>2</sup> Al	1 300	2 500	Satisfactory	/
	2		35mm <sup>2</sup> Al	1 300	2 500	Satisfactory	
	7	2.4	35mm <sup>2</sup> Al	1 300	2 500	Satisfactory	
	8		35mm <sup>2</sup> Al	1 300	2 500	Satisfactory	
MJPT 50	1	/	50mm <sup>2</sup> Al	1 800	3 500	Satisfactory	/
	2		50mm <sup>2</sup> Al	1 800	3 500	Satisfactory	
	7	2.4	50mm <sup>2</sup> Al	1 800	3 500	Satisfactory	
	8		50mm <sup>2</sup> Al	1 800	3 500	Satisfactory	
MJPT 70	1	/	70mm <sup>2</sup> Al	2 500	5 000	Satisfactory	/
	2		70mm <sup>2</sup> Al	2 500	5 000	Satisfactory	
	7	2.4	70mm <sup>2</sup> Al	2 500	5 000	Satisfactory	
	8		70mm <sup>2</sup> Al	2 500	5 000	Satisfactory	
MJPT 95 (215)	1	/	95mm <sup>2</sup> Al	3 375	6 750	Satisfactory	/
	2		95mm <sup>2</sup> Al	3 375	6 750	Satisfactory	
	7	2.4	95mm <sup>2</sup> Al	3 375	6 750	Satisfactory	
	8		95mm <sup>2</sup> Al	3 375	6 750	Satisfactory	
MJPT 54N	1	/	54,6N Al alloy	10 300	15 800	Satisfactory	/
	2		54,6N Al alloy	10 300	15 800	Satisfactory	
	7	2.4	54,6N Al alloy	10 300	15 800	Satisfactory	
	8		54,6N Al alloy	10 300	15 800	Satisfactory	

ВАРНО С ОПРИГНАЛАТА



TEST DESCRIPTION : 2.3.2 Mechanical tests - Tensile test

Page 3/3

TEST RESULTS

TYPE OF SLEEVES	N° OF SAMPLE	PREVIOUS TEST	SECTION OF CONDUCTOR (in mm²)	F1 STRENGTH APPLIED DURING THE STEP	F2 STRENGTH APPLIED (in N)	COMMENTS	FOLLOWING TEST
MJPT 95 (173)	3	/	95mm² Al	3 375	6 750	Satisfactory	/
	4		95mm² Al	3 375	6 750	Satisfactory	
	9	2.4	95mm² Al	3 375	6 750	Satisfactory	
	10		95mm² Al	3 375	6 750	Satisfactory	
	17	2.9	95mm² Al	3 375	6 750	Satisfactory	
	18		95mm² Al	3 375	6 750	Satisfactory	
	19		95mm² Al	3 375	6 750	Satisfactory	
	20		95mm² Al	3 375	6 750	Satisfactory	
	MJPT 150	3	/	150mm² Al	5 300	10 500	
4			150mm² Al	5 300	10 500	Satisfactory	
9		2.4	150mm² Al	5 300	10 500	Satisfactory	
10			150mm² Al	5 300	10 500	Satisfactory	
17		2.9	150mm² Al	5 300	10 500	Satisfactory	
18			150mm² Al	5 300	10 500	Satisfactory	
19			150mm² Al	5 300	10 500	Satisfactory	
20			150mm² Al	5 300	10 500	Satisfactory	
MJPT 70N		3	/	70mm² Al alloy	12 700	19 500	Satisfactory
	4		70mm² Al alloy	12 700	19 500	Satisfactory	
	9	2.4	70mm² Al alloy	12 700	19 500	Satisfactory	
	10		70mm² Al alloy	12 700	19 500	Satisfactory	
	17	2.9	70mm² Al alloy	12 700	19 500	Satisfactory	
	18		70mm² Al alloy	12 700	19 500	Satisfactory	
	19		70mm² Al alloy	12 700	19 500	Satisfactory	
	20		70mm² Al alloy	12 700	19 500	Satisfactory	

ВЯРНО С ОПИМАНАТА



12/00

**TEST DESCRIPTION : 2.4 Dielectric and watertightness tests** Page 1/3

**DATE : FROM 10/01/2006 TO 12/01/2006**  
**PLACE : MICHAUD test laboratory** **OPERATORS : AC. BERNARD**  
**JP. RAPY**

**N° OF SAMPLES : 5 up to 10 for sleeves MJPT 95 (173), MJPT 150 and MJPT 70N**  
**3 up to 8 for the other type of sleeves.**

**TEST EQUIPMENTS**  
 - Measure equipment for traction / compression  
 - Dielectric test equipment A 1105


**PROCEDURES**

Procedures and acceptance criteria are the ones of § 2.4 of standard NF C 33-021 dated June 1998.

Samples are fitted on cores stripped over the length indicated on the sleeve. They are crimped with a pneumatic jack and adapted dies.

So as to assure a good crimping of the preinsulated sleeves, we check that a 0,05 mm thick wedge does not go in.

After having put a sealing cap on one of the stripped extremities of the conductor, assemblies sleeve - cores are installed vertically in water, as shown below :



Voltage generator used is regulated to release under a 10 mA leakage current.  
 After 30 min under water, a dielectric test is performed on the assembly under a 6 kV voltage at an industrial frequency for 1 min. The increase of voltage is performed at 1 kV/s speed.  
 No breakage (release of voltage source) shall occur.

**TEST RESULTS**

TYPE OF SLEEVES	N° OF SAMPLE	PREVIOUS TEST	SECTION OF CONDUCTOR (in mm <sup>2</sup> )	COMMENTS AFTER 1 min UNDER 6kV	FOLLOWING TEST
MJPT 16	3	/	16mm <sup>2</sup> Al	Satisfactory	2.6
	4		16mm <sup>2</sup> Al	Satisfactory	
	5		16mm <sup>2</sup> Al	Satisfactory	
	6		16mm <sup>2</sup> Al	Satisfactory	

ВЪРНО С ОПИТИНАТА



*[Handwritten signature]*

2009

MICHAUD SA  
TEST LABORATORY

**TEST REPORT**  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-08-02-03


Date : 16/06/06  
Page : 10/39

TEST DESCRIPTION : 2.4 Dielectric and watertightness tests

Page 2/3

TYPE OF SLEEVES	N° OF SAMPLE	PREVIOUS TEST	SECTION OF CONDUCTOR (in mm <sup>2</sup> )	COMMENTS AFTER 1 min UNDER 6kV	FOLLOWING TEST
MJPT 16	7	2.5	16mm <sup>2</sup> Al	Satisfactory	2.3.2
	8		16mm <sup>2</sup> Al	Satisfactory	
MJPT 25	3	/	25mm <sup>2</sup> Al	Satisfactory	2.6
	4		25mm <sup>2</sup> Al	Satisfactory	
	5		25mm <sup>2</sup> Al	Satisfactory	
	6		25mm <sup>2</sup> Al	Satisfactory	
	7	2.5	25mm <sup>2</sup> Al	Satisfactory	2.3.2
	8		25mm <sup>2</sup> Al	Satisfactory	
MJPT 35	3	/	35mm <sup>2</sup> Al	Satisfactory	2.6
	4		35mm <sup>2</sup> Al	Satisfactory	
	5		35mm <sup>2</sup> Al	Satisfactory	
	6		35mm <sup>2</sup> Al	Satisfactory	
	7	2.5	35mm <sup>2</sup> Al	Satisfactory	2.3.2
	8		35mm <sup>2</sup> Al	Satisfactory	
MJPT 50	3	/	50mm <sup>2</sup> Al	Satisfactory	2.6
	4		50mm <sup>2</sup> Al	Satisfactory	
	5		50mm <sup>2</sup> Al	Satisfactory	
	6		50mm <sup>2</sup> Al	Satisfactory	
	7	2.5	50mm <sup>2</sup> Al	Satisfactory	2.3.2
	8		50mm <sup>2</sup> Al	Satisfactory	
MJPT 70	3	/	70mm <sup>2</sup> Al	Satisfactory	2.6
	4		70mm <sup>2</sup> Al	Satisfactory	
	5		70mm <sup>2</sup> Al	Satisfactory	
	6		70mm <sup>2</sup> Al	Satisfactory	
	7	2.5	70mm <sup>2</sup> Al	Satisfactory	2.3.2
	8		70mm <sup>2</sup> Al	Satisfactory	
MJPT 95 (215)	3	/	95mm <sup>2</sup> Al	Satisfactory	2.6
	4		95mm <sup>2</sup> Al	Satisfactory	
	5		95mm <sup>2</sup> Al	Satisfactory	
	6		95mm <sup>2</sup> Al	Satisfactory	
	7	2.5	95mm <sup>2</sup> Al	Satisfactory	2.3.2
	8		95mm <sup>2</sup> Al	Satisfactory	

ВЯРНО С ОПРИГНАТА



*Handwritten signature*

5071



MICHAUD SA  
TEST LABORATORY

**TEST REPORT**  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03


Date : 16/06/06  
Page : 11/39

TEST DESCRIPTION : 2.4 Dielectric and watertightness tests

Page 3/3

TYPE OF SLEEVES	N° OF SAMPLE	PREVIOUS TEST	SECTION OF CONDUCTOR (in mm <sup>2</sup> )	COMMENTS AFTER 1 min UNDER 6kV	FOLLOWING TEST	
MJPT 54N	3	/	54,6N Al alloy	Satisfactory	2.6	
	4		54,6N Al alloy	Satisfactory		
	5		54,6N Al alloy	Satisfactory		
	6		54,6N Al alloy	Satisfactory		
	7	2.5	54,6N <sup>2</sup> Al alloy	Satisfactory	2.3.2	
	8		54,6N <sup>2</sup> Al alloy	Satisfactory		
	MJPT 95 (173)	5	/	95mm <sup>2</sup> Al	Satisfactory	2.6
		6		95mm <sup>2</sup> Al	Satisfactory	
7		95mm <sup>2</sup> Al		Satisfactory		
8		95mm <sup>2</sup> Al		Satisfactory		
9		2.5	95mm <sup>2</sup> Al	Satisfactory	2.3.2	
10			95mm <sup>2</sup> Al	Satisfactory		
MJPT 150	5	/	150mm <sup>2</sup> Al	Satisfactory	2.6	
	6		150mm <sup>2</sup> Al	Satisfactory		
	7		150mm <sup>2</sup> Al	Satisfactory		
	8		150mm <sup>2</sup> Al	Satisfactory		
	9	2.5	150mm <sup>2</sup> Al	Satisfactory	2.3.2	
	10		150mm <sup>2</sup> Al	Satisfactory		
MJPT 70N	5	/	70N Al alloy	Satisfactory	2.6	
	6		70N Al alloy	Satisfactory		
	7		70N Al alloy	Satisfactory		
	8		70N Al alloy	Satisfactory		
	9	2.5	70N Al alloy	Satisfactory	2.3.2	
	10		70N Al alloy	Satisfactory		

ВЯРНО С ОПРИМНАТА



miss

PO1

MICHAUD SA  
TEST LABORATORY

**TEST REPORT**  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03

Date : 16/06/06  
Page : 12/39

TEST DESCRIPTION : 2.5 Low temperature assembly test

Page 1/2

DATE : 12/01/2006

PLACE : MICHAUD test laboratory

OPERATOR : AC. BERNARD

N° OF SAMPLES : 9 and 10 for sleeves MJPT 95 (173), MJPT 150 and MJPT 70N  
3 and 8 for the other types of sleeves

TEST EQUIPMENTS

- Enclosure with regulated temperature - 25°C + 45°C
- Measure equipment for traction / compression

PROGEDURES

Procedures and acceptance criteria are the ones of § 2.5 of standard NF C 33-021 dated June 1998.

Each sleeve as well as cores which are ready to be fitted, are installed in the enclosure with regulated temperature - 25°C + 45°C, at a temperature of - 11°C.

After one hour, the assembly being kept in the enclosure, the sleeve is crimped with a pneumatic jack and adapted dies.

So as to assure a good crimping of the preinsulated sleeves, we check that a 0,05 mm thick wedge does not go in.

3 h after its exit of the enclosure with regulated temperature - 25°C + 45°C, the sleeve being fitted is subjected to the dielectric and watertightness tests, then to the tensile test (respectively § 2.4 and 2.3.2 of this test report).

TEST RESULTS

TYPE OF SLEEVES	N° OF SAMPLE	PREVIOUS TEST	SECTION OF CONDUCTOR (in mm <sup>2</sup> )	COMMENTS DURING THE ASSEMBLY AT -11°C	FOLLOWING TEST
MJPT 16	7	/	16mm <sup>2</sup> Al	Satisfactory	2.4
	8		16mm <sup>2</sup> Al	Satisfactory	
MJPT 25	7	/	25mm <sup>2</sup> Al	Satisfactory	2.4
	8		25mm <sup>2</sup> Al	Satisfactory	
MJPT 35	7	/	35mm <sup>2</sup> Al	Satisfactory	2.4
	8		35mm <sup>2</sup> Al	Satisfactory	
MJPT 50	7	/	50mm <sup>2</sup> Al	Satisfactory	2.4
	8		50mm <sup>2</sup> Al	Satisfactory	
MJPT 70	7	/	70mm <sup>2</sup> Al	Satisfactory	2.4
	8		70mm <sup>2</sup> Al	Satisfactory	
MJPT 95 (215)	7	/	95mm <sup>2</sup> Al	Satisfactory	2.4
	8		95mm <sup>2</sup> Al	Satisfactory	
MJPT 54N	7	/	54,6N Al alloy	Satisfactory	2.4
	8		54,6N Al alloy	Satisfactory	

ВАЖНО С ОПРИГНАЛАТА



MICHAUD SA  
TEST LABORATORY

TEST REPORT

QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03

Date : 16/06/06

Page : 13/39

TEST DESCRIPTION : 2.5 Low temperature assembly test

Page 2/2

TYPE OF SLEEVES	N° OF SAMPLE	PREVIOUS TEST	SECTION OF CONDUCTOR (in mm <sup>2</sup> )	COMMENTS DURING THE ASSEMBLY AT -11°C	FOLLOWING TEST
MJPT 95 (173)	9	/	95mm <sup>2</sup> Al	Satisfactory	2.4
	10		95mm <sup>2</sup> Al	Satisfactory	
MJPT 150	9	/	150mm <sup>2</sup> Al	Satisfactory	2.4
	10		150mm <sup>2</sup> Al	Satisfactory	
MJPT 70N	9	/	70N Al alloy	Satisfactory	2.4
	10		70N Al alloy	Satisfactory	

ВЯРНО С ОПИТАНАТА



SD?

**TEST DESCRIPTION : 2.6 Climatic ageing test** Page 1/5

**DATE : FROM 13/01/2006 TO 28/02/2006**  
**PLACE : MICHAUD laboratory test** **OPERATORS : A. BERNARD**  
**JP. ROPY**

**N° OF SAMPLES : 5 up to 8 for sleeves MJPT 95 (173), MJPT 150 and MJPT 70N**  
**3 up to 6 for the other types of sleeves**

**TEST EQUIPMENTS**  
 - Climatic ageing enclosure XR 35

PROCEDURES

Procedure and acceptance criteria are the ones of § 2.6 of standard NF C 33-021 dated June 1998.

**CLIMATIC TEST**

Procedures of this test are the ones of standard C 20-540 dated June 2002.

Samples support 6 weekly cycles, the enclosure temperature being 70 (± 2) °C for the conditionings A and C.



**ACCEPTANCE CRITERIA**

At the end of the climatic ageing cycles, the samples shall comply with the following tests, after being placed in the test laboratory atmosphere for at least 24 h without exceeding 72 h :

- ◊ **Dielectric test :**
  - \* The assembly, placed horizontally, is covered with lead balls, over 1 to 2cm. After 1min, a dielectric test is performed on the assembly at a 6kV voltage at an industrial frequency during 1min. Increase of voltage is performed at a 1kV/s speed. No breakage shall occur.
  - \* A dielectric test is performed on the assembly under a 1kV voltage, according to § 2.4 of this test report. No breakage shall occur.
- ◊ **Visual control :**
  - \* At the end of the tests, marking of the pieces shall be legible when examined with normal or correction vision without magnification.

TEST RESULTS

TYPE OF SLEEVES	SAMPLE N°	PREVIOUS TEST	COMMENTS AFTER 6 WEEKS CLIMATIC AGEING TEST	DIELECTRIC TEST		LEGIBILITY IDENTIFICATION MARKING	FOLLOWING TEST
				6KV TEST IN LEAD	1KV TEST IN WATER		
MJPT 16	3	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	4		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	



*Handwritten signature*

*Handwritten mark*

MICHAUD SA  
TEST LABORATORY

TEST REPORT

QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115, K116, K170 AND K175) N° 130-06-02-03


Date : 16/06/06  
Page : 15/39

TEST DESCRIPTION : 2.6 Climatic ageing test

Page 2/5

TYPE OF SLEEVES	SAMPLE N°	PREVIOUS TEST	COMMENTS AFTER 6 WEEKS CLIMATIC AGEING TEST	DIELECTRIC TEST		LEGIBILITY IDENTIFICATION MARKING	FOLLOWING TEST
				6KV TEST IN LEAD	1KV TEST IN WATER		
MJPT 16	5	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
MJPT 25	3	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	4		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	5		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
MJPT 35	3	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	4		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	5		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
MJPT 150	3	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/

ВЕРНО С ОПИШНАТА



Handwritten signature

501

TEST DESCRIPTION : 2.6 Climatic ageing test

Page 3/5

TYPE OF SLEEVES	SAMPLE N°	PREVIOUS TEST	COMMENTS AFTER 6 WEEKS CLIMATIC AGEING TEST	DIELECTRIC TEST		LEGIBILITY IDENTIFICATION MARKING	FOLLOWING TEST
				6KV TEST IN LEAD	1KV TEST IN WATER		
MJPT 150	4	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	5		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
MJPT 70	3	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	4		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	5		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
MJPT 95 (215)	3	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	4		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	5		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	

ВЕРНО С ОРИГИНАЛАТА



MICHAUD SA  
TEST LABORATORY

**TEST REPORT**  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03

Date : 16/06/06  
Page : 17/39

TEST DESCRIPTION : 2.6 Climatic ageing test

Page 4/5

TYPE OF SLEEVES	SAMPLE N°	PREVIOUS TEST	COMMENTS AFTER 6 WEEKS CLIMATIC AGEING TEST	DIELECTRIC TEST		LEGIBILITY IDENTIFICATION MARKING	FOLLOWING TEST
				6KV TEST IN LEAD	1KV TEST IN WATER		
MJPT 54N	3	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	4		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	5		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
MJPT 95 (173)	5	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	7		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	8		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
MJPT 150	5	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	7		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	

ВАРНО С ОПИТИВАНАТА



Handwritten signature

507

MICHAUD SA  
TEST LABORATORY

**TEST REPORT**  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03

Date : 16/06/06  
Page : 18/39

TEST DESCRIPTION : 2.6 Climatic ageing test

Page 5/5

TYPE OF SLEEVES	SAMPLE N°	PREVIOUS TEST	COMMENTS AFTER 6 WEEKS CLIMATIC AGEING TEST	DIELECTRIC TEST		LEGIBILITY IDENTIFICATION MARKING	FOLLOWING TEST
				6KV TEST IN LEAD	1KV TEST IN WATER		
MJPT 150	8	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
MJPT 70N	5	2.4	No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	/
	6		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	7		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	
	8		No visible damage (the body has slightly whitened and the cap has slightly faded on the side exposed to UV	No breakage	No breakage	Satisfactory	

ВАРНО С ОПИТНАТА





**TEST DESCRIPTION :** 2.8 Electric ageing test

**DATE :** FROM 02/02/2006 TO 03/03/2006  
**PLACE :** MICHAUD test laboratory  
**OPERATORS :** AC. BERNARD  
 JP. ROPY

**N° OF SAMPLES :** 11 up to 16 for sleeves MJPT 95 (173), MJPT 150 and MJPT 70N


**TEST EQUIPMENTS**

- Measure equipment for traction / compression
- N° 1, 2 and 4 electric ageing benches
- Measure stations NI1, NI2 and SA 70 NI

**PROCEDURES**

Procedures and acceptance criteria are the ones of § 2.8 of standard NF C 33-021 dated June 1998 which refers to standard NF C 33-004 dated June 1998.

The test loop carried out according to standard NF C 33-004 is the loop "A" in "U" form :



**LEGEND**

Sleeve
  Voltage measure point

Core :
 95mm<sup>2</sup> Al for the sleeve MJPT 95 (173)  
150mm<sup>2</sup> Al for the sleeve MJPT 150  
70mm<sup>2</sup> Al alloy for the sleeve MJPT 70N

**1. Preparation of the loop**

- Parameters of the loop are calculated :

TYPE OF SLEEVES	$\lambda$	L
MJPT 95 (173)	200mm	400mm
MJPT 150	250mm	500mm
MJPT 70N	200mm	400mm

- Voltage measure points are performed by means of equalizers (welding method : «TIG», metal filler : 1 050A aluminium). They are placed as shown on the previous schema.

ВЪРНО С ОПРИГНАЛА



504

TEST DESCRIPTION : 2.8 Electric ageing test

Page 2/17

- Conductors that come out of the sleeves, as well as the reference conductor, are equipped with terminal lugs.
- The reference core is stripped.


**2. Assembly of the loop**

- Samples are fitted on cores stripped over the length indicated on the sleeve. They are crimped with a pneumatic jack and adapted dies.
- So as to assure a good crimping of the preinsulated sleeves, we check that a 0,05 mm thick wedge does not go in.
- Conductors equipped with terminal lugs are linked between each other, to the electric ageing bench by means of bolts.
- Voltage measure points are installed.
- Temperature measure points are installed as follows :

	TYPE OF THERMOCOUPLE	PLACE OF FIXING	TYPE OF HOLD
Sleeve	- type «k», «sheathed» in a tube of inconel. - diameter 1 mm.	- at the middle of the sleeve, in a 1,2mm diameter hole.	- covered with «thermoconductor» grease - holding with a mastic type «polyurethane»
Reference core	- type «k», - diameter 0,5 mm.	- at the «middle» of the reference conductor core.	- holding through a splice (copper wire diameter 0,4mm) - covered with «thermoconductor» grease
Room temperature	- type «k», «sheathed» in a tube of inconel, - diameter 1 mm.	- at the middle of the loop in the horizontal level containing the sleeves.	/

**3. Process of a cycle**

		TYPE OF SLEEVES		
		MJPT 95 (173)	MJPT 150	MJPT 70N
Heating at 120°C of the reference core	Duration	5 min	5 min	4 min
	Intensity	~ 500A	~ 700A	~ 415A
Step at 120°C of the reference core	Duration	50 min	55 min	50 min
	Intensity	~ 355A	~ 490A	~ 275A
Temperature measure every 10 cycle				
Cooling	Duration	30min	35min	35min
Resistance measure every 10 cycle				
Total duration of a cycle	Duration	85min	95min	89min



*Handwritten signature*

*Handwritten mark*

**4. Performing of the test - Measures**

- Resistance measure is performed under a direct current of 25A for sleeve MJPT 70N, 30A for sleeve MJPT 95 (173) and 40A for sleeve MJPT 150, every 10 cycle.
- Rj resistance values of each sleeve are calculated according to § 5.3.3.4 of standard NF C 33-004 dated June 1998.
- The test is performed as follows :
  - \* 50 cycles of electrical ageing,
  - \* application of 4 overloads during 1 s with an intensity of 6 650A for sleeve MJPT 70N, 9 500A for sleeve MJPT 95 and 15 000A for sleeve MJPT 150,
  - \* 150 cycles of electrical ageing.

ВАРНО С ОПРИГНАЛАТА



*miss*

*597*

MICHAUD SA  
TEST LABORATORY

TEST REPORT  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03

Date : 16/06/06  
Page : 22/39

TEST DESCRIPTION : 2.8 Electric ageing test

Page 4/17


TEST RESULTS

Sleeve MJPT 95 (173)

TEMPERATURE RECORD  
(in °C)

Cycles	Reference core	Sleeves						Room temperature
		11	12	13	14	15	16	
1	120,9	82,8	82,4	84,1	80,0	79,7	83,6	23,1
10	119,5	81,7	81,0	85,3	80,6	81,2	84,8	24,5
20	119,3	82,2	81,3	84,2	81,9	80,9	84,9	25,1
30	118,7	83,6	81,9	85,0	83,5	81,1	86,4	25,3
40	119,6	82,4	81,1	84,0	82,0	81,0	84,6	23,9
50	119,7	83,0	81,6	84,0	82,4	81,4	84,9	24,3
60	119,8	85,2	84,1	86,7	85,8	84,7	87,3	24,1
70	121,3	85,5	84,3	87,3	85,3	84,6	87,4	23,9
80	120,0	86,8	85,7	88,5	86,4	86,0	88,5	24,1
90	119,5	86,3	85,5	87,4	86,1	84,6	88,3	24,2
100	120,5	87,1	86,2	88,3	86,5	86,2	88,1	24,1
110	120,3	86,2	85,3	87,0	85,9	85,5	87,7	24,4
120	118,5	85,3	85,7	87,7	86,4	85,1	88,4	25,0
130	119,8	86,2	85,7	85,4	86,1	85,1	85,9	24,8
140	120,6	86,9	86,3	85,8	87,0	85,4	86,3	24,7
150	120,8	86,8	85,8	86,0	87,0	85,9	86,9	24,8
160	120,3	86,5	85,9	85,5	86,9	85,5	86,0	25,1
170	120,3	86,0	85,4	85,4	86,6	85,5	86,2	24,9
180	121,1	86,7	86,6	85,6	87,0	86,7	86,0	24,7
190	120,3	86,2	86,4	85,3	87,1	86,0	86,3	25,3
200	120,7	86,8	86,2	85,9	87,0	86,3	86,6	25,0

ВЯРНО С ОПРИМКАТА



177

*[Handwritten signature]*


MICHAUD SA  
TEST LABORATORY

TEST REPORT  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03


Date : 16/06/06  
Page : 23/39

TEST DESCRIPTION : 2.8 Electric ageing test

Page 5/17



ВЪРХНО С ОПИТИНАТА



*[Handwritten scribble]*

593

TEST DESCRIPTION : 2.8 Electric ageing test

Page 6/17

*Sleeve MJPT 150*

TEMPERATURE RECORD  
(in °C)

Cycles	Reference core	Sleeves						Room temperature
		11	12	13	14	15	16	
1	119,5	82,5	83,3	84,4	85,1	83,1	82,4	24,1
10	120,1	81,2	81,8	84,8	84,6	82,4	81,0	24,6
20	121,2	80,3	82,0	83,6	84,0	82,3	80,9	24,8
30	120,3	81,6	81,9	83,5	84,0	81,7	80,4	25,0
40	119,7	80,2	82,3	83,5	84,1	82,0	81,0	25,2
50	119,1	81,8	82,3	84,0	84,4	82,5	81,3	25,0
60	121,8	83,3	85,1	84,6	86,3	84,0	82,9	25,7
70	118,8	84,0	84,6	86,3	87,0	84,9	83,5	25,6
80	120,6	83,8	84,8	86,1	86,8	85,4	83,9	25,0
90	121,5	84,7	85,7	86,4	87,5	86,1	83,9	25,3
100	120,5	84,5	85,1	85,7	88,0	85,1	83,6	25,2
110	121,2	86,1	85,9	86,8	88,6	86,7	84,0	25,4
120	120,6	83,4	84,6	84,5	87,1	83,8	83,6	24,7
130	120,8	84,0	84,5	85,0	86,7	84,8	83,3	25,5
140	120,3	83,9	85,8	85,8	87,3	85,3	84,3	25,8
150	119,1	83,5	84,9	85,1	86,9	86,2	84,2	25,5
160	119,6	83,8	85,7	85,1	86,9	84,9	84,1	25,9
170	120,3	83,7	84,8	84,1	86,5	86,0	84,3	25,4
180	121,0	84,4	85,0	86,2	86,9	85,6	83,3	25,6
190	120,8	84,5	84,5	87,4	86,4	84,5	82,2	25,3
200	119,0	83,8	83,7	85,6	85,5	86,1	81,8	25,4

ВЪРНО С ОПИТАНАТА



174

*[Handwritten signature]*



MICHAUD SA  
TEST LABORATORY

TEST REPORT  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03


Date : 16/06/06  
Page : 25/39

TEST DESCRIPTION : 2.8 Electric ageing test

Page 7/17



ВАРНО С ОПИТНАТА



316

<b>TEST DESCRIPTION : 2.8</b> Electric ageing test	Page 8/17
--	-----------

## Sleeve MJPT 70N

### TEMPERATURE RECORD

(in °C)



Cycles	Reference core	Sleeves						Room temperature
		11	12	13	14	15	16	
1	119,3	82,8	80,9	80,6	84,0	82,7	81,6	24,1
10	121,6	83,1	82,6	80,3	83,8	84,0	81,7	23,6
20	120,6	84,4	84,0	81,2	85,2	84,3	83,1	23,0
30	120,7	82,8	82,1	79,5	83,7	83,4	81,1	22,4
40	121,6	83,9	83,4	80,4	84,1	84,1	82,6	23,0
50	121,2	83,8	82,9	80,9	84,4	84,4	82,5	23,1
60	121,0	84,7	84,5	81,6	84,8	85,0	81,8	23,5
70	121,1	86,9	86,0	83,5	87,2	86,8	85,0	24,5
80	121,3	86,7	85,8	82,7	86,3	85,9	85,3	23,9
90	121,5	84,0	85,5	82,5	86,1	85,5	83,0	26,2
100	121,2	86,8	85,9	83,1	86,1	86,4	85,5	25,0
110	120,4	84,5	85,1	82,3	86,0	86,5	82,8	24,3
120	120,7	84,8	85,3	82,7	86,3	86,2	83,1	22,9
130	121,3	85,7	85,5	82,6	86,1	86,8	83,9	22,9
140	121,0	83,5	83,7	80,8	84,2	84,2	81,2	21,7
150	121,7	84,1	85,7	82,3	86,0	85,6	82,6	23,8
160	120,4	84,7	84,8	82,1	85,5	86,2	82,6	22,5
170	120,4	84,2	85,1	82,1	87,0	86,1	82,6	22,0
180	120,5	83,9	84,4	82,1	86,2	85,0	83,1	21,9
190	120,2	85,6	85,1	82,6	85,7	84,6	83,7	24,5
200	121,0	85,0	84,3	81,5	85,3	84,6	83,6	24,1

ВЪРНО С ОПРИГНАЛАТА




576





ВЪРНО С ОРМИНАЛА



597

MICHAUD SA  
TEST LABORATORY

TEST REPORT  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K105, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03

Date : 16/06/06  
Page : 28/39

TEST DESCRIPTION : 2.8 Electric ageing test


Page 10/17

### Sleeve MJPT 95 (173)

#### Rj RESISTANCE RECORD (in $\mu\Omega$ )

Cycles	Sleeves					
	11	12	13	14	15	16
0	84,1	90,3	87,2	89,5	83,6	86,4
10	92,9	100,6	99,0	97,4	91,6	100,3
20	95,8	104,0	102,7	100,3	94,3	104,2
30	97,6	107,6	104,8	102,6	96,9	107,1
40	99,1	109,4	106,7	104,2	98,1	109,6
50 before overloads	100,6	110,8	108,9	105,9	99,6	111,3
50 after overloads	104,9	114,5	113,3	111,5	104,3	115,2
60	105,6	115,8	115,0	113,0	105,1	117,5
70	106,2	117,0	116,4	114,6	105,8	119,0
80	106,7	118,2	117,1	115,8	106,8	120,6
90	107,7	118,6	118,3	116,5	107,3	121,2
100	108,2	118,9	118,7	117,4	107,8	121,6
110	108,5	119,1	119,3	118,0	108,1	122,0
120	109,0	119,5	119,6	118,5	108,4	122,6
130	109,6	120,0	119,9	118,9	108,7	123,1
140	110,1	120,3	120,1	119,3	108,9	123,5
150	110,3	120,7	120,4	119,6	108,9	123,9
160	110,6	121,2	120,7	119,8	109,2	124,2
170	110,9	121,8	120,9	120,2	109,4	124,4
180	111,3	122,4	121,1	120,5	109,5	124,4
190	111,3	122,7	121,3	120,6	109,5	124,5
200	111,5	122,8	121,4	120,8	109,6	124,5

ВЕРНО С ОПРИМАНАТА



*[Handwritten signature]*


MICHAUD SA  
TEST LABORATORY

TEST REPORT  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K108, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03

Date : 16/06/06  
Page : 29/39

TEST DESCRIPTION : 2.8 Electric ageing test

Page 11/17



ВЪРНО С ОПРИГНАЛА




*[Handwritten signature]*

*Sleeve MJPT 150*

**Rj RESISTANCE RECORD**  
(in  $\mu\Omega$ )

Cycles	Sleeves					
	11	12	13	14	15	16
0	51,3	46,8	43,6	45,1	52,6	41,4
10	59,7	53,6	50,7	51,0	60,1	47,3
20	62,3	56,4	54,1	53,4	63,2	49,9
30	64,1	58,0	56,4	55,6	65,0	51,5
40	65,4	59,3	58,6	57,0	66,4	53,2
50 before overloads	66,2	61,0	59,8	58,3	67,6	54,5
50 after overloads	68,5	62,7	62,4	60,5	69,6	56,4
60	69,6	63,6	63,3	61,4	70,7	57,3
70	70,3	64,0	64,4	62,3	71,9	58,2
80	70,9	64,3	64,9	63,2	72,6	58,7
90	71,5	64,9	65,6	63,9	73,4	59,1
100	72,0	65,4	66,0	64,6	74,1	59,6
110	72,3	65,7	66,6	65,0	74,6	59,8
120	72,8	66,0	67,1	65,5	75,2	60,2
130	73,2	66,2	67,5	65,8	75,7	60,6
140	73,5	66,5	67,9	66,2	76,0	61,0
150	73,7	66,7	68,4	66,5	76,4	61,2
160	73,9	66,9	68,6	66,8	76,7	61,5
170	74,3	67,2	68,9	67,0	76,9	61,9
180	74,5	67,5	69,2	67,3	77,2	62,1
190	74,6	67,6	69,3	67,5	77,3	62,3
200	74,6	67,6	69,6	67,4	77,4	62,3

ВАРПНО С ОПИТИВАЊАТА



*[Handwritten signature]*

MICHAUD SA  
TEST LABORATORY


TEST REPORT  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03

Date : 16/06/06  
Page : 31/39

TEST DESCRIPTION : 2.8 Electric ageing test

Page 13/17

- ◆ Sleeve 11
- Sleeve 12
- Sleeve 13
- Sleeve 14
- \* Sleeve 15
- Sleeve 16



ВЯРНО С ОРГАНИЗАТА



*[Handwritten signature]*

TEST DESCRIPTION : 2.8 Electric ageing test Page 14/17

## Sleeve MJPT 70N

### Rj RESISTANCE RECORD (in $\mu\Omega$ )

Cycles	Sleeves					
	11	12	13	14	15	16
0	44,0	46,1	40,9	41,4	44,9	46,7
10	53,5	54,2	45,8	47,4	54,3	55,2
20	56,4	57,4	48,1	50,1	57,5	58,5
30	58,3	59,9	50,6	51,8	59,6	60,4
40	59,9	61,6	52,3	53,2	61,3	62,4
50 before overloads	61,2	63,2	53,9	54,8	62,8	64,3
50 after overloads	64,6	65,3	56,4	58,0	65,1	67,0
60	65,7	66,9	57,2	58,9	66,2	68,2
70	66,5	67,5	58,4	60,1	67,3	68,9
80	67,4	68,0	58,9	60,5	68,0	69,3
90	68,1	68,8	59,6	61,3	68,9	69,7
100	68,7	69,5	60,5	61,9	69,6	70,1
110	69,3	70,1	61,1	62,4	70,3	70,4
120	69,8	70,7	61,7	62,7	71,0	70,8
130	70,2	71,1	62,2	62,9	71,7	71,2
140	70,5	71,4	62,6	63,2	72,2	71,3
150	70,9	71,6	62,9	63,6	72,5	71,7
160	71,2	71,9	63,3	63,8	72,7	71,9
170	71,5	72,1	63,5	64,0	72,9	72,2
180	71,6	72,2	63,6	64,2	73,2	72,3
190	71,8	72,1	63,7	64,5	73,5	72,3
200	71,9	72,3	63,7	64,6	73,5	72,5



ВЪРНО С ОРИГИНАЛАТА

"BAK - 02" ПОД  
 САМОКОВ

TEST DESCRIPTION : 2.8 Electric ageing test

Page 15/17

- ◆ Sleeve 11
- Sleeve 12
- Sleeve 13
- Sleeve 14
- \* Sleeve 15
- Sleeve 16



TEST DESCRIPTION : 2.8 Electric ageing test

Page 16/17


The results are the ones of § 5.4 of standard NF C 33-004 which defines the following acceptance criteria :

- ◇ Relative initial scatter of resistances :  $\delta \leq 0,30$
- ◇ Stability of resistances  $R_j$  (on the 11<sup>th</sup> last measures) :  $\frac{\Delta R_j}{R_j} \leq 12\%$
- ◇ Stability of temperatures  $\theta_j$  (on the 11<sup>th</sup> last measures) :  
 $d_j - 10 \leq d_j \leq d_j + 10$  with : \*  $d_j = \theta_R - \theta_j$   
 \*  $\theta_R$  : temperature of the warmest reference core  
 $\theta_j \leq \text{Max } \theta_R$   
 Equivalent to check :  $\text{Min } d_j \geq 0$

1) Temperature

TYPE OF SLEEVES	SAMPLE N°	TEMPERATURE STABILITY (IN K)			
		$\bar{d}_j - 10$	Min $d_j$	Max $d_j$	$\bar{d}_j + 10$
MJPT 95 (173)	11	23,9	33,2	34,4	43,9
	12	24,3	32,8	35,0	44,3
	13	24,1	30,8	35,5	44,1
	14	23,6	32,1	34,4	43,6
	15	24,5	33,4	35,2	44,5
	16	23,5	30,1	35,1	43,5
MJPT 150	11	26,1	35,1	37,2	46,1
	12	25,3	33,9	36,3	45,3
	13	24,7	33,4	36,2	44,7
	14	23,3	32,2	34,4	43,3
	15	24,9	32,9	36,8	44,9
	16	26,8	34,9	38,6	46,8
MJPT 70N	11	26,0	34,4	37,6	46,0
	12	25,8	35,1	37,3	45,8
	13	28,6	37,6	40,2	48,6
	14	24,9	33,4	36,8	44,9
	15	25,1	33,9	36,8	45,1
	16	27,6	35,7	39,8	47,6

ВЯРНО С ОРМОНАТА






TEST DESCRIPTION : 2.8 Electric ageing test

Page 17/17

2) Resistance

TYPE OF SLEEVES	SAMPLE N°	INITIAL SCATTER $\delta$	RESISTANCE STABILITY (in %)	$\frac{\Delta R_j}{R_j}$
MJPT 95 (173)	11	0,052	3,0	
	12		3,2	
	13		2,2	
	14		2,8	
	15		1,7	
	16		2,3	
MJPT 150	11	0,155	3,5	
	12		3,3	
	13		5,3	
	14		4,4	
	15		4,3	
	16		4,4	
MJPT 70N	11	0,090	4,5	
	12		3,9	
	13		5,1	
	14		4,3	
	15		5,4	
	16		3,4	

ВАРНО С ОПРАТНАТА



<b>MICHAUD SA</b> TEST LABORATORY	<b>TEST REPORT</b> QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115, K116, K170 AND K175) N° 130-06-02-03	Date : 16/06/06 Page : 36/39
--------------------------------------	---	---------------------------------

**TEST DESCRIPTION :** 2.9 Endurance test under mechanical and thermal stresses Page 1/4

**DATE :** FROM 27/02/2006 TO 13/06/2006  
**PLACE :** MICHAUD test laboratory **OPERATORS :** AC. BERNARD  
JP. ROPY

**N° OF SAMPLES :** 17 up to 20 for sleeves MJPT 95 (173), MJPT 150 and MJPT 70N

**TEST EQUIPMENTS**

- Measure equipment for traction / compression
- Mechanical tensile strength and endurance bench
- Measure station SA 32


PROCEDURES

Procedures and acceptance criteria are the ones of § 2.9 of standard NF C 33-021 dated June 1998.

**A) Sleeves MJPT 95 (173) et MJPT 150**

**1. Assembly**

The four sleeves are fitted on a core according to the principle scheme hereafter :



The free length between each sleeve and between the end sleeves and the anchoring equipment is of 1m.

Thermocouples are installed in the middle of both sleeves placed at both extremities of the assembly, as well as in the middle of a 1 m long stripped reference core placed outside anchoring equipment.

**2. Installation period**

A tensile strength of 4 050N for sleeve MJPT 95 (173) and 6 300N for sleeve MJPT 150 is applied in 1min on the core. This strength is regulated during 10min, temperature of the conductors core being regulated at the room temperature.



Then, while regulating the cores conductor at the room temperature, we leave the assembly stabilizing during 24 h.

**3. Cycles application**

After the previous stabilization period, 500 cycles of 90 min are applied on the assembly as follows :

- **Heating :**
  - for 45 min : Temperature of the conductors core maintained at  $(90 \pm 3)^\circ\text{C}$ ,
  - for 45 min : Natural cooling of the conductors core down to  $(25 \pm 3)^\circ\text{C}$  and stabilization at this temperature.
- **Mechanical strength :**  
 It is adjusted at 2 230N for sleeve MJPT 95 (173) and 3 500N for sleeve MJPT 150 at the end of the first cycle then once per 24 h at the end of a cycle.

Temperature of the sleeves is measured every 25 cycles at the end of the heating period at  $90^\circ\text{C}$ .



TEST DESCRIPTION : 2.9 Endurance test under mechanical and thermal stresses

Page 2/4

4. Acceptance criteria

a) Temperature of the sleeves n° 17 and 20, at the end of the heating periods, must be under the temperature of the reference core.

b) Sleeves n° 18 and 19 must be tested accordingly :

➤ Dielectric strength test in the balls

The assembly, placed horizontally, is covered with lead balls over 1 up to 2cm. After at least 1 min, a dielectric test is performed on the assembly at a 6kV voltage at an industrial frequency for 1min, at a 1kV/s speed  
No breakage shall occur.

➤ Dielectric strength test in water


A dielectric strength is then performed on the assembly under a 1kV voltage according to § 2.4 of this report.  
No breakage shall occur.

c) The four sleeves must be tested according to the mechanical test (§ 2.3.2 of this report).

B) Sleeve MJPT 70N

1. Assembly

The four sleeves are fitted on a core according to the principle scheme hereafter :



The free length between each sleeve and between the end sleeves and the anchoring equipment is of 1m.

Thermocouples are installed in the middle of both sleeves placed at both extremities of the assembly, as well as in the middle of a 1 m long stripped reference core placed outside anchoring equipment.

2. Cycles application

500 cycles of 90 min are applied on the assembly as follows :

-- Heating :



- for 45 min : Temperature of the conductors core maintained at  $(90 \pm 3)^\circ\text{C}$ ,
- for 45 min : Natural cooling of the conductors core down to  $(25 \pm 3)^\circ\text{C}$  and stabilization at this temperature.

-- Mechanical strength :

- for 75 min : a F1 tensile strength of 4 500N is applied on the assembly,
- for 15 min : the tensile strength is adjusted at F2 equal to 10 000N.

F2 strength application shall be progressive and performed in 5 up to 60 s.

Temperature of the sleeves is measured every 25 cycles at the end of the heating period at  $90^\circ\text{C}$ .



527

TEST DESCRIPTION : 2.9 Endurance test under mechanical and thermal stresses

Page 3/4

3. Acceptance criteria


- a) Temperature of the sleeves n° 17 and 20, at the end of the heating periods, must be under the temperature of the reference core.
- b) Sleeves n° 18 and 19 must be tested accordingly :
- > Dielectric strength test in the balls  
The assembly, placed horizontally, is covered with lead balls over 1 up to 2cm. After at least 1 min, a dielectric test is performed on the assembly at a 6kV voltage at an industrial frequency for 1min, at a 1kV/s speed. No breakage shall occur.
  - > Dielectric strength test in water  
A dielectric strength is then performed on the assembly under a 1kV voltage according to § 2.4 of this report. No breakage shall occur.
- c) The four sleeves must be tested according to the mechanical test (§ 2.3.2 of this report).

TEST RESULTS

a) Temperature of sleeves n° 17 et 20

CYCLES	TYPE OF SLEEVES								
	MJPT 95 (173)			MJPT 150			MJPT 70N		
	REFERENCE CORE	17	20	REFERENCE CORE	17	20	REFERENCE CORE	17	20
1	90,6	66,1	68,4	89,7	68,8	67,3	88,6	64,3	62,9
25	88,7	65,9	68,9	90,4	68,2	68,4	89,4	64,8	62,6
50	89,5	64,7	67,6	90,6	67,6	68,4	91,2	63,6	63,1
75	90,3	66,2	68,0	91,3	67,9	68,1	90,3	64,1	62,5
100	91,5	65,1	68,2	89,8	68,4	67,6	91,5	64,7	62,2
125	89,9	66,4	68,8	89,6	67,5	67,8	89,6	64,2	62,8
150	90,4	66,8	67,9	90,5	68,3	68,0	90,2	63,9	63,4
175	90,8	65,9	68,1	88,9	68,0	67,6	88,7	63,5	62,5
200	91,6	66,3	68,5	91,2	68,5	67,5	89,8	64,4	62,7
225	89,5	65,4	68,3	90,2	68,6	68,2	90,0	63,8	63,3
250	90,2	66,2	67,7	89,1	67,3	68,3	91,3	64,1	62,6
275	91,4	66,0	68,4	90,4	68,9	67,4	89,9	63,7	63,5
300	90,7	66,6	68,2	89,6	68,1	68,7	90,6	63,6	62,7
325	90,3	65,3	67,3	88,8	67,5	69,3	91,5	64,3	63,1
350	90,5	65,7	68,0	90,7	68,6	67,8	89,6	64,2	63,6
375	89,9	65,8	68,6	91,2	68,3	68,4	90,4	63,9	62,8

ВЯРНО С ОРИГИНАЛА



58

MICHAUD SA  
TEST LABORATORY

**TEST REPORT**  
QUALIFICATION TESTS OF MJPT SLEEVES (K101, K103, K106, K110, K121, K123, K115,  
K116, K170 AND K175) N° 130-06-02-03

Date : 16/06/06  
Page : 39/39

TEST DESCRIPTION : 2.9 Endurance test under mechanical and thermal stresses

Page 4/4


CYCLES	TYPE OF SLEEVES								
	MJPT 95 (173)			MJPT 150			MJPT 70N		
	REFERENCE CORE	17	20	REFERENCE CORE	17	20	REFERENCE CORE	17	20
400	90,4	66,3	68,8	91,1	68,6	67,1	88,5	64,4	63,0
425	91,5	65,9	68,6	89,8	68,3	67,6	89,6	64,6	62,9
450	89,7	66,0	67,4	90,4	67,5	68,3	90,1	64,3	63,3
475	90,3	66,4	68,5	90,7	68,1	68,1	91,2	64,2	62,8
500	90,6	65,8	68,3	89,2	68,7	67,9	90,5	63,9	62,6

Temperature of each sleeve is always under the reference core temperature.

b) Dielectric test of sleeves n° 18 and 19

TYPE OF SLEEVES	SAMPLE N°	COMMENTS AFTER 1min UNDER 6kV IN THE BALLS	COMMENTS AFTER 1min A 1kV IN WATER	FOLLOWING TEST
MJPT 95 (173)	18	Satisfactory	Satisfactory	2.3.2
	19	Satisfactory	Satisfactory	
MJPT 150	18	Satisfactory	Satisfactory	2.3.2
	19	Satisfactory	Satisfactory	
MJPT 70N	18	Satisfactory	Satisfactory	2.3.2
	19	Satisfactory	Satisfactory	

ВЪРНО С ОПИТИНАТА




529

СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ ЗА МАНШОН МЈРТ - К 117, К 116,  
К 115

1. № на тест: 130-06-02-03

- 2.3.1 Механични тестове – Изпитване на способността за пресоване.....5;  
2.3.2 Механични тестове – Изпитване на сила на якост.....6;  
2.4 Диелектричен и водоустойчив тест.....9;  
2.5 Тест за монтаж при ниска температура.....12;  
2.6 Тест за стреење под въздействието на климатичните условия.....14;  
2.8. Тест за стареење под действието на електричеството.....19;  
2.9 Тест за издръжливост под механичен и топлинен натиск.....36.

Съставил:





1 Equipment used during test.

1.1 Equipment used

N° U.T.	Designation	Characteristic
99 01 48	Indicator thermometer	Accuracy 2°C
93 05 48	Clamping machine	Strength 50 kN
93 02 04	Water tank	/
97 02 02	Calibrated ruler	Accuracy 0,5mm
	Claws L173	Width 9 mm


1.2 Cables

Section (mm <sup>2</sup> )	16
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08006
Conditioned on	03/02/2010 (1 h at 120°C)

2 Product tested

Designation : CP1A16  
 Quantity : 2  
 Batch number : 09M93760  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Received at the laboratory on the : 03/02/2010

На основание чл. 2  
от ЗЗЛД





### 3 Test procedure


Connectors are tested according to NFC 33 021 § 2.4.3 and § 2.4.4 (June 98) standard.

#### 3.1 Procedure

The assembly made by the lug and the conductor is placed at the bottom of a tank filled with water. The height of water is  $(30 \pm 10)$  cm measured above the lug.

The core crosses out of the tank through an appropriate seal which avoids any excessive stress on the core in tension according to figure below.

The assembly is left in the water for 24 h.



dimensions in cm

#### 3.2 Preparation

A E173 groove with 9 mm wide dies is used.

### 4 Requirements

No trace of water shall be observed at the end of the core.

### 5 Results

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 and 35°C	21°C
	Between 25 and 75% HR	26 % HR
Duration of immersion	24 h 00	24 h 00
Immersion depth	30 $\pm$ 10 cm	33 cm

### 6 Conclusion

No trace of water observed at the end of the core after the 24h.

На основание чл. 2  
от ЗЗЛД

ВРЪНО С ОПИТИНАТА



САМОКОВ

533

*[Handwritten scribble]*

*[Handwritten signature]*

Test report number 10 02 300  
Annex 1





SICAME LABORATORY

ВЯРНО С ОРИГИНАЛА



*[Handwritten scribble]*



С.С.С.С.

С.С.

Test report : Tensile test  
Test number : T0 02 191  
Product brand : SICAME  
Product type : CPTA 16

Demandeur of the test : SICAME DER  
Starting date of the test : 09/02/2010  
Report emission date : 12 FEB, 2010  
According to standard : NF C 33-021 § 2.3.2 (June 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 16 conform to the requirements of NF C 33-021 § 2.3.2 (June 98) standard.

( )

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



ВЯРНО С ОПИТОВАТА



135

**1. Equipment used during test.**

**1.1 Equipment used**

N° U.T.	Designation	Characteristic
09 01 48	Thermometer indicated	Accuracy 2°C
03 05 48	Crimping machine	50 kN
04 03 10	Traction bench 3 tons	Class 1
	Dies F173	Width 9 mm

**1.2 Cables :**

Section (mm <sup>2</sup> )	16
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08006
Conditioned on	03/02/2010 (1 h at 120°C)

**2. Product tested.**

Désignation : CPTA 16  
 Number : 2  
 Batch number : 09M193760  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



### 3. Test.

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.2 (june 98) standard.

#### 3.1 Test procedure.

Connection is carried out using 5 mm wide dies for groove E 140 and 9 mm wide dies for grooves E 173 and E 215. The minimum strength to be applied is given in the standard. The length of the cores used complies with the length indicated in the standard.

The assembly is submitted to a tensile strength applied to the conductor. The strength is increased at a rate between 1000 N/min and 5000 N/min up to:

- for phases: 50% of the minimum load indicated in standard. This strength is applied for 1 min.
- for neutral messenger: 65% of the minimum load indicated in standard. This strength is applied for 1 hour.

The strength is then increased up to the minimum load indicated in standard, and released.

#### 3.2 Preparation

A 9 mm wide dies for groove E173 is used.


### 4. Results.

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	22°C 28 % HR
Rate of the tensile (N/min)	Between 1000 et 5000	2500
Strength value maintained for 1 min (N)	1300	Sample 1 : ok Sample 2 : ok
Strength value applied without breakdown (N)	2500	Sample 1 : ok Sample 2 : ok

### 5. Requirement

No slippage is observed.

На основание чл. 2  
от ЗЗЛД





*[Handwritten signature]*

*[Handwritten signature]*

Test report number 10 02 190  
Annex 1

00




00

SICAME LABORATORY

*[Handwritten signature]*

ВЪРНО С ОПРИНАТА



528

Test report : Crimping ability test  
Test number : 10 02 081  
Product brand : SICAME  
Product type : CPTA 16


Demandeur of the test : SICAME DER  
Starting date of the test : 10/02/2010  
Report emission date : 12 FEB. 2010  
According to standard : NFC 33-021 § 2.3.1 (June 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 16 conform to the requirements of NFC 33-021 § 2.3.1 (June 98) standard

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

ВЪРНО С ОПРИГНАЛАТА



539

**1. Equipment used during test.****1.1 Equipment used**

N° U.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
02 01 35	50 µm thick gauge	Accuracy ± 1.5 µm
	Dies 1:175	Width 9 mm

**1.2 Cables :**

Section (mm <sup>2</sup> )	16
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08006
Conditioned on	03/02/2010 (1 h at 120°C)

**2. Product tested.**

Désignation : CPTA 16  
 Number : 2  
 Batch number : 09M93760  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА





### 3. Test.

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.1 (June 98) standard.

#### 3.1 Test procedure.

Crimping of the joint sleeve or terminal lug on the relevant core(s) shall be carried out using dies in compliance with table B.1 of annex B of the standard. The minimum compression strength given in table B.2 of annex B of the standard shall be applied.

#### 3.3 Preparation

A 9 mm wide dies for groove 173 is used.

### 4. Requirements

The two half-dies shall be in contact, which means that a 0.05 mm thick gauge cannot be inserted between the half-dies.


### 5. Results.

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C	21°C
	Between 25 % et 75 % HR	25 % HR
A 0,05 mm thick gauge is inserted between the half-dies	No	Sample 1 : no Sample 2 : no

### 6. Conclusion

The two half-dies are in contact, which means that a 0.05 mm thick gauge cannot be inserted between the half-dies.

На основание чл. 2  
от ЗЗЛД




*[Handwritten scribble]*

*[Handwritten scribble]*

Test report number 10 02 080  
Appendix I

*[Handwritten scribble]*



*[Handwritten scribble]*

SICAME LABORATORY

*[Handwritten signature]*

ВЯРНО С ОРИГИНАЛАТА




**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
НАКРАЙНИК ТИП СРГА 16**

1. № на тест: 1002301 - Тест за водонепромокаемост;
2. № на тест: 1002191 – Тест за якост на опън;
3. № на тест: 1002081 - Изпитване на способността за пресоване;

Съставил:

На основание чл. 2  
от ЗЗЛД




Test report : Crimping ability test  
Test number : 10 02 082  
Product brand : SICAME  
Product type : CPTA 25

Demandeur of the test : SICAME DLR  
Starting date of the test : 10 02 2010  
Report emission date : 12 FEB. 2010  
According to standard : NF C 33-021 § 2.3.1 (June 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 25 conform to the requirements of NF C 33-021 § 2.3.1 (June 98) standard.

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



1. Equipment used during test.

1.1 Equipment used

N° I.C.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Cramping machine	50 kN
02 01 35	50 µm thick gauge	Accuracy ± 1.5 µm
	Dies n°175	Width 9 mm



1.2 Cables :

Section (mm <sup>2</sup> )	35
Nature	Aluminium
Standard	NF C 53-209
From	France
Identification n°	08006
Conditioned on	03/02/2010 (1 h at 120°C)

2. Product tested.

Désignation : CPTA 25  
 Number : 2  
 Batch number : 09M493760  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date in the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД



*Handwritten signature*

*Handwritten signature*

### 3. Test.

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.1 (june 98) standard.

#### 3.1 Test procedure.

Crimping of the joint sleeve or terminal lug on the relevant core(s) shall be carried out using dies in compliance with table B 1 of annex B of the standard. The minimum compression strength given in table 9 2 of annex B of the standard shall be applied.

#### 3.3 Preparation

A 9 mm diameter for groove E173 is used.

### 4. Requirements

The two half-dies shall be in contact, which means that a 0.05 mm thick gauge cannot be inserted between the half-dies.

### 5. Results

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	21°C 25 % HR
A 0,05 mm. thick gauge is inserted between the half-dies	No	Sample 1 : no Sample 2 : no

### 6. Conclusion

The two half-dies are in contact, which means that a 0.05 mm thick gauge cannot be inserted between the half-dies.

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРНИМАТА

“BAK-02” ООД  
САМОКОВ

5/41

50

Test report : Tensile test  
 Test number : 10 02 192  
 Product brand : SICAME  
 Product type : CPTA 35

Demander of the test : SICAME DER  
 Starting date of the test : 09 02 2010  
 Report emission date : 12 FEB, 2010  
 According to standard : NF C 33-021 § 2.3.2 (June 98)  
 This report contains : 5 pages and 1 annex  
 Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 35 conform to the requirements of NF C 33-021 § 2.3.2 (June 98) standard.

50

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

ВАРНО С ОПРИЗНАТА

"BAK - 02" OOD  
 САМОКОВ

547

**1. Equipment used during test.**

**1.1 Equipment used**

N° U.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
94 03 10	Traction bench 3 tons	Class 1
	Dies F173	Width 9 mm

**1.2 Cables :**

Section (mm <sup>2</sup> )	25
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08006
Conditioned on	03/02/2010 (1 h at 120°C)

**2. Product tested.**

Désignation : CPFA 25  
 Number : 2  
 Batch number : 09M93760  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛАТА





3. Test.

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.2 (june 98) standard.

3.1 Test procedure.

Connection is carried out using 5 mm wide dies for groove E 140 and 9 mm wide dies for grooves E 173 and E 215. The minimum strength to be applied is given in the standard. The length of the cores used complies with the length indicated in the standard.

The assembly is submitted to a tensile strength applied to the conductor. The strength is increased at a rate between 1000 N/min and 5000 N/min up to:

- for phases: 50% of the minimum load indicated in standard. This strength is applied for 1 min.
- for neutral messenger: 65% of the minimum load indicated in standard. This strength is applied for 1 hour.

The strength is then increased up to the minimum load indicated in standard, and released.

3.2 Preparation

A 9 mm wide dies for groove E173 is used.


4. Results.

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	22°C 28 % HR
Rate of the tensile (N/min)	Between 1000 et 5000	2500
Strength value maintained for 1 min (N)	1500	Sample 1 : ok Sample 2 : ok
Strength value applied without breakdown (N)	2500	Sample 1 : ok Sample 2 : ok

5. Requirement

No slippage is observed.

На основание чл. 2  
от ЗЗЛД



549

Test report : Water tightness Test  
Test number : 10 02 302  
Product brand : SICAME  
Product type : CPTA 25



Demandeur of the test : SICAME DER  
Starting date of the test : 04/02 2010  
Report emission date : 12 FEB. 2010  
According to standard : NFC 33 021 § 2.4.3 and § 2.4.4 (June 98)  
This report contains : 3 pages and 1 annex

Conclusion : The tested SICAME LA pre-insulated terminal lugs type CPTA 25 conform to the requirements of NFC 33 021 § 2.4.3 and § 2.4.4 (June 98) standard.

This is an English translation. The original French test report is the only reference version

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



1 Equipment used during test

1.1 Equipment used

Nº	Designation	Characteristic
09 01 48	Digital thermometer	Accuracy 2°C
03 05 48	Compression machine	Strength 50 kN
03 02 02	Water tank	
07 02 32	Calibrated ruler	Accuracy 0.5mm Width 9 mm


1.2 Tables

Section (mm)	75
Name	Aluminum
Standard	EN 133-200
From	France
Identification nº	03000
Concentration	03 02 2010

2 Product tested

Designation : CPJA 35  
 Quantity : 3  
 Batch number : 09M93760  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Received in the laboratory on the : 03/02/2010

На основание чл. 2  
от ЗЗЛД



*Handwritten signature*

*Handwritten initials*

3 Test procedure


Conductor is tested according to NFC 33 021 § 2.4.3 and § 2.4.4 (June 98) standard.

3.1 Procedure

The conductor is held by the lug and the conductor is placed at the bottom of a tank filled with water. The height of immersion (30 ± 10) cm measured above the lug.

The core passes out of the tank through an appropriate seal which avoids any excessive stress on the conductor in accordance to figure below.

The conductivity is left in the water for 24 h.



Dimensions in cm

3.2 Preparation

All test pieces with 9 mm wide discs used.

4 Requirements

No leakage of water shall be observed at the end of the core.

5 Results

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 and 35°C	21°C
Duration of immersion	Between 25 and 75% HR	26 % HR
Immersion depth	25 to 60	24 h 00
	30 ± 10 cm	33 cm

6 Conclusion

No leakage of water observed at the end of the core after the 24h.

На основание чл. 2  
от ЗЗЛД



*Handwritten signature*

557

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
НАКРАЙНИК ТИП СРТА 25**

1. № на тест: 1002082 - Изпитване на способността за пресоване;
2. № на тест: 1002192 - Тест за якост на опън;
3. № на тест: 1002302 - Тест за водонепропускливост;


Съставил:

На основание чл. 2  
от ЗЗЛД



*Handwritten signature*

*Handwritten initials JB*



Laboratoire d'essais  
Material Studies and Research



Test report : Tensile test  
Test number : 10 02 190  
Product brand : SICAME  
Product type : CPTA 35

Demandeur of the test : SICAME DER  
Starting date of the test : 09/02/2010  
Report emission date : 12 FEB, 2010  
According to standard : NF C 33-021 § 2.3.2 (June 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 35 conform to the requirements of NF C 33-021 § 2.3.2 (June 98) standard.

This is an English translation. The original French test report is the only reference version.

На основании чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



**1. Equipment used during test.**

**1.1 Equipment used**

N° U.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
94 03 10	Traction bench 3 tons	Class I
/	Dies E173	Width 9 mm

**1.2 Cables :**

Section (mm <sup>2</sup> )	35
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08006
Conditioned on	03/02/2010 (1 h at 120°C)

**2. Product tested.**

Désignation : CPTA 35  
 Number : 2  
 Batch number : 09M93760  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

ВЯРНО С ОПРИГНАТА

На основание чл. 2  
от ЗЗЛД

САМОКОВ

**3. Test.**

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.2 (june 98) standard.

**3.1 Test procedure.**

Connection is carried out using 5 mm wide dies for groove E 140 and 9 mm wide dies for grooves E 173 and E 215. The minimum strength to be applied is given in the standard. The length of the cores used complies with the length indicated in the standard.

The assembly is submitted to a tensile strength applied to the conductor. The strength is increased at a rate between 1000 N/min and 5000 N/min up to:

- for phases: 50% of the minimum load indicated in standard. This strength is applied for 1 min,
- for neutral messenger: 65% of the minimum load indicated in standard. This strength is applied for 1 hour.

The strength is then increased up to the minimum load indicated in standard, and released.

**3.2 Preparation**

A 9 mm wide dies for groove E173 is used.

**4. Results.**

	Standard requirements	Results
<b>Ambient temperature and humidity conditions</b>	Between 15 et 35°C Between 25 % et 75 % HR	22°C 28 % HR
<b>Rate of the tensile (N/min)</b>	Between 1000 et 5000	2500
<b>Strength value maintained for 1 min (N)</b>	1300	Sample 1 : ok Sample 2 : ok
<b>Strength value applied without breakdown (N)</b>	2500	Sample 1 : ok Sample 2 : ok

**5. Requirement**

No slippage is observed.

ВЪРХО С ОПИТИНАТА



На основание чл. 2  
от ЗЗЛД



*[Handwritten scribble]*


*[Handwritten signature]*

Test report number 10 02 190  
Annex I




SICAME LABORATORY

ВЪРНО С ОРИГИНАЛА



*[Handwritten signature]*

507



Лаборатория d'essai  
 Direction Etudes et Recherches

Test report : water tightness Test  
 Test number : 10 02 300  
 Product brand : SICAME  
 Product type : CPTA 35

Demandeur of the test : SICAME DER

Starting date of the test : 04/02/2010

Report emission date : 12 FEB. 2010

According to standard : NFC 33 021 § 2.4.3 and § 2.4.4 (June 98)



This report contains : 3 pages and 1 annex

Conclusion : The tested SICAME LV pre-insulated terminal lugs type CPTA 35 conform to the requirements of NFC 33 021 § 2.4.3 and § 2.4.4 (June 98) standard.

This is an English translation. The original French test report is the only reference version

На основании чл. 2  
 от 33ЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



**1 Equipment used during test.**

**1.1 Equipment used**

N° U.T.	Designation	Characteristic
99 01 48	Indicator thermometer	Accuracy 2°C
93 05 48	Crimping machine	Strength 50 kN
93 02 04	Water tank	/
97 02 02	Calibrated ruler	Accuracy 0,5mm
/	Dies E173	Width 9 mm

**1.2 Cables**

Section (mm <sup>2</sup> )	35
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08006
Conditioned on	03/02/2010 (1 h at 120°C)

**2 Product tested**

Designation : CPTA 35  
 Quantity : 2  
 Batch number : 09M93760  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory on the : 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОПРИТНАТА

САМОКОВ

559

### 3 Test procedure


Connectors are tested according to NFC 33 021 § 2.4.3 and § 2.4.4 (june 98) standard.

#### 3.1 Procedure

The assembly made by the lug and the conductor is placed at the bottom of a tank filled with water. The height of water is  $(30 \pm 10)$  cm measured above the lug.

The core crosses out of the tank through an appropriate seal which avoids any excessive stress on the core insulation according to figure below

The assembly is left in the water for 24 h.



dimensions in cm

#### 3.2 Preparation

A E173 groove with 9 mm wide dies is used.

### 4 Requirements

No trace of water shall be observed at the end of the core.

### 5 Results

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 and 35°C Between 25 and 75% HR	21°C 26 % HR
Duration of immersion	24 h 00	24 h 00
Immersion depth	$30^{+10}_0$ cm	33 cm

### 6 Conclusion

No trace of water is observed at the end of the core after the 24h.



На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА

*[Handwritten signature]*


*[Handwritten scribble]*

Test report number 10 02 300  
Annex 1



SICAME LABORATORY

ВЯРНО С ОРИГИНАЛА



*[Handwritten signature]*

*[Handwritten signature]*



**sicame**

Laboratoire d'essais  
Direction Etudes et Recherches



**Test report** : Crimping ability test  
**Test number** : 10 02 080  
**Product brand** : SICAME  
**Product type** : CPTA 35

**Demandeur of the test** : SICAME DER  
**Starting date of the test** : 10/02/2010  
**Report emission date** : **12 FEV. 2010**  
**According to standard** : NF C 33-021 § 2.3.1 (June 98)  
**This report contains** : 3 pages and 1 annex  
**Conclusion** : The tested SICAME pre-insulated terminal lugs type CPTA 35 conform to the requirements of NF C 33-021 § 2.3.1 (June 98) standard.

**This is an English translation. The original French test report is the only reference version.**

На основании чл. 2  
от 33ЛД

**This document cannot be reproduced even partially without the authorization of SICAME SA.**



**1. Equipment used during test.****1.1 Equipment used**

N° U.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
02 01 35	50 µm thick gauge	Accuracy ± 1,5 µm
/	Dies E1 73	Width 9 mm

**1.2 Cables :**

Section (mm <sup>2</sup> )	35
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08006
Conditioned on	03/02/2010 (1 h at 120°C)

**2. Product tested.**

Désignation : CPTA 35  
 Number : 2  
 Batch number : 09M93760  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010 .

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПРИГНАТА

САМОКОВ

563

**3. Test.**

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.1 (June 98) standard.

**3.1 Test procedure.**

Crimping of the joint sleeve or terminal lug on the relevant core(s) shall be carried out using dies in compliance with table B.1 of annex B of the standard. The minimum compression strength given in table B.2 of annex B of the standard shall be applied.

**3.3 Preparation**

A 9 mm wide dies for groove E173 is used.

**4. Requirements**

The two half-dies shall be in contact, which means that a 0,05 mm thick gauge cannot be inserted between the half-dies.

**5. Results.**

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	21°C 25 % HR
A 0,05 mm thick gauge is inserted between the half-dies	No	Sample 1 : no Sample 2 : no

**6. Conclusion**

The two half-dies are in contact, which means that a 0,05 mm thick gauge cannot be inserted between the half-dies.

На основание чл. 2  
от ЗЗЛД



ВЯРНО С ОРИГИНАЛАТА



*[Handwritten signature]*


*[Handwritten signature]*

Test report number 10 02 080  
Annex 1



SICAME LABORATORY

ВЯРНО С ОРЪНИКАЛА



*[Handwritten signature]*

165

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
НАКРАЙНИК ТИП СРТА 35**

1. № на тест: 1002190 – Тест за якост на опън;
2. № на тест: 1002300 - Тест за водонепропускливост;
3. № на тест: 1002080 - Изпитване на способността за пресоване.

Съставил:

На основание чл. 2  
от ЗЗЛД



**SICAME**

Industrie Sicame  
Société Industrielle et Recherches

Test report : Tensile test  
Test number : 10 02 200  
Product brand : SICAME  
Product type : CPTA 50

Demandeur of the test : SICAME DER  
Starting date of the test : 09/02/2010  
Report emission date : 12 FEV. 2010  
According to standard : NF C 33-021 § 2.3.2 (june 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 50 conform to the requirements of NF C 33-021 § 2.3.2 (june 98) standard.

This is an English translation. The original French test report is the only reference version.

На основании чл. 2  
от 33ЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

ВЯРНО С ОРИГИНАЛА

BAK-02-001  
САМОКОВ

567

**1. Equipment used during test.**

**1.1 Equipment used**

N° U.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
94 03 10	Traction bench 3 tons	Class 1
/	Dies E173	Width 9 mm

**1.2 Cables :**

Section (mm <sup>2</sup> )	50
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08007
Conditioned on	03/02/2010 (1 h at 120°C)

**2. Product tested.**

Désignation : CPTA 50  
 Number : 2  
 Batch number : 09M01252  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОПИТНАТА

САМОКОВ

**3. Test.**

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.2 (june 98) standard.

**3.1 Test procedure.**

Connection is carried out using 5 mm wide dies for groove E 140 and 9 mm wide dies for grooves E 173 and E 215. The minimum strength to be applied is given in the standard. The length of the cores used complies with the length indicated in the standard.

The assembly is submitted to a tensile strength applied to the conductor. The strength is increased at a rate between 1000 N/min and 5000 N/min up to:

- for phases: 50% of the minimum load indicated in standard. This strength is applied for 1 min,
- for neutral messenger: 65% of the minimum load indicated in standard. This strength is applied for 1 hour.

The strength is then increased up to the minimum load indicated in standard, and released.

**3.2 Preparation**

A 9 mm wide dies for groove E173 is used.



**4. Results.**

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	22°C 28 % HR
Rate of the tensile (N/min)	Between 1000 et 5000	2500
Strength value maintained for 1 min (N)	1300	Sample 1 : ok Sample 2 : ok
Strength value applied without breakdown (N)	2500	Sample 1 : ok Sample 2 : ok

**5. Requirement**

No slippage is observed.

На основание чл. 2  
от ЗЗЛД





САМОКОВ

189

SICAME LABORATORY

Test report number 10 02 200  
Annex 1



ВЪРНЕ С ОРГАНИЗАЦИЯТА



*Handwritten signature*

Р. 40



sicame

laboratoire d'essais  
Direction Essais et Recherches

Test report : water tightness Test  
 Test number : 10 02 310  
 Product brand : SICAME  
 Product type : CPTA 50

Demandeur of the test : SICAME DER

Starting date of the test : 04/02/2010

Report emission date : 12 FEB. 2010

According to standard : NFC 33 021 § 2.4.3 and § 2.4.4 (June 98)

This report contains : 3 pages and 1 annex

Conclusion : The tested SICAME LV pre-insulated terminal lugs type CPTA 50 conform to the requirements of NFC 33 021 § 2.4.3 and § 2.4.4 (June 98) standard.

This is an English translation. The original French test report is the only reference version

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

ВЪРТИ С ОРГАНИЗАЦИЯТА

“BAK - 02” ООД  
САМОКОНТРОЛ

171

## 1 Equipment used during test.

### 1.1 Equipment used

N° U.T.	Designation	Characteristic
99 01 48	Indicator thermometer	Accuracy 2°C
93 05 48	Crimping machine	Strength 50 kN
93 02 04	Water tank	/
97 02 02	Calibrated ruler	Accuracy 0,5mm
/	Dies E173	Width 9 mm

### 1.2 Cables

Section (mm <sup>2</sup> )	50
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08007
Conditioned on	03/02/2010 (1 h at 120°C)

## 2 Product tested

Designation : CPTA 50  
 Quantity : 2  
 Batch number : 09M01252  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory on the : 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВАРНО С ОПИТИВАНАТА



### 3 Test procedure


Connectors are tested according to NFC 33 021 § 2.4.3 and § 2.4.4 (June 98) standard.

#### 3.1 Procedure

The assembly made by the lug and the conductor is placed at the bottom of a tank filled with water. The height of water is  $(30 \pm 10)$  cm measured above the lug.

The core crosses out of the tank through an appropriate seal which avoids any excessive stress on the core insulation according to figure below

The assembly is left in the water for 24 h.



dimensions in cm

#### 3.2 Preparation

A E173 groove with 9 mm wide dies is used.

### 4 Requirements

No trace of water shall be observed at the end of the core.


### 5 Results

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 and 35°C Between 25 and 75% HR	21°C 26 % HR
Duration of immersion	24 h 00	24 h 00
Immersion depth	$30^{+10}_0$ cm	33 cm

### 6 Conclusion

No trace of water is observed at the end of the core after the 24h.

На основание чл. 2  
от ЗЗЛД




*[Handwritten signature]*

*[Handwritten signature]*

Test report number 10 02 310  
Annex 1

SICAME LABORATORY



*[Handwritten signature]*


ВАРНОЕ СЕРТИФИКАТА



*[Handwritten signature]*

221

*[Handwritten scribble]*



**SICAME**

Appareils diesel.  
Direction des des et Recherches

*[Handwritten scribble]*

Test report : Crimping ability test  
Test number : 10 02 090  
Product brand : SICAME  
Product type : CPTA 50



Demandeur of the test : SICAME DER  
Starting date of the test : 10/02/2010  
Report emission date : **12 FEV. 2010**  
According to standard : NF C 33-021 § 2.3.1 (June 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 50 conform to the requirements of NF C 33-021 § 2.3.1 (June 98) standard.

This is an English translation. The original French test report is the only reference version.

На основании чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

B.P. N° 1 - 10231 POMPADOUR



*[Handwritten signature]*

575

**1. Equipment used during test.**

**1.1 Equipment used**

N° U.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
02 01 35	50 µm thick gauge	Accuracy ± 1,5 µm
/	Dies E173	Width 9 mm

**1.2 Cables :**

Section (mm <sup>2</sup> )	50
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08007
Conditioned on	03/02/2010 (1 h at 120°C)

**2. Product tested.**

Désignation : CPTA 50  
 Number : 2  
 Batch number : 09M01252  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЪРНЕ С ОПЛАЩАНАТА

САМОКОВ

**3. Test.**

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.1 (June 98) standard.

**3.1 Test procedure.**

Crimping of the joint sleeve or terminal lug on the relevant core(s) shall be carried out using dies in compliance with table B.1 of annex B of the standard. The minimum compression strength given in table B.2 of annex B of the standard shall be applied.

**3.3 Preparation**

A 9 mm wide dies for groove E173 is used.

**4. Requirements**

The two half-dies shall be in contact, which means that a 0,05 mm thick gauge cannot be inserted between the half-dies.

**5. Results.**

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	21°C 25 % HR
A 0,05 mm thick gauge is inserted between the half-dies	No	Sample 1 : no Sample 2 : no

**6. Conclusion**

The two half-dies are in contact, which means that a 0,05 mm thick gauge cannot be inserted between the half-dies.

На основание чл. 2  
от ЗЗЛД

ВЯНО С ОРЪГИНАЛАТА

САМОВ


377

*[Handwritten signature]*

*[Handwritten signature]*

Test report number 10 02 090  
Annex 1

SICAME LABORATORY



*[Handwritten signature]*

ВЯРНО С ОПРИЛЖАТА



**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
НАКРАЙНИК ТИП СРТА 50**

1. № на тест: 1002200 - Тест за якост на опън;
2. № на тест: 1002310 - Тест за водонепропускливост;
3. № на тест: 1002090 - Изпитване на способността за пресоване.

Съставил:

На основание чл. 2  
от ЗЗЛД



*msz*



Laboratoire d'essais  
LABEP

Rapport d'essai  
Test report

: Essai de corrosion au brouillard salin  
: Salt mist test

Rapport d'essai n°	: 14 05 390	Test report n.	: 14 05 390
Constructeur	: SICAME	Manufacturer	: SICAME
Référence produit	: CPTA 54	Product reference	: CPTA 54
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: 28 mai au 05 juin 2014	Date of the test	: 28 May to 5 June 2014
Date d'émission du rapport	: 05 juin 2014	Report issue date	: 5 June 2014

Essais réalisés suivant : NF C 33-021 (09/2013), § 6.7.1  
Tests carried out in accordance with

Ce rapport comprend : 5 pages  
This report contains

**Conclusion** : Les cosses préisolées SICAME de type CPTA 54 soumis à essai satisfont aux exigences du § 6.7.1 de la norme NF C 33-021 (09/2013).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

**Conclusion** : The tested SICAME preinsulated lugs CPTA 54 comply with the requirements of clause 6.7.1 of NF C 33-021 (09/2013) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основании чл. 2  
от ЗЗЛД

L'accréditation de la section essais du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation. Ce rapport ne concerne que les produits référencés ci-dessus. La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.



ACCREDITATION  
N° 1-1068  
PORTÉE  
DISPONIBLE SUR  
www.cofrac.fr

cofrac

D 0194 08

Accreditation 1-1068, Scope on request.  
The Cofrac testing section accreditation ensures the competence of the Laboratory staff for the tests for which the laboratory has obtained this accreditation.  
This report applies only to the products as listed above. With the authorization of Sicame S.A., this report may only be reproduced in its entirety.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - TEL: (33) 05 55 73 63 12 - FAX: (33) 05 55 73 63 12 - Email: info@sicame.fr



186



**1 Echantillons soumis à essai / Samples under test**

Type : Cosses préisolées  
Preinsulated lugs

Désignation / Designation : CPTA 54

Fabricant / Manufacturer : SICAME


Numéro de lot / Batch number : 12M435210  
Echantillons suivant le plan E1100310  
Samples in accordance with drawing n. E1100310

<b>Plage de sections</b> <i>Cross-section range</i>
54,6 mm <sup>2</sup>

Classes du produit selon NF EN 50483-1 (§9.3) <i>Classes of product in accordance with NF EN 50483-1 (§9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 2  
 Repérage / Identification : 1, 2

Date de réception au laboratoire : 26 mai 2014  
 Reception date at the laboratory : 26 May 2014



ВЕРНО С СЕРТИФИКАТА



*Handwritten signature*

*Handwritten signature*

## 2 Caractéristiques du matériel / Equipment used during test

### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
02 01 76	Thermomètre indicateur <i>Indicating thermometer</i>	Précision $\pm 2^{\circ}\text{C}$ <i>Accuracy <math>\pm 2^{\circ}\text{C}</math></i>
11 03 16	Hygromètre indicateur <i>Indicating hygrometer</i>	Précision $\pm 5\%$ <i>Accuracy <math>\pm 5\%</math></i>
10 03 33	pH-mètre <i>pH-meter</i>	Précision $\pm 0,1 \text{ pH}$ <i>Accuracy <math>\pm 0,1 \text{ pH}</math></i>
98 03 39	Densimètre <i>Densimeter</i>	Précision $\pm 0,1 \%$ <i>Accuracy <math>\pm 0,1 \%</math></i>
04 00 30	Thermomètre étanche <i>Watertight thermometer</i>	Précision $1^{\circ}\text{C}$ <i>Accuracy <math>1^{\circ}\text{C}</math></i>
10 01 98	Enceinte de brouillard salin <i>Salt spray enclosure</i>	Conforme à la NF EN 60068-2-11 (08/1999) <i>Compliant with NF EN 60068-2-11 (08/1999)</i>

## 3 Méthode / Method

Les essais sont effectués selon les prescriptions du paragraphe 6.7.1 de la norme NF C 33-021 (09/2013).

*Lugs are tested in accordance with NF C 33-021 (09/2013) § 6.7.1 standard.*

### 3.1 Conditions ambiantes / Ambient conditions

Les conditions ambiantes relevées lors de l'essai sont les suivantes :


*Ambient conditions when performing the test are as follows:*

	Exigences <i>Requirements</i>	Relevés <i>Results</i>	
		Min	Max
Température ambiante et humidité <i>Ambient temperature and humidity conditions</i>	$15^{\circ}\text{C} \leq T^{\circ} \leq 35^{\circ}\text{C}$ $25\% \leq \text{HR} \leq 75\%$	21 °C 46 %HR	22 °C 55 %HR

### 3.2 Configuration des échantillons / Samples configuration

Échantillon n° <i>Sample n.</i>	Section / Cross section (mm <sup>2</sup> )
1	54,6
2	

ВЯРНО С ОРИГИНАЛА



**4 Exigences / Requirements**

	Exigences / Requirements	Résultats / Results
Concentration de NaCl <i>NaCl concentration (%)</i>	5 ± 1	Min : 4,8 Max : 5,0
Valeur du pH <i>pH value</i>	6,5 ≤ pH ≤ 7,2	Min : 6,76 Max : 7,07
Nombre de cycle en brouillard salin <i>Number of cycles in salt spray</i>	1 × 168 h	1 × 168 h
Volume récolté <i>Collected volume (mL/cycle)</i>	168 ≤ v ≤ 336	185

**5 Résultats / Results**

	Exigences <i>Requirements</i>	Relevés / Results	
		Echantillon / Sample	
		1	2
Détérioration des raccords <i>Deterioration of the connectors</i>	Aucune <i>No deterioration</i>	Aucune <i>No deterioration</i>	Aucune <i>No deterioration</i>
Marquage <i>Identification marking</i>	Lisible <i>Legible</i>	Lisible <i>Legible</i>	Lisible <i>Legible</i>



**6 Conclusion / Conclusion**

Le marquage permettant l'identification des échantillons est lisible quand il est examiné avec une vue normale ou corrigée, sans grossissement.

Aucune détérioration des cosses pouvant nuire à leur bon fonctionnement ne s'est produit.

*The sample's identification marking is legible when examined with normal or corrected vision, without magnification.*

*No deterioration of the lugs occurred which would impair their normal function.*




7 Photographies / Pictures

Echantillon 1 après essai / Sample 1 after test




Echantillon 2 après essai / Sample 2 after test



FIN DU RAPPORT D'ESSAI / END OF TEST REPORT

ВЪРНО С ОРИГИНАЛА



*Handwritten signature*

*Handwritten initials*



Laboratoire d'essais  
**LABEP**

**Rapport d'essai** : Essai d'étanchéité  
**Test report** : *Water tightness test*

<b>Rapport d'essai n°</b>	: 14 05 290	<b>Test report n.</b>	: 14 05 290
<b>Constructeur</b>	: SICAME	<b>Manufacturer</b>	: SICAME
<b>Référence produit</b>	: CPTA 54	<b>Product reference</b>	: CPTA 54
<b>Demandeur de l'essai</b>	: SICAME S.A.	<b>Test applied by</b>	: SICAME S.A.
<b>Date d'essai</b>	: 03 au 04 Juin 2014	<b>Date of the test</b>	: 3 to 4 June 2014
<b>Date d'émission du rapport</b>	: 05 Juin 2014	<b>Report issue date</b>	: 5 June 2014

**Essais réalisés suivant :** NF C 33-021 (09/2013), § 6.4.2  
*Tests carried out in accordance with*

**Ce rapport comprend :** 4 pages  
*This report contains*

**Conclusion** : Les cosses préisolées SICAME de type CPTA 54 soumis à essai satisfont aux exigences du § 6.4.2 de la norme NF C 33-021 (09/2013).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

**Conclusion** : *The tested SICAME preinsulated lugs CPTA 54 comply with the requirements of clause 6.4.2 of NF C 33-021 (09/2013) standard.*  
*To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved*

Visa  
Responsable de l'essai  
*Supervisor of the test*  
C. ESPINASSE

Visa  
Responsable Qualité Environnement  
*Quality Manager*  
L. DUPAQUET

Visa  
Directeur Études et Recherches  
*Director Research & Development*  
X. SOUCHE


L'accréditation de la section essais du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation. Ce rapport ne concerne que les produits référencés ci-dessus. La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.

ACCREDITATION  
N° 1-1068  
PORTÉE  
DISPONIBLE SUR  
www.cofrac.fr

Accreditation 1-1068, Scope on request.

The Cofrac testing section accreditation ensures the competence of the Laboratory staff for the tests for which the laboratory has been accredited. This report applies only to the products as listed above. With the authorization of Sicame S.A., this report may only be reproduced in its totality.

B.P. N° 1 - 19231 POMPADOUR - CEDEX FRANCE - Tél : (33) 05 55 73 63 12 - Fax : (33) 05 55 73 63 12 - Email : info@sicame.fr



D 0184 08

585

**I Echantillons soumis à essai / Samples under test**

Type : Cosses préisolées  
Preinsulated lugs

Désignation / Designation : CPTA 54

Fabricant / Manufacturer : SICAME




Numéro de lot / Batch number : 12M435210  
Echantillons suivant le plan E1100310  
Samples in accordance with drawing n. E1100310

Plage de sections Cross-section range
54,6 mm <sup>2</sup>

Classes du produit selon NF EN 50483-1 (§9.3) Classes of product in accordance with NF EN 50483-1 (§9.3)	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit Class A : connectors subjected to heat cycles and short-circuit current tests
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique Class B : connectors subjected to heat cycles only
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau Class 1 : connectors subjected to dielectric test in water
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air Class 2 : connectors subjected to dielectric test in air

Nombre d'échantillons / Number of samples : 2  
Repérage / Identification : 1, 2

Date de réception au laboratoire : 26 mai 2014  
Reception date at the laboratory : 26 May 2014



*Handwritten signature*

*Handwritten mark*


## 2 Caractéristiques du matériel / Equipment used during test

## 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
02 01 76	Thermomètre indicateur <i>Indicating thermometer</i>	Précision $\pm 2^{\circ}\text{C}$ <i>Accuracy <math>\pm 2^{\circ}\text{C}</math></i>
11 03 16	Hygromètre indicateur <i>Indicating hygrometer</i>	Précision $\pm 5\%$ <i>Accuracy <math>\pm 5\%</math></i>
97 02 02	Réglet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
10 00 73	Bac d'étanchéité <i>Water tank</i>	/ /

## 2.2 Câbles / Cables

N° Lot / Identification	13001		
Norme / Standard	NF C 33-209		
Provenance / From	France		
Section / Cross section	54,6 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input type="checkbox"/> Aluminium	<input checked="" type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	<input type="checkbox"/> Souple <i>Flexible</i>
	<input type="checkbox"/> Rétreinte <i>Compacted</i>	<input checked="" type="checkbox"/> Non rétreinte <i>Non compacted</i>	
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	9,6 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 <i>Cross-linked polyethylene, TIX-5 type</i>		
Ø sur isolant / Ø on insulation	12,6 mm		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Charge de rupture minimale (CRM) Minimum Breaking Load (MBL)	16 600 N		
Référence du câble HD626 / HD626 conductor reference	6 E-1		



**3 Méthode / Method**

Les essais sont effectués selon les prescriptions du paragraphe 6.4.2 de la norme NF C 33-021 (09/2013).

*Lugs are tested in accordance with NF C 33-021 (09/2013) § 6.4.2 standard.*

**3.1 Conditions ambiantes / Ambient conditions**

Les conditions ambiantes relevées lors de l'essai sont les suivantes :  
*Ambient conditions when performing the test are as follows:*

	Exigences <i>Requirements</i>	Relevés <i>Results</i>
Température ambiante et humidité <i>Ambient temperature and humidity conditions</i>	15 °C ≤ T° ≤ 30 °C 25 % ≤ HR ≤ 75 %	21 °C 47 %HR
Hauteur d'eau au dessus du connecteur (cm) <i>Height of water above the connectors (cm)</i>	30 à 40 30 to 40	33

**3.2 Configuration des échantillons / Samples configuration**

Echantillon n° <i>Sample n.</i>	Section / Cross section (mm <sup>2</sup> )
1	54,6
2	

**4 Résultats / Results**

Echantillon n° <i>Sample n.</i>	Exigences <i>Requirements</i>	Résultats <i>Results</i>
1	Pas de trace d'eau après 24 h d'immersion	Pas de trace d'eau <i>No trace of water</i>
2	<i>No trace of water after 24 h immersion</i>	Pas de trace d'eau <i>No trace of water</i>

**5 Conclusion / Conclusion**

Aucune trace d'eau au-dessous de l'extrémité des conducteurs n'est constatée.  
*No trace of water is observed at the end of the core.*

FIN DU RAPPORT D'ESSAI / END OF TEST REPORT



*Handwritten signature*

1792





Labratoire d'essais  
LABEP

Rapport d'essai : Essai de traction  
Test report : Tensile test

Rapport d'essai n°	: 14 05 280	Test report n.	: 14 05 280
Constructeur	: SICAME	Manufacturer	: SICAME
Référence produit	: CPTA 54	Product reference	: CPTA 54
Demandeur de l'essai	: SICAME S.A.	Test applied by	: SICAME S.A.
Date d'essai	: 28 mai 2014	Date of the test	: 28 May 2014
Date d'émission du rapport	: 28 mai 2014	Report issue date	: 28 May 2014

Essais réalisés suivant : NF C 33-021 (09/2013), § 6.3.2  
Tests carried out in accordance with

Ce rapport comprend : 5 pages  
This report contains

**Conclusion** : Les cosses préisolées SICAME de type CPTA 54 soumis à essai satisfont aux exigences du § 6.3.2 de la norme NF C 33-021 (09/2013).  
Pour déclarer la conformité, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

**Conclusion** : The tested SICAME preinsulated lugs CPTA 54 comply with the requirements of clause 6.3.2 of NF C 33-021 (09/2013) standard.  
To give a ruling on the conformity, the uncertainty associated to the result is not implicitly involved

На основании чл. 2  
от ЗЗЛД


L'accréditation de la section essais du COFRAC atteste de la compétence des laboratoires pour les seuls essais couverts par l'accréditation. Ce rapport ne concerne que les produits référencés ci-dessus. La reproduction de ce rapport d'essais n'est autorisée que sous forme intégrale, avec l'accord de SICAME S.A.

ACCREDITATION  
N° 1-1059  
PORTÉE  
DISPONIBLE SUR  
www.cofrac.fr



Accreditation 1-1059. Scope on request.  
The Cofrac testing section accreditation ensures the competence of the Laboratory staff for the tests for which the laboratory is accredited.  
This report applies only to the products as listed above. With the authorization of Sicame S.A., this report may only be reproduced in its entirety.

B.P. N° 1 - 19231 POMPADOUR - CEDEX - FRANCE - Tél (33) 05 55 73 63 12 - Fax (33) 05 55 73 63 12 - Email : info@sicame.fr



D 0194 09

589

**1 Echantillons soumis à essai / Samples under test**

Type : Cosses préisolées  
*Preinsulated lugs*

Désignation / Designation : CPTA 54

Fabricant / Manufacturer : SICAME

Numéro de lot / Batch number : 12M435210  
Echantillons suivant le plan E1100310  
*Samples in accordance with drawing n. E1100310*



<b>Plage de sections</b> <i>Cross-section range</i>
54,6 mm <sup>2</sup>

<b>Classes du produit selon NF EN 50483-1 (§9.3)</b> <i>Classes of product in accordance with NF EN 50483-1 (§9.3)</i>	
<input checked="" type="checkbox"/>	Classe A : raccords soumis aux cycles de vieillissement électrique et aux essais de court-circuit <i>Class A : connectors subjected to heat cycles and short-circuit current tests</i>
<input type="checkbox"/>	Classe B : raccords soumis seulement aux cycles de vieillissement électrique <i>Class B : connectors subjected to heat cycles only</i>
<input checked="" type="checkbox"/>	Classe 1 : raccords soumis à l'essai de tenue diélectrique dans l'eau <i>Class 1 : connectors subjected to dielectric test in water</i>
<input type="checkbox"/>	Classe 2 : raccords soumis à l'essai de tenue diélectrique dans l'air <i>Class 2 : connectors subjected to dielectric test in air</i>

Nombre d'échantillons / Number of samples : 2

Repérage / Identification : 1, 2

Date de réception au laboratoire : 26 mai 2014  
*Reception date at the laboratory : 26 May 2014*



*[Handwritten signature]*

*[Handwritten mark]*



## 2 Caractéristiques du matériel / Equipment used during test

### 2.1 Appareillage utilisé / Equipment used

N° U.T.	Désignation / Designation	Caractéristiques / Characteristic
93 05 48	Presse à sertir <i>Compression tool</i>	5 tonnes <i>5 tons</i>
/	Matrices <i>Dies</i>	E173 largeur 9 mm <i>E173 width 9 mm</i>
02 01 76	Thermomètre indicateur <i>Indicating thermometer</i>	Précision $\pm 2^{\circ}\text{C}$ <i>Accuracy <math>\pm 2^{\circ}\text{C}</math></i>
11 03 16	Hygromètre indicateur <i>Indicating hygrometer</i>	Précision $\pm 5\%$ <i>Accuracy <math>\pm 5\%</math></i>
97 02 02	Réglet étalon <i>Calibrated ruler</i>	Précision 0,5 mm <i>Accuracy 0,5 mm</i>
94 03 10	Banc de traction 3 tonnes <i>Tensile test machine 3 tons</i>	Classe 1 <i>Class 1</i>

### 2.2 Câbles / Cables

N° Lot / Identification	13001		
Norme / Standard	NF C 33-209		
Provenance / From	France		
Section / Cross section	54,6 mm <sup>2</sup>		
Matériau de l'âme / Conductor material	<input type="checkbox"/> Cuivre <i>Copper</i>	<input type="checkbox"/> Aluminium	<input checked="" type="checkbox"/> Alliage d'aluminium <i>Aluminium alloy</i>
Type d'âme / Conductor type	<input type="checkbox"/> Massive <i>Solid</i>	<input checked="" type="checkbox"/> Câblée <i>Stranded</i>	<input type="checkbox"/> Souple <i>Flexible</i>
	<input type="checkbox"/> Rétreinte <i>Compacted</i>	<input checked="" type="checkbox"/> Non rétreinte <i>Non compacted</i>	
Forme d'âme / Conductor shape	<input checked="" type="checkbox"/> Ronde <i>Circular</i>	<input type="checkbox"/> Sectorale <i>Sector-shaped</i>	
Nombre de brins / Number of wires	7		
Ø sur âme / Ø on conductor	9,6 mm		
Matériau de l'isolant Insulation material	Polyéthylène réticulé type TIX-5 <i>Cross-linked polyethylene, TIX-5 type</i>		
Ø sur isolant / Ø on insulation	12,6 mm		
Conditionnement Conditioned on	1h00 à 120°C <i>1h00 at 120°C</i>		
Charge de rupture minimale (CRM) Minimum Breaking Load (MBL)	16 600 N		
Référence du câble HD626 / HD626 conductor reference	6 E-1		



**3 Méthode / Method**

Les essais sont effectués selon les prescriptions du paragraphe 6.3.2 de la norme NF C 33-021 (09/2013).

*Lugs are tested in accordance with NF C 33-021 (09/2013) § 6.3.2 standard.*

**3.1 Conditions ambiantes / Ambient conditions**

Les conditions ambiantes relevées lors de l'essai sont les suivantes :

*Ambient conditions when performing the test are as follows:*

	Exigences <i>Requirements</i>	Relevés <i>Results</i>
Température ambiante et humidité <i>Ambient temperature and humidity conditions</i>	15 °C ≤ T° ≤ 35 °C 25 % ≤ HR ≤ 75 %	21 °C 46 %HR


**3.2 Configuration des échantillons / Samples configuration**

Echantillon n° <i>Sample n.</i>	Section / Cross section (mm²)
1	54,6
2	

**4 Résultats / Results**

Echantillon n° <i>Sample n.</i>	Vitesse de montée programmée <i>Planned increase rate</i> (N/min)	
	Exigences <i>Requirements</i>	Résultats <i>Results</i>
1	1000 ≤ ... ≤ 5000	3000
2		3000

Echantillon n° <i>Sample n.</i>	Effort pour marquage pendant 1 minute <i>Strength for marking during 1 min</i> (N)		Effort maximum <i>Maximum strength</i> (N)	
	Exigences <i>Requirements</i>	Résultats <i>Results</i>	Exigences <i>Requirements</i>	Résultats <i>Results</i>
1	1500	1500	2500 ± 5%	2521
2		1500	↔ 2375 ≤ ... ≤ 2625	2523





1507


5 **Conclusion / Conclusion**

Aucun glissement ou rupture ne s'est produit.  
*No slippage or breakage occurred.*

6 **Courbes / Curves**



FIN DU RAPPORT D'ESSAI / END OF TEST REPORT



*ms*

*192*

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
НАКРАЙНИК ТИП СРТА 54**

1. № на тест: 1405390 – Корозионен тест в солна мъгла;
2. № на тест: 1405290 – Тест за водонепропускливост;
3. № на тест: 1405280 – Тест за якост на опън;

Съставил:

На основание чл. 2  
от ЗЗЛД



*Handwritten signature*

*Handwritten mark*

5,

Test report : Crimping ability test  
Test number : 10 02 091  
Product brand : SICAME  
Product type : CPTA 70

Demandor of the test : S.B. AMF DER  
Starting date of the test : 10/02/2010  
Report emission date : 12 FEB. 2010  
According to standard : NF C 33-021 § 2.3.1 (June 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 70 conform to the requirements of NF C 33-021 § 2.3.1 (June 98) standard.

00

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

ВЯРНО С ОРГИНАЛАТА



SAS

1. Equipment used during test.

1.1 Equipment used

N° I.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
02 01 35	50 µm thick gauge	Accuracy ± 1.5 µm
	Dies 1173	Width 9 mm

1.2 Cables :

Section (mm <sup>2</sup> )	70
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08007
Conditioned on	03/02/2010
	(1 h at 120°C)

2. Product tested.

Désignation : CP1A 70  
 Number : 2  
 Batch number : 09A101252  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА





3. Test.

Pre-insulated terminal lugs are tested according to NFC 33-021 § 2.3.1 (June 98) standard.

3.1 Test procedure.

Crimping of the joint sleeve or terminal lug on the relevant core(s) shall be carried out using dies in compliance with table B.1 of annex B of the standard. The minimum compression strength given in table B.2 of annex B of the standard shall be applied.

3.3 Preparation

A 9 mm wide dies for groove 1175 is used.

4. Requirements

The two half-dies shall be in contact, which means that a 0.05 mm thick gauge cannot be inserted between the half-dies


5. Results

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C	21°C
	Between 25 % et 75 % HR	25 % HR
A 0.05 mm. thick gauge is inserted between the half-dies	No	Sample 1 : no Sample 2 : no

6. Conclusion

The two half-dies are in contact, which means that a 0.05 mm thick gauge cannot be inserted between the half-dies.

На основание чл. 2  
от ЗЗЛД




*ms*

597

*[Handwritten signature]*

*[Handwritten signature]*





Test report : Tensile test  
Test number : 10 02 2010  
Product brand : SICAME  
Product type : CPTA 70

Demandeur of the test : SICAME-DISK  
Starting date of the test : 09 02 2010  
Report emission date : 12 FEB. 2010  
Accordinging to standard : NF C 33-021 § 2.3.2 (June 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 70 conform to the requirements of NF C 33-021 § 2.3.2 (June 98) standard.

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



*[Handwritten signature]*

502

1. Equipment used during test.

1.1 Equipment used

N° U.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
94 03 10	Traction bench 3 tons	Class 1
	Dies E173	Width 9 mm

1.2 Cables :

Section (mm <sup>2</sup> )	70
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08/07
Conditioned on	03/02/2010 (1 h at 120°C)

2. Product tested.

Désignation : CPTA 70  
 Number : 2  
 Batch number : 09M01252  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОПРИГНАЛАТА



599

### 3. Test.

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.2 (June 98) standard.

#### 3.1 Test procedure.

Connection is carried out using 5 mm wide dies for groove E 140 and 9 mm wide dies for grooves E 173 and E 215. The minimum strength to be applied is given in the standard. The length of the cores used complies with the length indicated in the standard.

The assembly is submitted to a tensile strength applied to the conductor. The strength is increased at a rate between 1000 N/min and 5000 N/min up to:

- for phases: 50% of the minimum load indicated in standard. This strength is applied for 1 min.
- for neutral messenger: 65% of the minimum load indicated in standard. This strength is applied for 1 hour.

The strength is then increased up to the minimum load indicated in standard, and released.

#### 3.2 Preparation

A 9 mm wide dies for groove F173 is used.



### 4. Results.

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	22°C 28 % HR
Rate of the tensile (N/min)	Between 1000 et 5000	2500
Strength value maintained for 1 min (N)	1500	Sample 1 : ok Sample 2 : ok
Strength value applied without breakdown (N)	2500	Sample 1 : ok Sample 2 : ok

### 5. Requirement

No slippage is observed.

На основание чл. 2  
от ЗЗЛД



*[Handwritten scribble]*

*[Handwritten scribble]*

CL 175 10

*[Faint stamp]*

*[Handwritten scribble]*

Test report : water tightness test  
 Test number : 10 02 311  
 Product brand : SICAME  
 Product type : CPTA70

Demandeur of the test : SICAME DLR

Starting date of the test : 04.02.2016

Report emission date : 12 FEB. 2016

According to standard : NFC 33 021 § 2.4.3 and § 2.4.4 (June 98)

This report contains : 3 pages and 1 annex

*[Handwritten scribble]*

**Conclusion** : The tested SICAME LV pre-insulated terminal lugs type CPTA70 conform to the requirements of NFC 33 021 § 2.4.3 and § 2.4.4 (June 98) standard.

This is a first translation. The original French test report is the only reference version

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced, partially without the authorization of SICAME SA.

*[Handwritten signature]*

ВЪРНО С ОРМИНАЛА

"BAK - 02" OOD  
 CAMOKOB

609

**1 Equipment used during test.**

**1.1 Equipment used**

N° D.T.	Designation	Characteristic
99 01 48	Indicator thermometer	Accuracy 2°C
93 05 48	Crimping machine	Strength 50 kN
93 02 04	Water tank	/
97 02 02	Calibrated ruler	Accuracy 0.5mm
/	Dies E173	Width 9 mm


**1.2 Cables**

Section (mm <sup>2</sup> )	70
Nature	Aluminium
Standard	NF C 33-209
From	France
Identification n°	08007
Conditioned on	03/02/2010 (1 h at 120°C)

**2 Product tested**

Designation : CPTA 70  
 Quantity : 3  
 Batch number : 09M01252  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory on the : 03/02/2010

На основание чл. 2  
от ЗЗЛД



602

### 3 Test procedure


Conductor is tested according to IEC 60302-1 § 2.4.3 and § 2.4.4 (June 98) standard.

#### 3.1 Procedure

The assembly made by the lug and the conductor is placed at the bottom of a tank filled with water. The height of water is  $(30 \pm 10)$  cm measured above the lug.

The core passes out of the tank through an appropriate seal which avoids any excessive stress on the conductor, with a flexibility, to figure below.

The assembly is left in the water for 24 h.



dimensions in cm

#### 3.2 Preparation

Al 17 conductor with 9 mm wide slot is used.

#### 4 Requirement

No. 20000000 shall be observed at the end of the core

#### 5 Results

	Standard requirements	Results
Ambient temperature and humidity condition	Between 15 and 35°C	21°C
	Between 25 and 75% HR	26 % HR
Duration of the immersion	24 h 00	24 h 00
Immersion depth	30 ± 10 cm	33 cm

#### 6 Conclusion

No. 20000000 is observed at the end of the core after the 24h.

На основание чл. 2  
от ЗЗЛД

ВАРНО С ОРИГИНАЛА




603

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
НАКРАЙНИК ТИП СРТА 70**

1. № на тест: 1002091 - Изпитване на способността за пресоване;
2. № на тест: 1002201 – Тест за якост на опън;
3. № на тест: 1002311 - Тест за водонепропускливост;

Съставил:


На основание чл. 2  
от ЗЗЛД



САМОУЧЕБНИК

6010





laboratoire d'essais  
Direction Studies et Recherches


Test report : Tensile test  
Test number : 10 02 210  
Product brand : SICAME  
Product type : CPTA 95

Demandeur de la test : SICAME DER  
Starting date of the test : 09/02/2010  
Report emission date : 12 FEV. 2010  
According to standard : NF C 33-021 § 2.3.2 (June 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 95 conform to the requirements of NF C 33-021 § 2.3.2 (June 98) standard.

This is an English translation. The original French test report is the only reference version.

На основании чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



## 1. Equipment used during test.

### 1.1 Equipment used

N° U.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
94 03 10	Traction bench 3 tons	Class 1
/	Dies E173	Width 9 mm

### 1.2 Cables :

Section (mm <sup>2</sup> )	95
Nature	Aluminium
Standard	UNE 21-030-92 (12/1992)
From	Spain
Identification n°	05024
Conditioned on	27/06/2006 (1 h at 120°C)

## 2. Product tested.

Désignation : CPTA 95  
 Number : 2  
 Batch number : 09M932780  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЪРНО С ОПИТИНАТА

### 3. Test.

Pre-insulated terminal lugs are tested according to NF C 33-021 § 2.3.2 (june 98) standard.

#### 3.1 Test procedure.

Connection is carried out using 5 mm wide dies for groove E 140 and 9 mm wide dies for grooves E 173 and E 215. The minimum strength to be applied is given in the standard. The length of the cores used complies with the length indicated in the standard.

The assembly is submitted to a tensile strength applied to the conductor. The strength is increased at a rate between 1000 N/min and 5000 N/min up to:

- for phases: 50% of the minimum load indicated in standard. This strength is applied for 1 min,
- for neutral messenger: 65% of the minimum load indicated in standard. This strength is applied for 1 hour.

The strength is then increased up to the minimum load indicated in standard, and released.

#### 3.2 Preparation

A 9 mm wide dies for groove E173 is used.

### 4. Results.

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C	22°C
	Between 25 % et 75 % HR	28 % HR
Rate of the tensile (N/min)	Between 1000 et 5000	2500
Strength value maintained for 1 min (N)	1300	Sample 1 : ok Sample 2 : ok
Strength value applied without breakdown (N)	2500	Sample 1 : ok Sample 2 : ok

### 5. Requirement

No slippage is observed.

На основание чл. 2  
от ЗЗЛД

ВЪРЖЕ С ОПРИТНАТА


*hms*

607

*[Handwritten signature]*

*[Handwritten signature]*

Test report number 10 02 210  
Annex 1




SICAME LABORATORY

*[Handwritten signature]*

ВАЖНО С ОПРЕДЕЛЕНИЕТО

“ВАК - 02” ООД  
ДАМКОВ  
*[Handwritten signature]*

608

 **SICAME**  
Laboratoire d'essais  
Direction: Bâtiment et Matériaux

Test report : water tightness Test  
Test number : 10 02 320  
Product brand : SICAME  
Product type : CPTA 95

Demandeur of the test : SICAME DER

Starting date of the test : 08/02/2010

Report emission date : 12 FEV. 2010

According to standard : NFC 33 021 § 2.4.3 and 2.4.4 (june 98)

This report contains : 3 pages and 1 annex

Conclusion : The tested SICAME LV pre-insulated terminal lugs type CPTA 95 conform to the requirements of NFC 33 021 § 2.4.3 and 2.4.4 (june 98) standard.

This is an English translation. The original French test report is the only reference version

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

*Handwritten signature*

609

## 1 Equipment used during test.

### 1.1 Equipment used

N° U.T.	Designation	Characteristic
99 01 48	Indicator thermometer	Accuracy 2°C
93 05 48	Crimping machine	Strength 50 kN
93 02 04	Water tank	/
97 02 02	Calibrated ruler	Accuracy 0,5mm
/	Dies E173	Width 9 mm

### 1.2 Cables

Section (mm <sup>2</sup> )	95
Nature	Aluminium
From	Spain
Standard	UNE 21-030-92 (12/1992)
Identification n°	05024
Conditioned on	27/06/2006 (1h at 120°C)

## 2 Product tested

Designation : CPTA 95  
 Quantity : 2  
 Batch number : 09M93278  
 Marking : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory on the : 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЪРХНО С ОПИМЕНАТА

640

### 3 Test procedure


Connectors are tested according to NFC 33 021 § 2.4.3 and 2.4.4 (june 98) standard.

#### 3.1 Procedure

The assembly made by the lug and the conductor is placed at the bottom of a tank filled with water. The height of water is  $(30 \pm 10)$  cm measured above the lug.

The core crosses out of the tank through an appropriate seal which avoids any excessive stress on the core insulation according to figure below

The assembly is left in the water for 24 h.



dimensions in cm

#### 3.2 Preparation

A E173 groove with 9 mm wide dies is used.

### 4 Requirements

No trace of water shall be observed at the end of the core.

### 5 Results

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 and 35°C	22°C
	Between 25 and 75% HR	32 % HR
Duration of immersion	24 h 00	24 h 00
Immersion depth	$30^{+10}_0$ cm	35 cm

### 6 Conclusion

No trace of water is observed at the end of the core after the 24h.

На основание чл. 2  
от ЗЗЛД


ВЯЖО С ОРИГИНАЛА

641

*[Handwritten signature]*

*[Handwritten signature]*

Test report number 10 02 320  
Annex I



SICAME LABORATORY

*[Handwritten signature]*

ВЪРНО С ОРИГИНАЛА

“BAK - 02” ООД  
САМОКОВ  
*[Handwritten signature]*



**SICAME**  
 Le spécialiste de la connectique  
 Câbles et Fiches en Aluminium


Test report : Crimping ability test  
 Test number : 10 02 100  
 Product brand : SICAME  
 Product type : CPTA 95

Demandeur of the test : SICAME DER  
 Starting date of the test : 10/02/2010  
 Report emission date : 12 FEV, 2010  
 According to standard : NF C 33-021 § 2.3.1 (june 98)  
 This report contains : 3 pages and 1 annex  
 Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 95 conform to the requirements of NF C 33-021 § 2.3.1 (june 98) standard.

This is an English translation. The original French test report is the only reference version.

На основании чл. 2  
 от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.



613

## 1. Equipment used during test.

### 1.1 Equipment used

N° U.T.	Designation	Characteristic
99 01 48	Thermometer indicated	Accuracy 2°C
93 05 48	Crimping machine	50 kN
02 01 35	50 µm thick gauge	Accuracy ± 1,5 µm
/	Dies E173	Width 9 mm

### 1.2 Cables :

Section (mm <sup>2</sup> )	95
Nature	Aluminium
Standard	UNE 21-030-92 (12/1992)
From	Spain
Identification n°	05024
Conditioned on	27/06/2006 (1 h at 120°C)

## 2. Product tested.

Désignation : CPTA 95  
 Number : 2  
 Batch number : 09M93278  
 Stamping : See annex 1  
 Identification : 1 and 2  
 Reception date at the laboratory : on the 03/02/2010

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА

**3. Test.**

Pre-insulated terminal lug are tested according to NF C 33-021 § 2.3.1 (june 98) standard.

**3.1 Test procedure.**

Crimping of the joint sleeve or terminal lug on the relevant core(s) shall be carried out using dies in compliance with table B.1 of annex B of the standard. The minimum compression strength given in table B.2 of annex B of the standard shall be applied.

**3.3 Preparation**

A 9 mm wide dies for groove E173 is used.

**4. Requirements**

The two half-dies shall be in contact, which means that a 0,05 mm thick gauge cannot be inserted between the half-dies.


**5. Results.**

	Standard requirements	Results
Ambient temperature and humidity conditions	Between 15 et 35°C Between 25 % et 75 % HR	21°C 25 % HR
A 0,05 mm thick gauge is inserted between the half-dies	No	Sample 1 : no Sample 2 : no

**6. Conclusion**

The two half-dies are in contact, which means that a 0,05 mm thick gauge cannot be inserted between the half-dies.

На основании чл. 2  
от 33ЛД



*Handwritten signature*



*Handwritten signature*

*[Handwritten signature]*

*[Handwritten signature]*

Test report number 10 02 100  
Annex 1

SICAME LABORATORY



ВЪРНО С ОПРИМАЛАТА

"ВАК - 02" ООД  
САДКОВ  
*[Handwritten signature]*

*[Handwritten signature]*

646

**СПИСЪК НА ОТДЕЛНИТЕ ИЗПИТВАНИЯ НА ИЗОЛИРАН ПРЕСОВ  
НАКРАЙНИК ТИП СРТА 95**

1. № на тест: 1002210 – Тест за якост на опън;
2. № на тест: 1002320 – Тест за водонепропускливост;
3. № на тест: 1002100 – Изпитване на способността за пресоване.

На основание чл. 2  
от ЗЗЛД

Съставил:



*Handwritten signature*

*Handwritten signature* 017

30

Test report : Crimping ability test  
Test number : 10 02 102  
Product brand : SICAME  
Product type : CPTA 150

30

Demandeur of the test : SICAME DER  
Starting date of the test : 10/02/2010  
Report emission date : 12 FEB. 2010  
According to standard : NFC 33-021 § 2.3.1 (June 98)  
This report contains : 3 pages and 1 annex  
Conclusion : The tested SICAME pre-insulated terminal lugs type CPTA 150 conform to the requirements of NFC 33-021 § 2.3.1 (June 98) standard.

This is an English translation. The original French test report is the only reference version.

На основание чл. 2  
от ЗЗЛД

This document cannot be reproduced even partially without the authorization of SICAME SA.

ВЯРНО С ОРМИНАЛАТА

