

**ТЕХНИЧЕСКО ПРЕДЛОЖЕНИЕ****ПРЕДЛОЖЕНИЕ**

за участие в „открита“ по вид процедура за сключване на рамково споразумение с предмет:  
“ Доставка на вентилни отводи средно напрежение (СрН)“, реф. № PPD 17-158

**ДО: „ЧЕЗ РАЗПРЕДЕЛЕНИЕ БЪЛГАРИЯ“ АД,**

**ОТ: „Филкаб“ АД**

адрес: гр. Пловдив, ул. Коматевско шосе № 92

тел.: 032/ 277171, факс: 032/ 671133; e-mail: [office@filkab.com](mailto:office@filkab.com)

Единен идентификационен код: 115328801

Представявано от Александър Викторов Приходков – пълномощник на Изпълнителния директор с нотариално заверено пълномощно № 5487/06.12.2017 на нотариус № 473 – Мина Стоилова

Лице за контакти: Даниел Иванов, тел.: 032 608 884, факс: 032 671 133, e-mail: [daniel.ivanov@filkab.com](mailto:daniel.ivanov@filkab.com)

**УВАЖАЕМИ ГОСПОЖИ И ГОСПОДА,**

Предоставям на Вашето внимание предложението ни за изпълнение на обществена поръчка с реф. PPD 17-158 и предмет: „Доставка на вентилни отводи средно напрежение (СрН),

1. Запознат съм и приемам изискванията на Възложителя, като представям техническите спецификации от раздел II на документацията за участие с попълнени всички изисквани стойности за всички позиции от предмета на поръчката и изискванията, описани в рамковото споразумение и приложенията към него.
2. Представям всички изисквани данни и документи, посочени в Приложение 2 от настоящото техническо предложение. Запознат съм с изискването, че представените документи трябва да бъдат на български език или с превод на български език, придружени с оригиналните документи, с изключение на протоколите от типовите изпитвания, които могат да се представят и само на английски език.
3. Запознат съм, че представените от нас технически документи (протоколи от изпитания, каталози и др.) са доказателство за декларираните от мен технически данни и параметри в техническите спецификации на стоката.
4. Потвърждавам, че представяните от нас стоки, описани в Техническото ни предложение, ще отговарят на посочените от Възложителя стандарти или на еквивалентни. В случай, че даден материал отговаря на стандарт, еквивалентен на посочения, се задължаваме да го отразим в отделен документ и да представим доказателства за еквивалентността на двата стандарта.

---

C

C

5. Всички стойности, попълнени в колона „Гарантирано предложение“ на приложените таблици от Технически спецификации от раздел II от документацията за участие, са точни и истински.
6. Предлагам следният гаранционен срок за предлаганите стоки – 24 (словом: двадесет и четири) месеца, от датата на приемно - предавателен протокол за получаване на стоката от Възложителя.
7. Запознат съм, че видовете стоки и прогнозните количества за доставка ще бъдат посочени от Възложителя при провеждане на вътрешен конкурентен избор.
8. Приемам количества със срокове за доставка на стоката, съгласно Приложение 3 към настоящото Техническо предложение.
9. Приемам, че в срок до \_\_\_\_\_ (не повече от 14 дни) от датата на подписване на рамково споразумение с Възложителя, ще сключа договор с посоченият/те в офертата подизпълнител/и (попълва се, ако участникът е декларирал, че ще използва подизпълнител/и).
10. Запознат съм, че при последваща обществена поръчка чрез вътрешен конкурентен избор за сключване на конкретен договор, изборът на изпълнител при определяне на икономически най-изгодната оферта ще бъде направен по критерий „най-ниска цена“.
11. Запознат съм, че максималният срок за изпълнение на конкретен договор ще бъде определен от Възложителя в поканата за участие при последващата обществена поръчка чрез вътрешен конкурентен избор.

**Приложения към настоящото техническо предложение:**

1. Технически изисквания и спецификации за изпълнение на поръчката – раздел IV от документацията за участие – попълнени на съответните места;
2. Изисквани документи от Технически изисквания и спецификации;
3. Срокове за доставка.

Дата: 30.03.2018 г.

Декларатор:

На основание чл. 2  
от ЗЗЛД



Пълномощник на  
р с нотариално  
5487/06.12.2017 на  
рилова

---

C

C



Приложение 1 към Техническо предложение

**II. ТЕХНИЧЕСКИ СПЕЦИФИКАЦИИ И ИЗИСКВАНИЯ НА ВЪЗЛОЖИТЕЛЯ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА**

**Наименование на материала:** Вентилен отвод метало-оксиден тип без искрови разрядници, 10 kV, 10 kA, клас 2

**Съкратено наименование на материала (40 знака):** Вентилен отвод ZnO, 10 kV / 10 kA / клас 2

**Област:** В – Въздушни електропроводни линии СрН  
Н – Трансформаторни постове

**Категория:** 20 – Защита от пренапрежения

**Мерна единица:** Брой

**Аварийни запаси:** Да

**Характеристика на материала:**

Метало-оксиден (ZnO) вентилен отвод без искрови разрядници, за монтиране на закрито и открито, с трайно работно напрежение min 10,8 kV, с номинален разряден ток 10 kA, с разряден клас на линията 2, с полимерна изолационната обвивка, с принадлежности (аксесоари) за свързване между тоководещи части и земя. Конфигурацията на стрехите на полимерната изолационна обвивка съответстват на изискванията на IEC/TS 60815-3.

**Използване:**

Вентилният отвод е предназначен за използване в електроразпределителни мрежи с номинално напрежение 10 kV с изолирана неутрала, със заземена през дъгогасителна бобина неутрала, със заземена през активно съпротивление неутрала или с комбинирано заземяване на неутралата през дъгогасителна бобина и активно съпротивление.

**Съответствие на предлаганото изделие със стандартизационните документи:**

Вентилният отвод трябва да отговаря на приложимите български и международни стандарти, включително на посочените по-долу и на техните валидни изменения и поправки или еквиваленти:

- БДС EN 60099-4:2014 „Вентилни отводи. Част 4: Металооксидни вентилни отводи без разрядници за електрически системи за променливо напрежение (IEC 60099-4:2014)“; и
- IEC/TS 60815-3:2008 „Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 3: Polymer insulators for a.c. systems“.

**Изисквания към документацията и изпитванията:**

№ по ред	Наименование	Приложение № (или текст)
1.	Точно обозначение на типа, производителя и страна на произход	OSP2-12S-NFF; TYCO Electronics Raychem; Индия
2.	Техническо описание, гарантирани параметри, волт-секундна характеристика, използвани материали и принадлежности (аксесоари)	<u>Приложение 2.1.</u>
3.	Чертежи с размери и надлъжен разрез	<u>Приложение 2.4.</u>

---

C

C

№ по ред	Наименование	Приложение № (или текст)
4.	Протоколи от типови изпитвания на английски или български език, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	<u>Приложение 2.6.</u>
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4 – заверено копие	<u>Приложение 2.8.</u>
6.	Изисквания за транспортиране и манипулиране	<u>Приложение 2.9.</u>
7.	Инструкции за монтиране и за експлоатация и обслужване	<u>Приложение 2.10.</u>
8.	Експлоатационна дълготрайност, год.	>35 години

**Забележка:** Всички оригинални документи трябва да бъдат на български език или с превод на български език. Каталозите и изпитвателните протоколи могат да бъдат и само на английски език.

#### Технически данни:

##### 1. Характеристики на работната среда

№ по ред	Характеристика	Стойност
1.1	Място на монтиране	На открито/закрито
1.2	Максимална околна температура	+ 40°C
1.3	Минимална околна температура	Минус 25°C
1.4	Относителна влажност	До 100 %
1.5	Надморска височина	До 1000 m
1.6	Други работни условия	Съгласно т. 5.4.1 от БДС EN 60099-4

##### 2. Параметри на електроразпределителната мрежа

№ по ред	Параметър	Стойност
2.1	Номинално напрежение	10 000 V
2.2	Най-високо напрежение на съоръженията	12 000 V
2.3	Най-високо напрежение на системата	10 800 V
2.4	Номинална честота	50 Hz
2.5	Брой на фазите	3

---

C

C

2.6	Заземяване на звездния център	<ul style="list-style-type: none"> <li>• През дъгогасителна бобина;</li> <li>• изолиран звезден център;</li> <li>• през активно съпротивление;</li> <li>или</li> <li>• през дъгогасителна бобина комбинирана с активно съпротивление.</li> </ul>
2.7	Максимална стойност на временните пренапрежения (при земно съединение) / максимална продължителност на временните пренапрежения:	-
2.7a	заземяване през дъгогасителна бобина; или изолиран звезден център	11,8 kV/2 часа
2.7b	заземяване през активно съпротивление; или през дъгогасителна бобина комбинирана с активно съпротивление	10,8 kV/3 s
2.8	Изолационно ниво:	-
2.8a	Обявено издържано мълниев импулсно напрежение (върхова стойност)	75 kV
2.8b	Обявено краткотрайно (1 min) издържано напрежение с промишлена честота (50 Hz) (ефективна стойност)	28 kV
2.9	Ток на късо съединение в мястото на монтиране на вентилния отвод - максимален ток при трифазно късо съединение	15 kA

### 3. Свързване в системата и защитавани съоръжения

№ по ред	Наименование	Изискване
3.1	Свързване в системата	Между фаза и земя
3.2	Защитавани съоръжения	<ul style="list-style-type: none"> <li>• Разпределителни трансформатори 10/0,4 kV, свързани директно към въздушна електропроводна линия (ВЛ) или чрез присъединена към ВЛ кабелна линия;</li> <li>• кабелни линии 10 kV;</li> <li>• входове на разпределителните уредби;</li> <li>• КРУ в елегазова изолационна среда (GIS)</li> </ul>

### 4. Технически характеристики

№ по ред	Характеристика	Изискване	Гарантирано предложение
4.1	Обявено издържано напрежение при атмосферни пренапрежения 1,2/50 $\mu$ s	min 75 kV	106 kV
4.2	Обявено издържано 1 min напрежение с промишлена честота 50 Hz при мокра изолация	min 28 kV	47 kV



4.3	Ниво на частичните разряди при $1,05 U_c$	max 10 pC	>10 pC
4.4	Материал, от който е изработено нелинейното съпротивление (варистора)	ZnO	ZnO
4.5	Материал, от който е изработена изолационната обвивка	Полимер	Полимер
4.6	Материал, от който са изработени принадлежностите (аксесоарите)	Неръждаема стомана	да
4.7	Якост на опън	min 1 kN	2 kN
4.8	Якост на усукване	min 50 Nm	50 Nm
4.9	Якост на огъване	min 200 Nm	350 Nm

## 5. Принадлежности (аксесоари)

№ по ред	Наименование	Изискване	Гарантирано предложение
5.1	Аксесоари за присъединяване на вентилния отвод към тоководещи части и към заземителния контур	Резбови съединения (шпилки) с резба M12, съоръжени съответно с две гайки и две подложни шайби и средства срещу самоотвиване	да
5.2	Възможност на резбовите съединения за присъединяване на две кабелни обувки	Да	да

## 6. Технически параметри

№ по ред	Параметър	Изискване	Гарантирано предложение
6.1	Трайно работно напрежение, $U_c$	min 10,8 kV	12 kV
6.2	Обявено напрежение, $U_r$	min 13,5 kV	15 kV
6.3	Номинален разряден ток, $I_n$ ( 8/20 $\mu$ s )	10 kA	10 kA
6.4	Силнотокков импулс (4/10 $\mu$ s)	100 kA	100 kA
6.5	Разряден клас на линията	2	2
6.6	Устойчивост на ток на късо съединение	min 20 kA/0,2 s	40 kA
6.7	Остатъчно напрежение при номинален разряден ток $I_n$ , $U_{res}$	max 42 kV	38,9 kV
6.8	Устойчивост на продължителен токов импулс	min 250 A/2000 $\mu$ s	530 A/2 ms
6.9	Стойност на временните пренапрежения съгласно приложение D на БДС EN 60099-4:	-	-
6.9a	с продължителност 3 s	min 14 kV	16,6 kV
6.9b	с продължителност 100 s	min 13 kV	15,4 kV
6.9c	с продължителност 7200 s	min 11,8 kV	14,95





6.10	Изоляционно разстояние по повърхността	min 370 mm	384 mm
6.11	Височина без аксесоарите за присъединяване	max 350 mm	183 mm
6.12	Тегло, kg	Да се посочи	1,8 kg

**Наименование на материала:** Вентилен отвод метало-оксиден тип без искрови разрядници, 20 kV, 10 kA, клас 1

**Съкратено наименование на материала:** Вентилен отвод ZnO, 20 kV / 10 kA / клас 1

**Област:** В – Въздушни електропроводни линии СрН  
Н – Трансформаторни постове

**Категория:** 20 – Защита от пренапрежения

**Мерна единица:** Брой

**Аварийни запаси:** Да

**Характеристика на материала:**

Метало-оксиден (ZnO) вентилен отвод без искрови разрядници, за монтиране на закрито и открито, с трайно работно напрежение min 21,6 kV, с номинален разряден ток 10 kA, с разряден клас на линията 1, с полимерна изоляционната обвивка, с принадлежности (аксесоари) за свързване между тоководещи части и земя. Конфигурацията на стрехите на полимерната изоляционна обвивка съответстват на изискванията на IEC/TS 60815-3.

**Използване:**

Вентилният отвод е предназначен за използване в електроразпределителни мрежи с номинално напрежение 10 kV с изолирана неутрала, със заземена през дъгогасителна бобина неутрала, със заземена през активно съпротивление неутрала или с комбинирано заземяване на неутралата през дъгогасителна бобина и активно съпротивление в райони с интензивност на мълниеносната дейност до 100 часа годишно.

**Съответствие на предлаганото изделие със стандартизационните документи:**

Вентилният отвод трябва да отговаря на приложимите български и международни стандарти, включително на посочените по-долу и на техните валидни изменения и поправки или еквиваленти:

- БДС EN 60099-4:2014 „Вентилни отводи. Част 4: Металооксидни вентилни отводи без разрядници за електрически системи за променливо напрежение (IEC 60099-4:2014)“; и
- IEC/TS 60815-3:2008 „Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 3: Polymer insulators for a.c. systems“.

**Изисквания към документацията и изпитванията:**

№ по ред	Наименование	Приложение № (или текст)
1.	Точно обозначение на типа, производителя и страна на произход	DA1-27D-FOFONO; TYCO Electronics Raychem; Индия
2.	Техническо описание, гарантирани параметри, волт-секундна характеристика, използвани материали и принадлежности (аксесоари)	<u>Приложение 2.2.</u>

---

C

C

№ по ред	Наименование	Приложение № (или текст)
3.	Чертежи с размери и надлъжен разрез	<u>Приложение 2.5.</u>
4.	Протоколи от типови изпитвания на английски или български език, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	<u>Приложение 2.7.</u>
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4 – заверено копие	<u>Приложение 2.8.</u>
6.	Изисквания за транспортиране и манипулиране	<u>Приложение 2.9.</u>
7.	Инструкции за монтиране и за експлоатация и обслужване	<u>Приложение 2.10.</u>
8.	Експлоатационна дълготрайност, год.	>35 години

**Забележка:** Всички оригинални документи трябва да бъдат на български език или с превод на български език. Каталозите и изпитвателните протоколи могат да бъдат и само на английски език.

#### Технически данни:

##### 1. Характеристики на работната среда

№ по ред	Характеристика	Стойност
1.1	Място на монтиране	На открито/закрито
1.2	Максимална околна температура	+ 40°C
1.3	Минимална околна температура	Минус 25°C
1.4	Относителна влажност	До 100 %
1.5	Надморска височина	До 1000 m
1.6	Интензивност на мълниеносната дейност	До 100 часа годишно
1.7	Други работни условия	Съгласно т. 5.4.1 от БДС EN 60099-4

##### 2. Параметри на електроразпределителната мрежа

№ по ред	Параметър	Стойност
2.1	Номинално напрежение	20 000 V
2.2	Най-високо напрежение на съоръженията	24 000 V
2.3	Най-високо напрежение на системата	21 600 V
2.4	Номинална честота	50 Hz
2.5	Брой на фазите	3



№ по ред	Параметър	Стойност
2.6	Заземяване на звездния център	<ul style="list-style-type: none"> <li>• През дъгогасителна бобина;</li> <li>• изолиран звезден център;</li> <li>• през активно съпротивление; или</li> <li>• през дъгогасителна бобина комбинирана с активно съпротивление.</li> </ul>
2.7	Максимална стойност на временните пренапрежения (при земно съединение) / максимална продължителност на временните пренапрежения:	-
2.7a	заземяване през дъгогасителна бобина; или изолиран звезден център	23,7 kV/2 часа
2.7b	заземяване през активно съпротивление; или през дъгогасителна бобина комбинирана с активно съпротивление	21,6 kV/3 s
2.8	Изоляционно ниво:	-
2.8a	Обявено издържано мълниевое импулсно напрежение (върхова стойност)	125 kV
2.8b	Обявено краткотрайно (1 min) издържано напрежение с промишлена честота (50 Hz) (ефективна стойност)	50 kV
2.9	Ток на късо съединение в мястото на монтиране на вентилния отвод - максимален ток при трифазно късо съединение	15 kA

### 3. Свързване в системата и защитавани съоръжения

№ по ред	Наименование	Изискване
3.1	Свързване в системата	Между фаза и земя
3.2	Защитавани съоръжения	<ul style="list-style-type: none"> <li>• Разпределителни трансформатори 20/0,4 kV, свързани директно към въздушна електропроводна линия (ВЛ) или чрез присъединена към ВЛ кабелна линия;</li> <li>• кабелни линии 20 kV;</li> <li>• входове на разпределителните уредби;</li> <li>• КРУ в елегазова изолационна среда (GIS)</li> </ul>

### 4. Технически характеристики

№ по ред	Характеристика	Изискване	Гарантирано предложение
4.1	Обявено издържано напрежение при атмосферни пренапрежения 1,2/50 μs	min 125 kV	196 kV



4.2	Обявено издържано 1 min напрежение с промишлена честота 50 Hz при мокра изолация	min 50 kV	85 kV
4.3	Ниво на частичните разряди при $1,05 U_c$	max 10 pC	>10 pC
4.4	Материал, от който е изработено нелинейното съпротивление (варистора)	ZnO	ZnO
4.5	Материал, от който е изработена изолационната обвивка	Полимер	Полимер
4.6	Материал, от който са изработени принадлежностите (аксесоарите)	Неръждаема стомана	да
4.7	Якост на опън	min 1 kN	2 kN
4.8	Якост на усукване	min 50 Nm	50 Nm
4.9	Якост на огъване	min 200 Nm	350 Nm

## 5. Принадлежности (аксесоари)

№ по ред	Наименование	Изискване	Гарантирано предложение
5.1	Аксесоари за присъединяване на вентилния отвод към тоководещи части и към заземителния контур	Резбови съединения (шпилки) с резба M12, съоръжени съответно с две гайки и две подложни шайби и средства срещу самоотвиване	да
5.2	Възможност на резбовите съединения за присъединяване на две кабелни обувки	Да	да

## 6. Технически параметри

№ по ред	Параметър	Изискване	Гарантирано предложение
6.1	Трайно работно напрежение, $U_c$	min 21,6 kV	21,6 kV
6.2	Обявено напрежение, $U_r$	min 27 kV	27 kV
6.3	Номинален разряден ток, $I_n$ ( 8/20 $\mu$ s )	10 kA	10 kA
6.4	Силнотокъв импулс (4/10 $\mu$ s)	100 kA	100 kA
6.5	Разряден клас на линията	1	1
6.6	Устойчивост на ток на късо съединение	min 20 kA/0,2 s	21 kA / 0,2 s
6.7	Остатъчно напрежение при номинален разряден ток $I_n$ , $U_{res}$	max 80 kV	71,6 kV
6.8	Устойчивост на продължителен токов импулс	min 250 A/2000 $\mu$ s	325 A / 2 ms
6.9	Стойност на временните пренапрежения съгласно приложение D на БДС EN 60099-4:	-	-
6.9a	с продължителност 3 s	min 28 kV	30,65 kV





6.9b	с продължителност 100 s	min 25 kV	26,46 kC
6.9c	с продължителност 7200 s	min 23,7 kV	23,8 kV
6.10	Изолационно разстояние по повърхността	min 540 mm	627 mm
6.11	Височина без аксесоарите за присъединяване	max 350 mm	247 mm
6.12	Тегло, kg	Да се посочи	2,0 kg

**Наименование на материала:** Вентилен отвод метало-оксиден тип без искрови разрядници, 20 kV, 10 kA, клас 2

**Съкратено наименование на материала:** Вентилен отвод ZnO, 20 kV / 10 kA / клас 2

**Област:** В – Въздушни електропроводни линии СрН  
Н – Трансформаторни постове

**Категория:** 20 – Защита от пренапрежения

**Мерна единица:** Брой

**Аварийни запаси:** Да

**Характеристика на материала:**

Метало-оксиден (ZnO) вентилен отвод без искрови разрядници, за монтиране на закрито и открито, с трайно работно напрежение min 21,6 kV, с номинален разряден ток 10 kA, с разряден клас на линията 2, с полимерна изолационната обвивка, с принадлежности (аксесоари) за свързване между тоководещи части и земя. Конфигурацията на стрехите на полимерната изолационна обвивка съответстват на изискванията на IEC/TS 60815-3.

**Използване:**

Вентилният отвод е предназначен за използване в електроразпределителни мрежи с номинално напрежение 20 kV с изолирана неутрала, със заземена през дъгогасителна бобина неутрала, със заземена през активно съпротивление неутрала или с комбинирано заземяване на неутралата през дъгогасителна бобина и активно съпротивление в райони с интензивност на мълниеносната дейност над 100 часа годишно или с преобладаващ брой потребители с повишени изисквания за осигуреност на електроснабдяването.

**Съответствие на предлаганото изделие със стандартизационните документи:**

Вентилният отвод трябва да отговаря на приложимите български и международни стандарти, включително на посочените по-долу и на техните валидни изменения и поправки или еквиваленти:

- БДС EN 60099-4:2014 „Вентилни отводи. Част 4: Металооксидни вентилни отводи без разрядници за електрически системи за променливо напрежение (IEC 60099-4:2014)”; и
- IEC/TS 60815-3:2008 „Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 3: Polymer insulators for a.c. systems”.

**Изисквания към документацията и изпитванията:**

№ по ред	Наименование	Приложение № (или текст)
1.	Точно обозначение на типа, производителя и страна на произход	OCP2-22S-NFF; TYCO Electronics Raychem; Индия

---

C

C

№ по ред	Наименование	Приложение № (или текст)
2.	Техническо описание, гарантирани параметри, волт-секундна характеристика, използвани материали и принадлежности (аксесоари)	<u>Приложение 2.3.</u>
3.	Чертежи с размери и надлъжен разрез	<u>Приложение 2.4.</u>
4.	Протоколи от типови изпитвания на английски или български език, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	<u>Приложение 2.6.</u>
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4 – заверено копие	<u>Приложение 2.8.</u>
6.	Изисквания за транспортиране и манипулиране	<u>Приложение 2.9.</u>
7.	Инструкции за монтиране и за експлоатация и обслужване	<u>Приложение 2.10.</u>
8.	Експлоатационна дълготрайност, год.	>35 години

**Забележка:** Всички оригинални документи трябва да бъдат на български език или с превод на български език. Каталогите и изпитвателните протоколи могат да бъдат и само на английски език.  
**Технически данни:**

### 1. Характеристики на работната среда

№ по ред	Характеристика	Стойност
1.1	Място на монтиране	На открито/закрито
1.2	Максимална околна температура	+ 40°C
1.3	Минимална околна температура	Минус 25°C
1.4	Относителна влажност	До 100 %
1.5	Надморска височина	До 1000 m
1.6	Интензивност на мълниеносната дейност	Над 100 часа годишно
1.7	Други работни условия	Съгласно т. 5.4.1 от БДС EN 60099-4

### 2. Параметри на електроразпределителната мрежа

№ по ред	Параметър	Стойност
2.1	Номинално напрежение	20 000 V
2.2	Най-високо напрежение на съоръженията	24 000 V
2.3	Най-високо напрежение на системата	21 600 V



№ по ред	Параметър	Стойност
2.4	Номинална честота	50 Hz
2.5	Брой на фазите	3
2.6	Заземяване на звездния център	<ul style="list-style-type: none"> <li>• През дъгогасителна бобина;</li> <li>• изолиран звезден център;</li> <li>• през активно съпротивление;</li> <li>или</li> <li>• през дъгогасителна бобина комбинирана с активно съпротивление.</li> </ul>
2.7	Максимална стойност на временните пренапрежения (при земно съединение) / максимална продължителност на временните пренапрежения:	-
2.7a	заземяване през дъгогасителна бобина; или изолиран звезден център	23,7 kV/2 часа
2.7b	заземяване през активно съпротивление; или през дъгогасителна бобина комбинирана с активно съпротивление	21,6 kV/3 s
2.8	Изоляционно ниво:	-
2.8a	Обявено издържано мълниевое импулсно напрежение (върхова стойност)	125 kV
2.8b	Обявено краткотрайно (1 min) издържано напрежение с промишлена честота (50 Hz) (ефективна стойност)	50 kV
2.9	Ток на късо съединение в мястото на монтиране на вентилния отвод - максимален ток при трифазно късо съединение	15 kA

### 3. Свързване в системата и защитавани съоръжения

№ по ред	Наименование	Изискване
3.1	Свързване в системата	Между фаза и земя
3.2	Защитавани съоръжения	<ul style="list-style-type: none"> <li>• Разпределителни трансформатори 20/0,4 kV, свързани директно към въздушна електропроводна линия (ВЛ) или чрез присъединена към ВЛ кабелна линия;</li> <li>• кабелни линии 20 kV;</li> <li>• входове на разпределителните уредби;</li> <li>• КРУ в елегазова изолационна среда (GIS)</li> </ul>

### 4. Технически характеристики

№ по ред	Характеристика	Изискване	Гарантирано предложение

---

(

(

4.1	Обявено издържано напрежение при атмосферни пренапрежения 1,2/50 $\mu$ s	min 125 kV	180 kV
4.2	Обявено издържано 1 min напрежение с промишлена честота 50 Hz при мокра изолация	min 50 kV	80 kV
4.3	Ниво на частичните разряди при 1,05 $U_c$	max 10 pC	>10 pC
4.4	Материал, от който е изработено нелинейното съпротивление (варистор)	ZnO	ZnO
4.5	Материал, от който е изработена изолационната обвивка	Полимер	Полимер
4.6	Материал, от който са изработени принадлежностите (аксесоарите)	Неръждаема стомана	да
4.7	Якост на опън	min 1 kN	2 kN
4.8	Якост на усукване	min 50 Nm	50 Nm
4.9	Якост на огъване	min 200 Nm	350 Nm

## 5. Принадлежности (аксесоари)

№ по ред	Наименование	Изискване	Гарантирано предложение
5.1	Аксесоари за присъединяване на вентилния отвод към тоководещи части и към заземителния контур	Резбови съединения (шпилки) с резба M12, съоръжени съответно с две гайки и две подложни шайби и средства срещу самоотвиване	да
5.2	Възможност на резбовите съединения за присъединяване на две кабелни обувки	Да	да

## 6. Технически параметри

№ по ред	Параметър	Изискване	Гарантирано предложение
6.1	Трайно работно напрежение, $U_c$	min 21,6 kV	22 kV
6.2	Обявено напрежение, $U_r$	min 27 kV	27,5 kV
6.3	Номинален разряден ток, $I_n$ ( 8/20 $\mu$ s )	10 kA	10 kA
6.4	Силноток импулс (4/10 $\mu$ s)	100 kA	100 kA
6.5	Разряден клас на линията	2	2
6.6	Устойчивост на ток на късо съединение	min 20 kA/0,2 s	40 kA/0,2 s
6.7	Остатъчно напрежение при номинален разряден ток $I_n$ , $U_{res}$	max 75 kV	71,3 kV
6.8	Устойчивост на продължителен ток импулс	min 250 A/2000 $\mu$ s	530 A/2 ms

---



№ по ред	Параметър	Изискване	Гарантирано предложение
6.9	Стойност на временните пренапрежения съгласно приложение D на БДС EN 60099-4:	-	-
6.9a	с продължителност 3 s	min 28 kV	29,88 kV
6.9b	с продължителност 100 s	min 26 kV	28,2 kV
6.9c	с продължителност 7200 s	min 23,7 kV	23,71 kV
6.10	Изоляционно разстояние по повърхността	min 540 mm	758 mm
6.11	Височина без аксесоарите за присъединяване	max 425 mm	299 mm
6.12	Тегло, kg	Да се посочи	3,0 kg

Дата: 30.03.2018 г.

Декларатор:

На основание чл. 2  
от ЗЗЛД



Пълномощник на  
с нотариално  
5487/06.12.2017 на  
илова




---

C

C

*Приложение 2 към Техническо предложение*

**ИЗИСКВАНИ ДОКУМЕНТИ ОТ  
ТЕХНИЧЕСКИ ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ**





**Приложение 2 към Техническо предложение****ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ  
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 2.1.**




# Bowthorpe

# OCP Series

## Distribution Surge Arrester

Metal oxide arrester	Continuous operating voltage	<b>OCP2-12</b> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Polymeric Housing	<b>Uc: 12kV</b>	
IEC 60099-4, Ed 2.0	Rated voltage	Standard Creep S <input type="checkbox"/>
Nominal discharge current: 10kA	<b>Ur: 15kV</b>	Long Creepage L <input type="checkbox"/>
Line discharge class: 2	Outdoor application	Mounting <input type="checkbox"/>
High current impulse 4/10 $\mu$ s: 100kA	Rated short circuit current: 40 kA	Ground Lead <input type="checkbox"/>
Energy absorption capability at - Line discharge imp.: 6kJ/kV Uc	Low Current 600 A	Line Lead <input type="checkbox"/>
Long Duration Ipeak 530A	Non-shattering design	

### Dimensions



### Arrester Housing

		S	L
Impulse voltage	1,2/50 $\mu$ s kV	106	128
Power frequency voltage	-wet: kV	47	57
Overall length, (H)	mm	183	220
Flashover distance	mm	178	214
Creepage Length	mm	384	505
Weight	kg	1.8	1.8
No of Sheds:		5	7
Cantilever strength*	Nm	350	350
Pull strength*	N	2000	2000
Max. Torque M12*	Nm	50	50


- 100% Routine testing
- Residual Voltage
- Reference Voltage
- Partial Discharge

### Residual Voltages (kV)

Lightning current impulse 8/20 $\mu$ s			Steep lightning current impulse		Switching current impulse 30/60 $\mu$ s	
5 kA	10 kA	20 kA	10 kA	1/20 $\mu$ s	125 A	500 A
36.7	38.9	43.4	40.4		29.5	31.1

### Power frequency voltage versus time

1 Sec. TOV: 17.2 kV  
100 Sec. TOV: 15.4 kV



### Marking

#### Bowthorpe

MO Surge Arrester  
50/60 Hz  
IEC 60099-4  
Isc 40 kA  
In 10 kA Class 2  
OCP2-12  
Uc: 12 kV  
Ur: 15 kV  
Manufacturing Year


MVSA-118-000-39/04-1

For Technical Sales and Information please e-mail: [surgearresters@tycoelectronics.com](mailto:surgearresters@tycoelectronics.com) or telephone: +359 89 6059318 or +353 61 470846

Print Date:  
03/02/2005 17:15:12

ВЯРНО С ОРИГИНАЛА









**OCP series naming and order query description:**


**Example: OCP = "Open Cage Polymeric"**



System Voltage Um	ph/ph (a)	ph/ground (b)
12	185	165
24	315	295
36	445	425



**Line lead accessories**




**Arrester Type = Continuous Operating Voltage U<sub>c</sub> in kV**

OCP [ ] -	03 04 05 06
	08 09 10 12
	15 18 20 21
	22 24


OCP [ ] - 12 [ ] - [ ] [ ] [ ]

All accessories use M12 stainless steel studs

**Mounting accessories**



**Ground lead accessories**





Additional accessory options available on request. Please contact: [surgearresters@tycoelectronics.com](mailto:surgearresters@tycoelectronics.com) with specific requirement.

ВЯРНО С ОРИГИНАЛА






**Приложение 2 към Техническо предложение****ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ  
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 2.2.**



# Bowthorpe EMP Distribution Surge Arrester

# DA Series (IEC)

**Zinc Oxide Arrester (Standard IEC 60099-4, Ed 2.1)**  
**DA Voltage range** 4 – 45 kV  
**Rated Voltage** 27 kV  
**Continuous Operating Voltage** 21.6 kV



**DA<sup>1</sup> 1<sup>2</sup> -27<sup>3</sup> D<sup>4</sup> -LL<sup>5</sup> EE<sup>6</sup> MM<sup>7</sup>**


- <sup>1</sup> Distribution Arrester
- <sup>2</sup> Class
- <sup>3</sup> Rated Voltage - U<sub>R</sub>
- <sup>4</sup> Housing creepage code
- <sup>5</sup> Line lead accessory
- <sup>6</sup> Earth lead accessory
- <sup>7</sup> Mounting accessory

Main Features		Arrester Housing - D **		Unit	
Housing	Silicone	Impulse voltage 1.2/50 µs	kV	196	
Nominal discharge current - I <sub>n</sub>	10 kA (8/20 µs)	Power frequency voltage - wet	kV	85	
Line discharge class:	1	Overall length (H)	mm	247	
High current impulse	100 kA (4/10 µs)	Flashover distance	mm	252	
Energy Absorption Capability:		Creepage Length	mm	627	
(IEC 60099-4, clause 8.5)	5.6 kJ/kV	Weight	kg	2.0	
Long duration current Imp.	325 A (2000 µs)	No of Sheds		8	
Short circuit rating (pre-failing method):		Cantilever strength *	Nm	350	
Rated short-circuit I <sub>sc</sub>	21 kA (0.2 s)	Pull strength	N	2000	
Low short-circuit current	600 A (1.0 s)	Max. Torque M12 *	Nm	50	
<ul style="list-style-type: none"> <li>Safe non-shattering design</li> <li>Suitable for installation in polluted environments</li> <li>Silicone directly moulded onto the core</li> </ul>		* Ref: Thermo-mechanical & bending moment test 60099-4 ** Other housing sizes available – Please contact Product Management 100% Routine testing: Residual Voltage, Reference Voltage, PD.			


Residual Voltages (kV)					
Lightning current impulse 8/20 µs:			Steep lightning current impulse 1/20 µs:	Switching current impulse 30/60 µs:	
5 kA	10 kA	20 kA	10 kA	125 A	500 A
67.2	71.6	78.4	75.2	53.8	56.9

Power frequency voltage versus time

1 s. TOV: 29.70 kV  
 100 s. TOV: 26.46 kV




Marking



All of the above information, including drawings, illustrations and graphic designs, reflects our present understanding and is to the best of our knowledge and belief correct and reliable. Users, however, should independently evaluate the suitability of each product for the desired application. Under no circumstances does this constitute an assurance of any particular quality or performance. Such an assurance is only provided in the context of our product specifications or explicit contractual arrangements. Our liability for these products is set forth in our standard terms and conditions of sale. BOWTHORPE EMP, TE logo and Tyco Electronics are trademarks.

For Technical and Sales Information please e-mail: [surgearresters@tycoelectronics.com](mailto:surgearresters@tycoelectronics.com) or visit <http://energy.tycoelectronics.com>

Energy Division





# DAX series arrester ordering information and accessory selection table:




## Naming convention cross reference:

ZZZ = series type: DAO for 5kA arrester; DA1 for 10kA, class1 arrester.

YY = Ur

M = Housing code

### 1 Line lead accessories




Bxxxx	Exxxx	Fxxxx	Hxxxx	Mxxxx	Oxxxx	Pxxxx	Qxxxx
Birdcap with F accessory	Birdcap with M accessory	Std Washers for Lug-45mm Stud	Cap screw & Spring Washer	Star Washers for 45mm Stud	No Stud. No Accessories	S-Clamp	L-Clamp

### 2 Line lead options

x0xxxx	No Line Lead Wire
x1xxxx	0.5m 16sq Copper Line Lead & 1-off M12 lug
x2xxxx	1m 16sq Copper Line Lead & 1-off M12 lug
x3xxxx	1m 16sq Copper Line Lead & no lug
x4xxxx	0.5m 35sq Copper Line Lead & 1-off M12 lug
x5xxxx	1m 35sq Copper Line Lead & 1-off M12 lug
x6xxxx	1m 35sq Copper Line Lead & no lug

### Ground lead accessories:




xxDxxx	xxExxx	xxFxxx	xxHxxx	xxMxxx	xxOxxx
Disconnect + M accessory	Disconnect + F accessory	Std Washers for Lug-45mm Stud	M12*25 Cap screw & Spring Washer	Star Washers for 45mm Stud	No Stud. No Accessories

### Ground lead options

xxx0xx	No Line Lead Wire
xxx1xx	0.5m 16sq Copper Line Lead & 1-off M12 lug
xxx2xx	1m 16sq Copper Line Lead & 1-off M12 lug
xxx3xx	1m 16sq Copper Line Lead & no lug
xxx4xx	0.5m 35sq Copper Line Lead & 1-off M12 lug
xxx5xx	1m 35sq Copper Line Lead & 1-off M12 lug
xxx6xx	1m 35sq Copper Line Lead & no lug

### 5 Mounting brackets:



xxxxAx	xxxxBx	xxxxEx	xxxxNx	xxxxPx	xxxxx0	xxxxx1	xxxxx6
Straight 2 hole Mounting Bracket	Insulating bracket	DIN metal bracket, (galvanised)	No Mounting Accessories	Pedestal Mounting Base (Siemens equivalent)	No Option	Metric Nema Cross Arm Bracket	T - mounting bracket

### Packaging

I	Individual Packing (as standard)
S	Standard 3 Pack, (with accessories loose in boxes)
B	Bulk Packing

ВАРНО С ОРИГИНАЛ:









*Приложение 2 към Техническо предложение*

**ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ  
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ**

**Приложение 2.3.**






## Distribution Surge Arrester

Metal oxide arrester	Continuous operating voltage	<b>OCP2-22</b> <input type="checkbox"/> - <input type="checkbox"/> <input type="checkbox"/>
Polymeric Housing	<b>Uc: 22kV</b>	
IEC 60099-4, Ed 2.0	Rated voltage	
Nominal discharge current: 10kA	<b>Ur: 27.5kV</b>	Standard Creep S <input type="checkbox"/>
Line discharge class: 2	Outdoor application	Long Creepage L <input type="checkbox"/>
High current impulse 4/10 $\mu$ s: 100kA	Rated short circuit current: 40 kA	Mounting <input type="checkbox"/>
Energy absorption capability at	Low Current 600 A	Ground Lead <input type="checkbox"/>
- Line discharge imp.: 6kJ/kV Uc	Non-shattering design	Line Lead <input type="checkbox"/>
Long Duration Ipeak 530A		

### Dimensions



### Arrester Housing

		S	L
Impulse voltage	1,2/50 $\mu$ s kV	180	205
Power frequency voltage	-wet: kV	80	91
Overall length, (H)	mm	299	340
Flashover distance	mm	293	334
Creepage Length	mm	758	885
Weight	kg	3	3.5
No of Sheds:		11	13
Cantilever strength*	Nm	350	350
Pull strength*	N	2000	2000
Max. Torque M12*	Nm	50	50

#### 100% Routine testing


- Residual Voltage
- Reference Voltage
- Partial Discharge

### Residual Voltages (kV)

Lightning current impulse 8/20 $\mu$ s			Steep lightning current impulse		Switching current impulse 30/60 $\mu$ s	
5 kA	10 kA	20 kA	10 kA	1/20 $\mu$ s	125 A	500 A
67.3	71.3	79.5	74.1		54.1	56.9

### Power frequency voltage versus time

1 Sec. TOV: 31.5 kV  
100 Sec. TOV: 28.2 kV



### Marking

#### Bowthorpe

MO Surge Arrester  
50/60 Hz  
IEC 60099-4  
Isc 40 kA  
In 10 kA Class 2  
OCP2-22  
Uc: 22 kV  
Ur: 28 kV  
Manufacturing Year

MVSA-123-000-39/04-1

For Technical Sales and Information please e-mail: [surgearresters@tycoelectronics.com](mailto:surgearresters@tycoelectronics.com) or telephone: +49 89 6089378 or +353 61 470846

Print Date:  
03/02/2005 17:15:12


ВЯРНО С ОРИГИНАЛА






**OCP series naming and order query description:**


**Example: OCP = "Open Cage Polymeric"**



System Voltage Um	ph/ph (a)	ph/ground (b)
12	185	165
24	315	295
36	445	425



**Line lead accessories**




**Arrester Type = Continuous Operating Voltage U<sub>c</sub> in kV**

OCP [ ] -	03 04 05 06
	08 09 10 12
	15 18 20 21
	22 24


OCP [ ] - 12 [ ] - [ ] [ ]

All accessories use M12 stainless steel studs

**Mounting accessories**



**Ground lead accessories**



Additional accessory options available on request. Please contact: [surgearresters@tycoelectronics.com](mailto:surgearresters@tycoelectronics.com) with your specific requirement.




**Приложение 2 към Техническо предложение**

**ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ  
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ**


**Приложение 2.4.**







*Handwritten signature*



SCD

SEE NOTE

DIM A ± 5

DIM B ± 5

NOTE:-  
 CANT. STRENGTH = 350NMT  
 TENSION STRENGTH = 28K  
 TORQUE = 50NMT  
 HIGH SHORT CIRCUIT = 40KA  
 LOW SHORT CIRCUIT = 60KA  
 STD STUD LENGTH = 55±2mm. OTHER LENGTHS  
 AVAILABLE DEPENDING ON ACCESSORY SELECTION  
 SEE DRG NO MV-CCP2-00085-S FOR HOUSING PRINT

NO	SHEDS	GREYPAGE	DRY ARC DIST
5	380	176	
7	505	214	
9	632	254	
11	758	293	
13	885	334	

REV	DATE	SIGN	MODIFICATION
0	11/24/81	SM	ORIGINAL ISSUE

**tupo**  
ELECTRONICS

ENERGY DIVISION

Bowdler EMP

DESIGNED BY	DATE	CHKD BY	DATE	APP'D BY	DATE
SCALE	1:1	NO. OF SHEETS	105	TOTAL SHEETS	105
TITLE	MV SURGE ARRESTER OCP2 RANGE				
PROJECT NO.	44-0029-0007-5				
SHEET NO.	5				




PRODUCT	SHEDS	DIM A	DIM B	TEXT V	TEXT W	TEXT X	TEXT Y	TEXT Z
CCP2-035	5	183	176	CCP2-035 In 10KA Class 2	Uc 3KV	Uc 3.75KV	Uc 3.75KV	1sc 40KA
CCP2-038	7	229	212	CCP2-038 In 10KA Class 2	Uc 3KV	Uc 3.75KV	Uc 3.75KV	1sc 40KA
CCP2-043	5	183	176	CCP2-043 In 10KA Class 2	Uc 4KV	Uc 5KV	Uc 5KV	1sc 40KA
CCP2-046	7	229	212	CCP2-046 In 10KA Class 2	Uc 4KV	Uc 5KV	Uc 5KV	1sc 40KA
CCP2-055	5	183	176	CCP2-055 In 10KA Class 2	Uc 5KV	Uc 6.25KV	Uc 6.25KV	1sc 40KA
CCP2-058	7	229	212	CCP2-058 In 10KA Class 2	Uc 5KV	Uc 6.25KV	Uc 6.25KV	1sc 40KA
CCP2-065	5	183	176	CCP2-065 In 10KA Class 2	Uc 6KV	Uc 7.5KV	Uc 7.5KV	1sc 40KA
CCP2-068	7	229	212	CCP2-068 In 10KA Class 2	Uc 6KV	Uc 7.5KV	Uc 7.5KV	1sc 40KA
CCP2-085	5	183	176	CCP2-085 In 10KA Class 2	Uc 8KV	Uc 10KV	Uc 10KV	1sc 40KA
CCP2-088	7	229	212	CCP2-088 In 10KA Class 2	Uc 8KV	Uc 10KV	Uc 10KV	1sc 40KA
CCP2-095	5	183	176	CCP2-095 In 10KA Class 2	Uc 9KV	Uc 11.25KV	Uc 11.25KV	1sc 40KA
CCP2-098	7	229	212	CCP2-098 In 10KA Class 2	Uc 9KV	Uc 11.25KV	Uc 11.25KV	1sc 40KA
CCP2-105	5	183	176	CCP2-105 In 10KA Class 2	Uc 10KV	Uc 12.5KV	Uc 12.5KV	1sc 40KA
CCP2-108	7	229	212	CCP2-108 In 10KA Class 2	Uc 10KV	Uc 12.5KV	Uc 12.5KV	1sc 40KA
CCP2-125	5	183	176	CCP2-125 In 10KA Class 2	Uc 12KV	Uc 15KV	Uc 15KV	1sc 40KA
CCP2-128	7	229	212	CCP2-128 In 10KA Class 2	Uc 12KV	Uc 15KV	Uc 15KV	1sc 40KA
CCP2-135	5	183	176	CCP2-135 In 10KA Class 2	Uc 15KV	Uc 18.75KV	Uc 18.75KV	1sc 40KA
CCP2-138	7	229	212	CCP2-138 In 10KA Class 2	Uc 15KV	Uc 18.75KV	Uc 18.75KV	1sc 40KA
CCP2-151	9	260	252	CCP2-151 In 10KA Class 2	Uc 15KV	Uc 18.75KV	Uc 18.75KV	1sc 40KA
CCP2-155	9	260	252	CCP2-155 In 10KA Class 2	Uc 18KV	Uc 22.5KV	Uc 22.5KV	1sc 40KA
CCP2-181	11	299	291	CCP2-181 In 10KA Class 2	Uc 18KV	Uc 22.5KV	Uc 22.5KV	1sc 40KA
CCP2-185	9	260	252	CCP2-185 In 10KA Class 2	Uc 18KV	Uc 22.5KV	Uc 22.5KV	1sc 40KA
CCP2-191	11	299	291	CCP2-191 In 10KA Class 2	Uc 20KV	Uc 23.75KV	Uc 23.75KV	1sc 40KA
CCP2-205	9	260	252	CCP2-205 In 10KA Class 2	Uc 20KV	Uc 23.75KV	Uc 23.75KV	1sc 40KA
CCP2-201	11	299	291	CCP2-201 In 10KA Class 2	Uc 20KV	Uc 25KV	Uc 25KV	1sc 40KA
CCP2-211	11	299	291	CCP2-211 In 10KA Class 2	Uc 21KV	Uc 26.25KV	Uc 26.25KV	1sc 40KA
CCP2-214	13	340	332	CCP2-214 In 10KA Class 2	Uc 21KV	Uc 26.25KV	Uc 26.25KV	1sc 40KA
CCP2-225	11	299	291	CCP2-225 In 10KA Class 2	Uc 22KV	Uc 27.5KV	Uc 27.5KV	1sc 40KA
CCP2-221	13	340	332	CCP2-221 In 10KA Class 2	Uc 22KV	Uc 27.5KV	Uc 27.5KV	1sc 40KA
CCP2-241	11	299	291	CCP2-241 In 10KA Class 2	Uc 24KV	Uc 30KV	Uc 30KV	1sc 40KA
CCP2-241	13	340	332	CCP2-241 In 10KA Class 2	Uc 24KV	Uc 30KV	Uc 30KV	1sc 40KA

ВЯРНО С ОРИГИНАЛА



АКЦИДЕНТЕН  
 ФИЛКАТЪ  
 16  
 ПЛОВДИ



SCD



*Handwritten signature or initials.*



NOTES -  
 Bawhorpe text font Univers 85 Extra Black Oblique  
 All remaining text font Arial  
 All print 0.25mm high

<b>ENERGY DIVISION</b>			<b>ENERGY DIVISION</b>	
<b>TEPCO ELECTRONICS</b>			<b>Bawhorpe EMBP</b>	
REV	DATE	SIGN	MODIFICATION	APP
0	12/04	JM	ORIGINAL ISSUE	

DIM	INCLUDES	STATION	REV	DATE
0000	0	000000	1/03	JM
APP	BY	DATE	SCALE	
			1:1	
THIS DRAWING AND THE INFORMATION ON IT (COPY OR NOT) ARE THE PROPERTY OF TEPCO ELECTRONICS INC. ANY USE BY YOU OR YOUR COMPANY WITHOUT THE WRITTEN PERMISSION OF TEPCO ELECTRONICS INC. IS STRICTLY PROHIBITED. THIS DRAWING IS UNCONTROLLED. THE LATEST REVISIONS ARE THE ONLY VALID ONES FOR FABRICATION.				
TITLE			DWG NO	SHEET OF
MV SURGE ARRESTER			MP-2071-4003-S	1
OCP2 RANGE				0

ВАРНО С ОРИГИНАЛА





*Приложение 2 към Техническо предложение*


**ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ  
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ**

**Приложение 2.5.**





SCD


PRODUCT	TEXT A	TEXT B	TEXT C	TEXT D	TEXT E
DAI-04A	DAI-04A	Uc 3.2kV	Ur 4kV	YEAR	XXXX
DAI-06A	DAI-06A	Uc 4.8kV	Ur 6kV	YEAR	XXXX
DAI-08A	DAI-08A	Uc 6.4kV	Ur 8kV	YEAR	XXXX
DAI-10A	DAI-10A	Uc 8kV	Ur 10kV	YEAR	XXXX
DAI-12A	DAI-12A	Uc 9.6kV	Ur 12kV	YEAR	XXXX



*Handwritten signature*



DETAIL A  
SCALE 3:2



TENSILE STRENGTH = 350Nm  
 TORSION STRENGTH = 2kN  
 TORQUE = 50Nm  
 HIGH SHORT CIRCUIT = 21kA  
 LOW SHORT CIRCUIT 600A  
 CREEP AGE = 329  
 DRY ARC DISTANCE = 152  
 STD. TUD LENGTH 45±2. OTHER LENGTHS  
 AVAILABLE DEPENDING ON ACCESSORY SELECTION  
 ALL DIMS IN mm  
 SEE DRAWING No MV-DAI-00436-S FOR LABEL PRINT

**Tyco Electronics**  
 BAY 100-05  
 SHANNON IND. EST.  
 SHANNON  
 CO. CLARE  
 IRELAND

**Surge Arrester**

DATE: 08/07  
 DRAWN: JM  
 CHECKED: [Signature]  
 APP: [Signature]  
 PCB: [Signature]

REV. DATE. SIGN. MODIFICATION. APP.

IEC MV SURGE ARRESTER  
 DAI - X X A RANGE

REV. DATE. SIGN. MODIFICATION. APP.


ВЯРНО С ОРИГИНАЛА

ФИЛКАЕ  
 16  
 \*ОБЩЕСТВО С ОГРАНИЧЕНА ОТГОВОРНОСТ\*








PRODUCT	TEXT A	TEXT B	TEXT C	TEXT D	TEXT E
DAI-04B	DAI-04B	Uc 3.2kV	Ur 4kV	YEAR	XXXX
DAI-06B	DAI-06B	Uc 4.8kV	Ur 6kV	YEAR	XXXX
DAI-08B	DAI-08B	Uc 6.4kV	Ur 8kV	YEAR	XXXX
DAI-10B	DAI-10B	Uc 8kV	Ur 10kV	YEAR	XXXX
DAI-12B	DAI-12B	Uc 9.6kV	Ur 12kV	YEAR	XXXX
DAI-15B	DAI-15B	Uc 12kV	Ur 15kV	YEAR	XXXX



*Handwritten signature*



DETAIL A  
SCALE 3:2



CANT. STRENGTH = 350Nm  
TENSION STRENGTH = 2kN  
TORQUE = 50Nm  
HIGH SHORT CIRCUIT = 21kA  
LOW SHORT CIRCUIT 600A  
CREEPAGE = 404mm  
DRY ARC DISTANCE = 177mm  
STD STUD LENGTH 45±2. OTHER LENGTHS AVAILABLE DEPENDING ON ACCESSORY SELECTION  
ALL DIMS IN mm  
DRAWING No MV-DAI-00436-S FOR LABEL PRINT

**Tyco Electronics**  
Bondrops Surge Arresters

DAI 100-105  
SHANNON IND. EST.  
CO. CLARE  
IRELAND


DATE	REV	BY	CHKD	APP	PCN	SEE ABOVE	REV NO	MV-DAI-00429-S	SHEET OF 1	0
------	-----	----	------	-----	-----	-----------	--------	----------------	------------	---

IEC MV SURGE ARRESTER  
DAI-xxB RANGE





REV	DATE	SIGN	MODIFICATION	APP
0	09/07	JH	ORIGINAL ISSUE	

ВЯРНО С ОРИГИНАЛА





PRODUCT	TEXT A	TEXT B	TEXT C	TEXT D	TEXT E
DAI-08C	DAI-08C	Uc 6.4kV	Ur 8kV	YEAR	XXXX
DAI-10C	DAI-10C	Uc 8kV	Ur 10kV	YEAR	XXXX
DAI-12C	DAI-12C	Uc 9.6kV	Ur 12kV	YEAR	XXXX
DAI-15C	DAI-15C	Uc 12kV	Ur 15kV	YEAR	XXXX
DAI-18C	DAI-18C	Uc 14.4kV	Ur 18kV	YEAR	XXXX
DAI-21C	DAI-21C	Uc 16.8kV	Ur 21kV	YEAR	XXXX
DAI-22C	DAI-22C	Uc 17.6kV	Ur 22kV	YEAR	XXXX



CANT. STRENGTH = 350Nm  
 TENSION STRENGTH = 2kN  
 TORQUE = 50Nm  
 HIGH SHORT CIRCUIT = 21kA  
 LOW SHORT CIRCUIT 600A  
 CREEPAGE = 55.3mm  
 DRY ARC DISTANCE = 227mm  
 STD STUD LENGTH 45±2. OTHER LENGTHS  
 AVAILABLE DEPENDING ON ACCESSORY SELECTION  
 ALL DIMS IN mm  
 DRAWING NO MV-DAI-00436-S FOR LABEL PRINT

DETAIL A  
 SCALE 3:2

**Tyco Electronics**  
 BAY 100-105  
 SHANNON IND. EST.  
 SHANNON CO. IRELAND

**Surge Arrester**

DATE: 09/07  
 DRAWN: JM  
 CHECKED: PAT F116  
 APP: [Signature]  
 FOR: SEE ABOVE

REV 0 DATE 09/07 JM ORIGINAL ISSUE

REV DATE SIGN MODIFICATION APP

TITLE: IEC MV SURGE ARRESTER DAI-XXC RANGE

FIG NO: MV-DAI-00436-S

SHEET: 01 OF 1

ВЯРНО С ОРИГИНАЛА








SCD

PRODUCT	TEXT A	TEXT B	TEXT C	TEXT D	TEXT E
DAI-150	DAI-150	Uc 12kV	Ur 15kV	YEAR	XXXX
DAI-180	DAI-180	Uc 14.4kV	Ur 18kV	YEAR	XXXX
DAI-210	DAI-210	Uc 16.8kV	Ur 21kV	YEAR	XXXX
DAI-220	DAI-220	Uc 17.6kV	Ur 22kV	YEAR	XXXX


*Handwritten signature*



SEE DETAIL A



DETAIL A  
SCALE 3:2



*Handwritten signature*

CANT. STRENGTH = 350Nm  
TENSION STRENGTH = 2KN  
TORQUE = 50Nm  
HIGH SHORT CIRCUIT = 21kA  
LOW SHORT CIRCUIT 600A  
CREEPAGE = 627mm  
DRY ARCL DISTANCE = 252mm  
STD STUD LENGTH 45±2. OTHER LENGTHS AVAILABLE DEPENDING ON ACCESSORY SELECTION  
ALL DIMS IN mm  
SEE DRAWING No MV-DAI-00436-S FOR LABEL PRINT

ВЯРНО С ОРИГИНАЛА




<b>Tyco Electronics</b>		Bwthorpe Surge Arrester	
<small>THE DRAWING IS THE PROPERTY OF TYCO ELECTRONICS LTD. IT IS TO BE USED FOR THE MANUFACTURE OF THE PRODUCT ONLY. IT IS NOT TO BE REPRODUCED, COPIED, EITHER WHOLLY OR IN PART, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM. ANY UNAUTHORIZED USE OF THIS DRAWING IS PROHIBITED.</small>		DATE	BY
CHECKED	PAT FILING		
APP'D	BY		
REV	DATE	SIGN	MODIFICATION
REV	DATE	SIGN	MODIFICATION
REV	DATE	SIGN	MODIFICATION

BAY 100-105  
 SHANNON IND. EST.  
 SHANNON  
 CO. CLARE  
 IRELAND



IEC MV SURGE ARRESTER  
 DAI - X XD RANGE

NO 900  
 MV-DAI-00436-S  
 SHEETS OF 1





SCD

PRODUCT	TEXT A	TEXT B	TEXT C	TEXT D	TEXT E
DAI-18E	DAI-18E	Uc 14.4kV Ur 18kV	YEAR	XXXX	XXXX
DAI-21E	DAI-21E	Uc 16.8kV Ur 21kV	YEAR	XXXX	XXXX
DAI-22E	DAI-22E	Uc 17.6kV Ur 22kV	YEAR	XXXX	XXXX
DAI-24E	DAI-24E	Uc 19.2kV Ur 24kV	YEAR	XXXX	XXXX



DETAIL A  
SCALE 3:2



CANT. STRENGTH = 350Nm  
TENSION STRENGTH = 2kN  
TORQUE = 50Nm  
HIGH SHORT CIRCUIT = 21kA  
LOW SHORT CIRCUIT 600A  
CREEPAGE = 702mm  
DRY ARC DISTANCE = 277mm  
STD STUD LENGTH 45±2. OTHER LENGTHS AVAILABLE DEPENDING ON ACCESSORY SELECTION  
ALL DIMS IN mm  
SEE DRAWING No MV-DAI-00436-S FOR LABEL PRINT

**Tyco Electronics**  
Boretope Surge Arrester

DAI 100-105 SHANNON IND. EST. CO. CLARE IRELAND

REV	DATE	SIGN	MODIFICATION	APP

IEC MV SURGE ARRESTER  
DAI - x x E RANGE

DRW NO: MV-DAI-00436-S  
SHEET 1 OF 1

ВАРНО С ОРИГИНАЛА




AKЦИОНЕРНО  
ФИЛКАБ  
16  
ПЛОВДИВ






SCD

PRODUCT	TEXT A	TEXT B	TEXT C	TEXT D	TEXT E
DAI-18F	DAI-18F	Uc 14.4kV	Ur 18kV	YEAR	XXXX
DAI-21F	DAI-21F	Uc 16.8kV	Ur 21kV	YEAR	XXXX
DAI-22F	DAI-22F	Uc 17.6kV	Ur 22kV	YEAR	XXXX
DAI-24F	DAI-24F	Uc 19.2kV	Ur 24kV	YEAR	XXXX
DAI-27F	DAI-27F	Uc 21.6kV	Ur 27kV	YEAR	XXXX
DAI-30F	DAI-30F	Uc 24kV	Ur 30kV	YEAR	XXXX



DETAIL A  
SCALE 3:2



CANT. STRENGTH = 350mm  
TENSION STRENGTH = 2kN  
TORQUE = 50Nm  
HIGH SHORT CIRCUIT = 21kA  
LOW SHORT CIRCUIT 600A  
CREEPAGE = 776mm  
DRY ARC DISTANCE = 302mm  
STD STUD LENGTH 45±2mm. OTHER LENGTHS  
AVAILABLE DEPENDING ON ACCESSORY SELECTION.  
SEE DRAWING No MV-DAI-00436-S FOR LABEL PRINT

**Tyco Electronics**  
Surge EHP Surge Arresters

DAI - MV SURGE ARRESTER  
DAI - XXF RANGE

REV: 0 DATE: 09/07 SIGN: JK ORIGINAL ISSUE APP: [ ]  
REV: [ ] DATE: [ ] SIGN: [ ] ORIGINAL ISSUE APP: [ ]  
REV: [ ] DATE: [ ] SIGN: [ ] ORIGINAL ISSUE APP: [ ]

DRW: [ ] CHECK: [ ] APP: [ ]  
MATERIALS: [ ]  
MFG: [ ]  
DATE: [ ]

DATE: 09/07  
SCALE: 3:2  
SHEET: 1 OF 1


ВЯРНО С ОРИГИНАЛА





SCD



PRODUCT	TEXT A	TEXT B	TEXT C	TEXT D	TEXT E
DAI-24G	DAI-24G	Uc 19.2kV	Ur 24kV	YEAR	XXXX
DAI-27G	DAI-27G	Uc 21.6kV	Ur 27kV	YEAR	XXXX
DAI-30G	DAI-30G	Uc 24kV	Ur 30kV	YEAR	XXXX
DAI-33G	DAI-33G	Uc 26.4kV	Ur 33kV	YEAR	XXXX
DAI-36G	DAI-36G	Uc 28.8kV	Ur 36kV	YEAR	XXXX




SEE NOTE

SEE NOTE

SEE DETAIL A



DETAIL A  
SCALE 3:2




CANT. STRENGTH = 350Nm  
TENSION STRENGTH = 2kN  
TORQUE = 50Nm  
HIGH SHORT CIRCUIT = 21kA  
LOW SHORT CIRCUIT 600A  
CREEPAGE = 925mm  
DRY ARC DISTANCE = 352mm  
STD. STUD LENGTH 45±2. OTHER LENGTHS AVAILABLE DEPENDING ON ACCESSORY SELECTION  
ALL DIMS IN mm  
SEE DRAWING No MV-DAI-00436-S FOR LABEL PRINT

Tyco Electronics Bowthorpe Surge Arrester		DRAWING NO: MV-DAI-00436-S		SHEET 1 OF 1	
CLASS 1		IEC 99-4		DAI - x x G RANGE	
Ic 21kA		Lot No		APP: MK	
Ic 10kA		TEXT E		CHECKED: R	
BOWTHORPE NZ		TEXT A		DESIGNED: M/M	
TEXT B		TEXT C		DATE: 09/2007	
TEXT D		TEXT E		SIGNATURE: [Signature]	
TEXT E		TEXT A		DATE: 09/2007	
TEXT A		TEXT B		SIGNATURE: [Signature]	
TEXT B		TEXT C		DATE: 09/2007	
TEXT C		TEXT D		SIGNATURE: [Signature]	
TEXT D		TEXT E		DATE: 09/2007	
TEXT E		TEXT A		SIGNATURE: [Signature]	
TEXT A		TEXT B		DATE: 09/2007	
TEXT B		TEXT C		SIGNATURE: [Signature]	
TEXT C		TEXT D		DATE: 09/2007	
TEXT D		TEXT E		SIGNATURE: [Signature]	
TEXT E		TEXT A		DATE: 09/2007	



ВЕРНО С ОРИГИНАЛА






SCD

PRODUCT	TEXT A	TEXT B	TEXT C	TEXT D	TEXT E
DAI-27H	DAI-27H	Uc 21.6kV	Ur 27kV	YEAR	XXXX
DAI-30H	DAI-30H	Uc 24kV	Ur 30kV	YEAR	XXXX
DAI-33H	DAI-33H	Uc 26.4kV	Ur 33kV	YEAR	XXXX
DAI-36H	DAI-36H	Uc 28.8kV	Ur 36kV	YEAR	XXXX
DAI-39H	DAI-39H	Uc 31.2kV	Ur 39kV	YEAR	XXXX
DAI-42H	DAI-42H	Uc 33.6kV	Ur 42kV	YEAR	XXXX
DAI-45H	DAI-45H	Uc 36kV	Ur 45kV	YEAR	XXXX



DETAIL A  
SCALE 3:2



CANT. STRENGTH = 350Nm  
TENSION STRENGTH = 2kN  
TORQUE = 50Nm  
HIGH SHORT CIRCUIT = 21kA  
LOW SHORT CIRCUIT 600A  
CREFRAGE = 107.4mm  
DRY ARC DISTANCE = 402mm  
STD STUD LENGTH 45±2. OTHER LENGTHS  
AVAILABLE DEPENDING ON ACCESSORY SELECTION  
ALL DIMS IN mm  
SEE DRAWING No MV-DAI-00436-S FOR LABEL PRINT

ВЯРНО С ОРИГИНАЛА

**Tyco Electronics**  
Shannon Ind. Est.  
Shannon Co. Clare  
Ireland

Electronics Surge Arresters

DATE: 09/07  
REV: 01  
SIGN: JN  
APP: [Signature]

TITLE: IEC MV SURGE ARRESTER DAI-xH RANGE

DRN: MULLOOLAN/27/09/07  
CHKR: P.V.  
APP: S. MICHEAL  
PCH: [Signature]

SEE ABOVE

FIG. NO: MV-DAI-00436-S  
SHEET OF 1




SCD

REV	DATE	SIGN	MODIFICATION	APP
0	09/07	JM	ORIGINAL ISSUE	


PRODUCT	SHEDS	TEXT A	TEXT B	TEXT C	TEXT D	TEXT E
DA1-04A	4	DA1-04A	Uc 3.2kV	Ur 4kV		
DA1-04B	5	DA1-04B	Uc 3.2kV	Ur 4kV		
DA1-06A	4	DA1-06A	Uc 4.8kV	Ur 6kV		
DA1-06B	5	DA1-06B	Uc 4.8kV	Ur 6kV		
DA1-08A	4	DA1-08A	Uc 6.4kV	Ur 8kV		
DA1-08B	5	DA1-08B	Uc 6.4kV	Ur 8kV		
DA1-08C	7	DA1-08C	Uc 6.4kV	Ur 8kV		
DA1-10A	4	DA1-10A	Uc 8kV	Ur 10kV		
DA1-10B	5	DA1-10B	Uc 8kV	Ur 10kV		
DA1-10C	7	DA1-10C	Uc 8kV	Ur 10kV		
DA1-12A	4	DA1-12A	Uc 9.6kV	Ur 12kV		
DA1-12B	5	DA1-12B	Uc 9.6kV	Ur 12kV		
DA1-12C	7	DA1-12C	Uc 9.6kV	Ur 12kV		
DA1-15B	5	DA1-15B	Uc 12kV	Ur 15kV		
DA1-15C	7	DA1-15C	Uc 12kV	Ur 15kV		
DA1-15D	8	DA1-15D	Uc 12kV	Ur 15kV		
DA1-18C	7	DA1-18C	Uc 14.4kV	Ur 18kV		
DA1-18D	8	DA1-18D	Uc 14.4kV	Ur 18kV		
DA1-18E	9	DA1-18E	Uc 14.4kV	Ur 18kV		
DA1-18F	10	DA1-18F	Uc 14.4kV	Ur 18kV		
DA1-21C	7	DA1-21C	Uc 16.8kV	Ur 21kV		
DA1-21D	8	DA1-21D	Uc 16.8kV	Ur 21kV		
DA1-21E	9	DA1-21E	Uc 16.8kV	Ur 21kV		
DA1-21F	10	DA1-21F	Uc 16.8kV	Ur 21kV		
DA1-22C	7	DA1-22C	Uc 17.6kV	Ur 22kV		
DA1-22D	8	DA1-22D	Uc 17.6kV	Ur 22kV		
DA1-22E	9	DA1-22E	Uc 17.6kV	Ur 22kV		
DA1-22F	10	DA1-22F	Uc 17.6kV	Ur 22kV		
DA1-24E	9	DA1-24E	Uc 19.2kV	Ur 24kV		
DA1-24F	10	DA1-24F	Uc 19.2kV	Ur 24kV		
DA1-24G	12	DA1-24G	Uc 19.2kV	Ur 24kV		
DA1-27F	10	DA1-27F	Uc 21.6kV	Ur 27kV		
DA1-27G	12	DA1-27G	Uc 21.6kV	Ur 27kV		
DA1-27H	14	DA1-27H	Uc 21.6kV	Ur 27kV		
DA1-30F	10	DA1-30F	Uc 24kV	Ur 30kV		
DA1-30G	12	DA1-30G	Uc 24kV	Ur 30kV		
DA1-30H	14	DA1-30H	Uc 24kV	Ur 30kV		
DA1-33G	12	DA1-33G	Uc 26.4kV	Ur 33kV		
DA1-33H	14	DA1-33H	Uc 26.4kV	Ur 33kV		
DA1-36G	12	DA1-36G	Uc 28.8kV	Ur 36kV		
DA1-36H	14	DA1-36H	Uc 28.8kV	Ur 36kV		
DA1-39H	14	DA1-39H	Uc 31.2kV	Ur 39kV		
DA1-42H	14	DA1-42H	Uc 33.6kV	Ur 42kV		
DA1-45H	14	DA1-45H	Uc 36kV	Ur 45kV		

YEAR OF MANUFACTURE

LOT No



DA1-30F SAMPLE LABEL



BLANK LABEL

**Tyco Electronics**

**ENERGY DIVISION**

Bowthorpe EMP Surge Arrester

BAY 100-109  
SHANNON IND. EST.  
SHANNON  
CO. CLARE  
IRELAND

THIS DRAWING AND THE INFORMATION SET FORTH HEREON ARE THE PROPERTY OF TYCO ELECTRONICS LTD AND ARE TO BE HELD IN TRUST AND CONFIDENCE. PUBLICATION, DUPLICATION, DISCLOSURE OR USE FOR ANY OTHER PURPOSE NOT EXPRESSLY AUTHORISED IN WRITING BY TYCO ELECTRONICS LTD IS PROHIBITED.	DRN	MULLIGAN	17/09/07	JM	PCN		TITLE <b>IEC MV SURGE ARRESTER          DA1 ARRESTER LABEL</b>
	CHECK	P. FRISSEARLD		PC	MAT'L		
	APP	B. MCGOWAN	30.11	BYG			
	SCALE		1:1				
	DRG NO	MV-DA1-00436-S		SHEET	16 SHANNON INDUSTRIAL EST. SHANNON CO. CLARE IRELAND		

ВАРНО С ОРИГИНАЛА

2

C

C



**Приложение 2 към Техническо предложение****ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ  
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 2.6.**

C

C

Превод от английски език

ОСР2 Квалификации, ENG					
No.	Изпитание	Лаборатория	№ на протокола	60099-4, Издание 1.2 (2001) Клауза	60099-4, Издание 2.0 (2004) Еквивалентна клауза
1	Тест за издръжливост на изолацията върху корпуса на предпазителя	CESI	13060	9.7.2	10.8.2
2	Изпитвания за остатъчно напрежение	CESI	11666	9.7.3	10.8.3
3	Тест за устойчивост на импулсен ток на късо съединение	CESI	510783	9.7.4	10.8.4
4	Изпитвания за устойчивост при работа	CESI	11670	9.7.5	10.8.5
5	Тестове за късо съединение	CESI	522781	9.7.7	10.8.7
6	Тестове за вътрешно-частични разряди	CESI	14190	9.7.8	10.8.8
7	Изпитване на огъващия момент	CESI	507956	13.7.2	10.8.9 (10.8.9.3)
8	Тест за влагоустойчивост	CESI	507955	9.7.9	10.8.13
9	Тест за износоустойчивост	EGU	8915/A3/04	9.7.10	10.8.14
10	Изпитване на съотношение на напрежение с промишлена честота към времето	CESI	521820	5.10, Annex D	6.10, Annex D







OCP2 Qualification, ENG					
No.	Test	Lab	Test Report Number	60099-4, Edition 1.2 (2001) Clause	60099-4, Edition 2.0 (2004) Equivalent Clause
1	Insulation withstand tests on the arrester housing	CESI	13060	9.7.2	10.8.2
2	Residual voltage tests	CESI	11666	9.7.3	10.8.3
3	Long-duration current impulse withstand test	CESI	510783	9.7.4	10.8.4
4	Operating duty tests	CESI	11670	9.7.5	10.8.5
5	Short-circuit tests	CESI	522781	9.7.7	10.8.7
6	Internal partial discharge tests	CESI	14190	9.7.8	10.8.8
7	Test of the bending moment	CESI	507956	13.7.2	10.8.9 (10.8.9.3)
8	Moisture Ingress Test	CESI	507955	9.7.9	10.8.13
9	Weather Ageing Test	EGU	8915/A3/04	9.7.10	10.8.14
10	Power –frequency voltage versus time characteristics on an arrester	CESI	521820	5.10, Annex D	6.10, Annex D

ВЯРНО СЪДЪРЖА







# Electronics

## Bowthorpe EMP

### Test Report

Type	OCP2
PPR Number	PPR-1827
Test Specification	Insulation withstand Test IEC 60099-4 (2001-12)

#### Test Information:

Laboratory	CESI
Date	28/04/2004
External Test Ref	AT-A4/013060

Report Prepared By	D Pirola
Test Verified by	A Sironi
Test Approved by	M de Nigris

#### Tyco Approvals:

<b>R&amp;D Manager</b> Brendan Normoyle	На основание чл. 2 от ЗЗЛД	Date	25/02/2005
<b>Technology Manager</b> Kwong Tong		Date	25/02/2005
<b>Product Manager</b> Brian McGowan		Date	25/02/2005

На основание чл. 2  
от ЗЗЛД

electronics.com

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Tyco confidential

Original Issue 03-2005

client TYCO, Electronics Energy Division - Shannon (Ireland)

equipment under test Housing for polymer housed metal-oxide surge arrester type OCP2 10 kA

tests performed Insulation withstand tests

normative documents IEC 60099-4 (2001-12)

receipt date of the sample April 27, 2004

test date from April 27, 2004 to April 28, 2004

no. of pages 13 no. of pages annexed 05

the test results relate only to the sample tested  
 this document shall not be reproduced except in full without the written approval of CESI

Typo confidential

first issue date June 10, 2004


prepared PeC/TEST - M

verified PeC/TEST - A

approved PeC/TEST - M

На основании чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА





tests witnessed by: ---

identification of the object: effected

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that these drawings adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawings identified by CESI and numbered A4/509282 no. 01 are annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3\%$  ; time parameters:  $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

На основание чл. 2  
от ЗЗЛД

L. Tiziani

P180

43160L



ВЯРНО С ОРИГИНАЛА

Original Issue 03-2005

Not Confidential

Very confidential

Original Issue 03-2005

contents	page	test date
Test object characteristics	4	
Panoramic view of the test object	5	
Panoramic view of the arrangement	6	
Reference standard	7	
Test carried out	7	
Test procedure	8	
Summary of test results	8	
Dry lightning impulse withstand voltage test	9	April 27, 2004
Wet power frequency withstand voltage test	10	April 28, 2004
Technical data of test circuits	11 + 13	


pages annexed

Oscillograms: 04 pages

reference document annexed

Manufacturer's drawing of surge arrester type OCP2 identified by CESI and numbered as A4/509282 no. 01

ВЕРНО С ОРИГИНАЛА



**Test object characteristics**

**type:** Housing for polymer housed metal oxide surge arrester

**electrical characteristics (claimed by the client)**

type	OCP2 10 kA
manufacturer's name	TYCO Electronics Energy division
line discharge class	2
rated voltage - U <sub>r</sub> [kV]	30,0
continuous operating voltage - U <sub>c</sub> [kV]	24,0
dry lightning impulse withstand voltage [kV <sub>peak</sub> ]	185
wet power frequency withstand voltage	90
rated frequency - [Hz]	50-60
year of manufacture	2004

**geometrical characteristics (measured on the test sample)**

total height [mm]	300 (not including studs)
arcing distance [mm]	295
creepage (leakage) distance [mm]	760
number of large sheds	6
large shed diameter [mm]	117
number of small sheds	5
small shed diameter [mm]	97
core dimensions [mm]	55 x 55

**other characteristics**

housing material	polymeric
housing color	grey

**Note:** The tested sample used for insulation withstand test was without active parts

**ВЯРНО С ОРИГИНАЛА**




Original Issue 09-2005

Very confidential

panoramic view of the test object

Original issue 03-2005

Very confidential




ВЯРНО С ОРИГИНАЛА



panoramic view of the test arrangement for insulation withstand test

Original Issue 03-2003

Top Confidential



*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten mark]*

ВЯРНО С ОРИГИНАЛА



Reference standard

IEC 60099-4 (2001-12) " Metal-oxide surge arrester without gaps for a.c. system"  
at clause 7.2

Test carried out

test carried out	number of sample tested
dry lightning impulse withstand test	1
wet power frequency withstand test	1

Original Issue 05-2005

True Confidential

ВЯРНО С ОРИГИНАЛА



Test procedure

Dry lightning impulse withstand test

The test sample has been submitted to fifteen voltage impulses for each polarity having waveshape 1,2/50  $\mu$ s and peak value equal to 185 kV<sub>peak</sub>. The test has been performed in dry condition.

Wet power frequency withstand test

The power frequency voltage level has been applied for 60 seconds on the sample at the value equal to 90 kV<sub>rms</sub>. The test has been performed in wet condition (as defined by IEC st. 60060-1 (1989))

Summary of test results

Dry lightning impulse withstand test

The surge arresters housing were submitted to 15 voltage impulses of each polarity. No flashover occurred during any of the impulse application

Wet power frequency withstand voltage test

The surge arresters housing were submitted to 1 minute power frequency voltage application under wet conditions.

No flashover occurred.

The test result is positive

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Type Confidential

100 CONFIDENTIAL

Original Issue 02-2005

**Dry lightning impulse withstand voltage test according to IEC 60099-4**


test object: Housing for polymer housed metal oxide surge arrester type OCP2 10 kA  
 test circuit: A002  
 arrangement: see pag. 6

atmospheric conditions and correction factor			
b kPa	t °C	h g / m <sup>3</sup>	K <sub>t</sub>
100,1	20 (14)	8,8	0,975

date: April 27, 2004

sample number	polarity	charging voltage		peak voltage		A: flashover (x)	withstand (o)														
		kV	kV	U	U x K <sub>t</sub>																
1	neg	91,5	185,0	180,4	180,5	180,4	180,5														
				180,5	181,0	180,7	180,1	181,0	180,2	180,3	180,0	180,6	180,4	180,4	180,4	180,4	180,6	180,4	180,5	03	
				180,6	181,1	180,8	180,2	180,9	180,5	180,7	180,4	180,6	180,3	180,0	180,6	180,4	180,4	180,4	180,4	180,5	180,5
				180,7	181,2	180,9	180,3	180,8	180,6	180,5	180,7	180,5	180,4	180,1	180,2	180,4	180,4	180,4	180,4	180,4	180,4
1	pos	91,5	185,0	180,2	180,6	180,2	180,6														
				180,3	180,7	180,5	180,1	180,4	180,2	180,5	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2	
				180,4	180,8	180,3	180,1	180,3	180,4	180,2	180,3	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2
				180,5	180,9	180,4	180,2	180,4	180,3	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2	180,2

ВАРНО С ОРИГИНАЛА





type confidential

Original Issue 03.2005

**Wet power frequency withstand voltage test according to IEC 60099-4**

test object: Housing for polymer housed metal oxide surge arrester type OCP2 10 kA  
 test circuit: A058-A059  
 arrangement: see pag. 6



atmospheric conditions and correction factor			
b	t	h	K <sub>t</sub>
kPa	°C	g / m <sup>3</sup>	
100,5	20	—	1,00

	precipitation conditions			water temperature °C	water resistivity Ω x m
	top	center	bottom		
vertical	-	1,6	-	17	104
horizontal	-	1,4	-		

date: April 28, 2004

test sample (no.)	required U	voltage correction factor		applied U x K <sub>t</sub>	test duration	test result	note
		U	K <sub>t</sub>				
1	kV <sub>rms</sub> 90,0	K <sub>t</sub> 1,00	kV <sub>rms</sub> 90,0	s 60	withstand		

ВЕРНО С ОРИГИНАЛА

name: -the voltage was directly measured with "calibrated voltage transformer" k = 1300 in parallel to the sample






**Test Report**

AT-A4/013060

p.10

**circuit A002**



**impulse generator**

plant P180

no. of stages 2

$C_g$  250 nF

$R_c$  280  $\Omega$  (2 x 140  $\Omega$ )

$R_f$  300  $\Omega$  (1 x 140  $\Omega$  + 2 x 60  $\Omega$  + 1 x 40  $\Omega$ )

$C_c$  0,6 nF

$R_{tot \text{ charging}}$  268 k $\Omega$

measuring system CESI no. 9792

voltage divider (D) CESI no. 6700 ; type RC series; scale factor 25299,7

high voltage capacitance 600 pF

low voltage unit (bt), CESI no. 6704

coaxial cable (K)

attenuation and termination unit (S), CESI no. 14924

digital oscilloscope (Osc) CESI no. 14232; type TEKTRONIX TDS 430A

measured waveshape			
	polarity	time	oscillogram
		$\mu s$	no.
front	positive	1,21	01
tail		55,0	02

check of the test circuit			
polarity	charging voltage	measured voltage	$\eta$
	$V_c$	$V_m$	$V_m / (V_c \cdot \eta_{std200})$
	kV/stage	kV	
negative	91,5	180,4	0,98


ВЕРНО С ОРИГИНАЛА



Original Issue 03-2005

Top confidential

circuit A058



power frequency test circuit - plant P180

R : regulation group PIVI composed by:

- single-phase voltage converter; power 210 kVA; voltage 380 V/0 ÷ 610 V
- booster transformer; power 200 kVA; voltage 600 V/6 kV

RE : variable reactor PIVI (not used)

T : booster transformer CGE mod. KOC; secondary winding power 700 kVA; voltage 6 kV/700 kV; no. of units 2; ratio /

R<sub>bt</sub> : protection resistor 2 Ω

TA : current transformer type CGS; ratio 50 A/5 A; CESI no.03399

I<sub>1</sub> : amperometer

TV<sub>1</sub> : voltage transformer type CGS; ratio 6 kV/100 V; CESI no.03384

V<sub>1</sub> : voltmeter ESCORT EDM-3150; CESI no.14469

tripping of the circuit breaker S

I <sub>N</sub>	k <sub>TA</sub>	instantaneous tripping			time delayed tripping		
		settings		t <sub>1</sub>	settings		t <sub>2</sub>
		s <sub>1</sub>	s <sub>1</sub> · I <sub>N</sub>		s <sub>2</sub>	s <sub>2</sub> · I <sub>N</sub>	
5	10	1	5	0,05	0,5	2,5	0,05


*[Handwritten signature]*

*[Handwritten signature]*

ВАРНО С ОРИГИНАЛА



**circuit A059**



power frequency measuring circuit - plant P180

- TV<sub>1</sub>: voltage transformer type CGS ; mat. 7595859 ; ratio 6000V/100V
- V<sub>1</sub> : voltmeter ESCORT EDM-3150; CESI no. 014469
- D : voltage divider type RC series (not used)
- V<sub>3</sub> : voltmeter (not used)
- TV<sub>2</sub>: voltage transformer type SCARPA & MAGNANO; ratio 130 kV/100 V; CESI no.05132
- V<sub>2</sub> : voltmeter ESCORT EDM-3150; CESI no. 014470

**functional check of the test circuit**

date: April 28, 2004

low voltage				high voltage				k <sub>1</sub>
V <sub>1</sub>	V <sub>bt</sub>	I <sub>1</sub>	I <sub>bt</sub>	k <sub>2</sub> = --		k <sub>3</sub> = ----		V <sub>AT</sub> / V <sub>1</sub>
V	V	A	A	V <sub>2</sub>	V <sub>AT</sub>	V <sub>3</sub>	V <sub>AT</sub>	
				V	KV	V	KV	
--	--	--	--	--	--	--	--	--

ВЕРНО С ОРИГИНАЛА




Original Issue 03-2005

Type 00010101010101

Two confidential

Original Issue 03-2006

**CESI** A4/013060, n.1



Vp[kV] T1/Tr[us] T2/Tc[us]

-180.433	1.224	54.984
----------	-------	--------

*[Handwritten signature]*

*[Handwritten signature]*

ВАРНО С ОРИГИНАЛА




*[Handwritten signature]*

Very confidential

Original Issue 05-2005

**CESI** A4/013060, n.2



$V_p$  [kV]  $T_1/T_p$  [us]  $T_2/T_c$  [us]

**-180.433 1.224 54.984**


ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very Confidential

**CESI** A4/013060, n.3



Vp[kV] T1/Tp[us] T2/Tc[us]

**-180.522 1.257 54.657**

*lg*

*[Handwritten signature]*

*[Handwritten mark]*

ВЯРНО С ОРИГИНАЛА




Very confidential

Original Issue 03-2005

**CESI**

A4/013060, п.4



Vp[KV] T1/Tp[us] T2/Tc[us]

180.099 1.291 56.069

ВЯРНО С ОРИГИНАЛА






Typo confidential

Original Issue 03-2003

SCD



NOTE:-

- Uc = 24KV
- NOM CREEPAGE = 758mm
- NOM DRY ARC DIST = 293mm
- CANT. STRENGTH = 350Nm
- TENSION STRENGTH = 2kN
- TORQUE = 50Nm
- HIGH SHORT CIRCUIT = 40KA
- LOW SHORT CIRCUIT = 600A

На основание чл. 2 от ЗЗЛД

PRO 4

DATA

55±1

PRO

4

DATA

**tubo**  
ELECTRONICS

Benthorpe E&MP

BENTHORPE EMP  
SILVERDALE RD.  
SHARNON  
IRELAND

DRN	1	18/11/04	23/04/04	PKN	*****-000	TITLE	0CP2-24S SURGE ARRESTER	DRG NO	MP-0CP2-00027-S	SHEET 1 OF 1	0
CHECK				MAINT							
APP				SCALE	2:5						

REVISION	DATE	DESIGN	MODIFICATION
0	18/11/04	EM	ORIGINAL ISSUE



ВЕРНО С ОРИГИНАЛА

ВЯРНО С ОРИГИНАЛА

A handwritten signature in black ink, consisting of a large, stylized initial letter 'A' followed by a cursive flourish.



Energy Division  
http://energy.tycoelectronics.com

## Electronics

### Bowthorpe EMP

### Test Report

Original Issue 03-2005

Type	OCP2
PPR Number	PPR-1828
Test Specification	Residual voltage test IEC 60099-4 (2001-12)

#### Test Information:

Laboratory	CESI
Date	30/04/2004
External Test Ref	AT-A4/011666

Report Prepared By	M Gregori
Test Verified by	A Sironi
Test Approved by	V Scarioni

#### Tyco Approvals:

R&D Manager	На основание чл. 2 от ЗЗЛД	Date	25/02/2005
Brendan Normoyle			
Technology Manager		Date	25/02/2005
Kwong Tong			
Product Manager		Date	25/02/2005
Brian McGowan			

For further information contact:  
 Tyco Electronics Energy Division  
 Bay 100 - 109  
 Shannon Industrial Estate  
 Co. Clare, Ireland  
 Tel: + 353-61-472885  
 Fax: + 353-61-472676  
 Email: mvsurgearresters@tycoelectronics.com

Tyco confidential

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2006

client TYCO Electronics Energy Division - Shannon (IRL)

equipment under test Polymer housed metal-oxide surge arrester  
type OCP2

tests performed Residual voltage test

normative documents IEC 60089-4 (2001-12)

receipt date of the sample April 15, 2004

test date from April 27, 2004 to April 30, 2004

no. of pages 18 no. of pages annexed 32

the test results relate only to the sample tested  
this document shall not be reproduced except in full without the written approval of CESI



Very confidential

first issue date May 25, 2004

prepared PeC/TEST -


verified PeC/TEST -

approved PeC/TEST -

На основание чл. 2  
от ЗЗЛД

CESI  
Centro Elettrotecnico  
Sperimentale Italiano  
Giacinto Motta SpA  
**ВЯРНО С ОРИГИНАЛА**

Via R. Rubattino, 64  
20134 Milano, Italia  
Telefono +39 02 22125.1  
Fax +39 02 21255440  
www.cesi.it



Capital sociale 8 550 000 Euro  
integramente versato  
Codice fiscale e numero  
iscrizione CCIAA 00793580150

Registro Imprese di Milano  
Sezione Ordinaria  
N. R.E.A. 429222  
P.I. IT00793580150

tests witnessed by: /

Original Issue 03-2008

Identification of the object: The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.

The drawings identified by CESI and numbered A4/503147, one page, is annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3\%$  ; time parameters:  $\pm 10\%$
- dielectric tests with impulse current : peak value:  $\pm 3\%$  ; time parameters:  $\pm 10\%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3\%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.


Very confidential

На основание чл. 2  
от ЗЗЛД

Podavitte - I. Guacci

arrester laboratory

keywords: 12015R, 23810H, 31020W, 46030U, 53001D




contents	page	test date
Test object characteristics	4	
Photograph of polymer housed metal-oxide surge arrester	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Power frequency voltage current characteristics	8	April 27, 2004
Lightning impulse residual voltage test	9 ÷ 10	April 27, 2004
Switching impulse residual voltage test	11	April 27, 2004
Steep current impulse residual voltage test (inductive effects of the voltage measuring circuit)	12	April 30, 2004
Steep current impulse residual voltage test	13	April 30, 2004
Power frequency voltage current characteristics	14	April 30, 2004
Technical data of the test circuit	15 ÷ 18	

ВЕРНО С ОРИГИНАЛА



Pages annexed:

- oscillograms n.31 pages
- TYCO drawing n. OCP2-5, CESI n.A4/503147-01; n.1 page



Test object characteristics

type: Polymer housed metal-oxide surge arrester section

electrical characteristics (claimed by the client)

manufacturer's name	TYCO Electronics Energy Division - Shannon (IRL)
nominal discharge current - $I_{nt}$ [kA]	10,0
rated voltage - $U_r$ [kV]	$0,980 \times U_{ref}$
continuous operating voltage - $U_c$ [kV]	$0,784 \times U_{ref}$
reference current - $I_{ref}$ [mA]	5,0
line discharge class	2
rated frequency - [Hz]	50
year of manufacture	2004

geometrical characteristics (measured on the test sample)

height [mm]	139
number of sheds	n.2 large - n.1 small
shed diameter [mm]	118 large - 96 small

other characteristics

housing material	SILICONE
housing color	GREY


Original Issue 03-2005

Tyco Confidential


ВЯРНО СЪДЪРЖА



Photograph of the test sample.



ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Original Issue



Reference Standard

IEC 60099-4 (2001-12) Clause 7.3

" Metal-oxide surge arrester without gaps for a.c. system"

Test carried out

test carried out	number of sample tested
Lightning impulse residual voltage test	3
Switching impulse residual voltage test	
Steep current impulse residual voltage test	

Test object identification

test object names	identification of test sample (given by the client)
polymer housed metal-oxide surge arrester section	RV1 - RV2 - RV3



Original Issue 03-2005

Very confidential

Test procedure

- The power frequency voltage at reference current ( $I_{ref} = 5 \text{ mA}$ ) was measured in both polarities, required by the Client
- The lightning impulse residual voltage with current waveshape having front time equal to  $8 \mu\text{s}$  and time to half value equal to  $20 \mu\text{s}$  at the following values has been measured at following current levels:

$$I_N = 10 \text{ kA}$$

$$0,5 I_N = 5 \text{ kA}$$

$$2 I_N = 20 \text{ kA}$$

- The switching impulse residual voltage with current waveshape having front time greater then to  $30 \mu\text{s}$  but less than  $100 \mu\text{s}$  and time to half value roughly twice at following current has been measured according to table 3 of the reference standard

$$I = 125 \text{ A}$$

$$I = 500 \text{ A}$$

- The steep current residual voltage at  $I_N$  with current waveshape having front time equal to  $1 \mu\text{s}$  and time to half value not longer than  $20 \mu\text{s}$  has been measured. The inductive error was measured replacing the surge arresters section with a metal blocks having the same dimensions. The inductive correction was applied by subtracting the impulse shape measured on the surge arrester sections and the impulse shape on the metal block.
- The power frequency voltage at reference current ( $I_{ref} = 5 \text{ mA}$ ) has been measured in both polarities

Original Issue 03-2005

Type confidential



Power frequency voltage-current characteristics before test.

test object: Polymer housed metal-oxide surge arrester section  
test circuit: AO19

date: April 27, 2004

Original issue 02-2005

sample no. RV2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	6,93	5,00	4,47	1,62	7,25	---
2	6,96	5,64	5,04	1,79	8,03	---

sample no. RV1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	6,99	5,04	4,58	1,6	7,13	---
4	6,93	5,56	5,04	1,75	7,82	---

sample no. RV3						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
5	6,93	5,04	4,51	1,64	7,44	---
6	6,98	5,64	5,00	1,79	8,14	---

Type confidential

ВЯРНО С О...

Lightning impulse residual voltage test.

test object: Polymer housed metal-oxide surge arrester section  
test circuit: A014

date: April 27, 2004

sample	requested current	charging voltage	oscillogram	current waveshape	discharge current	residual voltage	lightning impulse protection level
no.		kV	no.	$\mu$ s	kA	kV	kV
RV1	$0,5 \times I_N$	21,6	10	8,4/18,6	5,00	15,11	see relevant curve in the following page
	$I_N$	29,1	7	8,5/18,4	10,0	16,08	
	$2,0 \times I_N$	45,0	13	8,5/18,4	20,2	17,94	
RV2	$0,5 \times I_N$	21,7	11	8,4/18,6	5,00	15,19	
	$I_N$	29,1	8	8,5/18,4	10,0	15,92	
	$2,0 \times I_N$	45,0	14	8,5/18,4	20,3	17,61	
RV3	$0,5 \times I_N$	21,7	12	8,4/18,6	5,00	15,19	
	$I_N$	29,1	9	8,5/18,4	10,1	16,08	
	$2,0 \times I_N$	45,0	15	8,5/18,4	20,10	17,78	


		oscilloscope settings		
		sampling division	input	attenuation
		$\mu$ s	$V_{dv}$	
current	$0,5 I_N$	5	0,5	20:5
	$I_N$		0,5	50:5
	$2 I_N$		1,0	50:5
voltage	$0,5 I_N$		1,0	20:5
	$I_N$		1,0	20:5
	$2 I_N$		1,0	20:5

ВАРНО С ОРИГИНАЛА



Original issue 03-2005

Very confidential



*[Handwritten signature]*

*[Handwritten signature]*

ВЯРНО С ОРИГИНАЛА



Switching impulse residual voltage test.

test object: Polymer housed metal-oxide surge arrester section

test circuit: A014A

date: April 27, 2004

sample	requested current	charging voltage	oscillogram	current waveshape	discharge current	residual voltage	switching impulse protection level
no.	A	kV	no.	$\mu s$	A	kV	kV
RV1	125	12,7	16	32,0/82,0	123	12,12	12,84
	500	15,2	19	34,0/79,0	500	12,73	
RV2	125	12,7	17	32,0/82,0	129	12,12	
	500	15,2	20	34,0/79,0	510	12,73	
RV3	125	12,7	18	32,0/82,0	128	12,20	
	500	15,2	21	34,0/79,0	496	12,84	

	oscilloscope settings		
	sampling division	input	attenuation
	$\mu s$	V <sub>div</sub>	
current	20	0,5	5:5 (125 A) - 20:5 (500 A)
voltage	20	0,7	20:5

Original Issue 03-2005

Type confidential

ВАРИО С ОРИГИНАЛА



Steep current impulse residual voltage test.  
measurement of the inductive error

test object: Tets sample replaced by an aluminium blocks have same dimension as the test sampled  
test circuit: A014B

Original Issue 03-2005

date: April 30, 2004

sample	charging	oscillogram	current	discharge	peak	inductive error
	voltage		waveshape	current	voltage	
	kV		$\mu s$	kA	V	
Aluminium blocks	32,7	22	0,97/2,11	10,0	1210	2% + 20% (1)

	oscilloscope settings		
	sampling division	input	attenuation
	$\mu s$	V <sub>div</sub>	
current	1	2,0	x 10
voltage	1	1,0	/

(1) = correction is required.

Very confidential

ВЯРНО С ОРИГ.



Steep current impulse residual voltage test.

test object: Polymer housed metal-oxide surge arrester section

test circuit: A014B


date: April 30, 2004

sample	charging voltage	oscillogram	current waveshape	discharge current	residual voltage	steep current impulse protection level
no.	kV	no.	$\mu s$	kA	kV	kV
RV1	32,6	23	0,97/2,1	9,95	16,64	16,72
RV2	32,8	24		10,0	16,64	
RV3	33,2	25		9,95	16,72	

	oscilloscope settings		
	sampling division	input	attenuation
	$\mu s$	$V_{div}$	
wave 1 - current	1,0	2,0	x 10
wave 2 - voltage		5,0	/
wave M2 - corrected voltage		4,0	/

Original Issue 03-2005

Type confidential





Power frequency voltage-current characteristics after test.

test object: Polymer housed metal-oxide surge arrester section  
test circuit: A019

date: April 30, 2004

sample no. RV2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
26	7,18	5,06	4,52	1,62	7,01	---
27	7,11	5,66	5,00	1,76	7,54	---

sample no. RV1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
28	6,97	5,06	4,70	1,65	7,08	---
29	6,97	5,48	5,06	1,75	7,63	---

sample no. RV3						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
30	7,04	5,12	4,70	1,65	7,29	---
31	7,18	5,36	5,12	1,76	7,75	---


Original Issue 03-2005

Type confidential

ВЯРНО СЪДЪРЖА



**circuit A019**



**power frequency supply**

RE : programmable supply CESI no. 23702-32191 ; type Larcet A.C. Power Source 5000 P.S.

PC : personal computer

T : transformer type Specialtrasfo ; power 30 kVA ; voltage 200 V/15-30 kV

current shunt (R) CESI no.11537 ;  $R = 811,94 \Omega$

oscilloscope CESI no. 30223-30224

type Data Precision DATA 6100

voltage divider (D) CESI no.11120;  $K = 1010$


electro optical system CESI no. 11519/520; attenuation 50:5

oscilloscope CESI no. 30223-30224


type Data Precision DATA 6100

Original Issue 03-2005

Very confidential



circuit A014



impulse generator

plant P177

no. of stages 1

$C_g$  4,98  $\mu F$

$L_c$  10  $\mu H$

S spark gap

current shunt (R) CESI no. 6042;  $R = 0,002\Omega$  ; 100 kA

electro optical system CESI no. 11517/518

oscilloscope CESI no. 13217

type Tektronix TDS 540A

voltage divider (D) CESI no.11120 ;  $k = 1010$

electro optical system CESI no.11519/520

oscilloscope CESI no. 13217

type Tektronix TDS 540A

Original Issue 03-2005


Type confidential

ВЯРНО С ОРИГИНАЛА



circuit A014A

Original Issue 03-2005



Impulse generator

plant P177

no. of stages 1

$C_g$  6,64  $\mu F$

$L_c$  100  $\mu H$

S spark gap

current shunt (R) CESI no. 6039 ;  $R = 0,02\Omega$  ; 10 kA

electro optical system CESI no. 11517/518

oscilloscope CESI no. 13217

type Tektronix TDS 540A

voltage divider (D) CESI no.11120 ;  $k = 1010$

electro optical system CESI no.11519/520


oscilloscope CESI no. 13217

type Tektronix TDS 540A

Type confidential



circuit A014B



Impulse generator

plant P177

no. of stages 1

$C_g$  0,25  $\mu$ F

$L_c$  1  $\mu$ H

S spark gap

current TA (R) type Pearson CESI no.8250 ; 0,01 V x A  
oscilloscope CESI no. 11873  
type Tektronix TDS 540A

voltage divider (D) CESI no.11120 ; k = 1010  
oscilloscope CESI no. 11873  
type Tektronix TDS 540A

ВЯРНО С ОРИГИНАЛА





Original issue 03-2005

Very confidential

Original Ref: 30-23015

30-23015



ВЯРНО С ОРИГИНАЛА





*[Handwritten signature]*

CESI TEST A4/011666 oscillogram n. 1

Two confidential

Original Issue 03-2005





CESI TEST A4/011666 oscillogram n. 2

ВЯРНО С ОПРИ



Original Issue 25-2002

Original Issue 25-2002





ВЯНО С ОРИГИНАЛА



TEST A4/011666 oscillogram n. 3





*ay*



CESI TEST A4/011666 oscillogram n. 4

**ВЯРНО С ОРИГИНАЛА**



Top Secret

Original Issue 03-2005





ВЯРНО С ОРИГИНАЛА



CESI TEST A4/011666 oscillogram n. 5

Type confidential

Original Issue 03-2005




*Handwritten signature*

CESI TEST A4/011666 oscillogram n. 6

ВЯРНО С ОРИГИНАЛА





27 Apr 2004 11:59:18


ВЯРНО С ОРИГИНАЛА



CESI TEST A4/011666 oscillogram n. 7

Typo confidential

Original Issue 03-2005



27 Apr 2004  
12:05:51


CESI TEST A4/011666 oscillogram n. 8

ВЯРНО С ОРИГИНАЛА



Typo confidential

Original Issue 03-2005



27 Apr 2004  
12:15:12


ВЯРНО С ОРИГИНАЛА



CESI TEST A4/011666 oscillogram n. 9

Тыко confidential

Original Issue 03-2002



Handwritten signature


CESI TEST A4/011666 oscillogram n. 10

ВЯРНО С ОРИГИНАЛА



Type confidential

Original Issue 03-2005



ВЪРНО С ОРИГИНАЛА




CESI TEST A4/011666 oscillogram n. 11



Very confidential

Original Issue 03-2005



CESI TEST A4/011666 oscillogram n. 12


ВЯРНО С ОРИГИНАЛА



*[Handwritten signature]*


Very confidential

Original Issue 03-2005



ВЯРНО С ОРИГИНАЛА





*Handwritten signature*


CESI TEST A4/011666 oscillogram n. 14

**ВЯРНО С ОРИГИНАЛА**



Type confidential

Original Issue 03-2005




ВЯНО С ОРИГИНАЛА



Typo confidential

Original Issue 03-2605



CESI TEST A4/011666 oscillogram n. 16


ВЯРНО С ОРИГИНАЛА



Handwritten signature

Typo confidential


Original Issue 03-2003



ВЯРНО С ОРИГІНАЛА



ESI TEST A4/011666 oscillogram n. 17



*Handwritten signature*


CESI TEST A4/011666 oscillogram n. 18

**ВЯРНО С ОРИГИНАЛА**



Original Issue 03-2005

Very confidential




ВЯРНО С ОРИГИНАЛА

АКЦИОНЕРНО ДРУЖЕСТВО  
ФИЛКАБ  
16  
ПЛОВДИВ



Types confidential

Original Issue 03-2005



CESI TEST A4/011666 oscillogram n. 20

ВЯРНО С ОРИГИНАЛА





*[Handwritten signature]*

ВЪРНО С ОРИГИНАЛА

Tek STOP 2.50MS/S

1 Acqs






CESI TEST A4/011666 oscillogram n. 22


ВЯРНО С ОРИГИНАЛА





ВЪРНО С ОРИГИНАЛА






CESI TEST A4/011666 oscillogram n. 24

ВЯРНО С ОРИГИНАЛА







ВЯНО С ОРИГИНАЛА



Typo confidential

Original Issue 03-2005



CESI TEST A4/011666 oscillogram n. 26

ВЯРНО С ОРИГИНАЛА




*[Handwritten signature]*


Type confidential

Original issue 03-2005

BUF . A1



BUF . A2





CESI TEST A4/011666 oscillogram n. 27

ВЕРНО С ОРИГИНАЛА







CESI TEST A4/011666 oscillogram n. 28

ВЯРНО С ОРИГИНАЛА




By


Very confidential

Original Issue 03-2005

BUF .A1



BUF .A2





ВЯРНО С ОРИГИНАЛА



Very confidential

Original issue 03-2005



CESI TEST A4/011666 oscillogram n. 30

*Handwritten signature*

**ВЯРНО С ОРИГИНАЛА**




*Handwritten signature*



Very confidential

Original Issue 03-2003

BUF.A1






BUF.A2



Original Issue 03-2003

Original Issue 03-2003



CREEPAGE=265mm  
 DRY ARC DIST=138mm

*[Handwritten signature]*

*[Handwritten signature]*

		<b>ENERGY DIVISION</b> SOVDKABPBG SOVDKABPBG	
THE DRAWING AND THE INFORMATION ON IT ARE THE PROPERTY OF THE DRAWING OFFICE. THE INFORMATION ON IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT PERMISSION IN WRITING BY THE DRAWING OFFICE.	DIM CHECK APP	MILLION PLUM DIM	DIM DATE DIM
TITLE SKV 10kA DCP2 SURGE ARRESTER PRODUCT	DIM DATE DIM	DIM DATE DIM	DIM DATE DIM

PROLOGO

DATA

03 JUL 2004



ВАРНО С ОРИГИНАЛА





Energy Division  
http://energy.tycoelectronics.com

## Electronics

### Bowthorpe EMP

## Test Report

Type OCP2  
 PPR Number PPR-1950  
 Test Long Duration Current Impulse Withstand Test  
 Specification IEC 60099-4 (2001-12)

#### Test Information:

Laboratory CESI  
 Date 07/09/2004  
 External Test Ref AT-A4510783

Report Prepared By M Gregori  
 Test Verified by A Sironi  
 Test Approved by M de Nigris

#### Tyco Approvals:

R&D Manager	На основание чл. 2 от ЗЗЛД	Date	25/02/2005
Brendan Normoyle			
Technology Manager			
Kwong Tong		Date	25/02/2005
Product Manager			
Brian McGowan		Date	25/02/2005

For further information contact:  
Division

На основание чл. 2 от ЗЗЛД

tycoelectronics.com

ВАРНО С ОРИГИНАЛА



Original Issue 03-2005

Tyco confidential

Original Issue 05-2005

client TYCO Electronics Energy Division - Shannon (IRL)

equipment under test Polymer housed metal-oxide surge arrester  
type OCP2

tests performed Long duration current impulse withstand tests

normative documents IEC 60099-4 (2001-12) and Client request

receipt date of the sample August 31, 2004

test date from September 01, 2004 to September 07, 2004

no. of pages 18 no. of pages annexed 22

the test results relate only to the sample tested  
this document shall not be reproduced except in full without the written approval of CESI




Typo confidential

first issue date September 10, 2004

prepared PeC/TEST -  
verified PeC/TEST -  
approved PeC/TEST -

На основание чл. 2  
от ЗЗЛД



CESI  
Centro Elettrotecnico  
Sperimentale Italiano  
Giachino, Motte SpA

Via R. Rubattino 54  
20134 Milano - Italia  
Telefono +39 022125.1  
Fax +39 0221255440  
www.cesi.it

Capitale sociale 8 560 000 Euro  
interamente versato  
Codice fiscale e numero  
Iscrizione CCIAA 00793580150

Registro Imprese di Milano  
Sezione Ordinaria  
N. R.E.A. 429222  
P.I. IT00793580150



tests witnessed by: ---

Original Issue 03-2005

identification of the object: The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.

The drawings identified by CESI and numbered. A4/503147, one page, is annexed to this document.

Top confidential

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with impulse current : peak value:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

На основание чл. 2  
от ЗЗЛД

Podavitte - I. Guacci

7 surge arrester laboratory

OH, 31020W, 46030U, 53001D

ВАРНО С ОРИГИНАЛА



Two confidential

Original Issue 03-2005

contents	page	test date
Test object characteristics	4	
Photograph of polymer housed metal-oxide surge arrester.	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Summary of test result	8	
Power frequency voltage-current characteristic	9	September 01, 2004
Lightning impulse residual voltage measurement before the test	10	September 02, 2004
Long duration current impulse withstand test	11 ÷ 13	September 07, 2004
Long duration current impulse withstand test (additional shot)	14	September 07, 2004
Lightning impulse residual voltage measurement after the test	15	September 07, 2004
Technical data of the test circuit	16 ÷ 18	

Pages annexed:

- oscillogram n.21 pages
- TYCO drawing n. OCP2-5, CESI n.A4/503147-01; n.1 page

**БЯРНО С ОРВИ ВНАПА**



**Test Report**



AT-A4510783

Test object characteristics

type: Polymer housed metal-oxide surge arrester section

electrical characteristics (claimed by the client)

manufacturer's name	TYCO Electronics Energy Division - Shannon (IRL)
nominal discharge current - $I_N$ [kA]	10
rated voltage - $U_r$ [kV]	0,980 x $U_{ref}$
continuous operating voltage - $U_c$ [kV]	0,784 x $U_{ref}$
reference current - $I_{ref}$ [mA]	5
line discharge class	2 (*)
rated frequency - [Hz]	50
year of manufacture	2004

geometrical characteristics (measured on the test sample)

height [mm]	139
number of sheds	n.2 large - n.1 small
shed diameter [mm]	118 large - 96 small

other characteristics

housing material	SILICONE
housing color	GREY

(\*) Note: Upon Client request the test was carried out with an energy of the single shot equal to 15,5 kJ (i.e. 3,05 kJ/kV- $U_c$ ). Such energy is higher than the energy calculated for class 2 arrester according to IEC procedure ( see CESI report A4/011673). The test is therefore more severe.


**ВЯРНО С ОРИГИНАЛА**



Original Issue 03-2005

Tyco confidential

Photograph of the test sample.



Original Issue 95-2005

Confidential

ВЯРНО С ОРИГИНАЛА



Reference Standard

IEC 60099-4 (2001-12) Clause 7.4.3  
" Metal-oxide surge arrester without gaps for a.c. system"

Test carried out

test carried out	number of sample tested
Long duration current impulse withstand test	3

Test object identification

test object names	identification of test sample (given by manufacturer)
polymer housed metal-oxide surge arrester section	LD1 - LD2 - LD3

Original Issue 03-2005

Very confidential

ВЯРНО С ОРИГИНАЛА



Test procedure

- The measurement of the power frequency voltage at reference current ( $I_{ref} = 5 \text{ mA}$ ) has been performed
- The lightning impulse residual voltage at  $I_N = 10 \text{ kA}$  has been measured
- Eighteen long duration current impulses with the specified energy and a virtual duration of  $2000 \mu\text{s}$  have been applied in six groups of three operations. Intervals between operations of the same groups have been about 60 seconds; between different groups the samples have been let to cool down to near ambient temperature
- After eighteenth impulses the test sample have been cool down to ambient temperature and a nineteenth impulse has been applied
- The measurement of the lightning impulse residual voltage at  $I_N$  has been repeated

Original issue 03-2005

True confidential

ВЯРНО С ОРГИНАЛАТА



Visual Inspection and summary of test result

variation of lightning impulse residual voltage at  $I_N$

sample	before test		after test		variation %
	discharge current	residual voltage	discharge current	residual voltage	
	kA	kV	kA	kV	
LD1	10,1	16,00	10,0	15,84	1,0
LD2	10,1	16,08	10,0	16,00	0,5
LD3	10,1	15,92	10,0	15,84	0,5

The test has been performed without disconnecter.

The visual inspection of the metal-oxide surge arrester after the test has revealed no sign of physical damage. The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%).

The oscillographic record of the 19<sup>th</sup> impulse doesn't reveal any sign of internal discharge.

All acceptance criteria according to the reference standard are satisfied and therefore the result is to be considered positive.

Original Issue 03-2005

Type confidential

ВЯРНО С ОРИГИНАЛА



Power frequency voltage-current characteristics.

test object: Polymer housed metal-oxide surge arrester section  
test circuit: A019

date: September 01, 2004

sample no. LD1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	6,77	5,10	4,91	1,876	8,959	---

sample no. LD2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
2	6,79	5,03	4,73	1,812	8,540	---

sample no. LD3						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	6,74	5,09	4,83	1,851	8,734	---

ВЯРНО С ОРИГИНАЛА



Original no. 03-2009

Type: 0010/0010/0010



Long duration current impulse withstand test.

lightning impulse residual voltage measurement at  $I_N$  before the test

test object: Polymer housed metal-oxide surge arrester section

test circuit: A014

date: September 02, 2004

sample no.	requested current	charging voltage kV	oscillogram no.	current waveshape $\mu s$	discharge current kA	residual voltage kV
LD1	$I_N$	29,4	4	8,5/19,0	10,1	16,00
LD2		29,4	5		10,1	16,08
LD3		29,4	6		10,1	15,92

	oscilloscope settings		
	sampling division $\mu s$	input $V_{in}$	attenuation
current	5,0	0,5	50:5
voltage		1,0	20:5

Original Issue 03-2006

Two confidential

ВЯРНО С ОРИГИНАЛА



Long duration current impulse withstand test.

test object: Polymer housed metal-oxide surge arrester section  
test circuit: A017


date: September 07, 2004

sample no.	impulse no.	charging voltage V <sub>c</sub> kV	oscillogram no.	peak current I A	residual voltage V <sub>r</sub> kV	energy E kJ
LD1	1	15,3		535	12,83	15,77
	2	15,3		535	12,83	15,71
	3	15,4	7	530	12,83	15,63
	4	15,3		540	12,83	15,87
	5	15,3		540	12,83	15,70
	6	15,4		530	12,83	15,60
	7	15,3		535	12,83	15,70
	8	15,3		540	12,83	15,86
	9	15,4	10	535	12,83	15,71
	10	15,3		540	12,83	15,95
	11	15,3		535	12,83	15,73
	12	15,4		535	12,83	15,71
	13	15,3		540	12,83	16,07
	14	15,3		540	12,83	15,92
	15	15,4		530	12,83	15,60
	16	15,3		535	12,83	15,70
	17	15,3		535	12,83	15,70
	18	15,4	13	540	12,83	15,77

measured waveshape	
virtual duration	virtual total duration
μs	μs
2200	2910

	oscilloscope settings		
	sampling division	input	attenuation
	μs	V <sub>div</sub>	
current	50,0	1,0	10:5
voltage		0,5	50:5

cont'd



Original is 03-09-04

17.09.04 10:00

cont'd

date: September 07, 2004

sample	impulse	charging voltage	oscillogram	peak current	residual voltage	energy
		$V_c$		$I$	$V_r$	$E$
no.	no.	kV	no.	A	kV	kJ
LD2	1	15,3		540	12,83	15,86
	2	15,3		535	12,83	15,60
	3	15,4	8	535	12,83	15,65
	4	15,3		540	12,83	15,67
	5	15,3		545	12,83	16,22
	6	15,4		530	12,83	15,60
	7	15,3		548	12,83	16,16
	8	15,3		540	12,83	16,06
	9	15,4	11	535	12,83	16,20
	10	15,3		540	12,83	15,94
	11	15,3		530	12,83	15,60
	12	15,4		545	12,83	16,16
	13	15,3		540	12,83	15,96
	14	15,3		530	12,83	15,58
	15	15,4		530	12,83	15,58
	16	15,3		540	12,83	16,00
	17	15,3		540	12,83	15,91
	18	15,4	14	535	12,83	15,58

measured waveshape

virtual duration	virtual total duration
$\mu s$	$\mu s$
2200	2910

oscilloscope settings

	sampling division	input	attenuation
	$\mu s$	$V_c$	
current	50,0	1,0	10:5
voltage		0,6	50:5

cont'd

**ВЯРНО С ОРИГИНАЛА**



Original Issue 00-2005

True confidential

cont'd

date: September 07, 2004

sample no.	impulse no.	charging voltage $V_c$ kV	oscillogram no.	peak current I A	residual voltage $V_r$ kV	energy E kJ
LD3	1	15,3		558	12,83	16,34
	2	15,3		548	12,83	16,22
	3	15,4	9	544	12,83	16,12
	4	15,3		548	12,83	16,23
	5	15,3		545	12,83	16,15
	6	15,4		535	12,83	15,70
	7	15,3		560	12,83	15,52
	8	15,3		545	12,83	16,10
	9	15,4	12	540	12,83	16,06
	10	15,3		555	12,83	16,30
	11	15,3		545	12,83	16,08
	12	15,4		540	12,83	15,86
	13	15,3		555	12,83	16,26
	14	15,3		545	12,83	16,06
	15	15,4		538	12,83	15,86
	16	15,3		550	12,83	16,24
	17	15,3		550	12,83	16,20
	18	15,4	15	545	12,83	16,06

measured waveshape	
virtual duration $\mu s$	virtual total duration $\mu s$
2200	2910

oscilloscope settings			
	sampling division $\mu s$	input $V_{av}$	attenuation
current	50,0	1,0	10:5
voltage		0,5	50:5

ВЯРНО С ОРИГИНАЛА



cont'd

Original Issue 03-2005

Doc confidential

Long duration current impulse withstand test.

(check the integrity of the internal parts with an additional shot at ambient temperature)

test object: Polymer housed metal-oxide surge arrester section

test circuit: A014

date: September 07, 2004

sample	impulse	charging voltage $V_c$	oscillogram	peak current $I$	residual voltage $V_r$	energy $E$
no.	no.	kV	no.	A	kV	kJ
LD1	19	15,3	16	540	12,83	15,88
LD2	19	15,3	17	548	12,83	16,06
LD3	19	15,3	18	550	12,83	16,16

measured waveshape	
virtual duration $\mu s$	virtual total duration $\mu s$
2200	2910

	oscilloscope settings		
	sampling division $\mu s$	input $V_{div}$	attenuation
current	50,0	1,0	10:5
voltage		0,5	50:5

cont'd

**ВЯРНО С ОРИГИНАЛА**



Original Issue 03-2005

Very confidential

Long duration current impulse withstand test.

lightning impulse residual voltage measurement at  $I_N$  after the test

test object: Polymer housed metal-oxide surge arrester section  
test circuit: A014

Original Issue 03-2005

date: September 07, 2004

sample no.	requested current	charging voltage kV	oscillogram no.	current waveshape $\mu s$	discharge current kA	residual voltage kV
LD1	$I_N$	29,4	19	8,5/19,0	10,0	15,84
LD2		29,4	20		10,0	16,00
LD2		29,4	21		10,0	15,84


	oscilloscope settings		
	sampling division $\mu s$	Input $V_{div}$	attenuation
current	5,0	0,5	50:5
voltage		1,0	20:5

Type confidential

ВЯРНО С ОРИГИНАЛА



circuit A019



power frequency supply

RE : programmable supply CESI no. 23702-32191 ; type Larcet A.C. Power Source 5000 P.S.  
 PC : personal computer  
 T : transformer type Specialtrafo ; power 30 kVA ; voltage 200 V/ 15 kV

current shunt (R) CESI no. 11537 ;  $R = 811,94 \Omega$   
 oscilloscope CESI no. 9090  
 type RTD 710 A

voltage divider (D) CESI no. 11120  $k = 1010$   
 electro optical system CESI no. 11519/520 ; attenuation 50:5  
 oscilloscope CESI no. 9090  
 type RTD 710 A


Original Issue 03-2005

Type confidential

ВЯРНО С ОРИГИНАЛА



**circuit A014**



**impulse generator**

plant P177

no. of stages 1

$C_g$  4,98  $\mu$ F

$L_c$  10  $\mu$ H

S spark gap

current shunt (R) CESI no.6042;  $R = 0,002 \Omega$ ; 100 kA

electro optical system CESI no.11517/518

oscilloscope CESI no. 13217

type Tektronix TDS 540A

voltage divider (D) CESI no.11120;  $k = 1010$

electro optical system CESI no.11519/520

oscilloscope CESI no. 13217

type Tektronix TDS 540A

Original Issue 03-2005


Pre confidential





**circuit A017**

long duration withstand impulse test



**impulse generator**

plant P177

- C<sub>1</sub> ... C<sub>12</sub>: capacitors 18,75 μF
- L<sub>1</sub> ... L<sub>11</sub>: inductors 666 μH
- L<sub>12</sub>: inductor (500 + 666) μH
- S spark gap

shunt (R) CESI no. 60 ; R = 0,010 Ω ; 20 kA  
 electro optical system CESI no. 11519/520  
 oscilloscope CESI no. 13217 ; type Tektronix TDS 540A

voltage divider (D) CESI no.11120 ; k = 1010  
 electro optical system CESI no.8008/8014  
 oscilloscope CESI no. 13217 ; type Tektronix TDS 540A

Original issue 05-2005



Type confidential

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Too confidential





CESI AT- A4510783 oscillogram n. 1

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Type confidential



*Handwritten signature*

CESI AT-A4510783 oscillogram n. 2



*Handwritten signature*

**ВЯРНО С ОРИГИНАЛА**



Original Issue 03-2003


True confidential



CESI AT- A4510783 oscillogram n. 3

ВАРНО С ОРИГИНАЛА






CESI TEST A4510783 oscillogram n. 4

ВЯРНО С ОРИГИНАЛА




*Handwritten signature*



ВЯРНО С ОРИГИНАЛА






CESI TEST A4510783 oscillogram n. 6

ВЯРНО С ОРИГИНАЛА



ay



ВЯНО С ОРИГИНАЛА






Very confidential

Original Issue 03-2005

Tek Run: 1.00MS/s Hi Res **100k**




Math1 1.00 VV 500µs

*[Handwritten signature]*

CESI TEST A4510783 oscillogram n. 8


ВЯРНО С ОРИГИНАЛА





ВЯРНО С ОРИГИНАЛА






CESI TEST A4510783 oscillogram n. 10

ВЯРНО С ОРИГИНАЛА



Very confidential


Original Issue 03-2006



ВЯРНО С ОРИГИНАЛА



Tek **STOP** 1.00MS/s 3 Acqs



M1 Area  
-7.94568mV

**Math1** 1.00 VV 500µs


CESI TEST A4510783 oscillogram n. 12

ВЯРНО С ОРИГИНАЛА




Tyco confidential

Original Issue 03-2005



ВЯНО С ОРИГИНАЛА






CESI TEST A4510783 oscillogram n. 14

ВЯРНО С ОРИГИНАЛА



Type confidential


Original Issue 03-2005



ВЯРНО С ОРИГИНАЛА








CESI TEST A4510783 oscillogram n. 16

ВЯРНО С ОРИГИНАЛА






ВЯРНО С ОРИГИНАЛА



Type confidential

Original Issue 03-2005



*[Handwritten signature]*

CESI TEST A4510783 oscillogram n. 18

**ВЯРНО С ОРИГИНАЛА**



*[Handwritten signature]*


Type confidential

Original Issue 03-2005

ВЯРНО С ОРИГИНАЛА


2 Acqs

Tek STOP 10.0MS/S



Ch1 500mV  $B_W$  Ch2 1.00 V  $B_W$  M 5.00 $\mu$ s Ch1  $\downarrow$  380mV





*Handwritten signature*

*Handwritten signature*


CESI-TEST A4510783 oscillogram n. 20

ВЯРНО С ОРИГИНАЛА



Too confidential

Original Issue 03-2005



ВЯРНО С ОРИГИНАЛА




TEST A4510783 oscillogram n. 21


Typo confidential

Original Issue 03-2005

На основание чл. 2  
от ЗЗЛД



CREEPAGE=265mm  
DRY ARC DIST=138mm



**ENERGY DIVISION**

**5kV 10kA DCP2 SURGE ARRESTER PRODUCT**

DRN	MALLICK	DATE	PCN	NUMBER	TITLE
DECK			HATL		
APP					
SCALE	2:5				

DESIGNED BY: [Signature]

DATE: [Date]

SCALE: 2:5

DRN: [Name]

PCN: [Number]

DATE: [Date]

NUMBER: [Number]

TITLE: 5kV 10kA DCP2 SURGE ARRESTER PRODUCT

DRN NO: [Number]

SHEET 1 OF 1



THIS DRAWING AND THE INFORMATION CONTAINED THEREIN ARE THE PROPERTY OF TUBO ELECTRONICS. ALL RIGHTS ARE RESERVED. NO PART OF THIS DRAWING OR THE INFORMATION CONTAINED THEREIN MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT PERMISSION IN WRITING BY TUBO ELECTRONICS.

[Handwritten signature]

ВЯРНО С ОРИГИНАЛА









Energy Division  
http://energy.tycoelectronics.com

## Electronics

### Bowthorpe EMP Test Report

Type	OCP2
PPR Number	PPR-1975
Test Specification	Accelerated ageing test of the resistor blocks IEC 60099-4 (2001-12)

#### Test Information:

Laboratory	CESI
Date	02/08/2004
External Test Ref	AT-A4517696

Report Prepared By	L. Podavitte
Test Verified by	A Sironi
Test Approved by	M de Nigris

#### Tyco Approvals:

R&D Manager	На основание чл. 2 от ЗЗЛД	Date	25/02/2005
Brendan Normoyle		Date	25/02/2005
Technology Manager		Date	25/02/2005
Kwong Tong		Date	25/02/2005
Product Manager		Date	25/02/2005
Brian McGowan		Date	25/02/2005

For further information contact:  
Tyco Electronics Energy Division  
Bay 100 - 109  
Shannon Industrial Estate  
Co. Clare, Ireland  
Tel: + 353-61-472885  
Fax: + 353-61-472676  
Email: mvsurgearresters@tycoelectronics.com

ВАРНО С ОРИГИНАЛА



Original Issue 03-2005

Tyco confidential

Original Issue 03-2005

client Tyco Electronics Energy Division - Shannon (IRL)

equipment under test Metal oxide resistors blocks section type OCP2

tests performed Accelerated ageing test of the resistor blocks

normative documents IEC 60099-4 (2001-12)

receipt date of the sample June 16 , 2004

test date from June 16, 2004 to August 02, 2004

no. of pages 14 no. of pages annexed 13

the test results relate only to the sample tested  
 this document shall not be reproduced except in full without the written approval of CESI

Very confidential

first issue date October 29 , 2004

prepared PeC/TEST - L

verified PeC/TEST - A

approved PeC/TEST - M

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



CESI  
 Centro Elettrotecnico  
 sperimentale Italiano  
 Giacinto Motte SpA

Via R. Rubattino 54  
 20134 Milano - Italia  
 Telefono +39 022125.1  
 Fax +39 0221255440  
 www.cesi.it

Capitale sociale 8 550 000 Euro  
 interamente versato  
 Codice fiscale e numero  
 iscrizione CCIAA 00793580150

Registro Imprese di Milano  
 Sezione Ordinaria  
 N. R.E.A. 429222  
 P.I. IT00793580150

tests witnessed by: /

Original Issue 03-2005

**identification of the object:** The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.

The drawings identified by CESI and numbered A4503147 n. 01, one page, is annexed to this document.



Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: ---

Type confidential

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with impulse current : peak value:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3 \%$
- dielectric tests with direct voltage : voltage:  $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

**laboratory information**

CESI testing team: L.Podavitte , M. Gregori  
I. Guacci

test laboratory: C228 Surge arrester laboratory

activity code: 389930

keywords: 12015R, 23810H, 31020W, 46030U, 53001D



ВЯРНО С ОРИГИНАЛА





contents	page	test date
Test object characteristics	4	
Reference standard	6	
Test carried out and identification	6	
Test procedure	6	
Summary of test results	7	
Power frequency voltage-current characteristics at ambient temperature	8	16/06/2004
Power frequency voltage-current characteristics at beginning test	9	21/06/2004
Power frequency voltage-current characteristics at end of test	10	02/08/2004
Technical data of test circuits	11	

page annexed: oscillograms n. 12 pages

- TYCO Drawing no.OCP2-5; CESI n. A5/004333 n. 01, one page

ВЯРНО С ОРИГИНАЛА



Test object characteristics

The test was carried out on three samples of resistor blocks section surrounded by the same material as in the actual surge arrester. A view of the test samples is shown on page 5. The characteristics of the test samples are listed in the tables below.

Type: metal oxide resistor blocks section

electrical characteristics (claimed by the client)

manufacturer's name of tested sections	Tyco Electronics Energy Division - Shannon (IRL)
line discharge class	2
nominal discharge current - $I_N$ [kA]	5
rated voltage - $U$ , [kV]	$0,98 * U_{ref}$
continuous operating voltage - $U_c$ [kV]	$0,784 * U_{ref}$
reference current - $I_{ref}$ , [mA]	5
rated frequency [Hz]	50
year of manufacture	2004

geometrical characteristics measured on tested section

total height [mm]	140
tube diameter [mm]	55


Original issue 09-2006

Tyco confidential

ВЯРНО С ОРИГИНАЛА



photograph of tested section



Original Issue 03-2005

Confidential

ВЪРНО С ОРИГИНАЛА



Reference standard

IEC 60099-4 (2001-12): " Metal-oxide surge arrester without gaps for a.c. system" - Clause 7.5.2

Test carried out and identification

Test carried out	Number of sample tested	test object identification
Accelerated ageing test	3	AG7 - AG8 - AG9

Test procedure

The test has been performed on three sample of resistor blocks sections surrounded by the same material as in the actual surge arrester.

The test voltage  $U_{ct}$  has been calculated as:

$$U_{ct} = K_c * 1.15 * U_{ref} = 0,784 * 1,15 * 6,58 = 5,93 \text{ kV}$$

where:

- $K_c$  is equal to the ratio  $U_c/U_{ref}$  claimed by the manufacturer
- 1.15 is the voltage unbalance factor as determined by the manufacturer
- $U_{ref}$  is the measured reference voltage

The test samples has been placed in separate chambers (not sealed) and then positioned in the oven The oven has been heated up to 115 °C and then the samples has been energized at a the power frequency voltage of 5,93 kV<sub>rms</sub> for a total duration of 1000 hours while maintained at a temperature of 115 °C ± 4 °C. Power losses and the temperature have been monitored continuously during the test (see oscillogram 10,11 and 12). More detailed data, are given for measurement carried out at the beginning (two hours after energization) and at the end of the test.

note: a scheme of test chamber and test oven are annexed to this test report in pag 11 and 12

Original issue 03-2005

For confidential

ВЯРНО С ОРИГИНАЛА



Summary of the test result

Details of the measurements carried out at the beginning (two hours after energization) and at the end of the test are given in the table below. The trend of the power losses monitored during the test is shown on the oscillogram n. 10, 11 and 12.

Metal-Oxide resistors n.	AG7	AG8	AG9
Ageing Test Voltage = $U_{test}$ (kV)	5,93		
$P_{1c}$ [W] (after 2 hours)	3,39	2,93	3,03
$T_{1c}$ [°C] (after 2 hours)	112,0	112,9	113,0
$P_{2c}$ [W] (after 1000 hours)	2,26	2,12	2,15
$T_{2c}$ [°C] (after 1000 hours)	113,9	115,3	115,9
$k_{ct} = P_{2c}/P_{1c}$	0,666	0,723	0,709

Evaluation criteria according to IEC 60099-4 (2001-12)

The ratio  $P_{2c}/P_{1c}$  was less than 1.0 for all samples.

Where:


$P_{2c}$  is the power losses measured at the end of the test

$P_{1c}$  is the power losses measured at the beginning of the test (two hours after energization)

No correction factor to the test voltage during the operating duty test relevant to the accelerated ageing test has to be applied.

Original Issue 02-2005

Type confidential





Accelerated ageing test. IEC 60099-4

Power frequency voltage-current characteristics at ambient temperature

test object: metal-oxide resistors blocks section  
test circuit: A019

date: June 16, 2004

Original Issue 03-2005

sample no. AG7						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	6,56	5,00	4,621	1,727	7,715	---

sample no. AG8						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
2	6,58	5,00	4,454	1,654	7,269	---

Type confidential

sample no. AG9						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	6,54	5,00	4,518	1,686	7,464	---

ВЯРНО С ОРИГИНАЛА



Accelerated ageing test. IEC 60099-4

Power frequency voltage-current characteristics at the beginning of the test

test object: metal-oxide resistor blocks section

test circuit: A019B

date: June 21,2004

sample no. AG7					
oscillogram.	voltage	current	current	power	Temperature
n.	kV	+ mA <sub>gr</sub>	- mA <sub>gr</sub>	W	°C
4	5,93	1,74	1,62	3,39	112,0

sample no. AG8					
oscillogram.	voltage	current	current	power	temperature
n.	kV	+ mA <sub>gr</sub>	- mA <sub>gr</sub>	W	°C
5	5,93	1,53	1,46	2,93	112,9

sample no. AG9					
oscillogram.	voltage	current	current	power	temperature
n.	kV	+ mA <sub>gr</sub>	- mA <sub>gr</sub>	W	°C
6	5,93	1,55	1,49	3,03	113,0

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005  
Top Confidential

Accelerated ageing test. IEC 60099-4

Power frequency voltage-current characteristics at the end of the test

test object: metal oxide resistor blocks section

test circuit: A019B

date: August 02, 2004

Original Issue 03-2005

sample no. AG7					
oscillogram.	voltage	current	current	power	Temperature
n.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	W	°C
7/10	5,93	1,23	1,15	2,26	113,9

sample no. AG8					
oscillogram.	voltage	current	current	power	temperature
n.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	W	°C
8/11	5,93	1,11	1,09	2,26	115,3



Too confidential

sample no. AG9					
oscillogram.	voltage	current	current	power	temperature
n.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	W	°C
9/12	5,93	1,09	1,08	2,15	115,9

ВАРНО С ОРИГИНАЛА



General scheme of the chamber



all dimension are in cm.


Original Issue 03-2005

This is confidential

ВЯРНО С ОРИГИНАЛА



Disposition of the chamber in test oven



Original Issue 03-2003


Type confidential

no gas has been used since the test was carried out in open air

ВЯРНО С ОРИГИНАЛА



**circuit A019**



**power  
frequency supply**

RE : programmable supply CESI no. 23702-32191 ; type Larcet A.C. Power Source 5000 P.S.  
 PC : personal computer  
 T : transformer type SPECIAL TRAF0 ; power 30 kVA ; voltage 220V/ 15 kV

current shunt (R) CESI no.11536 ;  $R = 100,4 \Omega$  ;  
 oscilloscope CESI no. 30223-30224  
 type DATA PRECISION DATA 6100

voltage divider (D) CESI no.11120  $k=1010$   
 electro optical system CESI no.11521/522 ; attenuation 50:5  
 oscilloscope CESI no. 30223-30224  
 type DATA PRECISION DATA 6100


Original issue 02-2006

Type confidential

ВАРНО С ОРИГИНАЛА



circuit A019B



Original Issue 03-2005

Very confidential

**power frequency supply**

RE : power supply

T : transformer type PIVI ; power 10 kVA ; voltage 220 V/ 12,5 kV

current shunt (R) R = 1000 Ω ; type SECI

voltage transformer (D) CESI 30000:100



acquisition system type NATIONAL INSTRUMENTS SCXI-1001

ВЯРНО С ОРИГИНАЛА



Original Issue 09-2005

Type confidential



10 kA Sample 1 Class 2

ВЯРНО С ОРИГИНАЛА





CESI PeC A4517696 oscillogram n. 1



Original Issue 03-2005

True confidential



10 kA Sample 2 Class 2



CESI PeC A4517696 oscillogram n. 2

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Type confidential



10 kA Sample 3 Class 2

ВАРНО С ОРИГИНАЛА



CESI PeC A4517696 oscillogram n. 3



Very confidential

Original Issue 03-2005




CESI РеС А4517696 oscillogram n. 4

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005


Original Issue 03-2005



ESI PeC A4517696 oscillogram n. 5

Original Issue 03-2005

Two confidential



*[Handwritten signature]*

CESI PeC A4517696 oscillogram n. 6


**ВЯРНО С ОРИГИНАЛА**



*[Handwritten signature]*

Original Issue 09-2005

09-2005



ВЯНО С ОРИГИНАЛА



CESI PeC A4517696 oscillogram n. 7


Very confidential

Original Issue 03-2005

CESI PeC A4517696


oscillogram n. 8

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very Confidential



ВЯРНО С ОРИГИНАЛА




CESI PeC A4517696 oscillogram n. 9



Very confidential

Original Issue 03-2005

### Accelerated ageing test sample n. 1



Date


CESI PeC A4517696 oscillogram n. 10

ВЯРНО С ОРИГИНАЛА



Світлофор №851 з 00-20000

### Accelerated ageing test Sample n.2




ВЯРНО С ОРИГІНАЛОМ



Very confidential

Original Issue 03-2005

### Accelerated ageing test Sample n.3



Date

CESI PeC A4517696

oscillogram n. 12




**ВЯРНО С ОРИГИНАЛА**



PRODOTTORE: S. PIGNATI  
 MODELLO: 02-0002  
 C. PIGNATI

PROTODOLLO DATA  
 A. W. 5681477 09 MAG. 2004

Firma: *Staco S.p.A.*



CREEPAGE=265mm  
 DRY ARC DIST=138mm

ВАРНО С ОРИГИНАЛА



**ELCO ELECTRONICS**

ENERGY DIVISION

5KV 10kA DCP2 SURGE ARRESTER PRODUCT

CREPAGE=265mm  
 DRY ARC DIST=138mm

DATE: 09 MAG. 2004

SCALE: 2:1

NO. 02-0002

SHEET 1 OF 1



Energy Division  
http://energy.tycoelectronics.com

## Electronics

### Bowthorpe EMP

### Test Report

Original Issue 03-2005

Type	OCP2
PPR Number	PPR-1976
Test Specification	Short Circuit Tests IEC 60099-4 (2004-05)

#### Test Information:

Laboratory	CESI
Date	11/11/2004
External Test Ref	A4/522781
Report Prepared By	P Beccarini
Test Verified by	A Sironi
Test Approved by	V Scarioni

#### Tyco Approvals:

R&D Manager	На основание чл. 2 от ЗЗЛД	Date	25/02/2005
Brendan Normoyle		Date	25/02/2005
Technology Manager		Date	25/02/2005
Kwong Tong		Date	25/02/2005
Product Manager		Date	25/02/2005
Brian McGowan		Date	25/02/2005

Tyco confidential

For further information contact:  
 Tyco Electronics Energy Division  
 Bay 100 - 109  
 Shannon Industrial Estate  
 Co. Clare, Ireland  
 Tel: + 353-61-472885  
 Fax: + 353-61-472676  
 Email: mvsurgearresters@tycoelectronics.com

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Client TYCO ELECTRONICS ENERGY DIVISION  
Shannon - IRELAND

Tested equipment Polymeric housed metal-oxide surge arrester  
Type OCP2

Tests carried out Short-circuit tests

Standards/Specifications IEC 60099-4 (2004)

Test date from November 10, 2004 to November 11, 2004

The results reported in this document relate only to the tested equipment.  
Partial reproduction of this document is permitted only with the written permission from CESI

Confidential

No. of pages 22 No. of pages annexed 13

Issue date December 15, 2004

Prepared PeC - P. BECCA

Verified PeC - A. SIRONI

Approved PeC - M. de NICOLA

На основание чл. 2  
от ЗЗЛД

На основание чл. 2  
от ЗЗЛД

//

ВЪРНО С ОРИГИНАЛА



Via R. Rubattino 54  
20134 Milano - Italia  
Telefono +39 022125.1  
Fax +39 0221255440  
http://www.cesi.it

Capitale sociale 8 550 000 Euro  
Interamente versato  
Codice fiscale e numero  
iscrizione CCIAA 00793580150

Registro Imprese di Milano  
Sezione Ordinaria  
N. R.E.A. 429222  
P.I. IT00793580150

Tests witnessed by

Mr. Normoyle Brendan TYCO  
Ms. Claire O'Keeffe TYCO

Identification of the object effected.

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawing identified by CESI and numbered A4/522916 No.1 is annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: A4/518477

The measurement uncertainties of the test results reported in the document are the following:

voltage: ± 5 % ; current: ± 5 % ; time: ± 5 % ; temperature: ± 2 °C

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

Receipt date of the sample November 3, 2004

Activity code 43160L



ВЯРНО С ОРИГИНАЛА



Original issue 03-2005

Very confidential

Contents	Page	Test date
<p>Rated characteristics of the tested object assigned by the Client</p> <p>Test arrangement</p> <p>Tests performed</p> <ul style="list-style-type: none"> <li>High-current short-circuit test with 25,2 kA for 0,20 s</li> <li>High-current short-circuit test with 39,2 kA for 0,20 s</li> <li>High-current short-circuit test with 13,0 kA for 0,20 s</li> <li>Low-current short-circuit test with 0,62 kA for 1,00 s</li> </ul> <p>Test circuit</p> <p>Photos</p> <p>Pages annexed</p> <p>Oscillograms (No.12)</p> <p>Reference documents annexed</p> <p>Drawing No. MY-ОСР2-00107-S-2 - CESI Ref.No.-A4/522916 (No.1 page)</p>	<p>4</p> <p>5</p> <p>6</p> <p>7</p> <p>8</p> <p>9</p> <p>10</p> <p>11 to 22</p>	<p>November 10, 2004</p> <p>November 11, 2004</p> <p>November 11, 2004</p> <p>November 11, 2004</p>

ВЯРНО СОПТИМАЛА






Rated characteristics of the tested object assigned by the Client

Metal-oxide surge arrester	
Manufacturer	BOWTHORPE
Type	OCP2
Drawing	MV-OCP2-00107-S-2
Rated voltage (Ur)	36,25 kV
Maximum continuous operating voltage (Uc)	29 kV
Rated frequency	50/60 Hz
Nominal discharge current (8/20 $\mu$ s impulse shape)	10 kA
Pressure relief class	
High current	for 0,2 s ; 40,0 kA
Low current	for 1,0 s ; 0,60 kA

Original Issue 03-2005

yes confidential




ВЯРНО С ОРИГИНАЛА



D8000 - Test arrangement

Original Issue 08-2005



- 1 : Surge arrester
- 2 : Flexible conductor
- 3 : Rigid conductor
- 4 : Support
- 5 : Circular enclosure

- A : 1,0 m
- B : 0,4 m
- C : 1,8 m

The arrester to be tested was fixed on a support at 0,4 m to ground in the middle of a circular enclosure of 1,8 m in diameter. The live side of the supply was connected to the upper end of the arrester while the return circuit, earthed, was connected to the lower end.

ВЯРНО С ОРИГИНАЛА



**High-current short-circuit test with 25,2 kA for 0,20 s**

**Test circuit :** See D0046 Power factor : <0,15 Frequency : 50 Hz

**Test arrangement :** See D8400 and photo No.1

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source.

The short-circuit current of the auxiliary low power source has been set at about 11,0 A

The voltage applied to the arrester was risen in order to get a current equal to 50mA (0-peak)(i.e. 54kVpk) and kept at this value till arrester failure.

The pre-failure process duration was 8 minutes and 30 seconds.

The short-circuit test was performed 15minutes after the completion of the pre-failure process.

Condition of the apparatus before the tests: new, see photo No.2.

Date: November 10, 2004

Test No.	Oscillogram No.	Arrester under test No.	Duration s	Test voltage kV	Test current		Venting time	Notes
					Peak value kA	rms value kA		
1	6	OCP2	0,20	24,5	46,6	25,2	ms 0,9	No. -

Oscillogram No.	Sheets	Prospective test current	
		rms value kA	Peak value kA
4	1	25,2	65,6

Condition of the apparatus after the tests: see photos No.3 and 4.

- The arrester structure remained almost intact.
- The arrester remained connected to the supply and return circuit.
- No fragment were found inside or outside the circular enclosure.
- No flame was noted after the test.

**ВАРНО С ОРИГИНАЛА**



*[Handwritten signature]*

**Test Report**

**CESI**

Approved

**High-current short-circuit test with 39.2 kA for 0,20 s**

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz;

Test arrangement : See D8000

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source. The short-circuit current of the auxiliary low power source has been set at about 9,00 A. The voltage applied to the arrester was risen in order to get a current equal to 50mA (0-peak)(i.e. 54kVpk) and kept at this value till arrester failure. The pre-failure process duration was 7 minutes and 0 seconds. The short-circuit test was performed 9 minutes after the completion of the pre-failure process.

Condition of the apparatus before the tests: new, see photo No.5.

Date: November 11, 2004

Test No.	Oscillogram		Arrester under test No.	Duration s	Test voltage kV	Test current		Venting time	Notes
	No.	Sheets				Peak value kA	rms value kA		
2	21	2	OCP2	0,20	24,5	102	39,2	1,1	-

Condition of the apparatus after the tests: see photos No.6 and 7.

- The arrester structure remained almost intact.
- The upper connection was found detached due to melting of the stud.
- No fragment were found inside or outside the circular enclosure.
- No flame was noted after the test.

ВЯРНО С ОРИГИНАЛА



No.	Oscillogram		Prospective test current	
	Sheets	kA	rms value	Peak value
19	1	43,3	kA	121

Very confidential

Original Issue 03-2005

**High-current short-circuit test with 13.0 kA for 0.20 s**

Test circuit : See D0046 Power factor : < 0,15 Frequency : 50 Hz

Test arrangement : See D8800

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source. The short-circuit current of the auxiliary low power source has been set at about 11.0 A. The voltage applied to the arrester was risen in order to get a current equal to 50mA (0-peak)(i.e. 54 kVpk) and kept at this value till arrester failure. The pre-failure process duration was 5 minutes and 30 seconds. The short-failure test was performed 10 minutes after the completion of the pre-failure process.

Condition of the apparatus before the tests: new, see photo No.8.

Date: November 11, 2004

Test No.	Oscillogram		Arrester under test No.	Duration s	Test voltage kV	Test current		Venting time ms	Notes
	No.	Sheets				Peak value kA	rms value kA		
3	25	2	OCP2	0,20	24,5	30,4	13,0	1,2	-

Condition of the apparatus after the tests: see photos No.9 and 10.

- The arrester structure remained almost intact.
- The arrester remained connected to the supply and return circuit.
- No pieces were projected inside or outside the circular enclosure.
- No flame was noted after the test.

**ВРЪНС С ОРИГИНАЛА**



*by*

**CESI**

**Low-current short-circuit test with 0.62 kA for 1,00 s**

Test circuit : Sec.D0046 Power factor : < 0,15 Frequency : 50 Hz

Test arrangement : See D8000

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source. The short-circuit current of the auxiliary low power source has been set at about 11,0 A. The voltage applied to the arrester was risen in order to get a current equal to 50mA (0-peak)(i.e. 54 kVpk) and kept at this value till arrester failure. The pre-failure process duration was 5 minutes and 50 seconds. The short-circuit test was performed 9 minutes after the completion of the pre-failure process.

Condition of the apparatus before the tests: new, see photo No.11.

Date: November 11, 2004

Test No.	Oscillogram		Arrester under test No.	Duration s	Test voltage		Test current		Venting time	Notes	
	No.	Sheets			Peak value	rms value	Peak value	rms value			
4	32	2	OCP2	1,00	kV	24,5	kA	0,62	ms	2,90	No.
											-

Condition of the apparatus after the tests: see photo No.12.


- The arrester structure remained almost intact.
- The arrester remained connected to the supply and return circuit.
- No pieces were projected inside or outside the circular enclosure.
- No flame was noted after the test.

ВЪРНО С ОРИГИНАЛА



Original Issue 13-2005

Test circuit D0046



Symbols used in this diagram are the same as those on the oscillograms.

Very confidential

ВЯРНО С ОРИГИНАЛА



Създадено: 2006-03-23 10:05




Photo no. 1

ВЯРНО С ОРИГИНАЛА





Original Issue 03-2005

type confidential




Photo no. 2

ВЯРНО С ОРИГИНАЛА



001-001-001-001-001-001




Photo no. 3

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very confidential




Photo no. 4

ВЪРНО С ОРИГИНАЛА









Photo no. 5

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very confidential



*[Handwritten signature]*

Photo no. 6

*[Handwritten mark]*  
**ВЯРНО С ОРИГИНАЛА**



Original Issue 15-2005

Very confidential





Photo no. 7

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Typo confidential



A handwritten signature or set of initials in black ink, located below the photograph.

Photo no. 8

ВЯРНО С ОРИГИНАЛА





Original Issue 03-2005

Very confidential




Photo no. 9


ВЯРНО С ОРИГИНАЛА





Original Issue 03-2005

Very confidential



Handwritten signature.

Photo no. 10

Handwritten signature.

Stamp: ВЪРНО С ОРИГИНАЛА (True to original)

Stamp: АКЦИОНЕРНО ФИЛКАЕ 16 ПЛОВДИВ

Original issue 30-2005





Photo no. 11

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very confidential



*Handwritten signature*

Photo no. 12

ВЯРНО С ОРИГИНАЛА

АКЦИОНЕРНО СЪОБЩЕСТВО  
ФИЛКАБ  
16  
ПЛОВДИВ

I<sub>peak</sub> = 65,63 kA  
dt = 204,1 mSec

Original Issue 03-2004

Very confidential


U 30 kV

ВЯРНО С ОРИГИНАЛА

135 kA




VENT 4 V



CESI P141 A4/518477-0004

Sec: 1SEC Osc: 0 Meas: HF1 - 1



Seq: 1SEC Osc: 0 Meas: HF1 - 1


CESI P141 A4/518477-0006

ВЯРНО С ОРИГИНАЛА

17538A

АКЦИОНЕРНО С.О.О.О.  
ФИЛКАЕ  
16  
ПРОБЛЕМ

I: peak = 46,60 kA  
dT = 926,7 uSec



U 45 kV

ВЯРНО С ОРИГИНАЛА

1,25 kA




VENT 4 V

33,633 40,000 45,000 50,000 55,000 60,000 65,000 70,000 75,000 80,000 85,000 90,000 95,000 100,000 106,157  
0,500 [msec/div.]

CESI P141 A4/518477-0006

Original Issue 03-2011  
I<sub>peak</sub> = 121,30 kA

I<sub>rms</sub> = 43,43 kA



30,000 60,000 80,000 100,000 120,000 140,000 160,000 180,000 200,000 220,000 240,000 253,023  
2,000 [msec/div.]  
Seq: 1SEC Osc: 0 Meas: HF1 - 1

U 30 kV  
ВЯНО С ОРИГИНАЛА


I 60 kA



VENT 4 V

CESI P141 A4/518477-0019

dt = 211,2 mSec



U 30 kV

ВАРНО С ОРИГИНАЛА

1807A



VENT 4 V

35,077 60,000 80,000 100,000 120,000 140,000 160,000 180,000 200,000 220,000 240,000 260,053  
2,000 [msec/div.]

CESI P141 A4/518477-0021

Sec: 1SEC Osc: O Meas: HF1 - 1




U 30 KV

ВЯРНО С ОРИГИНАЛА

I 60 KA



VENT 4 V



Very confidential

Original Issue 03-2000

dT = 200,6 mSec  
I<sub>peak</sub> = 36,20 kA  
I<sub>rms</sub> = 13,25 kA

U 30 kV


ВЯРНО С ОРГИНАЛА

*[Signature]*

I 15 kA



VENT 4 V



26,377 40,000 60,000 80,000 100,000 120,000 140,000 160,000 180,000 200,000 220,000 240,000 253,437  
2,000 [msec/div.] Seq: 1SEC Osc: 0 Meas: HF1 - 1

CESI P141 A4/518477-0023

Original Issue 03-2012 200,5 mSec

Typo confidential

*Handwritten signature*

U 30 kV

**ВАРНО С ОРИГИНАЛА**


*Handwritten signature*

I 15 kA



*Handwritten signature*


VENT 4 V



CESI P141 A4/518477-0025

Seq: 1SEC Osc: 0 Meas: HF1-1

I. peak = 30,38 kA  
dT = 1,2 mSec



35,463 40,000 45,000 50,000 55,000 60,000 65,000 70,000 75,000 80,000 85,000 90,000 95,000 100,487  
0,500 [msec/div.]  
Set: 1SEC Out: 0 Meas: HF1 - 1

U 30 kV

ВЯРНО С ОРИГИНАЛА

I 15 kA



VENT 4 V

CESI P141 A4/518477-0025

Original Issue 03.2005  
I<sub>rms</sub> = 622,83 A  
dt = 1,006 Sec

True confidential

*Handwritten signature*


U 30 KV

**ВЯРНО С ОРИГИНАЛА**

*Handwritten signature*  
10,70KA



*Handwritten signature*  
VENT 4 V



22,190 100,000 200,000 300,000 400,000 500,000 600,000 700,000 800,000 900,000 1000,000 1083,045  
10,000 [msec/div.]

**CESI** P141 A4/518477-0030

Seq: 1SEC Osc: 0 Meas: HF1 - 1

Very confidential


Original Issue 03.2004 dT: 1.001 Sec

U 30 kV

ВЯРНО С ОРИГИНАЛА



VENT 4 V



30,000 100,000 200,000 300,000 400,000 500,000 600,000 700,000 800,000 900,000 1,000,000 1,087,860  
10,000 [msec/div.]

CESI P141 A4/518477-0032

Sec: 18SEC Osc: 0 Meas: HF1 - 1

Original Issue 03.2012 2.9 mSec

Very confidential

*Handwritten signature*


U 30 kV

**ВЯРНО С ОРИГИНАЛА**

I 0,70 kA



VENT 4 V




30,720 40,000 50,000 60,000 70,000 80,000 90,000 100,000 109,240

CESI P141 A4/518477-0032


Set: 15EC Osc: 0 Meas: HF1 - 1

Original Issue 03-2003

SCD



NOTE:-  
 UC = 29KV  
 NOM CREEPAGE = 885mm  
 NOM DRY ARC DIST = 334mm  
 CANT. STRENGTH = 350Nm  
 TENSION STRENGTH = 2kN  
 TORQUE = 50Nm  
 HIGH SHORT CIRCUIT = 40KA  
 LOW SHORT CIRCUIT = 600A



ВЯРНО С ОРИГИНАЛА

ORIGINAL

PHOTO-COLO

№ 5 2 2 0 1 6 n.1 14 088 2004

На основание чл. 2  
от ЗЗЛД



REV/DATE	DESIGN	MODIFICATION	APP
0	04/01/04	INITIAL ISSUE	
1	04/01/04	TECHNICALS ADPT	
2	04/01/04	PROTECTIVE ANCHORAGE FROM DESIGN 03/2003	

DRN	J	MILLICAN	17/04/04	POK	**
CHECK	3	HONORARY			MATL.
APP	3	DESIGNER			
SCALE	2:5				

ION  
 de EMP  
 BONDURGE DUP  
 BAY 100-100  
 CHAMBER NO. EST.  
 DO. CLUSE  
 BELAND

-29S  
 ARRESTER

SHEET 1 OF 1  
 2





Energy Division  
http://energy.tycoelectronics.com

## Electronics

### Bowthorpe EMP

## Test Report

Type	OCP2
PPR Number	PPR-1824
Test Specification	Internal Partial discharge tests IEC 60099-4 (2001-12)

#### Test Information:

Laboratory	CESI
Date	28/04/2004
External Test Ref	AT-A4/014190

Report Prepared By	D Pirola
Test Verified by	A Sironi
Test Approved by	M de Nigris

#### Tyco Approvals:

<b>R&amp;D Manager</b>			
Brendan Normoyle	Si	На основание чл. 2 от ЗЗЛД	Date 25/02/2005
<b>Technology Manager</b>			
Kwong Tong	Si		Date 25/02/2005
<b>Product Manager</b>			
Brian McGowan	Si		Date 25/02/2005

For further information contact:  
 Tyco Electronics Energy Division  
 Bay 100 - 109  
 Shannon Industrial Estate  
 Co. Clare, Ireland  
 Tel: + 353-61-472885  
 Fax: + 353-61-472676  
 Email: mvsurgearresters@tycoelectronics.com

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Tyco Confidential

Original Issue 03-2005

client **TYCO, Electronics Energy Division - Shannon (Ireland)**

equipment under test **Polymer housed metal-oxide surge arrester,  
type OCP2 10 kA**

tests performed **Internal partial discharges tests**

normative documents **IEC 60099-4 (2001-12)**

receipt date of the sample **April 27, 2004**

test date **from April 28, 2004 to April 28, 2004**

no. of pages **11** no. of pages annexed **04**

the test results relate only to the sample tested  
this document shall not be reproduced except in full without the written approval of CESI

Very confidential

first issue date **June 10, 2004**

prepared **PeC/TEST -**

verified **PeC/TEST -**

approved **PeC/TEST -**

На основание чл. 2  
от ЗЗЛД



CESI  
Centro Elettrotecnico  
Sperimentale Italiano  
Giacinto Motta SpA

Via R. Rubattino 54  
20134 Milano - Italia  
Telefono +39 022125.1  
Fax +39 0221255440  
www.cesi.it

Capitale sociale 8 550 000 Euro  
Interamente versato  
Codice fiscale e numero  
Iscrizione CCIAA 00793580150

Registro Imprese di Milano  
Sezione Ordinaria  
N. R.E.A. 429222  
P.I. IT00793580150

tests witnessed by: ---

Identification of the object: effected

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that these drawings adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawings identified by CESI and numbered A4/509282 no. 01 are annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with alternating voltage : voltage (rms):  $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.


laboratory information

CESI testing team: L. Tiziani

test laboratory: P180

activity code: 43160L

ВЯРНО С ОРИГИНАЛА



Original Issue 05-2005

Very Confidential

Very confidential

Original Issue 03-2005


contents	page	test date
Test object characteristics	4	
Panoramic views	5 - 6	
Reference standard and test carried out	7	
Test procedure and summary of Test result	8	
Measurement of partial discharges	9	April 28, 2004
Test circuits	10 - 11	

**Page annexed:**

oscillograms (03 pages)

**Reference document annexed:**

Manufacturer's drawing of surge arrester type OCP2 identified by CESI and numbered as A4/509282, no. 01



**Test Report**



Test object characteristics

type: Polymer housed metal oxide surge arrester

electrical characteristics (claimed by the client)

type	OCP2 10 kA
manufacturer's name	TYCO Electronics Energy division
line discharge class	2
rated voltage - $U_n$ [kV]	30,0
continuous operating voltage - $U_c$ [kV]	24,0
rated frequency - [Hz]	50-60
year of manufacture	2004

geometrical characteristics (measured on the test sample)

total height [mm]	385
arcing distance [mm]	295
creepage (leakage) distance [mm]	760
number of large sheds	6
large shed diameter [mm]	117
number of small sheds	5
small shed diameter [mm]	97
core dimensions [mm]	55 x 55

other characteristics

housing material	polymeric
housing color	grey

Original Issue 03-2005

Tyco confidential


ВАРНО С ОРИГИНАЛА



panoramic view of the test object

Original № 03-2006

For confidential




ВЯРНО С ОРИГИНАЛА

АКЦИОНЕРНО ДРУЖЕСТВО  
ФИЛКАБ  
16  
ПЛОВДИВ \*

panoramic view of the test arrangement for partial discharges test

Original Issue 03-2005

Typo confidential



*Handwritten signature*

*Handwritten signature*

*Handwritten signature*

ВЯРНО С ОРИГИНАЛА

*Handwritten signature*



Reference standard

IEC 60099-4 (2001-12)  
IEC 60270 (2000-12)

Test carried out

polymer housed metal-oxide surge arrester unit	test carried out
type OCP2	Partial discharge test

Original Issue 03-2005

True confidential

ВЯРНО С ОРИГИНАЛА





Test procedure

The application voltage has been increased up to rated voltage ( $U_r$ ) and maintained for 10 sec.  
The voltage has been decreased to 1,05 times the continuous operating voltage ( $U_c$ ) and the partial discharge level has been measured according to the reference standard (IEC 60270).

Summary of test results

The partial discharge level found was less than 1 pC (background noise).  
The test result is to be considered positive.

Original Issue 05-2005

Type confidential

ВЯРНО С ОРИГИНАЛА



**Measurement of partial discharges**

test object: polymer housed metal oxide surge arrester type OCP2 10 kA  
 test circuit: A022  
 measurement circuit: A027

atmospheric conditions		
b	t	h
kPa	°C	g / m³
100,3	20 (15)	10,1

date: April 28, 2004

	applied voltage	duration of voltage application	temperature of the test object	partial discharge measurement		oscillogram	note
				voltage increase	voltage decrease		
	kV <sub>rms</sub>	sec	°C	Q max	Q max		
Background noise	0		20	pC	pC	no.	
				≤ 1		02	
U <sub>r</sub>	30,0	10	20				
1,05 U <sub>c</sub>	25,2	measure	20	≤ 1	≤ 1	03	

oscillogram 01: test circuit calibration


КОПИЈА С ОРИГИНАЛА



**Test Report**

Circuit A027

Plant P220. High voltage circuit  
partial discharges measurement



- F : wide band filter TELEC; 380 V; 100 A
- G : Faraday cage
- S : single phase circuit breaker SACE; 600 V; 400 A
- R : regulator CORMES; power 66 kVA; voltage 380 V/0 ÷ 220 V
- T : booster transformer PIVI; power 250 kVA; voltage 200-400 V/250 kV
- C<sub>k</sub> : coupling capacitor PIVI; 300 pF; 250 kV
- TA : current transformer CGS; ratio 150-300 A/5 A
- TV<sub>1</sub>: voltage transformer 440/100 V
- V<sub>1</sub> : analogic voltmeter
- TV<sub>2</sub>: voltage transformer PIVI; ratio 250 kV/100 V
- V<sub>2</sub> : voltmeter FLUKE; CESI no. 06393

Original Issue 03-2005

Type Confidential


ВЯРНО С ОРИГИНАЛА



Circuit A022

Partial discharges measurement

Direct circuit - scheme 1a



- P: calibrator
- C<sub>k</sub>: coupling capacitor PIVI; 300 pF; 250 kV
- AKV: matching coupling quadrupole HAEFELY TRENCH; type AKV 573; CESI No.13290
- K: special, multi-wire, connecting cable (AKV KB)
- PD: partial discharge detector HAEFELY TRENCH; type PD DETECTOR TE 571; CESI No.13281

ВЯРНО С ОРИГИНАЛА



Original Issue 02-2005

Type confidential

HAEFELY TRENCH TETTEX

PD-DETECTOR

Info: 1

Start date: 00.00.00

Measurement name:

Start time: 00:00

Comment:

1st PD Range: 20 pC

2nd PD Range: Not applied

Noise Suppression: 5 %

Lockout Time: 7.3 usec


Test Measuring Time: 15 s

Voltage Range: 35 kV

Remarks:

Original Issue No 03-2005

type certificate



*Handwritten signature*


CESI TEST AT-A4/014190 oscillogram 01

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very Confidential




CESI TEST AT-A4/014190 oscillogram 02

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

tyco confidential



*MB*

*BY*

CESI TEST AT-A4/014190 oscillogram 03


ВЯРНО С ОРИГИНАЛА



Type confidential


Original Issue 02-2005

SCD



На основание чл. 2  
от ЗЗЛД

NOTE:-  
 Uc = 24kV  
 NOM CREEPAGE = 758mm  
 NOM DRY ARC DIST = 293mm  
 CANT. STRENGTH = 350Nm  
 TENSION STRENGTH = 2kN  
 TORQUE = 50Nm  
 HIGH SHORT CIRCUIT = 40KA  
 LOW SHORT CIRCUIT = 600A



ВЯРНО С ОРИГИНАЛА



REV	DATE	DESIGN	MODIFICATION	ISSUE
0	04/04	04	ORIGINAL	ISSUE

THE DRAWING AND THE INFORMATION SET THEREON ARE THE PROPERTY OF TUPRO ELECTRONICS LTD. ANY REPRODUCTION, STORAGE, DISTRIBUTION, OR USE OF THIS DRAWING OR INFORMATION SET WITHOUT THE EXPRESS WRITTEN PERMISSION OF TUPRO ELECTRONICS LTD IS PROHIBITED.

DRN	J. WILKINSON	23/04/04	POB	*****-000	TITLE
CHECK	NORMAN				
APP	B. MCGOWAN				
SCALE		2:5			

OCP2-24S  
SURGE ARRESTER

ENG NO: MV-0CP2-00027-S  
SHEET 1 OF 1

WILKINS DAP  
MANAGER  
SHAWEN RD, EST.  
OL CLARE  
IRELAND

WILKINS DIVISION  
Bourthorpe EMP





Energy Division  
http://energy.tycoelectronics.com

## Electronics

### Bowthorpe EMP

## Test Report

Type OCP2  
 PPR Number PPR-1977  
 Test Specification Power frequency voltage versus time test  
 IEC 60099-4 (2004-05)

#### Test Information:

Laboratory CESI  
 Date 09/12/2004  
 External Test Ref A4/521820

Report Prepared By M Gregori  
 Test Verified by A Sironi  
 Test Approved by M de Nigris

#### Tyco Approvals:

R&D Manager	На основание чл. 2 от ЗЗЛД	Date	25/02/2005
Brendan Normoyle		Date	25/02/2005
Technology Manager		Date	25/02/2005
Kwong Tong		Date	25/02/2005
Product Manager		Date	25/02/2005
Brian McGowan		Date	25/02/2005

For further information contact:  
 Tyco Electronics Energy Division  
 Bay 100 - 109  
 Shannon Industrial Estate  
 Co. Clare, Ireland  
 Tel: + 353-61-472885  
 Fax: + 353-61-472676  
 Email: mvsdrgearresters@tycoelectronics.com

ВАРНО С ОРИГИНАЛА



Original Issue 06-2005

Tyco Confidential

Original Issue 03-2005

Client TYCO Electronics Energy Division – Shannon (IRL)

Tested equipment Polymer housed metal-oxide surge arrester type OCP2

Tests carried out Power frequency voltage versus time test

Standards/Specifications IEC 60099-4 (2004-05)

Test date from December 03, 2004 to December 09, 2004

The results reported in this document relate only to the tested equipment.  
Partial reproduction of this document is permitted only with the written permission from CESI.

Also confidential

No. of pages 16 No. of pages annexed 27

Issue date December

Prepared BU PeC -

Verified BU PeC -

Approved BU PeC -

На основание чл. 2  
от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



Via R. Rubattino 54  
20134 Milano - Italia  
Telefono +39 022125.1  
Fax +39 0221256440  
http://www.cesi.it

Capitale sociale 8 550 000 Euro  
interamente versato  
Codice fiscale e numero  
iscrizione CCIAA 00793580150

Registro Imprese di Milano  
Sezione Ordinaria  
N. R.E.A. 429222  
P.I. IT00793580150

Tests witnessed by: ---

Identification of the object:

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing.  
CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.  
This drawing, identified by CESI and numbered A4503147 No. 1, is annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked: ---

- dielectric tests with impulse voltage : peak voltage:  $\pm 3 \%$ ; time parameters:  $\pm 10 \%$
- dielectric tests with impulse current : peak value:  $\pm 3 \%$ ; time parameters:  $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3 \%$
- dielectric tests with direct voltage : voltage:  $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values

Laboratory information

Receipt date of the sample

Test location CESI - Via Rubattino 54 - Milan

CESI testing team Mr L. Podavitte

Test laboratory P177

Activity code 43160L



Original Issue 03-2006

Two confidential

content	page	test date
Test object characteristics	4	
Panoramic view of the test object	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Summary of test results	7	
Power frequency voltage-current characteristics	8	December 03, 2004
Power frequency voltage versus time test	9 - 11	December 05-09, 2004
Technical data of the test circuit	13 - 16	
Pages annexed:		
Oscillograms n. 24 pages		
TYCO drawing n. OCP2-5, CESI n. A4503147, n. 1 page		
TYCO document n. 041103/OCP2-THC (thermal equivalency); CESI n.524527, n.1 page		
TYCO Technical data n. 041202/OCP2 TOV curve V.4; CESI n. A4524512, n.1 page		

**ВЯРНО С ОРИГИНАЛА**



Test object characteristics

type: Polymer housed metal-oxide surge arrester section (thermal equivalent)

electrical characteristics (assigned by the client)

manufacturer's name	TYCO Electronics Energy division - Shannon (IRL)
nominal discharge current - $I_N$ [kA]	10,0
rated voltage - $U_r$ [kV]	0,980 x $U_{ref}$ .
continuous operating voltage - $U_c$ [kV]	0,784 x $U_{ref}$ .
reference current - $I_{ref}$ [mA]	5,0
line discharge class	2
rated frequency - [Hz]	50 - 60
year of manufacture	2004

geometrical characteristics (measured on the test sample)

height [mm]	139
number of sheds	n.2 large- n.1 small
shed diameter [mm]	118 large - 96 small

other characteristics

housing material	silicone
housing color	grey

NOTE: The surge arresters were tested with the additional thermal insulation supplied by the Client. The verification of the thermal equivalency according to annexe B was carried out by the Client (see report n.A4524527)

Upon Client request the test was carried out with an energy equal to 15,5 kJ for each single shot applied. The approach is different from the IEC approach for class 2 surge arresters ( based on the calculated energy) and results is an higher energy ( see CESI report A4/503158). The test is therefore more severe.

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Type Confidential

Original Issue 12-2005

Original Issue 12-2005




Photo no. 1  
Photograph of the prorated section

ВЯРНО С ОРИГИНАЛА



Reference standard

The test was carried according to the IEC 60099-4 (2004) Standard – Annexed D

“Metal-oxide surge arrester without gaps for a.c. system “

Test carried out

test carried out	number of sample tested
power frequency voltage versus time test	3

Test object identification

test object names	identification of test sample (assigned by the client)
polymer housed metal-oxide surge arrester section	183 – 190 - 222

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

type confidential

## Test procedure

- The power frequency voltage at reference current ( $I_{ref} = 5 \text{ mA}$ ) has been carried out.
- The voltage correction factors have been calculated according to reference standard
- The samples have been kept in an oven at the temperature of  $60 \text{ }^\circ\text{C}$  till thermal equilibrium
- Two long duration current impulse having duration  $2000\mu\text{s}$  and specified energy  $15,5 \text{ kJ}$  have been applied and a time shorter than  $100 \text{ ms}$  after the application of the second long duration current impulse the sample has been energized at  $U_{tov}$  (declared by the manufacturer) and then the voltage  $U_c'$  has been applied for  $30 \text{ min.}$  in order to verify the thermal stability.
- Three samples were tested as specified below:
  - one sample at the voltage  $U_{TOV}=1,43*U_c'$  for a time duration  $T_{TOV}$  equal to  $1 \text{ sec.}$  (sample n.183)
  - one sample at the voltage  $U_{TOV}=1,29*U_c'$  for a time duration  $T_{TOV}$  equal to  $100 \text{ sec.}$  (sample n.190)
  - one sample at the voltage  $U_{TOV}=1,22*U_c'$  for a time duration  $T_{TOV}$  equal to  $1000 \text{ sec.}$  (sample n.222)

## Summary of test results

- The thermal stability was achieved for all tested sample.
- The visual inspection of the test sample has revealed no sign of physical damage.
- All acceptance criteria are satisfied and therefore the curve claimed by the manufacturer is to be considered verified.

ВЯРНО С ОРИГИНАЛА





Power frequency voltage versus time test.

Power frequency voltage-current characteristics

Test circuit: A0019

Date: December 03, 2004

Original Issue 03-2005

Sample No.183						
oscillogram	voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	6,67	5,14	4,80	1,70	8,39	--

Sample No. 190						
oscillogram	voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
2	6,59	5,05	4,73	1,72	8,00	--

Sample No.222						
oscillogram	voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	6,69	5,02	4,71	1,77	8,31	--

Too confidential



ВЯРНО С ОРИГИНАЛА



Power frequency voltage versus time test.

voltage correction factor calculations

test object: Polymer housed metal-oxide surge arrester type section

sample no.	$U_{ref}$ [1] kV	$KU_r$ [2]	$KU_c$ [3]	$U_r'$ [4] kV	$U_c'$ [5] kV
183	6,67	0,980	0,784	6,537	5,229
190	6,59			6,458	5,167
222	6,69			6,556	5,245

The factors used for the calculation of the test voltages allow to cover all possible arresters of the series within manufacturer's tolerances so that requirement at clause 7.3 of the reference standard is satisfied.

- [1]  $U_{refmin}$  : measured reference voltage
- [2]  $KU_r$  : maximum guarantees factor for calculation of  $U_r$
- [3]  $KU_c$  : maximum guarantees factor for calculation of  $U_c$
- [4]  $U_r'$  : corrected rated voltage [4] = [1] × [2]
- [5]  $U_c'$  : corrected continuous operating voltage [5] = [1] × [3]

ВЯРНО С ОРИГИНАЛА



Original Issue 01-2005

Все оригинали

Switching surge operating duty test. IEC 60099-4 Standard

Application of the long duration impulses, of the temporary overvoltage  $U_{TOV}$  and evaluation of thermal stability

Test circuit: A0124-A0130-A0020

Sample No.: 183

Preheating temperature: 61 °C

Date: December 06, 2004

Long duration current impulses application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current A	Energy kJ
4	1	15,0	12,80	490	16,10
5	2	15,0	12,84	485	15,80

Measured waveshape	
virtual front time $\mu s$	virtual total duration $\mu s$
2200	2910

$U_{TOV}$  voltage application

Oscillogram No.	Time s	Voltage kV	Current + $A_{cr}$	Current - $A_{cr}$
6	0	7,477	2,30	3,20
7	1		2,20	2,90

$U_c'$  voltage application

Oscillogram No.	Time s	Voltage kV	Current + $mA_{cr}$	Current - $mA_{cr}$	Power W	
8	0	5,229	2,04	2,16	3,80	
	5		0,76	0,74	0,995	
	10		0,70	0,73	0,830	
9	15		0,67	0,71	0,760	
	20		0,66	0,67	0,690	
	25		0,64	0,65	0,680	
	30		0,63	0,64	0,660	
10						

Original Issue 05-2005

2004-01-06



ВЯРНО С ОРИГИНАЛА



continued

continued

Sample No.: 190

Preheating temperature: 61 °C

Date: December 05,2004

Long duration current impulses application

Oscillogram No.	Impulse No.	Charging voltage kV	Residual voltage kV	Discharge current A	Energy kJ
11	1	15,0	12,76	490	16,15
12	2	15,0	12,80	480	15,97

Measured waveshape	
virtual front time	virtual total duration
µs	µs
2200	2910

U<sub>TOV</sub> voltage application

Oscillogram No.	Time s	Voltage kV	Current + mA <sub>cr</sub>	Current - mA <sub>cr</sub>
13	0	6,67	93,0	128,0
14	100		14,0	16,0

U<sub>c'</sub> voltage application

Oscillogram No.	Time s	Voltage kV	Current + mA <sub>cr</sub>	Current - mA <sub>cr</sub>	Power W
15	0	5,167	0,75	0,83	1,04
	5		0,71	0,76	0,84
	10		0,70	0,74	0,77
16	15		0,68	0,73	0,72
	20		0,65	0,71	0,68
	25		0,64	0,70	0,65
17	30		0,63	0,69	0,64

ВЯРНО С ОРИГИНАЛА



continued

Original Issue 03-2005

Type Confidential

continued

Sample No.: 222

Preheating temperature: 61 °C

Date: December 09, 2004

Long duration current impulses application

Oscillogram	Impulse	Charging voltage	Residual voltage	Discharge current	Energy
No.	No.	kV	kV	A	kJ
18	1	15,0	12,84	480	15,65
19	2	15,0	12,84	480	15,55

Measured waveshape	
virtual front time	virtual total duration
μs	μs
2200	2910

U<sub>TOV</sub> voltage application

Oscillogram	Time	Voltage	Current	Current
No.	s	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>
20	0	6,398	20,0	28,0
21	10	6,398	2,0	3,0

U<sub>c'</sub> voltage application

Oscillogram	Time	Voltage	Current	Current	Power
No.	s	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	W
22	0	5,245	0,67	0,71	0,761
	5		0,66	0,70	0,742
	10		0,66	0,69	0,720
23	15		0,65	0,68	0,655
	20		0,64	0,67	0,625
	25		0,63	0,66	0,620
24	30		0,62	0,65	0,610



ВЯРНО С ОРИГИНАЛА





continued

Original Issue 03-2005

www.cesi.com

Circuit A0019

Original issue 03-2005



Power frequency supply

- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI No.31120; R= 941,4 Ω
- Electro optical system CESI No. -- ; attenuation
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI No.6318

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/1522; attenuation 50:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI No.6318


This document is

ВЯРНО С ОРИГИНАЛА



Circuit A0124

Original Issue 03-2005



Impulse generator circuit

- $C_1 \dots C_{12}$  - capacitors 18,75  $\mu\text{F}$
- $L_1 \dots L_{11}$  - inductors 666  $\mu\text{H}$
- $L_{12}$  - inductor (500 +600)  $\mu\text{H}$
- $S$  - spark-gap


For confidential

ВЯРНО С ОРИГИНАЛА



Circuit A0130

Original Issue 03-2005



Power-frequency circuit

from 380Vac power supply

- $R_1$  - single-phase voltage regulator CORMES; power 20 kVA; voltage 380/04220 Vac
- $T_1$  - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200-400 V/15-30 kV

from Medium Voltage (MV) power supply

- $R_2$ - $T_2$  - voltage regulator group BONNEFOND; power 3x350 kVA; voltage 23 kV/046\* $\sqrt{3}$  kV


True & Confidential

ВЕРНО С ОРИГИНАЛА





Circuit A0020



Impulse generator circuit A0123

I - Circuit-breaker

Impulsive current measuring system

- Sh<sub>1</sub> - Current shunt CESI No.6042; R= 2 mΩ
- Electro optical system CESI No.11517/518; attenuation 300:5
- OSC<sub>1</sub> - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

Power frequency voltage measuring system circuit A013

- D - Voltage divider SAGI; CESI No.13027
- Electro optical system CESI No.11521/522; attenuation 20:5
- OSC<sub>2</sub> - Oscilloscope type TEKTRONIX TDS 460A; CESI No.14434 (on channel No.2)
- OSC<sub>3</sub> - Oscilloscope type SONY TEKTRONIX RTD 710A ; CESI No.9090 (on channel No.1)

Power frequency current measuring system circuit A013



- Sh<sub>2</sub>(TOV) - Current shunt CESI ; R= 100 Ω (TOV 1000sec. – 100 sec.)– Pearson 1 V\*A CESI No.9099 (TOV 1 sec.);
- Sh<sub>2</sub> (MCOV) - Current shunt CESI R= 500 –1000 Ω
- Electro optical system CESI No. 8011/17; attenuation 300-5:5
- OSC<sub>2</sub> - Oscilloscope type SONY TEKTRONIX RTD 710A ; CESI No.9090 ; CESI No.13217 (on channel No.2)

ВЯРНО С ОРИГИНАЛА!



Original Issue 03-2005

Very confidential





CESI Pec A4521820 oscillogram n.1

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2006

Very confidential



*Handwritten signature*

CESI Pec A4521820 oscillogram n.2

*Handwritten signature*



ВЯРНО С ОРИГИНАЛА



*Handwritten signature*

Original Issue 03-2005

Very confidential




CESI Pec A4521820 oscillogram n.3

ВЯРНО С ОРИГИНАЛА



Very confidential

Original issue 03-2005



*[Handwritten signature]*


CESI PeC A4521820 oscillogram n. 4

**ВЯРНО С ОРИГИНАЛА**



Very confidential

Original Issue 03-2005



CESI PeC A4521820

oscillogram n. 5

ВЯРНО С ОРИГИНАЛА




Tek **stop** Single Seq 5.00ks/s

Ch1 Zoom: 2.0X Vert 0.5X Horiz

C2 PK-PK  
5.80 V

C2 RMS  
1.080 V



*[Handwritten signature]*

CESI PeC A4521820

oscillogram

**ВЯРНО С ОРИГИНАЛА**

6


*[Handwritten signature]*



*[Handwritten signature]*

Технически

Original Issue 03-2005



CESI PeC A4521820

oscillogram n. 7



ВЯРНО С ОРИГИНАЛА





Original Issue 03-2005

Very confidential





CESI Pec A4521820 oscillogram n.8

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2003

Very confidential





CESI Pec A4521820 oscillogram n.9

ВАРНО С ОРИГИНАЛА



Original Issue 03-2008

Твърдо конфиденциал



CESI Pec A4521820 oscillogram n.10


*Handwritten signature*

**ВЯРНО С ОРИГИНАЛА**



Type confidential


Original Issue 03-2005



CESI PeC A4521820 oscillogram n. 11

ВЯРНО С ОРИГИНАЛА





*[Handwritten signature]*

CESI PeC A4521820


oscillogram n. 12

**ВЯРНО С ОРИГИНАЛА**



*[Handwritten signature]*

Tek **STOP** Single Seq 1.00ks/s



CESI PeC A4521820



oscillogram n. 14

ВАРНО С ОРИГИНАЛА



Original Issue 03-2005

Very confidential



*Handwritten signature*

CESI Pec A4521820 oscillogram n.15



*Handwritten signature*

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very Confidential



CESI Pec A4521820 oscillogram n.16



ВЯРНО С ОРИГИНАЛА

АКЦИОНЕРНО ДРУЖЕСТВО  
ФИЛКАБ  
16  
ПЛОВДИВ



Original Issue #3-2003


Усво confidential



CESI Pec A4521820 oscillogram n.17

ВЯРНО С ОРИГИНАЛА






CESI PeC A4521820 oscillogram n. 18

ВАРНО С ОРИГИНАЛА





*[Handwritten signature]*

CESI PeC A4521820

oscillogram n. 19

ВЯРНО С ОРИГИНАЛА




*[Handwritten signature]*

Very confidential

Original Issue 03-2005

Tek STOP Single Seq 1.00kS/s



C2 PK-PK  
4.40 V


C2 RMS  
1.570 V

CEST PeC  
ВЯРНО С ОРИГИНАЛА

A4521820

oscillogram n. 20





*Handwritten signature*

*Handwritten signature*



CESI PeC A4521820 oscillogram n. 21

**ВЯРНО С ОРИГИНАЛА**



Original Issue 03-2005

Copy confidential





CESI Pec A4521820 oscillogram n.22

ВЯРНО С ОРИГИНАЛА



Original Issue IS-2003

Very confidential



*Handwritten signature*

CESI Pec A4521820 oscillogram n.23



*Handwritten signature*

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very confidential



CESI Pec A4521820 oscillogram n.24

ВАРНО С ОРИГИНАЛА





Top confidential




Original Issue 03-2005

**CESI**

PROTOCOLLO DATA

A-4/503147M1 27 SET, 2005

Firma: *Mario Geronzi*



CREEPAGE=6.65mm  
DRY ARC DIST=138mm

ВЯРНО С ОРИГИНАЛА

**TECNOELECTRONICS**

ENERGY DIVISION

INDUSTRIAL E.P. S.p.A.  
Via S. Felice 10  
37030 S. Felice del Bianco  
Verona - Italy

Discharge  
UNIT

5kV 10kA OCP2 SURGE  
ARRESTER PRODUCT

REG. NO. OCP2-5 SHEET 1 OF 1

DESIGN	REVISION	DATE	BY	CHECKED	DATE
DCEP					
APP					
SCALE					

TITLE

PER. MATERIAL

WATEL

END


THIS DRAWING IS THE PROPERTY OF TECNOELECTRONICS S.p.A. AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.



# TEST REPORT

041103/OCP2-THC

## OCP2 Thermal behaviour



Test Engineer: Hannah Piper  
Senior Test Engineer: Roy Fisher  
HV Lab Manager: Kwong Tong

PROT. n. <sup>04/</sup> 524527
GESI TEST 27 DIC. 2006
COPIA _____
A _____

ВЯРНО С ОРИГИНАЛА


На основании чл. 2  
от ЗЗЛД

# TEST REPORT

041202/OCP2 TOV curve V.4

Original Issue 03-2005

TOV curve of OCP2 with 2 long duration discharges (total 6.2kJ/kV Uc) prior energy



*[Handwritten signature]*

Test Engineer: Hannah Fleming  
Senior Test Engineer: Roy Fisher  
HV Lab Manager: Kwong Tong

PROT. n. A4524512  
CESI TEST 27 DIC. 2004  
COPIA  
A

*[Handwritten signature]*

Remark: This TOV curve superseded 041104 OCP2 TOV curve V.3

Registered in England No. 2266375. Registered Office Faraday Road, Dorcan, Swindon, Wilt. SN3 5HH

A tyco INTERNATIONAL LTD. COMPANY

ВЯРНО С ОРИГИНАЛА



L

(

(



Energy Division  
http://energy.tycoelectronics.com

## Electronics

### Bowthorpe EMP

### Test Report

Original Issue 03-2005

Type	OCP2
PPR Number	PPR-1854
Test Specification	Weather Ageing Test IEC 60099-4 (2001-12)

#### Test Information:


Laboratory	EGU HV Lab
Date	19/03/2004
External Test Ref	8915_A3_04
Report Prepared By	Jonko Tetev
Test Verified by	Vaclav Sklenicka
Test Approved by	

#### Tyco Approvals:

R&D Manager	На основание чл. 2 от ЗЗЛД	Date	25/02/2005
Brendan Normoyle		Date	25/02/2005
Technology Manager		Date	25/02/2005
Kwong Tong		Date	25/02/2005
Product Manager		Date	25/02/2005
Brian McGowan		Date	25/02/2005

Tyco confidential

For further information contact:  
 Tyco Electronics Energy Division  
 Bay 100 - 109  
 Shannon Industrial Estate  
 Co. Clare, Ireland  
 Tel: + 353-61-472885  
 Fax: + 353-61-472676  
 Email: mvsurgearresters@tycoelectronics.com



**EGÚ - HV LABORATORY**  
190 11 Prague 9 – Běchovice

ACCREDITED TESTING LABORATORY No.: 1029  
Accredited by Czech Accreditation Institute , o.p.s.

**CUSTOMER:**  
Tyco Electronics  
Shannon Industrial Estate  
BAY 100-104  
SHANNON  
IRELAND

**ORDER No.:**  
PO No. 2250302760

**DATE OF TEST:**  
from 2004-01-20 till 2004-03-19

**TEST No.:**  
8915/04

**TEST REPORT**  
No.: 8915/A3/04

**TEST OBJECT:** Composite metal oxide surge arrester  
**TYPE:** OCP2 – 24S  
**PRODUCER:** TYCO Electronics, Raychem Shannon, Ireland  
**TYPE OF TEST:** Weather ageing test  
**TEST STANDARD:** IEC 60099-4 Ed.1.2: 2001-12, clause 9.7.10

На основание чл. 2  
от ЗЗЛД



На основание чл. 2  
от ЗЗЛД

LABORATORY:

Test report is confidential and must not be passed over or transferred to any third party without written approval of the customer. Test results relate only to the tests given in presented report and do not substitute any other documents. The report shall not be reproduced except in full without written approval of the testing laboratory.

In Prague 9 -Běchovice; 2004-04-28

ВЯРНО С ОРИГИНАЛА



**REQUEST**

Weather ageing test in accordance with IEC 60099-4 Ed.1.2: 2001-12, test series A: 1000 hours was performed on

**COMPOSITE METAL OXIDE SURGE ARRESTER  
TYPE OCP2 - 24S**

Technical drawing - see Figure 1.

**DATE OF TEST SAMPLES DELIVERY**

2004 - 01 - 14

**TEST STANDARD**

The test was performed in accordance with IEC 60099-4 Ed.1.2: 2001-12 "Surge arresters - Part 4: Metal-oxide surge arresters without gaps for a.c.systems".

**TESTS PERFORMED**


Weather ageing test	IEC 60099 - 4, clause:
Test series A: 1000 hours	9.7.10
Evaluation of the test	9.7.10.2.1
	9.7.10.3

**METAL OXIDE SURGE ARRESTER MANUFACTURER AND IDENTIFICATION**

The insulators were manufactured by TYCO Electronics, Energy Division, Raychem Shannon, BAY 100-109, Shannon Ind. Est., Shannon, Co. Clare, Ireland.

**TEST EQUIPMENT**

Weather ageing test 1000 hours



T - test transformer ČKD Praha, 0,65/70 kV, 30 kVA  
 B - inductive regulator ČKD Praha 3x380/3x 0 - 760V, 45 kVA  
 MT - voltage measuring transformer UZGT 30, 35 000/100 V, serial No. 76/02021  
 voltmeter Metra, type MUL 10, serial No. 144320

Original Issue 03-2006

Type confidential

*Handwritten signature*

*Handwritten signature*


2/8

**ВАРНО С ОРИГИНАЛА**

ACCREDITED TESTING LABORATORY  
 EGÚ - HV LABORATORY  
 PRAGUE  
 No. 1029


АКЦИОНЕРНО ДРУЖЕСТВО  
 ФИЛКАБ  
 16  
 ПЛОВДИВ

Measurement of reference voltage



- synchronous generator BEZ Bratislava 6 kV, 1300 kVA, 50 Hz
- test transformer Fischer-Köln, 3-6/250 kV, 250 kVA
- instrument voltage transformer Škoda, 380/√3 kV / 100/√3 V, serial No. 917355
- digitizer ADAM Maurer, serial No. 9401.9620
- universal voltmeter Siemens, type MU 15, serial No. 879953

Measurement of partial discharges



- induced regulator ČKD Praha, 6/0-3 kV, 50 kVA
- test transformer Fischer-Köln, 3-6/250 kV, 250 kVA
- instrument voltage transformer Škoda, 380/√3 kV / 100/√3 V, serial No. 917355
- PD measuring system Tettex, type 2801, serial No. 123989
- universal voltmeter Siemens, type MU 15, serial No. 879953


UNCERTAINTIES OF MEASUREMENTS

TYPE OF MEASUREMENT	UNCERTAINTY
<i>Power-frequency voltage</i>	1,8 %
<i>Partial discharges</i>	8,0 %

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor  $k = 2$ , which for a Normal (Gaussian) distribution corresponds to a coverage probability of approximately 95 %.

ВЯРНО С ОРИГИНАЛА

3/8  
 ФИЛКАБ  
 16  
 ПЛОВДИВ





TEST SAMPLES

Test sample	Type	Uc (kV)
C	OCP2 - 24S	24
G	-	-
I	-	-
O	-	-

TEST SPECIFICATION

Weather ageing test:

Metal oxide surge arrester samples were subjected to a salt fog test in accordance with IEC 60099-4, clause 9.7.10.2.1 (test series A).

The metal oxide surge arresters were energised at a voltage of 24 kV that is continuous operating voltage of tested metal oxide surge arresters.

The protection level of the tripping device was set at 1 A (r.m.s.).

During the test the salt fog was sprayed into the test chamber.

The characteristic of the salt fog were as follows:

Water flow rate:  $(0,4 \pm 0,1) \text{ l/m}^3 \cdot \text{h}$

Starting salinity:  $5 \text{ kg/m}^3$

Temperature:  $20^\circ \text{C} \pm 5 \text{ K}$

Duration of the test: 1000 hours (excluding duration of interruption)

Verification tests:

Before and after weather ageing test the measurement of reference voltage according to IEC 60099-4, clause 6.2 and partial discharges according to IEC 60099-4, clause 7.8 were performed.

Original issue 03.2005

This certificate

4/8

ВЯРНО С ОРИГИНАЛА



**TEST RESULTS**

The OCP2 - 24S surge arrester **has passed** all requirements of clause 9.7.10 of IEC 60099 – 4 Ed.1: 2001 – 12.

The course of the weather ageing test is given in the following Table 1.

The record of test voltage is given on Figure 2.

Table 1

Test sample	Time of flashover (from the beginning of the test)	Duration of voltage interruption	Total duration of voltage interruption (hours)	Salinity (kg/m <sup>3</sup> )
Beginning of the test 2004-01-26 at 14.30 hour		0	0	5
G	584	10 h	10 h 10 min	5
O	598	1h 40 min	11 h 50 min	5
I	636	31 h	42 h 50 min	5
OCP2-24S	669	3 h 20 min	46 h 10 min	5
G	678	14 h	60 h 10 min	3,5
G	811	25 h 40 min	85 h 50 min	3,5
O	877	5 h	90 h 50 min	3,5
I	918	8 h	98 h 50 min	3,5
End of the test 2004-03-12 at 9.20 hour			98 h 50 min	3,5
Total duration of the test including interruptions		1099 hours		

The results of the verification tests before and after the weather ageing tests and evaluation of the test are given in Table 2.

Table 2

Sample type	Reference voltage (kV)		Partial discharges (pC)		Visual inspection after test	Evaluation of the test
	before test	after test	before test	after test		
OCP2-24S	32,9	32,4	0,6	1,0	no tracking, erosion or puncture	passed

The results of hydrophobicity measurement (using STRI method) \*) are given in Table 3.


Table 3

Sample type	Hydrophobicity before the test	Hydrophobicity after finishing of the test	Hydrophobicity 24 hours after finishing of the test
OCP2-24S	1	7	3

The photographs of the wetted arrester immediately after finishing of the test and 24 hours after finishing of the test are shown on Figure 3.


Note: \*) This test is not a subject of laboratory accreditation.

ВЯРНО С ОРИГИНАЛА



Original issue 03-2005

True confidential



*Handwritten signature*

Figure 1: Technical drawing of the arrester type OCP2-24S

6/8

ВЯРНО С ОРИГИНАЛА

ФИЛКАБ  
16  
\* ПЛОВДИВ \*

ACCREDITED TESTING LABORATORY  
EGÚ - HV LABORATORY  
PRAGUE  
No. 1029

Original Issue 03-2005

Very confidential





Figure 2: Record of the test voltage during 1000 hour test



ВЯРНО С ОРИГИНАЛА

78  
ФИЛКАБЕ  
16  
АНТИМОНЕРНО ДРУЖЕСТВО  
\* ПЛОВДИВ \*



Original Issue 03-2004

True confidential



*Handwritten signature*

Figure 3: OCP2 – 24S, test sample C


*Handwritten signature*

8/8

ВЯРНО С ОРИГИНАЛА

*Handwritten signature*







Energy Division  
http://energy.tycoelectronics.com

## Electronics

### Bowthorpe EMP

### Test Report

Original Issue 03-2005

Type	OCP2
PPR Number	PPR-1830
Test Specification	Switching surge operating duty test IEC 60099-4 (2001-12)

#### Test Information:

Laboratory	CESI
Date	30/04/2004
External Test Ref	AT-A4/011670
Report Prepared By	M Gregori
Test Verified by	A Sironi
Test Approved by	V Scarioni

#### Tyco Approvals:

R&D Manager	На основание чл. 2 от ЗЗЛД	Date	25/02/2005
Brendan Normoyle			
Technology Manager			
Kwong Tong		Date	25/02/2005
Product Manager			
Brian McGowan		Date	25/02/2005

For further information contact:  
 Tyco Electronics Energy Division  
 Bay 100 - 109  
 Shannon Industrial Estate  
 Co. Clare, Ireland  
 Tel: + 353-61-472885  
 Fax: + 353-61-472676  
 Email: mvsurgearresters@tycoelectronics.com

Tyco confidential

ВАРНО С ОРИГИНАЛА



Original Issue 03-2005

client TYCO Electronics Energy Division - Shannon (IRL)

equipment under test Polymer housed metal-oxide surge arrester  
type OCP2

tests performed Switching surge operating duty test

normative documents IEC 60099-4 (2001-12)

receipt date of the sample April 15, 2004

test date from April 27, 2004 to April 30, 2004

no. of pages 25 no. of pages annexed 54

the test results relate only to the sample tested  
this document shall not be reproduced except in full without the written approval of CESI



Proprietà intellettuale

first issue date May 25, 2004

prepared PeC/TEST

verified PeC/TEST

approved PeC/TEST

На основании чл. 2  
от ЗЗЛД


CESI  
Centro Elettrotecnico  
Sperimentale Italiano  
Giacinto Motta SpA

Via R. Rubattino 54  
20134 Milano - Italia  
Telefono +39 0221251  
Fax +39 0221255440  
www.cesi.it

Capital - 550 000 Euro  
interamente versato  
Codice fiscale e numero  
iscrizione CCIAA. 00793580150

Registro Imprese di Milano  
Sezione Ordinaria  
N. R.E.A. 429222  
P.I. IT00793580150

ВЯРНО С ОРИГИНАЛА





tests witnessed by: /

Original Issue 03-2015

identification of the object: The manufacturer guarantees that the tested object is manufactured according to the submitted drawings.

CESI checked that drawing adequately represents in shape and dimension the essential detail and the parts of the tested object.

The drawings identified by CESI and numbered A4/503147, one page, is annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: —

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with impulse current : peak value:  $\pm 3 \%$  ; time parameters:  $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms):  $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

laboratory information

На основание чл. 2  
от ЗЗЛД

Davidte - I. Guacci

ge arrester laboratory

10H, 31020W, 46030U, 53001D

ВЯРНО С ОРИГИНАЛА




Typo confidential

Original Issue 03-2003

contents	page	test date
Test object characteristics	4	
Photograph of polymer housed metal-oxide surge arrester	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Summary of test result	8	
High current impulse operating duty test	9 ÷ 18	April 27 ÷ April 30, 2004
Technical data of the test circuit	19 ÷ 25	

ВЯРНО С ОРИГИНАЛА



Pages annexed:  
 Oscillograms n.52 pages  
 U/CO drawing n. OCP2-5; CESI n. A4/503147, n. 1 page  
 TYCO document n.041103/OCP2-THC (thermal equivalency); CESI n. A4/524527, n. 1 page

Test object characteristics

type: Polymer housed metal-oxide surge arrester section ( thermal equivalent)

electrical characteristics (claimed by the client)

manufacturer's name	TYCO Electronics Energy Division - Shannon (IRL)
nominal discharge current - $I_N$ [kA]	10
rated voltage - $U_r$ [kV]	$0,980 \times U_{rel.}$
continuous operating voltage - $U_c$ [kV]	$0,784 \times U_{rel.}$
reference current - $I_{rel.}$ [mA]	5
line discharge class	2
rated frequency - [Hz]	50
year of manufacture	2004

geometrical characteristics (measured on the test sample)

height [mm]	139
number of sheds	n.2 large - n.1 small
shed diameter [mm]	118 large - 96 small

other characteristics

housing material	SILICONE
housing color	GREY

**NOTE** The surge arresters were tested with the additional thermal insulation supplied by the Client. The verification of the thermal equivalency according to annexe B was carried out by the Client (see annexed report A4/524527)


ВЯРНО С ОРИГИНАЛА




Original issue 03-2005

Tyco confidential

Photograph of the test sample.



Photograph of the test sample with thermal insulation



ВЯРНО С ОРИГИНАЛА



Original image of 03-2006

Original image of 03-2006

Reference Standard

IEC 60099-4 (2001-12) Clause 7.5.4 ,  
" Metal-oxide surge arrester without gaps for a.c. system"

Test carried out

test carried out	number of sample tested
switching surge impulse operating duty test	3

Test object identification

test object names	identification of test sample (given by manufacturer)
polymer housed metal-oxide surge arresters section	OD1 - OD2 - OD3

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very confidential

Test procedure

- The power frequency reference voltage at  $I_{ref} = 5,0$  mA has been measured
- The lightning impulse residual voltage at  $I_N = 10$  kA has been measured
- The switching impulse residual voltage at 125 A has been measured
- The voltage correction factors have been calculated according to reference standard
- The preconditioning has been performed on surge arrester at ambient temperature according to reference standard as per the following procedure:
  - Twenty shots  $8/20 \mu s$  at  $I_N$  have been applied superimposed to the power frequency at the voltage level  $1.2 \cdot U_c'$ . The shots have been applied in four groups of five impulses. The interval between impulses of the same group was 50-60 seconds while the interval between groups was 30 minutes. The polarity of the impulses was the same as that of the half cycle of power frequency voltage during which it occurred (positive) and they were applied 60 electrical degrees before the peak of the power frequency.
- The samples have been let to cool down to ambient temperature
- Two high current impulses having waveshape  $4/10 \mu s$  and peak value equal to 100 kA has been applied
- The surge arrester sections have been kept in an oven at the temperature of 60 °C till thermal equilibrium
- Two long duration current impulses with a virtual duration equal to 2000  $\mu s$  and with the specified calculated energy (for the line discharge class 2) has been applied with one minute time interval. A time shorter than 100 ms after the application of the second long duration current impulse the sample has been energized at  $U_c'$  for 10 sec. and then at the voltage  $U_c'$  for 30 min. to verify the thermal stability.
- The lightning impulse residual voltage at  $I_N = 10$  kA has been measured during two consecutive shots

Original Issue 03-2005

Type 600000000000

ВЯРНО С ОРИГИНАЛА



Visual inspection and summary of test result

variation of lightning impulse residual voltage test

test object	before test		after test		variation
	discharge current	residual voltage	discharge current	residual voltage	
	kA	kV	kA	kV	
OD1	10,20	16,08	10,00	16,08	0
OD2	10,10	16,00	10,20	16,08	+ 0,5
OD3	10,10	16,00	10,00	16,08	+ 0,5

The test has been performed without disconnecter.

The visual inspections of the test sample after the test has revealed no sign of physical damage. The variation of lightning impulse residual voltage before and after the test was less than 5%.

The thermal stability was achieved.

The oscillogram of the two last impulses do not reveal any sign of breakdown.

All acceptance criteria are satisfied and therefore the test result is positive.

ВЯРНО С ОРИГИНАЛА

АКЦИОНЕРНО ДРУЖЕСТВО  
ФИЛКАБ  
16  
ПЛОВДИВ

Original Issue 03-2005

Too confidential

Switching surge operating duty test.

Power frequency voltage-current characteristics

test object: Polymer housed metal-oxide surge arrester section  
test circuit:A019

date: April 27, 2004

sample no. OD1						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
1	6,73	4,99	4,47	1,66	7,48	---

sample no. OD2						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
3	6,80	4,97	4,60	1,66	7,41	---

sample no. OD3						
oscill.	voltage	current	current	current	power	3rd harmonic amplitude
no.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
5	6,79	4,98	4,51	1,58	7,63	---

ВЯРНО С ОРИГИНАЛА



Original issue 05-2005

Type confidential



Switching surge operating duty test.

lightning impulse residual voltage measurement before the test

test object: Polymer housed metal-oxide surge arrester section  
test circuit: A014

date: April 27, 2004

sample no.	requested current	charging voltage kV	oscillogram no.	current waveshape $\mu s$	discharge current kA	residual voltage kV
OD1	$I_N$	29,0	7	8,5/18,4	10,20	16,08
OD2	$I_N$	29,0	8		10,10	16,00
OD3	$I_N$	29,0	9		10,10	16,00

	oscilloscope settings		
	sampling division $\mu s$	input $V_{in}$	attenuation
current	5	0,5	50:5
voltage		1,0	20:5

Original file no. 03-2004

True confidential

ВЯРНО С ОРИГИНАЛА

Switching surge operating duty test..  
Switching impulse residual voltage measurement

test object: Polymer housed metal-oxide surge arrester section  
test circuit: A014A

Original Issue 03-2005

date: April 27, 2004

sample no.	requested current A	charging voltage kV	oscillogram no.	current waveshape $\mu s$	discharge current A	residual voltage kV
OD1	125	12,7	10	32,0/82,0	128	11,92
OD2	125	12,7	11	32,0/82,0	131	11,92
OD3	125	12,7	12	32,0/82,0	122	11,92

	oscilloscope settings		
	sampling division $\mu s$	input $V_{div}$	attenuation
current	20	0,5	5:5
voltage	20	0,7	20:5

From 000-00000000

ВЯРНО С ОРИГИНАЛА



Switching surge operating duty test.

voltage correction factor and energy calculations

test object: Polymer housed metal-oxide surge arrester section

date: April 28, 2004

sample no.	$U_{ref}$ [1] kV	$KU_r$ [2]	$KU_c$ [3]	$U_r'$ [4] kV	$U_c'$ [5] kV	$U_s'$ [6] kV
OD1	6,73	0,980	0,784	6,60	5,28	6,33
OD2	6,80			6,66	5,33	6,40
OD3	6,79			6,65	5,32	6,39

The manufacturer guarantees that the factors used for the calculation of the test voltages allow to cover all possible arresters of the series within manufacturer's tolerances.

So that requirement at clause 6.3 of the reference standard is satisfied

- [1]  $U_{ref}$  : measured reference voltage
- [2]  $KU_r$  : factor claimed by the manufacturer for calculation of  $U_r'$
- [3]  $KU_c$  : factor claimed by the manufacturer for calculation of  $U_c'$
- [4]  $U_r'$  : corrected rated voltage [4] = [1] × [2]
- [5]  $U_c'$  : corrected continuous operating voltage [5] = [1] × [3]
- [6]  $U_s'$  : corrected voltage to be applied during the preconditioning [6] = [5] × 1,2

sample no.	$U_r'$ kV	$U_L$ kV	$V_{res}$ kV	$T$ $\mu s$	$Z$ $\Omega$	$W$ kJ	$W'$ kJ / kV
OD1	6,60	21,12	11,92	2000	15,84	13,846	2,098
OD2	6,66	21,31		2000	15,98	14,008	2,103
OD3	6,65	21,28		2000	15,96	13,981	2,102

$V_{res}$  : switching impulse residual voltage

$U_L, T, Z$  : see table 4 of IEC 60099-4 Standard

$W = V_{res} \times (U_L - V_{res}) \times (T / Z)$

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very confidential

Switching surge operating duty test.

conditioning

test object: Polymer housed metal-oxide surge arrester section

test circuit: A015

date: April 28, 2004

imp. no.	osc. no.	sample no. OD1		osc. no.	sample no. OD2		osc. no.	sample no. OD3	
		charging voltage kV	peak current kA		charging voltage kV	peak current kA		charging voltage kV	peak current kA
1	13	51,5	10,2		51,5	10,5		51,5	10,2
2		51,4	10,5		51,4	10,5		51,5	10,3
3		51,5	10,3		51,4	10,4		51,4	10,1
4		51,5	10,4		51,5	10,4		51,5	10,2
5	14	51,5	10,3	15	51,5	10,4	16	51,4	10,2
6		51,5	10,3		51,4	10,4		51,4	10,4
7		51,4	10,3		51,5	10,3		51,4	10,4
8		51,4	10,2		51,5	10,4		51,5	10,3
9		51,5	10,5		51,5	10,4		51,5	10,3
10	17	51,5	10,3	18	51,4	10,5	19	51,5	10,4
11		51,4	10,4		51,5	10,6		51,5	10,1
12		51,4	10,4		51,5	10,6		51,4	9,9
13		51,5	10,4		51,5	10,5		51,4	10,1
14		51,5	10,3		51,4	10,4		51,5	10,1
15		51,5	10,4		51,5	10,6		51,4	10,2
16		51,4	10,4		51,5	10,5		51,7	9,8
17		51,4	10,5		51,7	9,8		51,7	10,1
18		51,6	10,6		51,7	9,6		51,7	9,8
19		51,5	10,6		51,8	10,7		51,6	10,0
20	20	51,4	10,6	21	51,7	10,5	22	51,6	9,8

power frequency voltage applied to the test sample	sample no.OD1	sample no.OD2	sample no.OD3
		6,33 kV	6,40 kV

	oscilloscope settings		
	sampling time ms	input V <sub>ts</sub>	attenuation
current	20	0,2	50:5
voltage	20	1,0	50:5

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2004

Too Confidential

Switching surge operating duty test.

conditioning (second part)

test object: Polymer housed metal-oxide surge arrester section

test circuit: A014B

date: April 28, 2004

sample	impulse	charging voltage	oscillogram	discharge current
no.	no.	kV	no.	kA
OD1	1	77,0 x 2	23	97,5
	2	78,0 x 2	26	99,9
OD2	1	78,0 x 2	24	100,0
	2	78,0 x 2	27	99,9
OD3	1	78,0 x 2	25	100,2
	2	78,0 x 2	28	100,2

current waveshape	front	4,5 $\mu$ s
	tail	9,5 $\mu$ s
	opposite polarity	2,4 %

	oscilloscope settings		
	sampling division	input	attenuation
	$\mu$ s	V <sub>div</sub>	
current	2	0,8	300:5
voltage	/	/	/

note:

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very confidential

Switching surge operating duty test.

application of long duration impulses, of the rated voltage  $U_r$  and evaluation of thermal stability

test object: Polymer housed metal-oxide surge arrester section

test circuit: A017-A020

sample no. OD1

preheating temperature: 62 °C

date: April 29, 2004

long duration current impulses application

oscillogram	impulse	charging voltage	residual voltage	discharge current	energy
no.	no.	kV	kV	A	kJ
29	1	14,70	12,62	435	13,75
30	2	14,75	12,62	440	13,90

measured waveshape	
virtual front time	virtual total duration
$\mu s$	$\mu s$
2200	2910

$U_r$  voltage application

oscillogram	time	voltage	current	current
no.	s	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>
31	0	6,60	71,0	45,0
32	10		26,0	16,0

$U_c$  voltage application

oscillogram	time	voltage	current	current	power
no.	minutes	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	W
33	0	5,28	2,70	2,50	4,75
	5		2,15	2,05	2,37
	10		2,10	2,00	2,24
34	15		2,05	1,98	2,20
	20		2,00	1,95	2,10
	25		1,95	1,90	2,05
35	30		1,90	1,90	2,00

cont'd

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

This content is original

cont'd  
sample no. OD2  
preheating temperature: 62°C

date: April 29, 2004  
long duration current impulse application

oscillogram	impulse	charging voltage	residual voltage	discharge current	energy
no.	no.	kV	kV	A	kJ
36	1	14,80	12,62	440	14,24
37	2	14,85	12,62	445	14,45

measured waveshape	
virtual duration	virtual total duration
$\mu s$	$\mu s$
2200	2910

U<sub>v</sub>' voltage application

oscillogram	time	voltage	current	current
no.	s	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>
38	0	6,66	103,0	66,0
39	10		33,0	22,0

U<sub>c</sub>' voltage application

oscillogram	time	voltage	current	current	power
no.	minutes	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	W
40	0	5,33	3,00	2,80	5,57
	5		2,10	1,95	2,21
	10		2,05	1,90	2,11
41	15		2,00	1,90	2,07
	20		1,98	1,88	2,00
	25		1,95	1,85	1,95
42	30	1,90	1,85	1,92	

cont'd

ВАРНО С ОРИГИНАЛА



Original Issue 03-2006

File: 200404290001

Switching surge impulse operating duty test.

Check of the integrity of internal parts with additional shots and final lightning impulses residual voltage measurement after the test.

test object: Polymer housed metal-oxide surge arrester section  
test circuit: A014

date: April 30, 2004

sample	requested current	charging voltage	oscillogram	current waveshape	discharge current	residual voltage
no.		kV	no.	$\mu s$	kA	kV
OD1	I <sub>N</sub>	29,5	50	8,6/18,4	10,00	16,08
OD1		29,5	51		10,00	16,08
OD2		29,5	52		10,10	16,08
OD2		29,5	53		10,20	16,08
OD3		29,5	54		10,00	16,00
OD3		29,5	55		10,00	16,08

	oscilloscope settings		
	sampling time	input	attenuation
	$\mu s$	V <sub>fs</sub>	
current	5,0	0,5	50:5
voltage		1,0	20:5

ВЯРНО С ОРИГИНАЛА




Original file is 02-2008

Type confidential



circuit A019



power frequency supply

RE : programmable supply CESI no. 23702-32191 ; type Larcet A.C. Power Source 5000 P.S.  
 PC : personal computer  
 T : transformer type Specialtrasfo ; power 30 kVA ; voltage 200 V/15-30 kV

current shunt (R) CESI no. 11537;  $R = 811,94 \Omega$   
 oscilloscope CESI no.30223-30224  
 type Data Precision DATA 6100

voltage divider (D) CESI no. 11120  $k = 1010$   
 electro optical system CESI no.11519/520 ; attenuation 50:5  
 oscilloscope CESI no.30223-30224  
 type Data Precision DATA 6100


Original Issue 03-2005

Too Confidential

ВЯРНО С ОРИГИНАЛА



**circuit A014**



**impulse generator**

plant P177

no. of stages 1

$C_g$  4,98  $\mu F$

$L_c$  10  $\mu H$

S spark gap

current shunt (R) CESI no. 6042 ;  $R = 0,002 \Omega$  ; 100 kA

electro optical system CESI no.11517/518

oscilloscope CESI no.13217

type Tektronix TDS 540A

voltage divider (D) CESI no.11120 ;  $k = 1010$

electro optical system CESI no.11519/520 ; attenuation 20:5

oscilloscope CESI no.13217

type Tektronix TDS 540A


ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Type approved

circuit A014A



impulse generator

plant P177

no. of stages 1

$C_g$  6,64  $\mu F$

$L_c$  100  $\mu H$

S spark gap

current shunt (R) CESI no.6039 ;  $R = 0,020 \Omega$  ; 10 kA

electro optical system CESI no.11517/518

oscilloscope CESI no. 13217

type Tektronix TDS 540A

voltage divider (D) CESI no.11120;  $k = 1010$

electro optical system CESI no.11519/520

oscilloscope CESI no.13217

type Tektronix TDS 540A

ВЯРНО С ОРИГИНАЛА




Original Issue 03-2005

Type confidential

**circuit A015**

Original Issue 03-2005



**impulse generator**

plant P177

no. of stages 1

$C_g$  2,49  $\mu F$

L inductance of the circuit

$L_c$  20  $\mu H$

S spark gap

additional block has been added

**power frequency supply**

RE: regulator type CORMES; power 20 kVA; voltage 220 V/ 0 V + 220 V

T : transformer type Specialtrasfo; power 30 kVA; voltage 200 V/ 15 kV

B : blocking gaps

current shunt (R) CESI no. 6042;  $R = 0,002 \Omega$ ; 100 kA

electro optical system CESI no. 11517/518

oscilloscope CESI no. 13217

type Tektronix TDS 540A

voltage divider (D) CESI no.11120;  $k = 1010$

electro optical system CESI no. 11519/520

oscilloscope CESI no. 13217


type Tektronix TDS 540A

Type 6005/2005/07

ВЯРНО С ОРИГИНАЛА



circuit A014B



impulse generator

plant P177

no. of stages

$C_g$  3,32  $\mu$ F

$L_c$  1  $\mu$ H

S spark gap

and in addition four blocks in parallel

current shunt (R) CESI no.6042 ;  $R = 0,002 \Omega$  ; 100 kA

electro optical system CESI no.11517/518 ; attenuation 300:5

oscilloscope CESI no.13217

type Tektronix TDS 540A

voltage divider (D) CESI no./

electro optical system CESI no./

oscilloscope CESI no. /

ВЯРНО С ОРИГИНАЛА




Original Issue 03-2005

2005-03-01

**circuit A017**

long duration withstand impulse test



of the measurement systems

**impulse generator**

plant P177

C<sub>1</sub> ... C<sub>12</sub>: capacitors 37,5 μF

L<sub>1</sub> ... L<sub>12</sub>: inductors 666 mH

L<sub>13</sub> inductor 500 mH

S spark gap

shunt (R) CESI no. 6042 ; R = 0,002 Ω ; 100 kA

electro optical system CESI no. 11519/520

oscilloscope CESI no. 13217 ; type Tektronix TDS 540A

voltage divider (D) CESI no.11120 ; k = 1010

electro optical system CESI no. 8010/8017

oscilloscope CESI no. 13217 ; type Tektronix TDS 540A


Original Issue 03-2005

Not confidential

ВЯРНО С ОРИГИНАЛА



**circuit A020**



**impulse generator**

**plant P177**

C<sub>g</sub> circuit A017 see pag.24

**power frequency supply**

RE<sub>1</sub> regulator type BONNEFOND ; power 3x350 kVA ; voltage 23 kV/0 V ÷ 10,39 kV

RE<sub>2</sub> regulator type CORMES ; power 20 kVA ; voltage 220 V/0 V ÷ 220 V

T transformer type Specialtrasfo ; power 30 kVA ; voltage 200 V/ 15 kV

I insulated circuit breaker type

current shunt (R<sub>1</sub>) CESI no. 6041 ; R = 0,010 Ω ; 20 kA

electro optical system CESI no. 11519/11520; attenuation 5:5

oscilloscope CESI no. 13217 ; type Tektronix TDS 540A

current shunt for TOV (R) ; R = 500 Ω

electro optical system CESI no.14236/14237; attenuation 300:10

oscilloscope CESI no. 14456 type Tektronix TDS 430A

current shunt for MCOV(R) ; R = 1000 Ω

electro optical system CESI no.14246/14247; attenuation 10:10

oscilloscope CESI no.30223-30224 type DATA 6100

voltage divider CESI no. 11120 ; k = 1010

electro optical system CESI no. 8010/8017 ; attenuation 50:5

oscilloscope CESI no.14456 -13217 - 30223/224 type Tektronix TDS 430A - 540A - DATA 6100

Original issue 03-2005



Type confidential



**ВЯРНО С ОРИГИНАЛА**

Сигнал 18534 18-0018

Сигнал 18534 18-0018



CESI TEST A4/011670 oscillogram n. 1



ВЯРНО С ОРИГИНАЛА





Topo confidential

Original Issue 03-2005





CESI TEST A4/011670 oscillogram n. 3

ВЯРНО С ОРИГИНАЛ



Оригинал №0000000000

№0000000000




CESI TEST A4/011670 oscillogram n. 5

ВЯРНО С ОРИГИНАЛА

*[Handwritten signature]*





*[Handwritten signature]*

CESI TEST A4/011670 oscillogram n. 7


ВЯРНО С ОРИГИНАЛА



*[Handwritten signature]*

Type confidential


Original issue 03-2005



CESI TEST A4/011670 oscillogram n. 8

ВЯРНО С ОРИГИНАЛА





*[Handwritten signature]*

CESI TEST A4/011670 oscillogram n. 9


ВЯРНО С ОРИГИНАЛА



*[Handwritten signature]*

Confidential


Original Issue 03-2005



CESI TEST A4/011670 oscillogram n. 10

ВЯРНО С ОРИГИНАЛА





*Handwritten signature*

CESI TEST A4/011670 oscillogram n. 11

ВЯРНО С ОРИГИНАЛА




*Handwritten signature*

*Handwritten signature*

Top confidential

Original Issue 03-2002




CESI TEST A4/011670 oscillogram n. 12

ВЯРНО С ОРИГИНАЛА







*[Handwritten signature]*

CESI TEST A4/011670 oscillogram n. 13

ВЯРНО С ОРИГИНАЛА



*[Handwritten signature]*


*[Handwritten signature]*

Tek Stop 5.00KS/s

6 Acqs

Ch2 Zoom: 1.0X Vert 1.0X Horz

Ch2 RMS  
620mV



Ch1 200mV 80 Ch2 132mV  
M10.0ms Ch1 1.00 V

28 Apr 2004  
05:54:47


CESI TEST A4/011670 oscillogram n. 14

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Very confidential




CESI TEST A4/011670 oscillogram n. 15

ВЯРНО С ОРИГИНАЛА



28 Apr 2004 06:02:45



28 Apr 2004 06:11:52

CESI TEST A4/011670 oscillogram n. 16

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2003


Original Issue 03-2003

Tek STOP 5.00KS/s

5 Acqs

[T]

Ch2 Zoom: 1.0X Vert 1.0X Horz



Ch2 RMS 622mV

Ch1 200mV 1.00 V M10.0ms Ch1 136mV

28 Apr 2004 06:26:56

*[Handwritten signature]*


*[Handwritten signature]*

*[Handwritten signature]*

CESI TEST A4/011670 oscillogram n. 17

ВЯРНО С ОРИГИНАЛА






CESI TEST A4/011670 oscillogram n. 18

ВЯРНО С ОРИГИНАЛА

*[Handwritten signature]*



28 Apr 2004 06:35:37



28 Apr 2004 06:43:56

*[Handwritten signature]*


CESI TEST A4/011670 oscillogram n. 19

ВЯРНО С ОРИГИНАЛА



*[Handwritten signature]*

*[Handwritten signature]*



28 Apr 2004 07:25:37


CESI TEST A4/011670 oscillogram n. 20

ВЯРНО С ОРИГИНАЛА

*[Handwritten signature]*







*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*


CESI TEST A4/011670 oscillogram n. 21

ВЯРНО С ОРИГИНАЛА



Original Image 00-2000

True Identical




CESI TEST A4/011670 oscillogram n. 22

ВЯРНО С ОРИГИНАЛА



28 Apr 2004 07:44:07



28 Apr 2004 08:51:02

*Handwritten signature*

CESI TEST A4/011670 oscillogram n. 23


ВЯРНО С ОРИГИНАЛ:



*Handwritten signature*

Proprietary/Confidential

Original Issue 00-2005




28 Apr 2004  
09:04:59

CESI TEST A4/011670 oscillogram n. 24

ВЯРНО С ОРИГИНАЛА



Tek Stop 10.0MS/s 3 Acqs



28 Apr 2004 09:26:44


*Handwritten signature*

CESI TEST A4/011670 oscillogram n: 25

ВЯРНО С ОРИГИНАЛА



*Handwritten signature*



28 Apr 2004  
09:43:32

CESI TEST A4/011670 oscillogram n. 26


ВЯРНО С ОРИГИНАЛА



Tek **STOP** Single Seq 10.0MS/s

Ref1 Zoom: 1.0X Vert 2.0X Horz

$\Delta$ : 3.33 V  
@: 3.33 V



M 2.50µs Ch1 J 784mV

Ref1 800mV 2.50µs

28 Apr 2004  
10:03:41

*MS*


CESI TEST A4/011670 oscillogram n. 27

*A*



ВЯРНО С ОРИГИНАЛА

Tek STOP Single Seq 10.0MS/s



28 Apr 2004 10:14:25


CESI TEST A4/011670 oscillogram n. 28

ВЯРНО С ОРИГИНАЛА





Tek **STOP** Single Seq 1.00MS/s



*Handwritten signature*


CESI TEST A4/011670 oscillogram n 29

ВЯРНО С ОРИГИНАЛА



*Handwritten signature*

Tek Stop Single Seq 1.00MS/s




Math1 500mV 500µs

CESI TEST A4/011670 oscillogram n. 30

ВАРНО С ОРИГИНАЛА

*[Handwritten signature]*






*Handwritten signature*

CESI TEST A4/011670 oscillogram n. 31

*Handwritten signature*



ВЯРНО С ОРИГИНАЛА



CESI TEST A4/011670 oscillogram n. 32


ВЯРНО С ОРИГИНАЛА




Original Issue 03-2007

Original Issue 03-2007

BUF.A1



BUF.A2





CESI TEST A4/011670 oscillogram n. 33

ВЯРНО С ОРИГИНАЛА



Fig. 00 Confidential

Original Issue 03-2003



CESI TEST A4/011670 oscillogram n. 34


ВЯРНО С ОРИГИНАЛА



Original Issue 02-2005

CONFIDENTIAL

BUF .A1



BUF .A2




CESI TEST A4/011670 oscillogram n. 35

ВЯРНО С ОРИГИНАЛА



*Handwritten signature*

Tek STOP Single Seq 1.00MS/s



Math1 500mV 500µs

CESI TEST A4/011670 oscillogram n. 36


ВЯРНО С ОРИГИНАЛА

*[Handwritten signature]*





Tek **stop** Single Seq 1.00MS/s



*[Handwritten signature]*


CESI TEST A4/011670 oscillogram n. 37

*[Handwritten signature]*

ВАРНО С ОРИГИНАЛА




Tek STOP Single Seq 1.00kS/s



CESI TEST A4/011670 oscillogram n. 38

ВЯРНО С ОРИГИНАЛА





*Handwritten signature*

CESI TEST A4/011670 oscillogram n. 39


ВЯРНО С ОРИГИНАЛА




Very Confidential

Original Issue 03-2003

BUF.A1



BUF.A2



CESI TEST A4/011670 oscillogram n. 40

ВЯРНО С ОРИГИНАЛА




Тип: конфиденциал

Original Issue 03-2005

BUF . A1



BUF . A2



CESI TEST A4/011670 oscillogram n. 41

ВЯРНО С ОРИГИНАЛА




CONFIDENTIAL

Original Issue 00-2005

BUF.A1



BUF.A2




CESI TEST A4/011670 oscillogram n. 42

ВЯРНО С ОРИГИНАЛА



Tek STOP Single Seq 1.00MS/s



*[Handwritten signature]*

CESI TEST A4/011670 oscillogram n. 43


ВЯРНО С ОРИГИНАЛА



*[Handwritten signature]*

Typical Confidential

Original Issue 03-2007




CESI TEST A4/011670 oscillogram n. 44

ВЯРНО С ОРИГИНАЛА





Tek STOP Single Seq 1.00kS/s



*MS*

*[Handwritten signature]*


CESI TEST A4/011670 oscillogram n 45

ВЯРНО С ОРИГИНАЛА



Very confidential

Original issue 02-2005




CESI TEST A4/011670 oscillogram n. 46

ВЯРНО С ОРИГИНАЛА




BUF.A1



*[Handwritten signature]*

BUF.A2



*[Handwritten signature]*

*[Handwritten signature]*

CESI TEST A4/011670 oscillogram n. 47


ВЯРНО С ОРИГИНАЛА




Top Confidential

Original Issue 02-2005

BUF.A1




BUF.A2



CESI TEST A4/011670 oscillogram n. 48

ВЯРНО С ОРИГИНАЛА



Typo confidential


Original issue 03-2005

BUF . A1



*[Handwritten signature]*

BUF . A2



*[Handwritten signature]*


CESI TEST A4/011670 oscillogram n. 49

ВЯРНО С ОРИГИНАЛА



Typical confidential

Original Issue 03-2007




CESI TEST A4/011670 oscillogram n. 50

ВЯРНО С ОРИГИНАЛА



Original Issue 03-2005

Not confidential



*Handwritten signature*

CESI TEST A4/011670 oscillogram n. 51


**ВЯРНО С ОРИГИНАЛА**



*Handwritten signature*

For confidential

Original Issue 03-2003




CESI TEST A4/011670 oscillogram n. 52

ВЯРНО С ОРИГИНАЛА








*[Handwritten signature]*

CESI TEST A4/011670 oscillogram n. 53

ВЯРНО С ОРИГИНАЛА



*[Handwritten signature]*




CESI TEST A4/011670

oscillogram n. 54

ВЯРНО С ОРИГИНАЛА





*MS*



*[Handwritten signature]*

*[Handwritten signature]*


CESI TEST A4/011670 oscillogram n. 55

ВЯРНО С ОРИГИНАЛА





CREEPAGE=265mm  
 DRY ARC DIST=138mm



SPECIFICATIONS		TITLE	
ITEM NO.	DATE	DESIGN NO.	REV.
DESCRIPTION	REV.	DATE	REV.
<b>ENERGY DIVISION</b> SKV 10KA DCP2 SURGE ARRESTER PRODUCT		SKV 10KA DCP2 SURGE ARRESTER PRODUCT SECT 1 OF 1	

PROJ. 020203  
 11 FEB 2002  
 DATA




ВАРНО С ОРИГИНАЛА

# TEST REPORT

041103/OCP2-THC

## OCP2 Thermal behaviour



На основании чл. 2  
от ЗЗЛД

PROT. n.A4/524523  
GESI 27 DIC. 2004  
TEST  
COPIA  
A

На основании чл. 2  
от ЗЗЛД

Registered in England No. 2266375. Registered Office Faraday Road,  
A tyco INTERNATIONAL LTD

ВЯРНО С ОРИГИНАЛА





**Приложение 2 към Техническо предложение****ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ  
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 2.7.**





Списък на проведените изпитвания на Вентилни разрядници тип DA1 съгласно  
IEC 60099-4, 2006-07 изд. 2.1

№	Типово изпитване	Лаб.	№ на протокола	т. от стандарта IEC 60099-4	№ на документа
1	Изпитване на изолацията на външната обвивка	EGU	9301/A/07	10.8.2	2276
2	Тест на остатъчни напрежения	CESI	A7020275	10.8.3	2277
3	Продължителен токов импулс	CESI	A7020276	10.8.4	2278
4	Работно натоварване	CESI	A7020582	10.8.8	2279
5	Тест токове на късо съединение	CESI	A7029908	10.8.7	2280
6	Частични разряди	CESI	A7031384, A7031450	10.8.8	-
7	Усукващ момент	CESI	A7031450	10.8.9	2281
8	Устойчивост на проникване на влага	CESI	A7031384	10.8.13	2282
9	Устойчивост на климатични въздействия	EGU	7725/A/07	10.8.14	2283
10	Характеристика – време/напрежение	CESI	A7020280	6.10, Annex D	2285

*Handwritten signature*

*Handwritten signature*

*Handwritten signature*  
**ВЯРНО С ОРИГИНАЛА**



ВАРИАНТ С ОПЕЧАТКАМИ





DA1 qualification summary  
(IEC 60099-4, 2006-07 Ed 2.1)

No.	Type Test	Lab	Test Report Number	60099-4 2006-07 Ed. 2.1	PPR Number
1	Insulation withstand tests on the arrester housing	EGU	9301/A/07	10.8.2	2276
2	Residual voltage tests	CESI	A7020275	10.8.3	2277
3	Long-duration current impulse withstand test	CESI	A7020276	10.8.4	2278
4	Operating duty tests	CESI	A7020582	10.8.5	2279
5	Short-circuit tests	CESI	A7029908	10.8.7	2280
6	Internal partial discharge tests	CESI	Refer to A7031384 and A7031450	10.8.8	-
7	Test of the bending moment	CESI	A7031450	10.8.9	2281
8	Moisture Ingress Test	CESI	A7031384	10.8.13	2282
9	Weather Ageing Test	EGU	7725/A/07	10.8.14	2283
10	Power –frequency voltage versus time characteristics on an arrester	CESI	A7020280	6.10, Annex D	2285

All type tests were carried out at independent accredited test laboratories:

- EGU - HV laboratory, Prague Czech Republic
- CESI - HV laboratory, Milan, Italy



For further information contact: [surgearresters@tycoelectronics.com](mailto:surgearresters@tycoelectronics.com)

ВЯРНО С ОРИГИНАЛА



ROMA C. ...





DA1 - Distribution Surge Arrester  
Bending Moment  
Type Test Report

*PA*

*MS*



**Tyco Electronics**

Our commitment. Your advantage.

ВЯРНО С ОРИГИНАЛА



## Test Report

---

Type	DA1
PPR Number	PPR-2276
Test Specification	Insulation withstand tests on the arrester housing IEC 60099-4 (2006-07) Ed. 2.1

### Test Information:

Laboratory	EGU
Date	16/11/2007
External Test Ref	9301/A/07
Test Performed by	M. Brosch
Test Approved by	V. Sklenicka


### Tyco Approvals:

---

<b>R&amp;D Manager</b> Brendan Normoyle	<div style="border: 1px solid red; padding: 5px;">На основании чл. 2 от 33ЛД</div>	Date 28/11/2007
<b>Product Manager</b> Brian McGowan		Date 28/11/2007

---


For further information contact:  
Tyco Electronics Energy Division  
Bay 100-109  
Shannon Industrial Estate  
Co. Clare, Ireland  
Tel: + 353-61-472885  
Fax: + 353-61-472676  
Email: [mvsurgearresters@tycoelectronics.com](mailto:mvsurgearresters@tycoelectronics.com)



# EGU - HV Laboratory a. s.

High voltage testing laboratory

Areál výzkumných ústavů 267, Praha 9, Běchovice



**CUSTOMER:**

Tyco Electronics  
Shannon Industrial Estate  
100-104 BAY  
SHANNON  
IRELAND

**ORDER No.:**

2250310811  
2250310637

**DATE OF TEST:**

from 2007-09-10 till 2007-10-09

**TEST No.:**

9301/07

## TEST REPORT

No.: 9301/A/07

**TEST OBJECT:** SURGE ARRESTERS

**TYPE :** DA1

**PRODUCER:** TYCO Electronics

**TEST STANDARD:** IEC 60060-1:1989, IEC60099-4:2006-07 Ed. 2.1

На основании чл. 2  
от ЗЗЛД

Test report is confidential and must not be passed over or transferred to any third party without written approval of the customer. Test results relate only to the tests given in presented report and do not substitute any other documents. The report shall not be reproduced except in full without written approval of the testing laboratory.

In Prague 9 - Běchovice: 2007-11-16

ВЯРНО С ОРИГИНАЛА



**TEST OBJECTS:**

**SURGE ARRESTERS**

Housing Type	DA1-xxA	DA1-xxB	DA1-xxC	DA1-xxE	DA1-xxF	DA1-xxG
Arrester Drawing	DA1-xxA-NONONO	DA1-xxB-NONONO	DA1-xxC-NONONO	DA1-xxE-NONONO	DA1-xxF-NONONO	DA1-xxG-NONONO
Figure	1	2	3	4	5	6
Sheds	4	5	7	9	10	12
Product Length (mm)	147	172	222	272	297	347
Creepage (mm)	329	404	553	702	776	925
Dry arc distance (mm)	152	177	227	277	302	352

**DATE OF DELIVERY**

2007-09-07 and 2007-09-20

**SCHEDULE OF TESTS**

*Insulation withstand tests on the arrester housing*

- 1. Lightning impulse voltage test IEC 60099-4, clause 8.2.6
- 2. Wet power-frequency voltage test IEC 60099-4, clause 8.2.8

**TEST PROCEDURE**

**1. Dry lightning impulse voltage test**


Test was carried out in compliance with IEC 60099-4, clause 8.2.6 and in compliance with IEC 60060-1, clause 20.1.2.

Fifteen impulses of both positive and negative polarities were applied to the test object at the given lightning impulse voltage. This procedure was repeated to determine the maximum withstand lightning impulse voltage level ( $U_{MWLI}$ ).


The wave shape of the test lightning impulse is given in Figure 7.

The test arrangement is given on Figure 8.

**Testing and measuring devices:**



impulse generator TuR Dresden 750 kV, 30 kJ  
 $R_{d1}/R_{d2}$  - resistive divider Haefely, type R 800, serial No. 554333  
 measuring system Haefely Trench, type HiAS 743, serial No. 080649-01  
 measuring system for atmospheric conditions, COMET, D4130, serial No. 04900257






**2. Wet power-frequency voltage test**

Test was carried out in compliance with IEC 60099-4, clause 8.2.8 and in compliance with IEC 60060-1, clause 17.

The one minute maximum wet power-frequency withstand voltage ( $U_{MW}$ ) was measured according to IEC 60060-1, clause 17.1.

The test arrangement is given on Figure 9.

**Testing and measuring devices:**



- G - synchronous generator BEZ Bratislava 6 kV, 1300 kVA, 50 Hz
- T - test transformer Fischer-Köln, 3-6/250 kV, 250 kVA
- IVT – instrument voltage transformer Škoda, 380/√3 kV / 100/√3 V, serial No. 917355
- universal voltmeter Siemens, type MU 15, serial No. 879953
- measuring system for atmospheric conditions, COMET, D4130, serial No. 04900257
- digital stop-watch Speedo

**UNCERTAINTY OF MEASUREMENT**

QUANTITY	UNCERTAINTY	
	k=2	
<i>Lightning impulse voltage</i>	$U_m$	1,5 %
	$T_1$	2,6 %
	$T_2$	2,2 %
<i>Power-frequency voltage</i>	1,7 %	
<i>Temperature</i>	0,7 °C	
<i>Air pressure</i>	0,04 kPa	
<i>Relative humidity</i>	4 %	
<i>Time</i>	0,2 %	

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor  $k = 2$ , which for a normal distribution corresponds to a coverage probability of approximately 95 %.

*MS*

*A*

*[Signature]*

ВЯРНО С ОРИГИНАЛА



### LIST OF SYMBOLS

All measured voltages are corrected for the standard reference atmosphere according to IEC 60060-1, clause 11.

All measured data including values of atmospheric conditions as well as corresponding correction factors are given in the following tables where:


**b** atmospheric pressure (kPa),  
**t** air temperature (°C),  
**RH** relative humidity (%)

**k<sub>1</sub>** air density correction factor,  
**k<sub>2</sub>** humidity correction factor,  
**K<sub>t</sub>** atmospheric correction factor,

**r.i.** average value of rainfall intensity (mm/min):  
v.c. - vertical component,  
h.c. - horizontal component,  
**ρ** water resistivity (Ωm)

**U<sub>MVLI</sub>** dry lightning impulse maximum withstand voltage (kV), corresponding to standard reference atmosphere

**U<sub>MW</sub>** wet power-frequency maximum withstand voltage (kV), corresponding to standard reference atmosphere (test duration - 60 s).



**TEST RESULTS**

**1. Dry lightning impulse voltage test**

Table 1

Type of the arrester	DA1-xxA		DA1-xxB		DA1-xxC		DA1-xxE		DA1-xxF		DA1-xxG	
	+	-	+	-	+	-	+	-	+	-	+	-
b (kPa)	99,1		97,7		98,1		98,2		98,2		98,2	
t (°C)	17,4		20,9		18,1		19,4		19,4		19,4	
RH (%)	58,2		58,1		59,2		52,9		52,9		52,9	
k <sub>1</sub>	0,987	0,987	0,961	0,961	0,975	0,975	0,971	0,971	0,971	0,971	0,971	0,971
k <sub>2</sub>	1,000	1,000	1,000	1,000	1,000	1,000	1,000	0,999	0,999	0,998	0,997	0,997
K <sub>t</sub>	0,987	0,987	0,961	0,961	0,975	0,975	0,972	0,970	0,970	0,969	0,969	0,969
U <sub>MWLI</sub>	187	134	160	161	220	194	244	229	256	247	273	275

**2. Wet power-frequency voltage test**

Table 2

Type of the arrester		DA1-xxA	DA1-xxB	DA1-xxC	DA1-xxE	DA1-xxF	DA1-xxG
b (kPa)		99,5	99,0	99,0	99,0	99,0	99,0
t (°C)		17,1	18,7	18,7	18,7	18,7	18,7
RH (%)		65,0	67,5	67,5	67,5	67,5	67,5
r.i. (mm/min)	v.c.	1,2	1,0	1,0	1,0	1,0	1,0
	h.c.	1,0	1,0	1,0	1,0	1,0	1,0
ρ (Ωm)		104	99	99	99	99	99
k <sub>1</sub>		0,992	0,990	0,984	0,982	0,982	0,982
k <sub>2</sub>		1,000	1,000	1,000	1,000	1,000	1,000
K <sub>t</sub>		0,992	0,990	0,984	0,982	0,982	0,982
U <sub>MW</sub>		50	56	66	92	102	122

ВЯРНО С ОРИГИНАЛА







Figure 1  
Surge arrester type DA1-xxA, drawing No DA1-xxA-N0N0N0






Figure 2  
Surge arrester type DA1-xxB, drawing No DA1-xxB-N0N0N0

*[Handwritten signature]*

7/13



ВАРНО С ОРИГИНАЛА





Figure 3  
Surge arrester type DA1-xxC, drawing No DA1-xxC-N0N0N0






Figure 4  
Surge arrester type DA1-xxE, drawing No DA1-xxE-N0N0N0

*Handwritten signature*

9/13



ВЪРНО С ОРИГИНАЛА





Figure 5  
Surge arrester type DA1-xxF, drawing No DA1-xxF-N0N0N0









Figure 6  
Surge arrester type DA1-xxG, drawing No DA1-xxG-N0N0N0

ВЯРНО С ОРИГИНАЛА



TYCO ELECTRONICS, SHANNON / OMEZOVAC "B" (IEC 99-4)


18/09/2007 10:03:41



No. 1  
LI full  
Upk : 153.386 kV  
T1 : 1.179 μs  
T2 : 48.862 μs

TYCO ELECTRONICS, SHANNON / OMEZOVAC "B" (IEC 99-4)


18/09/2007 10:21:45




No. 3  
LI full  
Upk : -155.284 kV  
T1 : 1.209 μs  
T2 : 48.967 μs


Figure 7

The wave shape of the test lightning impulse 1,2/50 μs





**Figure 8**  
**Surge arrester type DA1**  
**test arrangement under the dry lightning impulse voltage test**



**Figure 9**  
**Surge arrester type DA1**  
**test arrangement under the wet power-frequency voltage test**


*Handwritten signature*


13/13

ВЯРНО С ОРИГИНАЛА

*Handwritten signature*  
*Handwritten signature*  
ОКМОНЕРНО ДРУЖЕСТВО  
ФИЛКАБ  
16  
ПЛОВДИВ

ВЕРНО С ОРИГИНАЛА





DA1 - Distribution Surge Arrester  
Residual Voltage Tests  
Type Test Report

*Handwritten initials*

*Handwritten signature*



**Tyco Electronics**

Our commitment. Your advantage.

**ВЯРНО С ОРИГИНАЛА**



## Test Report

---

Type	DA1
PPR Number	PPR-2277
Test Specification	Residual voltage tests IEC 60099-4 (2006-07) Ed. 2.1

### Test Information:

Laboratory	CESI
Date	3/09/2007
External Test Ref	A7020275
Report Prepared by	M. Gregori
Test Verified by	A. Sironi
Test Approved by	V. Scarioni

### Tyco Approvals:

---

**R&D Manager**

Brendan Normoyle

---

**Product Manager**

Brian McGowan

---


На основании чл. 2  
от ЗЗЛД

Date 28/11/2007

Date 28/11/2007

For further information contact:  
Tyco Electronics Energy Division  
Bay 100-109  
Shannon Industrial Estate  
Co. Clare, Ireland  
Tel: + 353-61-472885  
Fax: + 353-61-472676  
Email: [mvsurgearresters@tycoelectronics.com](mailto:mvsurgearresters@tycoelectronics.com)

REPORT OF TESTS



Client TYCO Electronics – Shannon ( Ireland )

Tested equipment Polymer-housed metal-oxide surge arrester section type DA1

Tests carried out Residual voltage tests

Standards/Specifications IEC 60099-4 – Edition 2.1 (2006-07)

Test date From July 25 , 2007 to July 30, 2007

PUBBLICATO A7020275 (PAD - 980975)

The results reported in this document relate only to the tested equipment.  
 Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 17 No. of pages annexed 23

Issue date September 03, 2007

Prepared Unit LABORATORIES

Verified Unit LABORATORIES

Approved Area COMPONENTS -

На основание чл. 2  
от ЗЗЛД

ВАРНО С ОРИГИНАЛА



Tests witnessed by: -

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object. This drawing, identified by CESI and numbered A7027907 No. 1, is annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked: ---

- dielectric tests with impulse voltage : peak voltage: ± 3 %; time parameters: ± 10 %
- dielectric tests with impulse current : peak value: ± 3 %; time parameters: ± 10 %
- dielectric tests with alternating voltage : voltage (rms): ± 3 %
- dielectric tests with direct voltage : voltage: ± 3 %

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values

Laboratory information

Receipt date of the sample

Test location

CESI testing team

Test laboratory

Activity code

На основании чл. 2 от ЗЗЛД

ВЕРНО С ОФИСАЛА





content	page	test date
Test object characteristics	4	
Photograph of the test sample	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Lightning impulse residual voltage test	from page 8 to 9	July 25, 2007
Switching impulse residual voltage test	10	July 25, 2007
Steep current impulse residual voltage test (measurement of inductive error)	11	July 30, 2007
Steep current impulse residual voltage test	12	July 30, 2007
Reference voltage test	13	July 30, 2007
Technical data	from page 14 to 17	

*[Handwritten signature]*

ВЯРНО С ОРИГИНАЛА

Pages annexed:  
oscillograms n. 22 pages

Document annexed:

Тусо Electronics drawing n.DA1-6.5-NONONO, CESI n. A7027907 - n. 1 page



*[Handwritten signature]*

**Test Report**





Test object characteristics

type: Polymer-housed metal-oxide surge arrester sections

electrical characteristics (assigned by the client)

Manufacturer's name	TYCO Electronics – Shannon (Ireland)
type	DAI
Nominal discharge current – $I_n$ [kA]	10
Rated voltage – $U_r$ [kV]	1,045 x $U_{ref}$
Continuous operating voltage - $U_c$ [kV]	0,836 x $U_{ref}$
Reference current - $I_{ref}$ [mA]	5,0
Line discharge class	1
Standard rated frequency - [Hz]	50/60
year of manufacture	2007



View of the test object




Photo no. 1

Polymer-housed metal-oxide surge arrester section

*MS*

*[Handwritten signature]*

ВАРНО С ОРИГИНАЛА




Reference Standard

IEC 60099-4 – Edition 2.1 (2006-07) - Clause 10.8.3  
 “Metal-oxide surge arresters without gaps for a.c. system”

Test carried out	Number of sample tested
Lightning impulse residual voltage test	3
Switching impulse residual voltage test	
Steep current impulse residual voltage test	

Test object identification

Test object name	Identification of test sample (given by CESI)
Polymer- housed metal-oxide surge arrester section	RV1-RV2-RV3



### Test procedure

The following tests have been carried out on the same three samples

#### a) Lightning impulse residual voltage test

- wave-shape 8/20  $\mu$ s
- peak current  $I_n = 10$  kA,  $0,5 I_n = 5$  kA &  $2 I_n = 20$  kA

#### b) Switching impulse residual voltage test

- wave-shape front time in the range 30 $\mu$ s to 100 $\mu$ s, tail time twice the virtual time
- peak current 125 A & 500 A (according to table 4 of the reference standard)

#### c) Steep current impulse residual voltage test

- wave-shape front time equal to 1  $\mu$ s, tail time less than 20  $\mu$ s
- peak current  $I_n = 10$  kA
- note Correction of the inductive error

The inductive error was determined replacing the surge arrester section with a metal part having the same dimensions and measuring the voltage across the metal part in this condition..

Being the inductive error (peak value) in the range 2% to 20% of the measured residual voltage (peak value) the correction was applied by subtracting the impulse voltage shape measured on the surge arrester section and the impulse voltage shape on the metal part.

In addition , upon client request, the reference voltage was measured at the reference current

### Test result

See relevant pages .



Residual voltage tests

Lightning impulse residual voltage test.



Test circuit: A0120

Date: July 25, 2007


Sample	Requested current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage	Lightning impulse protection level
No.		kV	No.	$\mu$ s	kA	kV	kV
RV1	$0,5 \times I_n$	21,8	04	8,9/19,0	5,00	15,12	17,65
	$I_n$	30,5	01	8,8/18,9	10,0	16,10	
	$2,0 \times I_n$	45,7	07	8,9/19,0	20,14	17,65	
RV2	$0,5 \times I_n$	21,8	05	8,9/19,0	5,05	14,99	
	$I_n$	30,2	02	8,8/18,9	10,07	16,09	
	$2,0 \times I_n$	45,6	08	8,9/19,0	20,20	17,58	
RV3	$0,5 \times I_n$	21,7	06	8,9/19,0	4,96	14,99	
	$I_n$	30,0	03	8,8/18,9	10,15	16,08	
	$2,0 \times I_n$	45,5	09	8,9/19,0	20,17	17,55	

	Requested current	Oscilloscope settings		
		sampling division	input	Attenuation
		$\mu$ s	$V_{div}$	
Current	$0,5 \times I_n$	5	0,5	20:10
	$I_n$		1,0	50:10
	$2 \times I_n$		1,0	50:10
Voltage	$0,5 \times I_n$	5	1,0	20:5
	$I_n$		1,0	20:5
	$2 \times I_n$		1,0	20:5

Notes:



### Lightning impulse protection level



*[Handwritten signature]*

ВЯРНО С ОРИГИНАЛА



**Residual voltage tests**

**Switching impulse residual voltage test.**


Test circuit: A0122

Date: July 25, 2007

Sample	Requested current	Charging Voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage	Switching impulse protection level
No.	A	kV	No.	$\mu$ s	A	kV	kV
RV1	125	13,2	10	31,0/72,0	131	12,06	12,81
	500	18,0	13	33,0/71,0	500	12,80	
RV2	125	13,2	11	31,0/72,0	119	12,02	
	500	18,0	14	33,0/71,0	501	12,81	
RV3	125	13,1	12	31,0/72,0	123	12,11	
	500	18,0	15	33,0/71,0	498	12,80	

Oscilloscope settings			
	sampling division	Input	attenuation
	$\mu$ s	V <sub>div</sub>	
(125 A) Current	20	0,5	10:10
Voltage		1,0	20:5
(500A) Current		0,5	50:10
Voltage		0,5	20:5

Notes:





Residual voltage tests

Steep current impulse residual voltage test.

Measurement of the inductive error

Test circuit: A0121B

Date: July 30, 2007

Sample	Charging voltage	Oscillogram	Current waveshape	Discharge current	Peak voltage	Inductive error
No.	kV	No.	$\mu$ s	kA	V	%
aluminium blocks	35,0,	16	0,95/2,1	10,2	530	2 $\pm$ 20 (1)

	Oscilloscope settings		
	sampling division	input	attenuation
	$\mu$ s	V <sub>div</sub>	
Current	1	2	x 10
Voltage		1,0	---

Notes: (1) correction is required

ВЯРНО С ОРИГИНАЛА



Residual voltage tests

Steep current impulse residual voltage test.


Test circuit: A0121B

Date: July 30, 2007

Sample	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage	Steep current impulse protection level
No.	kV	No.	$\mu$ s	kA	kV	kV
RV1	34,1	17	0,95/2,1	10,00	16,93	16,93
RV2	34,1	18		10,11	16,83	
RV3	34,1	19		10,03	16,73	

	Oscilloscope settings		
	sampling division	input	attenuation
	$\mu$ s	V <sub>div</sub>	
Current	1	2	x10
Voltage		5,0	---

Notes:



Residual voltage tests

Reference voltage test

Test circuit: A019

Date: July 30, 2007

Sample No. RV1						
oscillogram	voltage	current	current	current	power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
20	6,82	3,10	5,03	1,55	6,54	---


Sample No. RV2						
oscillogram	voltage	current	current	current	power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
21	6,78	3,08	5,10	1,53	6,59	---

Sample No. RV3						
oscillogram	voltage	current	current	current	power	3rd harmonic amplitude
No.	kV	+ mA <sub>cr</sub>	- mA <sub>cr</sub>	mA <sub>rms</sub>	W	μA
22	6,77	3,20	5,09	1,51	6,64	---

ВАРНО С ОРИГИНАЛА



Circuit A0120



**Impulse generator**


- No. of stages 1
- Cg 4,98  $\mu$ F
- Lc 10  $\mu$ H
- S - Spark-gap

**Voltage measuring system.**


- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

**Current measuring system**

- Sh - Current shunt CESI No.6042; R= 2 m $\Omega$ ; peak current= 250 kA
- Electro optical system CESI No.11517/518;
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)



Circuit A0122



**Impulse generator**

- No. of stages 1
- Cg 2,49 $\mu$ F
- Lc 120  $\mu$ H
- S - Spark-gap

**Voltage measuring system.**

- D - Voltage divider SAGI; CESI No.13027
- Electro optical system CESI No 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

**Current measuring system**


- Sh - Current shunt CESI No.6037; R= 20 m $\Omega$ ; peak current= 250 kA
- Electro optical system CESI No11517/518
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

*[Handwritten signature]*

ВЯРНО С ОРИГИНАЛА



Circuit A0121B



**Impulse generator**

No. of stages 1  
 Cg 0,500  $\mu$ F


S - Spark-gap

**Voltage measuring system.**


D - Voltage divider SAGI; CESI No.11120  
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

**Current measuring system**

Sh - Current Pearson CESI No.6042; 0,01 V x A  
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)



Circuit A0019



Power frequency supply

- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system

- R - Current shunt CESI No.31 120;  $R= 941,4 \Omega$
- Electro optical system CESI No. -- ; attenuation
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI No.6318


Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/1522; attenuation 50:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI No.6318

*MS*


*AK*






CESI A7020275 - Oscillogram n. 1

LABORIO DI ELETTRONICA








*[Handwritten signature]*

CESI A7020275 Oscillogram n. 2

ВЯРНО С ОРИГИНАЛА






CESI A7020275 Oscillogram n. 3

ARMANDO C. COPPINI






CESI A7020275 Oscillogram n. 4

*[Handwritten signature]*

ВЯРНО С ОРИГИНАЛА




*[Handwritten signature]*



CESI A7020275 Oscillogram n. 5

ВАРНО С ОБРАЗОВАНИЕ






CESI A7020275 Oscillogram n. 6


*[Handwritten signature]*

ВЯРНО С ОРИГИНАЛА






CESI A7020275 Oscillogram n. 7








CESI A7020275 Oscillogram n. 8

*[Handwritten signature]*

ВЯРНО С ОРИГИНАЛА






CESI A7020275 Oscillogram n. 9

ВЕРНО С ОРИГИНАЛА








CESI A7020275 Oscillogram n. 10

*Handwritten signature*


ВЯРНО С ОРИГИНАЛА






CESI A7020275 Oscillogram n. 11

ВАТНО С ОРНИКНАДА






CESI A7020275 Oscillogram n. 12


*Handwritten signature*


ВЯРНО С ОРИГИНАЛА





CESI A7020275 Oscillogram n. 13






CESI A7020275 Oscillogram n. 14

*Handwritten signature*

ВЯРНО С ОРИГИНАЛА






CESI A7020275 Oscillogram n. 15

ВЕРНО С СЕР...








CESI A7020275 Oscillogram n. 16

*[Handwritten signature]*

ВЯРНО С ОРИГИНАЛА





CESI A7020275 Oscillogram n. 17

ОРИГОН С ОРИГИНАЛА

