



**HIGH VOLTAGE LABORATORY  
INSTYTUT ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
tel. fax. (22) 8366048, e-mail: ewn@ten.com.pl

EWN/134/E/15

Annex 1


**ANNEX 1 for test report EWN/134/E/15**

(3 pages)

Documents provided by ABB Sp. z o.o. used as base of identification of test

object:

- Declaration of conformity – No. 102/2015 (EN),
- Rating plate – Document No. 1HSE 22040-PCB,
- Technical drawing – Document id. 1HSE8851773.

<b>ABB</b>	Declaration of conformity	ABB Sp. z o.o. Dept. in Przasnysz POLAND
<b>DECLARATION OF CONFORMITY No. 102/2015 (EN)</b> (acc. to ISO/IEC 17050-1)		
Manufacturer:	ABB	
Product:	Voltage Instrument Transformer EMF-E145	
Above mentioned product conforms with the following standard :		
Standard	Title	Edition/Date
IEC 61869 - 3	Voltage Instrument Transformers	2015
Additional information: Serial numbers: 1HSE8851773;		
Place and date of issue of declaration Przasnysz 29.10.2015		
 Kierownik ds. Zapewnienia Jakości ABB Sp. z o.o. Oddział w Przasnyszu Krzysztof Lubocki (Signature)		

**ABB** Voltage transformer  
 Serial number: 1HSE8851773  
 Insulation level: 145 kV  
 Rated primary voltage: 275/650 kV  
 Highest voltage for equipment: 145 kV  
 Temperature range: -40 ~ +40 °C  
 Total mass: 295 kg

ABB AB  
 Type: EMF-E145  
 Production year: VVVV  
 Standard: IEC 61853-3  
 Frequency: 50 Hz  
 Made in Sweden

1HSE 88504-5

Serial number: 1HSE8851773

Insulation oil: IEC 61853-3

Transformer: IEC 61853-3

Terminal	Voltage V	Class	Burden VA	Total burden VA	Normal limit VA
A-N	145000/23	0.1	0.05	0.05	0.05
In	145/23	0.1	0.05	0.05	0.05
2n	145/23	0.1	0.05	0.05	0.05
3n	145/23	0.1	0.05	0.05	0.05
4n	145/23	0.1	0.05	0.05	0.05
5n	145/23	0.1	0.05	0.05	0.05
6n	145/23	0.1	0.05	0.05	0.05
7n	145/23	0.1	0.05	0.05	0.05
8n	145/23	0.1	0.05	0.05	0.05
9n	145/23	0.1	0.05	0.05	0.05
10n	145/23	0.1	0.05	0.05	0.05
11n	145/23	0.1	0.05	0.05	0.05
12n	145/23	0.1	0.05	0.05	0.05
13n	145/23	0.1	0.05	0.05	0.05
14n	145/23	0.1	0.05	0.05	0.05
15n	145/23	0.1	0.05	0.05	0.05
16n	145/23	0.1	0.05	0.05	0.05




ABB Technology Ltd  
 Copyright 2015 ABB  
 Project: 2015-14-03  
 Drawing: 2015-14-03  
 Revision: 2015-14-03  
 Title: Voltage Transformer EMF-E145

Mass = 274 kg

Item No.	Qty	Part No.	Name	Rev
16	1	20HV027107	Oil	
15	60	20HV027107	Oil	
14	1	20HV027107	Oil	
13	1	20HV027101	Plate	
12	1	1HSE5314-B	Expansion gasket	
11	1	1HSE1658-B	Insulator	
10	4	578 M4	Screw M4	
9	8	578 M4	Washer	
8	1	20HV042554	Terminal box	
7	4	578 M4	Screw M4	
6	20	578 M4	Screw M4	
5	17	578 M4	Washer	
4	1	20HV027089	Plug	
3	1	20HV028424	Washer	
2	1	20HV027053	Terminal cover	
1	1	20HV027027	Tank	

Prepared	Gustaf Högberg	2015-06-18	Responsible department	PPHC/IM
Approved	Björn Sjöström	2015-06-18	Take over department	
Revision	A	Data changed, 2015-07-01	Order No.	E90000012-20
	ABB AB		Document No.	1HSE 22040-PCB
			Sheet	1
			Language	CD
			Title	Rating plate

We reserve all rights in this document and in the information contained herein. Reproduction, distribution or use in any form without express authority is strictly prohibited. © ABB Power Technologies AB (2015)

This document is issued by means of a computerized process. The digitally signed original is electronically approved. The approved document has a date entered in the Approved-field. A manual signature is not required.



**HIGH VOLTAGE LABORATORY**  
**INSTYTUT ENERGETYKI**  
 01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
 tel. fax. (22) 3563048, e-mail: ewn@ien.com.pl

EWN/134/E/15

Annex 2

**ANNEX 2 for test report EWN/134/E/15**

(8 pages)

Reports of routine test and determination of errors:

- Routine test report of voltage instrument transformer EMF-145 (1HSE8851773),
- Routine test report of voltage instrument transformer EMF-145 (1HSE8851773) after lightning impulse,

<b>ABB Sp. z o.o.</b> 06-300 Przasnysz ul. Leszno 59		<b>Routine test report of voltage instrument Transformer</b>		<b>TYPE:</b> EMF-E145
A-N	145/√3 kV	145/275/650 kV	Voltage factor: 1.9/8h	Serial no: 1HSE8851773
				IEC 61869-3
				50 Hz

Winding	U <sub>sn</sub> [kV]	S <sub>n</sub> [VA]	Class	S <sub>th</sub> [VA]
1a - 1n	0,115·√3	25	0,1	1500
1a - 1n	0,115·√3	25	1,0	1500
2a - 2n	0,115·√3	25	0,1	1500
2a - 2n	0,115·√3	25	1,0	1500
3a - 3n	0,115·√3	25	0,1/3P	1500
3a - 3n	0,115·√3	500	3,0/3P	1500
da - dn	0,115	100	0,1	450
da - dn	0,115	300	3P	450

1. Oil dielectric parameters check before filling (oil after treatment):  
 tg δ acc. IEC 60247, breakdown voltage acc. IEC 60156
2. Verification of terminal markings
3. Pressure and tightness test: oil overpressure: 0,8 bar / 24h - no traces of oil leakage
4. Power-frequency withstand test on primary windings  
 - A: U<sub>p</sub> = 275kV / 60s, f = 120Hz; N: U<sub>p</sub> = 3kV / 60s, f = 50Hz
5. Partial discharge measurement - U<sub>p</sub> = 3 kV/60s
6. Power-frequency withstand test on secondary windings.
7. Determination of errors
8. Measurement of capacitance and dielectric dissipation factor - tg δ
9. Measurement of windings' resistance

**Oil dielectric parameters check before filling (oil after treatment)**

- Measurement of oil tg δ according to IEC 60247  
 Tg δ = 0.0909 %; electrical stress = 1kV/mm, f = 50Hz, oil temp. = 90C ±1C.

- Measurement of breakdown voltage according to IEC 60156  
 Mean breakdown voltage = 75.58 kV, Relative standard deviation = 4.66 %;  
 f = 50Hz, oil temp. = 22.8 °C, measurement without the stirrer, type of electrodes used; partially spherical.

Sample	Breakdown voltage [kV]
1	78.6
2	73.5
3	75.3
4	77.2
5	68.8
6	79.1



ABB Sp. z o.o. 06-300 Przasnysz ul. Leszno 59		Routine test report of voltage instrument transformer after lightning impulse		TYPE: EMF-E145 Serial no: 1HSE8851773	
A-N	145√3 kV	145/275/650 kV	Voltage factor: 1.9/8h	IEC 61869-3	50 Hz

Measurement of capacitance and dielectric dissipation factor - tg δ  
Temperature: 23 °C, Frequency: 50 Hz


Primary voltage	Tg δ [%]	Capacity [pF]	Leak current [mA]
10 kV	0.21	238	0.773
84 kV	0.24	239	6.309
84 kV	0.24	239	6.309

Measurement of windings' resistance

	R (23 °C)	Rct (75 °C)
A-N	18.20 kΩ	21.919 kΩ
1a-1n	53.000 mΩ	63.831 mΩ
2a-2n	51.700 mΩ	62.265 mΩ
3a-3n	33.100 mΩ	39.884 mΩ
da-dn	143.900 mΩ	173.307 mΩ

Checked by: *[Signature]*

Przasnysz, 2015-10-20



Winding	Usn [kV]	Sn [VA]	Class	Sth [VA]
1a - 1n	0,115√3	25	0,1	1500
1a - 1n	0,115√3	25	1,0	1500
2a - 2n	0,115√3	25	0,1	1500
2a - 2n	0,115√3	25	1,0	1500
3a - 3n	0,115√3	25	0,1/3P	1500
3a - 3n	0,115√3	500	3,0/3P	1500
da - dn	0,115	100	1,0	450
da - dn	0,115	300	3P	450

- Oil dielectric parameters check before filling (oil after treatment):  
tg δ acc. IEC 60247, breakdown voltage acc. IEC 60156
- Verification of terminal markings
- Pressure and tightness test: oil overpressure: 0,8 bar / 24h - no traces of oil leakage
- Power-frequency withstand test on primary windings  
- A: Up = 220 kV / 60s, f = 120Hz; N: Up = 3kV / 60s, f = 50Hz  
- Up = 3 kV/60s
- Partial discharge measurement
- Power-frequency withstand test on secondary windings
- Determination of errors
- Measurement of capacitance and dielectric dissipation factor - tg δ
- Measurement of windings' resistance

Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil tg δ according to IEC 60247  
Tg δ = 0.0909 %; electrical stress = 1kV/mm, f = 50Hz, oil temp. = 90C ±1C.

- Measurement of breakdown voltage according to IEC 60156  
Mean breakdown voltage = 75.58 kV, Relative standard deviation = 4.66 %;  
f = 50Hz, oil temp. = 22.8 °C, measurement without the stirrer, type of electrodes used: partially

Sample	Breakdown voltage [kV]
1	76.6
2	73.5
3	75.3
4	77.2
5	69.8
6	70.1

*[Large handwritten signature]*

313





**HIGH VOLTAGE LABORATORY**  
**INSTYTUT ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
 tel. fax. (22) 8368048, e-mail: ewn@en.com.pl

EWN/134/E/15

Annex 3

**Measurement of capacitance and dielectric dissipation factor - tg δ**  
 Temperature: 23 °C, Frequency: 50 Hz

Primary voltage	Tg δ [%]	Capacity [pF]	Leak-current [mA]
10 KV	0.19	241	0.785
84 KV	0.19	241	6.362
84 KV	0.19	241	6.362


**Measurement of windings' resistance**

	R (23 °C)	Rct (75 °C)
A-N	18.20 kΩ	21.391 kΩ
1a-1n	52.800 mΩ	63.798 mΩ
2a-2n	51.200 mΩ	61.864 mΩ
3a-3n	32.970 mΩ	39.837 mΩ
da-dn	145.400 mΩ	175.685 mΩ

Checked by: *S. Jankowski*

OGA  
KJ-38

Przasnysz, 2015-11-10



INSTITUTE OF POWER ENGINEERING  
 Certification Department

Witnessed  Reviewed

Date / Sign. M. Sc. Eng. Jerzy Mielczyk

**ANNEX 3 for test report EWN/134/E/15**

(7 pages)

Lightning impulse test protocol:

□ ewn134e15



Próba udarem uciętym 1,2/50us

project: ewm134e15

test date 06-11-2015

page 1

**Test - object - data**

WNR EWN134E15 TR-No. 1HSE8851773 O.-No. 4500678253

test object EMF-E145 vector group  
output - kVA BIL 650  
voltage 145 KV frequency 50 Hz

customer ABB Sp. z o. o. ul. Zeganska 1, 04-713 Warszawa

LI lightning-impulse

no.	Up [kV]	T1[us]	T2[us]	Tc[us]	Ip [A]	remark
1	-326.4	1.21	45.3		-71.42	LI: A - RW(50.0%)
2	-648.4	1.22	45.6		-142.1	LI: A - FW(100.0%)
3	-374.3	1.22		3.42	-137.1	LI: A - CRW(57.5%)
4	-746.6	1.22		3.43	-285.1	LI: A - CFW(115.0%)
5	-746.9	1.23		3.41	-287.1	LI: A - CFW(115.0%)
6	-649.9	1.22	45.6		-141.9	LI: A - FW(100.0%)
7	-649.7	1.22	45.6		-142	LI: A - FW(100.0%)
8	-649.7	1.22	45.6		-141.9	LI: A - FW(100.0%)
9	-650.1	1.22	45.6		-141.9	LI: A - FW(100.0%)
10	-650.2	1.22	45.6		-142	LI: A - FW(100.0%)
11	-649.7	1.22	45.6		-141.9	LI: A - FW(100.0%)
12	-650	1.22	45.7		-142	LI: A - FW(100.0%)
13	-649.8	1.22	45.7		-142	LI: A - FW(100.0%)
14	-650.2	1.22	45.7		-142	LI: A - FW(100.0%)
15	-649.9	1.22	45.6		-142.1	LI: A - FW(100.0%)
16	-649.6	1.22	45.7		-142.2	LI: A - FW(100.0%)
17	-649.7	1.22	45.7		-142	LI: A - FW(100.0%)
18	-650	1.22	45.7		-142	LI: A - FW(100.0%)
19	-650.2	1.22	45.7		-142.1	LI: A - FW(100.0%)
20	327.1	1.22	45.5		71.62	LI: A - RW(50.0%)
21	649	1.22	46		142	LI: A - FW(100.0%)
22	649.5	1.22	45.9		142	LI: A - FW(100.0%)
23	649.3	1.23	45.9		142	LI: A - FW(100.0%)
24	649.3	1.23	45.9		142.1	LI: A - FW(100.0%)
25	649	1.22	45.9		142	LI: A - FW(100.0%)
26	648.6	1.23	46		141.9	LI: A - FW(100.0%)
27	648.6	1.22	45.9		142.1	LI: A - FW(100.0%)
28	648.4	1.22	46		142	LI: A - FW(100.0%)
29	647.9	1.22	46		142	LI: A - FW(100.0%)



Próba udarem uciętym 1,2/50us

project: ewm134e15





page 2

30	647.6	1.22	46		141.9	LI: A - FW(100.0%)
31	648.6	1.23	45.9		141.9	LI: A - FW(100.0%)
32	648.5	1.22	46		142.1	LI: A - FW(100.0%)
33	647	1.22	46.1		142.3	LI: A - FW(100.0%)
34	648.4	1.22	46		141.9	LI: A - FW(100.0%)
35	647.8	1.22	46		141.7	LI: A - FW(100.0%)









Próba udarem ucietym 1,2/50us  
project: own134e15



Próba udarem ucietym 1,2/50us  
project: own134e15



317

Handwritten signature or scribble.

Handwritten signature or scribble.

318




# HIGH VOLTAGE LABORATORY

POLAND 01-330 WARSZAWA, ul. Mory 8  
fax: (+4822) 636-80-48, mail: ewn@ion.com.pl

Próba udarem uciętym 1,2/50us

project: ewn134e15

page 5




# HIGH VOLTAGE LABORATORY

POLAND 01-330 WARSZAWA, ul. Mory 8  
fax: (+4822) 636-80-48, mail: ewn@ion.com.pl

Próba udarem uciętym 1,2/50us

project: ewn134e15

page 6








# HIGH VOLTAGE LABORATORY

POLAND 01-330 WARSZAWA, ul. Mory 8  
fax: (+4822) 836-90-48, mail: ewn@len.com.pl

Próba udarem uciętym 1,2/50us  
project : ewn134e15

page 7




319

(

(

# HIGH VOLTAGE LABORATORY



## INSTYTUT ENERGETYKI



LABORATORY ACCREDITED  
BY THE POLISH CENTRE FOR ACCREDITATION  
Accreditation Certificate of Testing Laboratory  
No AB 272

TEST REPORT  
No EWN/45/E/16

Impulse voltage withstand test on primary terminal,  
chopped impulse voltage withstand test on primary terminal,  
of voltage instrument transformer type PV145a

Warsaw, May 2016



**HIGH VOLTAGE LABORATORY**  
**INSTYTUT ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
tel. fax. (22) 8368048, e-mail: ewn@ien.com.pl

EWN/45/E/16

Page 2/8

### TEST REPORT EWN/45/E/16

**TEST OBJECT:** Voltage instrument transformer type PV145a

**TEST CUSTOMER:** ABB Sp. z o.o.  
04-713 Warszawa, ul. Żegalska 1

**MANUFACTURER:** ABB Sp. z o.o.  
04-713 Warszawa, ul. Żegalska 1

**ORDER NO:** 4500743552 (17.05.2016)

**TEST TYPE:** Impulse voltage withstand test on primary terminal,  
Chopped impulse voltage withstand test on primary terminal

**TEST PROCEDURE:** According to:  
PN-EN 61869-1:2009 (IEC 61869-1:2007)  
PN/EN 61869-3:2011 (IEC 61869-3:2011)

**TEST DATE:** 19.05.2016

**TEST RESULT:** Positive - details are presented in following parts of report

**TEST PERFORMERS:**

Michał Molas, M. Sc. EE

Adam Wielonek, Tech.

**AUTHORISATION:**

Jerzy Mikołajczyk, M. Sc. EE

**HEAD OF LABORATORY:**


J. L. Mikiński, Prof., Ph. D. EE

	Signature
	Signature
	Signature
	Signature

Warsaw, May 2016.

*Publication or reproduction of the Report in any other form than a complete copy thereof is forbidden without written consent of the Laboratory*


322



**HIGH VOLTAGE LABORATORY**  
**INSTYTUT ENERGETYKI**  
 01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
 tel. fax. (22) 8368048, e-mail: ewn@iem.com.pl

EWN/45/E/16

Page 3/8



**HIGH VOLTAGE LABORATORY**  
**INSTYTUT ENERGETYKI**  
 01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
 tel. fax. (22) 8368048, e-mail: ewn@iem.com.pl

EWN/45/E/16

Page 4/8

**1 COMPETENCE OF THE LABORATORY**

The High Voltage Laboratory is in possession of accreditation issued by the Polish Centre for Accreditation (Accreditation Certificate of Testing Laboratory No AB 272) concerning following tests:

- Insulators and insulator strings
  - lightning and switching impulse tests
  - power frequency voltage 50 Hz tests
  - radio interference measurements
- Distribution substations
  - lightning and switching impulse tests
  - power frequency voltage 50 Hz tests
  - radio interference measurements
- Circuit breakers, switches
  - lightning and switching impulse tests
  - power frequency voltage 50 Hz tests
  - radio interference measurements
- Disconnectors
  - lightning and switching impulse tests
  - power frequency voltage 50 Hz tests
  - radio interference measurements
- Current and voltage transformers
  - lightning and switching impulse tests
  - power frequency voltage 50 Hz tests
  - radio interference measurements
- Power transformers
  - lightning and switching impulse tests
  - power frequency voltage 50 Hz tests
- Lightning arresters and limiters
  - lightning and switching impulse tests
  - power frequency voltage 50 Hz tests
- Cables and cable fittings
  - lightning and switching impulse tests
  - power frequency voltage 50 Hz tests
- Line and station fittings
  - radio interference measurements
- Occupational safety equipment
  - power frequency voltage 50 Hz tests

Full scope of accreditation of High Voltage Laboratory available on [www.pca.gov.pl](http://www.pca.gov.pl)

**CONTENTS**

1	COMPETENCE OF THE LABORATORY	4
2	TEST OBJECT DESCRIPTION	5
3	SCOPE OF TESTS AGREED UPON	6
3.1	Impulse voltage withstand test on primary terminal	7
3.1.1	Method of testing and acceptance criteria	7
3.1.2	Test arrangement	7
3.1.3	Test conditions	7
3.1.4	Test results	8

Test report includes:

- 8 numbered pages;
  - 2 figures;
  - 1 photograph;
  - 3 tables.
- Attached to the test report:
- Annex 1: Dimensional drawing (1 page);
  - Annex 2: Reports of routine test and determination of errors (8 pages);
  - Annex 3: Lightning impulse test protocol (7 pages);




**2 TEST OBJECT DESCRIPTION**

The tested object was instrument voltage transformer PV145a manufactured by ABB sp. z o.o. 04-713 Warszawa, Żegalska 1 St. (Fabryka Aparatury Wysokich i Średnich Napięć, 06-300 Przasnysz, Leszno 59 St.), with the following parameters:

Type – PV145a

Serial number: 2GKP015V1188086

- Highest voltage for equipment 145 kV
- Rated primary voltage 145000 /  $\sqrt{3}$  V
- Rated secondary voltage 115/ $\sqrt{3}$  V (1a-1n, 2a-2n, 3a-3n) ; 115 V (da-dn)
- Insulation level 275 / 650 kV
- Frequency 50 Hz
- Temperature range -40 – +40 °C
- Total mass 265 kg



Phot. 1: Tested voltage transformer PV145a – general view

*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*



**ABB Voltage transformer**

Type: PV 145a S/N: 2000001188086

Insulation level: 145/275/650 kV Standard: IEC 61869-3

± 50% F: 3.3 MVA F<sub>1</sub>: 1.9 / 8kV

Transportation: Vertical/horizontal Temp. range: -40/+40°C

Insulation class: A Year: 2010

Total weight: 265 kg Oil type: Naphen type: 150-150P-20000P

Oil weight: 42 kg

Attention: Handle with care! Do not use! Observe the manufacturer's instructions.

Fig. 1: Tested voltage transformer PV145a – rating plate

**3 SCOPE OF TESTS AGREED UPON**

Test plan for voltage instrument transformer type PV145a was consulted with the Customer. Tab. 1 includes the list of performed tests and requirements, which tested objects should comply with.

Tab. 1: Scope of tests of voltage instrument transformer

Item	Performed tests	Requirement
1	Impulse voltage withstand test on primary terminal	PN-EN/IEC 61869-1, p.7.2.3
2	Chopped impulse voltage test on primary terminal	PN-EN/IEC 61869-1, p.7.4.1

Determination of errors of transformer, performed to prove the positive results of consecutive tests, was carried out on the premises of Factory Laboratory of ABB Sp. z o.o.. Detailed results are presented in Annex 2.

Tests were carried out according to:

- IEC 61869-1:2007 „Instrument transformers - Part 1: General requirements” (equiv. with: PN-EN 61869-1:2009 “Przekładniki – Część 1: Wymagania ogólne”)
- IEC 61869-3:2011 „Instrument transformers - Part 3: Additional requirements for inductive voltage transformers” (equiv. with: PN-EN 61869-3:2011 “Przekładniki – Część 3: Wymagania szczegółowe dotyczące przekładników napięciowych indukcyjnych”)



### 3.1 Impulse voltage withstand test on primary terminal

#### 3.1.1 Method of testing and acceptance criteria

According to IEC 61869-1 clause 7.4.1 lightning impulse test (for negative polarity) can be combined with chopped impulse voltage test. For positive polarity lightning impulse test was performed according to IEC 61869-1 clause 7.2.3 (15 impulse method).

It is considered that the instrument transformer passed the test with a positive result if analysis of the waveforms recorded during the test does not indicate failure of internal insulation of instrument transformer.

#### 3.1.2 Test arrangement

Arrangement for testing with full lightning impulse 1,2/50  $\mu$ s and chopped lightning impulse was based on Marx impulse generator made by HAEFELY. Voltage measurement was performed with impulse voltage measuring system Dr Strauss TR-AS 200-14, in connection with a capacitive voltage divider (impulse peak value measuring uncertainty doesn't exceed 2% of the measured value for the coverage probability 95% and coverage factor  $k=2$ ). Simplified diagram of the measurement system is shown in the Fig. 2.




Fig. 2: Simplified diagram of the lightning impulse measurement system (for one step of the generator):  
IG - impulse generator; VD - voltage divider; C<sub>v</sub>, R<sub>v</sub> - generator elements; CD - chopping device;  
IT - instrument transformer (general schematic representation); R<sub>d</sub> - detection resistance

#### 3.1.3 Test conditions

Test conditions for full lightning impulse 1,2/50  $\mu$ s test and chopped lightning impulse test (parameters of the measurement system, values of test voltages and sequence of impulses applications) are presented in Tab. 2 and Tab. 3. The influence of atmospheric condition on test voltage value was not taken into consideration.



Tab. 2: Parameters of the lightning impulse measurement system

IMPULSE GENERATOR	
Number of steps	n - 6
General capacitance	C <sub>g</sub> $\mu$ F 0,125
Discharge resistance	R <sub>d</sub> $\Omega$ 534
Damping resistance	R <sub>d</sub> $\Omega$ 157
VOLTAGE DIVIDER	
HV unit capacitance	C <sub>v</sub> ' pF -1200
LV unit capacitance	C <sub>v</sub> '' $\mu$ F 1,103
Scale factor	$\Phi_v$ - 927,0
DETECTION RESISTOR	
Detection resistance	R <sub>d</sub> $\Omega$ 0,707

Tab. 3: Values of test voltages and sequence of impulses applications

Full impulse test voltage	RW = 325 kV FW = 650 kV
Chopped impulse test voltage	CRW = 373,7 kV CFW = 747,5 kV
Sequence of impulses	Negative polarity Positive polarity 1 reduced full impulse (RW), 15 full impulses (FW), 1 reduced full impulse (RW), 1 full impulse (FW), 1 reduced chopped impulse (CRW), 2 chopped impulses (CFW), 14 full impulses (FW).
Registration	Transients of test voltage (channel 1) Current flowing through whole voltage transformer (channel 2)

#### 3.1.4 Test results

Oscillograms registered during the tests do not indicate any failures of the transformers' insulation (Annex 5). Comparison of the accuracy verification before and after the lightning impulse test of the transformers don't indicate significant changes of the transformers' metrological characteristics (Annex 2).

**TEST RESULT: POSITIVE**





**HIGH VOLTAGE LABORATORY**  
**INSTYTUT ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
 tel. fax. (22) 8368048, e-mail: ewn@iem.com.pl

EWN/45/E/16


Annex 1

**ANNEX 1 for test report EWN/45/E/16**

(1 page)

Dimensional drawing:

□ ID: 2GKV314360A0001





**HIGH VOLTAGE LABORATORY**  
**INSTYTUT ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
tel. fax. (22) 8368048, e-mail: ewz@len.com.pl

EWN/45/E/16

Annex 2

**ANNEX 2 for test report EWN/45/E/16**

(8 pages)

Reports of routine test and determination of errors:

- Routine test report of voltage instrument transformer – before lightning impulse test
- Routine test report of voltage instrument transformer – after lightning impulse test

ABB Sp. z o.o. 06-300 Przeczyszcz ul. Leszno 59		Routine test report of voltage instrument transformer-before lightning impulse test		TYPE: PV 145a Serial no: 2GKP015V1188086
A-N 145-√3 kV	Insulation level: 145/275/850 kV	Voltage factor: 1.9/8h		IEC 61869-3 50 Hz
Rating 1				
Winding		U <sub>sn</sub> [kV]	S <sub>n</sub> [VA]	Class
1a - 1n	0,115-√3	25	0,1	S <sub>th</sub> [VA] 1500
2a - 2n	0,115-√3	25	0,1	1500
3a - 3n	0,115-√3	25	0,1	1500
da - dn	0,115	100	1,0	1500
Rating 2				
Winding		U <sub>sn</sub> [kV]	S <sub>n</sub> [VA]	Class
1a - 1n	0,115-√3	25	1,0	S <sub>th</sub> [VA] 1500
2a - 2n	0,115-√3	25	1,0	1500
3a - 3n	0,115-√3	500	1,0	1500
da - dn	0,115	300	3P	1500

**List of performed tests**

1. Power-frequency withstand test on primary windings
  2. Partial discharge measurement
  3. Power-frequency withstand test on secondary windings
  4. Determination of errors
  5. Measurement of capacitance and dielectric dissipation factor - tg δ
  6. Measurement of windings' resistance
  7. Rating plate
- A: U<sub>p</sub> = 275kV / 60s, f = 120Hz; N: U<sub>p</sub> = 3kV / 60s, f = 50Hz  
- U<sub>p</sub> = 3 kV/60s

**Partial discharge measurement**

- Measurement according to procedure A (PD test voltages were reached while decreasing the voltage after the power-frequency withstand test on primary winding)
- Stress voltage: 275 kV / 60 s
- Frequency: 120 Hz

Test voltage	1,2 U <sub>m</sub> = 174 kV	1,2 U <sub>m</sub> / √3 = 100,5 kV
Level of partial discharge	0,6 pC	0,5 pC

- PD inception voltage: 230 kV
- PD extinction voltage: 225 kV

Remarks: background noise level: 0.5 (measured after voltage switch off), measuring circuit was calibrated with 5.1 pC (calibrating charge).

Verification of accuracy (ε U%), (Δφ U min) – rating 1

Date of measurement: 2016-05-17  
Ambient temperature: 31 +/- 2°C  
Relative air humidity: 40 +/- 10%

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.056	-0.054	-0.054		
$\Delta\phi$ U	0.7	0.7	0.7		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.020	-0.018	-0.018		
$\Delta\phi$ U	0.5	0.6	0.6		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.057	-0.056	-0.055		
$\Delta\phi$ U	0.5	0.5	0.5		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.023	-0.022	-0.021		
$\Delta\phi$ U	0.5	0.5	0.5		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.066	-0.059	-0.058		
$\Delta\phi$ U	0.4	0.4	0.4		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.032	-0.030	-0.030		
$\Delta\phi$ U	0.4	0.4	0.4		
1a-1n: 100 VA		1a-1n: 100 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.02 Un	0.05 Un	1.0 Un	1.9 Un		
$\epsilon$ U	-0.128	-0.064	0.010		
$\Delta\phi$ U	-1.1	-0.7	0.0		

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.015	-0.014	-0.013		
$\Delta\phi$ U	1.7	1.8	1.8		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	0.021	0.022	0.023		
$\Delta\phi$ U	1.6	1.7	1.7		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.016	-0.014	-0.014		
$\Delta\phi$ U	1.6	1.6	1.6		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	0.018	0.020	0.020		
$\Delta\phi$ U	1.6	1.6	1.6		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.019	-0.017	-0.017		
$\Delta\phi$ U	1.3	1.3	1.4		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	0.010	0.011	0.012		
$\Delta\phi$ U	1.5	1.5	1.5		
1a-1n: 100 VA		1a-1n: 100 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.02 Un	0.05 Un	1.0 Un	1.9 Un		
$\epsilon$ U	0.092	0.159	0.233		
$\Delta\phi$ U	0.7	1.0	1.6		

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.056	-0.054	-0.054		
$\Delta\phi$ U	0.7	0.7	0.7		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	0.021	0.022	0.023		
$\Delta\phi$ U	1.6	1.7	1.7		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.016	-0.014	-0.014		
$\Delta\phi$ U	1.6	1.6	1.6		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	0.018	0.020	0.020		
$\Delta\phi$ U	1.6	1.6	1.6		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.019	-0.017	-0.017		
$\Delta\phi$ U	1.3	1.3	1.4		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	0.010	0.011	0.012		
$\Delta\phi$ U	1.5	1.5	1.5		
1a-1n: 100 VA		1a-1n: 100 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.02 Un	0.05 Un	1.0 Un	1.9 Un		
$\epsilon$ U	0.092	0.159	0.233		
$\Delta\phi$ U	0.7	1.0	1.6		

Measurements uncertainty:  $U_{res} = \pm 0.015\%$ ,  $U_{app} = \pm 1.5$  min

Verification of accuracy ( $\epsilon$  U%), ( $\Delta\phi$  U min) – rating 2  
 Date of measurement: 2016-05-17  
 Ambient temperature: 31 +/- 2°C  
 Relative air humidity: 40 +/- 10%

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.434	-0.432	-0.432		
$\Delta\phi$ U	-9.7	-8.7	-9.6		

1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.398	-0.398	-0.396		
$\Delta\phi$ U	-9.8	-9.8	-9.8		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.450	-0.450	-0.448		
$\Delta\phi$ U	-10.6	-10.6	-10.5		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.417	-0.415	-0.414		
$\Delta\phi$ U	-10.6	-10.6	-10.6		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.932	-0.930	-0.931		
$\Delta\phi$ U	0.5	0.6	0.6		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.893	-0.892	-0.890		
$\Delta\phi$ U	1.6	1.7	1.8		
1a-1n: 125 VA		1a-1n: 125 VA		cos $\phi$ = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 0 VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.171	-0.170	-0.169		
$\Delta\phi$ U	0.4	0.5	0.5		
1a-1n: 75 VA		1a-1n: 75 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 0 VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.02 Un	0.05 Un	1.0 Un	1.9 Un		
$\epsilon$ U	0.006	0.068	0.141		
$\Delta\phi$ U	0.5	0.8	1.3		

1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.398	-0.398	-0.396		
$\Delta\phi$ U	-9.8	-9.8	-9.8		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.450	-0.450	-0.448		
$\Delta\phi$ U	-10.6	-10.6	-10.5		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.417	-0.415	-0.414		
$\Delta\phi$ U	-10.6	-10.6	-10.6		
1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.932	-0.930	-0.931		
$\Delta\phi$ U	0.5	0.6	0.6		
1a-1n: 6.25 VA		1a-1n: 6.25 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.893	-0.892	-0.890		
$\Delta\phi$ U	1.6	1.7	1.8		
1a-1n: 125 VA		1a-1n: 125 VA		cos $\phi$ = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 0 VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.8 Un	1.0 Un	1.2 Un	1.2 Un		
$\epsilon$ U	-0.171	-0.170	-0.169		
$\Delta\phi$ U	0.4	0.5	0.5		
1a-1n: 75 VA		1a-1n: 75 VA		p.f. = 0.8 lag.	
2a-2n: 25VA; 3a-3n: 0 VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0.8 lag.	
0.02 Un	0.05 Un	1.0 Un	1.9 Un		
$\epsilon$ U	0.006	0.068	0.141		
$\Delta\phi$ U	0.5	0.8	1.3		

Measurements uncertainty:  $U_{res} = \pm 0.015\%$ ,  $U_{app} = \pm 1.5$  min

Measurement of capacitance and dielectric dissipation factor – tg  $\delta$   
 Temperature: 26 °C, Frequency: 50 Hz

||
||
||

Rating plate

**ABB Voltage transformer**

Type: PV 145g S/N: 2GKP015V1188086

Insulation level: 145/275/650 kV Standard: IEC 61869-3

Transportation: Vertical/horizontal F<sub>v</sub>: 1.9 / 8h

Insulation class: A Temp. range: -40/+45°C

Year: 2016

Attention: Hermetic device, do not vent. Oil sampling according to the manufacturer's instruction.

Checked by: *[Signature]*

Przasnysz, 2016-05-17

ABB Sp. z o.o. 06-300 Przasnysz ul. Leszno 59		Routine test report of voltage instrument transformer-after lightning impulse test		TYPE: PV 145a	Serial no: 2GKP015V1188086
A-N 145-13 kV	Insulation level: 145/275/650 kV	Voltage factor: 1.9/8h		IEC 61869-3	
		Rating 1			
Winding	Usn [kV]	Sn [VA]	Class	Sth [VA]	
1a - 1n	0.115-13	25	0.1	1500	
2a - 2n	0.115-13	25	0.1	1500	
3a - 3n	0.115-13	25	0.1	1500	
da - dn	0.115	100	1.0	450	
		Rating 2			
Winding	Usn [kV]	Sn [VA]	Class	Sth [VA]	
1a - 1n	0.115-13	25	1.0	1500	
2a - 2n	0.115-13	25	1.0	1500	
3a - 3n	0.115-13	500	1.0	1500	
da - dn	0.115	300	3P	450	

List of performed tests

1. Power-frequency withstand test on primary windings
  2. Partial discharge measurement
  3. Power-frequency withstand test on secondary windings
  4. Determination of errors
  5. Measurement of capacitance and dielectric dissipation factor - tg δ
  6. Measurement of windings' resistance
  7. Rating plate
- A: Up = 220kV / 60s, f = 120Hz; N: Up = 3kV / 60s, f = 50Hz
- Up = 3 kV/80s

Partial discharge measurement

- Measurement according to procedure A (PD test voltages were reached while decreasing the voltage after the power-frequency withstand test on primary winding)

Stress voltage: 220 kV / 60 s

Frequency: 120 Hz

Test voltage	1,2 Um = 174 kV	1,2 Um /√3 = 100.5 kV
Level of partial discharge	1 pC	0.6 pC

- PD inception voltage: >220 kV
- PD extinction voltage: >220 kV

Remarks: background noise level: 0.6 (measured after voltage switch off), measuring circuit was calibrated with 5.1 pC (calibrating charge).

Verification of accuracy (± U%), (Δp U min) - rating 1

Date of measurement: 2016-05-30  
 Ambient temperature: 31 +/- 2°C  
 Relative air humidity: 40 +/- 10%

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,058	-0,056	-0,015	1,8	
ε U	0,7	0,7	1,8	1,8	
Δφ U	0,7	0,7	1,8	1,8	

1a-1n: 6,25 VA		1a-1n: 6,25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,022	-0,020	-0,019	0,6	
ε U	0,6	0,6	1,7	1,7	
Δφ U	0,6	0,6	1,7	1,7	

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,064	-0,062	-0,062	0,6	
ε U	0,5	0,5	1,7	1,7	
Δφ U	0,5	0,5	1,7	1,7	

1a-1n: 6,25 VA		1a-1n: 6,25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,030	-0,028	-0,027	0,5	
ε U	0,2	0,3	0,3	0,3	
Δφ U	0,2	0,3	0,3	0,3	

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,063	-0,061	-0,061	0,5	
ε U	0,2	0,3	0,3	0,3	
Δφ U	0,2	0,3	0,3	0,3	

1a-1n: 6,25 VA		1a-1n: 6,25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,033	-0,032	-0,031	0,4	
ε U	0,4	0,4	0,4	0,4	
Δφ U	0,4	0,4	0,4	0,4	

1a-1n: 100 VA		1a-1n: 25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,02 Un	0,05 Un	1,0 Un	1,9 Un	
Δφ U	-0,116	-0,053	0,023	0,020	
ε U	-1,4	-1,0	-0,4	-0,2	
Δφ U	-1,4	-1,0	-0,4	-0,2	

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,433	-0,431	-0,431	-0,5	
ε U	-0,6	-0,6	-0,6	-0,5	
Δφ U	-0,6	-0,6	-0,6	-0,5	

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,017	-0,015	-0,014	1,8	
ε U	1,8	1,8	1,8	1,8	
Δφ U	1,8	1,8	1,8	1,8	

1a-1n: 6,25 VA		1a-1n: 6,25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,399	-0,398	-0,396	0,021	
ε U	-9,7	-9,6	-9,6	1,7	
Δφ U	-9,7	-9,6	-9,6	1,7	

1a-1n: 25 VA		1a-1n: 25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,452	-0,451	-0,449	-0,021	
ε U	-10,4	-10,4	-10,4	1,7	
Δφ U	-10,4	-10,4	-10,4	1,7	

1a-1n: 6,25 VA		1a-1n: 6,25 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 500VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,418	-0,415	-0,415	0,013	
ε U	-10,5	-10,4	-10,4	1,6	
Δφ U	-10,5	-10,4	-10,4	1,6	

1a-1n: 500 VA		1a-1n: 500 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,944	-0,943	-0,945	0,8	
ε U	0,7	0,7	0,8	0,8	
Δφ U	0,7	0,7	0,8	0,8	

1a-1n: 125 VA		1a-1n: 125 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,8 Un	1,0 Un	1,2 Un	1,2 Un	
Δφ U	-0,256	-0,254	-0,253	0,6	
ε U	0,6	0,6	0,6	0,6	
Δφ U	0,6	0,6	0,6	0,6	

1a-1n: 300 VA		1a-1n: 300 VA		p.f. = 0,8 lag.	
2a-2n: 25VA; 3a-3n: 25VA		2a-2n: 0 VA; 3a-3n: 0 VA		p.f. = 0,8 lag.	
ε U	0,02 Un	0,05 Un	1,0 Un	1,9 Un	
Δφ U	-0,943	-0,877	-0,807	-0,809	
ε U	-13,6	-13,2	-12,1	-12,2	
Δφ U	-13,6	-13,2	-12,1	-12,2	

Measurements uncertainty:  $U_{k,as} = \pm 0,015\%$ ,  $U_{A,as} = \pm 1,5$  min

Measurement of capacitance and dielectric dissipation factor - tg δ

Primary voltage	Tg δ	Capacity [pF]	Leak current [mA]
10 kV	0,2	239	0,835
63 kV	0,2	239	6,316
71 kV	0,2	239	6,868

Measurement of windings' resistance

	R (25 °C)	Ret (20 °C)	Ret (75 °C)
A-N	18,50 kΩ	17,918 kΩ	21,917 kΩ
1a-1n	53,7 mΩ	52,012 mΩ	63,619 mΩ
2a-2n	50,365 mΩ	50,365 mΩ	61,605 mΩ
3a-3n	33,8 mΩ	32,737 mΩ	40,043 mΩ
ds-dn	147,9 mΩ	142,959 mΩ	174,863 mΩ

Reading plate

# ABB Voltage transformer

Type PV 145q S/N 26K015V1180086

Insulation level 145/275/650 kV Standard EC 21869-3

1k 50Hz F 3.5 MN Fv 1.9 / 8h

Transportation Vertical/Horizontal

Insulation class A Year 2016

Temp. Range -40/+40°C


Year 2016

Attention: Hermetic devices not allowed, oil sampling according to the manufacturer's instruction.

1k-1p	115/230/500VA	U <sub>10</sub> 0.1	1500VAh
2k-2h	115/230/500VA	U <sub>10</sub> 0.1	1500VAh
3k-3h	115/230/500VA	U <sub>10</sub> 0.1	1500VAh
4k-4h	115/230/500VA	U <sub>10</sub> 0.1	1500VAh
5k-5h	115/230/500VA	U <sub>10</sub> 0.1	1500VAh

Total weight 263 kg Oil weight 62 kg

Oil type None Myro Libra ISO-L-RTMO-260150

Checked by:  Przasnysz, 2016-05-30



**HIGH VOLTAGE LABORATORY**  
**INSTYTUT ENERGETYKI**  
 01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
 tel. fax. (22) 8368048, e-mail: ewn@ien.com.pl

EWN/45/E/16  
 Annex 3

## ANNEX 3 for test report EWN/45/E/16

(8 pages)

Lightning impulse test protocol:

□ ewn45e16



project: ewm45e16

test date 19-05-2016

page 1

**Test - object - data**

WNR ewm45e16 TR-No. 2GKP0115Y1188080-No. 4500743552

test object PV145a vector group -  
output - kVA BIL  
voltage 145 kV frequency 50 Hz

customer ABB Sp. z o.o. ul. Zeganska 1, 04-713 Warszawa.

LI lightning-impulse						
no.	Up [kV]	T1[us]	T2[us]	Tc[us]	Ip [A]	remark
1	-325.3	1.22	45.4		-363.6	LI: A - FW(50.0%)
2	-648.1	1.23	45.8		-453	LI: A - FW(100.0%)
3	-375	1.22		3.48	-625.2	LI: A - CRW(57.5%)
4	-744.8	1.24		3.44	-1122	LI: A - CFW(115.0%)
5	-745.3	1.24		3.4	-1123	LI: A - CFW(115.0%)
6	-647.7	1.23	45.7		-537.8	LI: A - FW(100.0%)
7	-648	1.23	45.8		-361.4	LI: A - FW(100.0%)
8	-648.2	1.23	45.8		-393.7	LI: A - FW(100.0%)
9	-648.3	1.23	45.8		-412.2	LI: A - FW(100.0%)
10	-648	1.23	45.8		-493.4	LI: A - FW(100.0%)
11	-646.9	1.24	45.9		-485.1	LI: A - FW(100.0%)
12	-648	1.23	45.9		-531.1	LI: A - FW(100.0%)
13	-648.3	1.23	45.8		-496.6	LI: A - FW(100.0%)
14	-648.2	1.23	45.9		-305.8	LI: A - FW(100.0%)
15	-648.2	1.23	45.9		-346.5	LI: A - FW(100.0%)
16	-648.7	1.23	45.8		-394.9	LI: A - FW(100.0%)
17	-648.9	1.23	45.8		-353	LI: A - FW(100.0%)
18	-648.1	1.23	45.9		-481.3	LI: A - FW(100.0%)
19	-648	1.23	45.8		-460	LI: A - FW(100.0%)
20	323.8	1.23	45.5		326.4	LI: A - RW(50.0%)
21	649.9	1.23	45.9		425.5	LI: A - FW(100.0%)
22	650.2	1.23	45.8		364.9	LI: A - FW(100.0%)
23	650.2	1.23	45.6		424.7	LI: A - FW(100.0%)
24	649.5	1.23	45.9		476.2	LI: A - FW(100.0%)
25	649.9	1.23	45.9		323.1	LI: A - FW(100.0%)
26	649.9	1.22	45.8		433.1	LI: A - FW(100.0%)
27	649.6	1.23	45.9		538.4	LI: A - FW(100.0%)
28	649.4	1.23	45.9		349.9	LI: A - FW(100.0%)
29	649.3	1.23	45.7		396.1	LI: A - FW(100.0%)



project: ewm45e16


page 2

30	649.2	1.23	45.9	367.3	LI: A - FW(100.0%)
31	649.1	1.22	45.9	459.3	LI: A - FW(100.0%)
32	649.6	1.22	45.9	376.5	LI: A - FW(100.0%)
33	648.6	1.22	45.9	343.2	LI: A - FW(100.0%)
34	649.1	1.23	45.9	540.2	LI: A - FW(100.0%)
35	648.8	1.23	45.8	336.1	LI: A - FW(100.0%)




project: ewm45e16

page 3



project: ewm45e16

page 4








# HIGH VOLTAGE LABORATORY

POLAND, 01-330 WARSZAWA, ul. Mary 8  
fax: (+4822) 836-80-48, mail: ewn@ien.com.pl

project: ewn45e16

page 5



*Handwritten signature*

333




# HIGH VOLTAGE LABORATORY

POLAND, 01-330 WARSZAWA, ul. Mary 8  
fax: (+4822) 836-80-48, mail: ewn@ien.com.pl

project: ewn45e16

page 6



*Handwritten signature*

*Handwritten signature*






# HIGH VOLTAGE LABORATORY

POLAND 01-330 WARSZAWA, ul. Mary 8  
fax: (+4822) 836-80-48, mail: ewn@iem.com.pl

project: ewn45e16

page 7



# LABORATORIUM WYSOKICH NAPIĘĆ



## INSTYTUT ENERGETYKI



LABORATORIUM AKREDYTOWANE  
PRZY POLSKIM CENTRUM AKREDYTACJI  
Certyfikat Akredytacji Laboratorium Badawczego  
Nr. AB 272

SPRAWOZDANIE Z BADAŃ

Nr. EWN/45/E/16

Próba napięciem udarowym piorunowym pełnym,  
próba napięciem udarowym piorunowym uciętym  
przekładnika napięciowego typu PY145a

Warszawa, maj 2016 r.



## LABORATORIUM WYSOKICH NAPIĘĆ INSTYTUTU ENERGETYKI

01-330 WARSZAWA, ul. Mocy 8, tel. (+48 22) 3451242  
tel. fax. (+48 22) 836-80-48, e-mail: ewn@ien.com.pl

EWN/45/E/16

Str. 2/8

### SPRAWOZDANIE Z BADAŃ EWN/45/E/16

**OBIEKT BADAŃ:** Przekładnik napięciowy typu PY145a  
**ZLECENIODAWCA:** ABB Sp. z o.o.  
04-713 Warszawa, ul. Żegańska 1  
**PRODUCENT:** ABB Sp. z o.o.  
04-713 Warszawa, ul. Żegańska 1  
**NR. ZAMÓWIENIA:** 4500743552 (17.05.2016)  
**RODZAJ BADAŃ:** – Próba napięciem udarowym piorunowym pełnym  
– Próba napięciem udarowym piorunowym uciętym

**Zgodna z:** PN-EN 61869-1:2009 (IEC 61869-1:2007)  
PN/EN 61869-3:2011 (IEC 61869-3:2011)

**DATA WYKONANIA BADAŃ:** 19.05.2016

**WYNIK BADAŃ:** pozytywny – szczegóły w dalszej części raportu

**PROWADZĄCY BADAŃIA:**

mgr inż. Michał Molas

tech. Adam Wielonek

**AUTORYZUJĄCY BADAŃIA:**

mgr inż. Jerzy Mikobajczyk

**KIEROWNIK LABORATORIUM:**


prof. nadzw. dr hab. inż.  
J. L. Mikulski

	Podpis
	Podpis
	Podpis
	Podpis

Warszawa, maj 2016 r.


*Bez pisemnej zgody laboratorium nie zważa się na publikowanie lub reprodukcję sprawozdania w innej postaci niż jego kompletna kopia*

335



**LABORATORIUM WYSOKICH NAPIĘĆ  
INSTYTUTU ENERGETYKI**  
01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 3451242  
tel. fax. (+48 22) 836-80-48, e-mail: ewn@ten.com.pl

EWN/45/E/16  
Str. 3/8



**LABORATORIUM WYSOKICH NAPIĘĆ  
INSTYTUTU ENERGETYKI**  
01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 3451242  
tel. fax. (+48 22) 836-80-48, e-mail: ewn@ten.com.pl

EWN/45/E/16  
Str. 4/8

**1 KOMPETENCJE LABORATORIUM**  
Laboratorium Wysokich Napięć posiada akredytację Polskiego Centrum Badań i Akredytacji (Certyfikat Akredytacji Laboratorium Badawczego Nr AB 272) w zakresie badań:

Izolatorów i łączonych izolatorów

- próby napięciem udarowym: piorunowym i łączeniowym
- próby napięciem przeniennym 50 Hz

Stacje rozdzielcze

- pomiary zakłóceń radioelektrycznych
- próby napięciem udarowym: piorunowym i łączeniowym
- próby napięciem przeniennym 50 Hz

Wyłączniki, rozłączniki

- pomiary zakłóceń radioelektrycznych
- próby napięciem udarowym: piorunowym i łączeniowym
- próby napięciem przeniennym 50 Hz

Odłączniki

- pomiary zakłóceń radioelektrycznych
- próby napięciem udarowym: piorunowym i łączeniowym
- próby napięciem przeniennym 50 Hz

Przekładniki prądowe i napięciowe

- próby napięciem udarowym: piorunowym i łączeniowym
- próby napięciem przeniennym 50 Hz

Transformatory

- pomiary zakłóceń radioelektrycznych
- próby napięciem udarowym: piorunowym i łączeniowym

Odgromniki i ograniczniki przepięć

- próby napięciem przeniennym 50 Hz
- próby napięciem udarowym: piorunowym i łączeniowym

Kable i osprzęt kablowy

- próby napięciem przeniennym 50 Hz
- próby napięciem udarowym: piorunowym i łączeniowym

Osprzęt linii napowietrznych i stacji

- próby napięciem przeniennym 50 Hz
- pomiary zakłóceń radioelektrycznych

Sprzęt BHP

- próby napięciem przeniennym 50 Hz

Pełny zakres akredytacji Laboratorium Wysokich Napięć dostępny na [www.pca.gov.pl](http://www.pca.gov.pl)

## SPIS TREŚCI

1	KOMPETENCJE LABORATORIUM	4
2	OPIS OBIEKTÓW BADAŃ	5
3	UZGODNIONY ZAKRES BADAŃ	6
3.1	Próba napięciem udarowym piorunowym pełnym i uciętym	7
3.1.1	Metoda badania i kryteria oceny wyników	7
3.1.2	Układ probierzo-pomiarowy	7
3.1.3	Warunki próby	7
3.1.4	Wynik badań	8

Sprawozdanie zawiera:

- 8 stron kolejno numerowanych;
- 2 rysunki;
- 1 fotografię;
- 3 numerowane tablice.

Do sprawozdania załączone:

- Załącznik 1: Rysunek wymiarowy (1 strona)
- Załącznik 2: Protokoły z prób wyrobu i pomiaru uchybów (8 stron)
- Załącznik 3: Protokół z próby napięciem udarowym (7 stron)

EWN/45/E/16

Str. 5/8

**LABORATORIUM WYSOKICH NAPIĘĆ  
INSTYTUTU ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 3451242  
tel. fax. (+48 22) 836-80-48, e-mail: ewn@ten.com.pl

EWN/45/E/16

Str. 6/8

**LABORATORIUM WYSOKICH NAPIĘĆ  
INSTYTUTU ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 3451242  
tel. fax. (+48 22) 836-80-48, e-mail: ewn@ten.com.pl

**2 OPIS OBIEKTÓW BADAŃ**

Obiektem badań był przekładnik napięciowy PV145a wyprodukowany przez ABB sp. z o.o. 04-713 Warszawa, Żegotańska. (Fabryka Aparatury Wysokich i Średnich Napięć, 06-300 Przasnysz, Leszno 59), o następujących parametrach technicznych:

Typ – PV145a

Numer seryjny: 2GKCP015V1188086

- Najwyższe napięcie pracy urządzenia 145 kV
- Znamionowe napięcie pierwotne 145000 / √3 V
- Znamionowe napięcie wtórne 115/√3 V (1a-1a, 2a-2a, 3a-3a) ; 115 V (da-dn)
- Znamionowe napięcie wtórne 275 / 650 kV
- Poziom izolacji 50 Hz
- Częstotliwość -40 – +40 °C
- Zakres temperatury 265 kg
- Masa całkowita

**ABB** Przekładnik napięciowy

Typ PV 145a Nr seryjny 2GKCP015V1188086

Podział izolacji 145/275/650 kV Normel sc 61869-3

U 50Hz F 3,5 MW F<sub>v</sub> 1,8 / 6h

Transport Płonie/wskazy Temp. -40/+40°C

Klasa izolacji A

Risk produkcji 2018

Uwaga! Urządzenie homologowane, dla rozpraszania, poddawane próbie, według normy IEC 61869-3.

Masa całkowita 265 kg

Typ oleju Masa oleju litra 82 kg

Typ oleju 100L-3000-2000S

A-N 145 / √3 kV

1a-1a 115 / √3 kV

2a-2a 115 / √3 kV

3a-3a 115 / √3 kV

100L-3000-2000S

Rys. 1: Badany przekładnik napięciowy PV145a – tabliczka znamionowa

**3 UZGODNIONY ZAKRES BADAŃ**

Zakres badań dla przekładnika napięciowego PV145a został określony przez Zleceniodawcę, Tab. 1. Zawiera listę przeprowadzonych badań oraz wymagania, jakie badany przekładnik powinien spełniać.


Tab. 1: Plan badań dla przekładnika napięciowego

Punkt	Przeprowadzone badania	Wymagania
1	Próba napięciem udarowym piorunowym pełnym	PN-EN/IEC 61869-1, p. 7.2.3
2	Próba napięciem udarowym piorunowym uciętym	PN-EN/IEC 61869-1, p. 7.4.1

Pomiar uchybów przekładnika wykonywany w celu potwierdzenia wyników kolejnych prób został przeprowadzony na terenie Laboratorium Fabrycznego ABB SP. z o.o.. Szczegółowe wyniki są przedstawione w Załączniku 2.

Badania zostały przeprowadzone zgodnie z:

- IEC 61869-1:2007 „Instrument transformers - Part 1: General requirements” (tożsame z PN-EN 61869-1:2009 „Przekładniki – Część 1: Wymagania ogólne”)
- IEC 61869-3:2011 „Instrument transformers - Part 3: Additional requirements for inductive voltage transformers” (tożsame z PN-EN 61869-3:2011 „Przekładniki – Część 3: Wymagania szczegółowe dotyczące przekładników napięciowych indukcyjnych”)



Fot. 1: Badany przekładnik napięciowy PV145a – widok ogólny

*[Handwritten signature]*

### 3.1 Próba napięciem udarowym piorunowym pełnym i uciętym


#### 3.1.1 Metoda badania i kryteria oceny wyników

Zgodnie z IEC 61869-1 pkt. 7.4.1 próba napięciem udarowym piorunowym pełnym (dla biegunowości ujemnej) może być połączona z próbą napięciem udarowym uciętym. Dla biegunowości dodatniej próba udarowa została przeprowadzona zgodnie z IEC 61869-1 pkt. 7.2.3 (metoda 15 udarów).

Uznaje się, że wynik badań przekładnika napięciowego jest pozytywny, jeżeli analiza przebiegów zarejestrowanych w trakcie próby nie wskazuje na uszkodzenie izolacji wewnętrznej przekładnika.

#### 3.1.2 Układ probierczo-pomiarowy

Układ probierczo-pomiarowy do prób napięciem udarowym piorunowym pełnym i uciętym składa się z generatora napięć udarowych pracującego w układzie Marx'a, produkcji HAERFELY. Pomiar napięcia został przeprowadzony przy wykorzystaniu cyfrowego rejestratora napięć udarowych Dr. Strauss TR-AS 200-14, współpracującego z pojemnościowym dzielnikiem napięć (niepewność pomiaru wartości szczytowej napięcia nie przekraczała 2% od wartości mierzonej, przy prawdopodobieństwie rozszerzenia 95% i współczynnika rozszerzenia  $k=2$ ). Uproszczony schemat układu przedstawiony jest y na Rys. 2..



Rys. 2: Uproszczony schemat układu probierczo-pomiarowego (dla jednego stopnia generatora):  
IG – generator udarowy; VD – dzielnik napięcia;  $C_1, R_1, R_2, R_3$  – elementy generatora; CD – ucinacz napięcia;  
IT – przekładnik napięciowy (uproszczony schemat);  $R_4$  – boczny pomiarowy

#### 3.1.3 Warunki próby

Warunki próby dla prób napięciem udarowym piorunowym pełnym i uciętym (parametry układu probierczo-pomiarowego, wartości napięć probierczych oraz sposób podawania napięcia) są przedstawione w Tab. 2 i Tab. 3. Wpływ warunków atmosferycznych na wartość napięcia probierczego nie był brany pod uwagę.

Tab. 2: Parametry układu probierczo-pomiarowego

GENERATOR NAPIĘCIA	
Ilość stopni	6
Pojemność główna	0,125 $\mu\text{F}$
Rezystancja rozładowcza	534 $\Omega$
Rezystancja tłumiąca	157 $\Omega$
DZIELNIK NAPIĘCIA	
Pojemność WN	$C_1'$ pF -1200
Pojemność nn	$C_2''$ $\mu\text{F}$ 1,109
Przekładania	$\phi_v$ - 927,0
BOCZNIK POMIAROWY	
Bocznik pomiarowy	$R_4$ $\Omega$ 0,707

Tab. 3: Wartości napięć probierczych oraz sposób podawania napięcia

Próba napięciem udarowym pełnym	RW = 325 kV
	FW = 650 kV
Próba napięciem udarowym uciętym	CRW = 373,7 kV
	CFW = 747,5 kV
Sposób podawania napięcia	Biegunowość dodatnia: Biegunowość ujemna:
	1 udar pełny obniżony (RW), 1 udar pełny obniżony (RW),
	15 udarów pełnych probierczych (FW), 1 udar pełny probierczy (FW),
	1 udar ucięty obniżony (CRW), 2 udary ucięte probiercze (CFW),
Rejestracja	14 udarów pełnych probierczych (FW).
	Przebieg napięcia probierczego (kanal 1) Przebieg prądu płynącego przez przekładnik (kanal 2)

#### 3.1.4 Wynik badań

Oscylogramy zarejestrowane w trakcie badań nie wskazują na wystąpienie uszkodzeń izolacji wewnętrznej przekładnika (Załącznik 3). Porównanie raportów z pomiarów uchybów wykonanych przed i po próbach udarowych nie wykazało żadnych znaczących zmian we własnościach metrologicznych przekładnika (Załącznik 2).

WYNIK BADAŃ: POZYTYWNY





**HIGH VOLTAGE LABORATORY  
INSTYTUT ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (22) 3451242  
tel. fax. (22) 8368048, e-mail: ewn@ien.com.pl

EWN/45/E/16

Załącznik 2

**Załącznik 2 do raportu EWN/45/E/16**

(8 stron)

Protokoły z prób wyrobu i pomiaru uchybów:

- Protokół sprawdzenia Przekładnika Napięciowego – przed badaniem udarem piorunowym
- Protokół sprawdzenia Przekładnika Napięciowego – po badaniu udarem piorunowym

ABB Sp. z o.o. 06-300 Przasnysz ul. Leszno 59		Protokół sprawdzania Przekładnika Napięciowego-przed badaniem udarem piorunowym		TYP: PV 145a Nr fabr.: 2GKP015V1188086
A-N 145kV/3	Poziom izolacji: 145/275/650 kV	Wsp.napięciowy: 1,9/8h		IEC 61869-3 50 Hz
<b>Parametry 1</b>				
<b>Uzwojenie</b>	<b>U<sub>sn</sub> [kV]</b>	<b>S<sub>n</sub> [VA]</b>	<b>Klasa</b>	<b>S<sub>th</sub> [VA]</b>
1a - 1n	0,115√3	25	0,1	1500
2a - 2n	0,115√3	25	0,1	1500
3a - 3n	0,115√3	25	0,1	1500
da - dn	0,115	100	1,0	1500
<b>Parametry 2</b>				
<b>Uzwojenie</b>	<b>U<sub>sn</sub> [kV]</b>	<b>S<sub>n</sub> [VA]</b>	<b>Klasa</b>	<b>S<sub>th</sub> [VA]</b>
1a - 1n	0,115√3	25	1,0	1500
2a - 2n	0,115√3	25	1,0	1500
3a - 3n	0,115√3	500	1,0	1500
da - dn	0,115	300	3P	1500

**Lista przeprowadzonych badań**

1. Sprawdzenie oznaczeń wywodzeń
  2. Próba izolacji uzwojeń pierwotnych napięciem o częstotliwości sieciowej
  3. Pomiar wyładowań niezupełnych
  4. Próba izolacji uzwojeń wtórnych napięciem o częstotliwości sieciowej
  5. Sprawdzenie dokładności
  6. Pomiar pojemności i współczynnika strat dielektrycznych (tg δ) przekładnika
  7. Pomiar rezystancji uzwojeń
  8. Tabliczka znamionowa
- A: Up = 275kV / 60s, I = 120Hz; N: Up = 3kV / 60s, f = 50Hz  
- Up = 3 kV/60s

**Pomiar wyładowań niezupełnych**

- Pomiar wykonano wg procedury A (napięcia probiercze osiągnięto podczas obniżania napięcia po próbie izolacji uzwojenia pierwotnego)
- Napięcie stresu: 275 kV / 60 s
- Częstotliwość: 120 Hz

Napięcie probiercze	1,2 Um = 174 kV	1,2 Um /√3 = 100,5 kV
Poziom wyładowań niezupełnych	0,6 pC	0,6 pC

- Napięcie zapiłonu WNZ: 230 kV
- Napięcie wygaszenia WNZ: 225 kV

Uwagi: Poziom zakłócał: 0,5 pC (odczyt po wyłączeniu napięcia), Ładunek kalibrujący: 5.1 pC

Sprawdzenie dokładności (ε U%), (Δφ U min) – parametry 1

Data pomiaru: 2016-05-17  
Temperatura otoczenia: 31 +/- 2°C  
Wilgotność względna powietrza: 40 +/- 10%





**ABB** Przekładnik napięciowy

Typ: PV 145a Nr serijny: ZKPK015V1188086

Poziom Izolacja: 145/275/650 kV Norma: IEC 61869-3

Transport: F 3,0 kV F<sub>v</sub> 1,5 / 5h

Klasa izolacji: A Temp: -40/+40°C

Rok produkcji: 2016

Uzasadnienie techniczne:  
 Pobieranie prądu: według instrukcji producenta.

Masa całkowita: 285 kg Masa oleju: 82 kg

Typ oleju: Nynas Nynco Libra 150-L-RT10-2000130

1a-1n 115/√3 275 0,115 √3 1500VAh  
 2a-2n 115/√3 275 0,115 √3 1500VAh  
 3a-3n 115/√3 275 0,115 √3 1500VAh  
 da-dn 115/√3 275 0,115 √3 2500VAh

Przasnysz, dn. 2016-05-17



Sprawdził: .....

ABB Sp. z o.o. 06-300 Przasnysz ul. Leszno 59		Protokół sprawdzania Przekładnika Napięciowego-po badaniu udarem piorunowym		TYP: PV 145a Nr fabr.: ZGKP015V1188086
A-N 145-√3 kV	Poziom Izolacja: 145/275/650 kV	Wsp.napięciowy: 1,9/8h		IEC 61869-3 50 Hz
Uzwojenie				
Parametry 1				
1a-1n	Usn [kV]	Sn [VA]	klasa	Sth [VA]
2a-2n	0,115-√3	25	0,1	1500
3a-3n	0,115-√3	25	0,1	1500
da-dn	0,115	100	0,1	1500
			1,0	450
Uzwojenie				
Parametry 2				
1a-1n	Usn [kV]	Sn [VA]	klasa	Sth [VA]
2a-2n	0,115-√3	25	1,0	1500
3a-3n	0,115-√3	25	1,0	1500
da-dn	0,115	300	1,0	1500
			3P	450

Lista przeprowadzonych badań

1. Próba Izolacji uzwojeń pierwotnych napięciem o częstotliwości sieciowej
  2. Pomiar wyładowań niezupełnych
  3. Próba Izolacji uzwojeń wtórnych napięciem o częstotliwości sieciowej
  4. Sprawdzenie dokładności
  5. Pomiar pojemności i współczynnika strat dielektrycznych (tg δ) przekładnika
  6. Pomiar rezystancji uzwojeń
  7. Tabliczka znamionowa
- A: U<sub>p</sub> = 220kV / 60s, f = 120Hz; N: U<sub>p</sub> = 3kV / 60s, f = 50Hz  
 - U<sub>p</sub> = 3 kV/60s

Pomiar wyładowań niezupełnych  
 - Pomiar wykonano wg procedury A (napięcia próbierza osiągnięto podczas obniżania napięcia po próbie izolacji uzwojenia pierwotnego)  
 Napięcie stresu: 220 kV / 60 s  
 Częstotliwość: 120 Hz

Napięcie próbierze	1,2 Um = 174 kV
Poziom wyładowań niezupełnych	1 pC 1,2 Um / √3 = 100,5 kV 0,6 pC

- Napięcie zapłonu WNZ: >220 kV
- Napięcie wygaszenia WNZ: >220 kV

Uwagi: Poziom zakłócań: 0,6 pC (odczyt po wyłączeniu napięcia), ładunek kalibrujący: 5,1 pC

Sprawdzenie dokładności (ε U%), (Δp U min) – parametry 1  
 Data pomiaru: 2016-05-30  
 Temperatura otoczenia: 31 +/- 2°C  
 Wilgotność względna powietrza: 40 +/- 10%







project: ewn45e16 test date 19-05-2016 page 1

**Test - object - data**

WNR ewn45e16 TR-No. 2GKFP0115V1188080D.-No. 4500743552

test object PV145a vector group 650  
output voltage 145 kVA 50 Hz  
145 kV frequency

customer ABB Sp. z o. o. ul. Zeganska 1, 04-713 Warszawa

L1 lightning-impulse		Up [kV]	T1 [us]	T2 [us]	Tc [us]	Ip [A]	remark
1		-325.3	1.22	45.4		-363.6	LI: A - FW(50.0%)
2		-648.1	1.23	45.8		-453	LI: A - FW(100.0%)
3		-375	1.22		3.48	-625.2	LI: A - CFW(57.5%)
4		-744.8	1.24		3.44	-1122	LI: A - CFW(115.0%)
5		-745.3	1.24		3.4	-1123	LI: A - CFW(115.0%)
6		-647.7	1.23	45.7		-537.8	LI: A - FW(100.0%)
7		-648	1.23	45.8		-361.4	LI: A - FW(100.0%)
8		-648.2	1.23	45.8		-393.7	LI: A - FW(100.0%)
9		-648.3	1.23	45.8		-412.2	LI: A - FW(100.0%)
10		-648	1.23	45.8		-493.4	LI: A - FW(100.0%)
11		-646.9	1.24	45.9		-465.1	LI: A - FW(100.0%)
12		-648	1.23	45.9		-531.1	LI: A - FW(100.0%)
13		-648.3	1.23	45.8		-498.6	LI: A - FW(100.0%)
14		-648.2	1.23	45.9		-305.8	LI: A - FW(100.0%)
15		-648.2	1.23	45.9		-346.5	LI: A - FW(100.0%)
16		-648.7	1.23	45.8		-394.9	LI: A - FW(100.0%)
17		-648.9	1.23	45.8		-353	LI: A - FW(100.0%)
18		-648.1	1.23	45.9		-461.3	LI: A - FW(100.0%)
19		-648	1.23	45.8		-460	LI: A - FW(100.0%)
20		323.8	1.23	45.5		326.4	LI: A - RW(50.0%)
21		649.9	1.23	45.9		425.5	LI: A - FW(100.0%)
22		650.2	1.23	45.8		364.9	LI: A - FW(100.0%)
23		650.2	1.23	45.6		424.7	LI: A - FW(100.0%)
24		649.5	1.23	45.9		476.2	LI: A - FW(100.0%)
25		649.9	1.23	45.9		323.1	LI: A - FW(100.0%)
26		649.9	1.22	45.8		433.1	LI: A - FW(100.0%)
27		649.6	1.23	45.9		538.4	LI: A - FW(100.0%)
28		649.4	1.23	45.9		349.9	LI: A - FW(100.0%)
29		649.3	1.23	45.7		396.1	LI: A - FW(100.0%)

*Handwritten mark*

345



project: ewn45e16 page 2

30	649.2	1.23	45.9	367.3	LI: A - FW(100.0%)
31	649.1	1.22	45.9	459.3	LI: A - FW(100.0%)
32	649.6	1.22	45.9	376.5	LI: A - FW(100.0%)
33	648.6	1.22	45.9	343.2	LI: A - FW(100.0%)
34	649.1	1.23	45.9	540.2	LI: A - FW(100.0%)
35	648.8	1.23	45.8	336.1	LI: A - FW(100.0%)

*Handwritten mark*

346




# HIGH VOLTAGE LABORATORY

POLAND 01-330 WARSZAWA, ul. Mary 8  
fax: (+4822) 835-80-48, mail: ewn@hvl.com.pl

project: ewn45e16

page 3




# HIGH VOLTAGE LABORATORY

POLAND 01-330 WARSZAWA, ul. Mary 8  
fax: (+4822) 835-80-48, mail: ewn@hvl.com.pl

project: ewn45e16

page 4













# HIGH VOLTAGE LABORATORY

POLAND 01-330 WARSZAWA, ul. Mory 8  
fac (+4922) 836-80-48, mail: ewm@ien.com.pl

project: ewm45e16

page 6



Handwritten signature











# HIGH VOLTAGE LABORATORY

POLAND 01-330 WARSZAWA, ul. Mory 8  
fac (+4922) 836-80-48, mail: ewm@ien.com.pl

project: ewm45e16

page 5




Handwritten signature

347





	<b>INSTYTUT ENERGETYKI</b> INSTITUTE OF POWER ENGINEERING	address: ul. Mocy 3 01-530 Warszawa, Poland phone: +48 22 836 80 16 e-mail: ewp@iec.com.pl www.iec.com.pl/ewp
	<b>LABORATORIUM WIELKOPRĄDOWE</b> HIGH CURRENT LABORATORY	

	<b>INSTITUTE OF POWER ENGINEERING</b> HIGH CURRENT LABORATORY	Test Report No. EWP/40/E/2015
---	--	----------------------------------

Contents	
1.	Description of the test object
2.	Technical data declared by the Manufacturer
3.	Technical documentation of the test object
4.	Scope of the tests
5.	Tests and their results
6.	Summary
7.	Opinions and interpretations
8.	Photographic documentation

Report contents 17 numbered pages with:

6	Photographs
6	Appendices

**TEST REPORT NO.**  
**EWP/40/E/2015**

**TEST OBJECT:** Voltage transformers type EMF-E072 and EMF-E145

**MANUFACTURER:** ABB Sp. z o.o.  
Ul. Leszno 59  
06-300 Przasnysz, Poland

**TESTS ORDERED BY:** ABB Sp. z o.o.  
Ul. Żegalska 1  
04-713 Warszawa, Poland  
Orders No. 4500660979 dated 08.07.2015 and No. 4500679239 dated 17.09.2015

**TYPE OF TESTS:** Mechanical impact test

**TESTS PROCEDURE:** IEC 61869-1:2007

**OBJECT DELIVERED:** 24.08.2015

**DATE OF TESTS:** 25.08.2015 – 02.10.2015

**TESTS RESULTS:** Positive

**THE TESTS WERE WITNESSED BY:**

<p>Authorised by <b>TEST ENGINEER:</b> Mariusz SUL M.Sc. Eng.</p> <p><i>Mariusz Sul</i></p>	<p>Approved by <b>HEAD OF LABORATORY:</b> Maciej OWSINSKI M.Sc. Eng.</p> <p><i>Maciej Owsinski</i></p>
---	--

Warsaw, 8.10.2015

*[Signature]* 349

*[Large Signature]*

This report refers only to the test object.  
The Test Report cannot be used for and beyond the scope of accreditation (details in sub-2.4).  
Publishing or reproducing of this report in other vesels than exact and complete without permission of laboratory is forbidden.

1.	Description of the test object
Test object No.1	Voltage transformer
Type	EMF-E072
Serial number	2GKP015V1188091
Year of production	2015
Insulator	Porcelain insulator
Dimensions	According to drawing No. 2GKP015V1188091 (Appendix No. 1)

Test object No.2	Voltage transformer
Type	EMF-E072
Serial number	2GKP015V1188038
Year of production	2015
Insulator	Composite insulator
Dimensions	According to drawing No. 2GKP015V1188038 (Appendix No. 2)

Test object No.3	Voltage transformer
Type	EMF-E145
Serial number	1HSE8849700
Year of production	2015
Insulator	Composite insulator
Dimensions	According to drawing No. 1HSE8849700 (Appendix No. 3)

Test object No.4	Voltage transformer
Type	EMF-E145
Serial number	2GKP013K1486306
Year of production	2015
Insulator	Porcelain insulator
Dimensions	According to drawing No. 2GKP013K1486306 (Appendix No. 4)



Test object No.5	Voltage transformer
Type	EMF-E072
Serial number	2GKP015V1188093
Year of production	2015
Insulator	Porcelain insulator
Dimensions	According to drawing No. 2GKP015V1188093 (Appendix No. 5)

Test object No.6	Voltage transformer
Type	EMF-E072
Serial number	2GKP015V1188092
Year of production	2015
Insulator	Composite insulator
Dimensions	According to drawing No. 2GKP015V1188092 (Appendix No. 6)

The identification of the test objects was made by Laboratory basing on the documentation mentioned in sub-cl. 3 and appendices No. 1-6. The objects were prepared for tests by the Manufacturer.

2.	Technical data declared by the Manufacturer
Protection against mechanical impact (IK code)	
	IK 07

3.	Technical documentation of the test object
<ol style="list-style-type: none"> <li>1. Voltage transformer EMF-E072. Prototype V - drawing No. 2GKP015V1188091.</li> <li>2. Voltage transformer EMF-E072. Prototype IV - drawing No. 2GKP015V1188038.</li> <li>3. Voltage transformer EMF-E145. Prototype VII - drawing No. 1HSE8849700.</li> <li>4. Voltage transformer EMF-E145. Prototype VIII - drawing No. 2GKP013K1486306.</li> <li>5. Voltage transformer EMF-E072. Prototype X - drawing No. 2GKP015V1188093.</li> <li>6. Voltage transformer EMF-E072. Prototype IX - drawing No. 2GKP015V1188092.</li> </ol>	




<b>4. Scope of the tests</b>	
Test program agreed with Orderer comprised of the following tests:	
<b>Kind of test</b>	<b>Standard</b>
Mechanical impact test	IEC 61869-1:2007 sub-cl. 7.2.7.2

<b>5. Tests and their results</b>	According to standard
<b>5.1 Mechanical impact test (IK code)</b>	IEC 61869-1:2007 sub-cl. 7.2.7.2
Mechanical impact tests were performed on six specimens of voltage transformers. Three shocks were applied to points of the enclosure that are likely to be the weakest points. The impact energy was equal 2J. Places such as connectors and displays were exempt from the test. After the tests enclosures did not have any breaks or deformation that may affect the normal operation of the voltage transformers. Specified degree of protection was fulfilled. The points of impact are shown on the photographs 1-6.	
<b>Test result:</b> Positive for IK 07.	

<b>6. Summary</b>	Tested voltage transformers meet the requirements of the following standards:	
<b>Kind of test</b>	<b>Standard</b>	<b>Test result</b>
Mechanical impact test	IEC 61869-1:2007 sub-cl. 7.2.7.2	Positive

<b>7. Opinions and interpretations</b>
None

**8. Photographic documentation**




**ABB Voltage Transformer**

Type	EMF-E072	Serial No	EGKP015/1188081
Insulation level	72.5/140/325 kV	Standard	IEC 61869-3
Frequency	50 Hz	Fv	1.8 / 8kV
Transportation	Horizontal/vertical	Insulation class	A
Temp. range	-40 / +40 °C	Production year	2015
Weight	180 kg	Oil weight	40 kg
Oil type	Nynas Nycro 10KN ISO-L-NTD-2980130		

Attention: Herewithly tested unit - do not open. Oil sampling possible according to manufacturer's guidelines.

Photograph No. 1. Tested object No. 1

351.



**ABB Voltage Transformer**

Type | EMF-5072 | Serial No | 223RPT15V1188038

Insulation level | 72.5/140/325 kV | Standard | IEC 61888-3

f | 50 Hz | F | kN | F<sub>1</sub> | 1.8 / 8h

Transportation | Horizontal/Vertical |

Insulation class | A | Temp. range | -40 / +40 °C

Production year | 2015

A-N | 66 / 43 kV

1e-1e 100kV 0VA 0VA 40.2 100VAh

2e-2e 100kV 50VA 40.2 200VAh

3e-3e 100kV 100VA 40.2 400VAh

4e-4e 100kV 50VA 40.2 200VAh

5e-5e 100kV 100VA 40.2 400VAh


Weight | 160 kg | Oil weight | 40 kg

Oil type | Nynas Nynas ION

ISO-L-NTIC-2660130

Hermetically sealed unit - do not open. Oil sampling possible according to manufacturer's guidelines.

Photograph No 2. Tested object No. 2



**ABB Voltage Transformer**

Type | EMF-E145 | Serial No | THSE8849700

Insulation level | 145/275/550 kV | Standard | IEC 61888-3

f | 50 Hz | F | kN | F<sub>1</sub> | 1.9 / 8h

Transportation | Horizontal/Vertical |

Insulation class | A | Temp. range | -40 / +40 °C

Production year | 2015

A-N | 139 / 43 kV

1e-1e 100kV 0VA 0VA 40.2 100VAh

2e-2e 100kV 50VA 40.2 200VAh

3e-3e 100kV 100VA 40.2 400VAh

4e-4e 100kV 50VA 40.2 200VAh

5e-5e 100kV 100VA 40.2 400VAh

Weight | 274 kg | Oil weight | 70 kg

Oil type | Nynas Nynas ION

ISO-L-NTIC-2660130


Hermetically sealed unit - do not open. Oil sampling possible according to manufacturer's guidelines.

Photograph No. 3. Tested object No. 3.



INSTITUTE OF POWER ENGINEERING  
HIGH CURRENT LABORATORY

Test Report No.  
EWP/40/E/2015



**ABB Voltage Transformer**

Type EMF-E146 Serial No 2GRF013K1468308

Insulation level 145/215/50 kV Standard IEC 61809-3

Frequency 50 Hz F KN F<sub>v</sub> 1,9 / 8h

Transportation Horizontal/Vertical

Insulation class A Temp. range -40 / +40 °C

Production year 2015

Weight 340 kg Oil weight 70 kg

Oil type Nynas Nviro 10XN  
ISO-L-NTIO-2960130


Attention:  
Hermetically sealed unit - do not open. Oil sampling possible according to manufacturer's guidelines.

Photograph No. 4. Tested object No. 4.



INSTITUTE OF POWER ENGINEERING  
HIGH CURRENT LABORATORY

Test Report No.  
EWP/40/E/2015



**ABB Voltage Transformer**

Type EMF-E072 Serial No 2GRF013V1180893

Insulation level 72.8/140/325 kV Standard IEC 61809-3

Frequency 50 Hz F KN F<sub>v</sub> 1,9 / 8h

Transportation Horizontal/Vertical

Insulation class A Temp. range -40 / +40 °C


Production year 2015

Weight 220 kg Oil weight 45 kg

Oil type Nynas Nviro 10XN  
ISO-L-NTIO-2960130

Attention:  
Hermetically sealed unit - do not open. Oil sampling possible according to manufacturer's guidelines.

Photograph No. 5. Tested object No. 5.



**ABB Voltage Transformer**

Type: EMF-6072    Serial No: 2GKPO18V1180092

Insulation level: 72.5/140/225 KV    Standard: IEC-81809-3

f<sub>s</sub>: 50 Hz    F: RN    F<sub>v</sub>: 1.9 / 8h

Transportation: Horizontal/Vertical

Insulation class: A    Temp. range: -40 / +40 °C

Production year: 2015

Weight: 160 kg    Oil weight: 45 kg


Oil type: Nymra Nytra 100X  
ISO-LANTIC-2880130

Harmlessly tested unit - do not open. Oil sampling possible according to manufacturer's guidelines.

Photograph No. 6. Tested object No. 6.




Appendix No. 1






Appendix No. 3




Appendix No. 2






Appendix No. 5



Appendix No. 4




356



*Handwritten signature*

*Handwritten signature*

Appendix No. 6



*Handwritten signature*

C

C



**INSTYTUT ENERGETYKI**  
 INSTITUTE OF POWER ENGINEERING  
 LABORATORIUM WIELKOPRĄDOWE  
 HIGH CURRENT LABORATORY

address: ul. Mory 8  
 01-339 Warszawa, Poland  
 phone/fax: +48 22 836 80 16  
 e-mail: ewp@im.com.pl  
 www.im.com.pl/ewp

Test Report No.  
 EWP/52/E/2015-1

INSTITUTE OF POWER ENGINEERING  
 HIGH CURRENT LABORATORY

Contents	
1.	Description of the test object
2.	Technical data declared by the Manufacturer
3.	Technical documentation of the test object
4.	Scope of the tests
5.	Tests and their results
6.	Summary
7.	Photographic documentation

Report contains 13 numbered pages with:

- 2 Drawings
- 1 Photographs
- 2 Appendices

**TEST REPORT NO.**  
**EWP/52/E/2015-1**

**TEST OBJECT:** Voltage transformer type EMF-E084

**MANUFACTURER:** ABB Sp. z o.o.  
 ul. Leszno 59  
 06-300 Przasnysz, Poland

**TESTS ORDERED BY:** ABB Sp. z o.o.  
 ul. Żeglarska 1  
 04-713 Warszawa, Poland  
 Order No. 4500678261 dated 15.09.2015

**TYPE OF TESTS:** Temperature-rise test

**TESTS PROCEDURE:** IEC 61869-1:2007, IEC 61869-3:2011

**OBJECT DELIVERED:** 02.10.2015

**DATE OF TESTS:** 06.10.2015

**TESTS RESULTS:** Positive

**THE TESTS WERE WITNESSED BY:**

Authorised by  
**TEST ENGINEER:**  
 Mariusz SUI, M.Sc. Eng.

*Mariusz SUI*

Approved by  
**HEAD OF LABORATORY:**  
 Maciej OWŚNICKI M.Sc. Eng.

*Maciej Owśnicki*

Warsaw, 12.10.2015

Tests result reflect only to the test object.  
 The Test Report contains tests from and beyond the scope of accreditation (details in sub-cl. 4)  
 Publishing or reproducing of this report in other version than exact and complete without written permission of laboratory is forbidden

360

1.	Description of the test object
	Voltage transformer
Type	EMF-E084
Serial number	1HSE8851777
Manufacturer	ABB Sp. z o.o.
Year of production	2015
Insulator	Porcelain insulator
Number of windings	3
Oil type	L-NTIO-296
Temperature range	-40°C - +40°C
Insulating oil weight	41 kg
Total weight	190 kg
Dimensions	According to appendix No.1 1HSE8851777

The laboratory made the identification of test objects basing documentation given in sub-cl. 3, appendix No. 1. The test object is shown in the photographs No. 1. The object was prepared for tests by the Manufacturer.

2. Technical data declared by the Manufacturer			
Rated voltage		77:√3 kV	
Maximum operating voltage		84 kV	
Rated frequency		50 Hz	
Voltage factor and time		1,9U <sub>d</sub> /8h	
Winding	1a-1n	2a-2n	da-dn
Rated secondary voltage	110:√3 V	110:√3 V	110/3 V
Rated output	25 VA	25 VA	50 VA
Accuracy class	0,2	0,2	3P
Thermal limiting output	1000 VA	1000 VA	150 VA

3.	Technical documentation of the test object
1.	Drawing No. 1HSE8851777 – Voltage Transformer EMF-E084 PROTOTYPE V ; ABB Sp. z o.o. , approved 29.09.2015 – Appendix No. 1
2.	Declaration of Conformity No. 098/2015 (EN) ; ABB Sp. z o.o., Przasnysz, 05.10.2015 – Appendix No. 2

4. Scope of the tests			
Test program agreed with Orderer comprised of following tests:			
No.	Kind of test	Tests according the Standard	Location of the test
1.	Temperature-rise tests	IEC 61869-1:2007 sub-cl. 6.4.1 and 7.2.2 IEC 61869-3:2011 sub-cl. 6.4.1 and 7.2.2 IEC 62271-1:2007, table No. 3	EWP
EWP The test was performed in Institute of Power Engineering, by High - Current Laboratory.			



### 5. Tests and their results

Voltage transformer was installed at the test stand, as it was during normal operation. Electric diagram of terminal box of tested voltage transformer is given in Fig. 1. The rated voltage with a required value was applied to the primary voltage winding. The secondary voltage windings and the residual voltage winding were loaded with the suitable power, according to the test program given below, which was agreed with the Orderer.

The arrangement of the thermocouples is given in Fig. 2. The temperature-rises of windings were measured by the resistance rise method. During the test, the measurements of loaded windings were made every 1-hour. The abstract of the protocol of temperature-rise test is given in Table No. 1. The summary of test results is given in Table No. 2.

The temperature-rise of windings were calculated from the formula:

$$\Delta T = \frac{R}{R_0 \alpha} \frac{R_1 - R_0}{R_0} \cdot 0,004$$

#### Stage No. 1: Test at the rated load

Test was performed according to the IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2. The voltage value  $1,2 U_n = 53,4 \text{ kV}$  was applied to the A terminal. The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow 25 \text{ VA}$ ,  $\cos\phi = 1$ , at the voltage  $110/\sqrt{3} \text{ V}$ ; 2a-2n  $\Rightarrow 25 \text{ VA}$ ,  $\cos\phi = 1$ , at the voltage  $110/\sqrt{3} \text{ V}$ .

The winding of residual voltage remained open. The test was performed till reached steady state of the measured temperatures.

#### Stage No. 2: Test of 8 h

Test was done immediately after the Stage No. 1 according to the IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2. The voltage value  $1,9 U_n = 84,5 \text{ kV}$  was applied to the A terminal.

The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow 25 \text{ VA}$ ,  $\cos\phi = 1$ , at the voltage  $110/\sqrt{3} \text{ V}$ ; 2a-2n  $\Rightarrow 25 \text{ VA}$ ,  $\cos\phi = 1$ , at the voltage  $110/\sqrt{3} \text{ V}$ .

The residual winding da-dn was loaded by  $\Rightarrow 150 \text{ VA}$ ,  $\cos\phi = 1$ , at the voltage  $110/3 \text{ V}$ .

The duration of the test was 8 h.

#### Stage No. 3: Test with thermal limiting output

Test was done immediately after Stage No. 2 according to the IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2. The voltage value  $U_n = 44,5 \text{ kV}$  was applied to the A terminal.

According to Manufacturers request secondary voltage windings (i.e. 1a-1n, 2a-2n) were loaded by limit power  $1000 \text{ VA}$  at  $\cos\phi = 1$ . The residual winding remained open.

The test was performed till reaching the steady state of the measured temperatures.



### Measuring instruments

The temperatures were measured by means of type K thermocouples (NICK - NIAI) with accuracy  $\pm 0,6^\circ\text{C}$ . The ambient temperature was measured using four thermocouples type K immersed into tank filled with oil. These thermocouples were placed in the distance of 1 meter from the tested transformer at the height of 1 meter above floor - the accuracy of measurement  $\pm 0,6^\circ\text{C}$ . The resistance was measured by means of meter type 2291 manufactured by TETTEX Instruments with accuracy  $\pm 0,01 \text{ m}\Omega$ .

ABB Voltage transformer IEC 61869-3 Made in Sweden  
Serial number 2292  
Type EWP/52/EK Production year IEC 61869-3  
IESE minimum Standard 30 Hz  
150/300 kV Frequency 50 Hz  
Rated primary voltage 77000/3 V Temperature range -40 - 120 kg  
Highest voltage for equipment 94 kV Total mass

1HSE 68504-5

Serial number IIESE number  
Insulation oil (IEC 61869-3:2004) kV  
Voltage 110/3 kV

Terminal	Voltage V	Class	burden VA	Total burden VA	Thermal limit VA
1a	110/3	0,2	25	50	1000/3
1n	110/3	0,2	25	50	1000/3
2a	110/3	0,2	25	50	1000/3
2n	110/3	0,2	25	50	1000/3
da	110/3	30	30	30	1500
dn					

1HSE 68504-6

Fig. 1. Nameplates of tested voltage transformer

364

<sup>1</sup> The expanded uncertainty assigned corresponds to a coverage probability of 95 % and the coverage factor  $k = 2$ .

Table No. 1. Temperature-rise test results of voltage transformer EHV-E084, serial No. HSP851777

Parameter	Stage No. 1				Stage No. 2				Stage No. 3				
	0	1	2	3	4	5	6	7	8	9	10	11	12
U <sub>0</sub> , kV	53.4												
I <sub>0</sub> , mA	-	-	-	-	4.3	-	-	-	-	-	-	-	-
AT thermocouple No. 1, K	0	0.62	0.52	0.93	1.07	1.75	1.79	1.76	1.79	1.74	2.10	2.54	2.90
AT thermocouple No. 2, K	0	0.67	0.72	1.28	1.68	2.19	2.40	2.52	2.68	2.90	3.28	3.52	3.98
AT thermocouple No. 3, K	0	0.59	0.64	1.77	1.86	2.59	2.65	3.10	3.43	3.61	3.76	3.94	4.03
t <sub>0</sub> , °C	19.25	19.48	19.56	19.55	19.59	19.65	19.73	19.72	19.85	19.85	19.89	19.90	20.06
R <sub>tan δ</sub> , mΩ	108.8	109.48	109.64	110.12	110.33	110.88	111.30	111.55	111.82	112.01	112.21	112.32	112.45
R <sub>tan δ</sub> , mΩ	100.20	100.85	101.19	101.44	101.63	102.15	102.53	102.75	103.18	103.36	103.46	103.57	103.69
R <sub>tan δ</sub> , mΩ	39.77	40.04	40.16	40.25	40.32	40.45	40.67	40.84	40.91	40.96	41.01	41.04	41.04
AT <sub>tan δ</sub>	0	1.56	1.56	1.56	1.56	1.56	1.56	1.56	1.56	1.56	1.56	1.56	1.56
AT <sub>tan δ</sub>	0	1.62	1.62	1.62	1.62	1.62	1.62	1.62	1.62	1.62	1.62	1.62	1.62
AT <sub>tan δ</sub>	0	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70
AT <sub>tan δ</sub>	0	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88

Heating time (h): 44.5




Fig. 2. Arrangement of thermocouples during temperature-rise test.  
1 - oil; 2 - under the flange of tank lid; 3 - lower tank (placed inside over earthing terminal).



Table No. 2. Temperature-rises [K] given during the tests voltage transformer EMF-E084 serial No. 1HSE851777

		Temperature rise ΔT [K]	Limit [K]
Stage No. 1	Windings	1a-1n	3,52
		2a-2n	3,57
		da-dn	3,48
		A-N	2,47
		Oil	1,07
Thermocouple No. 1			55 <sup>1)</sup>
	Under the flange of tank lid	1,68	40 <sup>2)</sup>
	Enclosure of lower tank	1,86	
Stage No. 2	Windings	1a-1n	8,39
		2a-2n	8,41
		da-dn	8,02
		A-N	7,92
		Oil	2,90
Thermocouple No. 1			55+10 <sup>1)</sup>
	Under the flange of tank lid	3,32	40 <sup>2)</sup>
	Enclosure of lower tank	4,03	
Stage No. 3	Windings	1a-1n	37,02
		2a-2n	35,80
		da-dn	27,87
		A-N	41,90
		Oil	6,76
Thermocouple No. 1			55 <sup>1)</sup>
	Under the flange of tank lid	5,60	40 <sup>2)</sup>
	Enclosure of lower tank	6,14	

<sup>1)</sup> acc. to IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2

<sup>2)</sup> acc. to IEC 62271-1

**6. Summary**


In tested voltage transformer type EMF-E084 with porcelain insulator, as results of temperature-rise test:

- in steady state, at the rated load of secondary voltage windings (without residual winding), and supply voltage 1,2U<sub>n</sub> (Stage No. 1), permitted temperature-rise limits were not exceeded.

- results of test 8 h at supply voltage 1,9U<sub>n</sub> and rated load of voltage windings and load of residual winding with thermal limiting output (Stage No. 2), shows that permitted temperature-rise limits were not exceeded.


- results of test with thermal limiting output for all voltage windings (without residual windings) and supply voltage U<sub>n</sub> (Stage No. 3), shows that permitted temperature-rise limits were not exceeded.

The tested voltage transformer met requirements of IEC 61869-1:2007 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3:2011 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 62271-1:2007 standards.



364


7. Photographic documentation



Photograph No. 1. Voltage transformer on the test stand during temperature-rise test.




Appendix No. 1









Appendix No. 2

	Declaration of conformity	ABB Sp. z o.o. Dept. in Przasnysz POLAND						
<p><b>DECLARATION OF CONFORMITY No. 09812015 (EN)</b> (acc. to ISO/IEC 17050-1)</p> <p>Manufacturer: ABB</p> <p>Product: Voltage Instrument Transformer EMF-E084</p> <p>Above mentioned product conforms with the following standard :</p> <table border="0"> <tr> <td>Standard</td> <td>Title</td> <td>Edition/Date</td> </tr> <tr> <td>IEC 61869 - 3</td> <td>Voltage Instrument Transformers</td> <td>2015</td> </tr> </table> <p>Additional information: Serial numbers: 1HSE 8851777;</p> <p>Place and date of issue of declaration Przasnysz 05.10.2015</p>			Standard	Title	Edition/Date	IEC 61869 - 3	Voltage Instrument Transformers	2015
Standard	Title	Edition/Date						
IEC 61869 - 3	Voltage Instrument Transformers	2015						
<table border="0"> <tr> <td style="vertical-align: top;"> <p>Konwent Organizacji PPPT ABB Sp. z o.o. Osiedle w Przasnysz</p> <p><i>[Signature]</i> (Name)</p> </td> <td style="vertical-align: top;"> <p>- kierownik ds. Zapewnienia Jakości ABB Sp. z o.o. Osiedle w Przasnysz</p> <p><i>[Signature]</i> Krzysztof Lubbecki (Signature)</p> </td> </tr> </table>			<p>Konwent Organizacji PPPT ABB Sp. z o.o. Osiedle w Przasnysz</p> <p><i>[Signature]</i> (Name)</p>	<p>- kierownik ds. Zapewnienia Jakości ABB Sp. z o.o. Osiedle w Przasnysz</p> <p><i>[Signature]</i> Krzysztof Lubbecki (Signature)</p>				
<p>Konwent Organizacji PPPT ABB Sp. z o.o. Osiedle w Przasnysz</p> <p><i>[Signature]</i> (Name)</p>	<p>- kierownik ds. Zapewnienia Jakości ABB Sp. z o.o. Osiedle w Przasnysz</p> <p><i>[Signature]</i> Krzysztof Lubbecki (Signature)</p>							

365



	<b>INSTYTUT ENERGETYKI</b> INSTITUTE OF POWER ENGINEERING LABORATORIUM WIELKOPRADOWE HIGH CURRENT LABORATORY	address: ul. Mory 8 01-330 Warszawa, Poland phone/fax: +48 22 336 80 16 e-mail: ewp@ieh.com.pl www.ieh.com.pl/ewp
---	---	---

	<b>INSTITUTE OF POWER ENGINEERING</b> HIGH CURRENT LABORATORY	Test Report No. EWP/52/E/2015-3
---	--	------------------------------------

**TEST REPORT NO.**  
**EWP/52/E/2015-3**

**TEST OBJECT:** Voltage transformer type EMF-E145

**MANUFACTURER:** ABB Sp. z o.o.  
ul. Leszno 59  
06-300 Przasnysz, Poland

**TESTS ORDERED BY:** ABB Sp. z o.o.  
ul. Żegalska 1  
04-713 Warszawa, Poland  
Order No. 4500678261 dated 15.09.2015

**TYPE OF TESTS:** Temperature-rise test

**TESTS PROCEDURE:** IEC 61869-1:2007, IEC 61869-3:2011

**OBJECT DELIVERED:** 22.10.2015

**DATE OF TESTS:** 25.10.2015

**TESTS RESULTS:** Positive

**THE TESTS WERE WITNESSED BY:**

Authorised by  
**TEST ENGINEER:** Mariusz SUL M.Sc. Eng.  
*Mariusz Sul*

Approved by  
**HEAD OF LABORATORY:** Maciej OWSIŃSKI M.Sc. Eng.  
*Maciej Owsinski*

Warsaw, 16.11.2015

Contents	
1.	Description of the test object
2.	Technical data declared by the Manufacturer
3.	Technical documentation of the test object
4.	Scope of the tests
5.	Tests and their results
6.	Summary
7.	Photographic documentation

Report contains 12 numbered pages with:	
2	Drawings
1	Photographs
2	Appendices

*[Handwritten mark]*

Tests result refers only to the test object.  
The Test Report consist tests from and beyond the scope of accreditation (details in sub-d. 9)  
Publishing or reproducing of this report in other version than exact and complete without written permission of laboratory is forbidden

*[Large handwritten signature]*

<b>1. Description of the test object</b>	
Test object	Voltage transformer
Type	EMF-E145
Serial number	1HSE8851772
Manufacturer	ABB Sp. z o.o.
Year of production	2015
Insulator	Composite insulator
Number of windings	4
Oil type	L-NTIO-296
Temperature range	-40°C - +40°C
Insulating oil weight	80 kg
Total weight	248 kg
Dimensions	According to appendix No.1 1HSE8851772
The laboratory made the identification of test objects basing documentation given in sub-cl. 3. The test object is shown in the photographs No. 1. The object was prepared for tests by the Manufacturer.	

<b>2. Technical data declared by the Manufacturer</b>	
Rated voltage [kV]	145√3
Maximum operating voltage [kV]	145
Rated frequency [Hz]	50
Voltage factor and time	1,9U <sub>n</sub> /8h
Winding	1a-1n    2a-2n    3a-3n    da-dn
Rated secondary voltage [V]	115√3    115√3    115√3    115√3    115    115
Rated output [VA]	25    25    25    25    500    100    300
Accuracy class	0,1    1,0    0,1    1    0,1/3P    1,0    3P
Thermal limiting output [VA]	1500    1500    1500    1500    1500    450    450

<b>3. Technical documentation of the test object</b>			
1.	Drawing No. 1HSE8851772 – Voltage Transformer EMF-E145 PROTOTYPE I; ABB Sp. z o.o. , approved 23.06.2015 – Appendix No. 1		
2.	Declaration of Conformity No. 101/2015 (EN); ABB Sp. z o.o., Przasnysz, 29.10.2015 – Appendix No. 2		
<b>4. Scope of the tests</b>			
Test program agreed with Orderer comprised of following tests:			
No.	Kind of test	Tests according the Standard	Location of the test
1.	Temperature-rise tests	IEC 61869-1:2007 sub-cl. 6.4.1 and 7.2.2 IEC 61869-3:2011 sub-cl. 6.4.1 and 7.2.2 IEC 62271-1:2007, table No. 3	EWP
EWP The test was performed in Institute of Power Engineering, by High - Current Laboratory.			

<b>5. Tests and their results</b>	
Voltage transformer was installed at the test stand, as it was during normal operation. Electric diagram of terminal box of tested voltage transformer is given in Fig. 1. The rated voltage with a required value was applied to the primary voltage winding. The secondary voltage windings and the residual voltage winding were loaded with the suitable power, according to the test program given below, which was agreed with the Orderer.	
The arrangement of the thermocouples is given in Fig. 2. The temperature-rises of windings were measured by the resistance rise method. During the test, the measurements of loaded windings were made every 1-hour. The abstract of the protocol of temperature-rise test is given in Table No. 1. The summary of test results is given in Table No. 2.	
The temperature-rise of windings were calculated from the formula: $\Delta T = \frac{R}{R_0} \alpha = \frac{R_1 - R_0}{R_0} \cdot 0,004$	

368



**Stage No. 1: Test at the rated load**  
 Test was performed according to the IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2. The voltage value  $1,2 U_n = 100,5$  kV was applied to the A terminal. The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage  $115/\sqrt{3}$  V; 2a-2n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage  $115/\sqrt{3}$  V; 3a-3n  $\Rightarrow$  500 VA,  $\cos\phi = 1$ , at the voltage  $115/\sqrt{3}$  V.  
 The winding of residual voltage remained open.  
 The test was performed till reached steady state of the measured temperatures.

**Stage No. 2: Test of 8 h**  
 Test was done immediately after the Stage No. 1 according to the IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2. The voltage value  $1,9 U_n = 159$  kV was applied to the A terminal.  
 The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage  $115/\sqrt{3}$  V; 2a-2n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage  $115/\sqrt{3}$  V; 3a-3n  $\Rightarrow$  500 VA,  $\cos\phi = 1$ , at the voltage  $115/\sqrt{3}$  V.  
 The residual winding da-dn was loaded by  $\Rightarrow$  450 VA,  $\cos\phi = 1$ , at the voltage 115 V.  
 The duration of the test was 8 h.

**Measuring instruments**

The temperatures were measured by means of type K thermocouples (NiCr - NiAl) with accuracy  $\pm 0,6^\circ\text{C}$ . The ambient temperature was measured using four thermocouples type K immersed into tank filled with oil. These thermocouples were placed in the distance of 1 meter from the tested transformer at the height of 1 meter above floor - the accuracy of measurement  $\pm 0,6^\circ\text{C}$ . The resistance was measured by means of meter type 2291, manufactured by TETTEX Instruments with accuracy  $\pm 0,01$  m $\Omega$ .<sup>1</sup>

<sup>1</sup> The expanded uncertainty assigned corresponds to a coverage probability of 95% and the coverage factor  $k = 2$ .



**ABB** **CE** **ABB AB** Made in Sweden

Voltage transformer Type BMT-E143 Production year 182 G1602

Serial number 2157630 KV Frequency 50 Hz

Insulation level 145000 kV Test temperature -10 ~ +40 °C

Rated primary voltage 145 kV Total mass 248 kg

Highest voltage for equipment

THRE 08504-5

Serial number 11531-units/anal

Insulation oil IEC 61003-L-RTIC-200 kV

Warranty 1,97 h

Winding	Current	Voltage V	Class	Power VA	Thermal limit VA
1a	1a-n	115/√3	0,1	25	3000,0
2a	2a-n	115/√3	0,05	25	3000,0
3a	3a-n	115/√3	1,0	25	3000,0
da	da-dn	115/√3	0,102	450	15000,0
3a	3a-n	115/√3	3,050	500	15000,0
3a	3a-n	115	1,0	500	15000,0
da	da-dn	115	3,0	500	15000,0

Fig. 1. Nameplates of tested voltage transformer




Fig. 2. Arrangement of thermocouples during temperature-rise test:  
1 - oil; 2 - under the flange of tank lid; 3 - lower tank (placed inside over earthing terminal).

Table No. 1. Test results of voltage transformer EMF-E145, serial No. 1HSE8851772

Parameter	Heating time [h]												
	Stage No. 1						Stage No. 2						
	0	1	2	3	4	5	6	7	8	9	10	11	12
$U_n$ , kV	100.5												
$I_n$ , mA	159												
$\Delta T$ thermocouple No. 1, K	8.9	8.9	8.9	8.9	8.9	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4
$\Delta T$ thermocouple No. 2, K	0	-0.07	0.10	0.52	0.81	2.01	3.02	3.38	4.15	4.48	4.90	5.26	5.54
$\Delta T$ thermocouple No. 3, K	0	-0.02	0.60	1.05	1.36	2.77	3.81	4.61	5.22	5.74	6.08	6.39	6.67
$t_{w, \text{°C}}$	18.94	18.95	19.13	19.43	19.49	19.48	19.51	19.52	19.73	19.72	19.58	19.54	19.58
$R_{\text{w, m}\Omega}$	53.19	53.75	53.93	54.07	55.07	55.50	55.63	56.09	56.29	56.47	56.62	56.72	56.72
$R_{\text{sh, m}\Omega}$	33.55	33.70	33.80	33.89	34.50	34.74	34.93	35.07	35.20	35.31	35.39	35.44	35.44
$R_{\text{sh, k}\Omega}$	18.03	18.08	18.13	18.21	18.23	18.58	18.75	18.91	19.00	19.06	19.13	19.21	19.28
$\Delta T_{\text{w, m}\Omega}$	0	1.49	2.63	3.47	4.14	8.80	10.84	12.41	13.61	14.56	15.40	16.09	16.55
$\Delta T_{\text{sh, m}\Omega}$	0	1.51	2.64	3.24	4.07	8.64	10.44	11.87	12.89	13.89	14.67	15.31	15.68
$\Delta T_{\text{w, k}\Omega}$	0	1.75	2.91	3.77	4.40	9.33	11.33	12.82	13.92	14.89	15.69	16.27	16.71
$\Delta T_{\text{sh, k}\Omega}$	0	0.69	1.39	2.50	2.77	7.68	9.98	12.20	13.45	14.28	15.25	16.36	17.23

Table No. 2. Temperature-rises given during the tests voltage transformer EMF-E145 serial No. 1HSE8851772

Stage No. 1	Temperature rise $\Delta T$ [K]	Limit [K]
Windings	1a-1n	4.14
	2a-2n	4.27
	3a-3n	4.07
	da-dn	4.40
	A-N	2.77
Thermocouple No. 1	Oil	0.81
Thermocouple No. 2	Under the flange of tank lid	1.36
	Enclosure of lower tank	0.74
		55 <sup>1)</sup>
		40 <sup>2)</sup>

Table No. 2. cont.

Stage No. 2	Description	Temperature rise $\Delta T$	Limit
		[K]	[K]
Windings	1a-1n	16,55	65+10 <sup>1)</sup>
	2a-2n	16,64	
	3a-3n	15,68	
	da-dn	16,71	
	A-N	17,33	
Thermocouple No. 1	Oil	5,54	55+10 <sup>1)</sup>
Thermocouple No. 2	Under the flange of tank lid	6,67	40 <sup>2)</sup>
Thermocouple No. 2	Enclosure of lower tank	4,75	

1) acc. to IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2

2) acc. to IEC 62271-1

6. Summary


Results of temperature-rise test of tested voltage transformer type EMF-EI45 are as follows:

- in steady state, at the rated load of secondary voltage windings (without residual winding) and supply voltage 1,2U<sub>n</sub> (Stage No. 1), permitted temperature-rise limits were not exceeded.

- results of test 8 h at supply voltage 1,9U<sub>n</sub> and rated load of voltage windings and load of residual winding with thermal limiting output (Stage No. 2), shows that permitted temperature-rise limits were not exceeded.

The tested voltage transformer met requirements of IEC 61869-1:2007 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3:2011 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 62271-1:2007 standards.



7. Photographic documentation




Photograph No. 1. Voltage transformer on the test stand during temperature-rise test





<b>ABB</b>	Declaration of conformity	ABB Sp. z o.o. Dept. in Przasnysz POLAND
<b>DECLARATION OF CONFORMITY No. 104/2015 (EN)</b> (acc. to ISO/IEC 17050-1)		
Manufacturer:	ABB	
Product:	Voltage Instrument Transformer EMF-E145	
Above mentioned product conforms with the following standard :		
Standard	Title	Edition/Date
IEC 61869 - 3	Voltage Instrument Transformers	2015
Additional information:		
Serial numbers: 1HSE8851772;		
Place and date of issue of declaration		
Przasnysz 28.10.2015		
 Krzysztof Lubacki (Signature)		 Krzysztof Lubacki (Signature)



372





**INSTYTUT ENERGETYKI**  
**INSTITUTE OF POWER ENGINEERING**  
**LABORATORIUM WIELKOPRĄDOWE**  
**HIGH CURRENT LABORATORY**

address: ul. Mory 8  
 01-530 Warszawa, Poland  
 phone/fax: +48 22 836 80 16  
 e-mail: ewp@ipen.com.pl  
 www.ipen.com.pl/ewp

**INSTITUTE OF POWER ENGINEERING**  
**HIGH CURRENT LABORATORY**

Test Report No.  
**EWP/52/E/2015-4**

**TEST REPORT NO.**  
**EWP/52/E/2015-4**

**TEST OBJECT:** Voltage transformer type EMF-E145

**MANUFACTURER:** ABB Sp. z o.o.  
 ul. Leszno 59  
 06-300 Przasnysz, Poland

**TESTS ORDERED BY:** ABB Sp. z o.o.  
 ul. Żegalska 1  
 04-713 Warszawa, Poland  
 Order No. 4500678261 dated 15.09.2015

**TYPE OF TESTS:** Temperature-rise test

**TESTS PROCEDURE:** IEC 61869-1:2007, IEC 61869-3:2011

**OBJECT DELIVERED:** 12.11.2015

**DATE OF TESTS:** 17.11.2015

**TESTS RESULTS:** Positive

**THE TESTS WERE WITNESSED BY:**

Authorised by  
**TEST ENGINEER:**  
 Grzegorz Zaboklicki M.Sc. Eng.  
*Grzegorz Zaboklicki*

Approved by  
**HEAD OF LABORATORY:**  
 Maciej OWSIŃSKI M.Sc. Eng.  
*Maciej Owsinski*

Warsaw, 18.11.2015

This result is valid only for the test object.  
 The Test Report cannot be used and beyond the scope of accreditation (details in sub-cl. 4)  
 Publishing or reproducing of full report in other version than issued complete without written permission of laboratory is forbidden

Contents	
1.	Description of the test object
2.	Technical data declared by the Manufacturer
3.	Technical documentation of the test object
4.	Scope of the tests
5.	Tests and their results
6.	Summary
7.	Photographic documentation

Report contains 13 numbered pages with:	
2	Drawings
1	Photographs
2	Appendices

1. Description of the test object	
Test object	Voltage transformer
Type	EMF-E145
Serial number	IHSE8851773
Manufacturer	ABB Sp. z o.o.
Year of production	2015
Insulator	Porcelain insulator
Number of windings	4
Oil type	L-NTIO-296
Temperature range	-40°C - +40°C
Insulating oil weight	80 kg
Total weight	296 kg
Dimensions	According to appendix No.1 IHSE8851773
The laboratory made the identification of test objects basing on documentation given in sub-cl. 3. The test object is shown in the photographs No. 1. The object was prepared for tests by the Manufacturer.	

**2. Technical data declared by the Manufacturer**

Rated voltage [kV]	145 $\sqrt{3}$			
Maximum operating voltage [kV]	145			
Rated frequency [Hz]	50			
Voltage factor and time	1.9U <sub>n</sub> /8h			
Winding	1a-1n	2a-2n	3a-3n	da-dn
Rated secondary voltage [V]	115 $\sqrt{3}$	115 $\sqrt{3}$	115 $\sqrt{3}$	115
Rated output [VA]	25	25	25	500
Accuracy class	0.1	1.0	0.1	3P
Thermal limiting output [VA]	1500	1500	1500	450

3. Technical documentation of the test object			
1.	Drawing No. IHSE8851773 – Voltage Transformer EMF-E145 PROTOTYPE II; ABB Sp. z o.o., approved 03.11.2015 – Appendix No. 1		
2.	Declaration of Conformity No. 102/2015 (EN) ; ABB Sp. z o.o., Przasnysz, 29.10.2015 – Appendix No. 2		
4. Scope of the tests			
Test program agreed with Orderer comprised of following tests:			
No.	Kind of test	Tests according the Standard	Location of the test
1.	Temperature-rise tests	IEC 61869-1:2007 sub-cl. 6.4.1 and 7.2.2 IEC 61869-3:2011 sub-cl. 6.4.1 and 7.2.2 IEC 62271-1:2007, table No. 3	EWP
EWP The test was performed in Institute of Power Engineering, by High - Current Laboratory.			



**5. Tests and their results**

Voltage transformer was installed at the test stand, as it would be during normal operation. Electric diagram of terminal box of tested voltage transformer is given in Fig. 1. The rated voltage with a required value was applied to the primary voltage winding. The secondary voltage windings and the residual voltage winding were loaded with the suitable power, according to the test program given below. This program was agreed with the Orderer.

The arrangement of the thermocouples is given in Fig. 2. The temperature-rises of windings were measured by the resistance rise method. During the test, the measurements of loaded windings were made every 1-hour. The abstract of the protocol of temperature-rise test is given in Table No. 1. The summary of test results is given in Table No. 2.

The temperature-rise of windings were calculated from the follow formula:

$$\Delta T = \frac{R}{R_0} \alpha \frac{R_1 - R_0}{R_0} \cdot 0,004$$

**Stage No. 1: Test with thermal limiting output.**

Test was performed according to the IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2. The voltage value  $U_n = 83,7$  kV was applied to the A terminal. The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow$  1500 VA,  $\cos\phi = 1$ , at the voltage 115/√3 V; 2a-2n  $\Rightarrow$  1500 VA,  $\cos\phi = 1$ , at the voltage 115/√3 V; 3a-3n  $\Rightarrow$  1000 VA,  $\cos\phi = 1$ , at the voltage 115/√3 V.

The winding of residual voltage was opened.

The test was performed till reached steady state of the measured temperatures.

**Stage No. 2: Test with thermal limiting output**

Test was done immediately after the Stage No. 1 according to the IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2. The voltage value  $U_n = 83,7$  kV was applied to the A terminal.

The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow$  1500 VA,  $\cos\phi = 1$ , at the voltage 115/√3 V; 2a-2n  $\Rightarrow$  1500 VA,  $\cos\phi = 1$ , at the voltage 115/√3 V; 3a-3n  $\Rightarrow$  1500 VA,  $\cos\phi = 1$ , at the voltage 115/√3 V.

The winding of residual voltage was opened.

The test was performed till reached steady state of the measured temperatures.



**Stage No. 3: Test with thermal limiting output**

Stage no. 3 was started after three hours break from Stage No. 2. Test was done according to the IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2. The voltage value  $U_n = 83,7$  kV was applied to the A terminal.

The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow$  2400 VA,  $\cos\phi = 1$ , at the voltage 115/√3 V;

The other windings were opened.

The test was performed till reaching the steady state of the measured temperatures.

**Measuring equipment**

The temperatures were measured by means of type K thermocouples (NiCr - NiAl) with accuracy  $\pm 0,6^\circ\text{C}$ . The ambient temperature was measured using four thermocouples type K immersed into tank filled with oil. These thermocouples were placed in the distance of 1 meter from the tested transformer at the height of 1 meter above floor - the accuracy of measurement  $\pm 0,6^\circ\text{C}$ . The resistance was measured by means of meter type 2291 manufactured by TETTEX Instruments with accuracy  $\pm 0,01$  mΩ.

**ABB** **CE**

ABB AB Type 190T-E145 Production year 2007  
Voltage transformer IISSE minimum 14500/0,35 kV  
Serial number 237 750 kV Frequency 50 Hz  
Insulation level 145 kV Temperature range -40...+40 °C  
Rated primary voltage 145 kV  
Highest voltage for equipment 175 kV

Made in Sweden  
IEC 61869-3  
-40...+40 °C  
-40...250 kg

145E 61869-3

ABB AB Type 190T-E145 Production year 2007  
Voltage transformer IISSE minimum 14500/0,35 kV  
Serial number 237 750 kV Frequency 50 Hz  
Insulation level 145 kV Temperature range -40...+40 °C  
Rated primary voltage 145 kV  
Highest voltage for equipment 175 kV

Made in Sweden  
IEC 61869-3  
-40...+40 °C  
-40...250 kg

145E 61869-3

Terminal	Voltage V	Class	Burden VA	Total burden VA	Thermal limit VA
1a-1n	115/√3	0,1	25	25	1500
2a-2n	115/√3	0,1	25	25	1500
3a-3n	115/√3	0,1	25	25	1500
4a-4n	115/√3	0,1	25	25	1500
5a-5n	115/√3	0,1	25	25	1500
6a-6n	115/√3	0,1	25	25	1500
7a-7n	115/√3	0,1	25	25	1500
8a-8n	115/√3	0,1	25	25	1500
9a-9n	115/√3	0,1	25	25	1500
10a-10n	115/√3	0,1	25	25	1500
11a-11n	115/√3	0,1	25	25	1500
12a-12n	115/√3	0,1	25	25	1500
13a-13n	115/√3	0,1	25	25	1500
14a-14n	115/√3	0,1	25	25	1500
15a-15n	115/√3	0,1	25	25	1500
16a-16n	115/√3	0,1	25	25	1500
17a-17n	115/√3	0,1	25	25	1500
18a-18n	115/√3	0,1	25	25	1500
19a-19n	115/√3	0,1	25	25	1500
20a-20n	115/√3	0,1	25	25	1500
21a-21n	115/√3	0,1	25	25	1500
22a-22n	115/√3	0,1	25	25	1500
23a-23n	115/√3	0,1	25	25	1500
24a-24n	115/√3	0,1	25	25	1500
25a-25n	115/√3	0,1	25	25	1500
26a-26n	115/√3	0,1	25	25	1500
27a-27n	115/√3	0,1	25	25	1500
28a-28n	115/√3	0,1	25	25	1500
29a-29n	115/√3	0,1	25	25	1500
30a-30n	115/√3	0,1	25	25	1500
31a-31n	115/√3	0,1	25	25	1500
32a-32n	115/√3	0,1	25	25	1500
33a-33n	115/√3	0,1	25	25	1500
34a-34n	115/√3	0,1	25	25	1500
35a-35n	115/√3	0,1	25	25	1500
36a-36n	115/√3	0,1	25	25	1500
37a-37n	115/√3	0,1	25	25	1500
38a-38n	115/√3	0,1	25	25	1500
39a-39n	115/√3	0,1	25	25	1500
40a-40n	115/√3	0,1	25	25	1500
41a-41n	115/√3	0,1	25	25	1500
42a-42n	115/√3	0,1	25	25	1500
43a-43n	115/√3	0,1	25	25	1500
44a-44n	115/√3	0,1	25	25	1500
45a-45n	115/√3	0,1	25	25	1500
46a-46n	115/√3	0,1	25	25	1500
47a-47n	115/√3	0,1	25	25	1500
48a-48n	115/√3	0,1	25	25	1500
49a-49n	115/√3	0,1	25	25	1500
50a-50n	115/√3	0,1	25	25	1500
51a-51n	115/√3	0,1	25	25	1500
52a-52n	115/√3	0,1	25	25	1500
53a-53n	115/√3	0,1	25	25	1500
54a-54n	115/√3	0,1	25	25	1500
55a-55n	115/√3	0,1	25	25	1500
56a-56n	115/√3	0,1	25	25	1500
57a-57n	115/√3	0,1	25	25	1500
58a-58n	115/√3	0,1	25	25	1500
59a-59n	115/√3	0,1	25	25	1500
60a-60n	115/√3	0,1	25	25	1500
61a-61n	115/√3	0,1	25	25	1500
62a-62n	115/√3	0,1	25	25	1500
63a-63n	115/√3	0,1	25	25	1500
64a-64n	115/√3	0,1	25	25	1500
65a-65n	115/√3	0,1	25	25	1500
66a-66n	115/√3	0,1	25	25	1500
67a-67n	115/√3	0,1	25	25	1500
68a-68n	115/√3	0,1	25	25	1500
69a-69n	115/√3	0,1	25	25	1500
70a-70n	115/√3	0,1	25	25	1500
71a-71n	115/√3	0,1	25	25	1500
72a-72n	115/√3	0,1	25	25	1500
73a-73n	115/√3	0,1	25	25	1500
74a-74n	115/√3	0,1	25	25	1500
75a-75n	115/√3	0,1	25	25	1500
76a-76n	115/√3	0,1	25	25	1500
77a-77n	115/√3	0,1	25	25	1500
78a-78n	115/√3	0,1	25	25	1500
79a-79n	115/√3	0,1	25	25	1500
80a-80n	115/√3	0,1	25	25	1500
81a-81n	115/√3	0,1	25	25	1500
82a-82n	115/√3	0,1	25	25	1500
83a-83n	115/√3	0,1	25	25	1500
84a-84n	115/√3	0,1	25	25	1500
85a-85n	115/√3	0,1	25	25	1500
86a-86n	115/√3	0,1	25	25	1500
87a-87n	115/√3	0,1	25	25	1500
88a-88n	115/√3	0,1	25	25	1500
89a-89n	115/√3	0,1	25	25	1500
90a-90n	115/√3	0,1	25	25	1500
91a-91n	115/√3	0,1	25	25	1500
92a-92n	115/√3	0,1	25	25	1500
93a-93n	115/√3	0,1	25	25	1500
94a-94n	115/√3	0,1	25	25	1500
95a-95n	115/√3	0,1	25	25	1500
96a-96n	115/√3	0,1	25	25	1500
97a-97n	115/√3	0,1	25	25	1500
98a-98n	115/√3	0,1	25	25	1500
99a-99n	115/√3	0,1	25	25	1500
100a-100n	115/√3	0,1	25	25	1500

145E 61869-3

Fig. 1. Nameplates of tested voltage transformer

1. The expanded uncertainty assigned corresponds to a coverage probability of 95 % and the coverage factor k = 2.

375

Parameter	Sarge No. 1										Sarge No. 2										Sarge No. 3									
	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24					
U <sub>L</sub> KV	44.8	44.8	44.9	44.8	44.7	44.8	44.8	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9	44.9					
I <sub>sc</sub> mA	19.08	19.01	19.18	19.33	19.42	19.49	19.72	19.56	19.63	19.66	19.73	19.78	19.84	19.85	19.86	19.84	19.80	19.80	19.80	19.80	19.80	19.80	19.80	19.80	19.80					
R <sub>sc</sub> mΩ	52.90	56.56	57.35	58.31	58.84	59.29	59.67	59.89	58.16	58.42	58.56	58.70	60.47	61.07	61.37	61.61	61.73	61.83	61.97	62.11	62.25	62.39	62.53	62.67	62.81					
R <sub>sc</sub> mΩ	51.58	55.07	55.80	56.69	57.18	57.61	57.96	58.16	58.42	58.56	58.70	60.47	61.07	61.37	61.61	61.73	61.83	61.97	62.11	62.25	62.39	62.53	62.67	62.81	62.95					
R <sub>sc</sub> mΩ	33.10	35.08	35.51	36.01	36.29	36.51	36.72	36.85	37.00	37.09	37.17	37.23	37.28	37.33	37.38	37.43	37.48	37.53	37.58	37.63	37.68	37.73	37.78	37.83	37.88					
R <sub>sc</sub> mΩ	144.72	153.43	155.41	157.74	158.70	159.87	160.77	161.33	161.96	162.38	162.72	162.93	163.14	163.35	163.56	163.77	163.98	164.19	164.40	164.61	164.82	165.03	165.24	165.45	165.66					
R <sub>sc</sub> mΩ	17.94	18.72	19.18	19.71	20.12	20.38	20.52	20.61	20.76	20.86	20.92	21.19	21.40	21.58	21.72	21.82	21.89	21.95	22.01	22.07	22.13	22.19	22.25	22.31	22.37					
R <sub>sc</sub> mΩ	17.27	21.04	25.54	28.07	30.21	31.99	33.04	34.34	35.06	35.78	36.48	37.16	37.82	38.47	39.11	39.74	40.26	40.76	41.25	41.73	42.19	42.67	43.14	43.61	44.08					
ΔT <sub>sc</sub>	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
ΔT <sub>sc</sub>	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
ΔT <sub>sc</sub>	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
ΔT <sub>sc</sub>	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
I <sub>sc</sub> A	21.49	21.48	21.44	21.43	21.46	21.45	21.48	21.48	21.50	21.50	21.50	21.50	21.47	21.41	21.41	21.40	21.43	21.40	21.40	21.40	21.40	21.40	21.40	21.40	21.40					
I <sub>sc</sub> A	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29	21.29					
I <sub>sc</sub> A	14.47	14.47	14.46	14.43	14.44	14.44	14.44	14.44	14.44	14.44	14.44	14.44	14.43	14.43	14.43	14.43	14.43	14.43	14.43	14.43	14.43	14.43	14.43	14.43	14.43					
I <sub>sc</sub> mA	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8					

**INSTITUTE OF POWER ENGINEERING  
HIGH CURRENT LABORATORY**

Test Report No. EWP/52/E/2015-4




Fig. 2. Arrangement of thermocouples during temperature-rise test:  
1- oil; 2- under the flange of tank lid; 3- lower tank (placed inside over earthing terminal).

**INSTITUTE OF POWER ENGINEERING  
HIGH CURRENT LABORATORY**

Test Report No. EWP/52/E/2015-4

**Table No. 2. Temperature-rises [K] given during the tests voltage transformer EMF-E145 serial No. 1HSE851773**

Winding	Stage No. 1		Stage No. 2		Stage No. 3		$\Delta T_{per}$
	$\Delta T$ after	$\Delta T$ after	$\Delta T$ after	$\Delta T$ after	$\Delta T$ after	$\Delta T$ after	
1a-1n	35,78	42,87	36,31				
2a-2n	34,51	41,34	34,51				
3a-3n	30,71	36,97	30,42				65 <sup>1)</sup>
da-dn	31,10	38,07	31,20				
A-N	41,53	55,05	34,70				

Thermocouple No.	Stage No. 1		Stage No. 2		Stage No. 3		$\Delta T_{per}$
	$\Delta T$ after	$\Delta T$ after	$\Delta T$ after	$\Delta T$ after	$\Delta T$ after	$\Delta T$ after	
1	6,80	8,80	7,17				55 <sup>1)</sup>
2	6,35	8,08	6,20				40 <sup>2)</sup>
3	4,62	5,81	4,50				

<sup>1)</sup> acc. to IEC 61869-1 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3 sub-cl. 6.4.1, sub-cl. 7.2.2  
<sup>2)</sup> acc. to IEC 62271-1  
 $\Delta T$  - temperature-rise [K];  $\Delta T_{per}$  - permitted value in steady state [K]

**Table No. 3. Power losses in windings**

Winding	Stage No. 1			Stage No. 2			Stage No. 3		
	R [m $\Omega$ ]	I [A]	P <sub>20</sub> [W]	R [m $\Omega$ ]	I [A]	P <sub>20</sub> [W]	R [m $\Omega$ ]	I [A]	P <sub>20</sub> [W]
1a-1n	60,47	21,5	24,5	61,97	21,4	24,4	60,59	34,4	62,9
2a-2n	58,70	21,1	23,0	60,11	21,1	22,9	-	-	-
3a-3n	37,17	14,4	6,9	38,00	21,5	15,4	-	-	-
A-N	20,92	44,9	36,4	21,89	50,2	45,5	20,43	27,2	13,3


P<sub>20</sub> - power losses calculated for temperature 20°C

**6. Summary**


Results of temperature-rise test of tested voltage transformer type EMF-E145 are as follow:

- Results of test with thermal limiting output for Stage No. 1 described in sub-cl. 5 of this Test Report: permitted temperature-rise limits were not exceeded;
- Results of test with thermal limiting output for Stage No. 2 described in sub-cl. 5 of this Test Report: permitted temperature-rise limits were not exceeded;
- Results of test with thermal limiting output for Stage No. 3 described in sub-cl. 5 of this Test Report: permitted temperature-rise limits were not exceeded;

The tested voltage transformer met requirements of IEC 61869-1:2007 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 61869-3:2011 sub-cl. 6.4.1, sub-cl. 7.2.2 and IEC 62271-1:2007 standards.




6. Photographic documentation





Photograph No. 1. Voltage transformer on the test stand during temperature-rise test

Appendix No. 1





Appendix No. 2

<b>ABB</b>	Declaration of conformity	ABB Sp. z o.o. Dept. in Przasnysz POLAND
<p><b>DECLARATION OF CONFORMITY No. 102/2015 (EN)</b> (acc. to ISO/IEC 17060-1)</p>		
Manufacturer: ABB		
Product: Voltage Instrument Transformer EMF-E145		
Above mentioned product conforms with the following standard :		
Standard IEC 61869 - 3	Title Voltage Instrument Transformers	Edition/Date 2015
Additional information: Serial numbers: 1HSE8851773;		
Place and date of issue of declaration Przasnysz, 29.10.2015		
 Krzysztof Lubbecki Przesnysz, z o.o. Politechniki	 Krzysztof Lubbecki Przasnysz, z o.o. Oddzial w Przasnyszu	( Signature )

*Handwritten mark*

*Handwritten signature*

*Handwritten mark*

374





<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB008898
Issued by department ZCCO/Poland/SST	Limit English	Revision 1.0
Customer ABB PLABB	Issue date 2015-05-25	Classification Confidential
Doc. title Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level.	Status of document Released	
Project name/ID SST activities - BU9953 - CHTET / 50005877	CR Program CHTET	
Main Author Grzegorz Juszkiewicz/PLCRC/SST	Case ID 15101	
Additional Author(s) Marcin Tarnowski/PPHV, Pawel Goyczal/PLHV, Jaroslaw Duzdowski/PPHV, Dariusz Siperek/PPHV, Piotr Mikulski/PPHV, Przemyslaw Nasierowski/PPHV, Piotr Saj/PLCRC, Marek Florowski/PLCRC		
Keywords simulation, FE method, seismic analysis, frequency modes, response spectrum		
Approved by Marek Florowski/PLCRC	Final Approval Date 2015-05-21	
Technical_Note.doc Rev. 1.00		

Electronic document  
**Technical report**

Simulation Support Team

Case submitted by	Marcin Tarnowski
Business Unit	PPHV
Type of analysis (used tool)	ABAQUS (seismic analysis)
Description of analysis	Seismic analysis different variants of current, voltage and combined transformers (PA123a / PA145a, PV123, PVA123a / PVA145a) according to guidelines described in IEC standard. Consideration of seismic, wind, and dead loads.

**Executive summary**

This report covers investigation related to seismic analysis of HV instrument transformers (PV123, PA123a / PA145a, PVA123a / PVA145a) subjected to various load scenarios. Simulation covered the following load conditions: dead load, wind load, terminal force load, seismic load (AF5 - 0.5 g). Analysis showed that all designs are satisfying required safety criteria.

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB008898
Doc. title Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	Revision 1.0	Page 2/37

**TABLE OF CONTENTS**

1	INTRODUCTION	4
2	SIMULATION SOFTWARE	4
3	SIMULATION SETUP	4
3.1	SIMULATION PROCEDURE	4
3.2	SIMULATION STEPS	4
3.2.1	Natural frequency extraction	4
3.2.2	Response spectrum analysis	5
3.3	LOADS AND BOUNDARY CONDITIONS	6
3.3.1	Loads	6
3.3.2	Boundary conditions	6
3.4	ACCEPTANCE CRITERIA	7
3.5	CURRENT TRANSFORMER - PA 123A/PA 145A	8
3.5.1	Model simplifications	8
3.6	MATERIAL AND MASS INFORMATION	8
3.7	FINITE ELEMENT (FE) MODEL	10
3.8	VOLTAGE TRANSFORMER - PV 123	11
3.8.1	Model simplifications	11
3.9	MATERIAL AND MASS INFORMATION	11
3.10	FINITE ELEMENT (FE) MODEL	13
3.11	COMBINED TRANSFORMER - PVA123A/PVA145A	14
3.11.1	Model simplifications	14
3.12	MATERIAL AND MASS INFORMATION	14
3.13	FINITE ELEMENT (FE) MODEL	17
4	SIMULATION RESULTS	18
4.1	PA123A/PA145A	18
4.1.1	Natural frequency extraction	18
4.1.2	Dynamic analysis	20
4.2	PV 123	24
4.2.1	Natural frequency extraction	24
4.2.2	Dynamic analysis	26
4.3	PVA123A/PVA145A	29
4.3.1	Natural frequency extraction	29
4.3.2	Dynamic analysis	30
5	CONCLUSIONS	33
6	BIBLIOGRAPHY	34
7	CHANGE HISTORY	34
8	APPENDICES	35

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

<b>ABB</b> Doc. title	<b>ZCCO</b> Corporate Research	<b>9ADB008898</b>	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		1.0	3/37
8.1	CURRENT INSTRUMENT TRANSFORMER PA123A/PA145A		35
8.2	VOLTAGE INSTRUMENT TRANSFORMER PV123		36
8.3	COMBINED INSTRUMENT TRANSFORMER PVA123A/PVA145A		37

<b>ABB</b> Doc. title	<b>ZCCO</b> Corporate Research	<b>9ADB008898</b>	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		1.0	4/37

## 1 INTRODUCTION

The goal of the analysis was to evaluate seismic performance of PA123a /PA145a (see 8.1), PV123 (see 8.2), PVA145a/PVA123a (8.3) type transformers. Simulation was done using guidelines of IEC TR 62271-300 standard. For more information please see [1].

Computations concerned evaluation of stress field distribution and maximum bending moment between flange and insulator. Present report describes used simulation technique, analysis steps, loads and boundary conditions variations and summarizes obtained results.

## 2 SIMULATION SOFTWARE

All simulations were performed using Abaqus/CAE package. Abaqus includes FEM (finite element method) solver, pre- and post processor and enables performing many types of multiphysics simulations: mechanical, thermal, acoustic, piezoelectric, seismic, and others.

Parts and assemblies can be created in Abaqus, or they can be imported from CAD systems using native file formats. Abaqus functionality enables to define materials, interactions, loads, boundary conditions, mesh. User is also available to set up simulation parameters such as pre-processing memory. It is always possible to change all simulation settings and properties, because they're all parameterized.

Simulation results can be visualized in Abaqus postprocessor or in external software, which is able to import simulation results in Abaqus format. In postprocessor user can view all predefined field outputs, show or hide part instances, create cross-sections, make animations, automatically generate reports, diagnose model (warnings, errors). For more information about ABAQUS please see [2].

## 3 SIMULATION SETUP

Analysis has been made using Finite Element Method.

### 3.1 Simulation procedure

According to [1] analysis included three main simulation steps:

- Static load:
  - Wind load.
  - Terminal load.
  - Gravitational load.
- Natural frequency extraction.
- Dynamic analysis.

### 3.2 Simulation steps

Simulation consisted of three main simulation steps.

#### 3.2.1 Natural frequency extraction

In the first simulation step natural frequency extraction was performed. The frequency extraction procedure performs eigenvalue extraction to calculate the natural frequencies and the corresponding mode shapes of a system.

The eigenvalue problem for the natural frequencies of an undamped finite element model can be described by equation (3-1):

$$(-\omega^2 M^{MN} + K^{MN})\phi = 0 \quad (3-1)$$

where:  $M^{MN}$  – mass matrix (kg);  $K^{MN}$  – stiffness matrix (Pa), which includes initial stiffness effects if the base state (gravitational load);  $\phi$  – eigenvector (the mode of vibration);  $M, N$  – degrees of freedom (-). Based on specification [1] one can assume that most critical frequency modes are in range of 0-35 Hz.

### 3.2.2 Response spectrum analysis

The response spectrum method is a convenient way of describing shock motion in terms of the maximum response of a single degree of freedom (1-DOF) oscillator of arbitrary natural period and damping ratio. Each data point of the response spectrum curve represents the peak response from a time history analysis of the earthquake applied to 1-DOF oscillator system. The ordinate defines the natural period at which the oscillator is tuned. Repeating the procedure for a great many frequencies defines a continuous curve for an assumed level of damping.

A spectral response analysis estimates the maximum displacement of the structure during a 'design' shock load without recourse of direct integration. Finite element implementation of the response spectrum calculate the response of each mode independent, and then combine the scaled response one of a number of established combination rules, to give an estimate of peak response. Spectrum plot used in simulation is presented in Figure 1.




Figure 1. Design response spectrum – 2% damping (red curve)

### 3.3 Loads and boundary conditions

#### 3.3.1 Loads

The following static load scenarios have been considered

1. Gravitational load,  $g=9.81 \text{ m/s}^2$ .
2. Terminal operating load, acc. to [3]. According to Table 14, page 90 terminal force are adequate to rated voltage and current level. Applied force values were the following:
  - a. PA123a (PA145a): Longitudinal force-1250 N, Transversal force – 1000 N, Vertical force – 1250 N.
  - b. PV123: Longitudinal force-1750 N, Transversal force – 1250 N, Vertical force – 1500 N.
  - c. PVA123a/PVA145a: Longitudinal force-1750 N, Transversal force – 1250 N, Vertical force – 1500 N.
3. Wind load, 10m/s load. Wind load has been represented as directional pressure evaluated according to drag force equation:

$$F_D = \frac{1}{2} \rho u^2 C_{DA} \quad (3-1)$$

where:  $F_D$  – drag force [N],  $\rho$  – mass density of the fluid [ $\text{kg/m}^3$ ],  $u$  – flow velocity [m/s],  $A$  – reference area [ $\text{m}^2$ ],  $C_D$  – drag coefficient [-].

Evaluated pressure level for all designs was ca.  $p=71 \text{ Pa}$ .

Seismic load have been predefined according design response spectrum described in the standard [1] – ground acceleration reference AF5. Main input parameters were the following:

- XZ base motion with vertical load equal to 50% of horizontal direction.
- YZ base motion with vertical load equal to 50% of horizontal direction.
- Damping ratio – 2% ([1], page 23, chapter 7.3.2 point b).

As the final outcome from the analysis static loads were combined with the most conservative seismic load.


#### 3.3.2 Boundary conditions

Simulation assumes that the apparatus will be mounted on ground. An example of boundary conditions is presented in

During analysis model has been fixed at the bottom face of used test frame. General view of static loads and boundary conditions is presented in Figure 2. Area highlighted in red has been constrained (Y-rotation released). Base of the bottom tank has been supported in Y direction (as it is placed on the ground). Described boundary conditions have been used for all analyzed models.

ms

383

 Doc. title	ZCCO Corporate Research	9ADB008898	Page
	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	Revision 1.0	7/37





Figure 2. Boundary conditions - general view

### 3.4 Acceptance criteria

According to [1] the following acceptance criteria shall be met

- Stresses observed at metallic parts should not exceed yield point of material.
  - The maximum bending moment of the insulator should not exceed ultimate value.
- For more information please refer to [4] (Table 1, page 23).

 Doc. title	ZCCO Corporate Research	9ADB008898	Page
	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	Revision 1.0	8/37

### 3.5 Current transformer - PA 123a/PA 145a

This chapter gathers details related to FE model of current transformer PA 123a/PA 145a.

#### 3.5.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 3. Red point indicates center of mass of the transformer.




Figure 3. Simplified representation of the PA 123a/PA 145a transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

### 3.6 Material and mass information

Component naming is presented in Figure 4.

384




Figure 4. Assembly – component naming

Material and mass information is listed in Table 1

Table 1. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKA310015	Base J123	EN-AC 43200 (grade F)	16.5	69000	80	160
2GKA310404	Insulator	Porcelain	71	100000	140	
	Insulator - Flange	EN-AC 43200 (grade TB)	3.5	69000	180	220
2GKA414718	Head	EN-AC 43200 (grade F)	22.5	69000	80	160
2GK314089	Head cover	EN-AC 43200 (grade F)	20	69000	80	160
	Coil		150			
2GK311093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
	Oil		120			

The maximum allowable bending moment for ceramic insulator is equal to  $M_B=13.3$  kNm.

### 3.7 Finite element (FE) model

General view of FE model is presented in Figure 5.




Figure 5. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 533430
- Total number of elements: 242886
  - 210555 quadratic tetrahedral elements of type C3D10
  - 31050 quadratic hexahedral elements of type C3D20R
  - 1243 quadratic quadrilateral elements of type S8R
  - 18 quadratic triangular elements of type STRI65

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

385

386

<b>ABB</b>	ZCCO Corporate Research	9ADB008898	Page
Doc. title			11/37
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level		Revision	1.0

### 3.8 Voltage transformer - PV 123

This chapter gathers details related to FE model of voltage transformer PV 123.

#### 3.8.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 6. Red point indicates center of mass of the transformer.




Figure 6. Simplified representation of the PV 123 transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

#### 3.9 Material and mass information

Component naming is presented in Figure 7.

<b>ABB</b>	ZCCO Corporate Research	9ADB008898	Page
Doc. title			12/37
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level		Revision	1.0





Figure 7. Assembly - component naming

Material and mass information is listed in Table 2.

Table 2. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKK310150P	Bottom tank	EN-AC 43200 (grade F)	25	69000	80	160
2GKK310147P	Core	Steel	22.5	206000	300	370
2GKV314005	Tank cover	EN-AC 43200 (grade F)	15.5	69000	80	160
2GKA310404	Insulator	Porcelain	71	100000	140	
	Insulator flange	EN-AC 43200 (grade TE)	3.5	69000	160	220
	Coil	-	30			
2GKK311093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
	Oil		60			

The maximum allowable bending moment for ceramic insulator is equal to  $M_B=13.3 \text{ kNm}$ .

	<b>ZCCO</b> Corporate Research	<b>9ADB008898</b>	Doc. title	Page
			Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level	13/37

### 3.10 Finite element (FE) model

General view of FE model is presented in Figure 8.





Figure 8. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 608507
- Total number of elements: 236033
  - 4606 quadratic quadrilateral elements of type S8R
  - 58 quadratic triangular elements of type STR165
  - 58965 quadratic hexahedral elements of type C3D20R
  - 8577 linear hexahedral elements of type C3D8R
  - 163827 quadratic tetrahedral elements of type C3D10

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

	<b>ZCCO</b> Corporate Research	<b>9ADB008898</b>	Doc. title	Page
			Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level	14/37

### 3.11 Combined transformer – PVA123a /PVA145a

This chapter gathers details related to FE model of combined transformer PVA123a /PVA145a.

#### 3.11.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 9. Red point indicates center of mass of the transformer.




Figure 9. Simplified representation of the PVA123a /PVA145a transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

#### 3.12 Material and mass information

Component naming is presented in Figure 7.

*[Handwritten signature]*

300

<b>ABB</b>	ZCCO Corporate Research	9ADB008898	Page 15/37
Doc. file	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		Revision 1.0




Figure 10. Assembly – component naming  
Material and mass information is listed in Table 3.

<b>ABB</b>	ZCCO Corporate Research	9ADB008898	Page 16/37
Doc. file	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		Revision 1.0

Table 3. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [NIPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKK314076	Tank	EN-AC 43200 (grade F)	25	69000	80	160
2GKK314084	Core	Steel	33.8	206000	300	370
2GKK314075	Tank cover	EN-AC 43200 (grade F)	18	69000	80	160
2GKK314070	Insulator	Porcelain	131	100000	140	
2GKK314080	Insulator flange	EN-AC 43200 (grade F)	5	69000	180	220
2GKK314080	Head	EN-AC 43200 (grade F)	23.5	69000	80	160
2GKK314089	Head cover PVA-PA123a /PA145a-145	EN-AC 43200 (grade F)	23	69000	80	160
2GKK310802	Bellow	Stainless steel	5	190000	200	500
2GKK310014P	Below enclosure	EN-AC 43200 (grade F)	7	69000	80	160
-	Voltage coil	-	30	-	-	-
-	Current coil	-	150	-	-	-
2GKK310802	Epoxy Insulator	-	2.5	-	-	-
2GKK311059R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
-	Oil	-	150	-	-	-

The maximum allowable bending moment for ceramic insulator is equal to  $M_B=13.3$  kNm.



### 3.13 Finite element (FE) model

General view of FE model is presented in Figure 11.




Figure 11. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 1009580
- Total number of elements: 463007
  - 58507 quadratic hexahedral elements of type C3D20R
  - 300489 quadratic tetrahedral elements of type C3D10
  - 2519 linear quadrilateral elements of type S4R
  - 97 linear triangular elements of type S3
  - 9900 linear hexahedral elements of type C3D8R
  - 528 quadratic wedge elements of type C3D15
  - 90967 quadratic tetrahedral elements of type C3D10M

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

## 4 SIMULATION RESULTS

This chapter gathers simulation results evaluated in the analysis. Obtained outcome includes static and the most conservative (design) seismic load.

### 4.1 PA123a /PA145a

#### 4.1.1 Natural frequency extraction

Effective modal mass plot is presented Figure 12. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 6.9 – 8.2 Hz.




Figure 12. Natural frequency extraction – effective modal mass  
Effective modes and associated with the shapes are presented in Figure 13.

*[Handwritten signature]*

*[Handwritten signature]*  
389




Figure 13. Natural frequency extraction - mode shapes  
 Summary of modal mass participation is listed in Table 4.

Table 4. Modal mass participation - summary

Mode no	Frequency [Hz]	X-direction	Y-direction	Z-direction
1	6.9	40%	0%	35%
2	8.2	34%	0%	40%
3	38.9	2%	0%	6%
4	39.7	6%	0%	2%
5	46.9	0%	0%	0%
6	98.7	0%	89%	0%
7	129.2	0%	0%	2%
8	150.3	4%	0%	0%
9	166.6	0%	0%	4%
10	167.4	2%	0%	0%

4.1.2 Dynamic analysis

Stress distribution for tank component is presented in Figure 14 and Figure 15. Stress scale has been limited to 80 MPa as the maximum allowable stress level.




Figure 14. Von-Mises stress [Pa] distribution - tank (view 01)




Figure 15. Von-Mises stress [Pa] distribution - tank (view 02)  
Displacement field is presented in Figure 16.




Figure 16. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x = 4848 \text{ Nm}$ .
- $M_z = 7476 \text{ Nm}$ .

Insulator has satisfied the maximum bending moment condition. One can observe that stresses evaluated at the base are slightly above yield point of material. Therefore small yielding may occur. One must have in mind that analysis did not cover possible casting imperfections. Design has been also verified according to AF3 seismic level (0.3 g Zero Period Acceleration). Stress distribution for such load scenario is presented from Figure 17 to Figure 18. Obtained stress level was significantly below yield point of material.

39A

	ZCCO Corporate Research	9ADB008898	Page
	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level	Revision 1.0	23/37

S. Mises	1.366E+03
(Avg: 75%)	1.001E+03
Min	6.000E+02
Max	3.000E+03
Min	1.000E+02
Max	1.000E+03




Figure 17. Von-Mises stress [Pa] distribution (AF3) – tank (View 01)

S. Mises	1.366E+03
(Avg: 75%)	1.001E+03
Min	6.000E+02
Max	3.000E+03
Min	1.000E+02
Max	1.000E+03




Figure 18. Von-Mises stress [Pa] distribution (AF3) – tank (View 02)

	ZCCO Corporate Research	9ADB008898	Page
	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level	Revision 1.0	24/37

4.2 PV 123

4.2.1 Natural frequency extraction

Effective modal mass plot is presented Figure 19. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 24.7–25.3 Hz




Figure 19. Natural frequency extraction – effective modal mass

Effective modes and associated with the shapes are presented in Figure 20.




Figure 20. Natural frequency extraction – mode shapes

Summary of modal mass participation is listed in Table 5.

Table 5. Modal mass participation – summary

Mode no.	Frequency [Hz]	X- direction	Y- direction	Z- direction
1	24.7	24%	0%	0%
2	25.2	0%	0%	24%
3	25.4	0%	0%	0%
4	26.5	0%	0%	0%
5	135.5	37%	0%	0%
6	139.3	0%	0%	36%
7	161.3	0%	34%	0%
8	162.4	0%	0%	0%
9	175.8	0%	0%	0%
10	176.2	0%	0%	0%

#### 4.2.2 Dynamic analysis

Stress distribution for tank component is presented in Figure 21 and Figure 22. As described in chapter 3.8.1 location of center of mass is close to the ground level, therefore expected bending moment and so the stress was low. One can see that the maximum stress level reached ca. 30 MPa and it was located at vicinity of coupling constraint. Stress level satisfies required safety condition.




Figure 21. Von-Mises stress [Pa] distribution – tank (view 01)

1	D. M. K.	27/37
2	11/11/2015	27/37
3	11/11/2015	27/37
4	11/11/2015	27/37
5	11/11/2015	27/37
6	11/11/2015	27/37
7	11/11/2015	27/37
8	11/11/2015	27/37
9	11/11/2015	27/37
10	11/11/2015	27/37
11	11/11/2015	27/37
12	11/11/2015	27/37
13	11/11/2015	27/37
14	11/11/2015	27/37
15	11/11/2015	27/37
16	11/11/2015	27/37
17	11/11/2015	27/37
18	11/11/2015	27/37
19	11/11/2015	27/37
20	11/11/2015	27/37
21	11/11/2015	27/37
22	11/11/2015	27/37
23	11/11/2015	27/37
24	11/11/2015	27/37
25	11/11/2015	27/37
26	11/11/2015	27/37
27	11/11/2015	27/37
28	11/11/2015	27/37
29	11/11/2015	27/37
30	11/11/2015	27/37
31	11/11/2015	27/37
32	11/11/2015	27/37
33	11/11/2015	27/37
34	11/11/2015	27/37
35	11/11/2015	27/37
36	11/11/2015	27/37
37	11/11/2015	27/37
38	11/11/2015	27/37
39	11/11/2015	27/37
40	11/11/2015	27/37
41	11/11/2015	27/37
42	11/11/2015	27/37
43	11/11/2015	27/37
44	11/11/2015	27/37
45	11/11/2015	27/37
46	11/11/2015	27/37
47	11/11/2015	27/37
48	11/11/2015	27/37
49	11/11/2015	27/37
50	11/11/2015	27/37




Figure 22. Von-Mises stress [Pa] distribution - tank (View 02)  
Displacement field is presented in Figure 23.




Figure 23. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x=2079 \text{ Nm}$ .
- $M_y=2263 \text{ Nm}$ .

Insulator has satisfied the maximum bending moment condition.

#### 4.3 PVA123a / PVA145a

##### 4.3.1 Natural frequency extraction

Effective modal mass plot is presented Figure 24. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 3.8– 4.1 Hz.




Figure 24. Natural frequency extraction – effective modal mass  
Effective modes and associated with the shapes are presented in Figure 25.




Figure 25. Natural frequency extraction – mode shapes

Summary of modal mass participation is listed in Table 6.

Table 6. Modal mass participation – summary

Mode no.	Frequency [Hz]	X- direction	Y- direction	Z- direction
1	3.8	35%	0%	32%
2	4.1	32%	0%	35%
3	22.4	7%	0%	0%
4	23.2	0%	2%	8%
5	26.5	0%	95%	0%
6	29.2	0%	0%	1%
7	29.3	1%	0%	0%
8	34.6	10%	0%	0%
9	35.5	0%	0%	8%
10	36.2	0%	0%	3%

##### 4.3.2 Dynamic analysis

Stress distribution for tank component is presented in Figure 26 and Figure 27. One can see that the maximum stress level reached ca. 70 MPa. Stress level satisfies required safety condition.

396

<b>ABB</b>	ZCCO Corporate Research	9ADB008898	Page
Doc. Title		Revision	
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		1.0	31/37




Figure 26. Von-Mises stress [Pa] distribution - tank (view 01)

Stress	0	100
Color	Blue	Red




Figure 27. Von-Mises stress [Pa] distribution - tank (view 02)  
Displacement field is presented in Figure 23.

<b>ABB</b>	ZCCO Corporate Research	9ADB008898	Page
Doc. Title		Revision	
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		1.0	32/37




Figure 28. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x = 6864 \text{ Nm}$ .
- $M_y = 7752 \text{ Nm}$ .

Insulator has satisfied the maximum bending moment condition.



<b>ABB</b> ABB	ZCCO Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	1.0	33/37

## 5 CONCLUSIONS

The goal of the analysis was to investigate family of HV Instrument Transformers using guidelines described in IEC 62271-300. Based on performed analysis main conclusions are the following:

- Current transformer PA 123a/PA 145a. This design has been investigated for two seismic levels: AF5 (0.5 g) and AF3 (0.3 g). For AF5 level stresses were above yield strength of material. These concentrations can be caused by sharp edges which are usually eliminated in real casting process. On the other hand one must have in mind that possible material imperfection were not considered in the simulation. For AF3 load scenario stresses were below yield strength of material. Bushing has satisfied required safety factor for both load scenarios.
- Voltage transformer - PV 123. Seismic level – AF5. Center of mass for this particular design is very close to the ground level. Therefore obtained level of stress and so bending moment was relatively low. Design satisfies required safety factors for AF5 seismic level.
- Combined transformer PVA 123a/PVA 145a. Seismic level – AF5. Obtained stress level was below yield strength of material. Bending moment was also below ultimate value. Whole design should be considered as safe.
- Damping factor used in the analysis was equal to 2%.
- Transformer oil has been modeled as uniformly distributed additional mass.

## Disclaimer

The analysis documented herein has been prepared in accordance with reasonable standards of scientific endeavor and the best knowledge of the author(s).  
The simulation results may depend on a variety of factors, including quality of input data, applied model simplifications and chosen numerical methods.

<b>ABB</b> ABB	ZCCO Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	1.0	34/37

## 6 BIBLIOGRAPHY

- [1] TR 62271-300 – High voltage switchgear and controigear – Part 300: Seismic qualification and alternating current circuit breakers, Technical report. First edition:2006-11
- [2] ABAQUS, ABAQUS 6.13 Documentation, DS Simulia, USA, [www.simulia.com](http://www.simulia.com)
- [3] IEC 62271-100 – High voltage switchgear and controigear – Part 100: Alternating-current circuit-breakers, Technical report. Edition 2.0: 2008-04
- [4] IEC 62155-100 – Hollow pressurized and unpressurized ceramic and glass insulators for use in electrical equipment with rated voltages greater than 1 000 V, International standard. First edition: 2003-05

## 7 CHANGE HISTORY


Date	Revision	Author(s)	Change
2015-05-22	Rev. 1	Juszkiewicz Grzegorz	original document

348

<b>ABB</b> Doc. title	ZCCO Corporate Research	9ADB008898	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level		Revision	35/37
		1.0	

8 APPENDICES


8.1 Current instrument transformer PA123a/PA145a



We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

<b>ABB</b> Doc. title	ZCCO Corporate Research	9ADB008898	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level		Revision	36/37
		1.0	

8.2 Voltage instrument transformer PV123



We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.



(

(

<b>ABB</b>	<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>
Issued by department ZCCO/Poland/SST	Last edit date 2015-08-17	Revision 1.0
Customer ABB PLABB	Language English	Classification Confidential
Project name Sismic analyses of HV Instrument Transformers. IEEC 693- high (0.5g)/moderate(0.25g) seismic level		
Doc. title	Status of document	Released
Project name ID Simserv_PPHV_Przasnyrz_15172/50005903	CR Project	CHTET
Main Author Grzegorz Juskiewicz/PLCRC/SST	Case ID	15172
Additional Author(s)	March Tarnowski/PPHV, Pawel Gnyzdar/PPHV, Jaroslaw Duzdowski/PPHV, Dariusz Siperek/PPHV, Piotr Mikulski/PPHV, Przemyslaw Nasterowski/PPHV Piotr Saj/PLCRC, Marek Florowski/PLCRC	
Classification	simulation, FE method, seismic analysis, frequency modes, response spectrum	
Keywords	Final Approval Date: 2015-08-17	
Approved by:	Technical Support Team	
Technical Support Team	2015-08-17	

Electronic document

# Technical report

Case submitted by	Marcin Tarnowski
Business Unit	PPHV
Type of analysis (used tool)	ABAQUS (seismic analysis)
Description of analysis	Seismic analysis different variants of current, voltage and combined transformers (PA123a/PA145a, PV123, PVA123a/PVA145a) according to guidelines described in IEEC 693 standard. Consideration of seismic and dead loads.

## Executive summary

This report covers investigation related to seismic analysis of HV Instrument transformers (PV123, PA123a/PA145a, PVA123a/PVA145a) subjected to various load scenarios. Simulation covered the following load conditions: dead load, terminal force load, seismic load (Moderate - 0.25g; High - 0.5g). Analysis showed that designs: PA123a/PA145a and PVA123a/PVA145a can withstand moderate seismic level, while PV123 can withstand high seismic load scenario.

<b>ABB</b>	<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>
Doc. title	Revision	Page
Sismic analyses of HV Instrument Transformers. IEEC 693- high (0.5g)/moderate(0.25g) seismic level	1.0	2/38

## TABLE OF CONTENTS

1 INTRODUCTION .....	4
2 SIMULATION SOFTWARE .....	4
3 SIMULATION SETUP .....	4
3.1 SIMULATION PROCEDURE .....	4
3.2 SIMULATION STEPS .....	4
3.2.1 Natural frequency extraction .....	4
3.2.2 Response spectrum analysis .....	5
3.3 LOADS AND BOUNDARY CONDITIONS .....	6
3.3.1 Loads .....	6
3.3.2 Boundary conditions .....	7
3.4 ACCEPTANCE CRITERIA .....	7
3.5 CURRENT TRANSFORMER - PA 123A/PA 145A .....	8
3.5.1 Model simplifications .....	8
3.6 MATERIAL AND MASS INFORMATION .....	10
3.7 FINITE ELEMENT (FE) MODEL .....	11
3.8 VOLTAGE TRANSFORMER - PV 123 .....	11
3.8.1 Model simplifications .....	11
3.9 MATERIAL AND MASS INFORMATION .....	11
3.10 FINITE ELEMENT (FE) MODEL .....	13
3.11 COMBINED TRANSFORMER - PVA123a/PVA145a .....	14
3.11.1 Model simplifications .....	14
3.12 MATERIAL AND MASS INFORMATION .....	14
3.13 FINITE ELEMENT (FE) MODEL .....	17
4 SIMULATION RESULTS .....	18
4.1 PA123a/PA145a .....	18
4.1.1 Natural frequency extraction .....	18
4.1.2 Dynamic analysis .....	20
4.2 PV 123 .....	23
4.2.1 Natural frequency extraction .....	23
4.2.2 Dynamic analysis .....	25
4.3 PVA123a/PVA145a .....	27
4.3.1 Natural frequency extraction .....	27
4.3.2 Dynamic analysis .....	29
5 CONCLUSIONS .....	34
6 BIBLIOGRAPHY .....	35
7 CHANGE HISTORY .....	35
8 APPENDICES .....	36

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers, IEEE 693- High (0.5g)/moderate(0.25g) seismic level		
8.1 CURRENT TRANSFORMER PA123A /PA145A.....	1.0	3/38
8.2 VOLTAGE TRANSFORMER PV123.....		36
8.3 COMBINED TRANSFORMER PVA123A /PVA145A.....		37
		38

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers, IEEE 693- High (0.5g)/moderate(0.25g) seismic level		
1 INTRODUCTION	1.0	4/38

8.1 CURRENT TRANSFORMER PA123A /PA145A.....	36
8.2 VOLTAGE TRANSFORMER PV123.....	37
8.3 COMBINED TRANSFORMER PVA123A /PVA145A.....	38

## 1 INTRODUCTION

The goal of the analysis was to evaluate seismic performance of PA123a/PA145a (see 8.1), PV123 (see 8.2), PVA145a/PVA123a (see 8.3) type transformers. Simulation was done using guidelines of IEEE 693 standard. For more information please see [1].

Computations concerned evaluation of stress field distribution and maximum bending moment between flange and insulator. Present report describes used simulation technique, analysis steps, loads and boundary conditions variations and summarizes obtained results.

## 2 SIMULATION SOFTWARE

All simulations were performed using Abaqus/CAE package. Abaqus includes FEM (finite element method) solver, pre- and post processor and enables performing many types of multiphysics simulations: mechanical, thermal, acoustic, piezoelectric, seismic, and others.

Parts and assemblies can be created in Abaqus, or they can be imported from CAD systems using native file formats. Abaqus functionality enables to define materials, interactions, loads, boundary conditions, mesh. User is also available to set up simulation parameters such as pre-processing memory. It is always possible to change all simulation settings and properties, because they're all parameterized.

Simulation results can be visualized in Abaqus postprocessor or in external software, which is able to import simulation results in Abaqus format. In postprocessor user can view all predefined field outputs, show or hide part instances, create cross-sections, make animations, automatically generate reports, diagnose model (warnings, errors). For more information about ABAQUS please see [2].

## 3 SIMULATION SETUP

Analysis has been made using Finite Element Method.

### 3.1 Simulation procedure

According to [1] analysis included three main simulation steps:

- Static load:
  - Terminal load.
  - Gravitational load.
- Natural frequency extraction.
- Dynamic analysis.

### 3.2 Simulation steps

Simulation consisted of three main simulation steps.

#### 3.2.1 Natural frequency extraction

In the first simulation step natural frequency extraction was performed. The frequency extraction procedure performs eigenvalue extraction to calculate the natural frequencies and the corresponding mode shapes of a system.

The eigenvalue problem for the natural frequencies of an undamped finite element model can be described by equation (3-1):

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

$$(-\omega^2 M^{MN} + K^{MN})\phi = 0 \quad (3-1)$$

where:  $M^{MN}$  – mass matrix (kg);  $K^{MN}$  – stiffness matrix (Pa), which includes initial stiffness effects if the base state (gravitational load);  $\phi$  – eigenvector (the mode of vibration);  $M, N$  – degrees of freedom (-). Based on specification [1] one can assume that most critical frequency modes are in range of 0-35 Hz.

### 3.2.2 Response spectrum analysis

The response spectrum method is a convenient way of describing shock motion in terms of the maximum response of a single degree of freedom (1-DOF) oscillator of arbitrary natural period and damping ratio. Each data point of the response spectrum curve represents the peak response from a time history analysis of the earthquake applied to 1-DOF oscillator system. The ordinate defines the natural period at which the oscillator is tuned. Repeating the procedure for a great many frequencies defines a continuous curve for an assumed level of damping.

A spectral response analysis estimates the maximum displacement of the structure during a 'design' shock load without recourse of direct integration. Finite element implementation of the response spectrum calculate the response of each mode independent, and then combine the scaled response one of a number of established combination rules, to give an estimate of peak response. Spectrum plot used in simulation is presented in Figure 1.




Figure 1. Design response spectrum (RS) – 0.5g

### 3.3 Loads and boundary conditions

#### 3.3.1 Loads

The following static load scenarios have been considered

1. Gravitational load,  $g=9.81 \text{ m/s}^2$ .
2. Terminal operating load. These load conditions were specified according to [3] (Table 7 – Static withstand test loads). For considered voltage-current range static withstand force (Load class II) should be equal to 3000 N. With respect to 'NOTE 1 The sum of the loads acting in routinely operating conditions should not exceed 50% of the specified withstand test load', maximum operating force is equal to 1500 N.

Seismic load have been predefined according design response spectrum described in the standard [1] – ground acceleration reference – Moderate/High Required Response Spectrum. Main input parameters were the following:

- XYZ base motion with vertical load (Y) equal to 80% of horizontal direction.
- Damping ratio – 2%.

As the final outcome from the analysis static loads were combined with the seismic load.

#### 3.3.2 Boundary conditions

Simulation assumes that the apparatus will be mounted on ground. During analysis model has been fixed at the bottom face of used test frame. General view of static loads and boundary conditions is presented in Figure 2. Area highlighted by red has been constrained (Y-rotation released). Base of the bottom tank has been supported in Y direction (as it is placed on the ground). Described boundary conditions have been used for all analyzed models.




Figure 2. Boundary conditions – general view

403

<b>ABB</b> Doc. title	ZCCO Corporate Research	9ADB009045	Page
	Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	Revision 1.0	7/38

### 3.4 Acceptance criteria

With respect to the standard [1] the following acceptance criteria were used

- Seismic load should be combined with dead load and possible normal operating loads.
- The maximum allowable bending moment shall not exceed 6.65 kNm (50% of ultimate load/stress)
- Aluminum components shall not exceed 73 MPa (minimum ultimate tensile strength divided by 2.2 safety factor).

<b>ABB</b> Doc. title	ZCCO Corporate Research	9ADB009045	Page
	Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	Revision 1.0	8/38

### 3.5 Current transformer - PA 123a/PA 145a

This chapter gathers details related to FE model of current transformer PA 123a/PA 145a.

#### 3.5.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 3. Red point indicates center of mass of the transformer.




Figure 3. Simplified representation of the PA 123a/PA 145a transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

### 3.6 Material and mass information

Component naming is presented in Figure 4.






Figure 4. Assembly – component naming

Material and mass information is listed in Table 1

Table 1. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKA310015	Base J123	EN-AC 43200 (grade F)	16.5	69000	80	160
2GKA310404	Insulator - Flange	Porcelain	71	100000	140	
	Head	EN-AC 43200 (grade F)	3.5	69000	180	220
2GKA414718	Head cover	EN-AC 43200 (grade F)	22.5	69000	80	160
2GK314089	Head cover	EN-AC 43200 (grade F)	20	69000	80	160
	Cell		150			
2GK311093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
	Oil		120			

The ultimate bending moment for ceramic insulator is equal to  $M_B=13.3$  kNm.

### 3.7 Finite element (FE) model

General view of FE model is presented in Figure 5.




Figure 5. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 533430
- Total number of elements: 242866
  - 210555 quadratic tetrahedral elements of type C3D10
  - 31050 quadratic hexahedral elements of type C3D20R
  - 1243 quadratic quadrilateral elements of type S8R
  - 18 quadratic triangular elements of type STRI65

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

*[Handwritten signature]*

*[Handwritten signature]*

<b>ABB</b> Doc. title	ZCCO Corporate Research	9ADB009045	Revision	Page
			1.0	11/38
Seismic analyses of HV Instrument Transformers, IEEE 693- high (0.5g)/moderate(0.25g) seismic level				

### 3.8 Voltage transformer - PV 123

This chapter gathers details related to FE model of voltage transformer PV 123.

#### 3.8.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 6. Red point indicates center of mass of the transformer.




Figure 6. Simplified representation of the PV 123 transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

#### 3.9 Material and mass information

Component naming is presented in Figure 7.

<b>ABB</b> Doc. title	ZCCO Corporate Research	9ADB009045	Revision	Page
			1.0	12/38
Seismic analyses of HV Instrument Transformers, IEEE 693- high (0.5g)/moderate(0.25g) seismic level				





Figure 7. Assembly - component naming

Material and mass information is listed in Table 2.

Table 2. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKK310150P	Bottom tank	EN-AC 43200 (grade F)	25	69000	80	160
2GKK310147P	Core	Steel	22.5	206000	300	370
2GKK314005	Tank cover	EN-AC 43200 (grade F)	15.5	69000	80	160
2GKK310404	Insulator	Porcelain	71	100000	140	
	Insulator flange	EN-AC 43200 (grade F)	3.5	69000	180	220
	Cell	-	30			
2GKK311093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
	Oil		60			

The ultimate bending moment for ceramic insulator is equal to  $M_B=13.3$  kNm.

 Doc. title	ZCCO Corporate Research	9ADB009045	Page
	Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	Revision 1.0	14/38

### 3.11 Combined transformer – PVA123a /PVA145a

This chapter gathers details related to FE model of combined transformer PVA123a /PVA145a.

#### 3.11.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 9. Red point indicates center of mass of the transformer.




Figure 9. Simplified representation of the PVA123a /PVA145a transformer


Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

### 3.12 Material and mass information

Component naming is presented in Figure 10

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

 Doc. title	ZCCO Corporate Research	9ADB009045	Page
	Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	Revision 1.0	13/38

### 3.10 Finite element (FE) model

General view of FE model is presented in Figure 8.




Figure 8. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 608507
- Total number of elements: 236033
  - 4606 quadratic quadrilateral elements of type S8R
  - 58 quadratic triangular elements of type STR165
  - 58965 quadratic hexahedral elements of type C3D20R
  - 8577 linear hexahedral elements of type C3D8R
  - 163827 quadratic tetrahedral elements of type C3D10

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

407




Figure 10. Assembly – component naming

Material and mass information is listed in Table 3.

Table 3. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKK314076	Tank	EN-AC 43200 (grade F)	25	69000	80	160
2GKK314084	Core	Steel	33.8	206000	300	370
2GKK314075	Tank cover	EN-AC 43200 (grade F)	18	69000	80	160
2GKK314070	Insulator	Porcelain	131	100000	140	
	Insulator flange	EN-AC 43200 (grade F)	5	69000	180	220
2GKK314080	Head	EN-AC 43200 (grade F)	23.5	69000	80	160
2GKK314089	Head cover PVA-PA123A /PA145A-145	EN-AC 43200 (grade F)	23	69000	80	160
2GKK310802	Bellow	Stainless steel	5	190000	200	500
2GKK310014P	Below enclosure	EN-AC 43200 (grade F)	7	69000	80	160
-	Voltage coil	-	30	-	-	-
-	Current coil	-	150	-	-	-
2GKK310802	Epoxy Insulator	-	2.5	-	-	-
2GKK31093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
-	Oil	-	150	-	-	-

The ultimate bending moment for ceramic insulator is equal to  $M_{IE}=13.3$  kNm.

<b>ABB</b>	ZCCO Corporate Research	9ADB009045	Page
Doc. title	Revision	1.0	17/38
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			

### 3.13 Finite element (FE) model

General view of FE model is presented in Figure 11.




Figure 11. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 1009580
- Total number of elements: 463007
  - 58507 quadratic hexahedral elements of type C3D20R
  - 300489 quadratic tetrahedral elements of type C3D10
  - 2519 linear quadrilateral elements of type S4R
  - 97 linear triangular elements of type S3
  - 9900 linear hexahedral elements of type C3D8R
  - 528 quadratic wedge elements of type C3D15
  - 90967 quadratic tetrahedral elements of type C3D10M

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

<b>ABB</b>	ZCCO Corporate Research	9ADB009045	Page
Doc. title	Revision	1.0	18/38
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			

## 4 SIMULATION RESULTS

This chapter gathers simulation results evaluated in the analysis. Obtained outcome includes static and the seismic load.

### 4.1 PA123a /PA145a

#### 4.1.1 Natural frequency extraction

Effective modal mass plot is presented Figure 12. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 6.9 – 8.2 Hz.




Figure 12. Natural frequency extraction – effective modal mass  
Effective modes and associated with the shapes are presented in Figure 13.

409

410

<b>ABB</b>	ZCCO Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	1.0	19/38




Figure 13. Natural frequency extraction – mode shapes  
Summary of modal mass participation is listed in Table 4.

Table 4. Modal mass participation – summary

Mode no	Frequency [Hz]	X-direction	Y-direction	Z-direction
1	6.9	40%	0%	35%
2	8.2	34%	0%	40%
3	38.9	2%	0%	6%
4	39.7	6%	0%	2%
5	46.9	0%	0%	0%
6	98.7	0%	89%	0%
7	129.2	0%	0%	2%
8	150.3	4%	0%	0%
9	166.6	0%	0%	4%
10	167.4	2%	0%	0%

<b>ABB</b>	ZCCO Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	1.0	20/38

4.1.2 Dynamic analysis

Stress distribution for tank component is presented in Figure 14 and Figure 15. Stress scale has been limited to 73 MPa as the maximum allowable stress level.




Figure 14. Von-Mises stress [Pa] distribution – tank (view 01)



Figure 15. Von-Mises stress [Pa] distribution – tank (view 02)  
Displacement field is presented in Figure 16.




Figure 16. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x=7961 \text{ Nm}$ .
- $M_z=7992 \text{ Nm}$ .

Insulator has not satisfied the maximum bending moment condition. One can observe that stresses evaluated at the base are slightly above allowable value. Therefore small yielding may occur. One must have in mind that analysis did not cover possible casting imperfections.

Design has been verified according to Moderate seismic level (0.25 g Zero Period Acceleration). Stress distribution for such load scenario is presented from Figure 17 to Figure 18. Obtained stress level was below allowable level.

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x=4816 \text{ Nm}$ .
- $M_z=4821 \text{ Nm}$ .

Insulator has satisfied allowable bending moment condition.




Figure 17. Von-Mises stress [Pa] distribution (AF3) – tank (view 01)




Figure 18. Von-Mises stress [Pa] distribution (AF3) – tank (view 02)

444

#### 4.2.1 Natural frequency extraction

Effective modal mass plot is presented Figure 19. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 24,7–25,3 Hz.




Figure 19. Natural frequency extraction – effective modal mass  
Effective modes and associated with the shapes are presented in Figure 20.




Figure 20. Natural frequency extraction – mode shapes  
Summary of modal mass participation is listed in Table 5.

Table 5. Modal mass participation – summary

Mode no.	Frequency [Hz]	X-direction	Y-direction	Z-direction
1	24.7	24%	0%	0%
2	25.2	0%	0%	24%
3	25.4	0%	0%	0%
4	26.5	0%	0%	0%
5	135.5	37%	0%	0%
6	139.3	0%	0%	36%
7	161.3	0%	34%	0%
8	162.4	0%	0%	0%
9	175.8	0%	0%	0%
10	176.2	0%	0%	0%



	<b>ZCCO</b> Corporate Research	9ADB009045	Page
			25/38
Doc. title <b>Seismic analyses of HV Instrument Transformers.</b> IEEE 693- high (0.5g)/moderate(0.25g) seismic level			

4.2.2.2 Dynamic analysis  
 Stress distribution for tank component is presented in Figure 21 and Figure 22. As described in chapter 3.8.1 location of center of mass is close to the ground level, therefore expected bending moment and so the stress was low. One can see that the maximum stress level reached ca. 24 MPa and it was located at vicinity of coupling constraint. Stress level satisfies required safety condition.




Figure 21. Von-Mises stress [Pa] distribution – tank (view 01)




Figure 22. Von-Mises stress [Pa] distribution – tank (view 02)

	<b>ZCCO</b> Corporate Research	9ADB009045	Page
			26/38
Doc. title <b>Seismic analyses of HV Instrument Transformers.</b> IEEE 693- high (0.5g)/moderate(0.25g) seismic level			

Displacement field is presented in Figure 23.




Figure 23. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x = 2224 \text{ Nm}$ .
- $M_z = 2228 \text{ Nm}$ .

Insulator has satisfied the maximum bending moment condition.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
 © 2015 ABB Ltd.

#### 4.3 PVA123a /PVA145a

##### 4.3.1 Natural frequency extraction

Effective modal mass plot is presented Figure 24. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 3.8– 4.1 Hz.




Figure 24. Natural frequency extraction – effective modal mass  
Effective modes and associated with the shapes are presented in Figure 25.





Figure 25. Natural frequency extraction – mode shapes  
Summary of modal mass participation is listed in Table 6.

Table 6. Modal mass participation – summary

Mode no.	Frequency [Hz]	X-direction	Y-direction	Z-direction
1	3.8	35%	0%	32%
2	4.1	32%	0%	35%
3	22.4	7%	0%	0%
4	23.2	0%	2%	8%
5	26.5	0%	95%	0%
6	29.2	0%	1%	0%
7	29.3	1%	0%	0%
8	34.6	10%	0%	0%
9	35.5	0%	0%	8%
10	36.2	0%	0%	3%



416

 Doc. 016	<b>ZCCO</b> Corporate Research		9ADB009045
			Revision 1.0
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			Page 31/38





Figure 28. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x = 10451 \text{ Nm}$ .
- $M_z = 8515 \text{ Nm}$ .

Insulator has not satisfied the maximum bending moment condition. Stress distribution for moderate seismic level is presented in Figure 29 and Figure 30.

 Doc. 016	<b>ZCCO</b> Corporate Research		9ADB009045
			Revision 1.0
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			Page 32/38





Figure 29. Von-Mises stress [Pa] distribution - tank (view 01)




Figure 30. Von-Mises stress [Pa] distribution - tank (view 02)

	<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>	Revision	Page
			1.0	33/38
Doc. title <b>Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level</b>				

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_{1c}=6335 \text{ Nm}$ .
- $M_{2c}=4080 \text{ Nm}$ .

The maximum bending moment satisfies allowable value.

	<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>	Revision	Page
			1.0	34/38
Doc. title <b>Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level</b>				

## 5 CONCLUSIONS

The goal of the analysis was to investigate family of HV Instrument Transformers using guidelines described in IEEE 693 standard. Summary of satisfied criteria is presented in Table 7. Column 'IEEE 693' lists allowable seismic level for selected design. Columns (2, 3) list seismic level where obtained stresses/bending moment were below yield strength/ultimate bending moment.

Table 7. Summary of acceptance criteria

Design name	(1) IEEE 693	(2) Yield strength	(3) Ultimate bending load
PA123a /PA145a	MODERATE	HIGH	HIGH
PV 123	HIGH	HIGH	HIGH
PVA123a /PVA145a	MODERATE	HIGH	HIGH


With respect to IEEE 693 criteria main conclusions are the following:


- PA123a/PA145a withstands Moderate seismic qualification level.
- PV 123 withstands High seismic qualification level.
- PVA123a/PVA145a withstand Moderate seismic qualification level.

## Disclaimer

The analysis documented herein has been prepared in accordance with reasonable standards of scientific endeavor and the best knowledge of the author(s).

The simulation results may depend on a variety of factors, including quality of input data, applied model simplifications and chosen numerical methods.



 <small>Doc. title</small>	<b>ZCCO</b> Corporate Research		<b>9ADB009045</b>
	Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		<small>Revision</small> 1.0
			<small>Page</small> 35/38


## 6 BIBLIOGRAPHY

- [1] IEEE 693 – *IEEE Recommended Practice for Seismic Design and Substations*, The Institute of Electrical and Electronics Engineers, Inc, NY 10016-5997, USA
- [2] ABAQUS, *ABAQUS 6.13 Documentation*, DS Simulia, USA, [www.simulia.com](http://www.simulia.com)
- [3] IEC 61869-1 – *Instrument transformers – Part 1: General requirements*, International standard, Edition 1.0 2007-10

## 7 CHANGE HISTORY


Date	Revision	Author(s)	Change
2015-08-31	Rev. 1	Juszkiewicz Grzegorz	original document

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
 © 2015 ABB Ltd.

 <small>Doc. title</small>	<b>ZCCO</b> Corporate Research		<b>9ADB009045</b>
	Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		<small>Revision</small> 1.0
			<small>Page</small> 36/38

## 8 APPENDICES


### 8.1 Current transformer PA123a / PA145a



We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
 © 2015 ABB Ltd.

<b>AABB</b>	ZCCO Corporate Research	9ADB009045	Doc. title	Page
			Revision	Page
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			1.0	37/38


8.2 Voltage transformer PV123



We reserve all rights in the document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

<b>AABB</b>	ZCCO Corporate Research	9ADB009045	Doc. title	Page
			Revision	Page
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			1.0	38/38

8.3 Combined transformer PVA123a /PVA145a



We reserve all rights in the document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

*[Handwritten signature]*

*[Handwritten scribble]*

219





<b>ABB</b> <b>PLABB</b>		<b>ZCRD</b> Corporate Research		<b>9ADB009226</b>	
Issued by department ZORD/Poland/SST	Last edit date 2015-10-13	Lang. English	Revision 1.0	Page 1/14	Page 2/14
Customer ABB PLABB	Classification Confidential		Status of document Released		
Doc. title Calculation of damping factors and natural frequencies based on dynamic test.	Research Area Mechanical Engineering				
Project name/ID Bartłomiej Kasprzyk/PLABB					
Main Author Marek Florowski/PLCRC, Piotr Saj/PLCRC					
Additional Author(s) calculation, damping factor, natural frequencies, dynamic test, FFT transformation, voltage transformer					
Keywords Marek Florowski/PLCRC	First Approval Date 2015-10-13				
Approved by Formosa_M/PLABB Rev. 1.00					

<b>ABB</b> <b>PLABB</b>		<b>ZCRD</b> Corporate Research		<b>9ADB009226</b>	
Doc. title Calculation of damping factors and natural frequencies based on dynamic test.		Revision 1.0	Page 2/14		

**TABLE OF CONTENTS**

1 TEST OBJECT ..... 3

2 SCOPE OF TEST ..... 3

3 RESULTS ..... 11

4 CALCULATIONS ..... 13

5 SUMMARY ..... 14

6 BIBLIOGRAPHY ..... 14

7 CHANGE HISTORY ..... 14


## Technical note

Simulation Support Team

Calculation of damping factors and natural frequencies based on dynamic test performed in institute of power engineering.

### Executive summary

The technical note covers investigation related to evaluation of damping factors and natural frequencies based on real dynamic test. Calculations were based on literature resources.




### 1 TEST OBJECT

The voltage transformers type EMF-E072 and EMF-E145 are used for supplying of measuring and protection circuits. The transformer consists of coil, winding, porcelain enclosure, tank, cover and other parts. All parts inside the voltage transformer are immersed in the oil. For more details see [5].

### 2 SCOPE OF TEST

The test program of voltage transformers is sudden loading the A terminal in two horizontal directions. Two values of force were applied: 2040N and 3650N. For more details see [5].

### 3 RESULTS

In this chapter the result of tests are presented. The results were supplied by the institute of power engineering in Warsaw. Results contain distribution of the force [kN] vs. time [s] during dynamic test for two types of voltage transformers: EMF-E072 and EMF-E123/145. Both types of voltage transformers have two versions:

- Porcelain insulator.
- Composite insulator.

The force was recorded using electronic dynamometer. For more details see [5].




Figure 1. Force vs. time recorded for longitudinal direction - 2000N.

### EMF-E072-porcelain

Force vs. time




Figure 2. Force vs. time recorded for transverse direction - 2000N.

### EMF-E072-porcelain

Force vs. time




Figure 3. Force vs. time recorded for longitudinal direction - 3600N.




Figure 4. Force vs. time recorded for transverse direction – 3600N.




Figure 5. Force vs. time recorded for longitudinal direction – 2000N.




Figure 6. Force vs. time recorded for transverse direction – 2000N.




Figure 7. Force vs. time recorded for longitudinal direction – 3600N.

<b>ABB</b> Doc. title	ZCRD	9ADB009226	Page
	Corporate Research		
Calculation of damping factors and natural frequencies based on dynamic test.		Revision	7/14
		1.0	




Figure 8. Force vs. time recorded for longitudinal direction – 2000N.




Figure 9. Force vs. time recorded for transverse direction – 2000N.

<b>ABB</b> Doc. title	ZCRD	9ADB009226	Page
	Corporate Research		
Calculation of damping factors and natural frequencies based on dynamic test.		Revision	8/14
		1.0	




Figure 10. Force vs. time recorded for longitudinal direction – 3600N.




Figure 11. Force vs. time recorded for transverse direction – 3600N.




Figure 12. Force vs. time recorded for longitudinal direction – 2000N.




Figure 13. Force vs. time recorded for transverse direction – 2000N.




Figure 14. Force vs. time recorded for longitudinal direction – 3600N.




Figure 15. Force vs. time recorded for transverse direction – 3600N.

425

#### 4 CALCULATIONS

In this chapter, we would like to focus on the method of getting the natural frequencies based on the presented above dynamic charts and method of calculating the damping factors. The method of getting the natural frequencies is presented for the voltage transformer EMF-E072 and EMF-E123/145 with porcelain insulator (see Figure 1 and Figure 5). We will start with the voltage transformer EMF-E072.


To calculate natural frequencies we have to transform obtained charts (force vs. time) into frequency domain. To do this operation, we have to use fast Fourier transform (FFT). We will do it using Microsoft Excel application based on the information included in the [4] document.

Based on the data in time domain, we can say that the time interval between the points is 0.025s. We call this sampling interval  $T_s$ . For our analysis we don't take all time points only selected. Regarding the FFT requirements the suit of input data must have a size that is an integral power of 2 (i.e. 16, 32 or 64). In my case the selected number of points equals to  $2^8=256$ . In time domain it is range (1.2 - 7.575) s, that we call the overall sampling window time  $T_w$ . The sampling frequency here  $f_s$  is 40Hz ( $f_s=1/T_s$ ,  $f_s=1/0.025s$ ). We have to remember that our signal must meet the Nyquist criterion. In our case the "Nyquist frequency"  $f_n$  is 20Hz ( $f_n=f_s/2$ ,  $f_n=40/2$ ). It means that our frequency range is 0 - 20Hz. According to FEA calculations (for more details see [2]) we know that the expected first natural frequency ( $f_1$ ) for this voltage transformer is ~29Hz. It means that the sampling rate for this signal is too low. If we want to increase the frequency range we have to change the sampling frequency. Additionally we can't forget that the minimum number of points to describe the sine function is 8. It gives us that  $T_s$  should be rather ~0.0043s ( $T_s=1/(f^*8)$ ,  $1/(29^*8)$ ). Instead of 0.025s.

The same algorithm was used for the voltage transformer EMF-E123/145. In this case the sampling frequency ( $f_s$ ) is enough because the expected first natural frequency ( $f_1$ ) is ~12Hz (for more details see [1]). However in this case the second condition is not fulfilled. The minimum number of points to describe the sine function is 8 and it means that that  $T_s$  should be rather ~0.010 ( $T_s=1/(f^*8)$ ,  $1/(12^*8)$ ) instead of 0.025s.

There are plans to perform new tests with new electronic dynamometer which is able to register data with time interval between the points equals to 0.001s. It should help to catch natural frequencies for both voltage transformers based on the dynamic charts.

The damping factor was calculated based on the standard IEC 1463: 1996-07, Bushings- Seismic qualification. This method in the literature is widely known as the logarithmic decrement. It is the simplest method of calculating the damping factor when we have dynamic chart in time domain.



$n$  represents the number of cycles.

Figure 16. Typical case of oscillations with damping.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure in third parties without express authority is strictly forbidden.  
© 2014 ABB Ltd.

The following formula was used:

$$C = \frac{1}{2\pi n} * \ln\left(\frac{Y_n}{Y_{n+1}}\right) * 100\%$$

Where:

all parameters are explained in the picture above.

For the calculation, the adjacent peaks ( $Y_n$  and  $Y_{n+1}$ ) were taken so in every case the  $n$  which represents the number of cycles equals to 1. The result for every case is arithmetic mean of three damping factors. It means that for every case the damping factors  $c_1$ ,  $c_2$  and  $c_3$  were calculated. It is always that  $c_1$  is a result of  $Y_1$  peak and  $Y_2$  peak,  $c_2$  is a result of  $Y_2$  peak and  $Y_3$  peak and etc. The tables below present the results. The first result is for the ceramic insulator and the second one is for the composite insulator.

Table 1. Results of damping factor for the voltage transformer with ceramic insulator.

Type of voltage transformer	2000N		Longitudinal [%]	Transverse [%]
	Longitudinal [%]	Transverse [%]		
EMF-E072	1.58	1.67	1.32	1.44
EMF-E123/145	1.21	1.02	0.95	—*

\* The test was not done due to oil leakage after the longitudinal test.

Table 2. Results of damping factor for the voltage transformer with composite insulator.

Type of voltage transformer	2000N		Longitudinal [%]	Transverse [%]
	Longitudinal [%]	Transverse [%]		
EMF-E072	1.19	1.57	1.29	1.28
EMF-E123/145	0.89	1.16	1.22	1.05

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure in third parties without express authority is strictly forbidden.  
© 2014 ABB Ltd.

<b>ABB</b> ABB	<b>ZCRD</b> Corporate Research	<b>9ADB009226</b>	Doc. title	Revision	Page
Calculation of damping factors and natural frequencies based on dynamic test.				1.0	13/14

## 5 SUMMARY

Taking into account the calculations which are presented in this document, we must be aware of the fact that these values come from the real test so they are the most credible. However, the damping values are the arithmetic mean of the three damping factors ( $c_1$ ,  $c_2$  and  $c_3$  – see page 12). One example can prove that this approach has also some tricks. For the EMF-E072 voltage transformer, the damping factor for force 2000N in longitudinal direction is 1.58. The partial damping factors are:  $c_1$  is 2.51  $c_2$  is 1.60 and  $c_3$  is 0.63. It shows that there is an important discrepancy between the partial factors and the damping factors are very unstable. The second conclusion is that the damping factors for the voltage transformer EMF-E072 are averagely 25% (composite insulator) and 44% (ceramic insulator) higher as compared to the voltage transformer EMF-E123/145. It may be caused by the height of the voltage transformers, the EMF-E123/145 VT is much higher than the EMF-E072 VT. Generally, we can say that the damping factors used in FEA simulations are close to the reality. In our analysis, we assume that the damping factor is 2% and according to the test, these values fluctuate between 0.89% and 1.67%.

## Disclaimer

The analysis documented herein has been prepared in accordance with reasonable standards of scientific endeavor and the best knowledge of the author(s).

The simulation results may depend on a variety of factors, including quality of input data, applied model simplifications and chosen numerical methods.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2014 ABB Ltd.

<b>ABB</b> ABB	<b>ZCRD</b> Corporate Research	<b>9ADB009226</b>	Doc. title	Revision	Page
Calculation of damping factors and natural frequencies based on dynamic test.				1.0	14/14

## 6 BIBLIOGRAPHY

- [1] Zakład Badawczo-rozwojowy, Zespół Laboratoriów Badań Środowiskowych – Laboratorium badań poligonowych, Gdańsk, Report badania – Badanie Własności dynamicznych konstrukcji przekładnika napięciowego EMF-E145, H. Michniewicz, W. Szkuclarek,
- [2] Static and seismic analysis of voltage transformer type IVT 123/145, SST report for case 14206, PLABB, B. Kasprzyk,
- [3] Standard IEC 1463: 1996-07, Bushings-Seismic qualification,
- [4] The Fourier analysis tool in Microsoft Excel, Douglas A. Kerr,
- [5] Test reports of Voltage transformers EMF-E072 and EMF-E123/145, Institute of Power Engineering, Distribution Equipment Laboratory, Warsaw, Tomasz Kaczmarczyk,

## 7 CHANGE HISTORY

Date	Revision	Author(s)	Change
2015-10-13	Rev. 1	Bartłomiej Kasprzyk	original document

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2014 ABB Ltd.

227

(

(

(



„Доставка на електрически апарати  
110кV“, реф. № РРД 17-064.

Обособена позиция 3 – Доставка на  
напреженови измервателни  
трансформатори 110кV за монтаж на  
открито – 6бр.

## ПРИЛОЖЕНИЕ 5





# ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ



Подписваща страна ЕА МЛА

## СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ НА ЛАБОРАТОРИЯ ЗА КАЛИБРИРАНЕ

# № AP 168

Това е, за да се потвърди, че:

**ABB Sp. z o.o.,**  
**Ул. Зеганска 1, 04-713 Варшава**  
**Лаборатория за калибриране**  
**ABB Продукти Високо Напрежение клон в Пшашниш**  
**ул. Лешно 59, 06-300 Пшашниш, Полша**

отговаря на изискванията на стандарт PN-EN ISO/IEC 17025:2005

Акредитирана дейност се определя в обхвата на акредитация № AP 168

Тази акредитация остава в сила, при условие че Лабораторията съблюдава изискванията на органа за акредитация, определени в договор № AP 168

Сертификатът за акредитация е валиден до 20.12.2020 г.

Директор  
Лучина Олборска

Варшава, 21 Декември 2016 г.

(

(

5

# POLSKIE CENTRUM AKREDYTACJI

## POLISH CENTRE FOR ACCREDITATION

ABB Sp. z o.o.  
ul. Żegańska 1, 04-713 Warszawa  
NIP: 5280304484  
KRS: 000047168  
ODZIAŁ W PRZASNYSZU  
ul. Leszno 59, 06-300 Przasnysz  
t. (22) 223 8349, fax (22) 223 8958  
(16)



Sygnatariusz EA MLA  
EA MLA Signatory

# CERTYFIKAT AKREDYTACJI

## LABORATORIUM WZORCUJĄCEGO

### ACCREDITATION CERTIFICATE OF CALIBRATION LABORATORY

# Nr AP 168

Potwierdza się, że: / This is to confirm that:


**ABB Sp. z o.o.**  
ul. Żegańska 1, 04-713 Warszawa  
Laboratorium Wzorcujące  
ABB PGHV w Przasnyszu  
ul. Leszno 59, 06-300 Przasnysz

spełnia wymagania normy PN-EN ISO/IEC 17025:2005  
meets requirements of the PN-EN ISO/IEC 17025:2005 standard

Akredytowana działalność jest określona w Zakresie Akredytacji Nr AP 168  
Accredited activity is defined in the Scope of Accreditation No AP 168

Akredytacja pozostaje w mocy pod warunkiem przestrzegania  
wymagań jednostki akredytującej określonych w kontrakcie Nr AP 168  
This accreditation remains in force provided the Laboratory observes  
the requirements of Accreditation Body defined in the Contract No AP 168

Certyfikat akredytacji ważny do dnia 20.12.2020 r.  
The certificate of accreditation is valid until 20.12.2020



DYREKTOR  
POLSKIEGO CENTRUM AKREDYTACJI

LUCYNA OLBORSKA

Warszawa, dnia 21 grudnia 2016 roku

433



# ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ



Подписваща страна ЕА МІА

## СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ НА СЕРТИФИЦИРАЩ ОРГАН ЗА ПРОДУКТИ № АС 117

Това е, за да се потвърди, че:

**ИНСТИТУТ ПО ЕНЕРГЕТИКА  
ИНСТИТУТ ЗА ИЗСЛЕДВАНИЯ  
отдел СЕРТИФИЦИРАНЕ  
ул. Мори 8, 01-330 Варшава**

отговаря на изискванията на стандарт PN-EN ISO/IEC 17065:2013-03

Акредитирана дейност се определя в обхвата на акредитация № АС 177

Тази акредитация остава в сила, при условие че Организацията съблюдава изискванията на органа за акредитация, определени в договор № АС 117

Сертификатът за акредитация е валиден до 03.02.2021 г.

Акредитацията е предоставена на 04.02.2005 г.

р.о. Директор  
Лучина Олборска

Варшава, 27 Януари 2017 г.

# ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ



Подписваща страна ЕА МІА

## СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ НА ЛАБОРАТОРИЯ ЗА ИЗПИТАНИЯ № АВ 323

Това е, за да се потвърди, че:

**ИНСТИТУТ ПО ЕНЕРГЕТИКА**  
**Лаборатория Високо Напрежение**  
**ул. Мори 8, 01-330 Варшава**

отговаря на изискванията на стандарт PN-EN ISO/IEC 17025:2005

Акредитирана дейност се определя в обхвата на акредитация № АВ 323

Тази акредитация остава в сила, при условие че Лабораторията съблюдава изискванията на органа за акредитация, определени в договор № АВ 323

Сертификатът за акредитация е валиден до 27.12.2019 г.

Акредитацията е предоставена на 28.12.2000 г.

ДИРЕКТОР  
ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ  
Луцина Олборска

Варшава, 16 Ноември 2015 г.



# ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ



Подписваща страна ЕА МЛА

## СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ НА ЛАБОРАТОРИЯ ЗА ИЗПИТАНИЯ № АВ 324

Това е, за да се потвърди, че:

**ИНСТИТУТ ПО ЕНЕРГЕТИКА**  
Лаборатория Разпределителни Устройства  
ул. Мори 8, 01-330 Варшава

отговаря на изискванията на стандарт PN-EN ISO/IEC 17025:2005

Акредитирана дейност се определя в обхвата на акредитация № АВ 324

Тази акредитация остава в сила, при условие че Лабораторията съблюдава изискванията на органа за акредитация, определени в договор № АВ 324

Сертификатът за акредитация е валиден до 27.12.2019 г.

Акредитацията е предоставена на 28.12.2000 г.

ДИРЕКТОР  
ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ  
Луцина Олборска

Варшава, 24 Ноември 2015 г.

C.

C.

# POLSKIE CENTRUM AKREDYTACJI

## POLISH CENTRE FOR ACCREDITATION



Sygnatariusz EA MLA  
EA MLA Signatory

# CERTYFIKAT AKREDYTACJI

## JEDNOSTKI CERTYFIKUJĄCEJ WYROBY

### ACCREDITATION CERTIFICATE FOR PRODUCT CERTIFICATION BODY

# Nr AC 117

Potwierdza się, że: / This is to confirm that:

**INSTYTUT ENERGETYKI  
INSTYTUT BADAWCZY  
ZESPÓŁ ds. CERTYFIKACJI  
ul. Mory 8, 01-330 Warszawa**

spełnia wymagania normy PN-EN ISO/IEC 17065:2013-03  
meets requirements of the PN-EN ISO/IEC 17065:2013-03 standard

Akredytowana działalność jest określona w Zakresie Akredytacji Nr AC 117  
Accredited activity is defined in the Scope of Accreditation No AC 117

Akredytacja pozostaje w mocy pod warunkiem przestrzegania  
wymagań jednostki akredytującej określonych w kontrakcie Nr AC 117  
This accreditation remains in force provided the Body observes  
the requirements of Accreditation Body defined in the Contract No AC 117

Certyfikat akredytacji ważny do dnia 03.02.2021 r.  
The certificate of accreditation is valid until 03.02.2021

Akredytacji udzielono dnia 04.02.2005 r.  
Accreditation was granted on 04.02.2005



DYREKTOR  
POLSKIEGO CENTRUM AKREDYTACJI

LUCYNA OLBORSKA

Warszawa, 27 stycznia 2017 roku

C

C

11

**POLSKIE CENTRUM AKREDYTACJI**  
POLISH CENTRE FOR ACCREDITATION



Sygnatariusz EA MLA  
EA MLA Signatory

**CERTYFIKAT AKREDYTACJI**  
**LABORATORIUM BADAWCZEGO**  
ACCREDITATION CERTIFICATE OF TESTING LABORATORY  
**Nr AB 324**

Potwierdza się, że: / This is to confirm that:

**INSTYTUT ENERGETYKI**  
**LABORATORIUM URZĄDZEŃ ROZDZIELCZYCH**  
ul. Mory 8, 01-330 Warszawa

spełnia wymagania normy PN-EN ISO/IEC 17025:2005  
meets requirements of the PN-EN ISO/IEC 17025:2005 standard

Akredytowana działalność jest określona w Zakresie Akredytacji Nr AB 324  
Accredited activity is defined in the Scope of Accreditation No AB 324

Akredytacja pozostaje w mocy pod warunkiem przestrzegania  
wymagań jednostki akredytującej określonych w kontrakcie Nr AB 324  
This accreditation remains in force provided the Laboratory observes  
the requirements of Accreditation Body defined in the Contract No AB 324

Certyfikat akredytacji ważny do dnia 27.12.2019 r.  
The certificate of accreditation is valid until 27.12.2019

Akredytacji udzielono dnia 28.12.2000 r.  
Accreditation was granted on 28.12.2000



DYREKTOR  
POLSKIEGO CENTRUM AKREDYTACJI

*Lucyna Olborska*  
LUCYNA OLBORSKA

ABB Sp. z o.o.  
Kopiecka 1, 04-713 Warszawa  
t. 223 030 41 97, PL 5260304484  
Regon 141004716  
DZIAŁ W PRZASNYSZU  
ul. Leszno 50, 08-300 Przasnysz  
t. (22) 223 8849, fax (22) 223 8958  
(16)

Warszawa, 24 listopada 2015 roku

WHA

**POLSKIE CENTRUM AKREDYTACJI**  
**POLISH CENTRE FOR ACCREDITATION**



Sygnatariusz EA MLA  
EA MLA Signatory

**CERTYFIKAT AKREDYTACJI**  
**LABORATORIUM BADAWCZEGO**  
**ACCREDITATION CERTIFICATE OF TESTING LABORATORY**  
**Nr AB 323**

Potwierdza się, że: / This is to confirm that:

**INSTYTUT ENERGETYKI**  
**LABORATORIUM WIELKOPRĄDOWE**  
**ul. Mory 8, 01-330 Warszawa**

spełnia wymagania normy PN-EN ISO/IEC 17025:2005  
meets requirements of the PN-EN ISO/IEC 17025:2005 standard


Akredytowana działalność jest określona w Zakresie Akredytacji Nr AB 323  
Accredited activity is defined in the Scope of Accreditation No AB 323

Akredytacja pozostaje w mocy pod warunkiem przestrzegania  
wymagań jednostki akredytującej określonych w kontrakcie Nr AB 323  
This accreditation remains in force provided the Laboratory observes  
the requirements of Accreditation Body defined in the Contract No AB 323

Certyfikat akredytacji ważny do dnia 27.12.2019 r.  
The certificate of accreditation is valid until 27.12.2019

Akredytacji udzielono dnia 28.12.2000 r.  
Accreditation was granted on 28.12.2000

**ABB**  
ABB Sp. z o.o.  
Legiańska 1, 04-713 Warszawa  
Tel: 22 60 44 44, PL 0260304484  
Fax: 22 610017168  
DZIAŁ W PRZASNYSZU  
ul. Leszno 59, 08-300 Przasnysz  
Tel: (22) 223 8849, fax (22) 223 8958  
(16)



DYREKTOR  
POLSKIEGO CENTRUM AKREDYTACJI

LUCYNA OLBORSKA

Warszawa, 16 listopada 2015 roku

**„Доставка на електрически апарати  
110кV“, реф. № PPD 17-064.**

**Обособена позиция 3 – Доставка на  
напреженови измервателни  
трансформатори 110кV за монтаж на  
открито – 6бр.**

# **ПРИЛОЖЕНИЕ 6**

C

C



ABB		ROUTINE TEST PLAN for Voltage Transformers План за рутинни изпитания на Напреженов Трансформатор		Number / Номер 2GKV614153	Page / Страница 1 Pages / Общо 2			
				Type / Тип				
		Valid for order ..... / KU .... Валидно за поръчка ..... / KU ....						
Sl. No	Test	Test according to: Изпитание съгл.:	Requirement according to: Изисквания	Place of test Място на	Remarks Забележки	Date Дата	Acceptance Приемане	Signature Подпис
1	Enclosure tightness test at ambient temperature Изпитване за херметичност при температура на околната среда	IEC 61869-1	Cl. 7.3.7.2	Quality control - ABB Przasnysz Контрол на качеството				
2	Verification of terminal markings and technical parameters Проверка на маркировката на клемите и техническите параметри	IEC 61869-1 IEC 61869-3	Cl. 6.13 Cl. 6.13	Quality control - ABB Przasnysz Контрол на качеството				
3	Power-frequency voltage withstand tests on primary windings and partial discharge measurement Обявено издържано напрежение с промишлена честота за изолацията на първичната	IEC 61869-1 IEC 61869-3 IEC 60270	Cl. 7.3.1; 7.3.2 Cl. 7.3.1; 7.3.2	Quality control - ABB Przasnysz Контрол на качеството				
4	Measurement of windings' internal resistance and ambient temperature Измерване на вътрешното съпротивление на намотките и температурата	-- --	Order (if special requirements) Поръчка (при специални изисквания)	Quality control - ABB Przasnysz Контрол на качеството				
Prepared by Подготвено от		Checked by Проверено от		Date Дата		Approved by Одобрено от		Date Дата
Ł. Lubieniecki		J. Duzdowski		27.07.2015		P. Dębski		27.07.2015



# ROUTINE TEST PLAN for Voltage Transformers

## План за рутинни изпитания на Напреженое Трансформатор

Number / Номер  
2GKV614153

Page / Страница 1  
Pages / Общо 2

Type / Тип

-- units of Voltage Transformers (-брой Напреженови Трансформатори)

Valid for order ..... / KU ....  
Валидно за поръчка ..... / KU ....

Sl. No	Test Изпитание	Test according to:		Place of test Място на	Remarks Забележки	Date Дата	Acceptance Приемане	Signature Подпис
		Изпитание	Requirement according to: Изисквания					
5	Power-frequency voltage withstand tests on secondary windings Обявено издържано напрежение с промишлена честота за изолацията на вторичните намотки	IEC 61869-1	Cl. 7.3.3; 7.3.4	Quality control - ABB Przasnysz Контрол на качеството				
6	Capacitance and dielectric dissipation factor measurement Измерване на капацитет и фактор на диелектрично разсейване	IEC 61869-1 IEC 61869-3	Cl. 7.4.3 Cl. 7.4.3	Quality control - ABB Przasnysz Контрол на качеството				
7	Test for accuracy of the voltage transformer Изпитание на точността на НТ	IEC 61869-3	Cl. 7.3.5.301; 7.3.5.302	Quality control - ABB Przasnysz Контрол на качеството				
8	Inspection : visual check & verification of parameters according to order Инспекция: Визуална проверка и проверка на параметрите по поръчка	-- --	Order Поръчка	Quality control - ABB Przasnysz Контрол на качеството				
Prepared by Подготвено от		Checked by Проверено от		Date Дата		Approved by Одобрено от		Date Дата
K. Lubieniecki		J. Duzdowski		27.07.2015		P. Dębski		27.07.2015



<b>ROUTINE TEST PLAN for Voltage Transformers</b> <i>Plan próby wyrobu dla Przekładników Napięciowych</i>		Number / Numer <b>2GKV614153</b>	Page / Strona 1 Pages / Stron 2
		Type/ Typ	
		Valid for order ..... / KU .... Obowiązuje do zam. dla ..... / KU ....	

Test		Test according to:	Requirement according to:	Place of test	Remarks	Date	Acceptance	Signature
Sl. No	Badanie	Badanie według:	Wymaganie według:	Miejsce badania	Uwagi	Data	Akceptacja	Podpis
1	Enclosure tightness test at ambient temperature <i>Sprawdzenie szczelności obudowy w temperaturze otoczenia</i>	IEC 61869-1	Cl. 7.3.7.2	Quality control - ABB Przasnysz <i>Kontrola Jakości</i>			<input type="checkbox"/>	
2	Verification of terminal markings and technical parameters <i>Sprawdzenie oznakowania zacisków i parametrów technicznych</i>	IEC 61869-1 IEC 61869-3	Cl. 6.13 Cl. 6.13	Quality control - ABB Przasnysz <i>Kontrola Jakości</i>			<input type="checkbox"/>	
3	Power-frequency voltage withstand tests on primary windings and partial discharge measurement <i>Próba izolacji uzwojeń pierwotnych napięciem o częstotliwości sieciowej oraz wyładowań niezupełnych</i>	IEC 61869-1 IEC 61869-3 IEC 60270	Cl. 7.3.1; 7.3.2 Cl. 7.3.1; 7.3.2	Quality control - ABB Przasnysz <i>Kontrola Jakości</i>			<input type="checkbox"/>	
4	Measurement of windings' internal resistance and ambient temperature <i>Pomiar wewnętrznych rezystancji uzwojeń i temperatury otoczenia</i>	- --	Order (if special requirements) <i>Zamówienie (jeśli są specjalne wymagania)</i>	Quality control - ABB Przasnysz <i>Kontrola Jakości</i>			<input type="checkbox"/>	
Prepared by <i>Opracował</i>		Checked by <i>Sprawdził</i>	Date <i>Data</i>	Approved by <i>Zarządził</i>	Date <i>Data</i>			
L. Lubieniecki		J. Duzdowski	27.07.2015	P. Dębski	27.07.2015			

M

247

ABB		ROUTINE TEST PLAN for Voltage Transformers Plan próby wyrobu dla Przekładników Napięciowych				Number / Numer 2GKV614153		Page / Strona 2 Pages / Stron 2	
						Type/ Typ			
		-- units of Voltage Instrument Transformers ( -- szt. Przekładników Napięciowych)				Valid for order ..... / KU .... Obowiązuje do zam. dla ..... / KU ....			
Sl. No	Test Badanie	Test according to: Badanie według:	Requirement according to: Wymaganie według:	Place of test Miejsce badania	Remarks Uwagi	Date Data	Acceptance Akceptacja	Signature Podpis	
5	Power-frequency voltage withstand tests on secondary windings Próba izolacji uzwojeń wtórnych napięciem o częstotliwości sieciowej Capacitance and dielectric dissipation factor measurement	IEC 61869-1	Cl. 7.3.3; 7.3.4	Quality control - ABB Przasnysz			<input type="checkbox"/>		
6	Pomiar pojemności i współczynnika strat dielektrycznych	IEC 61869-1 IEC 61869-3	Cl. 7.4.3 Cl. 7.4.3	Kontrola Jakości Quality control - ABB Przasnysz			<input type="checkbox"/>		
7	Test for accuracy of the voltage transformer	IEC 61869-3	Cl. 7.3.5.301; 7.3.5.302	Kontrola Jakości Quality control - ABB Przasnysz			<input type="checkbox"/>		
8	Inspection : visual check & verification of parameters according to order Oględziny – sprawdzenie zgodności parametrów z zamówieniem	- -	Order Zamówienie	Quality control - ABB Przasnysz Kontrola Jakości			<input type="checkbox"/>		
Prepared by Opracował		Checked by Sprawdził		Approved by Zatwierdził		Date Data		Date Data	
Ł. Lubieniecki		J. Duzdowski		P. Dębski		27.07.2015		27.07.2015	



## ДЕКЛАРАЦИЯ

за приемане на условията в проекта на договор

Долуподписаните Екехарт Нойрайтер и Стефан Минчев в качеството ни на представляващи АББ България ЕООД участник в обществена поръчка с предмет: „Доставка на електрически апарати 110кV“, реф. № PPD 17-064 Обособена позиция 3 - Доставка на напреженови измервателни трансформатори 110 kV за монтаж на открито – 6 бр.

### ДЕКЛАРИРАМЕ, ЧЕ:

Приемаме условията в проекта на договор, приложен в документацията за участие.

Дата: 11.07.2017

Декларатор:

Екехарт Нойрайтер  
Управител  
АББ България ЕООД

Стефан Минчев  
Управител  
АББ България ЕООД

ABB Bulgaria EOOD  
Main Office  
9, Hristofor Kolumb Blvd., fl. 3  
Mladost, Sofia-grad  
1592 Sofia, Bulgaria  
Phone: +359 (0) 2 807 55 00  
Fax: +359 (0) 2 807 55 99  
Web: www.abb.bg  
E-mail: office@bg.abb.com

UIC: 831133152  
VAT Nr.: BG 831133152  
Bank details:  
ING Bank, branch Sofia  
IBAN: BG13INGB91451000027317 (BGN)  
IBAN: BG60INGB91451400027311 (EUR)  
BIC: INGBBGSF



03.2017

C

C



ДЕКЛАРАЦИЯ  
за срока на валидност на офертата

Долуподписаните,

Екехарт Бернхард Нойрайтер, притежаващ лична карта ID N: L8XH0JRMР издадена на 11.03.2013 – Германия, адрес гр. София, бул. Христофор Колумб № 9, ет.3,

в качеството ми на Управител на АББ България ЕООД

и

Стефан Василев Минчев, притежаващ лична карта №641790843, издадена на 11.01.2011 от МВР – гр. София, адрес: гр. София, бул. Христофор Колумб № 9, ет.3,

в качеството ми на Управител на АББ България ЕООД,

участник в процедура за възлагане на обществена поръчка с предмет: „Доставка на електрически апарати 110kV“, реф. № PPD 17-064, Обособена позиция 3 - Доставка на напреженови измервателни трансформатори 110 kV за монтаж на открито – 6 бр.

ДЕКЛАРИРАМЕ, ЧЕ:

С подаване на настоящата оферта, направените от нас предложения и поети ангажименти са валидни за срока, посочен в обявлението, считано от крайния срок за подаване на офертите.

Дата: 11.07.2017

Декларатор:

Екехарт Нойрайтер  
Управител  
АББ България ЕООД

Стефан Минчев  
Управител  
АББ България ЕООД

ABB Bulgaria EOOD  
Main Office  
9, Hristofor Kolumb Blvd., fl. 3  
Mladost, Sofia-grad  
1592 Sofia, Bulgaria  
Phone: +359 (0) 2 807 55 00  
Fax: +359 (0) 2 807 55 99  
Web: www.abb.bg  
E-mail: office@bg.abb.com

UIC: 831133152  
VAT Nr.: BG 831133152  
Bank details:  
ING Bank, branch Sofia  
IBAN: BG13INGB91451000027317 (BGN)  
IBAN: BG60INGB91451400027311 (EUR)  
BIC: INGBBG5F



03.2017

