


Sts

CESI A7020275 Oscillogram n. 18


ВЯРНО С ОРИГИНАЛА






CESI A7020275 Oscillogram n. 19

СЕРТИФИКАТ






[Handwritten signature]

CESI A7020275 Oscillogram n. 20


ВЪРНО С ОРИГИНАЛА




[Handwritten signature]



CESI A7020275 Oscillogram n. 21






MS

CESI A7020275 Oscillogram n. 22

ВЯРНО С ОРИГИНАЛА



SCD



$U_{ref} = 6.22kV \text{ min}$
 $U_r = 6.5kV$
 $U_c = 5.2kV$
 CREEPAGE = 254mm
 DRY ARC DISTANCE = 127mm

На основе чл. 2
 от ЗЗЛД

DATA
 2. 2. 07. 2007

Tyco Electronics


ENERGY DIVISION


BAY 100-109
 SHANON IND. EST.
 SHANON
 CO. CLARE
 IRELAND

Bowthorpe EMP Surge Arrester

THIS DRAWING AND THE INFORMATION SET FORTH THEREIN ARE THE PROPERTY OF TYCO ELECTRONICS LTD AND ARE TO BE HELD IN TRUST AND CONFIDENCE. PUBLICATION, REPRODUCTION, DISCLOSURE OR USE FOR ANY OTHER PURPOSE NOT EXPRESSLY AUTHORIZED IN WRITING BY TYCO ELECTRONICS LTD IS PROHIBITED.	DRN	J MULLIGAN	17/09/07	PCN		TITLE	DA1-6.5-NONONO SURGE ARRESTER			
	CHECK	B MORNOYLE		NAT'L						
	APP	B MCGOWAN					DRG NO	DA1-6.5-NONONO	SHEET 1 OF 1	REV 0
	SCALE			1:1						

DA1-6.5-NONONO





DA1 - Distribution Surge Arrester
Long duration current impulse withstand
Type Test Report

MS



Tyco Electronics

Our commitment. Your advantage.

ВЯРНО С ОРИГИНАЛА



Test Report

Type	DA1
PPR Number	PPR-2278
Test Specification	Long duration current impulse withstand test IEC 60099-4 (2006-07) Ed. 2.1



Test Information:

Laboratory	CESI
Date	03/09/2007
External Test Ref	A7020276
Report Prepared by	M. Gregori
Test Verified by	A. Sironi
Test Approved by	V. Scarioni

Tyco Approvals:

R&D Manager	На основании чл. 2 от 33ЛД	Date	28/11/2007
Brendan Normoyle			
Product Manager		Date	28/11/2007
Brian McGowan			

For further information contact:
Tyco Electronics Energy Division
Bay 100-109
Shannon Industrial Estate
Co. Clare, Ireland
Tel: + 353-61-472885
Fax: + 353-61-472676
Email: mvsurgearresters@tycoelectronics.com



Client TYCO Electronics – Shannon (Ireland)

Tested equipment Polymer- housed metal-oxide surge arrester sections type DA1 fitted with disconnecter

Tests carried out Long-duration current impulse withstand test

Standards/Specifications IEC 60099-4 – Edition 2.1 (2006-07)

Test date from July 24, 2007 to August 02, 2007

PUBBLICATO A7020276 (PAD - 980964)


The results reported in this document relate only to the tested equipment.
 Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 21 No. of pages annexed 25

Issue date
 Prepared
 Verified
 Approved

На основании чл. 2
 от ЗЗЛД

ВАРНО С ОРГИНАЛА



Tests witnessed by: ---

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawing, identified by CESI and numbered A7027909 No. 1, is annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked: ---

- dielectric tests with impulse voltage : peak voltage: ± 3 %; time parameters: ± 10 %
- dielectric tests with impulse current : peak value: ± 3 %; time parameters: ± 10 %
- dielectric tests with alternating voltage : voltage (rms): ± 3 %
- dielectric tests with direct voltage : voltage: ± 3 %

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values

Laboratory information


Receipt date of the sample July 16 , 2007

Test location CESI – Via Rubattino 54 – Milan

CESI testing team Mr L. Podavitte – Mr I. Guacci

Test laboratory P177

Activity code 80090B



content	page a	test date
Test object characteristics	4	
Photograph of the test sample	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Visual inspection and summary of the test result	8	July 24, 2007
Power frequency voltage characteristics	9	July 25, 2007
Lightning impulse residual voltage measurement before the test	10	July 25, 2007
Switching impulse residual voltage test	11	July 25, 2007
Voltage correction factor and energy calculations	12	July 25, 2007
Long duration current impulse withstand test	from page 13 to 16	July 25, 2007
Lightning impulse residual voltage measurement after the test	17	August 02, 2007
Technical data of the test circuit	from page 18 to 21	

ВЪРНО СОПРИНАТА

Pages annexed:
Oscillograms n. 24 pages

Document annexed:
Tyco Electronics drawing no. DAI-6.5-NODONO; CESI no. A7027909 - n.1 page



Test Report




Approved

Test object characteristics

type: Polymer-housed metal-oxide surge arrester section fitted with disconnecter

electrical characteristics (assigned by the client)

Manufacturer's name	TYCO Electronics – Shannon (Ireland)
Type	DA1
Nominal discharge current – I_n [kA]	10
Rated voltage – U_r [kV]	$1,045 \times U_{ref}$
Continuous operating voltage - U_c [kV]	$0,836 \times U_{ref}$
Reference current - I_{ref} [mA]	5,0
Line discharge class	1
Standard rated frequency - [Hz]	50/60
year of manufacture	2007



View of the test object




Photo no. 1

Polymer-housed metal-oxide surge arrester section fitted with disconnector

[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРИГИНАЛА



[Handwritten signature]


Reference Standard

IEC 60099-4 (2006-07) – Edition 2.1 - Clause 10.8.4
“Metal-oxide surge arresters without gaps for a.c. system”

Test carried out	Number of sample tested
Long-duration current impulse withstand test	3

Test object identification

Test object name	Identification of test sample (given by CESI)
Polymer- housed metal-oxide surge arrester section fitted with disconnecter	LD1-LD2-LD3



Test procedure

The test procedure consisted of the following sequence:

- a) Measurement of the power frequency reference voltage at the reference current
- b) Measurement of the lightning impulse residual voltage at nominal discharge current
- c) Measurement of the switching impulse residual voltage at the lowest current peak prescribed by the standard in table 4 that is 125 A
- d) Calculation of the specified energy associated to each long duration current impulse according to clause 8.4.2 of the reference standard (see note 1)
- e) Application of eighteen long duration current impulses with the specified energy (see note 1) and a virtual duration of 2000 μ s in six groups of three operations each.
 - intervals between operations of the same group: 60 seconds
 - interval between different groups: as required to cool down the samples to near ambient temperature
- f) After cooling down to near ambient temperature cooling down to near ambient temperature application of a nineteenth impulse to check the sample integrity
- g) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value

Test result

The visual inspection of the sample after the test has revealed no sign of physical damage. The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%). The oscillographic record of the 19th impulse did not reveal any sign of internal discharge. The disconnectors did not operate

The acceptance criteria are fulfilled. The test result is positive

(* Note:

Upon Client request the test was carried out with a peak current of 325 A for each single shot applied. The approach is different from the IEC for 10 kA class 1 surge arrester (based on the specified calculated energy see page 12). The applied energy exceed the IEC specified claculated energy and thus the test was more onerous

ВЯРНО С ОРИГИНАЛА




Variation of lightning impulse residual voltage at I_n

sample	before test		after test		variation
	discharge current	residual voltage	discharge current	residual voltage	
	kA	kV	kA	kV	%
LD1	10,07	15,92	10,14	16,05	+ 0,82
LD2	10,09	15,72	10,17	15,94	+ 1,39
LD3	10,11	15,64	10,20	15,88	+1,53

Visual inspection after the test

The visual inspection of the surge arresters samples after the test has revealed no sign of physical damage



Long-duration current impulse withstand test.

Reference voltage test

Test circuit: A0019

Date: July 24, 2007

Sample No. LD1						
Oscillogram	Voltage	current	current	current	power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
1	6,65	4,62	5,11	1,66	6,98	---

Sample No. LD2						
oscillogram	Voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
2	6,65	4,65	5,04	1,66	7,00	---

Sample No. LD3						
oscillogram	Voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
3	6,61	4,72	5,03	1,66	6,91	---

Handwritten signature

Handwritten signature

ВАРНО С ОРИГИНАЛА



Handwritten signature

Long-duration current impulse withstand test.

Lightning impulse residual voltage measurement before the test


Test circuit: A0120

Date: July 25, 2007

Sample No.	Requested current	Charging Voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current kA	Residual voltage kV
LD1	I _n	30,0	4	8,8/18,8	10,07	15,92
LD2		30,0	5		10,09	15,72
LD3		29,9	6		10,11	15,64

	Oscilloscope settings		
	Sampling division μ s	Input V _{div}	attenuation
Current	5	1,0	50:10
Voltage	5	1,0	20:5

Notes:



Long-duration current impulse withstand test.

Switching impulse residual voltage test.

Test circuit: A0122

Date: July 25 , 2007

Sample No.	Requested current A	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current A	Residual voltage kV
LD1	250	13,2	7	31,0/72,0	126	11,89
LD2		13,2	8		131	11,88
LD3		13,1	9		125	11,89

Oscilloscope settings			
	sampling division μ s	input V_{div}	attenuation
Current	20	0,5	10:10
Voltage	20	1,0	20:5

Notes:

Handwritten signature

Handwritten mark

ВЯРНО С ОРГИНАЛА



Handwritten signature

Long-duration current impulse withstand test.

Voltage correction factor and energy calculations


Date: June 25, 2007

Sample	U _{ref} [1]	KU _r [2]	KU _c [3]	U _r ' [4]	U _c ' [5]
No.	kV			kV	kV
LD1	6,65	1,045	0,836	6,949	5,559
LD2	6,65			6,949	5,559
LD3	6,61			6,907	5,526

- [1] U_{ref} : measured reference voltage
- [2] KU_r : maximum guaranteed factor for calculation of U_r
- [3] KU_c : maximum guaranteed factor for calculation of U_c
- [4] U_r' : corrected rated voltage [4] = [1] × [2]
- [5] U_c' : corrected continuous operating voltage [5] = [1] × [3]

Sample	U _r '	U _L	U _{res}	T	Z	W	W'
No.	kV		kV	μs	Ω	kJ	kJ/kV
LD1	6,949	22,237	11,88	2000	34,050	7,227	1,040
LD2	6,949	22,237			34,050	7,227	1,040
LD3	6,907	22,102			33,844	7,168	1,038

- U_{res} : switching impulse residual voltage
- U_L, T, Z : see table 5 of IEC 60099-4 at clause 8.4.2
- W : = U_{res} × (U_L - U_{res}) × (T / Z)



Long-duration current impulse withstand test.

Test circuit: A0017

Date: July 25, 2007

Sample No.	Impulse No.	Charging voltage U_c kV	Oscillogram No.	Peak current I A	Residual voltage U_{res} kV	Energy E kJ
LD1	1	51,5		319	12,34	8,88
	2	52,0		326	12,44	8,98
	3	52,5	10	325	12,40	9,06
	4	52,5		329	12,38	9,10
	5	52,5		326	12,47	9,12
	6	52,5		327	12,48	9,17
	7	52,5		327	12,35	9,11
	8	52,5		326	12,38	9,10
	9	52,5	13	327	12,51	9,18
	10	52,5		327	12,35	9,12
	11	52,5		327	12,46	9,17
	12	52,5		326	12,45	9,17
	13	52,5		327	12,41	9,17
	14	52,5		327	12,45	9,14
	15	52,5		328	12,36	9,18
	16	52,5		328	12,45	9,12
	17	52,5		328	12,42	9,18
	18	52,5	16	327	12,46	9,18

Notes:

Measured waveshape	
virtual duration	virtual total duration
μs	μs
2010	2480

Oscilloscope settings			
	sampling division	Input	Attenuation
	μs	V_{div}	
Current	500	0,5	10:10
Voltage	500	1,0	10:5

ВЕРНО С ОРИГИНАЛА



Continued

Continued


Date: July 25, 2007

Sample No.	Impulse No.	Charging voltage U_0 kV	Oscillogram No.	Peak current I A	Residual voltage U_{res} kV	Energy E kJ
LD2	1	52,0		323	12,40	8,98
	2	52,5		325	12,44	9,01
	3	52,5	11	326	12,43	9,11
	4	52,5		327	12,55	9,10
	5	52,5		328	12,40	9,18
	6	52,5		328	12,40	9,19
	7	52,5		328	12,36	9,11
	8	52,5		327	12,48	9,15
	9	52,5	14	327	12,40	9,13
	10	52,5		327	12,38	9,12
	11	52,5		327	12,47	9,13
	12	52,5		327	12,49	9,16
	13	52,5		328	12,39	9,17
	14	52,5		327	12,38	9,16
	15	52,5		327	12,41	9,16
	16	52,5		327	12,32	9,11
	17	52,5		326	12,36	9,14
	18	52,5	17	325	12,30	9,12

Notes:

Measured waveshape	
virtual duration	virtual total duration
μs	μs
2010	2480

Oscilloscope settings			
	sampling division	input	Attenuation
	μs	V_{div}	
Current	500	0,5	10:10
Voltage	500	1,0	10:5



Continued

Continued

Date: July 25, 2007

Sample	Impulse	Charging voltage	Oscillogram	Peak current	Residual voltage	Energy
No.	No.	U_c kV	No.	I A	U_{res} kV	E kJ
LD3	1	52,0		327	12,34	9,00
	2	52,5		329	12,30	9,10
	3	52,5	12	328	12,37	9,11
	4	52,5		328	12,26	9,10
	5	52,5		327	12,25	9,08
	6	52,5		328	12,26	9,13
	7	52,5		328	12,32	9,09
	8	52,5		327	12,36	9,10
	9	52,5	15	328	12,33	9,14
	10	52,5		328	12,32	9,12
	11	52,5		328	12,31	9,11
	12	52,5		328	12,32	9,16
	13	52,5		328	12,35	9,10
	14	52,5		328	12,30	9,14
	15	52,5		328	12,43	9,18
	16	52,5		326	12,26	9,02
	17	52,5		326	12,30	9,06
	18	52,5	18	325	12,33	9,07

Notes:

Measured waveshape	
Virtual duration	virtual total duration
μs	μs
2010	2480

Oscilloscope settings			
	sampling division	input	Attenuation
	μs	V_{div}	
Current	500	0,5	10:10
Voltage	500	1,0	10:5

ВЯРНО С ОРИГИНАЛА



Continued

Long -duration current impulse withstand test.

(check the integrity of the internal parts with an additional shot at ambient temperature)

Test circuit: A0017


Date: July 25, 2007

Sample	Impulse	Charging voltage V_c	Oscillogram	Peak current I	Residual voltage V_r	Energy E
No.	No.	kV	No.	A	kV	kJ
LD1	19	52,5	19	327	12,36	9,12
LD2	19	52,5	20	327	12,33	9,11
LD3	19	52,5	21	328	12,27	9,08

Notes:

Measured waveshape	
virtual duration	virtual total duration
μs	μs
2010	2480

Oscilloscope settings			
	sampling division	input	attenuation
	μs	V_{div}	
Current	500	0,5	10:10
Voltage	500	1,0	10:5



continued

Long-duration current impulse withstand test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: August 02, 2007

Sample	Requested Current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.		kV	No.	μ s	kA	kV
LD1	I _n	30,1	22	8,8/18,8	10,14	16,05
LD2		30,1	23		10,17	15,94
LD3		30,1	24		10,20	15,88


Oscilloscope settings			
	sampling division	input	attenuation
	μ s	V _{div}	
Current	5	1,0	50:10
Voltage	5	1,0	20:5

Notes:

ВЯРНО С ОРИГИНАЛА



Circuit A0019



Power frequency supply


- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system


- R - Current shunt CESI No.31120; $R = 941,4 \Omega$
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522; attenuation 50:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090



Circuit A0120



Impulse generator

No. of stages 1
 Cg 4,98 μ F
 Lc 10 μ H

S - Spark-gap

Voltage measuring system.

D - Voltage divider SAGI; CESI No.13027
 - Electro optical system CESI No.11521/522;
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
 - Electro optical system CESI No.11517/518;
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

Handwritten signature

Handwritten signature


ВЯРНО С ОРИГИНАЛА



Handwritten signature

Handwritten signature

Circuit A0122



Impulse generator


- No. of stages 1
- Cg 2,49 μ F
- Lc 100 μ H
- S - Spark-gap

Voltage measuring system.


- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6037; R= 20 m Ω ; peak current= 250 kA
- Electro optical system CESI No 11517/519
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)



Circuit A0017



Impulse generator

- C₁ ... C₁₀ - capacitors 37,5 μF
- C₁₂ - capacitors 18,75 μF
- L₁ ... L₁₁ - inductors 666 μH
- L₁₂ - inductor (600+500) μH

S: - spark gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 mΩ
- Electro optical system CESI No 11521/11522.
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)


Handwritten signature

Handwritten signature


ВЯРНО С ОРГИНАЛА




Handwritten signature



CESI A7020276 Oscillogram n. 1






Handwritten signature

CESI A7020276 Oscillogram n. 2


ВЯРНО С ОРИГИНАЛА




Handwritten signature



CESI A7020276 Oscillogram n. 3






Handwritten signature

CESI A7020276 Oscillogram n. 4

ВЯРНО С ОРИГИНАЛА




Handwritten signature



CESI A7020276 Oscillogram n. 5

REDAZIONE






Handwritten signature

CESI A7020276 Oscillogram n. 6


ВЯРНО С ОРИГИНАЛА




Handwritten signature



CESI A7020276 - Oscillogram n. 7






MS

CESI A7020276 Oscillogram n. 8


ВЯРНО С ОРИГИНАЛА




[Handwritten signature]



CESI A7020276 Oscillogram n. 9






Handwritten signature


CESI A7020276 Oscillogram n. 10


ВЯРНО С ОРИГИНАЛА






CESI A7020276 Oscillogram n. 11







СЕСІ А7020276 Oscillogram n. 12


ВЕРНО С ОРИГИНАЛА





CESI A7020276 Oscillogram n. 13







MS

CESI A7020276 Oscillogram n. 14


ВЯРНО С ОРГИНАЛА




[Handwritten signature]



CESI A7020276 Oscillogram n. 15






Handwritten signature

CESI A7020276 Oscillogram n. 16

ВАРНО С ОРИГИНАЛА




Handwritten signature



CESI A7020276 Oscillogram n. 17

ВЕРНО С ОРИГИНАЛОМ







[Handwritten signature]

CEI A7020276 Oscillogram n. 18


ВЯРНО С ОРИГИНАЛА






CESI A7020276 Oscillogram n. 19

ESCLUSIVO C. SPINIMMATA





MS


CESI A7020276 Oscillogram n. 20

ВЯРНО С ОРИГИНАЛА


[Handwritten signature]




[Handwritten signature]



CESI A7020276 Oscillogram n. 21






Handwritten signature

CESI A7020276 Oscillogram n. 22


ВЯРНО С ОРИГИНАЛА






CESI A7020276 Oscillogram n. 23

STAMPED AREA





Handwritten signature


CESI A7020276 Oscillogram n. 24

ВАРНО С ОРИГИНАЛА



Handwritten signature

SCD



$U_{ref} = 6.22kV \text{ min}$
 $U_r = 6.5kV$
 $U_c = 5.2kV$
 $CREEPAGE = 254mm$
 $DRY \text{ ARC DISTANCE} = 127mm$

На основании чл. 2
 от ЗЗЛД
 2 2 ОТТ. 2007

Tyco Electronics


ENERGY DIVISION


BAY 100-109
 SHANNON IND. EST.
 SHANNON
 CO. CLARE
 IRELAND

Bowthorpe EMP Surge Arrester

THIS DRAWING AND THE INFORMATION SET FORTH HEREIN ARE THE PROPERTY OF TYCO ELECTRONICS LTD AND ARE TO BE HELD IN TRUST AND CONFIDENCE. PUBLICATION, REPLICATION, REUSE OR USE FOR ANY OTHER PURPOSE NOT EXPRESSLY AUTHORIZED IN WRITING BY TYCO ELECTRONICS LTD IS PROHIBITED.	DRN	J MULLIGAN	17/09/07	PCN		TITLE	DA1-6.5-NODONO SURGE ARRESTER	
	CHECK	B HARRIDYLE		MATL		DRG NO	DA1-6.5-NODONO	SHEET 1 OF 1
	APP	B HOGGWAH				REV	0	
	SCALE	1:1						

REVISIONS





DA1 - Distribution Surge Arrester
Operating Duty Test
Type Test Report

[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРИГИНАЛА



Tyco Electronics

Our commitment. Your advantage.

[Handwritten signature]



[Handwritten signature]

Test Report

Type	DA1
PPR Number	PPR-2279
Test Specification	Operating duty test IEC 60099-4 (2006-07) Ed. 2.1

Test Information:

Laboratory	CESI
Date	03/09/2007
External Test Ref	A7020582

Report Prepared by	M. Gregori
Test Verified by	A. Sironi
Test Approved by	V. Scarioni

Tyco Approvals:

R&D Manager

Brendan Normoyle

На основание чл. 2
от ЗЗЛД


Date 28/11/2007

Product Manager

Brian McGowan

Date 28/11/2007

For further information contact:
Tyco Electronics Energy Division
Bay 100-109
Shannon Industrial Estate
Co. Clare, Ireland
Tel: + 353-61-472885
Fax: + 353-61-472676
Email: mvsurgearresters@tycoelectronics.com



Client TYCO Electronics – Shannon (Ireland)

Tested equipment Polymer-housed metal-oxide surge arrester section type DA1 fitted with disconnecter assembled in thermal model

Tests carried out High current operating duty test

Standards/Specifications IEC 60099-4 – Edition 2.1 (2006-07)

Test date from July 27, 2007 to August 02, 2007

PUBBLICATO A7020582 (PAD - 980958)

The results reported in this document relate only to the tested equipment.
 Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 25 No. of pages annexed 44

Issue date

Prepared

Verified

Approved



На основание чл. 2
от ЗЗЛД


CESI
 Centro Elettrotecnico
 Sperimentale Italiano
 Giacinto Motta spa

Via R. Rubattino 54
 20134 Milano - Italia
 Telefono +39 022125.1
 Fax +39 022125440
 http://www.cesi.it

Capitale sociale 8 550 000 Euro
 interamente versato
 Codice fiscale e numero
 iscrizione CCIAA 00793580150

Registro Imprese di Milano
 Sezione Ordinaria
 N. R.E.A. 429222
 P.I. IT00793580150

ВЪРНО С ОПРИЖНАЛА



Tests witnessed by:

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object. This drawing, identified by CESI and numbered A7027909 No. 1, is annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked: ----

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with impulse current : peak value: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3 \%$ time: $\pm 3,5 \%$
- dielectric tests with direct voltage : voltage: $\pm 3 \%$ time: $\pm 3,5 \%$
- atmospheric conditions : temperature: $\pm 2 \text{ }^\circ\text{C}$; pressure: $\pm 0,133 \text{ kPa}$; humidity: $\pm 10 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory information



Receipt date of the sample July 16, 2007

Test location CESI - Via Rubattino 54 - Milan

CESI testing team Mr L. Podavitte

Test laboratory P177

Activity code 80090B



content	page	test date
<p><i>[Signature]</i></p> <p>Test object characteristics</p> <p>Photograph of the test object</p> <p>Reference standard</p> <p>Test carried out</p> <p>Test object identification</p> <p>Test procedure</p> <p>Visual inspection and summary of test result</p> <p>High current operating duty test</p> <p>Technical data</p>	<p>4</p> <p>5</p> <p>6</p> <p>6</p> <p>6</p> <p>7</p> <p>8</p> <p>from page 9 to 17</p> <p>from page 18 to 25</p>	<p>July 27 to August 02, 2007</p>
<p>Pages annexed:</p> <p>Oscillograms n. 42 pages</p>		
<p>Document annexed:</p> <p>Tyco Electronics drawing n.DA1-6.5-NODONO, CESI n. A7027909 - n. 1 page</p> <p>Tyco Electronics Thermal equivalency; CESI n. A7027911 - n.1 page</p>		

ВАРНО С ОРГИНАЛА



[Signature]

Test object characteristics

type: Polymer-housed metal-oxide surge arrester section fitted with disconnector assembled in thermal model

electrical characteristics (assigned by the client)


Manufacturer's name	TYCO Electronics – Shannon (Ireland)
Type	DA1
Nominal discharge current – I_n [kA]	10
Rated voltage – U_r [kV]	1,045 x U_{ref}
Continuous operating voltage - U_c [kV]	0,836 x U_{ref}
Reference current - I_{ref} [mA]	5,0
Line discharge class	1
Standard rated frequency - [Hz]	50/60
year of manufacture	2007

NOTE:

The thermal model was supplied by the manufacturer

The verification of the thermal equivalency according to annexe B was carried out by the Client

(see Tyco Electronics document DA1 Class 1 Surge Arrester Thermal equivalency*; CESI no.A7027911)



View of the test object




Photo no. 1

Polymer-housed metal-oxide surge arrester section fitted with disconnector assembled in thermal model

ВЯРНО С ОРИГИНАЛА



Reference standard

IEC 60099-4 (2006-07) – Edition 2.1 – Clause 10.8.5


“ Metal-oxide surge arresters without gaps for a.c. system “

Test carried out

test carried out	number of sample tested
High current operating duty test	3

Test object identification

test object names	identification of test sample (assigned by the CESI)
Polymer –housed surge arrester section assembled in thermal model fitted with disconnecter	OD1-OD2-OD3



Test procedure

The test procedure consisted of the following sequence:

- a) Measurement of the power frequency reference voltage at the reference current
- b) Measurement of the lightning impulse residual voltage at the nominal discharge current
- c) Calculation of the voltage correction factors according to the reference standard
- d) Conditioning 1: application of twenty impulses $8/20 \mu\text{s}$ at the nominal discharge current superimposed to the power frequency voltage at 1,2 times U_c' in four groups of five impulses
 - interval between impulses of the same group: 50-60 seconds
 - interval between groups: 30 minutes
 - polarity of the impulses: same as that of the half cycle of power frequency voltage during which it occurred (positive)
 - synchronization of the impulses: 60 electrical degrees before the peak of the power frequency.
- e) Conditioning 2: application of one high current impulse $4/10 \mu\text{s}$ at 100 kA
- f) Heating in an oven at the temperature of 60°C till thermal equilibrium
- g) Application of a second high current impulse $4/10 \mu\text{s}$ at 100 kA. A time shorter than 100 ms after the application of the second high current shot energization at U_r' for 10 sec. and then at U_c' for 30 min. to verify the thermal stability.
- h) Measurement of the lightning impulse residual voltage at nominal discharge current for comparison with initial value with two impulses at 50 sec to 60 sec. time interval in between

TEST RESULT

The visual inspection of the sample after the test has revealed no sign of physical damage.

The variation of lightning impulse residual voltage before and after the test was less than 5% (maximum allowed variation according to reference standard is 5%).

The oscillographic record of the two last lightning impulse at nominal discharge current did not reveal any sign of internal discharge.

The thermal stability was achieved

The disconnectors did not operate

The acceptance criteria are fulfilled. The test result is positive



ВЯРНО С ОРИГИНАЛА




Variation of lightning impulse residual voltage at I_n

Sample	before test		after test		Variation
	discharge current	residual voltage	discharge current	residual voltage	
	kA	kV	kA	kV	%
OD1	10,03	16,00	9,95	16,25	+ 1,50
OD2	10,02	16,09	10,10	16,23	+ 0,87
OD3	10,02	16,07	10,12	16,15	+0,50

Visual inspection after the test

The visual inspection of the surge arresters samples after the test has revealed no sign of physical damage



High current operating duty test.

Reference voltage test

Test circuit: A0019

Date: July 27, 2007

Sample No. OD1						
Oscillogram	voltage	current	current	current	power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
1	6,70	5,11	4,08	1,59	6,62	--

Sample No. OD2						
Oscillogram	voltage	current	current	Current	power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
2	6,72	4,90	5,13	1,69	7,12	--

Sample No. OD3						
Oscillogram	voltage	current	current	Current	power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
3	6,68	4,94	5,11	1,69	7,06	--

Handwritten signature

Handwritten signature

ВЯРНО С ОРИГИНАЛА



Handwritten signature

High current operating duty test.

Lightning impulse residual voltage measurement before the test


Test circuit: A0120

Date: July 27, 2007

Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current kA	Residual Voltage kV
OD1	I _n	29,9	4	8,8/19,0	10,03	16,00
OD2		29,9	5		10,02	16,09
OD3		29,9	6		10,02	16,07

	Oscilloscope settings		
	sampling division μ s	input V _{div}	Attenuation
Current	5	1,0	50:10
Voltage	5	0,5	20:5

Notes:



Voltage correction factor and energy calculations

Date: July 25, 2007

Sample	U_{ref} [1]	kU_r [2]	kU_c [3]	U_r' [4]	U_c' [5]	U_s' [6]
No.	kV			kV	kV	kV
OD1	6,70	1,045	0,836	7,00	5,60	6,720
OD2	6,72			7,02	5,62	6,744
OD3	6,68			6,98	5,58	6,701

- [1] U_{ref} : measured reference voltage
- [2] kU_r : factor claimed by the manufacturer for calculation of U_r'
- [3] kU_c : factor claimed by the manufacturer for calculation of U_c'
- [4] U_r' : corrected rated voltage [4] = [1] × [2]
- [5] U_c' : corrected continuous operating voltage [5] = [1] × [3]
- [6] U_s' : corrected voltage to be applied during the conditioning [6] = 1,2 × [5]



High current operating duty test.

Conditioning: application of twenty 8/20 μ s current impulses (first part)

Test circuit: A0015


Date: July 27, 2007

Imp. No.	Osc. No.	Sample No. OD1		Osc. No.	Sample No. OD2		Osc. No.	Sample No. OD3	
		charging kV	peak current kA		Charging kV	peak current kA		charging kV	peak current kA
1	7	38,0	10,0		38,0	10,0		38,0	10,0
2		38,0	10,0		38,0	10,0		38,0	10,0
3		38,0	10,0		38,0	10,0		38,0	10,0
4		38,0	10,0		38,0	10,0		38,0	10,0
5	8	38,0	10,0	9	38,0	10,0	10	38,0	10,0
6		38,0	10,0		38,0	10,0		38,0	10,0
7		38,0	10,0		38,0	10,0		38,0	10,0
8		38,0	10,0		38,0	10,0		38,0	10,0
9		38,0	10,0		38,0	10,0		38,0	10,0
10	n.r.	38,0	10,0	12	38,0	10,0	13	38,0	10,0
11		38,0	10,0		38,0	10,0		38,0	10,0
12		38,0	10,0		38,0	10,0		38,0	10,0
13		38,0	10,0		38,0	10,0		38,0	10,0
14		38,0	10,0		38,0	10,0		38,0	10,0
15		38,0	10,0		38,0	10,0		38,0	10,0
16		38,0	10,0		38,0	10,0		38,0	10,0
17		38,0	10,0		38,0	10,0		38,0	10,0
18		38,0	10,0		38,0	10,0		38,0	10,0
19		38,0	10,0		38,0	10,0		38,0	10,0
20	14	38,0	10,0	15	38,0	10,0	16	38,0	10,0

Power frequency voltage applied to the test sample during current impulse applications [kV]	Sample No. OD1	Sample No. OD2	Sample No. OD3
	6,720	6,744	6,701

	Oscilloscope settings		
	sampling division	Input	attenuation
	ms	V _{div}	
Current	10	1,0	50:10
Voltage	10	1,0	20:5

Notes:



High current operating duty test.

Conditioning: Application of the first impulse 100 kA 4/10 μ s high current impulses (second part)

Test circuit: A0121

Date: July 30, 2007

Sample	Impulse	Charging voltage	Oscillogram	Discharge current	Residual Voltage	Energy	current waveshape	Opposite polarity
No.	No.	kV	No.	kA	kV	kJ	μ s	%
OD1	1	76,3 x 2	17	96,2	34,0	15,1	4,5/9,8	8,4
OD2	1	76,3 x 2	18	96,5	35,0	15,3		
OD3	1	76,3 x 2	19	97,5	35,0	15,6		

Oscilloscope settings			
	sampling division	input	attenuation
	μ s	V _{div}	
Voltage	2	1,0	50:5
Current	2	1,0	300:10

Notes:

ВЕРНО С ОРГИНАЛА

НАЦИОНАЛНО ЕНЕРГЕТИЧЕСКО
ФИЛИАЛ
15
ПРОДАН

High current impulse operating duty test.

Application of the second high current impulse, of the rated voltage U_r' and evaluation of thermal stability

Test circuit: A0123 – A0020 – A0131

Sample No.: OD1

Preheating temperature: 61 °C

Date: July 31, 2007

Second high current impulse application


Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Energy kJ	Current waveshape μ s
20	76,3 x 2	33,0	100,0	17,0	4,5/9,8

U_r' voltage application

Oscillogram No.	Time s	Voltage kV	Current + mA _{cr}	Current - mA _{cr}	Power W
21	0	7,00	61,0	78,0	---
22	10		25,0	38,0	---

U_c' voltage application

Oscillogram No.	Time min	Voltage kV	Current + mA _{cr}	Current - mA _{cr}	Power W
23	0	5,60	2,31	2,44	4,10
	5		2,13	2,25	2,18
	10		2,00	2,03	2,07
24	15		1,96	2,00	1,83
	20		1,94	1,98	1,70
	25		1,91	1,95	1,68
25	30		1,89	1,91	1,65



continued

continued

Sample No.: OD2

Preheating temperature: 61 °C

Date: July 31, 2007

Second high current impulse application

Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Energy kJ	Current μ s
26	76,3 x 2	33,0	100,0	17,0	4,5/9,8


U_r' voltage application

Oscillogram No.	Time s	Voltage kV	Current + mA _{cr}	Current - mA _{cr}	Power W
27	0	7,02	37,0	49,0	---
28	10		24,0	37,0	---

U_c' voltage application

Oscillogram No.	Time min	Voltage kV	Current + mA _{cr}	Current - mA _{cr}	Power W
29	0	5,60	2,18	2,19	3,10
	5		2,00	2,09	2,02
	10		1,94	2,01	1,74
30	15		1,92	1,99	1,65
	20		1,90	1,97	1,56
	25		1,89	1,96	1,53
31	30		1,90	1,95	1,51

ВЯРНО С ОРИГИНАЛА



continued

continued

Sample No.: OD3

Preheating temperature: 61 °C

Date: July 31, 2007

Second high current impulse application



Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Energy kJ	Current μ s
32	76,0 x 2	32,5	100,0	14,8	4,5/9,8

U_r' voltage application

Oscillogram No.	Time s	Voltage kV	Current	Current	Power W
			+ mA _{cr}	- mA _{cr}	
33	0	6,98	58,0	74,0	---
34	10		15,0	27,0	---

U_c' voltage application

Oscillogram No.	Time min	Voltage kV	Current	Current	Power W
			+ mA _{cr}	- mA _{cr}	
35	0	5,58	2,10	2,10	2,89
	5		2,00	2,06	1,95
	10		1,96	1,98	1,89
36	15		1,95	1,97	1,84
	20		1,94	1,96	1,80
	25		1,93	1,95	1,78
37	30		1,91	1,94	1,69



continued

High current impulse operating duty test.

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: August 02, 2007


Sample No.	Requested current	Charging voltage kV	Oscillogram No.	Current waveshape μ s	Discharge current kA	Residual voltage kV
OD1	I_n	29,9	38	8,8/19,0	9,90	16,14
		30,1	39		9,95	16,25
OD2		30,2	40		10,10	16,18
		30,2	41		10,10	16,23
OD3		30,2	42		10,20	16,12
		30,1	43		10,12	16,15

Oscilloscope settings			
	sampling division μ s	input V_{div}	attenuation
Current	5	0,5	50:5
Voltage	5	1,0	20:5


Notes:

MS

[Handwritten signature]



Circuit A0019



Power frequency supply


- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system


- R - Current shunt CESI N° 31120; $R = 941,4 \Omega$
- Electro optical system CESI N°.-.; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI N° 6318

Voltage measuring system

- D - Voltage divider SAGI; CESI N° 11120
- Electro optical system CESI N° 11520/11524; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI N° 6318



Circuit A0120



Impulse generator

- No. of stages 1
- Cg 4,98 μ F
- Lc 10 μ H
- S - Spark-gap

Voltage measuring system.

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No. 11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No. 11517/518
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

Handwritten signature


Handwritten signature

ВЪРНО С ОРИГИНАЛА



Handwritten signature

Circuit A0122



Impulse generator


- No. of stages 1
- Cg 4,98 μ F
- Lc 100 μ H
- S - Spark-gap

Voltage measuring system.


- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/522; attenuation 5:5
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)



Circuit A0015



Impulse generator

No. of stages: 1

- C_g - Capacitor 2,49 μF
- L - Inductance of the circuit
- L_c - Inductor 10 μH
- S - Spark gap

One resistor block has been added

Power frequency supply

- RE - Regulator type specialtrasfo; power 20 kVA; voltage 380 V/ 220 V
- T - Transformer type Pivi; power 30 kVA; voltage 220 V/ 15 kV
- B - Blocking gap


Current measuring system

- Sh_1 - Current shunt CESI No.6042; $R = 0,002 \Omega$
- Electro optical system CESI No.11517/11518; attenuation 20:5
- OSC - Oscilloscope type Tektonix 540A; CESI No.13217 (on channel No.1)


Voltage measuring system

- D - Voltage divider SAGI ; CESI No.1120; $k = 1010$
- Electro optical system CESI No.11520/11521; attenuation 50:5
- OSC - Oscilloscope type Tektonix 540A; CESI No.13217 (on channel No.2)

ВЯРНО С ОРИГИНАЛА



Circuit A0121



Impulse generator

No. of stages 2
 Cg 3,32 μ F

S - Spark-gap



Three blocks in series have been added

Voltage measuring system.


- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No11517/518
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)



Circuit A0123



to circuit A0020

Impulse generator circuit

No. of stages 2


Cg 3,32 μ F

S - spark-gap

ВЯЛНО С ОРИГИНАЛА



Circuit A0020



Impulse generator circuit A0124

I - Circuit-breaker

Impulsive current measuring system

Sh₁ - Current shunt CESI No.6039; R= 20 m Ω

- Electro optical system CESI No.11517/518; attenuation 5:5

OSC₁ - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)

Power frequency circuit A0130

Voltage measuring system.

D - Voltage divider SAGI; CESI No.11120

- Electro optical system CESI No.8009/8015; attenuation 50:5


OSC₁ - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

OSC₂ - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090 (on channel No.2)


Power frequency current measuring system

Sh₂ (TOV) - Current shunt CESI R= 500 Ω - Electro optical system CESI No.8011/8017

OSC₂ - Oscilloscope type TEKTRONIX TDS 744A; CESI No.13937 (on channel No.1)




Circuit A0131




Power-frequency circuit

from 380Vac power supply


- R₁ single-phase voltage regulator CORMES; power 20 kVA; voltage 380/0 ÷ 220 Vac
- R₂ single-phase voltage regulator CORMES; power 10 kVA; voltage 380/0 ÷ 220 Vac
- T₁ voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200-400 V/15-30 kV






CESI A7020582 Oscillogram n. 1

СЕРТИФИКАТ






Handwritten signature

CESI A7020582 Oscillogram n. 2


ВАРНО С СЕРТИФИКАТА






CESI A7020582 Oscillogram n. 3

BARNO C. OPTIMIZAZIONE






MS

CESI A7020582 Oscillogram n. 4

ВЯРНО С ОРИГИНАЛА




[Handwritten signature]



CESI A7020582 Oscillogram n. 5

ПРОТО С ОПИМЛАНЈА






MS

CESI A7020582 Oscillogram n. 6

ВЕРНО С ОРИГИНАЛА




[Handwritten signature]



CESI A7020582 Oscillogram n. 7

ВЕРНО С СЕРИЯМ






[Handwritten signature]

СЕСІ А7020582 Oscillogram n. 8

ВЯРНО С ОРИГИНАЛА




[Handwritten signature]



CESI A7020582 Oscillogram n. 9

ВЕРНО С ОФОРМЛЕНА






Handwritten signature

CESI A7020582 Oscillogram n. 10

ВЯРНО С ОРИГИНАЛА





Handwritten signature



CESI A7020582 Oscillogram n. 12

ВАННО С ОРНИТИНАТА







Handwritten signature

CESI A7020582 Oscillogram n. 13

ВЯРНО С ОРИГИНАЛА





Handwritten signature



CESI A7020582 Oscillogram n. 14

ВЕРИЛИС ОФИЦИАЛНО





Handwritten signature


CESI A7020582 Oscillogram n. 15

ВЕРНО С ОПИШАННЯ

Handwritten signature





Handwritten signature



CESI A7020582 Oscillogram n. 16

РЕШЕНО С ОПТИМАЛИТА







MS

CESI A7020582 Oscillogram n. 17

ВЕРНО С ОРИГИНАЛА





[Handwritten signature]



CESI A7020582 Oscillogram n. 18

СЕРТИФИКАТ






Handwritten signature

CESI A7020582 Oscillogram n. 19

ВЯРНО С ОРИГИНАЛА





Handwritten signature



CESI A7020582 Oscillogram n. 20

ВЕРИТЬСЯ С ОПРЕДЕЛЕНИЕМ







CESI A7020582 Oscillogram n. 21

Handwritten signature

ВЪРНО С ОПИШИВАТА




Handwritten signature



CESI A7020582 Oscillogram n. 22

ВЕРНО С ОРИГИНАЛОМ






CESI A7020582 Oscillogram n. 23

ВЯРНО С ОПРИКЛАДА





Handwritten signature



CESI A7020582 Oscillogram n. 24

REPUBBLICA ITALIANA






Handwritten signature

CESI A7020582 Oscillogram n. 25

ВЫПО С ОРВИМАЛА





Handwritten signature



CESI A7020582 Oscillogram n. 26

RSPIO C OPTIMIZAREA








Handwritten signature

CESI A7020582 Oscillogram n. 27

ВЕРНО С ОРИГИНАЛА





Handwritten mark



CESI A7020582 Oscillogram n. 28

ВЕРНО С ОРИГИНАЛОМ






MS

CESI A7020582 Oscillogram n. 29

ВЯРНО С ОРИГИНАЛА





[Handwritten signature]



CESI A7020582 Oscillogram n. 30

ВОПРОС ОТВЕТА





MS


CESI A7020582 Oscillogram n. 31

ВЪРНО С ОРИГИНАЛА

[Signature]





[Signature]



CESI A7020582 Oscillogram n. 32

БАНКА С ОФИСАМИ






Handwritten signature


CESI A7020582 Oscillogram n. 33

ВЪРНО С ОРЪЖИНАТА




Handwritten signature


Handwritten signature



CESI A7020582 Oscillogram n. 34

ВОПРОС О ПОВТОРЕНИИ







Handwritten signature

CESI A7020582 Oscillogram n. 35

ВАЖНО С ОРИГИНАЛА





Handwritten signature



CESI A7020582 Oscillogram n. 36

РЕШЕНО С ОПИШЛИВАТА






Handwritten signature

CESI A7020582 Oscillogram n. 37

ВЪРНО С ОРИГИНАЛА





Handwritten signature



CESI A7020582 Oscillogram n. 38

REDAZIONE C. COMMUNICAZIONE







Handwritten signature

CESI A7020582 Oscillogram n. 39

ВАРНО С ОРИГИНАЛА





Handwritten signature



CESI A7020582 Oscillogram n. 40

ДИПЛОМ С ОПИШКАМИ







MS

CESI A7020582 Oscillogram n. 41

ВАРНО О СУДИНАТА





[Handwritten signature]



CESI A7020582 Oscillogram n. 42

ВЕРНО С ОРИГИНАЛА






Handwritten signature

CESI A7020582 Oscillogram n. 43

ВЯРНО С ОРИГИНАЛА



Handwritten signature


DATE:

22 OCT. 2007


На основание чл. 2
от ЗЗЛД

Tyco Electronics


DA1 Class 1 Surge Arrester Thermal equivalency



ВЕРНО С ОРИГИНАЛОМ



SCD



На основание чл. 2
от ЗЗЛД

$U_{ref} = 6.22kV \text{ min}$
 $U_r = 6.5kV$
 $U_c = 5.2kV$
 CREEPAGE = 254mm
 DRY ARC DISTANCE = 127mm

Tyco Electronics


ENERGY DIVISION

BAY 100-109
SHANNON IND. EST.
SHANNON
CO. CLARE
IRELAND

Bowthorpe EMP Surge Arrester


THIS DRAWING AND THE INFORMATION SET FORTH HEREIN ARE THE PROPERTY OF TYCO ELECTRONICS LTD AND ARE TO BE HELD IN TRUST AND CONFIDENCE. PUBLICATION, CIRCULATION, REPRODUCTION OR USE FOR ANY OTHER PURPOSE NOT EXPRESSLY AUTHORIZED IN WRITING BY TYCO ELECTRONICS LTD IS PROHIBITED.	DRN	J MULLIGAN	17/09/07	PCN		TITLE	DA1-6.5-NODONO		
	CHECK	B HOGHOYLE		HAT'L		SURGE ARRESTER			
	APP	B MCGOWAN							
	SCALE		1:1					SHEET 1 OF 1	REV 0

ВЪРНО С ОПРИНАТА



ВЪННО СЪВЕЩАНИЕ





DA1 - Distribution Surge Arrester
Short Circuit Tests
Type Test Report

MB

[Handwritten mark]



Tyco Electronics

Our commitment. Your advantage.

ВЯРНО С ОРИГИНАЛА



[Handwritten mark]

Test Report

Type	DA1
PPR Number	PPR-2280
Test Specification	Short circuit tests IEC 60099-4 (2006-07) Ed. 2.1


Test Information:

Laboratory	CESI
Date	13/11/2007
External Test Ref	A7029908
Report Prepared by	P. Beccarini
Test Verified by	A. Sironi
Test Approved by	V. Scarioni

Tyco Approvals:

R&D Manager Brendan Normoyle	На основание чл. 2 от ЗЗЛД	Date 28/11/2007
Product Manager Brian McGowan		Date 28/11/2007

For further information contact:
Tyco Electronics Energy Division
Bay 100-109
Shannon Industrial Estate
Co. Clare, Ireland
Tel: + 353-61-472885
Fax: + 353-61-472676
Email: mvsurgearresters@tycoelectronics.com



Client TYCO ELECTRONICS
Shannon – IRELAND

Tested equipment Polymer housed metal-oxide surge arresters

Tests carried out Short circuit tests

Standards/Specifications IEC 60099-4 (2006-07)

Test date from June 25, 2007 to June 26, 2007

PUBBLICATO A7029908 (FAD - 984345)

The results reported in this document relate only to the tested equipment.
Partial reproduction of this document is permitted only with the written permission from CESI

No. of pages 20 No. of pages annexed 13


Issue date November 13, 2007

Prepared Unit LABORATORIE

Verified Unit LABORATORIE

Approved Area COMPONENTS

На основание чл. 2
от ЗЗЛД



Tests witnessed by

Mr. Tim Smith

Tyco Electronics

Identification of the object Effected.

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawing identified by CESI and numbered A7029970 No.1 is annexed to this document.

Only for laboratory requirement, in order to reproduce the test conditions, all the laboratory data are contained in the document marked: A7017386


The measurement uncertainties of the test results reported in the document are the following:

voltage: $\pm 5\%$; current: $\pm 5\%$; time: $\pm 5\%$; temperature: $\pm 2\text{ }^\circ\text{C}$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to a confidence level of about 95 %) and have to be considered as maximum values.

Receipt date of the sample

June 25, 2007




Contents	Page	Test date
Rated characteristics of the tested object assigned by the Client		
Test arrangement	4	
Tests performed	5	
High-current short-circuit test with 21,3 kA for 0,21 s	6	June 25, 2007
Low-current short-circuit test with 617 A for 1,00 s	7	June 26, 2007
High-current short-circuit test with 11,3 kA for 0,21 s	8	June 26, 2007
High-current short-circuit test with 6,28 kA for 0,21 s	9	June 26, 2007
Test circuit	10	
Photos	11 to 20	
Pages annexed		
Oscillograms (No.12)		
Reference documents annexed		
Client's drawing - CESI Ref.No.A7029970 (No.1 page)		

ВЕРНО С. ОРИГИНАЛА




Rated characteristics of the tested object assigned by the Client

Metal-oxide surge arrester	
Manufacturer	Tyco Electronics
Type	DA1
Drawing	DA1-39G-NONONO
Rated voltage (Ur)	39 kV
Maximum continuous operating voltage (Uc)	31,2 kV
Rated frequency	50/60 Hz
Nominal discharge current (8/20 μ s impulse shape)	10 kA
Line discharge class	1
Pressure relief class	
High current	for 0,2 s ; 21 kA



D8058 - Test arrangement



MS


- 1 : Surge arrester
- 2 : Flexible conductor
- 3 : Flexible conductor
- 4 : Support
- 5 : Squared enclosure

- A : 1,0 m
- B : 0,4 m
- C : 1,8 m
- D : 1,6 m

[Handwritten signature]

The arrester to be tested was installed on a support at 1,6 m to ground in the middle of a squared enclosure of 1,8 m each side. The live side of the supply was connected to the upper end of the arrester while the return circuit, earthed, was connected to the lower end. The earth conductor was directed to the opposite direction as the incoming live conductor

ВЕРНО С ОРИГИНАЛА



[Handwritten signature]

High-current short-circuit test with 21,3 kA for 0,21 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

Test arrangement : See D8058

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source
 The short-circuit current of the auxiliary low power source has been set at about 12,0A
 The voltage applied to the arrester was increased in order to get a current equal to 100mA (0-peak)(i.e.61 kVpk) and kept at this value till arrester failure
 The pre-failure process duration was 3 minutes and 20 seconds
 The short-circuit test was performed 4 minutes and 30 sec after the completion of the pre-failure process

No.	Oscillogram		Prospective test current		Peak value
	No.	Sheets	rms value	kA	
2		1	21,3	kA	59,6

Condition of the apparatus before the tests: new; see photos No.1 and 2 (taken after the pre-failure)

Date: June 25, 2007


Test No.	Oscillogram		Arrester Under test	Duration	Test voltage	Test current		Time of flame extinction after the test	Venting time	Notes
	No.	Sheets				Peak value	rms value			
1	4	2	BE13	0,21 s	34,0 kV	55,4 kA	21,3 kA	- s	ms	No.
								-	0,85	-

Condition of the apparatus after the tests: see photos No.3 and 4.

- There was no violent shattering.
- The arrester structure was not damaged.
- The arrester remained connected to the supply and return circuits.
- No resistor or housing fragments were ejected inside or outside the enclosure.
- The surge arrester did not catch fire.

Acceptance criteria: Satisfied

Test result: Positive



Low-current short-circuit test with 617 A for 1,00 s

Test circuit : See D0046 Power factor : $<0,15$ Frequency : 50 Hz

Test arrangement : See D8058

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source. The short-circuit current of the auxiliary low power source has been set at about 12,0A. The voltage applied to the arrester was increased in order to get a current equal to 100mA (0-peak)(i.e.61 kVpk) and kept at this value till arrester failure

The pre-failure process duration was 3 minutes and 55 seconds
The short-circuit test was performed 4 minutes and 35 sec after the completion of the pre-failure process

Oscillogram No.	Prospective test current		Peak value kA
	Sheets	rms value A	
9	1	617	-

Condition of the apparatus before the tests: new; see photo No.5 (taken after the pre-failure)

Date: June 26, 2007

Test No.	Oscillogram		Arrester Under test	Duration s	Test voltage kV	Test current		Time of flame extinction after the test s	Venting time ms	Notes
	No.	Sheets				Peak value A	rms value A			
11	11	2	BE12	1,00	34,0	-	617	30	6,10	-

Condition of the apparatus after the tests: see photo No.6

- There was no violent shattering.
- The arrester structure was not damaged.
- The arrester remained connected to the supply and return circuits.
- No resistor or housing fragments were ejected inside or outside the enclosure.

Acceptance criteria: Satisfied
Test result: Positive



[Handwritten signature]

High-current short-circuit test with 11,3 kA for 0,21 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

Test arrangement : See D8058

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source
 The short-circuit current of the auxiliary low power source has been set at about 12,0A
 The voltage applied to the arrester was increased in order to get a current equal to 100mA (0-peak)(i.e.61 kVpk) and kept at this value till arrester failure
 The pre-failure process duration was 3 minutes and 55 seconds
 The short-circuit test was performed 4 minutes and 30 sec after the completion of the pre-failure process

Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
16	1	11,3 kA	30,4 kA

Condition of the apparatus before the tests: new; see photo No.7 (taken after the pre-failure)

Date: June 26, 2007


Test	Oscillogram	Arrester Under test	Duration	Test voltage	Peak value	Test current rms value	Time of flame extinction after the test	Venting time	Notes
No.	No.	Sheets	s	kV	kA	kA	s	ms	No.
3	17	2	0,21	34,0	26,1	11,3	-	1,30	-

Condition of the apparatus after the tests: see photo No.8

- There was no violent shattering.
- The arrester structure was not damaged by the test.
- The arrester remained connected to the supply and return circuits.
- No resistor or housing fragments were ejected inside or outside the enclosure.
- The surge arrester did not catch fire.

Acceptance criteria: Satisfied

Test result: Positive



High-current short-circuit test with 6,28 kA for 0,21 s

Test circuit : See D0046 Power factor : <0,15 Frequency : 50 Hz

Test arrangement : See D8058

To achieve the internal discharge, the surge arrester has been faulted by means of an overvoltage application using an auxiliary low power source. The short-circuit current of the auxiliary low power source has been set at about 12,0A.

The voltage applied to the arrester was increased in order to get a current equal to 100mA (0-peak)(i.e.61 kVpk) and kept at this value till arrester failure.

The pre-failure process duration was 4 minutes and 10 seconds.

The short-circuit test was performed 4 minutes and 40 sec after the completion of the pre-failure process.

Oscillogram		Prospective test current	
No.	Sheets	rms value	Peak value
21	1	6,28 kA	16,5 kA

Condition of the apparatus before the tests: new; see photo No.9 (taken after the pre-failure)

Date: June 26, 2007


Test No.	Oscillogram No.	Arrester Under test No.	Duration s	Test voltage kV	Test current		Time of flame extinction after the test s	Venting time ms	Notes
					Peak value kA	rms value kA			
4	22	2	0,21	34,0	13,7	6,20	-	1,10	No. -

Condition of the apparatus after the tests: see photo No.10

- There was no violent shattering.
- The arrester structure was not damaged by the test, the polymer housing was found partly detached from the arrester body.
- The arrester remained connected to the supply and return circuits.
- No resistor or housing fragments were ejected inside or outside the enclosure.
- The surge arrester did not catch fire.

Acceptance criteria: Satisfied

Test result: Positive




Test Report


CESI


Approved

Test circuit D0046



Symbols used in this diagram are the same as those on the oscillograms.





MS

Photo No.1

ВРЪНО С ОПИТНАТА








Photo No.2





ME

Photo No.3

ВЯРНО С ОРЪЖИНАТА








Photo No.4





MS

Photo No.5

[Handwritten signature]

ВЯРНО С ОРИГИНАЛА



[Handwritten signature]






Photo No.6





MS

Y

Photo No.7

ВЪРНО С ОРЪЖИЯТА



[Signature]






Photo No.8





MS

Photo No.9

ВЕРНО С ОРИГИНАЛА



[Handwritten signature]






Photo No.10




dT = 205,3 mSec
I.peak = 59,57 kA
I.rms = 21,29 kA



U 40 kV

I 25 kA

VENT 5 V




Seq: 1 SEC Osc: 0 Meas: HF1 - 1

39,232 60,000 80,000 100,000 120,000 140,000 160,000 180,000 200,000 220,000 240,000 266,757
2,000 [msec/div.]

CEESI P141 A70173886/0002

dT = 215,6 mSec



43,762 60,000 80,000 100,000 120,000 140,000 160,000 180,000 200,000 220,000 240,000 260,000 273,342

2,000 [msec/div.]

Seq: 1 SEC Osc: 0 Meas: HFI - 1

РАДИО С. СРНИКЛАД

U 40 KV




I 25 kA

VENT 5 V


CESI P141 A7017386/0004

I. peak = 55,40 kA
dT = 845,0 uSec




Seq: 1 SEC Osc: 0 Meas: HF1 - 1

ВЕРИТЕЛЬНО-ОПЫТАЛЬНАЯ



I_{rms} = 614,22 A



РЕЦЕПТ СЕРВИСА

U 40 KV




I 0,70 kA

VENT 5 V

CESI P141 A7017386/0009


Seq: 1SEC Osc: 0 Meas: HF1 - 1

dt = 1,004 Sec
dT = 6,1 mSec



ИНСТИТУТ СПИНАЛТА

U 40 KV




I 0,70 KA

VENT 5 V

40,332 50,000 60,000 70,000 80,000 90,000 100,000 110,000 119,427
1,000 [msec/div.]

CESI P141 A7017386/0011

I.rms= 11,32 kA
I.peak= 30,42 kA
dT= 213,5 mSec



ME

9

U 40 KV

I 10 KA

VENT 5 V

ВЕРНО С ОПИШУВАНА




41,688 60,000 80,000 100,000 120,000 140,000 160,000 180,000 200,000 220,000 240,000 260,000 277,588

2,000 [msec/div.]


Seq: 1SEC Osc: 0 Meas: HF1 - 1

dT = 211,8 mSec
I_{r-peak} = 26,05 kA



ВЕРНО С ОПТИКАМИ

U 40 kV




I 10 kA

VENT 5 V

CESI P141 A7017386/0017

dT = 211,8 mSec
I_{peak} = 26,05 kA
dT = 1,3 mSec




U 40 kV

I 10 kA

VENT 5 V


ПРОЦЕДУРА
ОПЕРАТИВНА



CESI P141 A7017386/0017

Seq: ISEC Osc: O Meas: HFI - 1

I.peak= 16,47 kA
I.rms= 6,28 kA
dT= 212,7 mSec



РАДИО С. СЕРВИС

U 40 kV




16 kA

VENT 5 V

CESI P141 A7017386/0021

dt = 211,8 mSec



33,992 60,000 80,000 100,000 120,000 140,000 160,000 180,000 200,000 220,000 240,000 271,512

2,000 [msec/div.]

Seq: 1 SEC Osc: 0 Meas: HFI - 1

U 40 KV

ENGINEERING CORPORATION


16 MA



VENT 5 V

CEESI P141 A7017386/0022

dT= 211,8 mSec
I-peak= 13,75 kA
dT= 1,1 mSec



ВЕРНО С ОРИГИНАЛОМ

U 40 kV




I 6 kA

VENT 5 V

44,112 50,000 55,000 60,000 65,000 70,000 75,000 80,000 85,000 90,000 95,000 101,022
0,500 [msec/div.]

CESI P141 A7017386/0022

SCD



ПУБЛИКАТО А7029970 (РАД - 982593)


MS

А 7
 Firma...
 На основание чл. 2
 от ЗЗЛД
 01


$U_r = 39kV$
 $U_c = 31.2kV$
 CANT. STRENGTH = 350Nm
 TENSION STRENGTH = 2kN
 TORQUE = 50Nm
 HIGH SHORT CIRCUIT = 21kA
 CREEPAGE = 925mm
 DRY ARC DISTANCE = 352mm


Tyco Electronics		ENERGY DIVISION		RAY 861-393 SULPHUR FLD 811 SULPHUR CO. FLA 344 REV 1.0	
		Bowthorpe EMP Surge Arrester			
<small> THE DRAWING AND THE INFORMATION ON IT ARE THE PROPERTY OF TYCO ELECTRONICS LTD. NO PART OF IT IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF TYCO ELECTRONICS LTD. © 1998 </small>		<small> DATE: 11/29/01 DRAWN BY: [blank] APP. BY: [blank] SCALE: 1:1 </small>	<small> TITLE: DA1-39G-NONONO SURGE ARRESTER Dwg No: DA1-39G-NONONO SHEET 1 OF 1 </small>	<small> REV: D </small>	

ВАРНО С ОПРИЖНАТА



ВОПРОС ОПИШВАДА





DA1 - Distribution Surge Arrester
Bending Moment
Type Test Report

MS


[Handwritten signature]



Tyco Electronics

Our commitment. Your advantage.

ВАРНО С ОПРИМНАТА



[Handwritten signature]

Test Report

Type	DA1
PPR Number	PPR-2281
Test Specification	Test of the bending moment IEC 60099-4 (2006-07) Ed. 2.1

Test Information:


Laboratory	CESI
Date	26/11/2007
External Test Ref	A7031450

Report Prepared by	M. Gregori
Test Verified by	A. Sironi
Test Approved by	V. Scarioni

Tyco Approvals:

R&D Manager		
Brendan Normoyle	Sign	Date 28/11/2007
Product Manager		
Brian McGowan	Sign	Date 28/11/2007

For further information contact:
Tyco Electronics Energy Division
Bay 100-109
Shannon Industrial Estate
Co. Clare, Ireland
Tel: + 353-61-472885
Fax: + 353-61-472676
Email: mvsurgearresters@tycoelectronics.com



Client Tyco Electronics Energy Division – Shannon (Ireland)

Tested equipment Polymer-housed metal-oxide surge arrester type DA1

Tests carried out Test of the bending moment

Standards/Specifications IEC 60099-4 (2006-07)

Test date from September 07, 2007 to October 17, 2007

The results reported in this document relate only to the tested equipment. Partial reproduction of this document is permitted only with the written permission from CESI.

PUBBLICATO A7031450 (PAD - 987967)

No. of pages

No. of pages annexed 11

Issue date

На основание чл. 2 от ЗЗЛД

Prepared

Verified

Approved


CESI Centro Elettrotecnico Sperimentale Italiano Giacinto Motta spa

Via R. Rubattino 54 20134 Milano - Italia Telefono +39 022125.1 Fax +39 0221255440 http://www.cesi.it

Capitale sociale 8.550.000 Euro interamente versato Codice fiscale e numero iscrizione CCIAA 00793580150

Registro Imprese di Milano Sezione Ordinaria N. R.E.A. 428222 P.I. IT00793580150

ВЪРНО С ОПИТНАТА



Tests witnessed by:-----

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawing, identified by CESI and numbered A7028193 No. 1, is annexed to this document.


The data necessary to permit repetition of the tests are contained in the document marked: ---

- dielectric tests with impulse voltage : peak voltage: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with impulse current : peak value: $\pm 3 \%$; time parameters: $\pm 10 \%$
- dielectric tests with alternating voltage : voltage (rms): $\pm 3 \%$
- dielectric tests with direct voltage : voltage: $\pm 3 \%$


The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values

Laboratory information

Receipt date of the sample	August 28, 2007
Test location	CESI – Via Rubattino 54 – Milan
CESI testing team	Mr L. Podavitte
Test laboratory	P177
Activity code	80090B



content	page	test date
<p>Test object characteristics</p> <p>Panoramic view of the test object</p> <p>Reference standard</p> <p>Test procedure</p> <p>Summary of test result</p> <p>Initial measurement</p> <p>Preconditioning test</p> <p>Water immersion test</p> <p>Final verification</p> <p>Technical data of the test circuit</p>	<p>4</p> <p>5</p> <p>6</p> <p>7</p> <p>8</p> <p>from page 9 to page 11</p> <p>from page 12 to 14</p> <p>13</p> <p>from page 15 to page 17</p> <p>from page 18 to page 21</p>	<p>September 05, 2007</p> <p>October 12, 2007</p> <p>October 13 to 17, 2007</p> <p>October 17, 2007</p>
<p>Pages annexed:</p> <p>oscillograms no.10 pages</p>		
<p>Document annexed:</p> <p>TYCO Electronics drawing no. DA1-39G-NONONO , CESI no. A7028193 - no.1 page</p>		



[Handwritten signature]

ВЕРНО С ОПИШАННЯ

Rated characteristics of the tested object assigned by the Client

Polymer housed Metal-oxide surge arrester

Manufacturer	Tyco Electronics - Shannon (Ireland)
Year of manufacture	2007
type	DA1

Electrical characteristics

Nominal discharge current (I_n)	10 kA
Rated voltage (U_r)	39 kV
Continuous operating voltage (U_c)	31,2 kV
Rated frequency	50/60 Hz

Mechanical characteristics

dynamic cantilever (Nxm)	350
--------------------------	-----


Geometrical characteristics


Height	347 mm
Number of sheds	n° 12
Shed diameter	104 mm
Core diameter	50 mm

Other characteristics

Housing material	Silicone
Housing color	Grey

Name and signature of Client's witness:





MS

Photo no. 1
Photograph of the test object

[Handwritten signature]

ВЯРНО С ОРИГИНАЛА




Reference Standard

IEC 60099-4 (2006-07): "Metal-oxide surge arrester without gaps for a.c. system", clause 10.8.9

Test carried out and identification of the test objects

Test carried out	Number of test objects	Test object identification
initial measurements	1	B1
Bending application		
water immersion test		
verification tests		



Test procedure

The test procedure consisted of the following sequence:

a) Initial verifications

- measurement of the power losses at a test voltage in the range $0,8 \cdot U_c$ to U_c
- partial discharge test
- measurements of the residual voltage test at the nominal discharge current

b) Bending load application

- the bending load was increased to the test load within 30 sec to 90 sec and maintained at the test load of 350 Nm for 90 sec. the specified bending moment was obtained by applying a force of 970 N with a 365 mm arm
- the bending load was released smoothly and the residual deflection was recorded

c) Water immersion

- the sample was kept for 42 hours in boiling deionized water with 1 kg/m^3 of NaCl

d) Final verifications (same as initial verifications)

- measurement of the power losses at a test voltage in the range $0,8 \cdot U_c$ to U_c
- partial discharge test
- measurements of the residual voltage test at the nominal discharge current

TEST RESULT AND EVALUATION

The visual inspection of the sample after the test has revealed no sign of physical damage.


The force-deflection curve shows no significant discontinuity or residual deflection after load release

The variation of the power losses measured before and after the test was less than 20%.

The variation of the residual voltage measured before and after the test was less than 5% and the relevant oscillogram reveals no sign of breakdown.

The partial discharges measured before and after the test were below the specified limit of 10 pC

The acceptance criteria are fulfilled. The test result is positive



Summary of test results

Electrical measurement

Variation of watt losses at $0,8 \times U_0$

sample	before test		after test		variation
	voltage	power	voltage	power	
	kV	W	kV	W	%
B1	25,12	0,650	25,12	0,664	+ 2,15


The variation of the watt losses before and after test was less than 20% (maximum allowed variation according to reference standard is 20%).

Variation of lightning impulse residual voltage at I_n

sample	before test		after test		variation
	discharge current	residual voltage	discharge current	residual voltage	
	kA	kV	kA	kV	%
B1	10,10	112,08	10,20	112,48	+ 0,36

The variation of the lightning impulse residual voltage before and after test was less than 5% (maximum allowed variation according to reference standard is 5%).

The measured partial discharges level was less than 1 pC (background noise) before and after the test



Tests of the bending moment

Initial measurement of watt losses

Test circuit: A0019

Date: September 05, 2007

Sample No. MI3						
oscillogram	voltage	current	current	current	power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
01	25,12	0,503	0,386	0,383	0,650	---

MS

ВАРНО С ОРИГИНАЛА

АНТИКОРЕРНО ДРУЖЕСТВО
ОИЛКАВ
16
ПЛОБАКЪ

Test of the bending moment



Measurement of partial discharges before the test

Test circuit: A012
 Measurement circuit: A022
 Arrangement: ---
 "direct" calibration: 5 pC/mV, oscillogram no. 02 - background noise ≤ 1 oscillogram no. 03

Atmospheric conditions and correction factor		
b	t_a/t_w	h
kPa	°C	g/m ³
100,23	18 / 11	6,21
		Relative umidity
		%
		40,49

Date: September 05, 2007

Test sample	Applied voltage	Duration of voltage application	Temperature of the test object	Partial discharge measurement		Oscillogram	Notes
				voltage increase	voltage decrease		
	kV _{max}	s	°C	Q _{max}	Q _{max}	No.	
MI	39,0	2 + 10		pC	pC		
MI	32,5	measure	18		≤ 1	04	



continued

Test of the bending moment

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: September 05, 2007


Sample	Requested current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.		kV	No.	μ s	kA	kV
MI	I_n	95,8 x 5	5	7,1 / 18,0	10,10	112,08

Oscilloscope settings			
	sampling division	input	attenuation
	μ s	V _{div}	
Current	5	0,5	50:10
Voltage	5	1,0	---

Notes:

ВЕРНО С ОПИШЕЛАТА





ВНИМАНИЕ! ЗАПРЕЩАЕТСЯ
СНИМАТЬ



Photo no. 2
Test setting for bending application

Bending application

Test date: October 12, 2007

The test sample was mounted in upright position. The specified load (corresponding to the specified bending moment of 350 N×m) was applied perpendicular to the axis to the free end of the surge arrester. The load was increased at constant speed, maintained at the specified value for about 90 seconds and then decreased to zero.


A view of the test arrangement is shown in the photos pages no.12.




The curves of the load-deflection versus time and the load versus deflection are shown on page 14 .

Water immersion test

Test date: from October 13 to October 17, 2007

The sample has been immersed in a vessel, in boiling deionized water with 1 kg/m³ of NaCl, for 42 hours. At the end the sample remained in the vessel until the water cooled to 50 °C and maintained at this temperature in the vessel until verification tests.





ESTRUCO CONTINUED

ESTRUCO S.p.A.
15

Test of the bending moment

Final measurement of watt losses


Test circuit: A0019

Date: October 17, 2007

Sample No. B1						
oscillogram	voltage	current	current	current	power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
06	25,12	0,427	0,506	0,333	0,664	----



ВЪРНО С ОРИГИНАЛА



Test of the bending moment


Measurement of partial discharges after the test

Test circuit: A012
 Measurement circuit: A022 "direct" calibration: 50 pC/mV, oscillogram no. 07 - background noise ≤ 1 oscillogram no. 08
 Arrangement: ---

Atmospheric conditions and correction factor			
b	t_a/t_w	h	Relative umidity
kPa	°C	g/m ³	%
99,97	18 / 13	8,59	56,07

Date: October 17, 2007

Test sample	Applied voltage	Duration of voltage application	Temperature of the test object	Partial discharge measurement		Oscillogram	Notes
				voltage increase Q max	voltage decrease Q max		
MI	kV _{max} 39,0	s 2 + 10	°C 18	pC ---	pC ---	No.	
MI	32,6	measure	18	---	≤ 1	09	



continued

Test of the bending moment

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: October 17, 2007

Sample	Requested current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.		kV	No.	μ s	kA	kV
MI	I_n	95,8 x 5	10	7,1 / 18,0	10,20	112,48

	Oscilloscope settings		
	sampling division	input	attenuation
	μ s	V_{div}	
Current	5	0,5	50:10
Voltage	5	1,0	100:5

Notes:

MS


[Signature]

[Signature]

ВЕРНО С ОРИГИНАЛОМ



Circuit A0019



Power frequency supply


- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system


- R - Current shunt CESI No.31120; R= 941,4 Ω
- Electro optical system CESI No.11521/522; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090



Circuit A0120



Impulse generator

No. of stages 5//
 Cg 250 μ F
 Lc 140 μ H


S - Spark-gap

Voltage measuring system.


D - Voltage divider P&V; CESI No.6700
 - Electro optical system CESI No.11521/522
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
 - Electro optical system CESI No11517/518
 OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)




Circuit A0012




Power frequency test circuit

- R - regulator type CORMES; power 66 kVA; voltage 380 V/0-0,22 kV
- TA - current transformer CGS; ratio 150/5 A/300/5 A
- I - amperemeter
- TV₁ - voltage transformer CGS; ratio 220-440 V/100 V
- V₁ - voltmeter direct reading TSE
- RE - (not used)
- T - booster transformer PIVI; power 250 kVA; voltage 200-400V/250 kV
- D - (not used)
- V₃ - (not used)
- TV₂ - voltage transformer type PIVI; ratio 25000 V/100 V
- V₂ - voltmeter CESI No.6393




Circuit A0022

Partial discharges measurement
Direct circuit - Scheme 1a



- P - calibrator CESI; CESI No. 346
- C_k - coupling capacitor 0,3 nF
- Z_m - coupling impedance
- RS - partial discharge detector HAEFELY TRENCH type TE 571; CESI No. 13281
- OSC - (not used)



ИЗДАНИЕ 1988 г.

[Handwritten signature]



CESI A7031450 (scillogram n. 1

HAEFELY TRENCH TETTEX

PD-DETECTOR

Info: 1

Start date: 00.00.00

Measurement name:

Start time: 00:00

Comment:

1st PD Range: 10 pC

2nd PD Range: Not applied

Noise Suppression: 5 %

Lockout Time: 7.3 usec

Test Measuring Time: 15 s

Voltage Range: 50 kV


Remarks:

Setup: TYCO_01

Date: 05.09.07 Time: 11:35

Discharge Range 10 pC

Calibrator Impulse 5 pC



Handwritten signature

F2 New Calibration

F8 Save Calibration and Exit

ESC Exit PD-Calibration

CESI A7031450 oscillogram n. 2

ВЯРНО С ОРГИНАЛА



Setup: TYCO

Date: 05.09.07 Time: 09:03

PD-Scope

PD Level 0.15 pC


Voltage 50.0 kV
50 Hz

PD-Range: 0.20 pC/div

Noise Suppression: 5%

Synchronisation: Auto


Gain: Auto




PD Trigger

All-F9 Load New Setup
ESC Onit PD-DETECTOR

ΕΠΙΧΕΙΡΗΣΙΑΣ ΑΣΦΑΛΙΣΤΙΚΗΣ
ΕΛΛΑΔΟΣ Α.Ε. (ΕΛΙΑΣ)



CESI A7031450@scillogram n. 3



CESI A7031450 oscillogram n. 6

ВЯРНО С ОРГИНАЛА





HAEFELY TRENCH TETTEX

PD-DETECTOR


Info: 1
Measurement name:
Comment:
1st PD Range: 100 pC
Noise Suppression: 5 %
Test Measuring Time: 15 s

Start date: 00.00.00
Start time: 00:00
2nd PD Range: Not applied
Lockout Time: 7.5 usec
Voltage Range: 40 kV

Remarks:



CESI A7031450 oscillogram n. 7



CESI A7031450 oscillogram n. 8

ВАЖНО С ОПИШВАЛА



Setup: AEM1

Date: 17.10.07 Time: 15:58

PD-Scope

Plot Level 0.80 pC

Voltage 32.7 kV


50 Hz

PD-Range: 1.0 pC/div

Noise Suppression: 5%

Synchronisation: Auto

Gain: Auto




PD Trigger

All-F9 Load New Setup
ESC Onil PD-DETECTOR

УПРАВЛЕНИЕ НАЦИОНАЛНИ
ИЗСЛЕДОВАТЕЛСКИ И
ТЕХНОЛОГИЧЕСКИ ЦЕНТРИ



CESI A7031450 oscillogram n. 9




Handwritten signature

CESI A7031450 oscillogram n. 10

ВЕРНО С ОПИШАННЯ



SCD




$U_r = 39kV$
 $U_c = 31.2kV$
 CANT. STRENGTH = 350Nm
 TENSION STRENGTH = 2kN
 TORQUE = 50Nm
 HIGH SHORT CIRCUIT = 21ka
 LOW SHORT CIRCUIT 600A
 CREEPAGE = 92mm
 DRY ARC DISTANCE = 352mm



CESI

PROTOCOLLO DATA
 A71 028193 # 24 OTT. 2007
 Firma Mario Gajari

Tyco Electronics		ENERGY DIVISION		BAY 101-01 QUALITY NO. 101 U.S. CLASS 001.000
Bonded EMP Surge Arrester				
THE WORKMAN HAS INSPECTED ALL PARTS AFTER THE PROCESS OF MANUFACTURING AND HE IS SURE IN THIS CASE THE QUALITY OF THE PARTS IS PERFECT. FOR OTHER QUALITY PROBLEMS OR FOR ANY OTHER REASON EXCEPT ASSIGNED TO WORK BY THE CUSTOMER I AM RESPONSIBLE.	DATE / PART / QTY / 17/01/07 CHECK / 1 / 10000001 APP / 1 / 10000001 SCALE / 1:1	PER / RATE /	TITLE DA1-39G-NONONO SURGE ARRESTER	
DES NO DA1-39G-NONONO		SHEET 1 OF 1		10

ЗАТВОР С ОПРЕДЕЛЕНАТА





ME

DA1 - Distribution Surge Arrester
Moisture Ingress
Type Test Report



Tyco Electronics

Our commitment. Your advantage

ВЪРНО С ОРГИНАЛА



Test Report

Type	DA1
PPR Number	PPR-2282
Test Specification	Moisture ingress test IEC 60099-4 (2006-07) Ed. 2.1

Test Information:


Laboratory	CESI
Date	26/11/2007
External Test Ref	A7031384

Report Prepared by	M. Gregori
Test Verified by	A. Sironi
Test Approved by	V. Scarioni

Tyco Approvals:

R&D Manager			
Brendan Normoyle	Signature	На основании чл. 2 от 33ЛД	Date 28/11/2007
Product Manager			
Brian McGowan	Signature		Date 28/11/2007

For further information contact:
Tyco Electronics Energy Division
Bay 100-109
Shannon Industrial Estate
Co. Clare, Ireland
Tel: + 353-61-472885
Fax: + 353-61-472676
Email: mvsurgearresters@tycoelectronics.com



Client Tyco Electronics Energy Division -- Shannon (Ireland)

Tested equipment Polymer-housed metal-oxide surge arrester type DA1

Tests carried out Moisture ingress test

Standards/Specifications IEC 60099-4 (2006-07)

Test date from September 07, 2007 to October 17, 2007

The results reported in this document relate only to the tested equipment. Partial reproduction of this document is permitted only with the written permission from CESI.

PUBBLICATO A7031384 (PAD - 987769)

No. of pages

Issue date

Prepared

Verified

Approved

На основание чл. 2 от ЗЗЛД

CESI Centro Elettrotecnico Sperimentale Italiano Giacinto Motta spa

Via R. Rubattino 54 20134 Milano - Italia Telefono +39 022125.1 Fax +39 0221255440 http://www.cesi.it

Capitale sociale 8 550 000 Euro interamente versato Codice fiscale e numero iscrizione CCIAA-00793580150

Registro Imprese di Milano Sezione Ordinaria N. R.E.A. 429222 P.I. IT00793580150

ВРНО С ОПИШНАРА



Tests witnessed by:-----

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawing, identified by CESI and numbered A7028193 No. 1, is annexed to this document.


The data necessary to permit repetition of the tests are contained in the document marked: ---

- dielectric tests with impulse voltage : peak voltage: ± 3 %; time parameters: ± 10 %
- dielectric tests with impulse current : peak value: ± 3 %; time parameters: ± 10 %
- dielectric tests with alternating voltage : voltage (rms): ± 3 %
dielectric tests with direct voltage : voltage: ± 3 %

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values

Laboratory information

Receipt date of the sample August 28, 2007
Test location CESI - Via Rubattino 54 - Milan
CESI testing team Mr L. Podavitte
Test laboratory P177
Activity code 80090B



content	page	test date
Test object characteristics	4	
Panoramic view of the test object	5	
Reference standard	6	
Test procedure	7	
Test result and evaluation	from page 7 to 8	September 5, 2007
Initial measurement	from page 9 to 11	from October 8 to 12, 2007
Preconditioning test	from page 12 to 13	from October 13 to 17, 2007
Water immersion test	14	from October 13 to 17, 2007
Verification test	from page 15 to 17	October 17, 2007
Technical data of the test circuit	from page 18 to 21	

ДАТНО С ОПИШЕЊЕМ

Pages annexed:
oscillograms n.10 pages

Document annexed:
TYCO Electronics drawing no. DA1-39G-NONONO , CESI no. A7028193 - no.1 page



Test Report

CESI

Approved

Rated characteristics of the tested object assigned by the Client

Polymer housed Metal-oxide surge arrester

Manufacturer	Tyco Electronics - Shannon (Ireland)
Year of manufacture	2007
type	DA1

Electrical characteristics

Nominal discharge current (I_n)	10 kA
Rated voltage (U_r)	39 kV
Continuous operating voltage (U_c)	31,2 kV
Rated frequency	50/60 Hz

Mechanical characteristics

terminal torque (Nxm)	50
static cantilever (Nxm)	350 (corresponding to a load of 1010 N applied to the fitting)

Geometrical characteristics


Height	347 mm
Number of sheds	n° 12
Shed diameter	104 mm
Core diameter	50 mm

Other characteristics

Housing material	Silicone
Housing color	Grey

Name and signature of Client's witness:

The image shows a handwritten signature in black ink over a rectangular stamp. To the right of the signature is a circular official seal. The seal contains the text 'ΕΠΙΧΕΙΡΗΣΗ ΕΡΓΑΣΤΗΡΙΟ' at the top, 'ΟΡΓΑΝΙΣΜΟΣ' in the center, and '16' at the bottom. The outer ring of the seal contains the text 'ΕΠΙΧΕΙΡΗΣΗ ΕΡΓΑΣΤΗΡΙΟ' and 'ΠΡΟΒΑΝΤΑ'.



[Handwritten signature]

Photo no. 1
Photograph of the test object

[Handwritten mark]

ВЕРНО С ОРИГИНАЛА

[Handwritten signature]



[Handwritten signature]

Reference Standard

IEC 60099-4 (2006-07): "Metal-oxide surge arrester without gaps for a.c. system", clause 10.8.13

Test carried out and identification of the test objects

Test carried out	Number of test objects	Test object identification
initial measurements	1	MI
mechanical preconditioning		
water immersion test		
verification tests		



Test procedure

The test procedure consisted of the following sequence:

a) Initial verifications

- measurement of the power losses at a test voltage in the range $0,8 \cdot U_c$ to U_c
- partial discharge test
- measurements of the residual voltage test at the nominal discharge current

b) Terminal torque preconditioning

The terminal torque specified by the manufacturer was applied for 30 sec

c) Thermomechanical preconditioning

The test sample was submitted to two 48 hours thermal cycles as shown in fig. 6 of the reference standard while mechanically stressed at the maximum continuous cantilever (bending) load specified by the manufacturer equal to 350 Nm. The load direction was changed every 24 hours according to fig. 7 of the reference standard

d) Water immersion

The test sample was kept for 42 hours in boiling deionized water with 1 kg/m^3 of NaCl

d) Final verifications (same as initial verifications)

- measurement of the power losses at a test voltage in the range $0,8 \cdot U_c$ to U_c
- partial discharge test
- measurements of the residual voltage test at the nominal discharge current

Test result and evaluation


The visual inspection of the sample after the test has revealed no significant damage.

The variation of the power losses measured before and after the test was less than 20%.

The variation of the residual voltage measured before and after the test was less than 5% and the relevant oscillogram reveals no sign of breakdown.

The partial discharges measured before and after the test were below the specified limit of 10 pC

The acceptance criteria are fulfilled. The test result is positive



Summary of test results

Electrical measurement

Variation of watt losses at $0,8 \times U_0$

sample	before test		after test		variation
	voltage	power	voltage	power	
	kV	W	kV	W	%
MI	25,06	0,693	25,06	0,820	+ 18,32


The variation of the watt losses before and after test was less than 20% (maximum allowed variation according to reference standard is 20%).

Variation of lightning impulse residual voltage at I_n

sample	before test		after test		variation
	discharge current	residual voltage	discharge current	residual voltage	
	kA	kV	kA	kV	%
MI	10,10	112,4	10,10	112,8	+ 0,36

The variation of the lightning impulse residual voltage before and after test was less than 5% (maximum allowed variation according to reference standard is 5%).

The measured partial discharges level was less than 1 pC (background noise) before and after the test





Moisture ingress test

Initial measurement of watt losses

Test circuit: A0019

Date: September 05, 2007

oscillogram No.	voltage kV	Sample No. MI3			power W	3rd harmonic amplitude μ A
		current + mA _{cr}	current - mA _{cr}	current mA _{rms}		
01	25,06	0,502	0,392	0,321	0,693	---




Moisture ingress test


Measurement of partial discharges before the test

Test circuit: A012
 Measurement circuit: A022 "direct" calibration: 5 pC/mV, oscillogram no. 02 - background noise ≤ 1 oscillogram no. 03
 Arrangement: ---

Atmospheric conditions and correction factor			
b	t_p/t_w	h	Relative umidity
kPa	°C	g/m ³	%
100,23	18/11	6,21	40,49

Date: September 05, 2007

Test sample	Applied voltage	Duration of voltage application	Temperature of the test object	Partial discharge measurement		Oscillogram	Notes
				voltage increase Q max pC	voltage decrease Q max pC		
MI	kV _{rms} 39,0	s 2 + 10	°C 18	---	---	No.	
MI	32,6	measure		---	≤ 1	04	



continued

Moisture ingress test

Lightning impulse residual voltage measurement before the test

Test circuit: A0120

Date: September 05, 2007

Sample	Requested current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.		kV	No.	μ s	kA	kV
MI	I_n	95,8 x 5	5	7,1 / 18,0	10,10	112,4

Oscilloscope settings			
	sampling division	input	attenuation
	μ s	V _{div}	
Current	5	0,5	50:10
Voltage	5	1,0	---

Notes:

ВЯРНО С ОРИГИНАЛА



Preconditioning tests

Terminal torque preconditioning

Test date: October 8, 2007



The terminal torque at the value, specified by the manufacturer (50 Nxm), has been applied for 30 seconds.

Thermomechanical preconditioning

Test date: from October 8 to October 12, 2007

sample	applied load	lower temperature	upper temperature	duration of temperature application	cycle	load duration
No.	Nxm	°C	°C	h	No.	degree
MI	350	---	+60	24	1	0
	350	-25	---	24	1	180
	350	---	+45	24	2	270
	350	-40	---	24	2	90

Thermomechanical preconditioning



Test set up for thermomechanical preconditioning




Photo no. 2

[Handwritten signature]

[Handwritten signature]

ВЯРНО С ОРИГИНАЛА




[Handwritten signature]

Water immersion test

Test date: from October 13 to October 17, 2007

The sample has been immersed in a vessel, in boiling deionized water with 1 kg/m³ of NaCl, for 42 hours. At the end the sample remained in the vessel until the water cooled to 50 °C and maintained at this temperature in the vessel until verification tests.



Moisture ingress test

Final measurement of watt losses

Test circuit: A0019

Date: October 17, 2007

oscillogram No.	voltage kV	Sample No. MI3			power W	3rd harmonic amplitude μ A
		current + mA _{cr}	current - mA _{cr}	current mA _{rms}		
06	25,06	0,429	0,509	0,331	0,820	----

ВЕРНО С ОРИГИНАЛА



Moisture ingress test


Measurement of partial discharges after the test

Test circuit: A012
 Measurement circuit: A022 "direct" calibration: 50 pC/mV, oscillogram no. 07 - background noise ≤ 1 oscillogram no. 08
 Arrangement: ---

Atmospheric conditions and correction factor		
b	t_d/t_w	h
kPa	°C	g / m ³
99,97	18 / 13	8,59
		Relative umidity
		%
		56,07

Date: October 17, 2007

Test sample	Applied voltage	Duration of voltage application	Temperature of the test object	Partial discharge measurement		Oscillogram	Notes
				voltage increase	voltage decrease		
	kV _{rms}	s	°C	Q _{max}	Q _{max}		
MI	39,0	2 ÷ 10	18	pC	pC	No.	
MI	32,6	measure	18	---	---	09	



continued

Moisture ingress test

Lightning impulse residual voltage measurement after the test

Test circuit: A0120

Date: October 17, 2007

Sample	Requested current	Charging voltage	Oscillogram	Current waveshape	Discharge current	Residual voltage
No.		kV	No.	μ s	kA	kV
MI	I_n	95,8 x 5	10	7,1 / 18,0	10,10	112,80

Oscilloscope settings			
	sampling division	input	attenuation
	μ s	V _{div}	
Current	5	0,5	50:10
Voltage	5	1,0	100:5


Notes:




БИРНО С ОПИШНАДА




Circuit A0019



Power frequency supply


- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV

Current measuring system


- R - Current shunt CESI No.31120; $R = 941,4 \Omega$
- Electro optical system CESI No.11521/522; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090

Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11517/518; attenuation 5:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710A; CESI No.9090



Circuit A0120



Impulse generator


- No. of stages 2
- Cg 3,32 μ F *ML*
- Lc 18 μ H
- S - Spark-gap

Voltage measuring system.


- D - Voltage divider SAGI; CESI No.13027
- Electro optical system CESI No.11521/522
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.2)

Current measuring system

- Sh - Current shunt CESI No.6042; R= 2 m Ω ; peak current= 250 kA
- Electro optical system CESI No.11517/518
- OSC - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)




Circuit A0012




Power frequency test circuit

- R - regulator type CORMES; power 66 kVA; voltage 380 V/0-0,22 kV
- TA - current transformer CGS; ratio 150/5 A/300/5 A
- I - ampermeter
- TV₁ - voltage transformer CGS; ratio 220-440 V/100 V
- V₁ - voltmeter direct reading TSE
- RE - (not used)
- T - booster transformer PIVI; power 250 kVA; voltage 200-400V/250 kV
- D - (not used)
- V₃ - (not used)
- TV₂ - voltage transformer type PIVI; ratio 25000 V/100 V
- V₂ - voltmeter CESI No.6393



Circuit A0022

Partial discharges measurement
Direct circuit - Scheme 1a




- P - calibrator CESI; CESI No. 346
- C_k - coupling capacitor 0,3 nF
- Z_m - coupling impedance
- RS - partial discharge detector HAEFELY TRENCH type TE 571; CESI No. 13281
- OSC - (not used)



Handwritten signature

Handwritten signature

ВЕРНО С ОРИГИНАЛА





CESI A7031384 oscillogram n. 1

HAEFELY TRENCH TETEX

PD-DETECTOR

Info: 1

Start date: 00.00.00

Measurement name:

Start time: 00:00

Comment:

1st PD Range: 10 pC

2nd PD Range: Not applied

Noise Suppression: 5 %

Lockout Time: 7.3 usec

Test Measuring Time: 15 s

Voltage Range: 40 kV

Remarks:

Setup: TYCO_01 Date: 05.09.07 Time: 11:44

Discharge Range 10 pC

Calibrator Impulse 5 pC

[Handwritten signature]

F2 New Calibration
F8 Save Calibration and Exit
ESC Exit PD-Calibration

CESI A7031384 oscillogram n. 2

ВАРНО С ОПИТНАТА



[Handwritten signature]

PD-Scope

Setup: ABB_SW

Date: 05.09.07 Time: 09:02

PD Level 0.16 pC


Voltage 50.0 kV
50 Hz

PD-Range: 0.20 pC/div

Noise Suppression: 5%

Synchronisation: Auto

Gain: Auto



PD Trigger

Alt-F9 Load New Setup

ESC Onit PD-DETECTOR



CESI A7031384 oscillogram n. 3

PD-Scope

Setup: TYCO_01 Date: 05.09.07 Time: 11:46

PD Level 0.26 pC


Voltage 33.1 kV
50 Hz

PD-Range: 0.50 pC/div

Noise Suppression: 5 %

Synchronisation: Auto

Gain: Auto




PD Trigger

Alt-F9 Load New Setup
ESC On/Off PD-DETECTOR

CESI A7031384 oscillogram n. 4
БЯРНО С ОПН МАШИНА






ВНИМАНИЕ
 ЗАЩИЩАЮЩИЙ
 ПОДПИСЬ



CESI A7031384 oscillogram n. 5



CESI A7031384 (scillogram n. 6)

ИЗМЕРИТЕЛЬНО-ИСПЫТАТЕЛЬНЫЙ ЦЕНТР






HAEFELY TRENCH TETEX

PD-DETECTOR

Info: 1
Measurement name:
Comment:
1st PD Range: 100 pC
Noise Suppression: 5 %
Test Measuring Time: 15 s

Start date: 00.00.00
Start time: 00:00
2nd PD Range: Not applied
Lockout Time: 7.5 usec
Voltage Range: 40 kV

Remarks:



CESI A7031384 oscillogram n. 7

PD-Scope

Setup: AEM1

Date: 15.10.07 Time: 15:45

Plot Level 0.14 pC


Voltage 0 kV
50 Hz

PD-Range: 0.20 pC/div

Noise Suppression: 5%

Synchronisation: Auto

Gain: Auto



Alt-F9 Load New Setup
ESC Quit PD-DETECTOR

PD Trigger


Handwritten signature

Handwritten signature

Handwritten signature

CESI A7031384 oscillogram n. 8

БІЛНІО С ОРГАНІЗАЦІЇ



PD-Scope

Setup: AEMI

Date: 27.10.07 Time: 15:51

Plot Level 0.78 pC

Voltage 32.7 kV


50 Hz

PD-Range: 1.0 pC/div

Noise Suppression: 5%

Synchronisation: Auto

Gain: Auto




PD Trigger


All-F9 Load New Setup

ESC Onit PD-DETECTOR

Stamp: *Handwritten signature*



CESI A7031384 oscillogram n. 9




CESI A7031384 oscillogram n. 10

ВЕРНО С ОРИГИНАЛА



SCD





На основание чл. 2
от ЗЗЛД

$U_r = 39kV$
 $U_c = 31.2kV$
 CANT. STRENGTH = 350Nm
 TENSION STRENGTH = 2kN
 TORQUE = 50Nm
 HIGH SHORT CIRCUIT = 21kA
 LOW SHORT CIRCUIT 600A
 CREEPAGE = 925mm
 DRY ARC DISTANCE = 352mm

Tyco Electronics				ENERGY DIVISION		<small> BAY 128-98 SHANNON RD. 151. GALWAY CO. CLON IRELAND </small>	
				Bardhorpe EMP Surge Arrester			
<small> THE DRAWING AND THE INFORMATION ON IT SHALL BE THE PROPERTY OF TYCO ELECTRONICS LTD AND NOT BE LOANED, REPRODUCED, COPIED, REPRODUCED, PUBLISHED, DISCLOSED, EITHER IN WHOLE OR IN PART, WITHOUT THE WRITTEN PERMISSION OF TYCO ELECTRONICS LTD. </small>		DES 11/22/07	PFM PART	TITLE DA1-39G-NONONO SURGE ARRESTER			
DES NO DA1-39G-NONONO	SHEET 1 OF 1						

ДОПНО С ОПИШВАЮЩА





DA1 - Distribution Surge Arrester
Weather Ageing Test
Type Test Report

Handwritten signature

Handwritten signature

ВЕРНО С ОРИГИНАЛА



Tyco Electronics

Our commitment. Your advantage.



Handwritten signature

Test Report

Type	DA1
PPR Number	PPR-2283
Test Specification	Weather ageing test IEC 60099-4 (2006-07) Ed. 2.1



Test Information:

Laboratory	EGU
Date	12/11/2007
External Test Ref	7725/A/07
Report Prepared by	M. Brosch
Test Approved by	V. Sklenicka

Tyco Approvals:

R&D Manager Brendan Normoyle	На основание чл. 2 от ЗЗЛД	Date 28/11/2007
Product Manager Brian McGowan		Date 28/11/2007

For further information contact:
Tyco Electronics Energy Division
Bay 100-109
Shannon Industrial Estate
Co. Clare, Ireland
Tel: + 353-61-472885
Fax: + 353-61-472676
Email: mvsurgearresters@tycoelectronics.com



EGU – HV Laboratory a.s.
190 11 Praha 9 – Běchovice

CUSTOMER:
Tyco Electronics
Shannon Industrial Estate
100-104 BAY
SHANNON
IRELAND

ORDER No.:
PO 2250310469
PO 2250310796

DATE OF TEST:
from 2007-07-16 till 2007-10-11

TEST No.:
7725/07

TEST REPORT

No.: 7725/A/07

TEST OBJECT: Composite metal oxide surge arresters
TYPE SPECIFICATION: DA1 Class 1 Surge Arrester
MANUFACTURER: Tyco Electronics
TEST STANDARD: IEC60099-4:2006-07 Ed. 2.1

TEST PERFORMED BY:
Marek Brosch


DIRECTOR OF EGU - HV Laboratory a.s.:
Václav Sklenička

COPIES: 3+1

PAGES: 8

Test report is confidential and must not be passed over or transferred to any third party without written approval of the customer. Test results relate only to the tests given in presented report and do not substitute any other documents. The report shall not be reproduced except in full without written approval of the testing laboratory.

In Prague 9 -Běchovice: 2007-11-12



TEST OBJECT

COMPOSITE METAL OXIDE SURGE ARRESTERS

Drawing No.: DA1 – 30F – NONON0 (see Figure 1)

DATE OF DELIVERY

2007-07-12

SCHEDULE OF TESTS

Test series A: 1000 hours

IEC60099-4:2006-07, clause 10.8.14.2.1

TEST PROCEDURE

Test series A: 1000 hours

Metal oxide surge arrester samples were subjected to a salt fog test in accordance with IEC60099-4:2006-07, clause 10.8.14.2.1 (test series A).

The metal oxide surge arresters were energised at a voltage of 24 kV that is continuous operating voltage of tested metal oxide surge arresters.

The protection level of the tripping device was set at 1 A (r.m.s.).

During the test the salt fog was sprayed into the test chamber.

The characteristic of the salt fog were as follows:


Water flow rate: $(0,4 \pm 0,1) \text{ l/h/m}^3$

Starting salinity: 5 kg/m^3

Temperature: $20 \text{ }^\circ\text{C} \pm 5 \text{ K}$

Duration of the test: 1000 hours (excluding duration of interruption)

Testing and measuring equipment




IR - inductive regulator MEZ Vsetfn type IR 37A-2, 20 kVA

T - test transformer BEZ Bratislava, 50 kV, 25 kVA


MT - voltage measuring transformer UZGT 30, 35 000/100 V, serial No. 02022

voltmeter Metra, type EI 20, serial No. 9718268



Measurement of reference voltage


Testing and measuring equipment:



IR - induced regulator ČKD Praha, 3x380/0-760, 45 kVA
 T - test transformer Fischer-Köln, 3-6/250 kV, 250 kVA
 IVT - instrument voltage transformer Škoda, 380/√3 kV / 100/√3 V, serial No. 917355
 digitizer ADAM Maurer, serial No. 9401.9620
 universal voltmeter Siemens, type MU 15, serial No. 879953

Measurement of partial discharges

Testing and measuring equipment:



IR - induced regulator ČKD Praha, 3x380/0-760, 45 kVA
 T - test transformer Fischer-Köln, 3-6/250 kV, 250 kVA
 IVT - instrument voltage transformer Škoda, 380/√3 kV / 100/√3 V, serial No. 917355
 PD measuring system Tettex, type 2801, serial No. 123989
 universal voltmeter Siemens, type MU 15, serial No. 879953

UNCERTAINTY OF MEASUREMENTS

TYPE OF MEASUREMENT	UNCERTAINTY (k=2)
<i>Power-frequency voltage</i>	0,4 %
<i>Partial discharges</i>	8,0 %

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a Normal (Gaussian) distribution corresponds to a coverage probability of approximately 95 %.

БСРНО С ОПРИМНАТА



TEST RESULTS

The results of the test are given in Table 1:

Beginning of the test: 2007-07-16 End of the test: 2007-08-27

The results of the verification tests before and after the weather ageing tests and evaluation of the test are given in Table 1.

Table 1

Sample No.:	Reference voltage (kV)		Partial discharges (pC)		Visual inspection after test	Evaluation of the test
	before test	after test	before test	after test		
#72	30,6	30,6	0,4	0,4	no tracking, erosion or puncture	passed
#84	30,4	30,6	0,4	0,4		


No flashovers occurred during the test.

No interruptions occurred during the test.

The leakage currents of tested insulators were measured as informative values. The records of the leakage currents are given in Figures 2 - 3.

The record of the test voltage during the tracking and erosion test is given in Figure 4.

The photographs of the wetted insulators immediately after finishing the test are shown in Figures 5 - 6.








Figure 2: Leakage current - test sample No.72 Figure 3: Leakage current - test sample No.84







Figure 4
Record of the test voltage during 1000 hour test

7/8

ВЕРНО С ОПИШАНІА






Figure 5
DA1 Class 1 Surge Arrester, test sample No.72 , after the test







Figure 6
DA1 Class 1 Surge Arrester, test sample No.84 , after the test





DA1 - Distribution Surge Arrester
Power frequency voltage versus time test
Type Test Report

ВСТУПО С ОПИТУВАЊА



Tyco Electronics

Our commitment Your advantage.



Test Report

Type	DA1
PPR Number	PPR-2284
Test Specification	Power frequency voltage versus time test IEC 60099-4 (2006-07) Ed. 2.1



Test Information:

Laboratory	EGU
Date	03/09/2007
External Test Ref	A7020280
Report Prepared by	M. Gregori
Test Verified by	A. Sironi
Test Approved by	V. Scarioni

Tyco Approvals:

R&D Manager		
Brendan Normoyle	Signature	Date 28/11/2007
Product Manager		
Brian McGowan	Signature	Date 28/11/2007

For further information contact:
Tyco Electronics Energy Division
Bay 100-109
Shannon Industrial Estate
Co. Clare, Ireland
Tel: + 353-61-472885
Fax: + 353-61-472676
Email: mvsurgearresters@tycoelectronics.com



Client TYCO Electronics – Shannon (Ireland)

Tested equipment Polymer-housed metal-oxide surge arrester section type DA1 assembled in thermal model

Tests carried out Power frequency voltage versus time test

Standards/Specifications IEC 60099-4 – Edition 2.1 (2006-07)

Test date from July 24, 2007 to August 01, 2007

PUBBLICATO A7020280 (RAD - 980963)

The results reported in this document relate only to the tested equipment.
 Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages 16 No. of pages annexed 24



Issue date September 03, 2007

Prepared Unit LABORATO

Verified Unit LABORATO

Approved Area COMPONE

На основание чл. 2
от ЗЗЛД



Tests witnessed by: ---

Identification of the object: Requested

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing. CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.

This drawing, identified by CESI and numbered A7027907 No. 1, is annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked: ----

The measurement uncertainties of the test results reported in this document are the following:

- dielectric tests with impulse voltage : peak voltage: ± 3 %; time parameters: ± 10 %
- dielectric tests with impulse current : peak value: ± 3 %; time parameters: ± 10 %
- dielectric tests with alternating voltage : voltage (rms): ± 3 % time: ± 3,5 %
- dielectric tests with direct voltage : voltage: ± 3 % time: ± 3,5 %
- atmospheric conditions : temperature: ± 2 °C; pressure: ± 0,133 kPa; humidity: ± 10 %

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values.

Laboratory information


Receipt date of the sample July 16, 2007

Test location CESI – Via Rubattino 54 – Milan

CESI testing team Mr L. Podavitte

Test laboratory P177

Activity code 80090B



content	page	test date
Test object characteristics	4	
Panoramic view of the test object	5	
Reference standard	6	
Test carried out	6	
Test object identification	6	
Test procedure	7	
Test results	7	
Reference voltage test	8	July 24, 2007
Voltage correction factor	9	July 24, 2007
Power frequency voltage versus time test	from page 10 to 12	July 31 to August 01, 2007
Technical data of the test circuit	from page 13 to 16	
Pages annexed:		
Oscillograms n. 21 pages		
Document annexed:		
Tyco Electronics drawing n.DA1-6.5-NONONO, CESI n. A7027907 - n. 1 page		
Tyco Electronics TOV curve; CESI n.A7027910 - n.1 page		
Tyco Electronics Thermal equivalency; CESI n. A7027911 - n.1 page		

ВЕРНО С ОРИГИНАЛОМ



Test Report



Approved

Test object characteristics

type: Polymer-housed metal-oxide surge arrester section assembled in thermal model

electrical characteristics (assigned by the client)



Manufacturer's name	TYCO Electronics – Shannon (Ireland)
Type	DA1
Nominal discharge current – I_n [kA]	10
Rated voltage – U_r [kV]	1,045 x U_{ref}
Continuous operating voltage - U_o [kV]	0,836 x U_{ref}
Reference current - I_{ref} [mA]	5,0
Line discharge class	1
Standard rated frequency - [Hz]	50/60
year of manufacture	2007

NOTE:


The thermal model was supplied by the manufacturer

The verification of the thermal equivalency according to annexe B was carried out by the Client

(see Tyco Electronics document DA1 Class 1 Surge Arrester Thermal equivalency*; CESI no.A7027911)



View of the test object




MS

Photo no. 1

Polymer-housed metal-oxide surge arrester section assembled in thermal model

R

ВЯРНО С ОРИГИНАЛА



M

Reference standard

The test was carried according to the IEC 60099-4 (2006-07) Standard – Annexe D


“ Metal-oxide surge arrester without gaps for a.c. system “

Test carried out

test carried out	number of sample tested
power frequency voltage versus time test	3

Test object identification

test object names	identification of test sample (assigned by the CESI)
Polymer – housed metal-oxide surge arrester assembled in thermal model	TOV1-TOV2-TOV3



Test procedure

The test procedure consisted of the following sequence:

- a) Measurement of the power frequency reference voltage at the reference current
- b) Calculation of the voltage correction factors according to the reference standard
- c) Heating in an oven at the temperature of 60 °C till thermal equilibrium
- h) Application of one high current impulse 4/10 μ s at 100 kA followed within 100 ms by the energization at the voltage U_{TOV} for a time T_{TOV} (according to the TOV curve to be proved as supplied by manufacturer) and then at the voltage U_c' for 30 min. in order to verify the thermal stability.



Three samples have been tested according to the table below

Sample	Voltage U_{TOV}	Time duration
TOV1	0,89 x U_r'	10000 sec.
TOV2	0,98 x U_r'	100 sec.
TOV3	1,10 x U_r'	1 sec.

Test results

The thermal stability was achieved for all tested sample.
 The visual inspection of the test sample after the test has revealed no sign of physical damage.

All acceptance criteria specified by the standard are satisfied and therefore the TOV curve claimed by the manufacturer are to be considered verified.



Power frequency voltage versus time test.

Reference voltage test



Test circuit: A0019

Date: July 24, 2007

Sample No. TOV1						
oscillogram	voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
1	6,54	5,01	4,25	1,62	6,71	--

Sample No. TOV2						
oscillogram	voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
2/B	6,68	5,00	4,27	1,62	6,96	--

Sample No. TOV3						
oscillogram	voltage	current	current	current	Power	3rd harmonic amplitude
No.	kV	+ mA _{cr}	- mA _{cr}	mA _{rms}	W	μA
3	6,58	4,62	5,05	1,67	6,95	--





Power frequency voltage versus time test.

Voltage correction factor

Date: July 24, 2007

Sample	U_{ref} [1]	KU_r [2]	KU_c [3]	U_r' [4]	U_c' [5]
No.	kV			kV	kV
TOV1	6,54	1,045	0,836	6,834	5,467
TOV2	6,68			6,981	5,584
TOV3	6,58			6,876	5,501

- [1] U_{ref} : measured reference voltage
- [2] KU_r : maximum guaranteed factor for calculation of U_r
- [3] KU_c : maximum guaranteed factor for calculation of U_c
- [4] U_r' : corrected rated voltage [4] = [1] × [2]
- [5] U_c' : corrected continuous operating voltage [5] = [1] × [3]



Power frequency voltage versus time.

Application of the high current impulse, of the rated voltage U_r' and evaluation of thermal stability

Test circuit: A0123 - A0131 – A0020

Sample No.: TOV 1

Preheating temperature: 61 °C

Date: July 31, 2007

Second high current impulse application

Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Energy kJ	Current waveshape μ s
4	78 x 2	---	99,0	---	4,5/9,8

Temporary overvoltage application

Amplitude claimed by the manufacturer $U_r' \times 0,89 = 6,834 \times 0,89 = 6,082$ kV



Duration claimed by the manufacturer 10000 sec.

U_r' voltage application

Oscillogram No.	Time s	Voltage kV	Current		Power W
			+ mA _{cr}	- mA _{cr}	
5	0	6,082	17,0	23,0	---
6	10000		0,94	1,0	---

U_c' voltage application

Oscillogram No.	Time min	Voltage kV	Current		Power W
			+ mA _{cr}	- mA _{cr}	
7	0	5,467	0,80	0,83	0,60
	5		0,79	0,82	0,54
	10		0,79	0,81	0,53
8	15		0,78	0,80	0,52
	20		0,77	0,79	0,51
	25		0,76	0,79	0,50
9	30		0,76	0,78	0,49



continued

continued

Sample No.: TOV3

Preheating temperature: 61 °C

Date: August 01, 2007

Second high current impulse application

Oscillogram No.	Charging voltage kV	Residual voltage kV	Discharge current kA	Energy kJ	Current μ s
16	76,0 x 2	---	96,0	---	4,5/9,8

Temporary overvoltage application

Amplitude claimed by the manufacturer $U_r' \times 1,10 = 6,876 \times 1,1 = 7,563$ kV



Duration claimed by the manufacturer 1 sec.

U_r' voltage application

Oscillogram No.	Time s	Voltage kV	Current + mA _{cr}	Current - mA _{cr}	Power W
17	0	7,563	140	217	---
18	1		133	214	---

U_c' voltage application

Oscillogram No.	Time min	Voltage kV	Current + mA _{cr}	Current - mA _{cr}	Power W
19	0	5,501	1,00	1,00	1,16
	5		0,87	0,94	1,05
	10		0,84	0,91	0,96
20	15		0,83	0,90	0,94
	20		0,82	0,90	0,93
	25		0,81	0,89	0,92
21	30		0,80	0,87	0,90



Test Report

CESI

Approved

Page 12

continued

Sample No.: TOV2

Preheating temperature: 61 °C

Date: August 01, 2007

Second high current impulse application

Oscillogram	Charging voltage	Residual voltage	Discharge current	Energy	Current
No.	kV	kV	kA	kJ	μs
22	78 x 2	---	99,0	---	4,5/9,8

Temporary overvoltage application

Amplitude claimed by the manufacturer $U_r' \times 0,98 = 6,981 \times 0,98 = 6,841$ kV


Duration claimed by the manufacturer 100 sec.

 U_r' voltage application


Oscillogram	Time	Voltage	Current	Current	Power
No.	s	kV	+ mA _{cr}	- mA _{cr}	W
23	0	6,841	54,0	63,0	---
24	100		9,0	16,5	---

 U_c' voltage application

Oscillogram	Time	Voltage	Current	Current	Power
No.	min	kV	+ mA _{cr}	- mA _{cr}	W
25	0	5,58	0,96	1,00	1,49
	5		0,90	0,98	1,30
	10		0,86	0,96	1,15
26	15		0,84	0,93	1,02
	20		0,83	0,91	0,96
	25		0,82	0,90	0,94
27	30		0,81	0,89	0,90



Circuit A0019



Power frequency supply

- RE - programmable supply type LARCET A.C. Power Source 5000 P.S.; CESI no. 23702-32191
- PC - personal computer
- T - voltage transformer type SPECIALTRASFO; power 30 kVA; voltage 200 V/15-30 kV


Current measuring system

- R - Current shunt CESI No.31120; $R= 941,4 \Omega$
- Electro optical system CESI No. -- ; attenuation
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI No.6318


Voltage measuring system

- D - Voltage divider SAGI; CESI No.11120
- Electro optical system CESI No.11521/1522; attenuation 50:5
- OSC - Oscilloscope type SONY TEKTRONIX RTD 710; CESI No.6318

ВАТНО С. СЕРИЯ 13/14



Circuit A0123




Impulse generator circuit


No. of stages 2

C_g 3,32 μ F

S - spark-gap



Circuit A0020



Impulse generator circuit A0123

I - Circuit-breaker

Impulsive current measuring system



- Sh₁ - Current shunt CESI No.6042; R= 2 m Ω
- Electro optical system CESI No.11517/518; attenuation 300:5
- OSC₁ - Oscilloscope type TEKTRONIX TDS 540A; CESI No.13217 (on channel No.1)


Power frequency voltage measuring system circuit A0131

- D - Voltage divider SAGI; CESI No.13027
- Electro optical system CESI No.11521/522; attenuation 20:5
- OSC₂ - Oscilloscope type TEKTRONIX TDS 460A; CESI No.14434 (on channel No.2)
- OSC₃ - Oscilloscope type SONY TEKTRONIX RTD 710A ; CESI No.9090 (on channel No.1)

Power frequency current measuring system circuit A0131

- Sh₂(TOV) - Current shunt CESI ; R= 100 Ω (TOV 1 s) – Current shunt CESI
- Current shunt CESI ; R= 1000 Ω (TOV 100/10000 s)
- Electro optical system CESI No. 8011/17; attenuation 300-5:5
- OSC₂ - Oscilloscope type SONY TEKTRONIX RTD 710A ; CESI No.9090 ; CESI No.13217 (on channel No.2)





Handwritten signature


CESI A7020280 Oscillogram n. 1

ВАЖНО С ОРИГИНАЛА

Handwritten signature


**НАЦИОНАЛНО БУЛЕТЕЛСТВО
ОШКАД
16
ПРОЕКТИ**


Handwritten signature



CESI A7020280 Oscillogram n. 2/B


ВЕРНО С СЕРТИФИКАТОМ






CESI A7020280 Oscillogram n. 3

ВАРНО С ОПИТНАТА





Handwritten signature or scribble.



CESI A7020280 Oscillogram n. 4

ВЕРНО С ОПИШКАДА







MS

CESI A7020280 Oscillogram n. 5

ВЕРНО С ОРИГИНАЛОМ





[Handwritten signature]



CESI A7020280 Oscillogram n. 6

РЕПОЗИТОРИЈА







MS

CESI A7020280 Oscillogram n. 7


ВРАНО С ОПРИМНАТА






CESI A7020280 Oscillogram n. 8

ВЕРНО С ОРИГИНАЛА






CESI A7020280 Oscillogram n. 9

ВАРНО С ОБИКНАТА

X




Handwritten signature or mark.



CESI A7020280 Oscillogram n. 16

БЕНО С ОПИШНАТА






CEESI A7020280 Oscillogram n. 17

ВЕРНО С ОРИГИНАЛОМ





Handwritten signature



CESI A7020280 Oscillogram n. 18

ВЕРНО С ОПИШІАЛА






MS

CEESI A7020280 Oscillogram n. 19

ВЯЗНО С ОРИГИНАЛА






CESI A7020280 Oscillogram n. 20

ВМНО С ОРНИМАЛА






CESI A7020280 Oscillogram n. 21

ISTRUTTORE C. COPPINI/MADEA

[Handwritten signature]




[Handwritten signature]



CESI A7020280 Oscillogram n. 22

ВСТІПНО С ПРОВІРЯЛА







Handwritten signature

CESI A7020280 Oscillogram n. 23

ВРНО С ОПИТНА

Handwritten signature






CESI A7020280 Oscillogram n. 24

ВЕРНО С ОПТИКАМ


[Handwritten signature]






CESI A7020280 Oscillogram n. 25

ВЕРНО С ОРИГИНАЛА






CESI A7020280 Oscillogram n. 26

ВЕРНО С ОПИДИНАТА





CESI A7020280 Oscillogram n. 27

ВЪРНО С ОРЪЖИНАЛА

[Handwritten signature]



[Handwritten signature]


Дата

2 ОКТ. 2007

На основании чл. 2
от 33ЛД

Tyco Electronics

DA1 Class 1 Surge arrester
TOV Uw/Ur @ 60°C with prior duty



ВЪРНО С ОРЪЖИЯТА




DATE:

07. 2007


На основание чл. 2
от ЗЗЛД

Tyco Electronics


DA1 Class 1 Surge Arrester Thermal equivalency



ВЯРНО С ОРИГИНАЛА



SCD



$U_{ref} = 6.22kV \text{ min}$
 $U_r = 6.5kV$
 $U_c = 5.2kV$
 CREEPAGE = 254mm
 DRY ARC DISTANCE = 127mm

На основании чл. 2
 от ЗЗЛД

Tyco Electronics


ENERGY DIVISION

BAY 100-109
 SHANNON IND. EST.
 SHANNON
 CO. CLARE
 IRELAND


Bowthorpe EMP Surge Arrester

THIS DRAWING AND THE INFORMATION SET FORTH HEREIN ARE THE PROPERTY OF TYCO ELECTRONICS LTD AND ARE TO BE HELD IN TRUST AND CONFIDENTIAL. REPRODUCTION, DUPLICATION, DISCLOSURE OR USE FOR ANY OTHER PURPOSE NOT EXPRESSLY AUTHORIZED IN WRITING BY TYCO ELECTRONICS LTD IS PROHIBITED.	DRN	MULLIGAN	17/09/07	PCN	TITLE DA1-6.5-NONONO SURGE ARRESTER
	CHECK	B NORRIS/YLE		MAT'L	
	APP	B MCGOWAN			
	SCALE	1:1			
	DRG NO	DA1-6.5-NONONO		SHEET 1 OF 1	REV 0

РАСПНО С ОРМІКІАРА



Приложение 2 към Техническо предложение**ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 2.8.**



Сертификат за акредитация

Номер на акредитация

0030

Ревизия 2

Ние декларираме, че

CESI S.p.A.Седалище:
ул. Рубатино 54 - 20134 Милано

Отговаря на изискванията на стандарт

*EN ISO/IEC 17025:2005 "Общи изисквания за компетентността на лаборатории за изпитване и калибриране"*като **Лаборатория за тестване**

Акредитацията удостоверява техническата компетентност на лабораторията, ограничена до обхвата, описан в Приложението. Обхватът може да варира във времето. Изискванията на системата за управление ISO/IEC 17025:2005 (раздел 4) са написани на език, съответстващ на операциите на лабораториите за изпитване и отговарят на принципите на ISO 9001:2008 и са съобразени с нейните съответни изисквания.

Настоящият сертификат е валиден само ако е свързан с приложенията и може да бъде ограничен или отнет по всяко време в случай на неизпълнение, както е установено от ACCREDITIA.

Статусът на акредитацията в сила може да се провери на WEB сайта (www.accredia.it) или по директно заявление до посочения отдел.


Дата на

На основание чл. 2
от ЗЗЛДНа основание чл. 2
от ЗЗЛДНа основание чл. 2
от ЗЗЛД


Mod. C

Pag. 1 di 2

ACCREDITIA

Sede operativa e legale: Via Guglielmo Saliceto, 7/9 | 00161 Roma - Italy | Tel. +39 06 8440991 | Fax +39 06 8841199
info@accredia.it | www.accredia.it | Partita IVA - Codice Fiscale 10566361001






L'ENTE ITALIANO DI ACCREDITAMENTO

Membro degli Accordi di Mutuo
Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

Сертификат за акредитация

Номер на акредитация **0030**

Rev. **2**

Ние декларираме, че

CESI S.p.A.
ул. Рубатино 54 - 20134 Милано
CESI S.p.A. – Седалище в Пиаченца
ул. Нино Биксио 39
29100 Пиаченца
CESI S.p.A. – Седалище в Сериате
ул. Пастренго 9
24068 Сериате

Mod. CA-01 rev. 01

ACCREDIA

Sede operative e legale: Via Guglielmo Saliceto, 7/9 | 00161 Roma - Italy | Tel. +39 06 8440991 | Fax +39 06 8841199
info@accredia.it | www.accredia.it | Partita IVA - Codice Fiscale 10566361001



CERTIFICATO DI ACCREDITAMENTO Accreditation Certificate

Accreditamento n°
Accreditation n°

0030

Rev. **2**

Si dichiara che
We declare that

CESI S.p.A.

Sede/Headquarters:
Via Rubattino 54 - 20134 Milano MI

è conforme ai requisiti
della norma

UNI CEI EN ISO/IEC 17025:2005 "Requisiti generali per la competenza dei
Laboratori di prova e taratura"

meets the requirements
of the standard

EN ISO/IEC 17025:2005 "General Requirements for the Competence of Testing
and Calibration Laboratories" standard

quale

Laboratorio di Prova

as

Testing Laboratory

L'accreditamento attesta la competenza tecnica del Laboratorio relativamente allo scopo riportato nelle schede allegate al presente certificato. Le schede possono variare nel tempo. I requisiti gestionali della ISO/IEC 17025:2005 (sezione 4) sono scritti in un linguaggio idoneo all'attività dei Laboratori di Prova, sono conformi ai principi della ISO 9001:2008 ed allineati con i suoi requisiti applicabili.

Il presente certificato non è da ritenersi valido se non accompagnato dalle schede allegate e può essere sospeso o revocato in qualsiasi momento nel caso di inadempienza accertata da parte di ACCREDIA.

La vigenza dell'accreditamento può essere verificata sul sito WEB (www.accredia.it) o richiesta direttamente ai singoli Dipartimenti.

The accreditation certifies the technical competence of the laboratory limited to the scope detailed in the attached Enclosure. The scope may vary in the time. The management system requirements in ISO/IEC 17025:2005 (Section 4) are written in a language relevant to Testing Laboratories operations and meet the principles of ISO 9001:2008 and are aligned with its pertinent requirements.

The present certificate is valid only if associated to the annexed schedule, and can be suspended or withdrawn at any time in the event of non fulfilment as ascertained by ACCREDIA.

The in force status of the accreditation may be checked in the WEB site (www.accredia.it) or on direct request to appointed Department.

На основание чл. 2
от ЗЗЛД



CERTIFICATO DI ACCREDITAMENTO *Accreditation Certificate*

Accreditamento n°
Accreditation n°

0030

Rev. **2**


Si dichiara che
We declare that

Sedi operative:

CESI S.p.A.
Via Rubattino 54
20134 Milano MI
CESI S.p.A. - Sede di Piacenza
Via Nino Bixio 39
29100 Piacenza PC
CESI S.p.A. - Sede di Seriate
Via Pastrengo 9
24068 Seriate BG





Приложение 2 към Техническо предложение**ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 2.9.**



ИНСТРУКЦИЯ ЗА ТРАНСПОРТ, СЪХРАНЕНИЕ И СКЛАДИРАНЕ

За да се защитят от случайни повреди по време на транспорт и съхранение ограничителите за пренапрежение тип DA1 и OCP2 трябва да се транспортират и съхраняват в оригиналната опаковка на производителя. При транспорта да се използват закрити превозни средства за да не се допусне навлажняване на опаковките.



Съхранението са препоръчва да бъде в закрити и сухи складови помещения при температура до 40 °С.

Дата: 30.03.2018 г.

Подпис и печат:

На основание чл. 2
от ЗЗЛДмощник на
отариално
06.12.2017
ова



Приложение 2 към Техническо предложение**ИЗИСКВАНИ ДОКУМЕНТИ ОТ ТЕХНИЧЕСКИ
ИЗИСКВАНИЯ И СПЕЦИФИКАЦИИ****Приложение 2.10.**




Инструкция за монтаж

Полимерни ZnO Разрядници с отворен кожух

ISO 9001 & 14001

ЕС 60099-4; Преработка 2 2001



Bowthorpe EMP

Разрядник за защита от атмосферни пренапрежения за средни напрежения,
серия OCP, DLA

Предупреждение за опасност



Разрядниците за защита от атмосферни пренапрежения трябва да бъдат монтирани само от компетентен персонал, запознат с добрата практика за безопасност и с работите по високоволтово, електрическо оборудване.

Включената инструкция за монтаж не замества подходящото обучение и опита по процедурите за безопасност, нито съществуващите процедури за безопасност, работа и поддръжка.

Забележка относно монтажа

Разрядниците за защита от атмосферни пренапрежения се монтират обикновено между фазовия проводник и "земя".

Единствено в някои специални случаи (защита на електродвигатели, защита на кабелни екрани) разрядниците могат да бъдат монтирани по различен начин. Ако е необходимо, консултирайте се с вашия системен администратор.

Преди да се започне

- У Проверете дали всички части (разрядник и принадлежности) са поставени в кутията, съгласно описанието на етикета върху кутията.
- У Ако принадлежностите са пристигнали в разглобено състояние, моля сглобете всички части по съответния начин преди да престъпите към крайния монтаж. Моля погледнете съпровождащата документация (чертежи) за точния въртящ момент при завинтване.
- У Проверете дали разрядникът или принадлежностите не са повредени по време на транспорта. Никога не монтирайте повреден разрядник. Монтажът на неизправни разрядници може да доведе до тежки персонални поражения.

ВЯРНО С ОРИГИНАЛА





Bowthorpe EMP

Разрядник за защита от атмосферни пренапрежения за средни напрежения, серия OCP, DLA

- У На всички разрядници за защита от атмосферни пренапрежения има фабрична табелка, съдържаща информация за типа на разрядника и работното напрежение на същия. Проверявайте работното напрежение на всеки отделен разрядник. Не инсталирайте разрядници с работни напрежения, различни от зададените от вашия системен администратор.
- У Проверете дали разрядникът за защита от атмосферни пренапрежения и принадлежностите отговарят на местните изисквания за механични размери. Не извършвайте изменения на разрядниците или на принадлежностите !!
Не оставяйте не монтирани части !!
- У Моля информирайте се от местния системен администратор за минималните разстояния между частите под напрежение и "земя". Прилагат се стойностите за външни подстанции (на открито). Ако нямате информация за стойностите, можете да направите справка с Таблица 1 вместо стойностите съгласно IEC 60071-2.
- У Ако монтирате специален тип разрядници за защита от атмосферни пренапрежения като SPA-I с изолиран линеен проводник, тогава се допускат по-малки междини. Моля обърнете се към съответното приложение, описващо тези разрядници.
- У Ако не сте сигурни за последователността на монтажа, моля питайте и направете справка със съответния монтажен чертеж.

Разрядниците за защита от атмосферни пренапрежения използвани при напрежения, по високи от номиналните за конкретния тип, могат да предизвикат повреди и поражения. За да използвате разрядниците по предназначение, проверявайте номиналните характеристики на същите, които са изписани ясно на фабричните табелки.

Монтаж

Не захващайте полимерните кожуси на разрядници за защита от атмосферни пренапрежения с механични инструменти. Някои типове разрядници имат монтажни издатъци в двата им края.

На предвидените за целта места разрядникът може да се захваща безопасно чрез втори ключ за притягане на гайките, включени към комплекта принадлежности. Използвайте издатъка в близост до гайката, която трябва да бъде притегната.

В случай, че разрядникът няма подобни технологични издатъци, дръжте същия на ръка.

ВЯРНО С ОРИГИНАЛА





Bowthorpe EMP

Разрядник за защита от атмосферни пренапрежения за средни напрежения, серия OCP, DLA


- ✓ Проверете дали захранването на електрическата система е изключено и дали същата е заземена.
 - ✓ Спазвайте стриктно местните инструкции за безопасност и процедурите за техническо обслужване.
 - ✓ Избирайте място на монтаж във възможно най-голяма близост до предпазването оборудване (трансформатор, кабелни кутии и др.), за да се получи най-висока степен на защита.
 - ✓ Свържете заземяващия кабел към заземителния извод на разрядника. Притегнете гайката с указания на съответния чертеж въртящ момент.
 - ✓ Ако разрядникът бъде получен с присъединена метална скоба е възможно заземяващият кабел да бъде свързан към скобата. Линейният (фазовият) извод може да не бъде включен ако скобата или изводът на разрядника са монтирани директно върху заземяния кожух или рама на апарата, при положение, че електрическият контакт е сигурен и са използвани подходящи заземителни връзки. Ако съществува съмнение за качеството на връзките, тогава моля използвайте отделен проводник за свързване на скобата или извода на разрядника към системната "земя".
 - ✓ Свържете линейния кабел към линейния извод на разрядника. Притегнете гайката с указания на съответния чертеж въртящ момент.
 - ✓ Връзките към земя и към линейните изводи трябва да бъдат възможно най-къси, без резки огъвания и контури. Ако връзката с линията (фазата) не може да бъде къса, помислете за свързване на линията директно към разрядника, след което същата да продължи към местоназначението.
-
- ✓ Продължителното механично натоварване на разрядника не трябва да надвишава специфицираните стойности. Механичното претоварване може да доведе до значително съкращаване на срока на експлоатация на разрядника.
 - ✓ Ако разрядникът е снабден с прекъсващо устройство (в средата на описанието е обозначено с "D", т.е ARR-ACC-BDM), тогава проверете дали заземителният извод е достатъчно гъвкав, така че прекъсвачът да може да работи безпрепятствено.
 - ✓ Възстановете захранването на електрическата система. Избягвайте еднофазно включване, понеже то може да доведе до феро-резонанс на трансформатора ! Ако се налага да се извърши еднофазно включване, проверете дали е налице защита, понеже феро-резонансът може да доведе до повреда на разрядниците.

Техническо обслужване

Разрядниците за защита от атмосферни пренапрежения на Bowthorpe не се нуждаят от техническо обслужване. В разрядника няма части, които се нуждаят от техническо обслужване.

ВАРНО С ОРИГИНАЛА





Bowthorne EMP

Разрядник за защита от атмосферни пренапрежения за средни напрежения, серия OCP, DLA

През време на срока на експлоатация не се налагат проверки на техническите характеристики.


Демонтаж на разрядници за защита от атмосферни пренапрежения

Полимерният кожух на повредения разрядник за защита от атмосферни пренапрежения понякога е раздут. Такъв ефект може да се получи ако токът причиняващ повредата се изключи бързо преди кожухът да се разруши.

Обикновено това не е опасно ако разрядникът се остави да се охлади до околната температура. Все пак проявявайте внимание при демонтаж на подобни видове разрядници.

- ✓ Проверете дали захранването на електрическата система е изключено и дали същата е заземена.
- ✓ Спазвайте стриктно местните инструкции за безопасност и процедурите за техническо обслужване.
- ✓ Откачете линейния извод от веригата.
- ✓ Откачете от веригата заземяващия извод.

Отстояния



Системно напрежение U_m [kV]	фаза/фаза* (a) [mm]	фаза / земя* (b) [mm]
7.2	152	121
12	182	151
17.5	222	191
24	282	251
36	382	351

* местните технически норми могат да изискват по-големи отстояния

Допълнителна информация можете да получите от : info@bowthorne.com

ВЯРНО С ОРИГИНАЛА






Bowthorpe EMP

Разрядник за защита от атмосферни пренапрежения за средни напрежения,
серия OCP, DLA

Таблица 1: Минимални отстояния съгласно IEC 60071-2 за надморски височини до 1000 m.



Фиг. 1 Максимален въртящ момент на изводите на разрядника

Други фактори: Надморска височина

Цитираните по-горе отстояния се препоръчват за приложения намиращи се на надморска височина до 1000 m. За инсталации на по-голяма надморска височина следва отстоянието да се увеличава с 3% на всеки 300 метра увеличение на надморското равнище. 3% с добавя също и към разстоянието за повърхностен разряд на външния кожух на самия разрядник.

Съдържащата се в настоящата инструкция за монтаж информация описва правилния начин за монтаж на продукта. Bowthorpe обаче не може да контролира природните условия, влияещи върху монтажа на продукта. Отговорност на потребителя е да определи приложимостта на метода на монтаж при конкретните природни условия. Единствените задължения на Bowthorpe са Стандартните условия на продажба на продукта и в никакъв случай Bowthorpe няма да носи отговорност за случайни, непреки или последващи поражения, произтичащи от неправилно използване на продукта.

На основание чл. 2
от ЗЗЛД


al Estate,


Тел.: +353-61-470839
Факс : +363-61-471169

Допълнителна информация можете да получите от:

ВЯРНО С ОРИГИНАЛА







Installation Instruction

Open Cage Polymeric ZnO Surge Arresters



ISO 9001 & 14001



EC 60099-4; Ammedment 2 2001

For further information please contact: surgearresters@tycoelectronics.com

ВЯРНО С ОРИГИНАЛА





Bowthorpe

11kV Surge Arrester OCP series

Safety Warning



Surge arresters should be installed only by competent personnel familiar with good safety practices and the handling of high voltage electrical equipment.

The enclosed installation instruction is not intended as a substitute for adequate training and experience in safe procedures nor to replace or supersede existing safety, operating and maintenance procedures.

Installation Note

Arresters are typically to be installed between the line conductor and ground.

Only in a few special cases (motor protection, cable sheath protection, ...) arresters may be installed in a different way. Please consult your system administrator for details if required.

Before Starting

- Check if all parts (surge arrester & accessories) are included in the box according to the description printed on the carton label.
- If the accessories come disassembled please assemble all parts as appropriate prior to the final installation. Please refer to the enclosed drawings for the correct torque.
- Check if the arrester or the accessories have been damaged during transport. Never install a damaged arrester. It may fail violently, causing severe personal injury.
- All surge arresters carry a nameplate giving details of arrester type and voltage rating. Check the voltage rating of each single arrester. Do not install arresters with voltage ratings other than specified by your system administrator.
- Check if the arrester and the accessories fulfill the local requirements in terms of mechanical dimensions. Do not alter the arrangement of the accessories or the accessory itself. Do not leave out any parts!
- Please ask your local system administrator about the minimum clearances you have to meet between live parts and ground. The values for outdoor substations do apply. If not available you may refer to Table 1 instead showing the values according to IEC 60071-2.


- If you are installing a special kind of surge arresters like SPA-I with insulated line lead, shorter clearances may apply. Please refer to the relevant addendum covering those arresters.
- If unsure about assembly sequence, please request and refer to relevant assembly drawing.

Arresters applied at voltages higher than rating may cause damage and injury. Check the arrester rating, marked clearly on the name plate, to ensure correct application!





Installation

Do not handle the polymeric housing of the arrester with tools!



Certain type of arresters ave a protrusion at both ends of the arrester.

You can hold the arrester there safely with a second wrench to fasten the nuts included with some accessories. Use the protrusion on the side close to the nut to be fastened.



In case the arrester hasn't got a protrusion please support the arrester by hand.

For further information please contact: surgearresters@tycoelectronics.com

ВЯРНО С ОРИГИНАЛА





Bowthorpe

11kV Surge Arrester OCP series

- Make sure that the electrical system is de-energized and earthed.
- Strictly follow the local safety instructions and maintenance procedures.
- Select a mounting position as close as practicable to the equipment (transformer, cable termination, ...) to be protect in order to obtain the highest degree of protection.
- Connect the ground lead to the arrester ground terminal stud or accessory. Fasten the nut to the torque indicated in the relevant drawing.
- In case the arrester comes with a metallic bracket attached it is possible to connect the ground lead to the bracket. The line lead may also be left out if the bracket or the arrester terminal is directly mounted on the earthed tank or frame of the apparatus provided that the electrical contact is reliable and earthing interconnections are suitable. In doubt please use separate conductor cables or strip to connect the bracket or the arrester terminal to system earth.
- Connect the line lead to the arrester line terminal stud or accessory. Fasten the nut to the torque indicated in the relevant drawing.
- Make the arrester ground and line connections as short as possible avoiding sharp bends and loops. If the line connection cannot be made short, consider connecting the line directly to the arrester and continue from there.
- The continuous mechanical stress applied to the arrester i.e. via the connection shall not exceed the specified values. Mechanical overload may shorten the arrester's service lifetime significantly.
- In case the arrester is equipped with a disconnecter device (a „D“ is shown in the middle of the description, e.g. ARR-ACC-BDM.) make sure that the ground lead is flexible enough to allow the disconnecter to operate properly.
- Re-energize the electrical system. Avoid single-phase switching because this may lead to ferro-resonance of the transformer! If single-phase switching needs to be done, make sure that you are operating with protection as arresters may be destroyed in case of ferro-resonances.

Maintenance

Bowthorpe arresters are maintenance free. There are no serviceable parts inside.

Performance checks are not required during the expected service life.


Removing Arresters

The polymeric housing of failed surge arrester sometimes is inflated. This can happen if the fault current is switched off fast before the housing ruptures!

This typically does not represent a hazard if the arrester is allowed to cool down to ambient temperature. Be careful anyway when removing such kind of arresters.

- Make sure that the electrical system is de-energized.
- Strictly follow the local safety instructions and maintenance procedures.
- Disconnect the line lead from the circuit.
- Disconnect the ground lead from the circuit.

Clearances




System Voltage U_m [kV]	ph/ph* (a) [mm]	ph/ground* (b) [mm]
7,2	152	121
12	182	151
17,5	222	191
24	282	251
36	382	351

* local regulations and standards may require wider clearances!

2

For further information please contact: surgearresters@tycoelectronics.com

ВЕРНО С ОРИГИНАЛА



Bowthorpe

MV Surge Arrester OCP series

Table 1: Minimum clearances following IEC60071-2 for altitudes up to 1000 m (3300 ft).




Fig 1: Max. torque at the terminals of the arrester

Other considerations: Altitude

The clearances quoted above are recommended min clearances required for applications up to 3,300 ft (1,000m metres). For installations at higher altitudes, the accepted practice is to add 3% to the clearance length for every 1,000 ft (300 metres) increase in altitude above 3,300 ft (1,000 metres). The 3% is also added to the external housing flashover distance of the arrester itself.

The information contained in this installation instruction is intended to describe the correct method of installation for this product. However, Bowthorpe has no control over the field conditions which influence product installation. It is user's responsibility to determine the suitability of the installation method in the user's field conditions. Bowthorpe's only obligations are those in Bowthorpe's standard Conditions of Sale for this product and in no case will Bowthorpe be liable for any other incidental, indirect or consequential damages arising from the use or misuse of the product.

Tyco Electronics Bowthorpe
Energy Division
100-104 Shannon Industrial Estate,
Shannon,
Co. Clare
Ireland
Tel: +353 61 470839
Fax: +353 61 471169



For further information please contact: surgearresters@tycoelectronics.com

ВЯРНО С ОРИГИНАЛА

ФИЛКАБ
16
ПЛОВДИВ



Приложение 3 към Техническо предложение

СРОКОВЕ ЗА ДОСТАВКА

№	Наименование	Мярка	Количества със срок на доставка до 7 кал. дни	Количества със срок на доставка до 30 кал. дни
1	2	3	4	5
1.	Вентилен отвод метало - оксиден тип без искрови разрядници, 10 kV, 10kA, клас 2	бр.	3	5
2.	Вентилен отвод метало - оксиден тип без искрови разрядници, 20 kV, 10kA, клас 1	бр.	20	50
3.	Вентилен отвод метало - оксиден тип без искрови разрядници, 20 kV, 10kA, клас 2	бр.	20	50

Забележки:

1/ Срокът на доставките започва да тече от датата на изпращане на поръчката.

2/ Количествата в колона 4, със срок на доставка до 7 /седем/ календарни дни, се доставят след SAP поръчка до посочените в обявлението складове на Възложителя за покриване на спешни нужди на Възложителя.

Възложителят може да поръчва посоченото спешно количество веднъж месечно.

3/ В случай, че крайният срок на доставката съвпада с празничен или неработен ден, то доставката се извършва не по-късно от първия работен ден след изтичането на срока.

4/ При поръчки на Възложителя на количества в рамките на потвърдените от Изпълнителя и недоставени в посочените срокове, ще бъдат налагани неустойки, съгласно условията на договора.

5/ Възложителят може да поръчва количества по-малки от посочените в колони 4 и 5.

6/ Възложителят може да поръчва количества по-високи от посочените в колони 4 и 5, като това обстоятелство ще бъде посочено текстово в съответната поръчка изпратена към Изпълнителя. С потвърждението на поръчката, Изпълнителят вписва в същата очаквана дата за доставка на количествата надвишаващи посочените в колони 4 и 5.

7/ Количествата за доставка в колони 4 и 5 са отделни и независими едно от друго.

8/ Количествата за доставка в колона 5 не включват в себе си количествата за доставка в колона 4.

9/ Възложителят има право да направи едновременно поръчки за доставка на количества от колони 4 и 5.

Дата: 30.03.2018 г.

Декларатор:

На основание чл. 2
от ЗЗЛД



Пълномощник
с нотариално
5487/06.12.2017 на
илова








ФИЛКАБ АД
ул. Коматевско шосе 92
4004 Пловдив, България

T +359 32 277 171
Ф +359 32 671 133

office@filkab.com
www.filkab.com

ПЪЛНОМОЩНО

Долуподписаният **АТАНАС ИВАНОВ ТАНЧЕВ**, На основание чл. 2 от ЗЗЛД ежаваш На основание чл. 2 от ЗЗЛД ена на 10.09.2014 г. от МВР - Пловдив, с постоянен адрес: гр. Пловдив, бул. "Любен Каравелов" № 11, ет.7, ап. 55, в качеството си на Изпълнителен директор, представляващ, „ФИЛКАБ“ АД, вписано в Търговския регистър при Агенцията по вписванията **ЕИК: 115328801**, със седалище и адрес на управление: гр. Пловдив, ул. „Коматевско шосе“ № 92,

УПЪЛНОМОЩАВАМ:

АЛЕКСАНДЪР ВИКТОРОВ ПРИХОДКОВ, На основание чл. 2 от ЗЗЛД ежаваш На основание чл. 2 от ЗЗЛД едена на 11.05.2010 г. от МВР - Пловдив, **със следните права:**

Да представлява „ФИЛКАБ“ АД, като от името и за сметка на представляваното от мен дружество има право:

Да подписва всички необходими тръжни документи в т.ч. и офертите за участие на дружеството в обявени процедури за всякакви обществени поръчки, търгове или други процедури по възлагане на доставки, монтаж, СМР и др.


Да получава и подава комплект от документи за участие на дружеството в обявени процедури за всякакви обществени поръчки, търгове или други процедури по възлагане на доставки монтаж, СМР и др., представлява дружеството при отваряне на подадените оферти, както и с правото да води преговори по тръжните процедури, да взема решения за възникване на права и задължения за сметка на дружеството, да подобрява офертата и подписва съответните протоколи от тях във връзка с участието на дружеството в тези процедури.

Да води преговори и сключва договори, свързани с предмета на дейност на дружеството.

Пълномощното следва да се тълкува разширително с оглед на предоставените на пълномощника права да представлява дружеството при извършване на посочените по-горе действия.

Настоящото пълномощно е със срок до 31.12.2014 г.

На основание чл. 2
от ЗЗЛД

 *Атанас*

На основание чл. 2
от ЗЗЛД

На основании чл. 2
от ЗЗЛД

[Handwritten signature]

Приложение № 4**ДЕКЛАРАЦИЯ**

за приемане на условията в проекта на рамково споразумение и проекта на конкретен договор,
неразделна част от рамковото споразумение

Долуподписаният Александър Викторов Приходков, , в качеството ми на Пълномощник на Изпълнителния директор с нотариално заверено пълномощно № 5487/06.12.2017 на нотариус № 473 – Мина Стоилова, представляващ „Филкаб“ АД, участник в процедура за възлагане на обществена поръчка с реф. № PPD 17-158 и предмет: „Доставка на вентилни отводи средно напрежение (СрН)“,

ДЕКЛАРИРАМ, ЧЕ:

1. Приемам условията в проекта на рамково споразумение, приложен в документацията за участие.
2. Приемам условията в проекта на конкретен договор, неразделна част от рамковото споразумение, приложен в документацията за участие.

Дата: 30.03.2018 г.

Декларатор:

На основание чл. 2
от ЗЗЛДПълномощник на
с нотариално
5487/06.12.2017 на
илова



Приложение № 5

ДЕКЛАРАЦИЯ

за срока на валидност на офертата

Долуподписаният Александър Викторов Приходков, притежаващ личностно На основание чл. 2 от ЗЗЛД издадена на 11.05.2010 г. от МВР – гр. Пловдив, адрес: гр. Пловдив, бул. „Марица“ № 29, в качеството ми на Пълномощник на Изпълнителния директор с нотариално заверено пълномощно № 5487/06.12.2017 на нотариус № 473 – Мина Стоилова, представляващ „Филкаб“ АД, участник в процедура за възлагане на обществена поръчка с реф. № PPD 17-158 и предмет: „Доставка на вентилни отводи средно напрежение (СрН)“,

ДЕКЛАРИРАМ, ЧЕ:

С подаване на настоящата оферта, направените от нас предложения и поети ангажименти са валидни за срока, посочен в обявлението, считано от крайния срок за подаване на офертите

Дата: 30.03.2018 г.

Декларатор:

На основание чл. 2
от ЗЗЛД



Пълномощник на
р с нотариално
5487/06.12.2017 на
илова

