


Typ/Type		SL3/1000-TM	SL3/1250		
Kabelanschluss Cable terminal	Flachanschluss Flat terminal	Bolzendurchmesser Bolt diameter	2 x M12	3 x M12	
		Kabelschuh Cable lug	2x 300, 3 x 120	3 x 300, 4 x 185	
		Flachschiene Flat bar	80 x 10	--	
	Klemme Clamp	Anzugsdrehmoment Tightening torque	M _s Nm	35-40	35-40
		Klemmquerschnitt Clamping cross-section	mm ²	--	--
		Anzugsdrehmoment Tightening torque	Nm	--	--
		Klemmquerschnitt Clamping cross-section	mm ²	--	--
Schutzart Degree of protection	Frontseitig, Gerät eingebaut mit Klemmen- und Seitenabdeckung Front side, device fitted with clamp and lateral covers	Betriebszustand Operating condition	IP30	IP30	
		Schaltdeckel geöffnet Switching element open	IP10	IP10	
Betriebsbedingungen Operating conditions	Umgebungstemperatur ⁵⁾ /Ambient temperature ⁵⁾ T _{amb} °C		-25 bis/to +55		
	Bemessungsbetriebsart/Rated operating mode		Dauerbetrieb/Uninterrupted duty	CIOISIMIO® CIOISIMIO®	
	Betätigung/Actuation		Abhängige Handbetätigung Dependent manual operation		
	Einbaulage/Mounting position		Senkrecht, waagrecht Vertical, horizontal		
	Höhenlage/Altitude	m	Bis zu 2000/Up to 2000	Klemmen Terminals	
Verschmutzungsgrad/Pollution degree		3			
Überspannungskategorie/Overvoltage category		IV			

NH-Sicherungs-
lastschaltelsten
NH strip
type fuse-switch-
disconnectors

NH-Sicherungs-
lasttrenn-
schalter
NH fuse-switch-
disconnectors


5) 35°C Normaltemperatur, bei 55°C mit reduziertem Betriebsstrom./35°C Normal temperature, at 55°C with reduced operating current.




NH-Sicherungslastschaltleisten

NH strip-type fuse-switch-disconnectors

Typ/Type	Artikel-Nr./Article No.	Seite/Page	Beschreibung/Description	Artikel-Nr./Article No.	Seite/Page
SLT3-3SL/3X...	L390000...	SL-25	SLT3-3SL/3X3...	L300000...	SL-25
SLT3-3SR/3X...	L390000...	SL-25	SLT3-3SR/3X3...	L300000...	SL-25



Typ/Type	Artikel-Nr./Article No.	Seite/Page	Typ/Type	Artikel-Nr./Article No.	Seite/Page
SLT3-3SR/3X6/2000/TM3	L3000501	SL-25	SLT3-3SR/3X2/2000/TM3	L3900501	SL-25



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № РРД 15-042

“Вертикален разединител НН 1000 А, с триполюсно управление”

Приложение № 2




ТЕХНИЧЕСКО ОПИСАНИЕ
 на
Вертикален разединител NH 1000A с триполюсно управление

I. Описание

Триполюсните разединители серия SLT-3S са произведени от фирма Jean Muller и са предназначени за включване, изключване, разединяване на шинни системи. Те комбинират три еднополюсни разединителя в един корпус. SLT-3S са с вертикална конструкция с общо управление на полюсите и могат да бъдат включвани и изключвани под товар. Те са за директен монтаж върху събирателни шини с междуосово разстояние 185 mm.

Корпусът на SLT-3S е изработен от високоякостна стъклонапълнена пластмаса. Контактната система със сребърно покритие осигурява малки загуби, оптимални термични характеристики и висока комутационна способност. Тоководещите части остават недостъпни и след премахване на горната част, благодарение на защитните капаци с вградени дъгогасителни камери оставащи в основата.

II. Размери



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № РРД 15-042

“Вертикален разединител НН 1000 А, с триполюсно управление”

Приложение № 3



NOTIFICATION OF TEST RESULTS

Product fuse-switch-disconnectors

Tested by request of Jean Müller GmbH, Friedrichstrasse 21,
D-65343 Bltville am Rhein, Germany

Manufactured at (name and place) Jean Müller GmbH, Friedrichstrasse 21,
D-65343 Bltville am Rhein, Germany

Rating and principal characteristics Ui 1000V, Ith 722 A/1000 A

Pre-licence factory inspection carried out by VDE

Trade mark (if any) JEAN MÜLLER

Model/Type Ref. SL 3-3x/1000 and SL 3-3x3/1000

Additional information (if any) _____

A sample of product has been tested and found to be in conformity with the current HD/EN and equivalent national standard, (number and edition) EN 60947-3:1999

as shown in the Test Report (ref.No.) 2001980.54 (36 pages)

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body.


N.V. KEMA


Arnhem

Date: December 6, 2000

Internal ref: HLS/Sco

Signature:


B.T.M. Holtus




N.V. KEMA
Utrechtseweg 310, 6812 AR Arnhem
P.O. Box 9035, 6800 ET Arnhem
The Netherlands
Telephone +31 26 3 56 28 50
Telefax +31 26 3 51 49 22

TEST REPORT EN 60 947-3

Low-voltage switchgear and controlgear Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

Report

Reference No. : 2001980.54
 Tested by (+ signature) : *H.L. Schendstok*
 Approved by (+ signature) : *L.J.W. van Meegen*
 Date of issue : 2000-11-30
 Contents : 36 pages



This report is based on a blank test report that was prepared by KEMA using information obtained from the TRF originator (see below).

Testing laboratory

Name : KEMA Registered Quality B.V.
 Address : Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
 Testing location : as above and
 : *Holec Laagspanning B.V., Hengelo, The Netherlands*
All tests were observed by compiler

Client

Name : *Jean Müller GmbH*
 Address : *Friedrichstrasse 21*
 : *D-65343 ELTVILLE am Rhein, Germany*

Test specification

Standard : EN 60 947-3:99
 Test procedure : CCA-scheme
 Procedure deviation : N.A.
 Non-standard test method : N.A.

Test Report Form/blank test report

Test Report Form No. : 60947-3B/98-09
 TRF originator : KEMA
 Master TRF : dated 98-05

Copyright reserved to the bodies participating in the Committee of Certification Bodies (CCB) and/or the bodies participating in the CENELEC Certification Agreement (CCA).

Test item

Description : *fuse-switch-disconnector*
 Trademark : *Jean Müller*
 Model and/or type reference : *SL 3-3x/1000 and SL 3-3x3/1000*
 Manufacturer : *Jean Müller GmbH, Eltville am Rhein, Germany*

ВЯРНО С
ОРИГИНАЛА

ЕКТОГЕН
СОФИЯ
00А



Rating(s) : *UI 1000 V, Ith 722 A / 1000 A*

Particulars: test item vs. test requirements

- method of operation : *dependent manual operation*
- switching positions : *2 (on and off)*
- number of poles : *3-poles*
- kind of current : *AC*
- number of phases : *3*
- rated frequency (Hz) : *50 Hz*
- number of positions of the main contacts : *2 (on and off)*

Rated and limiting values, main circuit

- rated operational voltage U_e (V) : *400 V, 500 V and 690 V*
- rated insulation voltage U_i (V) : *1000 V*
- rated impulse withstand voltage U_{imp} (kV) : *12 kV*
- conventional free air thermal current I_{th} (A) : *fuse: 722 A*
disconnect knife: 1000 A
- conventional enclosed thermal current I_{the} (A)
- rated operational current I_e (A) : *fuse: 722 A*
disconnect knife: 1000 A
- rated uninterrupted current I_u (A) : *fuse: 722 A*
disconnect knife: 1000 A
- utilization category : *with disconnect knife:*
AC-21B 630 A 690 V
AC-22B 1000 A 400 V
AC-22B 800 A 500 V

with fuse:
AC-21B 630 A 690 V
AC-22B 722 A 400 V
AC-22B 630 A 500 V

Short-circuit characteristic

- rated short-time withstand current I_{cw} (kA) : -
- rated short-time making capacity I_{cm} (kA) : -
- rated conditional short-circuit current : *50 kA at 400 V*

Rated and limiting values, auxiliary circuits

- rated operational voltage (V)
- rated frequency (Hz)


**ВЯРНО С
ОРИГИНАЛА**

TRF originator

TRF originator: KEMA SOFIA

- number of circuits	:
- number and kind of contact elements	:
Co-ordination of short-circuit protective devices	:
- kind of protective device	: fuse-link, M3gTr722 NH3 500 kVA (722 A)
Test case verdicts	
Test case does not apply to the test object	: N(.A.)
Test item does meet the requirement	: P(ass)
Test item does not meet the requirement	: F(ail)
.....	:

Testing	
Date of receipt of test item	: 2000-02-24
Date(s) of performance of test	: 2000-03 and 2000-05
.....	:



General remarks

This test report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item tested.

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.


The making and breaking tests and short-circuit tests were carried out with a metallic screen placed at 165 mm at the top and 150 mm from the side of the fuse-switch-disconnector, with the cable terminals at the top.

The fuse-switch-disconnector type SL 3-3x/1000 were tested as follows:




Test sequence I and II: tests were done on phase L2, the load circuit was connected to phase L2, phases L1 and L3 were connected to the supply.




Test sequence IV: tests were done with a 3-phase supply, in the 'O-test' the load circuit was connected to all phases, in the 'CO-test' the load circuit was connected to L1 and L2.

ВЯРНО С
ОРИГИНАЛА



Copy of marking plate



JEAN MULLER  **CE**
IEC/EN 60947-3 50Hz
400V - 1000A - AC-22B 
— max. 1000A 51W — 
SL3-3X3/1000 L3021300
TM3-1000A NH3-722A

JEAN MULLER  **CE**
IEC/EN 60947-3 50Hz
400V - 1000A - AC-22B 
— max. 1000A 51W — 
SL3-3X3/1000 L3921300
TM3-1000A NH3-722A

ВЯРНО С
ОРИГИНАЛА




EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
5.2	MARKING		
	Marking on equipment itself or on nameplate or nameplates attached to the equipment and legible from the front after mounting		
	- indication of the open and closed position	<i>main contacts are visible in the open position</i>	P
	- suitability for isolation		P
	- disconnectors AC-20 and DC-20 only: marked "Do not open under load"		N
	Marking on equipment not needed to be visible after mounting:		
	- manufacturer's name or trademark	JEAN MÜLLER	P
	- type designation or serial number	SL 3-3x/1000 and SL 3-3x3/1000	P
	- rated operational current	1000 A AC-22B 400 V	P
	- rated operational voltage	400 V	P
	- utilization category	AC-22B	P
	- rated frequency	50 Hz	P
	- manufacturer's claim for compliance with IEC 60 947-3	IEC/EN 60947-3	P
	- degree of protection	IP	N
	Marking on fuse-combination units:		
	- fuse type	NH3-722A	P
	- maximum rated current	722 A	P
	- power loss of the fuse-link	51 W	P
	Identification of terminals:		
	- line terminals	<i>immaterial</i>	P
	- load terminals	L1, L2, L3	P
	- neutral pole terminal		N
	- protective earth terminal		N
	Data in the manufacturer's published information:		
	- rated insulation voltage	1000 V	P
	- rated impulse withstand voltage for equipment suitable for isolation or when determined	12 kV	P
	- pollution degree, if different from 3	3	
	- rated duty	<i>uninterrupted duty</i>	



EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	- rated short-time withstand current and duration		N
	- rated short-circuit making capacity		N
	- rated conditional short-circuit current	50 kA	P

7.1	CONSTRUCTION		
7.1.2	Current-carrying parts and their connection	<i>no contact pressure through insulation material</i>	P
7.1.3	Clearances		
	Rated impulse withstand voltage	(see test sequence I)	P
	Creepage distances		
	Pollution degree	3	—
	Comparative tracking index (V)	600 V, 450 V, 375 V	—
	Material group	I, II, IIIa	—
	Rated insulation voltage Ui (V)	1000 V	—
	Minimum creepage distances (mm)	16 mm	—
	Measured creepage distances (mm)	> 16 mm	P
	In case Uimp is not indicated		N
7.1.4	Actuator		
7.1.4.1	Insulation		
7.1.4.2	Direction of movement	(IEC 447)	P
7.1.5	Indication of contact position		
7.1.5.1.	Indicating means	<i>by actuator</i>	P
7.1.5.2	Indication by the actuator	<i>all main contacts are visible in the open position</i>	P
7.1.6	Additional safety requirements for equipment suitable for isolation		
7.1.6.1	Additional constructional requirements for equipment suitable for isolation (Ue > 50 V):		
	- marking according to 5.2b		P
	- indication of the position of the contacts	<i>all main contacts are visible in the open position</i>	P
	- construction of the actuating mechanism		P
	- minimum clearances across open contacts (see Table XIII, Part 1) (mm)	14 mm	—
	- measured clearances (mm)	> 14 mm	P
	- test Uimp across gap (kV)	18,5 kV	P

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
7.1.6.2	Supplementary requirements for equipment with provision for electrical interlocking with contactors or circuit-breakers:		N
	auxiliary switch shall be rated according to IEC 60 947-5-1		
	minimum time interval between opening of the contacts of the auxiliary contact and the contacts of the main poles (ms)		-
	measured time interval (ms)		-
	During the closing operation the contacts of the auxiliary switch shall close after or simultaneously with the contacts of the main poles		
7.1.6.3	Supplementary requirements for equipment provided with means for padlocking the open position:		N
	the locking means shall be designed in such a way that it cannot be removed with the appropriate padlock(s) installed		
	test force F applied to the actuator in an attempt to operate to the closed position (N)		-
	rated impulse withstand voltage (kV)		-
	test U _{imp} on open main contacts at the test force		
7.1.7	Terminals		
7.1.7.1	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections shall be such that necessary contact pressure is maintained	(see 8.2.4 below)	P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminal shall not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage shall not be reduced below the rated value	(see 8.2.4 below)	P
8.2.4	Mechanical properties of terminals		P
	Mechanical strength of terminals		
	maximum cross-sectional area of conductor (mm ²)	(cable lugs or busbars)	
	diameter of thread (mm)	M12	
	torque (Nm)	40 Nm x 110% = 44 Nm	



EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	5 times on 2 separate clamping units		P
	Testing for damage to and accidental loosening of conductor (flexion test)		N
	conductor of the smallest cross-sectional area (mm ²)		-
	number of conductor of the smallest cross section		-
	diameter of bushing hole (mm)		-
	height between the equipment and the platen ..		-
	mass at the conductor(s) (kg)		-
	136 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	Pull-out test		N
	force (N)		-
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	conductor of the largest cross-sectional area (mm ²)		-
	number of conductor of the largest cross section		-
	diameter of bushing hole (mm)		-
	height between the equipment and the platen ..		-
	mass at the conductor(s) (kg)		-
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	Pull-out test		N
	force (N)		-
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	conductor of the largest and smallest cross-sectional area (mm ²)		-
	number of conductor of the smallest cross section, number of conductor of the largest cross section		-
	diameter of bushing hole (mm)		-
	height between the equipment and the platen ..		-
	mass at the conductor(s) (kg)		-

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		N
	Pull-out test		N
	force (N)		-
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		N
7.1.7.2	Connection capacity		
	type of conductors: <i>(cable lugs or busbars)</i>		-
	minimum cross-sectional area of conductor (mm ²)		-
	maximum cross-sectional area of conductor (mm ²)		-
	number of conductors simultaneously connectable to the terminal		-
7.1.7.3	Connection		
	terminals for connection to external conductors shall be readily accessible during installation		P
	clamping screws and nuts shall not serve to fix any other component		P
7.1.7.4	Terminal identification and marking		
	terminal intended exclusively for the neutral conductor		N
	protective earth terminal		N
	other terminals	L1, L2, L3	P
7.1.8	Additional requirements for equipment provided with a neutral pole		N
	Marking of neutral pole		N
	The switched neutral pole shall not break before and shall not make after the other poles		N
	Conventional thermal current of neutral pole		N
7.1.9	Provisions for protective earthing		N
7.1.9.1	The exposed conductive parts shall be electrically interconnected and connected to a protective earth terminal		N
7.1.9.2	The protective earth terminal shall be readily accessible		N
	The protective earth terminal shall be suitably protected against corrosion		N

ВЯРНО С. ОТКРИВАНА


РЕАКТОРЕН

РИОН


СОФИЯ

ООА

TRF originator: KEMA



EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	The electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N
	The protective earth terminal shall have no other functions		N
7.1.9.3	Protective earth terminal marking and identification		N
7.1.10	Enclosure for equipment		N
7.1.10.1	Design		N
	The enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N
	Sufficient space shall be provided inside the enclosure		N
	The fixed parts of a metal enclosure shall be electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N
	Under no circumstances shall a removable metal part of the enclosure be insulated from the part carrying the earth terminal when the removable part is in place		N
	The removable parts of the enclosure shall be firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means shall be provided to prevent loss of the fastening devices		N
	If the enclosure is used for mounting push-buttons, it shall not be possible to remove the buttons from the outside of the enclosure		N
7.1.10.2	Insulation		N
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining shall be securely fixed to the enclosure		N
7.1.11	Degree of protection of enclosed equipment		




C

C


EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Degree of protection	IP ..	N

8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS		
8.3.3.1	Temperature-rise		
	ambient temperature 10-40 °C	23 °C	-
	test enclosure W x H x D (mm x mm x mm)	-	-
	material of enclosure	-	-
	Main circuits, test conditions:		
	- conventional thermal current Ith (A)	722 A with fuse-links 1000 A with disconnect knives	-
	- conventional enclosed thermal current Ithe (A) :		-
	- cable/busbar cross-section (mm ²) / (mm)	fuse-links: 50 x 10 mm busbar and 2 x 240 mm ² cable disconnect knives: 60 x 10 mm horizontal busbar and 2 x 60 x 5 mm outgoing terminals	-
	Fuse-link details (fuse-combination units only):		
	- manufacturer's name, trademark or identification mark	Jean Müller	-
	- manufacturer's model or type reference	M3gTr722 NH3	-
	- rated current (A)	500 kVA (722 A)	-
	- power loss (W)	51 W	-
	- rated breaking capacity (kA)	100 kA	-
	Temperature-rise	(see appended table)	P
	Auxiliary circuits: temperature rise of connecting terminals (K)		N
	idem, requirement (K)	≤	-
	rated operation current (A)		-
	cross-section (mm ²)		-
8.3.3.2	Test of dielectric properties, impulse withstand voltage (Uimp indicated):		
	- rated impulse withstand voltage (kV)	12 kV	-
	- test Uimp main circuits (kV)	14,8 kV	P




EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	- test Uimp auxiliary circuits (kV)	N
	- test Uimp on open main contacts (equipment suitable for isolating) (kV)	18,5 kV	P
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		N
	- rated insulation voltage (V)		—
	- main circuits, test voltage for 1 min (V)		
	- control and auxiliary circuits, test voltage for 1 min (V)		

8.3.3.3	Making and breaking capacity	<i>fuse-switch-disconnector type</i> <i>SI. 3-3x3/1000</i>	
	utilization category	AC-22B	—
	rated operational voltage Ue (V)	400 V	—
	rated operational current Ie (A) or power (kW) ..	1000 A	—
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: 421 V L2: 421 V L3: 420 V	—
	- test current I/Ie = (A)	L1: 3800 A L2: 3830 A L3: 3860 A	—
	- power factor/time constant	L1: 0,64 L2: 0,64 L3: 0,64	—
	Conditions, break operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: L2: L3:	—
	- test current I/Ie = (A)	L1: L2: L3:	—
	- power factor	L1: L2: L3:	—
	transient recovery voltage (V)	L1: 421 V L2: 421 V L3: 420 V	—
	current duration (ms)	440 ms	—
	time interval between operations	180 s	—




EN 60 947-3			
Clause	Requirement ~ Test	Result - Remark	Verdict
	Number of make/break or make and break operations	5 x make/break	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		
	oscillatory frequency (kHz)	86,3 kHz	—
	Measured oscillatory frequency (kHz)	L1: 87,1 kHz L2: 87,1 kHz L3: 87,1 kHz	P
	Factor γ	L1: 1,11 L2: 1,11 L3: 1,11	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage (2 U _I) for 1 min (V)	2000 V	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	< 5 μ A	P
	test voltage (1,1 U _e) (V)	440 V	—
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 38 K – 60 K disconnect knives: 52 K – 80 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 50 x 10 mm busbar and 2 x 240 mm ² cable disconnect knives: 60 x 10 mm busbar and 4 x 150 mm ² cable	—
	test current I _e (A)	fuse-links: 722 A disconnect knives 1000 A	—
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and U _e > 50 V only)		
	actuator type (fig.)	one-hand operated (b)	—




EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	actuating force for opening (N)	215 N	—
	test force with blocked main contacts (N)	400 N	—
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P

8.3.3.3	Making and breaking capacity	<i>fuse-switch-disconnector type</i> <i>SL 3-3x/1000</i>	
	utilization category	AC-22B	—
	rated operational voltage Ue (V)	400 V	—
	rated operational current Ie (A) or power (kW) ..	1000 A	—
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: L2: 426 V L3:	—
	- test current I/Ie = (A)	L1: L2: 3768 A L3:	—
	- power factor/time constant	L1: L2: 0,64 L3:	—
	Conditions, break operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: L2: L3:	—
	- test current I/Ie = (A)	L1: L2: L3:	—
	- power factor	L1: L2: L3:	—
	transient recovery voltage (V)	L1: L2: 426 V L3:	—
	current duration (ms)	600 ms	—
	time interval between operations	180 s	—
	Number of make/break or make and break operations	5 x make/break	P




EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		
	oscillatory frequency (kHz)	85,9 kHz	—
	Measured oscillatory frequency (kHz)	L1: L2: 89,6 kHz L3:	P
	Factor γ	L1: L2: 1,11 L3:	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	4,0 μ A – 8,3 μ A	P
	test voltage (1,1 Ue) (V)	440 V, tested with 800 V	—
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	<i>fuse-links: 49 K – 72 K</i> <i>disconnect knives: 51 K – 74 K</i>	P
	conductor cross-sectional area (mm ²)	<i>fuse-links: 50 x 10 mm busbar and 2 x 240 mm² cable</i> <i>disconnect knives: 60 x 10 mm horizontal busbar and 2 x 60 x 5 mm outgoing terminals</i>	—
	test current Ie (A)	<i>fuse-links: 722 A</i> <i>disconnect knives 1000 A</i>	—
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and Ue > 50 V only)		
	actuator type (fig.)	one-hand operated (e)	—
	actuating force for opening (N)	181 N	—




EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	test force with blocked main contacts (N)	400 N	-
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P

8.3.3.3	Making and breaking capacity	<i>fuse-switch-disconnector type</i> <i>SL 3-3x3/1000</i>	
	utilization category	AC-21B	-
	rated operational voltage U_e (V)	690 V	-
	rated operational current I_e (A) or power (kW) ..	630 A	-
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		
	- test voltage $U/U_e = 1,05$ (V)	L1: 747 V L2: 747 V L3: 747 V	-
	- test current $I/I_e =$ (A)	L1: 974 A L2: 986 A L3: 985 A	-
	- power factor/time constant	L1: 0,95 L2: 0,95 L3: 0,95	-
	Conditions, break operation AC-23A and AC-23B only:		
	- test voltage $U/U_e = 1,05$ (V)	L1: L2: L3:	-
	- test current $I/I_e =$ (A)	L1: L2: L3:	-
	- power factor	L1: L2: L3:	-
	transient recovery voltage (V)	L1: 741 V L2: 747 V L3: 748 V	-
	current duration (ms)	460 ms	-
	time interval between operations	60 s	-
	Number of make/break or make and break operations	5 x make/break	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		



EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	oscillatory frequency (kHz)	kHz	—
	Measured oscillatory frequency (kHz)	L1: L2: L3:	N
	Factor γ	L1: L2: L3:	N
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage (2 U_i) for 1 min (V)	2000 V	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	4,6 μ A – 8,2 μ A	P
	test voltage (1,1 U_e) (V)	759 V, tested with 800 V	—
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 57 K – 74 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 40 x 10 mm busbar and 2 x 185 mm ² cable	
	test current I_e (A)	fuse-links: 630 A	
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and $U_e > 50$ V only)		
	actuator type (fig.)	one-hand operated (e)	
	actuating force for opening (N)	215 N	
	test force with blocked main contacts (N)	400 N	
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P



[Handwritten signature]

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity	<i>fuse-switch-disconnector type SL 3-3x/1000</i>	
	utilization category	AC-21B	—
	rated operational voltage Ue (V)	690 V	—
	rated operational current Ie (A) or power (kW) ..	630 A	—
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: L2: 747 V L3:	—
	- test current I/Ie = (A)	L1: L2: 991 A L3:	—
	- power factor/time constant	L1: L2: 0,94 L3:	—
	Conditions, break operation AC-23A and AC-23B only:		
	- test voltage U/Ue = 1,05 (V)	L1: L2: L3:	—
	- test current I/Ie = (A)	L1: L2: L3:	—
	- power factor	L1: L2: L3:	—
	transient recovery voltage (V)	L1: L2: 744 V L3:	—
	current duration (ms)	360 ms	—
	time interval between operations	60 s	—
	Number of make/break or make and break operations	5 x make/break	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		
	oscillatory frequency (kHz)	kHz	—
	Measured oscillatory frequency (kHz)	L1: L2: L3:	N
	Factor y	L1: L2: L3:	N




[Handwritten signature]

EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	4,4 μA – 8,1 μA	P
	test voltage (1,1 Ue) (V)	759 V, tested with 800 V	—
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	<i>fuse-links: 58 K – 73 K</i>	P
	conductor cross-sectional area (mm ²)	<i>fuse-links: 40 x 10 mm busbar and 2 x 185 mm² cable</i>	—
	test current Ie (A)	<i>fuse-links: 630 A</i>	—
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and Ue > 50 V only)		
	actuator type (fig.)	<i>one-hand operated (e)</i>	—
	actuating force for opening (N)	181 N	—
	test force with blocked main contacts (N)	400 N	—
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P

8.3.3.3	Making and breaking capacity	<i>fuse-switch-disconnector type SL 3-3x3/1000</i>	
	utilization category	<i>AC-22B</i>	
	rated operational voltage Ue (V)	<i>500 V</i>	
	rated operational current Ie (A) or power (kW) ..	<i>800 A</i>	
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		



EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	- test voltage $U/U_e = 1,05$ (V)	L1: 528 V L2: 532 V L3: 533 V	-
	- test current $I/I_e =$ (A)	L1: 2466 A L2: 2456 A L3: 2410 A	-
	- power factor/time constant	L1: 0,65 L2: 0,65 L3: 0,65	-
Conditions, break operation AC-23A and AC-23B only:			
	- test voltage $U/U_e = 1,05$ (V)	L1: L2: L3:	-
	- test current $I/I_e =$ (A)	L1: L2: L3:	-
	- power factor	L1: L2: L3:	-
	transient recovery voltage (V)	L1: 528 V L2: 532 V L3: 533 V	-
	current duration (ms)	360 ms	-
	time interval between operations	60 s	-
	Number of make/break or make and break operations	5 x make/break	P
Characteristic of transient recovery voltage for AC-22 and AC-23 only			
	oscillatory frequency (kHz)	65,75 kHz	-
	Measured oscillatory frequency (kHz)	L1: 66,7 kHz L2: 67,6 kHz L3: 65,8 kHz	P
	Factor γ	L1: 1,12 L2: 1,11 L3: 1,11	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage ($2 U_i$) for 1 min (V)	2000 V	-
	No flashover or breakdown		P




EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	3,9 μ A - 8,4 μ A	P
	test voltage (1,1 Ue) (V)	550 V, tested with 800 V	—
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 61 K - 78 K disconnect knives: 48 K - 61 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 40 x 10 mm busbar and 2 x 185 mm ² cable disconnect knives: 50 x 10 mm busbar and 2 x 240 mm ² cable	—
	test current Ie (A)	fuse-links: 630 A disconnect knives 800 A	—
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and Ue > 50 V only)		
	actuator type (fig.)	one-hand operated (e)	—
	actuating force for opening (N)	215 N	—
	test force with blocked main contacts (N)	400 N	—
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P
8.3.3.3	Making and breaking capacity	fuse-switch-disconnector type SL 3-3x/1000	
	utilization category	AC-22B	—
	rated operational voltage Ue (V)	500 V	—
	rated operational current Ie (A) or power (kW) ..	800 A	—
	Conditions, make/break operations or make operation AC-23A and AC-23B only:		




EN 60 947-3

Clause	Requirement - Test	Result - Remark	Verdict
	- test voltage $U/U_e = 1,05$ (V)	L1: L2: 528 V L3:	—
	- test current $I/I_e =$ (A)	L1: L2: 2414 A L3:	—
	- power factor/time constant	L1: L2: 0,66 L3:	—
Conditions, break operation AC-23A and AC-23B only:			
	- test voltage $U/U_e = 1,05$ (V)	L1: L2: L3:	—
	- test current $I/I_e =$ (A)	L1: L2: L3:	—
	- power factor	L1: L2: L3:	—
	transient recovery voltage (V)	L1: L2: 532 V L3:	—
	current duration (ms)	480 ms	—
	time interval between operations	60 s	—
	Number of make/break or make and break operations	5 x make/break	P
Characteristic of transient recovery voltage for AC-22 and AC-23 only			
	oscillatory frequency (kHz)	65,75 kHz	—
	Measured oscillatory frequency (kHz)	L1: L2: 66,7 kHz L3:	P
	Factor γ	L1: L2: 1,12 L3:	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		
	test voltage ($2 U_i$) for 1 min (V)	2000 V	—
	No flashover or breakdown		P



EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3.5	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA)	4,7 μ A - 8,3 μ A	P
	test voltage (1,1 Ue) (V)	550 V, tested with 800 V	-
8.3.3.6	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 55 K - 73 K disconnect knives: 52 K - 60 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 40 x 10 mm busbar and 2 x 185 mm ² cable disconnect knives: 50 x 10 mm busbar and 2 x 240 mm ² cable	-
	test current Ie (A)	fuse-links: 630 A disconnect knives 800 A	-
8.3.3.7	Strength of actuator mechanism (switch-disconnectors and Ue > 50 V only)		
	actuator type (fig.)	one-hand operated (e)	-
	actuating force for opening (N)	181 N	-
	test force with blocked main contacts (N)	400 N	-
	Lockability of driving mechanism in OFF-position at test force and blocked main contacts		N
	Position indicator does not show OFF-position after capture of test force at blocked main contacts		P

8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY <i>fuse-switch-disconnector type SL3-3x/1000</i>		
8.3.4.1	Operational performance test		
	utilization category	AC-22B	-
	rated operational voltage (V)	400 V	-
	rated operational current (A)	1000 A	-
	Test conditions electrical operation cycles:		




EN 60 947-3

Clause	Requirement - Test	Result - Remark	Verdict
	test voltage (V)	L1: - L2: 413 V L3: -	-
	test current (A)	L1: - L2: 1003 A L3: -	-
	power factor/time constant	L1: - L2: 0,81 L3: -	-
	Number of cycles with current	100	P
	Number of cycles without current	500	P
	First test sequence (with/without current)	with current	-
	Second test sequence (with/without current)	without current	-
	time interval between first and second test sequence	1 hour	-
8.3.4.2	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No breakdown or flashover		P
8.3.4.3	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA	5,7 μ A - 7,1 μ A	P
	test voltage (1,1 Ue) (V)	440 V, tested with 800 V	-
8.3.4.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 59 K - 71 K disconnect knives: 47 K - 57 K	P
	conductor cross-sectional area (mm ²)	fuse-links: 50 x 10 mm busbar and 2 x 240 mm ² cable disconnect knives: 60 x 10 mm horizontal busbar and 2 x 60 x 5 mm outgoing terminals	-
	test current Ie (A)	fuse-links: 722 A disconnect knives: 1000 A	-



EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY <i>fuse-switch-disconnector type SL3-3x/1000</i>		
8.3.4.1	Operational performance test		
	utilization category	AC-22B	—
	rated operational voltage (V)	500 V	—
	rated operational current (A)	800 A	—
	Test conditions electrical operation cycles:		
	test voltage (V)	L1: - L2: 510 V L3: -	—
	test current (A)	L1: - L2: 814 A L3: -	—
	power factor/time constant	L1: - L2: 0,80 L3: -	—
	Number of cycles with current	200	P
	Number of cycles without current	800	P
	First test sequence (with/without current)	with current	—
	Second test sequence (with/without current) ...	without current	—
	time interval between first and second test sequence	1 hour	—
8.3.4.2	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA	4,8 μ A – 7,3 μ A	P
	test voltage (1,1 Ue) (V)	550 V, tested with 800 V	—
8.3.4.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	fuse-links: 56 K – 72 K disconnect knives: 45 K – 60 K	P




EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	conductor cross-sectional area (mm ²)	<i>fuse-links: 40 x 10 mm busbar and 2 x 185 mm² cable</i> <i>disconnect knives: 50 x 10 mm busbar and 2 x 240 mm² cable</i>	-
	test current I _e (A)	<i>fuse-links: 630 A</i> <i>disconnect knives: 800 A</i>	-

8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY <i>fuse-switch-disconnector type SL3-3x/1000</i>		
8.3.4.1	Operational performance test		
	utilization category	<i>AC-21B</i>	-
	rated operational voltage (V)	<i>690 V</i>	-
	rated operational current (A)	<i>630 A</i>	-
	Test conditions electrical operation cycles:		
	test voltage (V)	L1: - L2: <i>689 V</i> L3: -	-
	test current (A)	L1: - L2: <i>632 A</i> L3: -	-
	power factor/time constant	L1: - L2: <i>0,95</i> L3: -	-
	Number of cycles with current	<i>200</i>	<i>P</i>
	Number of cycles without current	<i>800</i>	<i>P</i>
	First test sequence (with/without current)	<i>with current</i>	-
	Second test sequence (with/without current) ...	<i>without current</i>	-
	time interval between first and second test sequence	<i>1 hour</i>	-
8.3.4.2	Dielectric verification		
	test voltage (2 U _i) for 1 min (V)	<i>2000 V</i>	-
	No breakdown or flashover		<i>P</i>
8.3.4.3	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		<i>N</i>



EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Leakage current (other utilization categories) ≤ 2 mA	5,6 μ A - 7,8 μ A	P
	test voltage (1,1 Ue) (V)	759 V, tested with 800 V	-
8.3.4.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	<i>fuse-links: 55 K - 76 K</i>	P
	conductor cross-sectional area (mm ²)	<i>fuse-links: 40 x 10 mm busbar and 2 x 185 mm² cable</i>	-
	test current Ie (A)	<i>fuse-links: 630 A</i>	-

8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY <i>fuse-switch-disconnector type SL3-3x3/1000 only without current</i>		
8.3.4.1	Operational performance test		
	utilization category	AG-22B	-
	rated operational voltage (V)	400 V	-
	rated operational current (A)	1000 A	-
	Test conditions electrical operation cycles:		
	test voltage (V)	L1: - L2: - L3: -	-
	test current (A)	L1: - L2: - L3: -	-
	power factor/time constant	L1: - L2: - L3: -	-
	Number of cycles with current		P
	Number of cycles without current	500 + 100	P
	First test sequence (with/without current)	<i>without current</i>	-
	Second test sequence (with/without current) ...		-
	time interval between first and second test sequence		-
8.3.4.2	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No breakdown or flashover		P
8.3.4.3	Leakage current		




C

C

EN 60 947-3			
Clause	Requirement - Test	Result - Remark	Verdict
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		N
	Leakage current (other utilization categories) ≤ 2 mA	4,8 μ A - 7,3 μ A	P
	test voltage (1,1 Ue) (V)	440 V, tested with 800 V	-
8.3.4.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	<i>fuse-links: 51 K - 68 K</i> <i>disconnect knives: 51 K - 74 K</i>	P
	conductor cross-sectional area (mm ²)	<i>fuse-links: 50 x 10 mm busbar and 2 x 240 mm² cable</i> <i>disconnect knives: 60 x 10 mm horizontal busbar and 2 x 60 x 5 mm outgoing terminals</i>	-
	test current Ie (A)	<i>fuse-links: 722 A</i> <i>disconnect knives: 1000 A</i>	-

8.3.5	TEST SEQUENCE III: SHORT-CIRCUIT PERFORMANCE CAPABILITY		N
8.3.5.1	Short-time withstand current test		
	Rated short-time withstand current Icw (A)		
	test voltage (V)	L1: L2: L3:	
	r.m.s. test current (A)	L1: L2: L3:	
	peak test current (A)	L1: L2: L3:	
	power factor/time constant	L1: L2: L3:	
	test duration (s)		
	Equivalent with		
8.3.5.1.5	Behaviour of the equipment during the test		




EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
8.3.5.1.6	Conditions of the equipment after the test		
8.3.5.2	Short-circuit making capacity		
	Rated short-circuit making capacity I _{cm} (A)		
	test voltage (V)	L1: L2: L3:	
	r.m.s. test current (A)	L1: L2: L3:	
	peak test current (A)	L1: L2: L3:	
	power factor/time constant	L1: L2: L3:	
	current duration (s)		
	number of making cycles		
8.3.5.2.5	Behaviour of the equipment during the test		
8.3.5.2.6	Conditions of the equipment after the test		
8.3.5.3	Dielectric verification		
	test voltage (2 U _i) for 1 min (V)		
	No flashover or breakdown		
8.3.5.4	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		
	Leakage current (other utilization categories) ≤ 2,0 mA		
	test voltage (1,1 U _e) (V)		
8.3.5.5	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K		
	cross-sectional area (mm ²)		
	test current I _e (A)		

8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT <i>fuse-switch-disconnector type SL 3-3x3/1000</i>	
	Protective device details:	




EN 60 947-3

Clause	Requirement - Test	Result - Remark	Verdict
	- manufacturer's name, trademark or identification mark	Jean Müller ..	-
	- manufacturer's model or type reference	M3gTr722 NH3	-
	- rated voltage (V)	400 V	-
	- rated current (A)	500 kVA (722 A)	-
	- rated breaking capacity (kA)	100 kA	-
8.3.6.2	Fuse protected short-circuit withstand		
	test voltage (1,05 Ue) (V)	L1: 420 V L2: 420 V L3: 420 V	-
	test current (kA)	L1: 50,4 kA L2: 51,8 kA L3: 50,0 kA	-
	rated frequency (Hz)	50 Hz	-
	power factor	0,22	-
	Fuse protected short-circuit withstand		
	- max. let-through current (kA)	L1: 40,4 kA L2: 48,8 kA L3: 40,4 kA	-
	- Joule integral I ² dt (A ² s)	L1: 3690 kA ² s L2: 3970 kA ² s L3: 3710 kA ² s	-
	Fuse protected short-circuit making		
	- mean velocity of 15 manually under no-load conditions operations (m/s)	1,77 m/s	-
	- point at which the measurement is made		-
	- test speed during the fuse protected short-circuit making (m/s)	0,65 m/s	-
	- max. let-through current (kA)	L1: 42,7 kA L2: 42,7 kA L3: 5,50 kA	-
	- Joule integral I ² dt (A ² s)	L1: 3390 kA ² s L2: 3240 kA ² s L3: 88,2 kA ² s	-
8.3.6.2.5	Behaviour of the equipment during the test		P
8.3.6.2.6	Conditions of the equipment after the test		P
8.3.6.3	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No flashover or breakdown		P




EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
8.3.6.4	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA		
	Leakage current (other utilization categories) $\leq 2,0$ mA	4,2 μ A – 9,3 μ A	P
	test voltage (1,1 Ue) (V)	440 V, tested with 800 V	–
8.3.6.5	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	50 K – 69 K	P
	cross-sectional area (mm ²)	50 x 10 mm busbar and 2 x 240 mm ² cable	–
	test current Ie (A)	fuse-links: 722 A	–
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT <i>fuse-switch-disconnector type SL 3-3x/1000</i>		
	Protective device details:		
	- manufacturer's name, trademark or identification mark	Jean Müller	–
	- manufacturer's model or type reference	M3gTr722 NH3	–
	- rated voltage (V)	400 V	–
	- rated current (A)	722 A	–
	- rated breaking capacity (kA)	100 kA	–
8.3.6.2	Fuse protected short-circuit withstand		
	test voltage (1,05 Ue) (V)	L1: 420 V L2: 420 V L3: 420 V	–
	test current (kA)	L1: 50,4 kA L2: 51,8 kA L3: 50,0 kA	–
	rated frequency (Hz)	50 Hz	–
	power factor	0,22	–
	Fuse protected short-circuit withstand		
	- max. let-through current (kA)	L1: 38,1 kA L2: 50,2 kA L3: 38,1 kA	–
	- Joule integral I ² dt (A ² s)	L1: 3840 kA ² s L2: 4160 kA ² s L3: 3300 kA ² s	–



EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	Fuse protected short-circuit making		
	- mean velocity of 15 manually under no-load conditions operations (m/s)	1,15 m/s	-
	- point at which the measurement is made		-
	- test speed during the fuse protected short-circuit making (m/s)	0,65 m/s	-
	- max. let-through current (kA)	L1: 39,7 kA L2: 39,7 kA L3:	
	- Joule integral I ² dt (A ² s)	L1: 2960 kA ² s L2: 2960 kA ² s L3:	
8.3.6.2.5	Behaviour of the equipment during the test		P
8.3.6.2.6	Conditions of the equipment after the test		P
8.3.6.3	Dielectric verification		
	test voltage (2 Ui) for 1 min (V)	2000 V	-
	No flashover or breakdown		P
8.3.6.4	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		
	Leakage current (other utilization categories) ≤ 2,0 mA	4,0 μA – 8,7 μA	P
	test voltage (1,1 Ue) (V)	440 V, tested with 800 V	
8.3.6.5	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K	51 K – 74 K	P
	cross-sectional area (mm ²)	50 x 10 mm busbar and 2 x 240 mm ² cable	
	test current Ie (A)	fuse-links: 722 A	

8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY		
8.3.7.1	Overload test		
	ambient temperature 10-40 °C	23 °C	
	test enclosure W x H x D (mm x mm x mm)	-	
	material of enclosure		
	test current 1,6 Ithe or 1,6 Ith (A)	1155 A	



EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	cable/busbar cross-section (mm ²) / (mm)	busbar 50 x 10 mm cable 2 x 240 mm ²	—
	Fuse-link details:		
	- manufacturer's name, trademark or identification mark	Jean Müller	—
	- rated current (A)	500kVA (722 A)	—
	- power loss (W)	51 W	—
	- rated breaking capacity (kA)	100 kA	—
	- time duration of the overload test (s)	1860 s	—
	Within 3 min after the fuse(s) has(have) operated (or 1 h), the equipment shall be operated once, i.e. opened and closed		P
	The equipment shall not have undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		
	test voltage (2 U _i) for 1 min (V)	2000 V	—
	No flashover or breakdown		P
8.3.7.3	Leakage current		
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA		
	Leakage current (other utilization categories) ≤ 2 mA)	5,9 μA – 7,4 μA	P
	test voltage (1,1 U _e) (V)	440 V, tested with 800 V	—
8.3.7.4	Temperature-rise verification		
	Temperature rise of main circuit terminals ≤ 80 K (K)	53 K – 70 K	P
	cross-sectional area (mm ²)	50 x 10 mm busbar and 2 x 240 mm ² cable	—
	test current I _e (A)	fuse-links: 722 A	—



EN 60 947-3			
Clause	Requirement – Test	Result - Remark	Verdict
	TABLE: temperature rise measurements <i>with fuse-links</i>		
	temperature rise dT of part:	phase	dT (K)
	<i>terminal to horizontal busbar system (line terminal)</i>	L1	48
		L2	53
		L3	62
	<i>terminal to cable(s) (load terminal)</i>	L1	66
		L2	66
		L3	58
	<i>internal busbar near insulation material</i>	L1	122
	<i>actuator</i>	-	3
			required dT (K)
			70
			70
			70
			70
			70
			145
			25

TABLE: temperature rise measurements <i>with contact knives</i>			
temperature rise dT of part:	phase	dT (K)	required dT (K)
<i>terminal to horizontal busbar system (line terminal)</i>	L1	53	70
	L2	49	70
	L3	47	70
<i>terminal to cable(s) (load terminal)</i>	L1	62	70
	L2	64	70
	L3	61	70



Remarks

Additional test:

- Parts of insulation material necessary to retain current carrying parts were subjected to a glow-wire test according EN 60947-1, at 960 °C for the other insulation materials 650 °C.
These tests withstood the requirements.

description:

Type SL 3-3x/1000 : fuse-switch-disconnector, 3-poles, switching pole after pole

Type SL 3-3x3/1000 : fuse-switch-disconnector, 3-poles, switching 3-poles

СПИСЪК

на типовите изпитвания, проведени от независима изпитвателна лаборатория,
за предлаганите вертикални разединители, както следва:

Марка: Jean Muller
Продукт: вертикален предпазител-разединители
Серия: SL3

- 5.2 Маркировка
- 7.1 Конструкция
- 8.3.3 Основни характеристики
 - 8.3.3.1 Повишаване на температурата
 - 8.3.3.2 Диелектрични свойства
 - 8.3.3.3 Работна и гранична изключвателна възможност при късо съединение
 - 8.3.3.4 Проверка на диелектричните свойства
 - 8.3.3.5 Ток на утечка
 - 8.3.3.6 Проверка при повишаване на температурата
 - 8.3.3.7 Експлоатационна възможност на задвижващия механизъм
- 8.3.4 Работни характеристики
 - 8.3.4.1 Изпитване на експлоатационната възможност
 - 8.3.4.2 Проверка на диелектричните свойства на прекъсвач-разединителя
 - 8.3.4.3 Ток на утечка
 - 8.3.4.4 Проверка при повишаване на температурата
- 8.3.5 Характеристики при късо съединение
 - 8.3.5.1 Издържан импулсен ток
 - 8.3.5.2 Работна изключвателна възможност при късо съединение
 - 8.3.5.3 Проверка на диелектричните свойства
 - 8.3.5.4 Ток на утечка
 - 8.3.5.5 Проверка при повишаване на температурата
- 8.3.6 Условен ток на късо съединение
 - 8.3.6.2 Издържан ток на късо съединение със стопяем предпазител
 - 8.3.6.3 Проверка на диелектричните свойства
 - 8.3.6.4 Ток на утечка
 - 8.3.6.5 Проверка при повишаване на температурата
- 8.3.7 Характеристики при претоварване
 - 8.3.7.1 Изпитване на претоварване
 - 8.3.7.2 Проверка на диелектричните свойства
 - 8.3.7.3 Ток на утечка
 - 8.3.7.4 Проверка при повишаване на температурата



[Handwritten signature]

ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Вертикален разединител НН 1000 А, с триполюсно управление”

Приложение № 4



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**


Location where activities are performed under accreditation


Head Office

Meander 1051
6825 MJ
Arnhem
The Netherlands

No.	Material or product	Type of activity	Reference number	Remarks
A. Electrical Safety Tests				
1a	Cables and cords (CABL)	Type test of cables and cords according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	HD 21 HD 22 HD 603 HD 604 HD 605 EN 13501, EN 50143; EN 50214; EN 50267; EN 50525; EN 50288; EN 50399; EN 50618 NEN/EN 50200 NEN/EN/IEC 60228 NEN-EN 50525 NEN/EN 50266 NEN/EN 50362 NEN/EN /IEC 61034 IEC 60092; IEC 60227 *; IEC 60245 *; IEC 60331; IEC 60332; IEC 60502-1; IEC 60502-2; IEC 60754; IEC 60800; IEC 60840; IEC 62067	* see note 3

This annex has been approved by:


C. van der Poel
Chief Executive



C

C

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
1a	Cables and cords (CABL)	Type test of cables and cords according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	DEKRA K 42; DEKRA K 102 DEKRA K 145; DEKRA K 146 DEKRA K 151; DEKRA K 152 DEKRA K 156; DEKRA K 157 DEKRA K 158; DEKRA K160 DEKRA K 161; DEKRA K 162 DEKRA K 163; DEKRA K 164 DEKRA K 165; DEKRA K 167 DEKRA K 168; DEKRA K 169 DEKRA K 170; DEKRA K 171 DEKRA K 175; DEKRA K 176 DEKRA K 177; DEKRA K 178 DEKRA K 179 BS 6004; BS 6007; BS 4553; BS 5467; BS 6231; BS 6346; BS 6387; BS 6500; BS 6622; BS 6724; BS 6883; BS 7211; BS 7629; BS 7835; BS 7846; BS 7889; BS 8491; BS EN 50288-7 BS EN 50525 DIN VDE0815; DIN VDE0250	* see note 3
		Test methods for non-metallic materials	IEC 60811-201; IEC 60811-202 IEC 60811-203; IEC 60811-401 IEC 60811-402; IEC 60811-403 IEC 60811-404; IEC 60811-405 IEC 60811-406; IEC 60811-408 IEC 60811-409; IEC 60811-411 IEC 60811-412; IEC 60811-501 IEC 60811-502; IEC 60811-503 IEC 60811-504; IEC 60811-505 IEC 60811-506; IEC 60811-507 IEC 60811-508; IEC 60811-509 IEC 60811-510; IEC 60811-511 IEC 60811-605; IEC 60811-606 IEC 60811-607	
		Electrical test methods for low voltage energy cables	NEN-EN 50395	
		Non electrical test methods for low voltage energy cables	NEN-EN 50396	



[Handwritten signature]


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
1b	Conduits	Type test of conduits according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	NEN/EN/IEC 61386 DEKRA K24 EN 50086	
1c	Installation systems Cable trays Cable ladders	Type test of cable trays and cable ladders, according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	KEMA 55 NEN/EN 50085 NEN/IEC/EN 61537 BS EN 61537	
1d	Boxes and enclosures for electrical installations	Type test of boxes and enclosures for electrical installations, according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	NEN/EN/IEC 60670	
2a	Switches for appliances and automatic controls for electrical household appliances (CONT)	Type test of switches according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests. 	IEC/EN 60730*, 61095* IEC/EN 60691, 60934, 61058*, 60529 IEC 60265, 62271-1, 62271-100, 62271-101, 62271-102, 62271-105, 62271-110, 62271-200, 62271-201, 62271-202, 62271-203, EN 50152-1 IEEE Std C37.09, C37.081, 37.60, C37.013, C37.34, ANSI C37.41, C37.73, C37.20.2, C37.122 ANSI/IEEE C37.21 ANSI C37.54, C37.55, C37.20.2, C37.72	* see note 3



[Handwritten signature]


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
3	Household and similar equipment (HOUS)	Type test of household equipment according to the tests in the standard, among others:	IEC/EN 60335* IEC/EN 61770 IEC/EN 62233 EN 50366 IEC/EN 60204 IEC/EN 60730-1/ 2-8 / 2-9 IEC/EN 61558-1/ 2-3 / 2-6 / 2-5 / 2-6 / 2-16 IEC/EN 62061 EN/ISO 13849-1	* see note 3
		- electrical safety tests - mechanical tests - environmental tests		
		Low power measurements	IEC/EN 62301	
4	Installation accessories and connection devices (INST)	Type test of installation accessories and connection devices according to the tests in the standard, among others:	IEC/EN 60309*, 60320*, 60669*, 60670*, 60799*, 60884*, 60998*, 61058*, 61242*, 61534*, 61984*, 62208*; IEC/EN 60335-2-76, 60974, 61316, 61386, 62094 EN 50075, 50066, 50146, 50250, 50393 NEN 1251, IEC 60884*, 61238, 62080 BS 1363-1, BS 1363-2, BS 1363-3, BS 1363-4 SS 145 BS 546 BS 4573 BS 5733 NEN 1020 NF C61-314 DIN VDE 0620-1 DIN VDE 0620-2-1 CEI 23-50 NBN C 61-112-1 NEK IEC 60884-1 NEK 502 ÖVE/ÖNORM E 8684-1 ÖVE/ÖNORM E 8620-2(-3,-4, -5) SFS 5610 SS 428 08 34 DS 60884-2-D1 SEV 1011 UNE 20315-1-1; UNE 20315-1-2 IEC/EN 61535 EN 50428 required with 60669*	* see note 3



[Handwritten signature]

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
5	Luminaire (LITE)	Type test of luminaire according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 60155*, 60238*, 60400*, 60570*, 60598*, 60838*, 60921*, 60968*, 60969*, 61347*, 62471* IEC/EN 60929, 61184, 62031, 62035, 60923, 60925, 60927, 61047, 62384, 62560, 61195, 62493	* see note 3
6	Measurement, control and laboratory equipment (MEAS)	Type test of measurement-, control- and laboratory equipment according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 61010* IEC/EN 60044 IEC/EN 61243 IEEE Std C57.13	* see note 3
7	Electrical equipment for medical use (MED)	Type test of electrical equipment for medical use according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 60601* IEC/EN/ISO 80601 HD 395	* see note 3
8	Miscellaneous equipment (MISC)	Type test of miscellaneous equipment according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 60825*	* see note 3



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
9	IT and office equipment (OFF)	Type test of IT and office equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60950* IEC/EN 62040* IEC/EN 60825 IEC 62368 EN 41003	* see note 3
10	Low voltage, high power switching equipment (POW)	Type test of low voltage, high power switching equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60439*, 61439, IEC/EN 60947* IEC/EN 60282, 62208 EN 50178, IEC 60470, 60549, 60644, EN 60282-1 IEEE Std C37.41, C37.60 ANSI C37.44 IEC 61921	* see note 3
11	Installation protective equipment (PROT)	Type test of installation protective equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60127*, 60269*, 60529*, 60898*, 61008*, 61009*, 61643*, 60755, 62019 IEC 60099, 60137, 60168, 60383, 60507, 60660, 61109, 60815 HD 630, 639, 60269 IEEE Std 62.11 ANSI C29 CAN/CSA C411.1	* see note 3
12	Safety transformers and similar equipment (SAFE)	Type test of safety transformers and similar equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60044*, IEC/EN 61558* IEC/EN 62040, IEC/EN 60076, IEC/EN 60353 EN 50091, EN 50464-1 HD 538.1 IEEE Std. C57.12.90, C57.21 NEMA 107 CISPR 16	* see note 3



[Handwritten signature]

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**


This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
13	Electric tools (TOOL)	Type test of electric tools according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60745* IEC/EN 61029* IEC/EN 60335* (Gardening) IEC/EN 62233, IEC/EN 60204 EN 50144 EN 50260-2-7 EN 792 EN/ISO 1114 IEC/EN 62061 EN/ISO 13849-1	* see note 3
14	Electronics, entertainment equipment (TRON)	Type test according to the tests as mentioned in the standard, except the following tests which are subcontracted: 60065, cl. 20.1.3 Pre-conditioning of printed circuit boards 60065, cl. 12.1.2 Vibration-sine	IEC / EN 60065* IEC / EN 60491 IEC 62368	* see note 3
15	Products within the scope of the EMC Directive 2004/108/EC (EMC)	Type test according to the tests as mentioned in the standard	CISPR11; CISPR12; CISPR13; CISPR14-*; CISPR15; CISPR16-*-*; CISPR20; CISPR22; CISPR24; CISPR25; IEC60601-*-*; IEC60945; IEC60947-*-*; IEC61000-*-*; IEC61008-1; IEC61009-1; IEC61131-2; IEC61204-3; IEC61326-*; IEC61543; IEC61547; IEC61800-*; IEC62040-2; IEC62052-*; IEC62053-*; IEC62054-*;	* see note 3

B. Electromagnetic Compatibility (EMC): Automotive tests

1	Vehicles, Motorcycles, Motorboats and Spark-ignited engine-driven devices	Radiated emission 30 to 1000 MHz OATS	European Directives 2004/104/EC, 97/24/EC European regulation ECE-R10.04 EN 55012, CISPR 12	
2	Vehicles, Motorcycles, Motorboats and Spark-ignited engine-driven devices	Radiated immunity up to 30 V/m 20 to 2000 MHz OATS	European Directive 2004/104, 97/24/EC European regulation ECE-R10.04	



[Handwritten signature]

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
3	Electrical/ electronic sub-assembly	Pulse emission for ESA's along supply lines 12V and 24V	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 7637-1 ISO 7637-2	
4		Conducted emission for ESA's (V-method, LISN) 150 kHz to 108 MHz	European Directive 2004/104/EC European regulation ECE-R10.04 CISPR25	
5		Radiated emission for ESA's Anechoic Chamber method 30 to 1000 MHz	European Directive 2004/104/EC European regulation ECE-R10.04 CISPR25	
6		Radiated immunity for ESA's Anechoic Chamber method and GTEM method 20 to 2000 MHz up to 30V/m	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 11452-1, ISO 11452-2, ISO 11452-3	
7	Electrical/ electronic sub-assembly	Bulk Current Injection for ESA's 20 to 400 MHz up to 100 mA	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 11452-1, ISO 11452-4	
8		Pulse immunity for ESA's along supply lines 12V and 24V	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 7637-1 ISO 7637-2	

C. Electromagnetic Compatibility (EMC): EMF tests

1	Electrical and electronic equipment	EMF measurements: 0-400 kHz	EN 62233 EN 62493	
---	--	--------------------------------	--------------------------	--



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
-----	---------------------	------------------	------------------	---------

D. Electromagnetic Compatibility (EMC): Emission tests


1	Electrical and electronic equipment	Conducted emission 9 kHz to 30 MHz	EN 55011, CISPR 11 EN 55013, CISPR 13 EN 55014-1, CISPR 14-1 EN 55015, CISPR 15 EN 55022, CISPR 22	
2		Radiated Emission Electric (EM) Field 30 MHz to 18 GHz	EN 55011, CISPR 11 EN 55014-1, CISPR 14-1 EN 55022, CISPR 22	
3		Disturbance power 30 MHz to 300 MHz	EN 55014-1, CISPR 14-1	
4		Click disturbances 150 kHz to 30 MHz	EN 55011, CISPR 11 EN 55014-1, CISPR 14-1	
5		Radiated Emission Magnetic Field 9 kHz to 30 MHz	EN 55011, CISPR 11 EN 55015, CISPR 15	
6		Harmonic current emissions 0 Hz to 2 kHz up to 16 A per phase	IEC / EN 61000-3-2	
7		Pulse magnetic field immunity up to 1000 A/m	IEC/EN 61000-4-9	
8		Limitation of voltage fluctuations and flicker up to 16 A per phase	IEC / EN 61000-3-3	

E. Electromagnetic Compatibility (EMC): FCC tests (USA legislation)

1	Radio-Frequency Devices Industrial, Scientific and Medical Equipment	Emission 9 kHz to 3 GHz	47 CFR FCC Part 15, Part 18 ANSI C63.4 FCC MP-5	
---	---	----------------------------	---	--

F. Electromagnetic Compatibility (EMC): Immunity test

1	Electric and electronic equipment	Electrostatic discharge immunity up to 30 kV	IEC/EN 61000-4-2	
2		Radiated EM field immunity up to 2,5 GHz up to 30 V/m	IEC/EN 61000-4-3	
3		EFT Burst immunity up to 4 kV	IEC/EN 61000-4-4	



[Handwritten signature]

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
4	Electric and electronic equipment	Surge immunity up to 10 kV	IEC/EN 61000-4-5	
5		Immunity to conducted RF disturbances up to 230 MHz, up to 30 Vrms	IEC/EN 61000-4-6	
6		Power frequency magnetic field immunity up to 100 A/m	IEC/EN 61000-4-8	
7		Voltage dips and interruptions Single phase equipment up to 16 A	IEC/EN 61000-4-11	
8		Ring wave immunity test	IEC/EN 61000-4-12	


G. Electromagnetic Compatibility (EMC): MISC

1	Railway applications - Electromagnetic compatibility	Electromagnetic compatibility testing according the listed product standards	EN 50121-1 to -5	
2	Road traffic signal systems	Electromagnetic compatibility testing according the listed product standard	EN 50293	

H. Photometric Tests

(all tests are in accordance with the reference method)

1	Headlamps low and high beams and front fog lamps	All tests as mentioned in the ECE Regulations stated under Test method Photometry Colorimetry Heat tests Plastic tests	ECE Regulations Nos. 1, 5, 8, 19, 20, 31, 56, 57, 72, 76, 82, 98, 112, 113 and 123; European Directives 76/761, 76/762 and 97/24	Note 1
2	Signalling lamps	All tests as mentioned in the ECE Regulations stated under Test method Photometry Colorimetry Heat test	ECE Regulations Nos. 6, 7, 23, 38, 50, 77, 87 and 91 and European Directives 76/757, 76/759, 76/758, 77/538, 77/539, 77/540 and 97/24 ECE Regulation 38 (rear fog lamps only)	
3	Devices for the illumination of rear registration plates	All tests as mentioned in the ECE Regulations stated under Test method Luminance	ECE Regulations Nos. 4 and 50 European Directives 76/760 and 97/24	



Handwritten signature

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
4	Retro-reflective devices	All tests as mentioned in the ECE Regulations stated under Test method Retro-reflection Colorimetry Water resistance test Corrosion Fuel and oil resistance Heat test UV resistance	ECE Regulations Nos. 3, 27, 69, 70, 88 and 104 European Directive 76/757	Note 2
5	Light Sources	All tests as mentioned in the ECE Regulations stated under Test method Geometry Photometry Colorimetry Optical quality Mechanical tests	ECE Regulations Nos. 37, 99 IEC 60809 IEC 60810 IEC 60983 IEC 60061	
6	Special warning lamps (beacons and flash lights)	All tests as mentioned in the ECE Regulations stated under Test method Photometry Colorimetry Water resistance test	ECE Regulation No. 65	
7	Cornering Lamps	All tests as mentioned in the ECE Regulation stated under Test method Photometry Colorimetry	ECE Regulation No.119	



[Handwritten signature]

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
I. Lighting testing: EPA ENERGY STAR Program				
1	Non-directional Fluorescent Luminaires	Specifications for Performance of Self-Ballasted Compact Fluorescent Lamps, Source Run-up Time (ms)	ANSI C78.5:2003	
		Method of Measurement of Fluorescent Lamp Ballasts, Power Factor, Operating Frequency	ANSI C82.2:2002	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electric and Photometric Measurements of Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-9:2009	
		Life Testing of Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-40:2010	
		Life Testing of Compact Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-65:2010	
		Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-66:2011	



[Handwritten signature]


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
2	Directional Fluorescent Luminaires	Specifications for Performance of Self-Ballasted Compact Fluorescent Lamps, Source Run-up Time (ms)	ANSI C78.5:2003	
		Method of Measurement of Fluorescent Lamp Ballasts, Power Factor, Operating Frequency	ANSI C82.2:2002	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No, 15:2004	
		Electric and Photometric Measurements of Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-9:2009	
		Life Testing of Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-40:2010	
		Life Testing of Compact Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-65:2010	
		Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-66:2011	
		Photometric Testing of Outdoor Fluorescent Luminaires, Efficacy, Light Output, Zonal Lumen Distribution	IES LM-10:2013	
	Approved Method for Photometric Testing of Indoor Fluorescent Luminaries, Efficacy, Light Output, Zonal Lumen Distribution	IES LM-41:2013		
3	Luminaires CSD - Fluorescent Ballasts	Method of Measurement of Fluorescent Lamp Ballasts, Power Factor, Operating Frequency	ANSI C82.2:2002	



[Handwritten signature]


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
4	Luminaire CSD - Fluorescent Lamps	Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electric and Photometric Measurements of Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-9:2009	
		Life Testing of Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-40:2010	
		Life Testing of Compact Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-65:2010	
		Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-66:2011	
5	Non-Directional HID Luminaires	High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		Ballasts for High Intensity Discharge (HID) Lamps - Methods of Measurement, Power Factor, Lamp Current Crest Factor	ANSI C82.6:2005	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Life Testing of High Intensity Discharge (HID) Lamps, Light Source Life, Lumen Maintenance	IES LM-47:2012	
		Electrical and Photometric Measurements of High Intensity Discharge Lamps, Efficacy, Light Output, CCT, CRI	IES LM-51:2013	




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
6	Directional HID Luminaires	High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		Ballasts for High Intensity Discharge (HID) Lamps - Methods of Measurement, Power Factor, Lamp Current Crest Factor	ANSI C82.6:2005	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Life Testing of High Intensity Discharge (HID) Lamps, Light Source Life, Lumen Maintenance	IES LM-47:2012	
		Electrical and Photometric Measurements of High Intensity Discharge Lamps, Efficacy, Light Output, CCT, CRI	IES LM-51:2013	
		Photometric Testing of Roadway Luminaires Using Incandescent Filament and High Intensity Discharge (HID) Lamps, Efficacy, Output, Zonal Lumen Distribution	IES LM-31:2013	
		Photometric Testing of Indoor Luminaires Using High Intensity Discharge or Incandescent Filament Lamps, Efficacy, Light Output, Zonal Lumen Distribution	IES LM-46:2004	
7	Luminaires CSD - HID Ballasts	High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		Ballasts for High Intensity Discharge (HID) Lamps - Methods of Measurement, Power Factor, Lamp Current Crest Factor	ANSI C82.6:2005	



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
8	Luminaires CSD - HID Lamps	Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Life Testing of High Intensity Discharge (HID) Lamps, Light Source Life, Lumen Maintenance	IES LM-47:2012	
		Electrical and Photometric Measurements of High Intensity Discharge Lamps, Efficacy, Light Output, CCT, CRI	IES LM-51:2013	
9	Non-directional Solid State Luminaires and Subcomponents	Electrical and Photometric Measurements of Solid-State Lighting Products (section 10 not required for non-directional or subcomponents), Efficacy, Output, Lumen Maintenance, CCT, CRI, Color Maintenance	IES LM-79:2008	
		Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, Power Factor	ANSI C82.77:2002	
		Method of Measuring and Specifying Color Rendering of Light Sources, CRI	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Characterization of LED Light Engines and LED Lamps for Electrical and Photometric Properties as a Function of Temperature, Efficacy, Light Output, Lumen Maintenance, CCT, CRI, Color Maintenance, Light Source Life	IES LM-82:2012	
10	Directional Solid State Luminaires	Electrical and Photometric Measurements of Solid-State Lighting Products (Goniophotometer), Zonal Lumen Distribution, Color Angular Uniformity, Luminaire Photometry	IES LM-79:2008 sections 10 and 12	
		Guide to Spectroradiometric Measurements, Color Angular Uniformity	IES LM-58:2013	



Handwritten signature


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
10	Directional Solid State Luminaires	Method of Measuring and Specifying Color Rendering of Light Sources, CRI	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electrical and Photometric Measurements of Solid-State Lighting Products, Efficacy, Light Output, Lumen Maintenance, CCT, CRI, Color Maintenance	IES LM-79:2008	
11	Lumen Maintenance of LED Packages, Arrays, and Modules	Method for Measuring Lumen Maintenance of LED Light Sources, Light Source Life, Lumen Maintenance	IES LM-80:2008	
12	Non-Directional Outdoor Halogen Luminaires	Approved Method for Life Testing of Filament Lamps, Light Source Life Requirements	IES LM-49:2001, IES LM-49:2011	
13	Directional Outdoor Halogen Luminaires	Approved Method for Life Testing of Filament Lamps, Light Source Life Requirements	IES LM-49:2001	
		Photometric Testing of Outdoor Fluorescent Luminaires, Zonal Lumen Distribution	IES LM-10:1996	
		Photometric Testing of Roadway Luminaires Using Incandescent Filament and High Intensity Discharge (HID) Lamps, Zonal Lumen Distribution	IES LM-31:1991	
		Photometric Testing of Indoor Fluorescent Luminaires, Zonal Lumen Distribution	IES LM-41:1998	
		Photometric Testing of Indoor Luminaires Using High Intensity Discharge or Incandescent Filament Lamps, Zonal Lumen Distribution	IES LM-46:2004	
		Electrical and Photometric Measurements of Solid-State Lighting Products, Zonal Lumen Distribution	IES LM-79:2008 Section 10	




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
14	CFL Directional Lamps	Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Center beam Intensity, Lumen Maintenance, Lifetime, CCT, CRI	IES LM-66:2011	
		Life Testing of Compact Fluorescent Lamps, Lumen Maintenance, Lifetime, Rapid Cycle Stress Test	IES LM-65:2010	
		IEEE Recommended Practice on Characterization of surges in Low Voltage (1000V and Less) AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Fluorescent Lamp Ballasts, Method of Measurement of Power Factor (included supplements)	ANSI C82.2:2002	
		Specifications for the Chromaticity of Fluorescent lamps, CCT	ANSI C78.376-2001	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Tool for Calculating Minimum Center beam Intensity, Minimum Center Beam Intensity – PAR and MR Lamps	Energy Star Online CBCP Tool	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, ETLOR	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Light Output Ratio	
ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time			



Handwritten signature


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015 to 01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
14	CFL Directional Lamps	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	
15	CFL Omnidirectional and Decorative Lamps	Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Center beam Intensity, Lumen Maintenance, Lifetime, CCT, CRI	IES LM-66:2011	
		Life Testing of Compact Fluorescent Lamps, Lumen Maintenance, Lifetime, Rapid Cycle Stress Test	IES LM-65:2010	
		IEEE Recommended Practice on Characterization of surges in Low Voltage AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Specifications for the Chromaticity of Fluorescent lamps, CCT	ANSI C78.376-2001	
		Method of Measurement of Fluorescent Lamp Ballasts, Power Factor	ANSI C82.2:2002	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	
ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time			




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
16	LED Directional Lamps	Electrical and Photometric Measurements of Solid-State Lighting Products, Efficacy, Output, Center Beam Intensity, Luminous Intensity Distribution, Lumen Maintenance, Lifetime, CCT, CRI, Color Maintenance, Color Angular Uniformity	IES LM-79:2008	
		Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, Power Factor	ANSI C82.77:2002 Sections 6 and 7	
		IEEE Recommended Practice on Characterization of surges in Low Voltage AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Chromaticity of Solid State Lighting Products, CCT	ANSI C78.377-2011	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Tool for Calculating Minimum Center beam Intensity, Minimum Center Beam Intensity – PAR and MR Lamps	Energy Star Online CBCP Tool	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, ETLOR	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Light Output Ratio	



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
16	LED Directional Lamps	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	
17	LED Omnidirectional and Decorative Lamps	Electrical and Photometric Measurements of Solid-State Lighting Products, Efficacy, Output, Center Beam Intensity, Luminous Intensity Distribution, Lumen Maintenance, Lifetime, CCT, CRI, Color Maintenance, Color Angular Uniformity	IES LM-79:2008	
		Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, Power Factor	ANSI C82.77:2002 Sections 6 and 7	
		IEEE Recommended Practice on Characterization of surges in Low Voltage AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	



[Handwritten signature]


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
I. Additional Standards related to Energy Star				
1	Reflector type lamps	Photometric Testing	IES LM-35:2002	
2	Floodlights Using Incandescent Filament of Discharge Lamps	Electrical and photometric measurements	IES LM-45:2009	
3	Fluorescent Lamps	Electrical measurements	ANSI C78.375:1997 ANSI C78.375:2014	
4	Fluorescent Lamps	Chromaticity of Fluorescent Lamps	ANSI C78.376-2001	
5	Fluorescent Lamps	Chromaticity of Solid State Lighting Products	ANSI C78.377-2011	
6	Mercury Lamps	Measuring Characteristics	ANSI C78.386:1989	
7	Metal-Halide Lamps	Measuring Characteristics	ANSI C78.387:1987	
8	High Pressure Sodium Lamps	Measuring Characteristics	ANSI C78.388:1990	
9	High-Frequency Fluorescent Lamp Ballast	Measurement of a High-Frequency Fluorescent Lamp Ballast	ANSI C82.11-2002	
10	Light sources	The measurement of luminous flux	CIE 84:1989	
11	Luminaires	The Photometry and goniophotometry of luminaires	CIE121:1996	
12	All LED Products	Measurements of LEDs	CIE127:1997 CIE127:2007	
13	All products	Transient protection	ANSI/IEEE C62.41.1 ANSI/IEEE C62.41.2	
14	Decorative Light Strings	Weathering Test	ASTM G154-06 ASTM G154-12a	
15	Decorative Light Strings	ENERGY STAR Test Method for Decorative Light Strings	ENERGY STAR Test Method for Decorative Light Strings	
16	All products	ENERGY STAR Program requirements Product Specification for Lamps Version 1.0: Final Test Methods and Recommended Practices	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Final Test Methods and Recommended Practices	



Handwritten signature

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

Note 1: Weather-beaten tests of synthetic lenses is subcontracted

Note 2: Salt-nebula test is subcontracted

Note 3: See current list of sub set of standards on the IECEE CBTL website



[Handwritten signature]

ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № РРД 15-042

“Вертикален разединител НН 1000 А, с триполюсно управление”

Приложение № 5



EG-Konformitätserklärung EC Conformity Declaration

Dok.-Nr. L_98_01
Doc. No.

Hersteller, Anschrift Manufacturer, Address	Jean Müller GmbH Elektrotechnische Fabrik H.J.-Müller-Straße 7, D-65343 Eltville am Rhein
Produktbezeichnung Product designation	NH-Sicherungslastschaltleisten Baureihe SL, für Schalttafeleinbau und Schalttafelbau inklusive Zubehör. LV HRC Strip type fuse switch disconnectors, series SL and accessories, for panel board building. DIN-Size 00 (160A): SL00-3x3/100; SL00-3x(3); SL00-3x/400A DIN-Size 1 to 3 (250A/400A/630A): SL123-3x(3) DIN-Size 3: SL3-3x(3)/1000A (NH-Trennleiste) (LV HRC Busbar disconnect strip 1-and 3 pole switchable) DIN-Size 3: SL3-3x2/1.250A or 1.600A DIN-Size 3: SL3-3x(3)/910A DIN-Size 3: SL3-3x6/2.000A DIN-Size 3: SLT3-3SRSL/3x(3)/50 (NH-Stromschienen-Trennleiste) (busbar disconnect strip)

Jahr der Anbringung der CE-Kennzeichnung : 1998
Affixing of the CE marking

Das bezeichnete Produkt stimmt mit den Vorschriften folgender EG-Richtlinie/n überein:
The designated product conforms to the provisions of the following European directives

2006/95/EG

Richtlinie des Rates vom 12. Dezember 2006 zur Angleichung der Rechtsvorschriften der Mitgliedsstaaten betreffend elektrische Betriebsmittel zur Verwendung innerhalb bestimmter Spannungsgrenzen.

Directive of the European Parliament and of the council of 12. December 2006 on the harmonisation of the laws of Member States relating to electrical equipment designed for use within certain voltage limits.

Die Übereinstimmung des bezeichneten Produktes mit den Vorschriften der oben genannten Richtlinie/n wird nachgewiesen durch die Einhaltung folgender Normen:

The conformity of the designated product with the provisions of the above mentioned Directives is proved by full compliance with the following standards


Europäische Normen Harmonized European standards	EN 60947-3
IEC-Standards IEC standards	
Nationale Normen National standards	VDE 0660 Teil 107

Aussteller / Issuer	G / QM
Ort, Datum / Place, Date	Eltville, den 16. Jan. 2008

Rechtsverb. Unterschriften
Legally binding signature




Dr. B. Müller



I.V. A. Göttert

*Diese Erklärung bescheinigt die Übereinstimmung mit den genannten Richtlinien, beinhaltet jedoch keine Zusicherung von Eigenschaften. Mitgelieferte Sicherheitshinweise sind zu beachten.
This declaration certifies compliance with the indicated directives but implies no warranty of properties. The safety instructions of the accompanying product documentation shall be observed.*






KABEL KABEL

WV IsoMatic
ELECTRICAL DISTRIBUTION & CONTROL

ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният Владимир Лазаров,

Управител на фирма "ВиВ Изоматик" ООД, София, ул.Пирин 40А

В качеството си на търговски представители на JEAN MULLER GMBH

Декларираме, че продуктът:

Марка:	JEAN MULLER
Продукт:	Разединител 1000А
Серия:	SLT3-3S

За който се отнася тази декларация, при условие, че е инсталиран, обслужван и използван за приложения, за които е предназначен, в съответствие със следните стандарти, технически одобрения или други нормативни актове:

IEC/EN 60947-1
IEC/EN 60947-3.

София, 14.08.2012

Владимир Лазаров, управител
ВиВ Изоматик ООД



ДОКУМЕНТАЦИЯ

**за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки**


с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Вертикален разединител НН 1000 А, с триполюсно управление”

Приложение № 6



ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният /-ната/ инж. Георги Димитров Георгиев
в качеството ми на Управител на "ЕЛЕКТРОГЕЦ" ООД
със седалище и адрес на управление: гр. София, ул. Майор Горталов 9А, вписано в Търговския
регистър към Агенцията по вписванията с ЕИК 130 761 934, за участие в процедура за
възлагане на обществена поръчка за Доставка и монтаж на Бетонови комплектни
трансформаторни постове /БКТП/, РЕФ. № PPD 15-042,

ДЕКЛАРИРАМ,

че предлагания материал Вертикален разединител НН 1000 А, с триполюсно управление Jean
Muller тип SLT3-3SR/3X3/1000, съответства с изискванията на техническата спецификация на
стандарт за материал Вертикален разединител НН 1000 А, с триполюсно управление, вкл. на
параграфи „Характеристика на материала“ и „Съответствие на предложеното изпълнение с
нормативно-техническите документи“ от документацията по търг с реф. № РЕФ. № PPD 15-042.

Дата 20.01.2016 г.

Декларатор:

инж. Георги Димитров Георгиев

/име, подпис и печат/



Handwritten signature of Georgi Dimitrov Georgiev

Наименование на материала: Токови измервателни трансформатори НН Х/5 А, проходен тип

Съкратено наименование на материала: ТИТ НН Х/5 А, проходни

Област: Н - Трансформаторни постове

Категория: 27 – Измервателни

У - Уредби за търговско измерване

трансформатори

Мерна единица: Брой

Аварийни запаси: Да

Характеристика на материала:

Сухи неразглобяеми токови измервателни трансформатори НН от проходен тип, в пластмасов корпус, за монтиране на закрито, с клас на точност 0,5 и обявен вторичен ток $I_{sn} = 5$ А. Токовете трансформатори са преминали през първоначална метрологична проверка и са маркирани със съответния знак, по реда и при условията на Закона за измерванията.

Използване:

Сухите токови измервателни трансформатори НН от проходен тип са предназначени за трансформиране на тока в първичните вериги във вторичен ток за захранване на токовете вериги на електромерите за търговско измерване на използваните от потребителите количества електрическа енергия и на контролно-измервателните апарати.

Съответствие на предложеното изпълнение със стандартизационните документи:

Токовете измервателни трансформатори трябва да отговарят на БДС EN 60044-1:2001 „Измервателни трансформатори. Част 1: Токови трансформатори (IEC 60044-1:1996, с промени)“ и на неговите валидни изменения и допълнения или еквиваленти.

Изисквания към документацията и изпитванията:

№ по ред	Документ	Приложение № (или текст)
1.	Точно обозначение на типа на токовете измервателни трансформатори (ТИТ), производителя и страна на произход и последно издание на каталога на производителя	СТ-4 1200/5А, Елпром ЕМЗ ООД, България, Приложение 1
2.	Удостоверение за одобряване на типа на ТИТ, издадено по реда и при условията на Закона за измерванията	Приложение 2



[Handwritten signature]

[Handwritten signature]

№ по ред	Документ	Приложение № (или текст)
3.	Техническо описание на ТИТ, гарантирани параметри и характеристики, включително клас на изолацията, тегло и др.	Приложение 3
4.	Протоколи от типови изпитвания на ТИТ на английски или български език, проведени от независима изпитвателна лаборатория с приложени резултати от изпитванията	Приложение 4
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4.	Типовите изпитвания на ТТ НН са проведени в Български Институт по Метрология
6.	Информация за провежданите от производителя контролни (рутинни) изпитвания	Приложение 5
7.	Чертежи с размери	Приложение 6




Технически данни

1. Параметри на електрическата разпределителна мрежа

№ по ред	Параметър	Стойност
1.1	Обявено напрежение	400/230 V
1.2	Максимално работно напрежение	440/253 V
1.3	Обявена честота	50 Hz
1.4	Електроразпределителна мрежа	4 - проводникова (L1, L2, L3, PEN)
1.5	Схема на разпределителната мрежа	TN-C
1.6	Ток на късо съединение	15 kA

2. Характеристики на работната среда и място на монтиране


№ по ред	Характеристика /място на монтиране	Стойност/описание
2.1	Максимална околна температура	

2.2	Минимална околна температура	Минус 5°C
2.3	Относителна влажност	До 95 %
2.4	Замърсяване с прах, пушек, агресивни газове и пари	Умерено
2.5	Надморска височина	До 1000 m
2.6	Място на монтиране	В комплектни комутационни устройства (ККУ) - главни трансформаторни и главни разпределителни табла, електромерни табла и др.

3. Конструктивни характеристики и др. данни.


№ по ред	Характеристика	Изискване	Гарантирано предложение
3.1	Конструкция	а) ТИТ трябва да бъде от проходен тип с отвор за преминаване на тоководещата част на първичната верига - правоъгълни шини или изолирани проводници	а) ТИТ е от проходен тип с отвор за преминаване на тоководещата част на първичната верига - правоъгълни шини или изолирани проводници
		б) Корпусът на ТИТ трябва да бъде: неразглобяем, изграден от синтетична твърда изолация; или разглобяем, надеждно осигурен против разглобяване в процеса на експлоатация и защитен с два противоположно разположени холограмни, саморазрушаващи се при разлепване стикери, съдържащи фабричния номер на трансформатора. (Да се посочи)	б) Корпусът на ТИТ е: -разглобяем, надеждно осигурен против разглобяване в процеса на експлоатация защитен с два противоположно разположени холограмни. саморазрушаващи се при разлепване стикери, съдържащи фабричния номер на ТТ и името на фирмата производител
3.2	Вторични намотки - брой и предназначение	Една вторична намотка за целите на измерването	Една вторична намотка за целите на измерването
3.3	Монтиране	а) ТИТ трябва да позволяват монтиране в произволно	а) ТИТ позволяват монтиране в



№ по ред	Характеристика	Изискване	Гарантирано предложение
		положение.	произволно положение.
		б) ТИТ трябва да бъдат снабдени с приспособление за механично закрепване към тоководещата част на първичната верига.	б) ТИТ са снабдени с приспособление за механично закрепване към тоководещата част на първичната верига.
		в) ТИТ трябва да бъдат снабдени с приспособления за закрепване към монтажна плоча посредством винтови съединения.	в) ТИТ са снабдени с приспособления за закрепване към монтажна плоча посредством винтови съединения.
		г) Приспособленията за закрепване трябва да бъдат устойчиви на корозия.	г) Приспособленията за закрепване са устойчиви на корозия.
3.4	Клемен блок за свързване на вторичните вериги	а) Клемният блок трябва да бъде от винтов тип с възможност за свързване на многожични проводници на вторичните вериги със сечение до 4 mm ² .	а) Клемният блок те от винтов тип с възможност за свързване на многожични проводници на вторичните вериги със сечение до 4 mm ² .
		б) Всеки извод на клемния блок трябва да бъде с min два винта, гарантиращи ниски стойности на контактното съпротивление.	б) Всеки извод на клемния блок е с два винта, гарантиращи ниски стойности на контактното съпротивление.
		в) Клемният блок трябва да бъде защитен с капак с възможност за пломбиране.	в) Клемният блок е защитен с капак с възможност за пломбиране.
		г) Клемният блок и резбовите съединения трябва да бъдат изработени от подходящи некорозиращи метали или метални сплави.	г) Клемният блок и резбовите съединения са изработени от подходящи некорозиращи метали или метални сплави.
3.5	Маркиране на обявените стойности	а) Токовете измервателни трансформатори трябва да бъдат маркирани с информация за	а) Информацията е лазерно гравирана върху корпуса




№ по ред	Характеристика	Изискване	Гарантирано предложение
		обявените стойности, нанесена върху корпуса или табелка от устойчив на корозия материал или самозалепващо се фолио, съгласно изискванията на т. 11.7 от БДС EN 60044-1 или еквивалент.	
		б) Маркировката трябва да бъде нанесена трайно и четливо по начин, по който да не може да бъде заличена или променена.	б) Информацията е лазерно гравирана върху корпуса
		в) Табелката трябва да бъде фиксирана здраво към корпуса на токовите измервателни трансформатори, без възможност за подмяна или запазване на целостта и при демонтиране.	в) Лазерно гравирана
		г) Табелката от самозалепващо се фолио трябва да бъде: <ul style="list-style-type: none"> • саморазрушаваща се при разлепване; или • защитена с прозрачна капачка с възможност за пломбиране. (Да се посочи)	
		д) Препоръчително е върху изолацията на токовите измервателни трансформатори допълнително да бъде маркиран с вдлъбнат или релефен печат обявения коефициент на трансформация.	д) Коефициента е лазерно гравиран върху пластмасовата кутийка
3.6	Маркиране на изводите	Изводите на ТИТ трябва да бъдат маркирани трайно и четливо съгласно изискванията на т. 10.1 от БДС EN 60044-1 или еквивалент.	Изводите на ТИТ трябва са маркирани трайно и четливо съгласно изискванията на т. 10.1 от БДС EN 60044-1 или еквивалент.
3.7	Първоначална проверка и знаци за удостоверяване (съгласно разпоредбите на	а) Токовите измервателни трансформатори трябва да бъдат доставени след извършване на първоначална метрологична	а) Токовите измервателни трансформатори ще бъдат доставени след



№ по ред	Характеристика	Изискване	Гарантирано предложение
	Закона за измерванията)	проверка.	извършване на първоначална метрологична проверка.
		б) Първоначална метрологична проверка трябва да бъде удостоверена със знак за първоначална проверка и копието на протокола от проведените изпитвания.	б) Първоначалната метрологична проверка е удостоверена с холограмни стикери и протокол от изпитания
3.8	Транспортна опаковка	ТИТ трябва да бъдат опаковани в подходяща опаковка предпазваща ги от атмосферни влияния и механични повреди.	ТИТ са опаковани в подходяща опаковка предпазваща ги от атмосферни влияния и механични повреди.
3.9	Експлоатационна дълготрайност	min 25 години	25 години


4. Общи технически параметри


№ по ред	Параметър	Изискване	Гарантирано предложение
4.1	Най-високо напрежение за съоръженията - U_m	min 0,72 kV (ефективна стойност)	0,72 kV (ефективна стойност)
4.2	Обявено издържано напрежение с промишлена честота на изолацията	min 3 kV (ефективна стойност)	3kV (ефективна стойност)
4.3	Клас на точност	0,5	0,5
4.4	Обявен продължителен термичен ток	min 1,2 x I_{pn}	1.2 x I_{pn}
4.5	Номинален коефициент на безопасност - FS	5	5

5. Технически параметри на токовете измервателни трансформатори

5.1 Токов измервателен трансформатор НН, проходен тип, 1200/5 А

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 27 1410		Тип СТ-4	
Наименование на материала		Токов измервателен трансформатор НН, проходен тип, 1200/5 А	
Съкратено наименование на материала		ТИТ НН, проходен - 1200/5 А	
№ по ред	Параметър	Изискване	Гарантирано предложение
1.	Обявен първичен ток, I_{pn}	1200 А	1200 А
2.	Обявен първичен ток на термична устойчивост - 1 сек, I_{th}	min 72 kA	72 kA
3.	Обявен първичен ток на динамична устойчивост, I_{dyn}	min 180 kA	180 kA
4.	Обявен вторичен ток, I_{sn}	5 А	5 А
5.	Обявен коефициент на трансформация	1200/5 А	1200/5 А
6.	Обявен вторичен товар	min 5 VA	5VA
7.	Габаритни размери 	H = max 142 mm W = max 124 mm	H= 134mm W = 122mm
8.	Светъл отвор за тоководещата част на първичната верига за: правоъгълно сечение / кръгло сечение	min 60,5x10,5 mm / 2x50,5x10,5 mm / $\phi 44$	81x11/ $\phi 73$
9.	Тегло, kg	Да се посочи	0.920 kg



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:


„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Токови измервателни трансформатори НН X/5 А, проходен тип”

Приложение № 1





" ЕЛПРОМ ЕМЗ " ООД ГРАД ШАБЛА

ГАМА ТОКОВИ ИЗМЕРВАТЕЛНИ ТРАНСФОРМАТОРИ НН ТИП СТ-1; СТ-2; СТ-3 И СТ-4

ТЕЛЕФОН ЗА КОМПАНИЈА:
 Управител: 05743/46 - 88
 Технички оддел: 05743/42 - 84
 Тех. Служба: 05743/41 - 84
 Факс/телеграфски: 05743/60 - 20
 E-mail: elpromemz@inbox.infotel.bg




таблица 1.

Тип Турб.	Проводно отношение I _{pn} /I _{sn} Rated current ratio A/A	Най-високо работно напряжение Rated voltage power network kV	Клас на точност Class of accuracy %	Номинална мощност S _n Rated power VA	Номинален ток на терм. устойчивост Rated short-time thermal stability I _{th} , kA	Номинален ток на динам. устойчивост Rated short-time dynamic stability I _{dyn} , kA	Номинален коэффициент на безоп. Security factor for apparatus Fs	Заводски шифър Serial number:
1	2	3	4	5	6	7	8	9
СТ-1 първич и вторич	30 / 5	0,72	0,2; 0,5; 0,5S	5; 10	60 I _{pn}	2,5 I _{th}	5; 10	1210302 - XXXX
	50 / 5	0,72	0,2; 0,5; 0,5S	5; 10	60 I _{pn}	2,5 I _{th}	5; 10	1210502 - XXXX
	75 / 5	0,72	0,2; 0,5; 0,5S	5; 10	60 I _{pn}	2,5 I _{th}	5; 10	1210752 - XXXX
	100 / 5	0,72	0,2; 0,5; 0,5S	5; 10	60 I _{pn}	2,5 I _{th}	5; 10	1211002 - XXXX
	150 / 5	0,72	0,2; 0,5; 0,5S	5; 10	60 I _{pn}	2,5 I _{th}	5; 10	1211502 - XXXX
СТ-2 шина 30x10 40x10 кабел φ36	150 / 5	0,72	0,5	5	60 I _{pn}	2,5 I _{th}	5; 10	1221605 - XXXX
	200 / 5	0,72	0,5	5	60 I _{pn}	2,5 I _{th}	5; 10	1222005 - XXXX
	250 / 5	0,72	0,5	5	60 I _{pn}	2,5 I _{th}	5; 10	1222505 - XXXX
	300 / 5	0,72	0,5	5	60 I _{pn}	2,5 I _{th}	5; 10	1223005 - XXXX
СТ-3 шина 30x10 40x10 φ36	300 / 5	0,72	0,2; 0,5; 0,5S	5; 10	60 I _{pn}	2,5 I _{th}	5; 10	1233005 - XXXX
	400 / 5	0,72	0,2; 0,5; 0,5S	5; 10	60 I _{pn}	2,5 I _{th}	5; 10	1234005 - XXXX
	500 / 5	0,72	0,2; 0,5; 0,5S	5; 10	60 I _{pn}	2,5 I _{th}	5; 10	1235005 - XXXX
	600 / 5	0,72	0,2; 0,5; 0,5S	5; 10	60 I _{pn}	2,5 I _{th}	5; 10	1236005 - XXXX
СТ-3 шина 60x10 φ48	500 / 5	0,72	0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	1235005 - XXXX
	600 / 5	0,72	0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	1236005 - XXXX
	750 / 5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	1237505 - XXXX
	800 / 5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	1238005 - XXXX
СТ-4 за шина 80x10 или кабел φ73	300 / 5	0,72	0,5; 0,5S	5	60 I _{pn}	2,5 I _{th}	5; 10	1243005 - XXXX
	400 / 5	0,72	0,5; 0,5S	5	60 I _{pn}	2,5 I _{th}	5; 10	1244005 - XXXX
	500 / 5	0,72	0,5; 0,5S	5	60 I _{pn}	2,5 I _{th}	5; 10	1245005 - XXXX
	600 / 5	0,72	0,5; 0,5S	5	60 I _{pn}	2,5 I _{th}	5; 10	1246005 - XXXX
	750 / 5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	1247505 - XXXX
	800 / 5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	1248005 - XXXX
	1000 / 5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	1241005 - XXXX
	1200 / 5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	1241205 - XXXX
	1250 / 5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	12412505 - XXXX
	1500 / 5	0,72	0,2; 0,5; 0,5S	5; 10; 15	60 I _{pn}	2,5 I _{th}	5; 10	12415005 - XXXX

УПРАВИТЕЛ:
 Иво ДАРНАУДОВ



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Токови измервателни трансформатори НН X/5 А, проходен тип”

Приложение № 2






РЕПУБЛИКА
БЪЛГАРИЯ

ДЪРЖАВНА АГЕНЦИЯ
ЗА МЕТРОЛОГИЯ И
ТЕХНИЧЕСКИ НАДЗОР
STATE AGENCY FOR METROLOGY
AND TECHNICAL SURVEILLANCE

Сертификат № 2



УДОСТОВЕРЕНИЕ
ЗА ОДОБРЕН ТИП СРЕДСТВО ЗА ИЗМЕРВАНЕ
Measuring Instrument Type-approval Certificate

№ 06.04.4547

Издадено на:
Issued to:

"ЕЛПРОМ-ЕМЗ" ООД, 9680 Шабла,
обл. Добричка, ул. "Нефтяник" № 38

На основание на:
In Accordance with:

чл. 32, ал. 1 от Закона за измерванията
(ЗЗ, бр. 46 от 2002 г.)


Относно:
In Respect of:

гама токови измервателни трансформатори, тип СТ-х

Производител:
Manufacturer:

"ЕЛПРОМ-ЕМЗ" ООД, гр. Шабла

Знак за одобрен тип:
Type Approval Mark:



Технически и метрологични
характеристики:
*Technical and metrological
characteristics:*

приложение, неразделна част от настоящото удостоверение
за одобрен тип средство за измерване

Срок на валидност:
Valid until:

03.04.2016 г.


Вписана е в регистъра на
одобренията за използване
типове средства за
измерване под №:
Reference №:

4547


Дата на издаване на
удостоверението за одобрен
тип:
Date:

03.04.2006 г.

ПРЕДСЕДАТЕЛ



страница 1 от 3



Съгласно с измерванията

Приложение към удостоверение за одобрен тип № 06.04.4547

Изработено на: "ЕЛПРОМ-ЕМЗ" ООД, гр. Шабла

Относно: гама токови измервателни трансформатори, тип СТ-х

1. Описание на типа:

Токовите трансформатори тип СТ- х са предназначени за измерване на ток и за защита на разпределителни съоръжения (уредби) във вътрешно извънземяне.

Токовите трансформатори тип СТ- х се състоят от тороидален магнитопровод с първична и вторична намотка, поместени в кутия от пластмаса с клас на възпламеняемост съгласно IEC 707-V-0.

Изолацията спрямо магнитопровода и намотките е суха с клас на топлоустойчивост В.

Трансформаторите тип СТ-х са предназначени за експлоатация при надморска височина до 1000 m за закрит монтаж при температура на въздуха от минус 5° C до + 40° C и относителна влажност на въздуха до 70 % за условия на умерен климат.

1.1. Технически и метрологични характеристики:



Номинален първичен ток, А	СТ-1	30, 50, 75, 100, 150
	СТ-2	200, 250, 300
	СТ-3	400, 500, 600
Номинален вторичен ток, А		5
Клас на точност	СТ-1	0,2; 0,5
	СТ-2	0,5
	СТ-3	0,5
Коефициент на безопасност - Fs		5, 10
Номинална мощност, VA	СТ-1	5, 10
	СТ-2	5, 10
	СТ-3	5, 10, 15
Максимално работно напрежение, kV		0,72

Забележка: * Номиналната мощност 10 VA не се отнася за трансформатори с токово отношение 150/5 А.

1.2. Означаване на типа:


Означението на типа е СТ-х (СТ-1, СТ-2 и СТ-3)

Параметрите като клас на точност, първичен ток, вторичен ток, номинално напрежение и коефициент на сигурност са посочени на табелката на трансформатора.


Създадено от   страница 2 от 2

Приложение към удостоверение за одобрен тип № 06.04.4547


2. Схеми на местата за поставяне на знаците, удостоверяващи резултатите от контрола и места за пломбиране.



- 1 – Знак за първоначална проверка (марка за залепване)
- 2 – Знак за последваща проверка (марка за залепване)
- 3 – Знак за одобрен тип



- 1 – Знак за първоначална проверка (марка за залепване)
- 2 – Знак за последваща проверка (марка за залепване)
- 3 – Знак за одобрен тип



Андрей
Иванов



РЕПУБЛИКА
БЪЛГАРИЯ

БЪЛГАРСКИ ИНСТИТУТ ПО МЕТРОЛОГИЯ

BULGARIAN INSTITUTE OF
METROLOGY

ДОПЪЛНЕНИЕ № 06.07.4547.1

КЪМ УДОСТОВЕРЕНИЕ

ЗА ОДОБРЕН ТИП СРЕДСТВО ЗА ИЗМЕРВАНЕ № 06.04.4547

Measuring Instrument Type-approval Certificate-Revision 1

Издадено на:
Issued to:

"ЕЛПРОМ-ЕМЗ" ООД, 9680 Шабла,
оба. Добричка, ул. "Нефтяник" № 38

На основание на:
In Accordance with:

чл. 32, ал. 1 от Закона за измерванията
(ДВ, бр. 46 от 2002 г.)

Относно:
In Respect of:

токов измервателен трансформатор, тип СТ-х

Производител:
Manufacturer:

"ЕЛПРОМ-ЕМЗ" ООД, гр. Шабла

Технически и метрологични
характеристики:
Technical and metrological
characteristics:

приложение, неразделна част от настоящото удостоверение
за одобрен тип средство за измерване.

Срок на валидност:
Valid until:

03.04.2016 г.

Средството за измерване е
вписано в регистъра на
одобренията за използване
типове средства за
измерване под №:
Reference №:

4547

Дата на издаване на
допълнението към
удостоверението за одобрен
тип:
Date:

17.07.2006 г.



Handwritten signature

Handwritten signature and text: Катеринка, страница 1 от 2

Handwritten text at the bottom: София, ООД

Здравейте

Приложение към Допълнение № 06.07.4547.1 към удостоверение № 06.04.4547

Издадено на: "ЕДПРОМ-ЕМЗ" ООД, гр. Шабла

Относно: токов измервателен трансформатор, тип СТ-х

Описание на допълнението

1. Към т. 1 Описание на типа, се добавя:

Токовите трансформатори с клас на точност 0,5 S са за специални цели. Свързват се с електромери, които измерват стойности на тока между 50 mA и 6 A, което е от 1 % до 120 % от номиналния ток на трансформатора – 5 A.

Токовата и ъгловата грешка при 1 % от номиналния ток не превишават стойностите, посочени в стандарт БДС EN 60044-1:2001.

2. Към т. 1.1 Технически и метрологични характеристики:

2.1 Включва се токов измервателен трансформатор тип СТ-4 със следните метрологични характеристики:

Номинален първичен ток, A	750, 800, 1000, 1200, 1250 и 1500
Номинален вторичен ток, A	5
Клас на точност	0,5 и 0,5 S
Коефициент на безопасност - Es	5, 10
Номинална мощност, VA	5, 10 и 15
Максимално работно напрежение, kV	0,72

2.2 Включва се клас на точност 0,5 S за трансформатори тип СТ-1, тип СТ-2 и тип СТ-3;

2.3 Отпада забележката.



Всичко е одобрено

Димитър Димитров



РЕПУБЛИКА БЪЛГАРИЯ
БЪЛГАРСКИ ИНСТИТУТ ЗА МЕТРОЛОГИЯ
REPUBLIC OF BULGARIA
Bulgarian Institute of Metrology



ДОПЪЛНЕНИЕ № 13.11.4547.2

КЪМ УДОСТОВЕРЕНИЕ ЗА ОДОБРЕН ТИП СРЕДСТВО ЗА ИЗМЕРВАНЕ № 06.04.4547 *Measuring Instrument Type-approval Certificate-Revision 1*

Издадено на
производител:
Issued to manufacturer:

„Елпром ЕМЗ“ ООД, гр. Шабла

На основание на:
In Accordance with:

чл. 32, ал. 1 от Закона за измерванията (ДВ, бр. 46 от 2002 г., изм. бр. 88 от 05 г., изм. и доп. бр. 95 от 2009 г.)

Относно:
In Respect of:

токови измервателни трансформатори тип СТ 3

Технически и
метрологични
характеристики:
*Technical and metrological
characteristics:*

приложение, неразделна част от ваставното удостоверение за одобрен тип средство за измерване

Срок на валидност:
Valid until:

03.04.2016 г.

Средството за измерване е
вписано в регистъра на
одобренията за използване
типове средства за
измерване под №:
Reference №:

4547

Дата на издаване на
допълнението към
удостоверението за
одобрен тип:
Date:

04.11.2013 г.

И.Д. ПРЕДСЕЛАТЕЛ:
Димитра Иванова



страница 1 от 2

Възвръщане в оригинал

Допълнение

Приложение към Допълнение № 13.11.45-47.2 към удостоверение № 06.04.4547

Издадено на производител: „Европ БМЗ“ ООД, гр. Шабла


Относно: токови измервателни трансформатори тип СТ-х

Описание на допълнението към удостоверение за одобрен тип № 06.04.4547

В т. 1.1 „Технически и метрологични характеристики“ към „Номинален първичен ток, А“ в графата за СТ-2 се добавят следните стойности:

Номинален първичен ток, А	СТ-2	100; 150
---------------------------	------	----------

Всичко е вярно



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“


РЕФ. № PPD 15-042

“Токови измервателни трансформатори НН X/5 А, проходен тип”

Приложение № 3



“ЕЛПРОМ ЕМЗ” ООД град ШАБЛА



ТЕЛЕФОНИ ЗА КОНТАКТИ:

Управител 05743/45 - 68
 Гл. счетоводител 05743/42 - 84
 Търг. Отдел 05743/41 - 84
 Факс/тел. секретар 05743/50 - 20
 E-mail : elpromemz@mbx.infotel.bg

ТЕХНИЧЕСКО ОПИСАНИЕ

ГАМА ТОКОВИ ИЗМЕРВАТЕЛНИ ТРАНСФОРМАТОРИ
 тип СТ-1, СТ-2, СТ-3 и СТ-4 за НН до 1000V
 ПРОИЗВОДСТВО НА “ ЕЛПРОМ ЕМЗ ” ООД град ШАБЛА

Токови измервателни трансформатори тип СТ-1; тип СТ-2, тип СТ-3 и тип СТ-4 са за ниско напрежение до 1000V за вътрешен монтаж с клас на точност 0.2; 0.5 или 0.5S и номинална мощност до 50VA в диапазона от номинални токове до 3000A съгласно БДС EN 60044-1:2001 и IEC 60044-1:1999.

■ Тип СТ-1 се състои от тороидален магнитопровод с първична и вторична намотки, поместени в кутийка от пластмаса изработена от пластмаса тип Rosap - B4235 с клас на възпламеняемост съгласно IEC 707 - V-0.

Произвежданите токови трансформатори са в диапазона от 30/5 A до 150/5 A с клас на точност 0.2, 0.5 или 0.5S с мощност 5VA и 10VA.

• Тип СТ-2 Тип, СТ-3 и Тип СТ-4 са проходни типове токови измервателни трансформатори пригодени съответно за шина или кабел - състоят се от тороидален магнитопровод с вторична намотка, поместени в кутийка от пластмаса изработена от пластмаса тип Rosap - B4235 с клас на възпламеняемост съгласно IEC 707 - V-0.

Произвежданите токови трансформатори са в диапазона от 150/5A до 2000/5A с клас на точност 0.5 или 0.5S и мощност 5VA; 10VA и 15VA.



Handwritten signature



ТЕХНИЧЕСКИ ДАННИ Тип СТ-1, Тип СТ-2, Тип СТ-3 и Тип СТ-4

Условия на работа: Токовете измервателни трансформатори за средно напрежение се монтират на закрито при температура на околната среда от -35С до +45С и височина над морското равнище до 1000м.

- | | |
|--|------------------|
| 1. Номинално напрежение | - до 0,75 KV |
| 2. Честота | - 50 Hz |
| 3. Номинален първичен ток I_{pn} | - до 2000 А |
| 4. Номинален вторичен ток I_{sn} | - 5 А |
| 5. Клас на точност на ядрото за мерене | - 0.2, 0.5, 0.5S |
| 6. Номинална мощност | - 5, 10, 15VA |
| 7. Номинален ток на термична устойчивост I_{th} , kA | - 60 I_{pn} |
| 8. Номинален ток на динамична устойчивост I_{dyn} , kA | - 2,5 I_{th} |
| 9. Номинален коефициент на безопасност F_s | - 5 или 10 |
| 10. Маса, в кг в зависимост от преводното отношение от | - 0.485 до 1,070 |
| 11. Изолация - суха, клас на топлоустойчивост | В |

Стандартизирани документи: Изделието отговаря на БДС EN 60044-1:2001 и IEC 60044-1:1999.

При всички произведени от " ЕМПРОМ ЕМЗ " ООД град Шабла токови измервателни трансформатори е предвидена възможност за пломбиране както на кутията на трансформатора с цел предотвратяване на неправилен достъп до магнитопровода и самите намотки, така и на предпазната капачка, която предпазва клемите на вторичната намотка на трансформатора.

УПРАВИТЕЛ :

/ инж. Д. Арнаудов



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Токови измервателни трансформатори НН X/5 А, проходен тип”

Приложение № 4



БЪЛГАРСКИ ИНСТИТУТ ПО МЕТРОЛОГИЯ

Главна дирекция Мерки и измервателни уреди
отдел "Изследване на типа на средства за измерване"
сектор "Електрични величини"
София, бул. Г.М.Димитров 52 Б, тел. :873-52-98

ПРОТОКОЛ ОТ ИЗПИТВАНЕ

№ 19-ЕВ / 13.07.2006 г.

- 1. **Обект на изпитването:** Токов измервателен трансформатор тип СТ-Х
- 2. **Номер и дата на заявката:** АУ-03-654/27.06.2006 г.
- 3. **Заявител:** "ЕЛПРОМ - ЕМЗ" ООД гр. Шабла
- 4. **Производител:** "ЕЛПРОМ - ЕМЗ" ООД гр. Шабла
- 5. **Метод на изпитване:** БДС EN 60044-1 Измервателни трансформатори
Част 1: Токови трансформатори.
- 6. **Период на изпитване:** 07.07.2006 г. до 14.07.2006 г.
- 7. **Изпитани образци:** ф. № 20218, 33063, 29967, 29477, 34805, 32820

8. Описание на типа:

Гамата измервателни токови трансформатори тип СТ-х са за мрежи ниско напрежение.

Токовете трансформатори тип СТ-1 се състоят от тороидален магнитопровод с първична и вторична намотка, а тип СТ-2, тип СТ-3 и тип СТ-4 са проходен тип трансформатори, пригодени за шина или кабел, с вторична намотка.


Резултатите в протокола се отнасят само за изпитваните образци.

Началник отдел ИТСИ:

/инж./Хр. Соколова/



Протокола може да бъде разпечатван единствено и само с разрешение на началник-отдел "Изследване на типа на средствата за измерване"



Вярно с оригинала. /Handwritten signature and text at the bottom of the page.

9. Технически и метрологични характеристики:

Тип на трансформатора	СТ-1	СТ-2	СТ-3	СТ-4
Номинален първичен ток, А	30, 50, 75, 100,150	200, 250, 300	400, 500, 600	1200, 1250, 1500
Номинален вторичен ток, А	5			
Клас на точност	0,5 S			
Максимално работно напрежение, kV	0,72			
Честота, Hz	50			
Номинална мощност, VA	5, 10	5, 10	5, 10, 15	5, 10, 15

10. Технически средства използвани при изпитването:

10.1. Уредба за проверка на токови трансформатори тип АИТ ф. № 45/1972 с еталонен трансформатор тип ТТ 50 ф. № 7210453, свидетелство за калибриране № 037- ЕЕИ/ 16.03.2005 год.

10.2. Уредба за изпитване на диелектрична якост тип РЕО 3/50 ф. № 671897308

10.3. Мегаомметър тип Ф 41/2, ф. № 62862.

11. Резултати от изпитванията:

11.1. Проверка на маркировката

11.1.1. Маркировка на изводите --

БДС EN 60044-1
т. 10.1.1 и 10.1.2

Протоколи № 01÷ 03 /10.07.2006 г.
Протоколи № 04÷ 06 /11.07.2006 г.
Протокол № 12/12.07.2006 г.

11.1.2 Означение на полярностите --

БДС EN 60044-1
т. 10.1.3

Протоколи № 01÷ 03 /10.07.2006 г.
Протоколи № 04÷ 06 /11.07.2006 г.
Протокол № 12/12.07.2006 г.

11.2. Маркировка на табелките с технически данни --

БДС EN 60044-1
т. 10.2 и т. 11.7

Протоколи № 01÷ 03 /10.07.2006 г.
Протоколи № 04÷ 06 /11.07.2006 г.
Протокол № 12/12.07.2006 г.



Съгласно с означенията

11.3. Проверка на диелектричната якост на първичната намотка – /3 kV за 60 s/

БДС EN 60044-1
т. 5.1.4

Протоколи № 01÷ 03 /10.07.2006 г.
Протоколи № 04÷ 06 /11.07.2006 г.
Протокол № 12/12.07.2006 г.

11.4. Проверка на диелектричната якост на вторичната намотка – /3 kV за 60 s/

БДС EN 60044-1
т. 5.1.4

Протоколи № 01÷ 03 /10.07.2006 г.
Протоколи № 04÷ 06 /11.07.2006 г.
Протокол № 12/12.07.2006 г.

11.5. Определяне грешките на трансформаторите –

БДС EN 60044-1
т.11.2

Протоколи № 01÷ 03 /10.07.2006 г.
Протоколи № 04÷ 06 /11.07.2006 г.
Протокол № 12/12.07.2006 г.


11.6. Проверка – коефициент на безопасност -

БДС EN 60044-1
т.11.6


Протоколи № 01÷ 03 /10.07.2006 г.
Протоколи № 04÷ 06 /11.07.2006 г.


Присъствали на изпитването:

Младши експерт:


/инж. Р. Малинова/

Началник сектор "ЕВ":


/инж.Л. Сотирова/



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Токови измервателни трансформатори НН X/5 А, проходен тип”

Приложение № 5



ДОКУМЕНТАЦИЯ

**за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки**

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № РРД 15-042




“Токови измервателни трансформатори НН X/5 А, проходен тип”

Приложение № 6



ПРИСЪЕДИНИТЕЛНИ РАЗМЕРИ ЗА ТОКОВИ ИЗМЕРВАТЕЛНИ ТРАНСФОРМАТОРИ

тип СТ-4, включващи преводните отношения 800/5А, 1000/5А, и 1200/5А



Наименование на материала: Триполюсни и еднополюсни стопяем цилиндричен предпазител-прекъсвач-разединители, размер 10x38 mm

Съкратено наименование на материала: 3P и 1P Цилиндр. П-л П-ч Р-ли, 10x38 mm

Област: Н – Електрически уредби СрН/НН
J - Уредби за търговско измерване

Категория: 16 - Предпазителни, основи за предпазителни

Мерна единица: Брой

Аварийни запаси: Да

Характеристика на материала:

Триполюсните и еднополюсните стопяем цилиндричен предпазител-прекъсвач-разединители са предназначени за цилиндрични патрони размер 10x38 mm и могат да бъдат пломбирани във включено положение. Закрепването на апаратите към разпределителните табла се извършва посредством шина с DIN-профил с размери 35x7,5 mm.

Използване:

Триполюсните и еднополюсните стопяем цилиндричен предпазител-прекъсвач-разединители са предназначени за защита на напрежените вериги на електромерите и други подобни електрически съоръжения в главните разпределителни табла в трансформаторни постове и в електромерните табла за индиректно измерване на електрическата енергия.

Съответствие на предлаганото изпълнение с нормативно-техническите документи:

Триполюсните и еднополюсните стопяем цилиндричен предпазител-прекъсвач-разединители трябва да отговарят най-малко на посочените по-долу стандарти или еквиваленти.

- БДС EN 60947-1:2007 „Комутационни апарати за ниско напрежение. Част 1: Общи правила (IEC 60947-1:2007)“;
- БДС EN 60947-1:2007/A1:2011 „Комутационни апарати за ниско напрежение. Част 1: Общи правила (IEC 60947-1:2007/A1:2010)“; и
- БДС EN 60947-3:2009 „Комутационни апарати за ниско напрежение. Част 3: Товари прекъсвачи, разединители, товаров прекъсвач-разединители и апарати, комбинирани с предпазителни (IEC 60947-3:2008)“

и

да бъдат оценени положително по реда и при условията на Наредбата за съществените изисквания и оценяване на съответствието на електрически съоръжения, предназначени за използване в определени граници на напрежението, приета с ПМС № 182 от 6.07.2001 г., обн., ДВ, бр. 62 от 13.07.2001 г.

Изисквания към документацията и изпитванията:

№ по ред	Документ	Приложение № или текст
1.	Точно означение на типа, производителя и страната на производство (произход) и последно издание на каталога на производителя	FB01 В ..., Lovato, Италия Приложение 1.
2.	Техническо описание и чертежи с нанесени на тях размери	Приложение 2
3.	ЕО декларация за съответствие	Приложение 3
4.	Протоколи от типови изпитвания на английски или български език, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	Приложение 4
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провели типовите изпитвания по т. 4 – заверено копие	Приложение 5



Забележка: Всички оригинални документи трябва да бъдат на български език или с превод на български език. (Каталозите и протоколите от изпитванията могат да бъдат и само на английски език.)

Технически данни

1. Характеристики на работната среда:


№ по ред	Характеристика	Стойност
1.1	Околна среда, в която работи	На закрито
1.2	Максимална околна температура	+ 40°C
1.3	Минимална околна температура	Минус 5°C
1.4	Относителна влажност (при 20 °C)	До 90 %
1.5	Степен на замърсяване	III
1.6	Надморска височина	До 1000 m

2. Параметри на електроразпределителната мрежа НН:

№ по ред	Параметър	Стойност
2.1	Номинално напрежение	400 / 230 V
2.2	Максимално напрежение	440 / 253 V
2.3	Номинална честота	50 Hz
2.4	Брой проводници в разпределителната мрежа	4 проводна мрежа (L ₁ , L ₂ , L ₃ , PEN)
2.5	Вид схема на разпределителната мрежа	TN-C

3. Общи технически параметри

№ по ред	Параметър	Изискване	Гарантирано предложение
3.1	Обявено работно напрежение AC, U _e	min 500 V	690V
3.2	Обявена честота	50 Hz	50Hz
3.3	Обявено напрежение на изолацията U _i AC	min 750 V	750V
3.4	Категория по пренапрежение при 400 V AC	III	III
3.5	Обявено издържано импулсно напрежение, U _{imp}	4 kV	6kV
3.6	Диапазон на температурата на околната среда	min (от минус 5°C до + 40°C)	От минус 5 до +40
3.7	Категория на приложение (при 400V AC)	AC 21 В или по висока	AC21B
3.8	Термичен ток със стопяема вложка, I _{th}	32 A	32A




№ по ред	Параметър	Изискване	Гарантирано предложение
3.9	Условен ток на късо съединение (ефективна стойност) при 400 V AC	min 50 kA	100kA
3.10	Размер на цилиндричната стопяема вложка	10 x 38 mm	10x38mm
3.11	Максимална стойност на обявения ток на стопяемата вложка I _n	32 A	32A
3.12	Максимална мощност на разсейване на стопяемата вложка	3,5 W	3W
3.13	Механична износоустойчивост (комутационни цикли)	min 1 700	min 1700
3.14	Електрическа износоустойчивост (комутационни цикли)	min 300	min 300
3.15	Степен на защита	min IP20	IP20
3.16	Диапазон на сеченията на присъединяваните проводници	min (0,5 до 25 mm ²) за Cu/Al проводници	От 0.5 до 25 mm ² за Cu/Al проводници

4. Триполюсни и еднополюсни стопяем цилиндричен предпазител-прекъсвач-разединители, размер 10x38 mm

4.1 Триполюсен стопяем цилиндричен предпазител-прекъсвач-разединител, размер 10x38 mm

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 16 6001		FB01 B 3P	
Наименование на материала		Триполюсен стопяем цилиндричен предпазител-прекъсвач-разединител, размер 10x38 mm	
Съкратено наименование на материала		3P Цилиндр. П-л П-ч Р-л 10x38 mm	
№ по ред	Наименование	Изисквана стойност	Гарантирано предложение
4.1.1	Брой на полюсите	3	3
4.1.2	Ширина	max 54 mm	52,5 mm
4.1.3	Тегло, g	Да се посочи	195 g



4.2 Еднополюсен стопяем цилиндричен предпазител-прекъсвач-разединител, размер 10x38 mm

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 16 6101		Да се посочи	
Наименование на материала		Еднополюсен стопяем цилиндричен предпазител-прекъсвач-разединител, размер 10x38 mm	
Съкратено наименование на материала		1P Цилиндр. П-л П-ч Р-л 10x38 mm	
№ по ред	Наименование	Изисквана стойност	Гарантирано предложение
4.2.1	Брой на полюсите	1	1
4.2.2	Ширина	max 18 mm	18 mm
4.2.3	Тегло, g	Да се посочи	65 g



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки


с предмет:



„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042


“Триполюсни и еднополюсни стопяем цилиндричен предпазител-прекъсвач-разединители, размер 10x38 mm”

Приложение № 1






Fuse holders and fuses

 **Lovato**
electric
100% electricity




Fuse holders




- ◆ Modular concept for quick assembly of different versions based on various requirements.
- ◆ Compact size compliant with standards for electrical equipment.
- ◆ DIN rail mounting and removal ease.
- ◆ IP20 protection degree, finger safe.
- ◆ Sealable cover in open or closed position to increase user's safety.
- ◆ Version with status indicator to quickly determine if the fuse is still operative or needs to be replaced.
- ◆ Ergonomic grip for easy cover opening.
- ◆ Dedicated cylindrical 10x38 DC fuses for photovoltaic systems.
- ◆ UL and CSA certified versions.

Range	AC			DC	DC FUSES	CLASS CC
Fuse size	10x38	14x51	22x58	10x38	10x38	10x38
Type	gG or aM			gPV	gPV	Class CC
Rated voltage	690VAC			1000VDC / 690VAC	1000VDC	600VAC
Rated current	32A	50A	125A	32A	20A	30A
Utilisation category	AC-22B 500V AC-21B 690V		-	DC-20B 1000VDC AC-21B 690V	DC-20B 1000VDC	AC-22B 500V AC-21B 690V



and fuses




LOVATO Electric fuse holders can be used to protect against overloads and short circuits of electric lines, for motor protection and control and for the protection of electric installations.

This equipment can assure the disconnect function but is not suitable for isolation so cannot be used as switch disconnecter.

The range is available in two versions: with or without fuse status indicator. If the fuse fitted on the holder blows, the failure status is shown by the indicator on the fuse-holder front.

All the fuse holders are certified for the North-American market (UL Listed, UL Recognized and CSA). Furthermore, there is a non-certified version in 10x38mm size available too.






Fuse holders **AC** RANGE

LOVATO Electric AC fuse-holder range is suitable for class gG fuses, to protect cables and conductors, and for class aM fuses, to protect motor starting.


Function: Overload and short-circuit protection of control circuits, motor controls, electric installations.

Usage: Service industry, electric panels onboard machinery, electric installations in general.




	FB01 A...	FB01 B...	FB02 A...	FB03 A...
Fuse size	10x38		14x51	22x58
Version without indicator	1P, 1P+N, 2P, 3P, 3P+N			
Version with indicator	1P			
Main characteristics				
- Rated voltage	690VAC			
- Rated current	32A		50A	125A
- Utilisation category	AC-22B 500V, AC-21B 690V		AC-22B 500V, AC-21B 690V	AC-21B 690V
- Suitable for fuses	10x38 gG or aM		14x51 gG or aM	22x58 gG or aM
- Maximum conductor cross section	16mm ² flexible/stranded; 25mm ² rigid/solid		25mm ² flexible/stranded; 35mm ² rigid/solid	35mm ² flexible/stranded; 50mm ² rigid/solid
Certifications obtained	UR, CSA	-	cURus	cURus
Compliant with standards	IEC/EN 60947-1, IEC/EN 60947-3, RoHS directive, UL512, CSA C22.2 n°39			

UR: UL Recognized; cURus: UL Recognized for USA and Canada.



CLASS **CC** Fuse holders RANGE





FB01 C...

LOVATO Electric fuse holders for class CC fuses are used to protect branch circuits, consisting of conductors and components following the last overcurrent protective device protecting a load, in industrial applications which require high breaking capacity. Suitable only and exclusively for fitting fuses defined as "class CC", quite common on the North American market.


Usage: Service industry, electric panels onboard machinery, electric installations in general.

Fuse size	Class CC
Version without indicator	1P, 2P, 3P
Version with indicator	1P
Main characteristics	
- Rated voltage	600VAC
- Rated current	30A
- Utilisation category	AC-22B 500V, AC-21B 690V
- Suitable for fuses	10x38 class CC
- Maximum conductor cross section	16mm ² flexible/stranded; 25mm ² rigid/solid
Certifications obtained	UL, CSA
Compliant with standards	IEC/EN 60947-1, IEC/EN 60947-3UL512, RoHS directives, CSA 22.2 n° 39



Fuse holders

DC




FB01 D...

LOVATO Electric DC fuse holder range is suitable for 1000VDC rated voltage and gPV class.

Used for overload and short-circuit protection of photovoltaic modules (strings) and the relative connecting cables.

Fuse size	10x38
Version without indicator	1P, 2P
Version with indicator	1P
Main characteristics	
- Rated voltage	1000VDC / 690VAC
- Rated current	32A
- Utilisation category	DC-20B 1000VDC, AC-21B 690V
- Suitable for fuses	10x38 gPV
- Maximum conductor cross section	16mm ² flexible/stranded, 25mm ² rigid/solid
Compliant with standards	IEC/EN 60947-1, IEC/EN 60947-3, RoHS directive



Fuses

DC





FE01 D 0...

LOVATO Electric offers a range of cylindrical 10x38 fuses dedicated to photovoltaic duty and designed for 1000VDC maximum use.

Contrary to AC type fuses that blow for high overcurrent values, this type of DC fuse is designed to blow with low-intensity overcurrent values, created on photovoltaic cells and panels.

Fuses for photovoltaic application	
Breaking capacity	30kA
Main characteristics	
- Rated voltage	1000VDC
- Rated current	2...20A




TECHNICAL CHARACTERISTICS


Type	FB01 A...	FB01 B...	FB02 A...	FB03 A...	FB01 C...	FB01 D...	
Range	AC	AC	AC	AC	Class CC (AC)	DC	
Certifications obtained	UR, CSA	—	cURus	cURus	UL, CSA	—	
Maximum power dissipation	3W	3W	5W	9.5W	3W	4W	
Derating factor of current I_e for different ambient temperatures	20°C	1	1	1	1	1	
	30°C	0.95	0.95	0.95	0.95	0.95	
	40°C	0.9	0.9	0.9	0.9	0.9	
	50°C	0.8	0.8	0.8	0.8	0.8	
	60°C	0.7	0.7	0.7	0.7	0.7	
Derating factor of current I_e for sid-by-side fuse holders - n° poles	70°C	0.5	0.5	0.5	0.5	0.5	
	1-3	1	1	1	1	1	
	4-6	0.8	0.8	0.8	0.8	0.8	
	7-9	0.7	0.7	0.7	0.7	0.7	
	>10	0.6	0.6	0.6	0.6	0.6	
Voltage for status indicator	120...690VAC	120...690VAC	230...690VAC	230...690VAC	120...600VAC	350...1000VDC	
CONNECTIONS							
Maximum tightening torque	2.5Nm/22lbin	2.5Nm/22lbin	3Nm/26lbin	4Nm/35lbin	2.5Nm/22lbin	2.5Nm/22lbin	
Maximum conductor cross section	flexible/stranded	1-16mm ² /8 AWG	1-16mm ² /6 AWG	1-25mm ² /4 AWG	1-35mm ² /2 AWG	1-16mm ² /8 AWG	1-16mm ² /6 AWG
	rigid/solid	1-25mm ² /8 AWG	1-25mm ² /4 AWG	1-35mm ² /2 AWG	1-50mm ² /1 AWG	1-25mm ² /10 AWG	1-25mm ² /4 AWG
AMBIENT CONDITIONS							
Operating temperature	-20...+70°C	-20...+70°C	-20...+70°C	-20...+70°C	-20...+70°C	-20...+70°C	
Storage temperature	-40...+80°C	-40...+80°C	-40...+80°C	-40...+80°C	-40...+80°C	-40...+80°C	
HOUSING							
Din rail mount version	Yes	Yes	Yes	Yes	Yes	Yes	
Degree of protection	IP20	IP20	IP20	IP20	IP20	IP20	

DIMENSIONS


FB01 A... FB01 B... FB01 C... FB01 D...



FB02 A...




FB03 A...



ASSEMBLY

Accessories: Coupling elements (clips and pins) to mount and fix fuse holders side by side



HOW TO ORDER

FUSE HOLDERS

Order code	Pole arrangement	DIN modules n°	Status Indicator	Rated voltage Ue [V]	Rated nominale Ie [A]	Qty per pkg n°	Weight [kg]
Fuse holder (fuse disconnecter), 10x38, certified by UR and CSA.							
FB01 A 1P	1 pole	1	--	690VAC	32	12	0.750
FB01 A 1PL	1 pole	1	Yes	690VAC	32	12	0.750
FB01 A 1N	1 pole + N	2	--	690VAC	32	6	0.750
FB01 A 2P	2 poles	2	--	690VAC	32	6	0.750
FB01 A 3P	3 poles	3	--	690VAC	32	4	0.750
FB01 A 3N	3 poles + N	4	--	690VAC	32	3	0.750
Fuse holder (fuse disconnecter), 14x51, certified by cURus.							
FB02 A 1P	1 pole	1,5	--	690VAC	50	6	1.000
FB02 A 1PL	1 pole	1,5	Yes	690VAC	50	6	1.000
FB02 A 1N	1 pole + N	3	--	690VAC	50	3	1.000
FB02 A 2P	2 poles	3	--	690VAC	50	3	1.000
FB02 A 3P	3 poles	4,5	--	690VAC	50	2	1.000
FB02 A 3N	3 poles + N	6	--	690VAC	50	1	0.650
Fuse holder (fuse disconnecter), 22x58, certified by cURus.							
FB03 A 1P	1 pole	2	--	690VAC	125	6	1.050
FB03 A 1PL	1 pole	2	Yes	690VAC	125	6	1.050
FB03 A 1N	1 pole + N	4	--	690VAC	125	3	1.050
FB03 A 2P	2 poles	4	--	690VAC	125	3	1.050
FB03 A 3P	3 poles	6	--	690VAC	125	2	1.050
FB03 A 3N	3 poles + N	8	--	690VAC	125	1	0.700
Fuse holder (fuse disconnecter), class CC, certified by UL and CSA.							
FB01 C 1P	1 pole	1	--	600VAC	30	12	0.750
FB01 C 1PL	1 pole	1	Yes	600VAC	30	12	0.750
FB01 C 2P	2 poles	2	--	600VAC	30	6	0.750
FB01 C 3P	3 poles	3	--	600VAC	30	4	0.750
Fuse holder (fuse disconnecter), 10x38.							
FB01 B 1P	1 pole	1	--	690VAC	32	12	0.750
FB01 B 1PL	1 pole	1	Yes	690VAC	32	12	0.750
FB01 B 1N	1 pole + N	2	--	690VAC	32	6	0.750
FB01 B 2P	2 poles	2	--	690VAC	32	6	0.750
FB01 B 3P	3 poles	3	--	690VAC	32	4	0.750
FB01 B 3N	3 poles + N	4	--	690VAC	32	3	0.750
Fuse holder (fuse disconnecter), 10x38, for photovoltaic applications.							
FB01 D 1P	1 pole	1	--	1000VDC	32	12	0.750
FB01 D 1PL	1 pole	1	Yes	1000VDC	32	12	0.750
FB01 D 2P	2 poles	2	--	1000VDC	32	6	0.750

FUSES FOR PHOTOVOLTAIC APPLICATIONS


Order code	Rated breaking capacity [kA]	Rated voltage Ue [V]	Rated current Ie [A]	Qty per pkg n°	Weight [kg]
FE01 D 00200	30	1000VDC	2	10	0.130
FE01 D 00400	30	1000VDC	4	10	0.130
FE01 D 00600	30	1000VDC	6	10	0.130
FE01 D 00800	30	1000VDC	8	10	0.130
FE01 D 01000	30	1000VDC	10	10	0.130
FE01 D 01200	30	1000VDC	12	10	0.130
FE01 D 01600	30	1000VDC	16	10	0.130
FE01 D 02000	30	1000VDC	20	10	0.130

ACCESSORIES

Order code	Description	Qty per pkg n°	Weight [kg]
FBX 00	Coupling clip for 10x38, 14x51 and 22x58 sizes	100	0.050
FBX 01	Coupling pin for 10x38 size	100	0.130
FBX 02	Coupling pin for 14x51 and 22x58 sizes	100	0.150


N.B. Two clips FBX 00 and one pin FBX 01 are needed to couple two fuse holder FB01... types.
Three clips FBX 00 and one pin FBX 02 are needed to couple two fuse holder FB02... and FB03... types.

WIRING DIAGRAMS







2011




Switch disconnectors
16 to 1600A




Modular digital multimeters



Flush-mount digital multimeters
and power analyzers



Energy meters



Automatic transfer switch
controllers



Switching power supplies



100% electricity

Power Switch

Power Dia

Power Logic

- Motor protection circuit breakers
- Switch disconnectors
- Contactors
- Motor protection relays
- Electromechanical starters
- Control and signalling units
- Limit, micro and foot switches
- Rotary cam switches
- Modular contactors
- Time relays
- Protection relays
- Level control relays
- Earth leakage relays
- Fuse holders
- Metering instruments and current transformers
- Soft starters
- AC motor drives
- Automatic power factor controllers
- Automatic battery chargers
- Automatic transfer switch controllers
- Programmable logic relays
- Switching power supplies
- Expansion modules and accessories

www.LovatoElectric.com

LOVATO ELECTRIC S.P.A.
CONTROL SOLUTIONS FOR INDUSTRY
VIA DON E. MAZZA, 12 - 24020 GORLE (BERGAMO) ITALY
Tel. +39 035 4282111 Fax +39 035 4282200
E-mail: info@LovatoElectric.com

Sales department: Tel. +39 035 4282354 - Fax +39 035 4282400

LOVATO Electric offices in the world

United Kingdom
LOVATO (UK) LTD
Tel. +44 8458 110023
www.Lovato.co.uk

Czech Republic
LOVATO S.R.O.
Tel. +420 382 265482
www.Lovato.cz

Germany
DELTEC LOVATO GmbH
Tel. +49 7237 1733
www.DeltecLovato.de


USA
LOVATO ELECTRIC INC
Tel. +1 757 545 4700
www.LovatoUsa.com

Spain
LOVATO ELECTRIC S.L.U.
Tel. +34 93 7812016
www.LovatoElectric.es

Canada
LOVATO ELECTRIC
CORPORATION
Tel. +1 450 681 9200
www.Lovato.ca

Poland
LOVATO ELECTRIC SP. Z O.O.
Tel. +48 21 7970010
www.LovatoElectric.pl


Mexico
LOVATO ELECTRIC
DE MEXICO, S.A. DE C.V.
Tel. +52 555 3415662
www.LovatoElectric.com.mx



Present in over 90 countries

The products described in this publication are subject to be revised or improved at any moment. Catalogue descriptions and details, such as technical and operational data, drawings, diagrams and instructions, etc., do not have any contractual value. In addition, products should be installed and used by qualified personnel and in compliance with the regulations in force for electrical systems in order to avoid damages and safety hazards.

ClaroEmporioCreativo@gmail.com



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“


РЕФ. № PPD 15-042

“Триполюсни и еднополюсни стопяем цилиндричен предпазител-прекъсвач-разединители, размер 10x38 mm”

Приложение № 2




[Handwritten signature]



Page 12-2

AC FUSE HOLDERS


- Version without indicator: 1P, 1P+N, 2P, 3P, 3P+N
- Version with indicator: 1P
- For fuses 10x38, 14x51 and 22x58mm IEC class gG or aM.
- Rated current: 32A, 50A, 125A
- Rated voltage: 690VAC.



Page 12-2

AC FUSE HOLDERS CLASS CC FOR NORTH AMERICAN MARKET

- Version without indicator: 1P, 2P, 3P
- Version with indicator: 1P
- For 10x38mm UL/CSA class CC fuses
- Rated current: 30A
- Rated voltage: 600VAC.



Page 12-3

DC FUSE HOLDERS FOR PHOTOVOLTAIC APPLICATIONS

- Version without indicator: 1P, 2P
- Version with indicator: 1P, 2P
- For 10x38mm IEC class gPV fuses
- Rated current: 32A
- Rated voltage: 1000VDC
- IEC utilisation category: DC20B.




Page 12-3

DC FUSES FOR PHOTOVOLTAIC APPLICATIONS

- 10x38mm, IEC class gPV
- Rated current: 20A
- Rated voltage: 1000VDC.








- Modular size for 10x38, 14x51 and 22x58mm fuses
- Finger safe - IP20 IEC degree of protection against accidental contact with live parts and with sealable cover for operators' safety
- Version with status indicator to quickly determine if the fuse is still operative or needs to be replaced
- UL and CSA certified versions.

	SEC. - PAGE
Fuse holders	
AC fuse holders.....	12 - 2
DC fuse holders for photovoltaic applications.....	12 - 3
Fuses for photovoltaic applications	12 - 3
Accessories	12 - 3
Dimensions	12 - 4
Wiring diagrams	12 - 4
Technical characteristics	12 - 5



Fuse holders UL Recognized and CSA certified



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt [kg]
			n°	n°	[kg]

For 10x38mm fuses,
32A rated current at 690VAC.

FB01 A 1P	1P	—	1	12	0.066
FB01 A 1PL	1P	YES	1	12	0.065
FB01 A 1N0	1P+N	—	1	12	0.062
FB01 A 1N	1P+N	—	2	6	0.134
FB01 A 2P	2P	—	2	6	0.132
FB01 A 3P	3P	—	3	4	0.188
FB01 A 3N	3P+N	—	4	3	0.260

For 14x51mm fuses,
50A rated current at 690VAC.

FB02 A 1P	1P	—	1	12	0.113
FB02 A 1PL	1P	YES	1	12	0.114
FB02 A 1N	1P+N	—	2	6	0.237
FB02 A 2P	2P	—	2	6	0.224
FB02 A 3P	3P	—	3	4	0.335
FB02 A 3N	3P+N	—	4	3	0.460

For 22x58mm fuses,
125A rated current at 690VAC.

FB03 A 1P	1P	—	1	12	0.167
FB03 A 1PL	1P	YES	1	12	0.167
FB03 A 1N	1P+N	—	2	6	0.354
FB03 A 2P	2P	—	2	6	0.334
FB03 A 3P	3P	—	3	4	0.500
FB03 A 3N	3P+N	—	4	3	0.720

○ Not certified.

Operational characteristics

- IEC rated voltage U_e :
 - 690VAC (FB01 A 1M excluded)
 - 400VAC (FB01 A 1M only)
- IEC rated current I_e :
 - FB01 A: 32A
 - FB02 A: 50A
 - FB03 A: 125A
- IEC utilisation category:
 - FB01 A: AC22B 500V, AC21B 690V (except FB01 A 1M: AC22B 400V)
 - FB02 A: AC22B 500V, AC21B 690V
 - FB03 A: AC21B 690V
- Suitable for IEC fuse class: gG and aM
- IEC degree of protection: IP20.

Certifications and compliance

Certifications obtained:


Type	UL Recognized for USA (File E343395)	CSA certified (File 252040 class 6225)	UL Recognized for USA and Canada (File E343395)
FB01 A 1P, FB01 A 1PL, FB01 A 1N	●	●	—
FB02 A...	—	—	●
FB03 A...	—	—	●

● Certification obtained.

UL Recognized: Products having this type of marking are intended for use as components of complete workshop-assembled equipment.

Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3, UL 4248-1, UL 4248-4, CSA C22.2 n°4248.1, CSA C22.2 n°4248.4.

Fuse holders



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt [kg]
			n°	n°	[kg]

For 10x38mm fuses,
32A rated current at 690VAC.

FB01 B 1P	1P	—	1	12	0.062
FB01 B 1PL	1P	YES	1	12	0.064
FB01 B 1N	1P+N	—	2	6	0.127
FB01 B 2P	2P	—	2	6	0.128
FB01 B 3P	3P	—	3	4	0.185
FB01 B 3N	3P+N	—	4	3	0.247


Operational characteristics

- IEC rated voltage U_e : 690VAC
- IEC rated current I_e : 32A
- IEC utilisation category: AC22B 500V, AC21B 690V
- Suitable for IEC fuse class: gG and aM
- IEC degree of protection IP20.

Reference standards

Compliant with standards: IEC/EN 60947-1, IEC/EN 60947-3, IEC/EN 60269-1, IEC/EN 60269-2.

Fuse holders UL Listed and CSA certified for class CC fuses for North American market



Order code	Pole arrangement	Status indicator	DIN size	Qty per pkg	Wt [kg]
			n°	n°	[kg]

For 10x38mm fuses,
30A rated current at 600VAC.

FB01 C 1P	1P	—	1	12	0.070
FB01 C 1PL	1P	YES	1	12	0.072
FB01 C 2P	2P	—	2	6	0.140
FB01 C 3P	3P	—	3	4	0.210


NOTE: UL Listed and CSA certified as "Fuseholders, Cartridge Fuse" for use with Class CC fuses, Interrupting rating 200,000 Amps rms symmetrical, Voltage rating 600V, Current rating 30A.

Operational characteristics

- IEC rated voltage U_e : 600VAC
- IEC rated current I_e : 30A
- IEC utilisation category: AC22B 500V, AC21B 690V
- Suitable for UL/CSA fuse class: CC
- IEC degree of protection IP20.

Certifications and compliance

Certifications obtained: UL Listed (File E343395) and CSA certified (File 252040 class 6225).
Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3, UL 4248-1, UL 4248-4, CSA C22.2 n°4248.1, CSA C22.2 n°4248.4.




Fuse holders

DC fuse holders for photovoltaic applications.

Accessories

Fuse holders for photovoltaic applications



Order code	Pole arrangement	Status Indicator	DIN size	Qty per pkg	Wt [kg]
			n°	n°	[kg]

For 10x38mm fuses,
32A rated current at 1000VDC.

FB01 D 1P	1P	—	1	12	0.064
FB01 D 1PL	1P	YES	1	12	0.065
FB01 D 2P	2P	—	2	6	0.127
FB01 D 2PL	2P	YES	2	6	0.130

Operational characteristics

- IEC rated voltage U_e : 1000VDC
- IEC rated current I_e : 32A
- IEC utilisation category: DC20B:1000VDC
- Suitable for IEC fuse class: gPV
- IEC degree of protection: IP20

Reference standards
Compliant with standards: IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3.

Fuses for photovoltaic applications



Order code	Rated current I_n [A]	Qty per pkg	Wt [kg]
	[A]	n°	[kg]

For 10x38mm fuses,
30kA breaking capacity at 1000VDC.


FE01 D 00200	2	10	0.008
FE01 D 00400	4	10	0.008
FE01 D 00600	6	10	0.008
FE01 D 00800	8	10	0.008
FE01 D 01000	10	10	0.008
FE01 D 01200	12	10	0.008
FE01 D 01600	16	10	0.008
FE01 D 02000	20	10	0.008

Operational characteristics

- IEC rated voltage U_e : 1000VDC
- IEC rated current I_e : 2-20A
- IEC fuse class: gPV

Reference standards
Compliant with standards: IEC/EN 60269-6.

Accessories



Order code	Description	Qty per pkg	Wt [kg]
	[A]	n°	[kg]
FBX 00	Coupling clip for 10x38, 14x51 and 22x58mm sizes	100	0.003
FBX 01	Coupling pin for 10x38mm size	100	0.005
FBX 02	Coupling pin for 14x51 and 22x58mm sizes	100	0.008

For FB01 A... and FB01 B... types.

FBX 05	Three-phase connection busbar, for 57 modules in total, 1m/3.3ft long	10	0.465
FBX 07	One-pole terminal for 25mm ² max conductor	25	0.010
FBX 08	One-pole terminal for 50mm ² max conductor	25	0.020
FBX 11	End cap for FBX05 busbar	50	0.001

⊕ Not suitable for FB01 B1N, FB01 B2P, FB01 B3P and FB01 B3N types.


General and operational characteristics

THREE-PHASE BUSBAR



- Central point of power supply: 130A max
- Side point of power supply: 80A max
- Pitch: 18mm/0.7in
- Busbar section: 10mm²
- Number of modules/poles: 57
- For paralleling connection
- Length (standard supplied): 1m/3.3ft which can be cut in shorter sections.

12

Fuse holder assembly in multiple pole configuration



⊕ Not suitable for FB01 B1N, FB01 B2P, FB01 B3P and FB01 B3N types.




Fuse holders

Dimensions [mm (in)]




FUSE HOLDERS


FB01 A... FB01 B... FB01 C... FB01 D...



FB02 A...




FB03 A...




2

FUSES

FE01 D 0...



Wiring diagrams



Fuse holders

Technical characteristics


TYPE	FB01 A...	FB01 B...	FB02 A...	FB03 A...	FB01 C...	FB01 D...
Range	AC				Class CC (AC)	DC
IEC maximum rated current I _n	32A		50A	125A	30A	32A
IEC maximum rated voltage U _n	690VAC; 400VAC $\text{\textcircled{O}}$	690VAC			600VAC	1000VDC
IEC utilisation category	AC22B 500V; AC21B 690V; AC22B 400V $\text{\textcircled{O}}$			AC21B 690V	AC22B 500V; AC21B 690V	DC20B 1000VDC
Maximum power dissipation	3W		5W	9.5W	3W	4W
Derating factor of current I _n for different ambient temperatures	20°C	1				
	30°C	0.95				
	40°C	0.9				
	50°C	0.8				
	60°C	0.7				
	70°C	0.5				
Derating factor of current I _n for side-by-side fuse holders - n° poles	1-4	1				
	5-6	0.8				
	7-9	0.7				
	≥10	0.6				
Voltage for status indicator	120...690VAC		230...690VAC		120...600VAC	350...1000VDC
CONNECTIONS						
Maximum tightening torque	2.5Nm; 2Nm $\text{\textcircled{O}}$ / 22lbin		3Nm / 26lbin	4Nm / 35lbin	2.5Nm / 22lbin	
Maximum conductor cross section	flexible/stranded	1x16mm ² ; 1-16mm ² $\text{\textcircled{O}}$ / 8AWG	1x25mm ² / 6AWG	1x35mm ² / 2AWG	1x16mm ² / 8AWG	1x16mm ² / 6AWG
	rigid/solid	1x25mm ² ; 1-10mm ² $\text{\textcircled{O}}$ / 8AWG	1x35mm ² / 8AWG	1x50mm ² / 1AWG	1x25mm ² / 10AWG	1x25mm ² / 4AWG
AMBIENT CONDITIONS						
Operating temperature	-20...+70°C					
Storage temperature	-40...+80°C					
Maximum altitude	3,000m					
Operation position	Any					
Fixing	On 35mm DIN rail (IEC/EN 60715)					
$\text{\textcircled{O}}$ Values valid only for FB01 A 1M type.						

12

TECHNICAL CHARACTERISTICS FOR FE01 D... FUSES

TYPE	Rated current [A]	Power consumption at 0.7 I _n [W]	Power consumption at I _n [W]	Prearcing I ² t [A ² s]	Total I ² t at 1000VDC [A ² s]
FE01 D 00200	2	0.62	1.54	1.78	6.5
FE01 D 00400	4	0.73	1.84	3	11
FE01 D 00600	6	0.96	2.4	8.5	32
FE01 D 00800	8	1.02	2.55	25	93
FE01 D 01000	10	1.03	2.58	11	52
FE01 D 01200	12	1.04	2.6	25	116
FE01 D 01600	16	1.08	2.7	33	152
FE01 D 02000	20	1.16	2.9	85	390

TIME-CURRENT CHARACTERISTICS FOR FE01 D... FUSES



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

„Триполюсни и еднополюсни стопяем цилиндричен предпазител-прекъсвач-разединители, размер 10x38 mm“

Приложение № 3



ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният Владимир Лазаров,

Управител на фирма "ВиВ Изоматик" ООД, София, ул.Пирин 40А

В качеството си на търговски представители на LOVATO Electric

Декларираме, че продуктът:

Марка:	LOVATO
Продукт:	Основа за стопяеми предпазители
Серия:	FB

За който се отнася тази декларация, при условие, че е инсталиран, обслужван и използван за приложения, за който е предназначен, е в съответствие със следните стандарти, технически одобрения или други нормативни актове:

2006/95/ЕС /LV/
2004/108/ЕС/EMC/
IEC/EN 60269-1
IEC/EN 60947-1 ; 3

София, 20.10.2015

Владимир Лазаров, управител
ВиВ Изоматик ООД



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Триполюсни и еднополюсни стопяем цилиндричен предпазител-прекъсвач-разединители, размер 10x38 mm”

Приложение № 4



DEVICE UNDER TEST..... Fuse holder *FB01B types*
MANUFACTURER..... Lovato Electric S.p.A.
TYPE OF TEST..... Temperature rise test on FB01B fuse holders
DATE OF DEVICE RECEIPT..... 27/04/2011
START / END TESTING 29/04/2011 – 13/05/2011

SAMPLES STORING..... Eliminated / returned to customer Storage :

INDEX	1. PURPOSE OF TESTING.....	2
	2. TEST SAMPLES.....	2
	3. TEST METHOD.....	2
	4. TEST PROCEDURES.....	2
	5. TEST RESULTS	3
	6. TEST EQUIPMENT	5
	7. REMARKS & ANALYS.....	5
	8. ANNEX.....	6

ISSUE 16/05/2011
COMPILED STAFF LPR
APPROVED RESP. LPR

ВАРНО С
ОРИГИНАЛА

The test results are related only to the exemplary tested and listed under the "test samples".



1. PURPOSE OF TESTING

Requested test (according to the customer specification):

Temperature rise at 690V – 32A on FB01B fuse holders

Test purpose:

"Verify the good function of FB01B fuse holders ."

Test target:

Pass the test.

2. TEST SAMPLES

N. 1 FB01B1P fuse holder - 32A (10 x 38 mm), batch production number ...¹

N. 1 FB01B2P fuse holder - 32A (10 x 38 mm), batch production number ...¹

N. 1 FB01B3P fuse holder - 32A (10 X 38 mm), batch production number ...¹

3. TEST METHOD

IEC 60947-3 (2008-08) Ed. 3.0 + IEC 60947-1 Ed. 5.1 (2011-03)

Temperature rise (§ 8.3.3.1)

4. TEST PROCEDURES

Temperature rise..... Test instruction LPR 051-1, rev. 4, dated 11/10/2010.

¹ not available

¹ not available

¹ not available

The test results are related only to the exemplary tested and listed under the "test samples".

ВАРНО С
ОРИГИНАЛА



5. TEST RESULTS

5.1 TEMPERATURE RISE

5.1.1 WITH LEGRAND FUSE 32 A gG 400 V

Sample under test.....N. 1 FB01B1P - 32A
N. 1 FB01B2P - 32A
N. 1 FB01B3P - 32A

Test conditions

Ambient temperature.....21 °C
Relative humidity.....46 %
Installation.....in vertical way, on DIN RAIL 35mm

Data sheet fusible used:

- SupplierLegrand
- Codecod. 133 32

Test parameters

Wiring of the main circuit

- cables section / length6,0 mm² / 1,0 m
- screws tightening nominal torque2,0 + 2,5 N.m
- screws applied tightening torque2,0 N.m

Supply of the main circuit


- rated current.....I_{th} = 25 - 32 A
- test current.....I = 32 A
- supply frequency.....50 Hz

Test results

See next page.

ВЯРНО С
ОРИГИНАЛА

The test results are related only to the exemplary tested and listed under the "test samples".



Temperature rise main circuit

	[K]			Standard limit EN60947-1 tab. 2
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Terminal L1	43	54	57	65
Terminal T1	39	51	52	65
Terminal L2	-	55	61	65
Terminal T2	-	49	58	65
Terminal L3	-	-	57	65
Terminal T3	-	-	50	65
Note:	Silver plated-brass terminal			

Temperature rise for accessible parts

	[K]			Standard limit EN60947-1 tab. 3
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Line side	14	24	29	40
Load side	10	19	21	40
Left side	24	30	32	40
Right side	22	30	31	40
On front	18	24	29	40
Lever	9	16	17	40

ВЪРНО С
ОРИГИНАЛА



The test results are related only to the exemplary tested and listed under the "test samples".



6. TEST EQUIPMENT AND INSTRUMENTS

6.1. TEST EQUIPMENT

Description	Used for	Full scale	Code
Current supply station	Power supply main circuit	20V – 50A	LPRA 065

6.2. MEASURING INSTRUMENTS

Description	Used to measure	Full scale	Code	Calibration expiration date
Thermohygrometer	Ambient temperature	-5 + 50 °C	LPR 1 65	27/10/2011
Thermohygrometer	Relative humidity	10 + 90%	LPR 165	27/10/2011
Termometric instrument	Temperature rise	-30 + +200 °C	LPR 201	10/01/2012
Termocouple T type	Temperature rise	-30 + +200 °C	LPR 201	10/01/2012
Termocouple T type	Temperature rise	-30 + +200 °C	LPR 201.13	10/01/2012
Current transformer	Main circuit current	1.004/50 A	LPR 155	11/05/2014
Digital multimeter	Main circuit current	10 A	LPR 55	11/05/2012
Digital multimeter	Drop voltage	mV - Autom.	LPR 125	11/05/2012
Dynamometric screw driver	Main terminal screw tightening	6,0 Nm	LPR 231	07/01/2012

7. REMARKS & ANALYS

Temperature rise test 690V – 32A: test passed

ВАРНО С
ОРИГИНАЛА




The test results are related only to the exemplary tested and listed under the "test samples".




8. ANNEX

Picture 1: Temperature rise – test setup




Picture 1a: Temperature rise – test setup



ВЯРНО С
ОРИГИНАЛА

The test results are related only to the exemplary tested and listed under the "test samples".



Picture 2: Catalogue Legrand fuses

legrand

fusibili (standard)

0123 04 0143 10 0153 32 0151 50 0133 00


0133 08 0130 08

Informazioni tecniche, curve e quote (p. 122)

Libello	Alloggio	Tipologia GGG	Libello	Alloggio	Tipologia aM*
8,5 x 23 mm A.C.R. (Alta Capacità di Rottura) Rispondenti alla norma IEC 60269-1 EN 60269-1 EN 60269-3					
10	0113 02	0114 02 (1)	10	0120 01	1
10	0113 04	0114 04 (1)	10	0120 02	2
10	0113 06	0114 06 (1)	10	0120 04	4
100	0113 10	0114 10	10	0120 06	6
			10	0120 08	8
			10	0120 10	10
8,5 x 31,5 mm A.C.R. (Alta Capacità di Rottura) Conformi alla norma IEC 60269-1, 2 e 2-1 - EN 60269-1 Approvazioni Bureau Veritas					
10	0123 01		10	0130 02	0,25
10	0123 02	0124 02	10	0130 05	0,60
10	0123 04	0124 04	10	0130 01	1
10	0123 06	0124 06	10	0130 02	2
10	0123 08		10	0130 04	4
10	0123 10	0124 10	10	0130 06	6
10	0123 12		10	0130 08	8
100	0123 16	0124 16	10	0130 10	10
100	0123 20	0124 20	10	0130 12	12
			10	0130 16	16
			10	0130 20	20
			10	0130 25	25
10,3 x 38 mm A.C.R. (Alta Capacità di Rottura) Conformi alla norma IEC 60269-1 e 32-4 - IEC 60269-1, 2 e 2-1 - EN 60269-1 Approvazioni Bureau Veritas					
10	0133 04		10	0140 02	0141 02
10	0133 06	0134 06	10	0140 04	0141 04
10	0133 08	0134 08	10	0140 06	0141 06
10	0133 10	0134 10	10	0140 08	0141 08
10	0133 12	0134 12	10	0140 10	0141 10
10	0133 16	0134 16	10	0140 12	0141 12
10	0133 18	0134 18	10	0140 16	0141 16
10	0133 20	0134 20	10	0140 20	0141 20
10	0133 25	0134 25	10	0140 25	0141 25
			10	0140 32	0141 32
			10	0140 40	0141 40
			10	0140 45	0141 45
			10	0140 60	
14 x 51 mm A.C.R. (Alta Capacità di Rottura) Conformi alla norma IEC 60269-1 e 32-4 - IEC 60269-1, 2 e 2-1 - EN 60269-1 Approvazioni Bureau Veritas					
10	0143 02		10	0150 16	0151 16
10	0143 04	0145 04	10	0150 20	0151 20
10	0143 06	0145 06	10	0150 25	0151 25
10	0143 10	0145 10	10	0150 32	0151 32
10	0143 16	0145 16	10	0150 40	0151 40
10	0143 20	0145 20	10	0150 50	0151 50
10	0143 25	0145 25	10	0150 63	0151 63
10	0143 32	0145 32	10	0150 80	0151 80
10	0143 40	0145 40	10	0150 96	0151 96
10	0143 60	0145 60	10	0150 97	0151 97
22 x 58 mm A.C.R. (Alta Capacità di Rottura) Conformi alla norma IEC 60269-1 e 32-4 - IEC 60269-1, 2 e 2-1 - EN 60269-1 Approvazioni Bureau Veritas					
10	0153 10	0155 10	10	0163 00	8,5 x 21,5
10	0153 16	0155 16	10	0163 00	10,3 x 38
10	0153 20	0155 20	10	0163 00	14 x 51
10	0153 25	0155 25	10	0163 00	22 x 58
10	0153 32	0155 32			
10	0153 40	0155 40			
10	0153 50	0155 50			
10	0153 63	0155 63			
10	0153 80	0155 80			
10	0153 96	0155 96			
10	0153 97	0155 97			
Neutri 10 0123 00 8,5 x 21,5 10 0133 00 10,3 x 38 10 0143 00 14 x 51 10 0153 00 22 x 58					

(1) caso non normalizzato

The test results are related only to the exemplary tested and listed under the "test samples".



Тестови изпитвания приложени върху предпазител-разединители

Предпазител разединителите ГВ са изпитани съгласно IEC 60947-3 (2008-08) Ed. 3.0 + IEC 60947-1 Ed. 5.1 (2011-03) + IEC/EN 60269-1, IEC/EN 60269-2

извършените тестове са:

Капацитет за присъединявания проводник

Механична якост

Огъване

Усилие за отделяне на проводника

Изолационно разстояние

Повишено напрежение

Загуба на напрежение

Температурен тест

Тест при ток на късо съединение

Тест за стареене на материала

Точково нагряване

Управител:

Вл. Лазаров

ВЯРНО С
ОРИГИНАЛА



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“


РЕФ. № PPD 15-042

“Триполюсни и еднополюсни стопяем цилиндричен предпазител-прекъсвач-разединители, размер 10x38 mm”

Приложение № 5



A handwritten signature in black ink, appearing to be "Филип".



TESTING AUTHORIZATION

ACAE (Associazione per la Certificazione delle Apparecchiature Elettriche), Member of **LOVAG** (Low Voltage Agreement Group)

authorizes the Laboratory
LOVATO ELECTRIC S.p.A. Via Don Mazza 12 Gorle (BG)

Laboratory codification number: IL 01

to carry out the tests listed in the following, for the purpose to certify the products as stated in the Certificate n° 070B and its enclosure, issued to ACAE by ACCREDIA.

List of the authorized tests on the low - voltage components:

*Verification of dielectric withstand
Verification of temperature – rise
Operation and operating limits
Making and breaking capacities
Overload performance
Mechanical properties of terminals*

ACAE will witness the tests according to its Quality Procedure PA 5.2.1 "Test supervision".

The renewal of the authorization is subjected to annual audit.

First issue date: 2013-05-14

Current issue date: 2014-12-01

*ACAE General Secretary
Mr. Virginio Scarioni*

Virginio Scarioni



PRD N°070 B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC Mutual Recognition Agreements

ACAE

ASSOCIAZIONE PER LA CERTIFICAZIONE DELLE APPARECCHIATURE ELETTRICHE
Via Tito Livio 5 - 24123 Bergamo BG - ITALY
Tel: +39 035 4175244 Fax: +39 035 4534662
e-mail: acaecert.it www.acaecert.it
C.F. 03260610104 P.IVA IT 02911610166
R.E.A. N. 333322 C.C.I.A. BG



Scarioni

Наименование на материала: Щепселни кабелни глави за КРУ за едножилни полиетиленови кабели 10 kV и 20 kV

Съкратено наименование на материала: Щепселни каб. глави за КРУ 10 kV и 20 kV

Област: Н - Електрически уредби СрН/НН Категория: 11 - Кабелни комплекти, кабелни
накрайници, клеми, конектори

Мерна единица: Брой

Аварийни запаси: Да

Характеристика на материала:

Щепселни глави за проходни изводи на компактни комплектни комутационни устройства с SF₆ изолация с външен конус. Изолиращото тяло на щепселните глави е изработено от устойчив на външни въздействия и на пропълзяване на токове по повърхността еластомерен изолационен материал на силиконова основа. В щепселните глави са включени необходимите елементи и материали за управление на разпределението на електрическото поле, за възстановяване на изолационните характеристики на свързаните кабели и за реализиране на контактното съединение.

В зависимост от типа на проходните изводи на комплектните разпределителни устройства щепселните кабелни глави се доставят в две основни разновидности: кабелни глави за проходни изводи тип „А“ - за свързване на кабелите на трансформаторното присъединение; и кабелни глави за проходни изводи тип „С“ - за свързване на входящите/изходящите кабелни линии.

Щепселните глави за проходни изводи тип „А“ се доставят с „Г“ - образна форма или прави, а щепселните глави за проходни изводи тип „С“ се доставят в две разновидности: щепселни глави с „Г“ - образна форма (условно), които се използват самостоятелно за свързване на една кабелна линия; и щепселни глави с „Т“ - образна форма, които се използват в комбинация с „Г“ - образни глави за свързване на паралелни кабелни линии на един проходен извод на КРУ (или свързване на „сандвич“).

Щепселните глави са предназначени за едножилни кабели с полиетиленова изолация с номинални напрежения U_o/U - 6/10 kV и 12/20 kV съгласно БДС HD 620 S1:2003

„Разпределителни кабели с екструдирана изолация за обявено напрежение от 3,6/6 (7,2) kV до 20,8/36 (42) kV или БДС 2581:1986 “Кабели силови за неподвижно полагане с изолация от полиетилен и химически омрежен полиетилен“.

Щепселните глави се доставят пакетирани поединично в картонена опаковка с всички необходими крепежни и монтажни елементи, материали и приспособления, вкл. грес/паста и почистващи средства. В комплектуването са включени също така и заземленията с необходимата кабелна обувка за свързване на щепселната глава към заземителния контур на разпределителната уредба.

Щепселните кабелни глави се придружава с подробна добре илюстрирана монтажна инструкция на български език и списък на монтажните елементи и материали, чиито означения съответстват на посочените в списъка.

На картонената опаковка е залепен етикет на български език със следната информация: наименованието и/или логото на производителя; наименованието и означението на



Handwritten signature or initials.

Handwritten signature.

щепселните кабелни глави; сечението на свързваните токопроводими жила, за които са предназначени; датата на производство; датата на изтичане на годността; и референтния номер на стандарта – (БДС) HD 629.1 S2:2006.

Използване:

Щепселните кабелни глави се използват за монтиране на едножилни кабели с полиетиленова изолация с номинални напрежения $U_0/U - 6/10 \text{ kV}$ и $12/20 \text{ kV}$ и присъединяване към проходните изводи (бушинги) с външен конус на комплектните комутационни устройства - тип А или тип С съгласно БДС EN 50181:2001.


Съответствие на предложеното изпълнение със стандартизационните документи:

Щепселните кабелни глави за едножилни кабели с полиетиленова изолация трябва да отговарят на посочените по-долу стандарти или еквиваленти, включително на техните валидни изменения и поправки:

- БДС HD 629.1 S2:2006 "Изисквания за изпитване на аксесоари за използване със силови кабели с обявено напрежение от $3,6/6(7,2) \text{ kV}$ до $20,8/36(42) \text{ kV}$. Част 1: Кабели с екструдирана изолация";
- БДС HD 629.1 S2:2006/A1:2008 "Изисквания за изпитване на аксесоари за използване със силови кабели с обявено напрежение от $3,6/6(7,2) \text{ kV}$ до $20,8/36(42) \text{ kV}$. Част 1: Кабели с екструдирана изолация"; и
- БДС EN 50181:2001 „Прходни изводи щепселен тип над 1 kV до 36 kV и от 250 A до $3,15 \text{ kA}$ за съоръжения, различни от маслени трансформатори”.
- БДС HD 620 S2:2010 „Разпределителни кабели с екструдирана изолация за обявено напрежение от $3,6/6 (7,2) \text{ kV}$ до $20,8/36 (42) \text{ kV}$

Изисквания към документацията и изпитванията:

№ по ред	Документ	Приложение № (или текст)
1.	Точно означение на типа, производителя и страната на производство (произход) и последно издание на каталога на производителя	CGS 24 kV, 250 A, 25 -95 mm ² ; CTS 24 kV, 630 A, 95 - 240 mm ² , CELLPACK, Швейцария Приложение 1
2.	Техническо описание и чертежи с нанесени размери	Приложение 2
3.	Протоколи от типови изпитвания на английски или на български език съгласно таблица 3 от БДС HD 629.1 S2:2006, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	Приложение 3



№ по ред	Документ	Приложение № (или текст)
4.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания - заверено копие.	Приложение 4
5.	Декларация за съответствие на предлаганото изпълнение с изискванията на техническата спецификация на този стандарт за материал, вкл. на параграфи „Характеристика на материала“ и „Съответствие на предложеното изпълнение със стандартизационните документи“ по-горе	Приложение 5
6.	Инструкция за монтиране	Приложение 6
7.	Експлоатационна дълготрайност, min 20 год.	20 години

Забележка: Всички оригинални документи трябва да бъдат на български език или с превод на български език. (Каталозите и протоколите от изпитванията могат да бъдат и само на английски език).

Технически данни

1. Параметри на електрическата разпределителна мрежа

№ по ред	Параметър	Стойност	
1.1	Номинални напрежения	10 000 V	20 000 V
1.2	Максимални работни напрежения	12 000 V	24 000 V
1.3	Номинална честота	50 Hz	
1.4	Брой на фазите	3	
1.5	Заземяване на звездния център	<ul style="list-style-type: none"> • През активно съпротивление; • през дъгогасителна бобина; или • изолиран звезден център. 	

2. Характеристики на работната среда

№ по ред	Характеристика	Стойност/място
2.1	Максимална температура на околната среда	До + 40°C
2.2	Минимална температура на околната среда	Минус 5°C



Handwritten signatures and initials are present at the bottom of the page, including a large signature on the left and another on the right.


№ по ред	Характеристика	Стойност/място
2.3	Относителна влажност	До 90 %
2.4	Надморска височина	До 1000 m
2.5	Условия на работа	На закрито

3. Общи технически параметри, характеристики и др. Данни

№ по ред	Параметър/характеристика	Изискване	Гарантирано предложение
3.1	Конструкция	Щепселните кабелни глави се състоят от изолиращо тяло и необходимите елементи и материали за: управление на разпределението на електрическото поле; възстановяване на изолационните характеристики на присъединяваните кабели; реализиране на контактното съединение; свързване на тестваша апаратура за изпитване с повишено напрежение на присъединените кабели, без необходимост от демонтиране на щепселната кабелна глава; и свързване към заземителния контур.	Щепселните кабелни глави се състоят от изолиращо тяло и необходимите елементи и материали за: управление на разпределението на електрическото поле; възстановяване на изолационните характеристики на присъединяваните кабели; реализиране на контактното съединение; свързване на тестваша апаратура за изпитване с повишено напрежение на присъединените кабели, без необходимост от демонтиране на щепселната кабелна глава; и свързване към заземителния контур.
3.1.1	Изолиращо тяло	Изолиращото тяло трябва да бъде изработено от устойчив на външни въздействия и на пропълзяване на токове по	Изолиращото тяло трябва е изработено от устойчив на външни въздействия и на пропълзяване на токове по

ООА

№ по ред	Параметър/характеристика	Изискване	Гарантирано предложение
		повърхността еластомерен изолационен материал на силиконова основа.	пропълзяване на токове по повърхността еластомерен изолационен материал на силиконова основа.
3.1.2	Изолационни и полупроводими материали	Изолационните и полупроводимите материали трябва да осигуряват съответно възстановяването на изолационните характеристики на свързаните кабели и управление на разпределението на електрическото поле.	Изолационните и полупроводимите материали осигуряват съответно възстановяването на изолационните характеристики на свързаните кабели и управление на разпределението на електрическото поле.
3.1.3	Реализиране на контактното съединение	Плъзгащо щепселно съединение за проходни изводи от тип „А“ и проходен болт М16 за проходни изводи от тип „С“	Плъзгащо щепселно съединение за проходни изводи от тип „А“ и проходен болт М16 за проходни изводи от тип „С“
3.1.4	Свързване към заземителния контур	Заземления с необходимите кабелни обувки за свързване на щепселните глави към заземителния контур на разпределителната уредба	Заземления с необходимите кабелни обувки за свързване на щепселните глави към заземителния контур на разпределителната уредба
3.2	Приложимост на щепселните кабелни глави към:	-	-
3.2.1	вида на кабелите	Едножилни кабели с полиетиленова изолация 10 kV и/или 20 kV	Едножилни кабели с полиетиленова изолация 10 kV и/или 20 kV
3.2.1.1	конструкцията на кабелите	Съгласно БДС 2581-86, БДС HD 620 S2:2010 или еквивалент	Съгласно БДС 2581-86, БДС HD 620 S2:2010



[Handwritten signature]

[Handwritten signature]

№ по ред	Параметър/характеристика	Изискване	Гарантирано предложение
			или еквивалент
3.2.1.2	материала на токопроводимите кабелни жила	Алуминий/Мед	Алуминий/Мед
3.2.1.3	конструкцията на токопроводимите кабелни жила	Плътни, многожични или многожични уплътнени	Плътни, многожични или многожични уплътнени
3.2.2	типа на проходните изводи на КРУ	Проходни изводи от щепселен тип с външен конус : <ul style="list-style-type: none"> • тип „А“ - 250 А; или • тип „С“ - 630 А. 	Проходни изводи от щепселен тип с външен конус : <ul style="list-style-type: none"> • тип „А“ - 250 А; или • тип „С“ - 630 А.
3.2.2.1	конструкция и размери	Съгласно табл. 1 и табл. 2 от БДС EN 50181:2001 или еквивалент и фиг. 1 и фиг. 2, както са показани по-долу.	Съгласно табл. 1 и табл. 2 от БДС EN 50181:2001 или еквивалент и фиг. 1 и фиг. 2, както са показани по-долу.
3.3	Комплектация	Една щепселна кабелна глава, комплектувана с всички необходими крепежни и монтажни елементи и материали за присъединяване към проходните изводи на КРУ, с кабелни обувки и съоръжения за свързване на щепселната глава към заземителния контур на разпределителната уредба.	Една щепселна кабелна глава, комплектувана с всички необходими крепежни и монтажни елементи и материали за присъединяване към проходните изводи на КРУ, с кабелни обувки и съоръжения за свързване на щепселната глава към заземителния контур на разпределителната уредба.
3.4	Опаковка	Картонена опаковка, на която е залепен етикет на български език със следната информация: наименованието и/или логото на производителя; наименованието и означението на щепселната	Картонена опаковка, на която е залепен етикет на български език със следната информация: наименованието

БЪЛГАРСКИ
РЕПУБЛИКАНСКИ
УНИВЕРСИТЕТ
"СВ. СВЕТОСЛАВ"
СОФИЯ
1000


[Signature]

№ по ред	Параметър/характеристика	Изискване	Гарантирано предложение
		кабелна глава; сечението на свързаните токопроводими жила, за които е предназначена; датата на производство; датата на изтичане на годността; и референтния номер на стандарта – (БДС) HD 629.1 S2:2006 или еквивалент	и/или логото на производителя; наименованието и означението на щепселната кабелна глава; сечението на свързаните токопроводими жила, за които е предназначена; датата на производство; датата на изтичане на годността; и референтния номер на стандарта – (БДС) HD 629.1 S2:2006 или еквивалент
3.5	Монтажна инструкция	На български език във всяка опаковка	На български език във всяка опаковка
3.6	Списък на монтажните елементи и материали	На български език във всяка опаковка	На български език във всяка опаковка
3.7	Означение на монтажните елементи и материали	Да	Да
3.8	Срок на годност (считано от датата на производството), месеци	min 36	36
3.9	Експлоатационна дълготрайност, години	min 20	20




04


[Handwritten signature]



Фиг. 1. - Прходни щепселни изводи тип „А“




Фиг. 2. - Прходни щепселни изводи тип „С“



4. Щепселни кабелни глави за едножилни полиетиленови кабели 10 kV и 20 kV, за проходни изводи тип „А“ и тип „С“, на трансформаторни (Т) и кабелни (К) присъединения, на комплектни комутационни устройства

4.1 Щепселна кабелна глава за едножилни полиетиленови кабели 20 kV, 50 mm², за трансформаторно присъединение на КРУ – права


Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 11 3426		CGS 24 kV, 250 A, 25 -95 mm ²	
Наименование на материала		Щепселна кабелна глава - права, за едножилни полиетиленови кабели 20 kV, 50 mm ² , за трансформаторно присъединение на КРУ	
Съкратено наименование на материала		Каб. глава, права, модул „Т“, 20 kV, 50 mm ²	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.1.1	Обявено напрежение, $[U_d/U (U_m)]$	12/20 (24) kV	12/20 (24) kV
4.1.2	Обявен ток, I _r	250 A	250 A
4.1.3	Номинално сечение на токопроводимите кабелни жила	50 mm ²	25 -95 mm ²
4.1.4	Приложимост към:	-	-
4.1.4.1	типа на проходните изводи (бушинги) на КРУ	Тип А	Тип А
4.1.4.2	диаметъра на основната кабелна изолация:	-	-
4.1.4.2a	min диаметър	≤ 20,2 mm	14,7 mm
4.1.4.2b	max диаметър	≥ 21,7 mm	≥ 21,7 mm
4.1.5	Издържано постоянно напрежение - изпитване в сухо състояние	min 72 kV / 15 min	72 kV / 15 min
4.1.6	Издържано напрежение с промишлена честота 50 Hz, изпитване в сухо състояние	min 54 kV / 5 min	54 kV / 5 min
4.1.7	Допустимо ниво на частичния разряд	max 10 pC / 20,8 kV	<10 pC / 24 kV
4.1.8	Издържано напрежение с промишлена честота 50 Hz, изпитване във влажна среда	min 15 kV / 300 h	
4.1.9	Тегло, kg	Да се посочи	



Handwritten signatures and initials.

4.2 Щепселна кабелна глава за едножилни полиетиленови кабели 20 kV, 95 mm², за трансформаторно присъединение на КРУ – права


Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 11 3427		CGS 24 kV, 250 A, 25 -95 mm ²	
Наименование на материала		Щепселна кабелна глава - права, за едножилни полиетиленови кабели 20 kV, 95 mm ² , за трансформаторно присъединение на КРУ	
Съкратено наименование на материала		Каб. глава, права, модул „Т“, 20 kV, 95 mm ²	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.2.1	Обявено напрежение, $[U_d/U (U_m)]$	12/20 (24) kV	12/20 (24) kV
4.2.2	Обявен ток, I _r	250 A	250 A
4.2.3	Номинално сечение на токопроводимите кабелни жила	95 mm ²	25 -95 mm ²
4.2.4	Приложимост към:	-	-
4.2.4.1	типа на проходните изводи (бушинги) на КРУ	Тип А	Тип А
4.2.4.2	диаметъра на основната кабелна изолация:	-	-
4.2.4.2a	min диаметър	≤ 23,5 mm	14,7 mm
4.2.4.2b	max диаметър	≥ 25,0 mm	≥ 25,0 mm
4.2.5	Издържано постоянно напрежение - изпитване в сухо състояние	min 72 kV / 15 min	72 kV / 15 min
4.2.6	Издържано напрежение с промишлена честота 50 Hz, изпитване в сухо състояние	min 54 kV / 5 min	54 kV / 5 min
4.2.7	Допустимо ниво на частичния разряд	max 10 pC / 20,8 kV	<10 pC / 24 kV
4.2.8	Издържано напрежение с промишлена честота 50 Hz, изпитване във влажна среда	min 15 kV / 300 h	30 kV / 504 h
4.2.9	Тегло, kg	Да се посочи	3 kg



[Handwritten signature]

4.3 Щепселна кабелна глава за едножилни полиетиленови кабели 20 kV, 50 mm², за трансформаторно присъединение на КРУ – „Г” образна

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 11 3420		CWS 24 kV, 250 A, 16 -95 mm ²	
Наименование на материала		Щепселна кабелна глава с „Г” - образна форма, за едножилни полиетиленови кабели 20 kV, 50 mm ² , за трансформаторно присъединение на КРУ	
Съкратено наименование на материала		Каб. глава, Г-обр.,модул „Г”, 20 kV, 50 mm ²	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.3.1	Обявено напрежение, [U ₀ /U (U _m)]	12/20 (24) kV	12/20 (24) kV
4.3.2	Обявен ток, I _r	250 A	250 A
4.3.3	Номинално сечение на токопроводимите кабелни жила	50 mm ²	16 -95 mm ²
4.3.4	Приложимост към:	-	-
4.3.4.1	типа на проходните изводи (бушинги) на КРУ	Тип А	Тип А
4.3.4.2	диаметъра на основната кабелна изолация:	-	-
4.3.4.2a	min диаметър	≤ 20,2 mm	14,7 mm
4.3.4.2b	max диаметър	≥ 21,7 mm	≥ 21,7 mm
4.3.5	Издържано постоянно напрежение - изпитване в сухо състояние	min 72 kV / 15 min	72 kV / 15 min
4.3.6	Издържано напрежение с промишлена честота 50 Hz, изпитване в сухо състояние	min 54 kV / 5 min	54 kV / 5 min
4.3.7	Допустимо ниво на частичния разряд	max 10 pC / 20,8 kV	<10 pC / 24 kV
4.7.8	Издържано напрежение с промишлена честота 50 Hz, изпитване във влажна среда	min 15 kV / 300 h	30 kV / 504 h
4.3.9	Контактно съединение	Плъзгащо щепселно съединение -ø 7,9 mm	Плъзгащо щепселно съединение -ø 7,9 mm
4.3.10	Тегло, kg	Да се посочи	3,5 kg



4.4 Щепселна кабелна глава за едножилни полиетиленови кабели 20 kV, 95 mm², за трансформаторно присъединение на КРУ – „Г” образна


Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 11 3421		CWS 24 kV, 250 A, 16 -95 mm ²	
Наименование на материала		Щепселна кабелна глава с „Г” - образна форма, за едножилни полиетиленови кабели 20 kV, 95 mm ² , за трансформаторно присъединение на КРУ	
Съкратено наименование на материала		Каб. глава, Г-обр., модул „Т”, 20 kV, 95 mm ²	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.4.1	Обявено напрежение, $[U_0/U (U_m)]$	12/20 (24) kV	12/20 (24) kV
4.4.2	Обявен ток, I _r	250 A	250 A
4.4.3	Номинално сечение на токопроводимите кабелни жила	95 mm ²	16 -95 mm ²
4.4.4	Приложимост към:	-	-
4.4.4.1	типа на проходните изводи (бушинги) на КРУ	Тип А	Тип А
4.4.4.2	диаметъра на основната кабелна изолация:	-	-
4.4.4.2a	min диаметър	≤ 23,5 mm	14,7 mm
4.4.4.2b	max диаметър	≥ 25,0 mm	≥ 25,0 mm
4.4.5	Издържано постоянно напрежение - изпитване в сухо състояние	min 72 kV / 15 min	72 kV / 15 min
4.4.6	Издържано напрежение с промишлена честота 50 Hz, изпитване в сухо състояние	min 54 kV / 5 min	54 kV / 5 min
4.4.7	Допустимо ниво на частичния разряд	max 10 pC / 20,8 kV	<10 pC / 24 kV
4.4.8	Издържано напрежение с промишлена честота 50 Hz, изпитване във влажна среда	min 15 kV / 300 h	30 kV / 504 h
4.4.9	Контактно съединение	Плъзгащо щепселно съединение -ø 7,9 mm	Плъзгащо щепселно съединение -ø 7,9 mm
4.4.10	Тегло, kg	Да се посочи	3,5 kg



4.5 Щепселна кабелна глава с „Г” - образна форма, за едножилни полиетиленови кабели 20 kV, 95 mm², за кабелно присъединение на КРУ

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 11 3422		CTS 24 kV, 630 A, 95 - 240 mm ²	
Наименование на материала		Щепселна кабелна глава с „Г” - образна форма, за едножилни полиетиленови кабели 20 kV, 95 mm ² , за кабелно присъединение на КРУ	
Съкратено наименование на материала		Каб. глава, Г-обр., модул „К”, 20 kV, 95 mm ²	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.5.1	Обявено напрежение, $[U_0/U (U_m)]$	12/20 (24) kV	12/20 (24) kV
4.5.2	Обявен ток, I _r	630 A	630 A
4.5.3	Номинално сечение на токопроводимите кабелни жила	95 mm ²	95 - 240 mm ²
4.5.4	Приложимост към:	-	-
4.5.4.1	типа на проходните изводи (бушинги) на КРУ	Тип С	Тип С
4.5.4.2	диаметъра на основната кабелна изолация:	-	-
4.5.4.2a	min диаметър	≤ 23,5 mm	22 mm
4.5.4.2b	max диаметър	≥ 25,0 mm	≥ 25,0 mm
4.5.5	Издържано постоянно напрежение - изпитване в сухо състояние	min 72 kV / 15 min	76 kV / 15 min
4.5.6	Издържано напрежение с промишлена честота 50 Hz, изпитване в сухо състояние	min 54 kV / 5 min	57 kV / 5 min
4.5.7	Допустимо ниво на частичния разряд	max 10 pC / 20,8 kV	<10 pC / 25 kV
4.5.8	Издържано напрежение с промишлена честота 50 Hz, изпитване във влажна среда	min 15 kV / 300 h	32 kV / 504 h
4.5.9	Контактно съединение	Проходен болт М16	Проходен болт М16
4.5.10	Тегло, kg	Да се посочи	4,5 kg


Handwritten signature



Handwritten signature

4.6 Щепселна кабелна глава с „Г” - образна форма, за едножилни полиетиленови кабели 20 kV, 185 mm², за кабелно присъединение на КРУ


Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 11 3423		CTS 24 kV, 630 A, 95 - 240 mm ²	
Наименование на материала		Щепселна кабелна глава с „Г” - образна форма, за едножилни полиетиленови кабели 20 kV, 185 mm ² , за кабелно присъединение на КРУ	
Съкратено наименование на материала		Каб. глава, Г-обр., модул „К”, 20 kV, 185 mm ²	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.6.1	Обявено напрежение, $[U_0/U (U_m)]$	12/20 (24) kV	12/20 (24) kV
4.6.2	Обявен ток, I _r	630 A	630 A
4.6.3	Номинално сечение на токопроводимите кабелни жила	185 mm ²	95 - 240 mm ²
4.6.4	Приложимост към:	-	-
4.6.4.1	типа на проходните изводи (бушинги) на КРУ	Тип С	Тип С
4.6.4.2	диаметъра на основната кабелна изолация:	-	-
4.6.4.2a	min диаметър	≤ 27,4 mm	22 mm
4.6.4.2b	max диаметър	≥ 30,1 mm	≥ 30,1 mm
4.6.5	Издържано постоянно напрежение - изпитване в сухо състояние	min 72 kV / 15 min	76 kV / 15 min
4.6.6	Издържано напрежение с промишлена честота 50 Hz, изпитване в сухо състояние	min 54 kV / 5 min	57 kV / 5 min
4.6.7	Допустимо ниво на частичния разряд	max 10 pC / 20,8 kV	<10 pC / 25 kV
4.6.8	Издържано напрежение с промишлена честота 50 Hz, изпитване във влажна среда	min 15 kV / 300 h	32 kV / 504 h
4.6.9	Контактно съединение	Проходен болт М16	Проходен болт М16
4.6.10	Тегло, kg	Да се посочи	4,5 kg



[Handwritten signature]


4.7 Щепселна кабелна глава с „Т“ - образна форма, за едножилни полиетиленови кабели 20 kV, 95 mm², за кабелно присъединение на КРУ

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 11 3424		СТКС 24 kV, 630 A, 95 - 240 mm ²	
Наименование на материала		Щепселна кабелна глава с „Т“ - образна форма, за едножилни полиетиленови кабели 20 kV, 95 mm ² , за кабелно присъединение на КРУ	
Съкратено наименование на материала		Каб. глава, Т-обр., модул „К“, 20 kV, 95 mm ²	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.7.1	Обявено напрежение, $[U_d/U (U_m)]$	12/20 (24) kV	12/20 (24) kV
4.7.2	Обявен ток, I _r	630 A	630 A
4.7.3	Номинално сечение на токопроводимите кабелни жила	95 mm ²	95 - 240 mm ²
4.7.4	Приложимост към:	-	-
4.7.4.1	типа на проходните изводи (бушинги) на КРУ	Тип С	Тип С
4.7.4.2	диаметъра на основната кабелна изолация:	-	-
4.7.4.2a	min диаметър	≤ 23,5 mm	22 mm
4.7.4.2b	max диаметър	≥ 25,0 mm	≥ 25,0 mm
4.7.5	Издържано постоянно напрежение -изпитване в сухо състояние	min 72 kV / 15 min	76 kV / 15 min
4.7.6	Издържано напрежение с промишлена честота 50 Hz, изпитване в сухо състояние	min 54 kV / 5 min	57 kV / 5 min
4.7.7	Допустимо ниво на частичния разряд	max 10 pC / 20,8 kV	<10 pC / 25 kV
4.7.8	Издържано напрежение с промишлена честота 50 Hz, изпитване във влажна среда	min 15 kV / 300 h	32 kV / 504 h
4.7.9	Контактно съединение	Проходен болт М16	Проходен болт М16
4.7.10	Тегло, kg	Да се посочи	4,5 kg



4.8 Щепселна кабелна глава с „Т” - образна форма, за едножилни полиетиленови кабели 20 kV, 185 mm², за кабелно присъединение на КРУ

Номер на стандарта		Тип/референтен номер съгласно каталога на производителя	
20 11 3425		СТКС 24 kV, 630 A, 95 - 240 mm ²	
Наименование на материала		Щепселна кабелна глава с „Т” - образна форма, за едножилни полиетиленови кабели 20 kV, 185 mm ² , за кабелно присъединение на КРУ	
Съкратено наименование на материала		Каб. глава, Т-обр., модул „К”, 20 kV, 185 mm ²	
№ по ред	Технически параметър	Изискване	Гарантирано предложение
4.8.1	Обявено напрежение, $[U_0/U (U_m)]$	12/20 (24) kV	12/20 (24) kV
4.8.2	Обявен ток, I _r	630 A	630 A
4.8.3	Номинално сечение на токопроводимите кабелни жила	185 mm ²	95 - 240 mm ²
4.8.4	Приложимост към:	-	-
4.8.4.1	типа на проходните изводи (бушинги) на КРУ	Тип С	Тип С
4.8.4.2	диаметъра на основната кабелна изолация:	-	-
4.8.4.2a	min диаметър	≤ 27,4 mm	22 mm
4.8.4.2b	max диаметър	≥ 30,1 mm	≥ 30,1 mm
4.8.5	Издържано постоянно напрежение -изпитване в сухо състояние	min 72 kV / 15 min	76 kV / 15 min
4.8.6	Издържано напрежение с промишлена честота 50 Hz, изпитване в сухо състояние	min 54 kV / 5 min	57 kV / 5 min
4.8.7	Допустимо ниво на частичния разряд	max 10 pC / 20,8 kV	<10 pC / 25 kV
4.8.8	Издържано напрежение с промишлена честота 50 Hz, изпитване във влажна среда	min 15 kV / 300 h	32 kV / 504 h
4.8.9	Контактно съединение	Проходен болт М16	Проходен болт М16
4.8.10	Тегло, kg	Да се посочи	14,5 kg



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:


„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Щепселни кабелни глави за КРУ за едножилни полиетиленови кабели 10 kV и 20 kV”

Приложение № 1





Cable connecting systems & Accessories
Low and Medium Voltage

PRODUCT CATALOGUE
Portfolio cable connectors

Systems For Professionals

CELLPACK
Electrical Products





CWS 250A Elbow separable cable connector

for all 1-core polymeric cables, for outer cone system terminals type A


Cellplux elbow separable cable connectors CWS are suitable for connecting all polymeric-insulated 1-core cables (PVC, PE, XLPE, EPR), with different types of semi-conductive layers (graphite-coated or strippable) and screen design (wire or tape screen), to switching equipment and transformers having an outer cone system type A, up to maximum network voltage of 24 kV in accordance with EN 50180 and EN 50181.

Characteristics


- With capacitive measuring point
- Individually tested
- Outer semi-conductive layer made of semi-conductive EPDM provides protection from exposed electrical parts
- Cable sheath insulation fault test may be performed while under voltage
- For copper and aluminium conductors
- Quick, safe and easy assembly
- Suitable for a wide range of applications due to integrated screw cable lug

Application/Suitability

- Indoor
- Voltage level**
- U_0/U_{100} 6/10 (12) kV - 12.7/22 (24) kV
- Test standards**
- CENELEC HD 629.1 (DIN VDE 0278, part 629-1)
- Storage conditions/Shelf life**
- Unlimited shelf life



Dimensions



Scope of delivery

Set of 3 separable cable connectors, silicone stress control elements, earthing set, screw cable lug for main conductor, assembly material, assembly instructions

Optional accessory: EGA earthing kit for cables with tape screen (see Connecting technology)

Type	L mm	B mm	H mm	mm. Ø over core insulation after removal of the outer conductive layer mm	12 kV	17.5 kV	24 kV	Art. No	
					Nominal cross section mm ²				
U_0/U_{100} 6/10 (12) kV - 12.7/22 (24) kV									
CWS 250A 24kV	16-95 M EGA	200	80	178	14.7	50 - 95	25 - 95	16 - 95	295167
	70-150 M EGA	200	80	178	19.9	120 - 150	95 - 150	70 - 150	293792

MEDIUM VOLTAGE
Cable sets for screened electric cables





CGS 250A

Straight separable cable connector

for all 1-core polymeric cables, for outer cone system terminals type A


Cellplux straight separable cable connectors CGS are suitable for connecting all polymeric-insulated 1-core cables (PVC, PE, XLPE, EPR), with different types of semi-conductive layers (graphite-coated or strippable) and screen design (wire or tape screen) for switching equipment and transformers having an outer cone system type A, up to maximum network voltage of 24 kV in accordance with EN 50180 and EN 50181.

Characteristics


- With capacitive measuring point
- Individually tested
- Outer semi-conductive layer made of semi-conductive EPDM provides protection from exposed electrical parts
- Cable sheath insulation fault test may be performed while under voltage
- For copper and aluminium conductors
- Quick, safe and easy assembly
- Suitable for a wide range of applications due to integrated screw cable lug

Application/Suitability

- Indoor
- Voltage level**
- U_0/U_m 6/10 (12) kV - 12.7/22 (24) kV
- Test standards**
- CENELEC HD 629.1 (DIN VDE 0278, part 629-1)
- Storage conditions/Shelf life**
- Unlimited shelf life



Dimensions




MEDIUM-VOLTAGE
Cable sets for screened polymeric cables

Scope of delivery

Set of 3 separable cable connectors, silicone stress control elements, earthing set, screw cable lug for main conductor, assembly material, assembly instructions

Optional accessory: EGA earthing kit for cables with tape screen (see Connecting technology)

Type	L mm	B mm	min. Ø over core insulation after removal of the outer conductive layer mm	12 kV	17.5 kV	24 kV	Art. No.	
				Nominal cross section mm ²				
U_0/U_m 6/10 (12) kV - 12.7/22 (24) kV								
CGS 250A 24kV	25-95 M EGA	248	110	14.7	50 - 95	25 - 95	25 - 95	295283
	70-150 M EGA	248	110	19.9	120 - 150	95 - 150	70 - 150	293797





CWS 400A Elbow separable cable connector

for all 1-core polymeric cables, for outer cone system terminals type B


Cellflux elbow separable cable connectors CWS are suitable for connecting all polymeric-insulated 1-core cables (PVC, PE, XLPE, EPR), with different types of semi-conductive layers (graphite-coated or strippable) and screen design (wire or tape screen), to switching equipment and transformers having an outer cone system type B, up to maximum network voltage of 36 kV in accordance with EN 50180 and EN 50181.

Characteristics


- With capacitive measuring point
- Individually tested
- Outer semi-conductive layer made of semi-conductive EPDM provides protection from exposed electrical parts
- Cable sheath insulation fault test may be performed while under voltage
- For copper and aluminium conductors
- Quick, safe and easy assembly
- Suitable for a wide range of applications due to integrated screw cable lug

Application/Suitability

- Indoor
- Voltage level**
- U_0/U_m 6/10 (12) kV - 19/33 (36) kV
- Test standards**
- CENELEC HD 629.1 (DIN VDE 0278, part 629-1)
- Storage conditions/Shelf life**
- Unlimited shelf life



Dimensions




Scope of delivery

Set of 3 separable cable connectors, silicone stress control elements, earthing set, screw cable lug for main conductor, assembly material, assembly instructions

Optional accessory: EGA earthing kit for cables with tape screen (see Connecting technology)

MEDIUM VOLTAGE
Cable sets for screened polymeric cables

Type	L mm	B mm	H mm	min. Ø over core insulation after removal of the outer conductive layer mm	12 kV	17.5 kV	24 kV	36 kV	Art.-No.	
					Nominal cross section mm ²					
U_0/U_m 6/10 (12) kV - 12.7/22 (24) kV										
CWS 400A 24kV	25-70 EGA	215	107	250	14.7	50 - 95	25 - 95	25 - 70	250720	
	95-240 EGA	215	107	250	22.0	150 - 240	120 - 240	95 - 240	246176	
U_0/U_m 12/20 (24) kV - 19/33 (36) kV										
CWS 400A 36kV	50-95 EGA	215	107	250	22.0			95 - 95	35 - 95	250726
	150-240 EGA	215	107	250	30.8			240 - 240	150 - 240	247102





CTS 630A T-shaped separable connector

for all 1-core polymeric cables, for outer cone system terminals type C


Cellflux screwable T-shaped separable connectors CTS are suitable for connecting all polymeric-insulated 1-core cables (PVC, PE, XLPE, EPR), with different types of semi-conductive layers (graphite-coated or strippable) and screen design (wire or tape screen) to switching equipment and transformers having an outer cone system type C, up to maximum network voltage of 36 kV in accordance with EN 50180 and EN 50181.

Characteristics


- With capacitive measuring point
- Individually tested
- Outer semi-conductive layer made of semi-conductive EPDM provides protection from exposed electrical parts
- Cable sheath insulation fault test may be performed while under voltage
- For copper and aluminium conductors
- Quick, safe and easy assembly
- Suitable for a wide range of applications due to integrated screw cable lug

Application/Suitability

- Indoor
- Voltage level**
- U_0/U_m 6/10 (12) kV - 19/33 (36) kV
- Test standards**
- CENELEC HD 629.1 (DIN VDE 0278, part 629-1)
- Storage conditions/Shelf life**
- Unlimited shelf life



Dimensions



MEDIUM VOLTAGE
Cable sets for screened polymeric cables

Scope of delivery

Set of 3 separable cable connectors, silicone stress control elements, earthing set, screw cable lug for main conductor, screw cable lug for wire screen, assembly material, assembly instructions

Optional accessory: EGA earthing kit for cables with tape screen (see Connecting technology)

Note: Other T-separable cable connectors available on request.

Type	L mm	B mm	H mm	min. Ø over core insulation after removal of the outer conductive layer mm	12 kV	17.5 kV	24 kV	36 kV	Art.-No.	
					Nominal cross section mm ²					
U_0/U_m 6/10 (12) kV - 12.7/22 (24) kV										
CTS 630A 24kV	25-70 EGA	194	85	250	14.7	50 - 95	25 - 95	25 - 70	250711	
	95-240 EGA	194	85	250	22.0	150 - 240	120 - 240	95 - 240	220775	
	240-300 EGA	194	85	250	23.7	240 - 400	240 - 300	240 - 300	302732	
U_0/U_m 12/20 (24) kV - 19/33 (36) kV										
CTS 630A 36kV	50-95 EGA	194	85	250	22.0			95 - 95	35 - 95	250715
	95-150 EGA	194	85	250	22.0			95 - 240	95 - 150	256010
	150-240 EGA	194	85	250	30.8			240 - 240	150 - 240	224826
	240-400 EGA	194	85	265	31.5			300 - 400	240 - 400	256328





CTS 1250A T-shaped separable connector

for all 1-core polymeric cables, for outer cone system terminals type C


Cellplux screwable T-shaped separable connectors CTS are suitable for connecting all polymeric-insulated 1-core cables (PVC, PE, XLPE, EPR), with different types of semi-conductive layers (graphite-coated or strippable) and screen design (wire or tape screen) to switching equipment and transformers having an outer cone system type C, up to maximum network voltage of 36 kV in accordance with EN 50180 and EN 50181.

Characteristics


- With capacitive measuring point
- Individually tested
- Outer semi-conductive layer made of semi-conductive EPDM provides protection from exposed electrical parts
- Cable sheath insulation fault test may be performed while under voltage
- For copper and aluminium conductors
- Quick, safe and easy assembly
- Suitable for a wide range of applications due to integrated screw cable lug

Application/Suitability

- Indoor
- Voltage level**
 - U_0/U_m (U_m) 6/10 (12) kV - 19/33 (36) kV
- Test standards**
 - CENELEC HD 629.1 (DIN VDE 0278, part 629-1)
- Storage conditions/Shelf life**
 - Unlimited shelf life



Dimensions



Scope of delivery


Set of 3 separable cable connectors, silicone stress control elements, earthing set, screw cable lug for main conductor, screw cable lug for wire screen, assembly material, assembly instructions

Optional accessory: EGA earthing kit for cables with tape screen (see Connecting technology)

Note: Other T-separable cable connectors available on request.

MEDIUM VOLTAGE
Cable sets for screened polymeric cables

Type	L mm	B mm	H mm	min. Ø over core insulation after removal of the outer conductive layer mm	12 kV	17.5 kV	24 kV	36 kV	Art.-No.
					Nominal cross section mm ²				
U_0/U_m (U_m) 6/10 (12) kV - 12.7/22 (24) kV									
CTS 1250A 24kV 400-630 EGA M12 KS	205	87	310	33.4	500 - 630	400 - 630	400 - 630		309283
U_0/U_m (U_m) 12/20 (24) kV - 19/33 (36) kV									
CTS 1250A 36kV 400-630 EGA M12 KS	205	87	310	39.1			630	400 - 630	309284





CTKS 630A T-shaped separable coupling connector

for all 1-core polymeric cables, for separable connector type CTS


Celllux T-shaped separable coupling connectors CTKS are suitable for connecting all polymeric-insulated 1-core cables (PVC, PE, XLPE, EPR), with different types of semi-conductive layers (graphite-coated or strippable) and screen design (wire or tape screen) to the back of T-shaped separable connectors type CTS.

Characteristics


- With capacitive measuring point
- Individually tested
- Outer semi-conductive layer made of semi-conductive EPDM provides protection from exposed electrical parts
- Cable sheath insulation fault test may be performed while under voltage
- For copper and aluminum conductors
- Quick, safe and easy assembly
- Suitable for a wide range of applications due to integrated screw cable lug

Application/Suitability

- Indoor
- Voltage level
- U_0/U_n (U_m) 6/10 (12) kV - 19/33 (36) kV
- Test standards
- CENELEC HD 629.1 (DIN VDE 0278, part 629-1)
- Storage conditions/Shelf life
- Unlimited shelf life



Dimensions




Scope of delivery

Set of 3 separable coupling connectors, silicone stress control elements, earthing set, screw cable lug for main conductor, assembly material, assembly instructions

Optional accessory: EGA earthing kit for cables with tape screen (see Connecting technology)

MEDIUM VOLTAGE
Cable sets for screened and unshielded cables

Type	L mm	B mm	H mm	min. Ø over core insulation after removal of the outer conductive layer mm	Nominal cross-section mm ²				Art.-No.	
					12 kV	17.5 kV	24 kV	36 kV		
U_0/U_n (U_m) 6/10 (12) kV - 12.7/22 (24) kV										
CTKS 630A 24kV	25-70 EGA	290	74	250	14.7	50 - 95	25 - 95	25 - 70		256838
	95-240 EGA	290	74	250	22.0	150 - 240	120 - 240	95 - 240		256839
U_0/U_n (U_m) 12/20 (24) kV - 19/33 (36) kV										
CTKS 630A 36kV	50-95	310	85	250	22.0			95 - 95	35 - 95	257581
	150-240	310	85	250	30.8			240 - 240	150 - 240	257582





CTKSA Coupling surge arrester

Class 1, for separable connector type CTS


Cellplux coupling surge arresters CTKSA / Class 1 are suitable for the protection of encapsulated medium voltage installations with a maximum operating voltage of $U_0 = 24 \text{ kV}$. The compact design allows direct connection to double-row CTS T-shaped separable connectors, in accordance with International Standard IEC 60099-4.

Characteristics

- With capacitive measuring point
- Individually tested
- Outer semi-conductive layer made of semi-conductive EPDM provides protection from exposed electrical parts
- Quick, safe and easy assembly

Application/Suitability



- Indoor
- Storage conditions/Shelf life
- Unlimited shelf life



Scope of delivery


Set of 3 surge arresters, assembly material, assembly instructions

Dimensions



Type		L mm	B mm	H mm	Art.-No.
CTKSA	12kV	290	80	380	262054
	17kV	290	80	380	262055
	19.5kV	290	80	380	262816
	24kV	290	80	380	262056

Technical data	CTKSA/12kV	CTKSA/17kV	CTKSA/19.5kV	CTKSA/24kV
Nominal leakage current I [kA]	10	10	10	10
Rated voltage U_r [kV]	15.0	21.0	24.0	30.0
max. Operating voltage U_0 [kV]	12.7	17.0	19.5	24.0
Partial discharge at U_0 [pC]	< 5	< 5	< 5	< 5
Residual voltage [kV] at:				
Steep current impulse 1/20 μ s	53.0	74.2	84.8	105.9
Switching impulse current 125 A	35.8	50.1	57.3	71.7
Switching impulse current 500 A	38.2	53.5	61.2	76.5
Lightning impulse current 8/20 μ s	49.5	69.3	79.2	99.0



Handwritten signature

MEDIUM VOLTAGE
Cable sets for screened cables



CTKSA Coupling surge arrester

Class 2, for separable connector type CTS


Cellplux coupling surge arresters CTKSA / Class 2 are suitable for the protection of encapsulated medium voltage installations with a maximum operating voltage of $U_0 = 34$ kV. The compact design allows direct connection to double-row CTS T-shaped separable connectors, in accordance with International Standard IEC 60099-4.

Characteristics


- With capacitive measuring point
- Individually tested
- Outer semi-conductive layer made of semi-conductive EPDM provides protection from exposed electrical parts
- Quick, safe and easy assembly

Application/Suitability

- Indoor
- Storage conditions/Shelf life
- Unlimited shelf life




Dimensions



Scope of delivery


Set of 3 surge arresters, assembly material, assembly instructions



MEDIUM VOLTAGE
Cable sets for screened medium cables

Type		L mm	B mm	H mm	Art.-No.
CTKSA	34kV	290	80	380	301492

Technical data	CTKSA 34kV
Nominal leakage current I [kA]	10
Rated voltage U _r [kV]	42.0
max. Operating voltage U ₀ [kV]	34.0
Partial discharge at U ₀ [pC]	< 5
Residual voltage [kV] at:	
Steep current impulse 1/20 μs	120.4
Switching impulse current 125 A	84.0
Switching impulse current 500 A	89.6
Lightning impulse current 8/20 μs	108.5





ZS-CTS Accessory kit

for separable connectors type CTS


The ZS-CTS accessory set is designed for the reinstallation of T-shaped separable connectors CTS to switching equipment and transformers having an outer cone system type C, in accordance with EN 50180 and EN 50181. This set includes the proven and tested contact pin with shear head bolt, which eliminates the possibility of faulty assembly of the cable systems.

Characteristics

- Easy assembly

Application/Suitability

- Re-installation of type CTS separable connectors



Scope of delivery

Set of 3 contact pins with shear head bolt, assembly material, assembly instructions

Type	Art. No.
ZS-CTS	257622

MEDIUM VOLTAGE
Cable sets for screened and braided cables





CIK Voltage-resistant insulating cap

for plug-in connections type A 250A and type C 630A


The voltage-resistant insulating caps CIK are suitable for electrical insulations of outer cones type A 250A and type C 630A on encapsulated switching equipment and transformers up to 36 kV, in accordance with EN 50180 and EN 50181.

Characteristics

- Submersible
- Outer semi-conductive layer made of semi-conductive EPDM provides protection from exposed electrical parts
- Easy assembly

Application/Suitability

- Indoor
 - Outdoor
- Voltage level**
- U_0/U_m (U_m) 6/10 (12) kV - 19/33 (36) kV
- Storage conditions/Shelf life**
- Unlimited shelf life



Scope of delivery

Set of 3 voltage resistant insulating caps, assembly material, assembly instructions

Type	Art.-No
U_0/U_m (U _m) 6/10 (12) kV - 12.7/22 (24) kV	
CIK 250A 24kV	265023
U_0/U_m (U _m) 6/10 (12) kV - 19/33 (36) kV	
CIK 630A 36kV	265024

MEDIUM VOLTAGE
Cable sets for screened and unshielded cables.





Mounting ring Assembly guide for CWS 250A and CGS 250A

for plug-in connections type A


The mounting ring is suitable to secure the Cellplux separable cable connectors CWS 250A and CGS 250A to a special plug-in connection with outer cone systems type A. It is simply placed in the prefabricated groove in the cable connector. The two components may then be mounted on the bushing together.

Characteristics

- Secure connection to special Type A bushing
- Easy assembly

Application/Suitability

- Indoor
- Storage conditions/Shelf life
- Unlimited shelf life



Scope of delivery

Mounting ring

Type	Art.-No.
Mounting ring	264366

MEDIUM VOLTAGE
Cable sets for screened and shielded cables





CVS 250A

Connecting element up to 24 kV

for separable cable connectors type CWS and type CGS, for outer cone system terminals type A


The connecting element CVS is suitable for connecting two elbow separable cable connectors type CWS 250A and/or straight separable cable connectors CGS up to 24 kV. Its dimensions correspond to outer cone systems type A, in accordance with EN 50180 and EN 50181.

Characteristics

- Individually tested
- Safe and easy to handle
- Easy assembly

Application/Suitability


- Indoor
- Voltage level**
- U_0/U_m 6/10 (12) kV - 12.7/22 (24) kV
- Storage conditions/Shelf life**
- Unlimited shelf life



Scope of delivery

Set of 3 connecting elements, assembly material, assembly instructions

Dimensions



Type	L mm	Ø D mm	Art.-No.
U_0/U_m 6/10 (12) kV - 12.7/22 (24) kV			
CVS 250A 24kV	136	100	225844

MEDIUM VOLTAGE
Cable sets for screened and unshielded cables





CKS 630A Coupling element up to 36 kV

for T-shaped separable connectors type CTS


The coupling element CKS is suitable for connecting two T-shaped separable connectors CTS up to 36 kV. The dimensions of the longer outer cone correspond to the outer cone systems type C, in accordance with EN 50180 and EN 50181.

Characteristics

- Individually tested
- Safe and easy to handle
- Easy assembly

Application/Suitability


- Indoor
- Voltage level**
- U_0/U_m (U_m) 6/10 (12) kV - 19/33 (36) kV
- Storage conditions/Shelf life**
- Unlimited shelf life



Scope of delivery

Set of 3 coupling elements, assembly material, assembly instructions

Dimensions



D = Outer diameter

MEDIUM VOLTAGE
Cable sets for screened electric cables

Type	L mm	L1 mm	L2 mm	D mm	D1 mm	D2 mm	Art.-No.
U_0/U_m (U _m) 6/10 (12) kV - 19/33 (36) kV							
CKS 630A 36kV	196.5	61.5	91	70	56	46	224853





CPES

Test and earthing kit

for Cellplux separable cable connectors type CTS and type CTKS

The test and earthing kit CPES is suitable for the establishment of galvanic connections between cable conductors and ground. The CPES is compatible with all Cellplux T-shaped separable connectors CTS and T-shaped separable coupling connectors CTKS.

Characteristics


- Safe and easy to handle

Application/Suitability

- Cable testing
- Cable fault location
- Earthing for work
- Phase comparison

Voltage level

- U_0/U_m 6/10 (12) kV - 19/33 (36) kV



Scope of delivery

Chest, test adapter, set of 3 earthing adapters, assembly material, assembly instructions

Type	Art.-No.
U_0/U_m 6/10 (12) kV - 19/33 (36) kV	
CPES	259101

MEDIUM VOLTAGE
Cable sets for screened and metric cables



Handwritten signature



CPS Test kit

for Cellplux separable cable connectors type CTS and type CTKS

The test kit CPS is suitable for the establishment of galvanic connections between cable conductors and is compatible with all Cellplux T-shaped separable connectors CTS and T-shaped separable coupling connectors CTKS.

Characteristics


- Safe and easy to handle

Application/Suitability

- Cable testing
- Cable fault location
- Phase comparison

Voltage level

- U_0/U_m 6/10 (12) kV - 19/33 (36) kV



Scope of delivery

Chest, set of 3 test adapters, assembly material, assembly instructions

Type	Art.-No.
U_0/U_m 6/10 (12) kV - 19/33 (36) kV	
CPS	302227

MEDIUM VOLTAGE
Cable sets for screened and braid cables



INTERNATIONAL SALES ORGANISATIONS

Europe

Cellpack AG
Electrical Products
Anglikerstrasse 99
5612 Villmergen
Schweiz
Tel. +41 56 6181 234
Fax +41 56 6181 245
verkauf.epschweiz@cellpack.com

Cellpack GmbH
Electrical Products
Carl-Zeiss-Straße 20
79761 Waldshut-Tiengen
Deutschland
Tel. +49 7741 6007-0
Fax +49 7741 64989
electrical.products@cellpack.com

Cellpack Benelux B.V.
Keersluisweg 13
1332 EE Almere Buiten
Nederland
Tel. +31 36 549 03 36
Fax +31 36 532 74 99
info@cellpack.nl

Cellpack Polska Sp. z o.o.
ul. Matuszewska 14,
03-876 Warszawa
Polska
Tel. +48 22 853 53 54
Fax +48 22 853 53 56
biuro@cellpack.pl

Cellpack Italia Srl
Via Petrarca, 2
22100 Como
Italia
Tel. +39 349 903 41 61
epitalia@cellpack.com

Behr Bircher Cellpack
Ibérica, S.A.
C/.Mas Pujol, nr. 47 – Nave 4
Pol. Ind. Sector V
08520 – Les Franqueses del Vallès
Barcelona – España
Tel. +34 93 846 63 76
Fax +34 93 849 12 06
comercial@cellpackiberica.com

Behr Bircher Cellpack
BBC France s.à.r.l.
277, Boulevard des Technologies
54710 Ludres
France
Tel. +33.3.83.25.60.07
Fax +33.3.83.25.88.27
info@cellpack-ep.fr

International Distributors

Cellpack AG
Electrical Products
Anglikerstrasse 99
5612 Villmergen
Schweiz
Tel. +41 56 6181 818
Fax +41 56 6181 245
EPSalesExport@cellpack.com

Middle East

Behr Bircher Cellpack
BBC AG DMCC Branch
Jumeirah Lakes Towers
Dubai, UAE
Tel. +971 50 952 28 00
EPSalesME@cellpack.com

Asia Pacific

Cellpack Far East Pte Ltd
128 Joo Seng Road # 06 – 01
Singapore 368356
Tel. +65 6747 7024
Fax +65 6841 4554
info@cellpack.com.sg

Behr Bircher Cellpack
BBC Malaysia Sdn. Bhd.
No. 8, Jalan TU 50
Taman Tasik Utama
Ayer Keroh
75450 Melaka
Malaysia
Tel. +60 6 251 95 30
Fax +60 6 251 95 31
info@cellpack.com.my
www.cellpack.com.my

Behr Bircher Cellpack
BBC Australia Pty Ltd
PO Box 73
Oakdale, NSW, 2570
Australia
Tel. +61 407 103 621
Fax +61 2 4659 6531
New Zealand
Tel. +64 21 591 960
Fax +64 9 436 0897
salesanz@cellpack.com



Further information
on our products:
electricalproducts.cellpack.com

www.cellpack.com

Systems For Professionals

CELLPACK
Electrical Products

a BBC GROUP company



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № РРД 15-042

“Щепселни кабелни глави за КРУ за едножилни полиетиленови кабели 10 kV и 20 kV”


Приложение № 2




[Handwritten signature]

Medium Voltage | Plug-in Technology

CELLPLUX Plug-in Cable Connectors




- simple, secure, quick to assemble
- solution for entire cross-section range
- only standard tool required
- unlimited shelf life
- type tested to CENELEC HD 629.1



Systems For Professionals

CELLPACK

Electrical Products



Perfect connection

Profit from innovation

Cable accessories are indispensable for a high quality cable network. They must guarantee the same operational security as the cable itself. Due to the high costs incurred by energy suppliers for their medium voltage networks, outages are to be avoided wherever possible. Therefore it is of utmost importance to energy suppliers that cable accessories are **secure**, **quick** to implement and as **simple** as possible. Innovative solutions are in demand, particularly for medium-voltage networks where assembly defects, resulting in high costs, can be reduced drastically.

Cellplux plug-in cable connectors are the result of over five years of intensive development work at Cellpack and they represent the perfect connector system for the medium voltage field.

They have been especially developed for connecting polymeric-insulated medium-voltage cables. The system components are harmoniously matched to one another so that assembly is very **simple**, **secure** and done **quickly**. The innovative **integration concept** for this type of connector permits the majority of assembly steps (formerly performed at the construction site) to be accomplished in advance, under controlled conditions, at the Cellpack factory where they can be tested electrically. **Only a few remaining assembly steps** are performed on-site by the joiner himself.




Your advantages

- great operational security
- simple, secure and quick to assemble
- only standard tool required
- applicable to tight spaces
- solution for entire cross-section range
- mechanically robust
- unlimited shelf life
- each unit tested electrically

Your profit

- reduced costs for assembly, inventory and transport
- reduced operational costs for the cable network
- security



PROTEL
KIRI

H
#


Proven system

Insulation materials

The insulating materials used in Celllux cable connectors have outstanding electrical and mechanical characteristics. They are manufactured from high voltage resistant EPDM in a controlled injection moulding process. The individual material components have been subjected to years of electrical and mechanical testing and have proven themselves in actual applications for decades.

Stress control

Our refractive stress control system, proven millions of times around the world, is already integrated in Celllux. Faulty cable preparation and faulty stress-control body positioning are eliminated, thus drastically reducing the number of potential mounting mistakes.




Shear bolt cable lug and shear bolt contact bolt

Celllux plug-in cable connectors have a proven shear bolt connection system.

The diameter of the cable lug is designed to ensure a reliable connection for copper conductors as well as aluminium conductors over the entire range of cross-sections. Its contact screws have been optimised so that only a single conventional tool is necessary for assembly throughout the entire cross-section range. This proven system is already integrated into the CTS plug-in contact bolts, thus eliminating incorrect assembly of cable plug-in components.

Contact security

Celllux plug-in cable connectors have a 3 mm thick shield made of semi-conductive EPDM rubber. All models have successfully passed the «detectable current error» test at 6 kV.



CWS 250 A 24 kV | CGS 250 A 24 kV

Plug-in cable connectors for plastic-insulated single-core cables

Application

Cellplux straight and elbow plug-in cable connectors are advantageous for connecting all polymeric insulated single-conductor cables (PVC, PE, XLPE, EPR) with various types of semi-conductor layers (graphitized, pull-off or peel-off) as well as shield designs (wire or tape shield) to switching equipment and transformers having plug-in connections for Type A outer cone system terminals (per EN 50180, EN 50181 and DIN 47636) up to a maximum network voltage of 24 kV.

Voltage level

- E0/E (Em) 6/10 (12) 12.7/22 (24) kV

Attributes

- simple, secure, quick to assemble
- solution for entire cross-section range
- few components
- touch proof outer sheath
- outer sheath fault test possible in connected state
- applicable for enclosed or exposed installation
- submersible
- each piece pre-tested

Testing


- plug-in connection type-tested per CENELEC HD 629. 1
- shear bolt cable lug type-tested per EN/IEC 61238-1

Items included in delivery:

- set of 3 plug-in cable parts, electrically tested
- ancillary components and assembly materials
- illustrated assembly instructions

Primary elements


1. silicone stress control element
2. shear bolt cable lug
3. contact pin (PIN)
4. inner electrode
5. primary insulation
6. shield
7. fastener



Order data

Type	12 kV Q mm ²	17,5 kV Q mm ²	24 kV Q mm ²	Ø1 mm	Art.- No.
CWS 250A 24kV 16-95	50 - 95	25 - 95	16 - 95	14.7	205806
CWS 250A 24kV 70-150	120 - 150	95 - 150	70 - 150	19.9	245677
CWS 250A 24kV 16-95/EGA	50 - 95	25 - 95	16 - 95	14.7	220776
CWS 250A 24kV 70-150/EGA	120 - 150	95 - 150	70 - 150	19.9	245936
CGS 250A 24kV 25-95	50 - 95	25 - 95	25 - 95	14.7	224743
CGS 250A 24kV 70-150	120 - 150	95 - 150	70 - 150	19.9	245706
CGS 250A 24kV 25-95/EGA	50 - 95	25 - 95	25 - 95	14.7	224818
CGS 250A 24kV 70-150/EGA	120 - 150	95 - 150	70 - 150	19.9	245935

Q = nom. cross-section – for specific correlation see insulated diameter
 Ø1 = minimum insulated diameter after removal of the outer conducting layer



CVS 250 A 24 kV
Plug-in connector piece

Application

The CVS plug-in connector piece is advantageous for connecting two elbow and/or straight plug-in CWS or CGS connectors. Its dimensions correspond to Type A outer cone systems per EN 50180, EN 50181 and DIN 47636.

Voltage level


- E0/E (Em) 6/10 (12) 12.7/22 (24) kV

Attributes

- simple, secure, quick to assemble
- few components
- applicable for enclosed or exposed installation
- submersible
- each piece pre-tested



Items included in delivery:

- set of 3 connector pieces, electrically tested
- ancillary components and assembly materials
- illustrated assembly instructions



Order data

Type	Art.- No.
CVS 250 A 24kV	225844



CWS 400A 24kV | CWS 400A 36kV Plug-in cable connectors for plastic-insulated single-core cables

Application

Cellplux elbow plug-in cable connectors are suitable for connecting all plastic-insulated single-core cables (PVC, PE, XLPE, EPR), with different semi-conducting layers (graphited, pull-off or peelable) and shield designs (wire or strap shield), onto switching devices and transformers up to a maximum mains voltage of 36 kV, with female connectors for type B bushings according to the standards EN 50180, EN 50181 and DIN 47636.

Voltage level

- U0/U (Um) 6/10 (12) 18/30 (36) kV

Attributes

- Simple, safe, fast installation
- One solution for many cross sections
- Few components
- Shockproof
- Sheath fault test possible while connected
- For indoor and outdoor use
- Floodable
- Subjected to routine testing

Testing


- Plug-in connections, type-tested in accordance with CENELEC HD 629. 1

Delivery scope

- Set of 3 female plug-in connectors; individually electrically tested
- Ancillary components and small installation materials
- Illustrated installation instructions

Primary elements

1. silicone stress control element
2. shear bolt cable lug with integrated bracket
3. Contact pin (PIN)
4. Inner semiconducting layer
5. Main insulation body
6. Shielding
7. Fastening device




Order data

Type	12 kV Q mm ²	17,5 kV Q mm ²	24 kV Q mm ²	36 kV Q mm ²	Ø1 mm	Art.- No.
CWS 400A 24kV 25-70	---	25 - 95	25 - 70	---	14.7	250716
CWS 400A 24kV 95-240	---	120 - 240	95 - 240	---	22	245709
CWS 400A 24kV 25-70/EGA	50 - 95	25 - 95	25 - 70	---	14.7	250720
CWS 400A 24kV 95-240/EGA	150 - 240	120 - 240	95 - 240	---	22	246176
CWS 400A 36kV 50-95	---	---	95	50 - 95	22	250722
CWS 400A 36kV 150-240	---	---	240	150 - 240	30.8	245730
CWS 400A 36kV 50-95/EGA	---	---	95	50 - 95	22	250726
CWS 400A 36kV 150-240/EGA	---	---	240	150 - 240	30.8	247102

Q = nominal cross section – for clear assignment, see diameter over core insulation

Ø1 = minimum diameter over core insulation after removal of the outer semi-conducting layer



CTS 630 A 24 kV and CTS 630 A 36 kV Shear bolt plug-in cable connectors for polymeric insulated single-conductor cables

Application

CTS shear bolt Cellplux plug-in cable connectors are advantageous for connecting all polymeric insulated single-conductor cables (PVC, PE, XLPE, EPR) with various types of semi-conducting layers (graphitized, fully bonded or peel-off) as well as shield designs (wire or tape shield) to switching equipment and transformers having plug-in connections for Type C outer cone system terminals (per EN 50180, EN 50181) up to a maximum network voltage of 36 kV.

Voltage level

- E0/E (Em) 6/10 (12) – 18/30 (36) kV

Attributes

- simple, secure, quick to assemble
- solution for entire cross-section range
- few components
- touch-proof outer sheath
- outer sheath fault test possible in connected state
- applicable for enclosed or exposed installation
- submersible

Testing


- Plug-in connection type-tested per CENELEC HD 629. 1
- shear bolt cable lug type-tested per EN/IEC 61238-1

Items included in delivery:

- set of 3 plug-in cable parts, electrically tested
- ancillary components and assembly materials
- illustrated assembly instructions

Primary elements

- 1 silicone stress control element
- 2 shear bolt cable lug with shear-off screw and integrated holder
- 3 contact bolt with shear-off screw
- 4 inner electrode
- 5 primary insulation
- 6 shield
- 7 screw isolating plug with capacitive test point
- 8 protective cap




Order data

Type	12 kV Q mm ²	17,5 kV Q mm ²	24 kV Q mm ²	36 kV Q mm ²	Ø1 mm	Art.- No.
CTS 630A 24kV 25-70	---	25 - 95	25 - 70	---	14.7	250710
CTS 630A 24kV 95-240	---	120 - 240	95 - 240	---	22	206748
CTS 630A 24kV 25-70/EGA	50 - 95	25 - 95	25 - 70	---	14.7	250711
CTS 630A 24kV 95-240/EGA	150 - 240	120 - 240	95 - 240	---	22	220775
CTS 630A 36kV 50-95	---	---	95	50 - 95	22	250713
CTS 630A 36kV 150-240	---	---	240	150 - 240	30.8	224825
CTS 630A 36kV 240-400	---	---	300 - 400	240 - 400	31.5	252236
CTS 630A 36kV 50-95/EGA	---	---	95	50 - 95	22	250715
CTS 630A 36kV 95-150/EGA	---	---	95 - 240	95 - 150	22	256010
CTS 630A 36kV 150-240/EGA	---	---	240	150 - 240	30.8	224826
CTS 630A 36kV 240-400/EGA	---	---	300 - 400	240 - 400	31.5	256328

Q = nom. cross-section – for specific correlation see insulated diameter


Ø1 = minimum insulated diameter over insulation after removal of the outer semi-conducting layer



CKS 630 A up to 24 kV Shear bolt coupling piece

Application

The CKS shear bolt coupling piece is intended for the connection of two CTS plug-in cable connectors up to 24 kV at up to a rated current of 630 A. The dimensions of the longer outer cone corresponds to Type C outer cone systems per EN 50180, EN 50181.



Voltage level

- E0/E (Em) 6/10 (12) 12.7/22 (24) kV

Attributes


- simple, secure, quick to assemble
- few components
- applicable for enclosed or exposed installation
- submersible
- each piece pre-tested

Items included in delivery:

- set of 3 coupling pieces, electrically tested
- ancillary components and assembly materials
- illustrated assembly instructions

Order data

Type	Art.- No.
CKS 630 A 24 kV	224853



CTKS 630A 24kV | CTKS 630A 36kV Coupling connector

Application

The CTKS coupling connectors are suitable for connecting all plastic-insulated single-core cables (PVC, PE, XLPE, EPR), with different semi-conducting layers (graphited, pull-off or peelable) and shield designs (wire or strap shield), to the back of Cellpux plug-in cable connectors, model CTS 630 A 24 kV and 36 kV.

Voltage level

- U₀/U (U_m) 6/10 (12) – 18/30 (36) kV

Attributes


- Simple, safe, fast installation
- One solution for many cross sections
- Shallow installation depth
- Shockproof
- Sheath fault test possible while connected
- Floodable
- Subjected to routine testing

Delivery scope

- Set of 3 male cable connectors, electrically tested
- Ancillary components and small installation materials
- Illustrated installation instructions

Primary elements

1. silicone stress control element
2. shear bolt cable lug
3. Contact threaded pin
4. Shear bolt Contact pin
5. Internal semi-conductor layer
6. Main insulation
7. Integrated capacitive measuring point
8. Shielding
9. Screw insulation plug with capacitive measuring point





Order data

Type	12 kV Q mm ²	17,5 kV Q mm ²	24 kV Q mm ²	36 kV Q mm ²	Ø1 mm	Art.- No.
CTKS 630A 24kV 25-70/EGA	50 - 95	25 - 95	25 - 70	---	14.7	256838
CTKS 630A 24kV 95-240/EGA	150 - 240	120 - 240	95 - 240	---	22	256839
CTKS 630A 36kV 50-95	---	---	95	50 - 95	22	257581
CTKS 630A 36kV 150-240	---	---	240	150 - 240	30.8	257582

Q = nominal cross section – for clear assignment, see diameter over core insulation

Ø1 = minimum diameter over core insulation after removal of the outer semi-conducting layer



CTKSA

Plug- In Surge Arrester

Application

The CTKSA Surge Arrester is designed for the protection of encapsulated medium voltage installations with a maximum operating voltage of 24 kV. Its compact design allows direct connection to double-row CTS 630A screw plugs and complies with International Standard IEC 60099-4.

Voltage Level

- $U_0/U (U_m)$ 6/10 (12) - 12,7/22 (24) kV

Characteristics


- Safe, quick and easy assembly
- Minimal installation depth
- Protection from exposed electrical parts
- Capacitive test point
- Suitable for indoor and outdoor applications
- Individually tested

Scope of Delivery

- Set of three surge arresters, electrically tested
- Secondary components and assembly accessories
- Assembly instructions with illustrations



Primary Components

1. Surge arester
2. Screw cable lug with shear bolt
3. Connector element
4. Contact pins with shear bolt
5. Inner semi-conducting layer
6. Main insulation
7. Shielding
8. Screw-in dummy plug
9. Capacitive test point
10. Protective cap
11. Silicon stress control element



Order data

	CTKSA 12kV 10kA	CTKSA 17kV 10kA	CTKSA 19,5kV 10kA	CTKSA 24kV 10kA
Art.- No.	262054	262055	262816	262056
Nominal leakage current I [kA]	10	10	10	10
Rated voltage Ur [kV]	15	21	24	30
Maximum Operating Voltage Uc [kV]	12,7	17	19,5	24
Partial discharge Uc [pC]	< 5	< 5	< 5	< 5
Residual voltage [kV] at:				
Steep current impulse 1/20 μ s	53	74,2	84,8	105,9
Switching impulse current 125 A	35,8	50,1	57,3	71,7
Switching impulse current 500A	38,2	53,5	61,2	76,5
Lightning impulse current 8/20 μ s	49,5	69,3	79,2	99



CPES

Test and Earthing Kit

Application

The Test and Earthing Kit is designed for the establishment of galvanic connections between cable conductors and is compatible with all Type CTS and CTKS Cellplux T-plugs.

Voltage Level


- $U_0/U (U_m)$ 6/10 (12) - 18/30 (36) kV

Areas of Application

- Earthing for work
- Cable fault location
- Cable testing
- Phase compensation

Scope of Delivery

- 1x Test adapter
- 3x Earthing adapter
- 1x Case
- Assembly instructions with illustrations



Order data

Type	Art.- No.
CPES	259101

CIK

Voltage-proof Insulating Cap

Application

The CIK Voltage-proof Insulation Cap provides electrical insulation for Types A 250A and C 630A bushings in encapsulated substations and transformers up to 36kV, in compliance with EN 50180 and EN 50181.

Voltage Level


- $U_0/U (U_m)$ 6/10 (12) - 18/30 (36) kV

Characteristics

- Easy assembly
- Protection from exposed electrical parts
- Water-resistant

Scope of Delivery

- 3x Voltage-proof Insulating Caps
- Assembly accessories
- Assembly instructions with illustrations



Order data

Type	Art.- No.
CIK 250A 24kV	265023
CIK 630A 36kV	265024



ZS - CTS

Accessory Kit for Type CTS 630A Cellplex Plug-In Cable Connectors

Application

The ZS-CTS Accessory Kit is designed for the reinstallation of plug-in cable connectors in substations and transformers with bushings for Type C outer cone systems complying with EN 50180, EN 50181. The inclusion of the tried and tested contact pin with shear bolt in this kit eliminates the possibility of faulty assembly of cable systems.

Area of Application


- Reinstallation of Type CTS Plug-In Cable Connector

Scope of Delivery

- Set of 3 contact pins with shear bolt
- Assembly accessories
- Assembly instructions with illustrations

Order data

Type	Art.- No.
ZS - CTS	257622



Mounting Ring

Application

The Mounting Ring is designed to secure CWS 250A and CGS 250A Cellplex Plug-In Cable Connectors to a special bushing for Type A outer cone systems. The Mounting Ring is simply placed in the prefabricated groove in the cable connector. The two components may then be mounted on the bushing together.

Characteristics



- Easy assembly
- Secure connection to special Type A bushing

Scope of Delivery

- 1 x Mounting Ring

Order data

Type	Art.- No.
Mounting Ring	264366





WEST

Cellpack AG Electrical Products
Anglikerstrasse 99
5612 Villmergen
Schweiz
Tel. +41 56 618 12 34
Fax +41 56 618 12 45
verkauf.epschweiz@cellpack.com

Cellpack GmbH
Carl-Zeiss-Straße 20
79761 Waldshut-Tiengen
Deutschland
Tel. +49 7741 6007-0
Fax +49 7741 64989
electrical.products@cellpack.com

Cellpack Benelux B.V.
Keersluisweg 13
1332 EE Almere Buiten
Nederland
Tel. +31 (0) 36 549 03 36
Fax +31 (0) 36 532 74 99
info@cellpack.nl

Behr Bircher Cellpack Ibérica, S.A.
C/. Mas Pujol, nr. 47 – Nave 4
Pol. Ind. Sector V
08520 – Les Franqueses del Vallès
Barcelona – España
Tel. +34 93 846 63 76
Fax +34 93 849 12 06
comercial@cellpackiberica.com

Behr Bircher Cellpack BBC France s.à.r.l.
277, Boulevard des Technologies
54710 Ludres
France
Tel. +33.(0)3.83.25.60.07
Fax +33.(0)3.83.25.88.27
info@cellpack-ep.fr

EAST

Cellpack Polska Sp. z o.o.
ul. Matuszewska 14,
03-876 Warszawa,
Polska
Tel. +48 022 853 53 54
Fax +48 022 853 53 56
biuro@cellpack.pl

ASIA

Cellpack Far East (PTE) LTD.
128 Joo Seng Road # 06 – 01
Singapore 368356
Tel. +65 6747 7024
Fax +65 6841 4554
cellpack@singnet.com.sg

Behr Bircher Cellpack BBC Malaysia Sdn. Bhd.
No. 8, Jalan TU 50
Taman Tasik Utama
Ayer Keroh
75450 Melaka
Malaysia
Tel. + 60 6 251 95 30
Fax + 60 6 251 95 31
info@cellpack.com.my
www.cellpack.com.my

Systems For Professionals

CELLPACK
Electrical Products

a **BBC GROUP** company

All about us:
www.bbcgroup.biz



www.cellpack.com

ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № РРД 15-042


“Щепселни кабелни глави за КРУ за едножилни полиетиленови кабели 10 kV и 20 kV”

Приложение № 3



Bereich Hochspannungsprüftechnik

Institut für Elektroenergiesysteme und Hochspannungstechnik



Universität Fridericiana (TH) Karlsruhe

76128 Karlsruhe - Kaiserstraße 12

Telefon (0721) 608 2520 Telefax (0721) 69 52 24

Test Report No 2007-129

Type Test of

Separable Connectors

Type CELLPLUX-CGS 250 A 24 kV

Customer: Cellpack GmbH
Carl-Zeiss-Str. 20
79761 Waldshut-Tiengen

Reporter: Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer



This report includes 28 numbered pages and is only valid with the original signature. Copying of extracts is subject to the written authorization of the test laboratory. The test results concern exclusively to the tested objects.



1 Purpose of Test

4 separable connectors for $V_0 / V_n / V_m = 12 / 20 / 24$ kV were subjected to a type test according to CENELEC HD 629.1 S1 07/1996 and A1 11/2000 table 7 test sequence D1. 2 separable connectors for $V_0 / V_n / V_m = 12 / 20 / 24$ kV were subjected to additional tests according to CENELEC HD 629.1 S1 07/1996 and A1 11/2000, table 7 test pos. 19-22.

2 Miscellaneous Data

Test object: – 6 separable connectors type CELLPLUX-CGS 24 kV 250 A mounted on adapter CVS 24 kV 250 A
 $V_m = 24$ kV,
Drawing no.; MS 0015 Z from 31.05.2007 (seperable connector), Figure 2.1
Drawing no.; MS 0035 Z from 02.07.2007 (adapter), Figure 2.2 - 2.3
Installation instruction no.: 224441/0607/1/6, Figure 2.4 - 2.9
Type of the cable: The test object was mounted on a single-wire XLPE-cable,
type:NA2X(F)2Y 1x70RM/25 12/20kV


Cable length Connector - sealing end: 3 m


Place of test: *Institute of Electric Energy Systems and High Voltage Technology* – University of Karlsruhe
Kaiserstraße 12 – 76128 Karlsruhe

Testing dates: Delivery: 18.06.2007
 Mounting: 18.06.2007
 Test period: 18.06. - 20.09.2007

Atmospheric conditions: Temperature: 19°C – 24°C
 Air pressure: 980 - 1025 mbar
 rel. humidity: 35 % – 60 %

Representatives: Dr.-Ing. R. Badent
 Dr.-Ing. B. Hoferer
 Mr. O. Müller






Diese Zeichnung darf ohne schriftliche Genehmigung weder Dritten Personen noch Kopiermaschinen weder im Original noch in der Kopie, mitgeteilt werden. §§ 15, 23 des Hochspannungs vom 3.8.01 und §§ 23, 25 des BGR.

Figure 2.1: Separable connector.



Diese Zeichnung darf ohne unsere Genehmigung weder Dritten Personen noch Konzernfirmen weder im Original noch in der Kopie mitgeteilt werden. Bei 15,33 der Rechtsprechung vom 03.01 und 05.03, 020 der BGR.



Zeich.Nr.: MS0035Z
Datum: 02.07.2007
Skala: 1/2
Maßstab: 1:1
Werkstoff:

CVS 24KV 250A
 Verbindungsstück

CELLPACK GmbH
 Bereich Elektroprodukte
 Carl-Zeiss-Straße 20
 79761 Wädswil-Tengen
 Telefon 07741/60070
 Fax: 07741/6007975



ВАРНО С
 ОПИТУВАНА








Figure 2.3: Adapter





Montageanleitung

Gerader-Steckanschluss für
Einleiter Kunststoffkabel
bis 24 kV

224441/0607/1/6

CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com
e-mail: electrical_products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45

CELLPACK
Electrical Products

224441 CGS 24kV 250A 25-95

Figure 2.4: Installation Instruction

1/6
ВАРНО С
ОРИГИНАЛА

ЕЛЕКТРО
СОФ
[Signature]

Vor Montagebeginn beachten:

- Prüfen, ob die Garnitur für die vorhandenen Kabel geeignet ist.
- Material anhand der Packliste auf Vollständigkeit prüfen.
- Montageanleitung sorgfältig lesen.

Die Montage darf nur durch eine fachkundige Person erfolgen.
Für Ausfälle und Folgeschäden aufgrund falscher Montage ist der Hersteller nicht haftbar.


Gerader-Steckanschluss Typ CGS 250A 24kV 25-95

Querschnittzuteilung

Spannung U _o /U _{Um} kV	Leiterquerschnitte RM/RE (*) mm ²
6/10(12) kV	50 - 95
8,7/15(17,5) kV	25 - 95
12/20(24) kV	25 - 95

(*) Durchmesser über Aderisolierung min. 14,7 mm


Ausrichtung:



- Kabelmantel auf ca. 1 m Länge gründlich reinigen.
- Kabel ausrichten und mit 200 – 500 mm Überstand zur Durchführungsmitte anpassen und einkürzen.
- Durchführungsmitte und das Maß 150 mm auf Kabelmantel markieren.

224441 CGS 24kV 250A 25-95


Figure 2.5: Installation Instruction



Kabelvorbereitung


Kabel mit Drahtschirm:

1a)




- Kabelmantel bis auf untere Markierung absetzen.
- Schirmdrähte zurücklegen und mit PVC-Band auf dem Kabelmantel festlegen.
- Leiter auf 130 mm einkürzen.

2a)



- Leitschicht sorgfältig bis auf 30 mm entfernen (auf saubere Absetzkante achten).
- Leiterisolation um 35 mm absetzen.
- Isolation und Leitschicht gründlich reinigen.

3a)




- Am Leiterende einen Schutzwickel aus PVC Band anbringen.
- 2/3 der Länge des Dichtmastiks DM1, gemäß Zeichnung, 10 mm auf die Leitschicht und 20 mm auf den Drahtschirm wickeln (50% Dehnung).
- Am Leitschichtende gemäß Zeichnung Gleit- und Füllmittel GM1 aufbringen.
- Isolation gleichmäßig mit Gleit- und Füllmittel GM1 benetzen.


224441 CGS 24kV 250A 25-95

Figure 2.6: Installation Instruction


ВАЖНО С
ОРИГИНАЛА




Kabel mit Bandschirm:



- Kabelmantel 20mm weiter wie bis zur untere Markierung absetzen.
- Leiter gemäß Zeichnung einkürzen.
- Bandschirm bis auf 20 mm sauber entfernen.



- Leitschicht sorgfältig bis auf 30 mm entfernen (auf saubere Abseizkante achten).
- Leiterisolation um 35 mm absetzen.
- Isolation und Leitschicht gründlich reinigen.



- Am Leiterende Schutzwickel aus PVC-Band anbringen.
- Flachgewalztes Erdseil und Erdlitze (Erdungskit bitte separat bestellen) mittels Rollfeder RF auf dem Bandschirm kontaktieren
- 2/3 der Länge des Dichtmas tiks DM1 gemäß Zeichnung, 10 mm auf die Leitschicht und 20 mm auf den Bandschirm wickeln.
- Am Leitschichtende gemäß Zeichnung Gleit- und Füllmittel GM1 aufbringen.
- Isolation gleichmäßig mit Gleit- und Füllmittel GM1 benetzen.


224441 CGS 24kV 250A 25-95

Figure 2.7: Installation Instruction

4/8
ВЕРНО С
ОРИГИНАЛА



4)




- Zungen der Aufschiebehilfe AH mit Silikonfett einfetten.
- Aufschiebehilfe AH in das Feldsteuerelement einführen und bis vor den Dichtwickel aufschieben.
- Danach Aufschiebehilfe entfernen, dabei Zungen einzeln herausziehen.
- Feldsteuerelement mit leichter Drehung endgültig positionieren.

5)



- Schutzwickel am Leiterende entfernen.
- Schraubkabelschuh nach separater Montageanleitung montieren.
- Oberfläche des Feldsteuerelements gründlich reinigen.

6)




- Steckerkörper und Feldsteuerelement mit Gleit- und Füllmittel GM1 benetzen.
- Steckerkörper auf das Kabelende aufschleben bis der Kontaktstift im Steckerkörper einrastet.

224441 CGS 24KV 250A 25-95


5/6

Figure 2.8: Installation Instruction

ВЕРНО С
ОРИГИНАЛА




7)




- Zwischen Steckerende und Dichtbereich restliche (1/3) des Dichtmastiks DM1 aufwickeln.

8)




- Band Nr. 2585 ca. 20 mm über Steckerende bis Ende des Dichtbereiches wickeln.

9)



- Durchführung und Steckerinnenseite gleichmäßig mit Gleit- und Füllmittel GM1 benetzen.
- Eine Zunge der Aufschiebehilfe ausschneiden (Entlüftungshilfe).
- Entlüftungshilfe in den Stecker einführen. Stecker gerade auf die Durchführung aufstecken.

10)



- Befestigungsbügel, Halteplatte und Erdungslitze gem. Zeichnung montieren, Flügelmuttern dabei gleichmäßig handfest anziehen
- Entlüftungshilfe herausziehen, überschüssiges Gleit- und Füllmittel entfernen.
- Zwei Schirmdrähte verdrehen (bei Drahtschirm) oder Erdlitze (bei Bandschirm) und gemäß Zeichnung an der Halteplatte montieren.
- Erdungsmaßnahmen gemäß den lokalen Vorschriften durchführen.

224441 CGS 24kV 250A 25-95

ВЕРНО С
ОРИГИНАЛА




Figure 2.9: Installation Instruction

Tests: Test volume, chronological order and requirements conform to CENELEC HD 629.1 S1 07/1996 and A1 11/2000 test sequence D1, table 7 and additional test pos. 17 - 20.

The PD-test was performed at $2 V_0$. The tests were carried out in accordance with the test methods described in CENELEC HD 628 S1 07/1996.

Test sequence D1:

- Pos. 1. *DC voltage withstand test*
 $V = 6 V_0 = -72 \text{ kV}$; $t = 15 \text{ min}$
- Pos. 2. *AC voltage withstand test*
 $\hat{U}/\sqrt{2} = 4,5 V_0 = 54 \text{ kV}$; $t = 5 \text{ min}$
- Pos. 3. *Partial discharge test*
 $\hat{U}/\sqrt{2} = 2,0 V_0 = 24 \text{ kV}$; $PD \leq 10 \text{ pC}$
- Pos. 4. *Impulse voltage withstand test, at elevated temperature*
Impulse voltage
 $\hat{U} = 125 \text{ kV}$; positive and negative polarity each 10 impulses
- Pos. 5. *Electrical heat cycling in air*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{U}/\sqrt{2} = 30 \text{ kV}$
number of cycles: 3
- Pos. 6. *Partial discharge test at ambient temperature and elevated temperature*
 $\hat{U}/\sqrt{2} = 2,0 U_0 = 24 \text{ kV}$; $PD \leq 10 \text{ pC}$
- Pos. 10. *Electrical heat cycling in air*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{U}/\sqrt{2} = 30 \text{ kV}$
number of cycles: 60
- Pos. 11. *Electrical heat cycling in water*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{U}/\sqrt{2} = 30 \text{ kV}$
number of cycles: 63
- Pos. 12. *Disconnection / Connection*
5 complete operations,
no visible damage to contact



- Pos. 13. *Partial discharge test at ambient temperature and elevated temperature*
 $\hat{U}/\sqrt{2} = 2,0$ $V_0 = 24$ kV ; PD ≤ 10 pC
- Pos. 14. *Impulse voltage withstand test, lightning impulse voltage*
 $\hat{U} = 125$ kV; positive and negative polarity each 10 impulses
- Pos. 15. *AC voltage withstand test*
 $\hat{U}/\sqrt{2} = 2,5$ $V_0 = 30$ kV; t = 15 min

Additional Tests:

- Pos. 19. *Screen resistance measurement*
 $R \leq 5000$ Ω
- Pos. 20. *Leakage current measurement*
 $\hat{U}/\sqrt{2} = 2,0$ $V_m = 24$ kV
 $I \leq 0,5$ mA
- Pos. 21. *Screen fault current initiation*
Fault current to flow continuously
- Pos. 22. *Operating force test*
 $F \leq 900$ N

ВАРНО С
ОРИГИНАЛА



3 Mounting

Final assembling of the separable connector was executed in the high-voltage laboratory of the IEH

ВЯРНО С
ОРИГИНАЛА



4 Test Setups

4.1 DC Voltage Withstand Test

The DC-voltage was generated according to Figure 4.1. The voltage measurement was carried out with an ohmic-capacitive divider (ratio 2000:1). The measurement uncertainty was 3%.




Figure 4.1: Scheme of DC voltage test circuit.

$R_H = 3,6 \text{ k}\Omega$, $R_{H1} = 360 \text{ M}\Omega$, $C_H = 180 \text{ pF}$, ratio 2.000:1, PVM: Peak Voltmeter, TO: Test object, measurement uncertainty 3%

4.2 AC Voltage Withstand Test

The test voltage was generated by an 60-kVA transformer. The voltage measurement was carried out with a capacitive divider ($C_H = 180 \text{ pF}$; ratio = 2.000) and a peak voltmeter calibration $\hat{v}/\sqrt{2}$.




Figure 4.2: Scheme of AC test circuit

T_1 : transformer 400V / 200000V ; 60 kVA ; $v_K = 3,5 \%$; 50 Hz

C_H : 180 pF ; ratio 2000:1 ; PVM : Peak-Voltmeter

TO: Test object; measurement uncertainty 3 %

ВАРНО С
ОРИГИНАЛА



4.3 Partial-Discharge Test

The PD-measurement was performed with an analog bridge according to *Kreuger*, Figure 4.3. External PDs producing common mode signals at the detector are rejected by the differential amplifier. Internal PDs represent differential mode signals and are amplified. The background noise level at 24 kV_{rms} was 0,7 pC.





Figure 4.3: Scheme of PD test circuit
 TO1: Test object 1
 TO2: Test object 2

For balancing the bridge a calibrating impulse with $q_A = 10.000 \text{ pC}$ is applied between the terminals A (high-voltage) and C (ground) and the amplifier output is minimized. A pulse between the terminals A and C corresponds to an external PD. For the calibration a PD pulse, $q_A = 10 \text{ pC}$, is applied between A and B. Subsequently, the amplifier output of the PD measuring unit is adapted to the applied pulse.

Starting from zero the AC-voltage was steadily raised up to 27,0 kV and kept constant for 60 s, then slowly reduced to 24 kV including pd-reading.

ВЕРНО С
ОРИГИНАЛА



4.4 Lightning Impulse Voltage Withstand Test

For impulse testing was used a two-stage Marx generator (Haefely) with a maximum cumulative charging voltage of $V = 400 \text{ kV}$ and a maximum impulse energy of $E_{\text{max}} = 20 \text{ kW}$ s. At this test, the capacity of the energy storage capacitor was $C_S = 0.25 \text{ }\mu\text{F}$. The crest value of the impulse voltage was measured by a damped capacitive divider and a subsequent impulse peak voltmeter (Haefely). The front time and the time to half value were evaluated from the oscillographs.




Figure 4.4: Scheme of impulse voltage test circuit

C_H : 1200 pF ; $R_H = 70 \text{ }\Omega$; ratio: 3225;

IPV: impulse-peak-voltmeter (Haefely) – measurement uncertainty 3%

Oscilloscope: Tektronix TDS 3044B – measurement uncertainty 2%

The waveform parameters were determined at reduced charging voltage.

Positive impulse: $T_1 = 1.07 \text{ }\mu\text{s}$ $T_2 = 48.6 \text{ }\mu\text{s}$

Negative impulse: $T_1 = 1.04 \text{ }\mu\text{s}$ $T_2 = 48.0 \text{ }\mu\text{s}$

ВАРНО С
ОРИГИНАЛА



4.5 Electrical Heat Cycling in Air

The test objects must be heated by a current of $I = 250$ A. Current inception was accomplished by a transformer ($V_1 = 400$ V; $V_2 = 8$ V) which used the cable as secondary winding. The current was measured by an current transformer, 1500/5, and a digital multimeter. The measurement uncertainty was 1%.

ВЯРНО С
ОРИГИНАЛА



4.6 Electrical Heat Cycling in Water

The test object were placed in a tank and filled with water. The height of the water was 1000 mm above the test object. The conductivity of the water at 20°C was 63 mS/m.

4.7 Screen Resistance Measurement

Prior to the test silver-painted electrodes were installed. The screen resistance of the plug-in termination was measured at ambient temperature between the two electrodes. Then the test object was subjected to thermal ageing in an air oven at $(120\pm 2)^\circ\text{C}$ for 168 h. After thermal ageing the screen resistance at ambient temperature was measured again.

4.8 Leakage Current Measurement

Prior to the test a metal foil of 25 cm² was fixed without any air gap to the outer screen of the plug-in termination. The metal foil was placed at the end of the plug-in termination opposite to the earth bend and earthed through a milliamperemeter and a resistance of 2000 ohms. The leakage current was measured with a test voltage of V_m applied between conductor and earth.

4.9 Screen Fault Current Initiation

Prior to the test a faulting wire of approx. 0.2 mm was placed in the area of the hexagonal connecting bolt through a drilled hole. The wire was connected with the inner and outer screens and did not protrude beyond the outer screen surface.

The test voltage was generated by a 630 kVA-transformer. A capacitor was connected in series to the test object, resulting in a short-circuit current of 10A, Figure 4.9. The sequence of the test was as follows:

1. voltage switched on for 1 s
2. voltage switched off for 2 min
3. voltage switched on for 2 min
4. voltage switched off for 2 min
5. voltage switched on for 1 min
6. voltage switched off






Figure 4.9: Scheme of AC test circuit
T₁: Tránsformer 400V/20.000V; 630 kVA
C_H: 180 pF; ü = 2000:1; PVM; peak-voltmeter
C = 2,66 µF; W: current transformer; TO: test object

4.10 Operation Force Test

The test object was placed in a climate chamber an conditioned at (-20±2)°C for at least 12h. The test was carried out within 5 min after removal from the climate chamber. The plug-in termination was clamped by means of a tool which allows operation along the axis of the test object. The force was gradually applied to the plug-in termination and measured by means of a tractive dynamometer.

ВЯРНО С
ОРИГИНАЛА



5 Results

5.1 Test Sequence D1

5.1.1 DC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 18.06.2007

Test voltage: $V = - 72 \text{ kV}$; $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the DC voltage withstand test.

The test was passed successfully.

5.1.2 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 18.06.2007

Test voltage: $\hat{V}/\sqrt{2} = 54 \text{ kV}$, $t = 5 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

5.1.3 Partial Discharge Test


This test was carried out as described in 4.

Test date: 18.06.2007

Voltage: $\hat{V}/\sqrt{2} = 27 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\hat{V}/\sqrt{2} = 24 \text{ kV}$ with pd reading

PD magnitude (24 kV): $< 10 \text{ pC}$

The test was passed successfully.



5.1.4 Impulse Voltage Withstand Test at elevated Temperature

This test was carried out as described in 4

Test date: 18.06.2007
Test voltage: $\hat{U} = 125 \text{ kV}$
Heating current: $I = 250 \text{ A}$; $t = 5 \text{ h}$
Number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.1.5 Electrical Heat Cycling in Air

This test was carried out as described in 4.

Test date: 2.06. - 21.06.2007
Test voltage: $\hat{U}/\sqrt{2} = 30 \text{ kV}$
Heating current: $I = 250 \text{ A}$
Cycle: 5 h heating; 3 h cooling
Number of cycles: 3

Neither flashover nor breakdown occurred.

The test was passed successfully.

5.1.6 Partial Discharge Test

5.1.6.1 Partial Discharge Test at ambient temperature

This test was carried out as described in 4.

Test date: 22.06.2007
Voltage: $\hat{U}/\sqrt{2} = 27 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\hat{U}/\sqrt{2} = 24 \text{ kV}$ with pd reading
PD magnitude (24 kV): $< 10 \text{ pC}$

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



5.1.6.2 Partial Discharge Test at elevated temperature

This test was carried out as described in 4

Test date: 22.06.2007
Heating current: $I = 250 \text{ A}$, $t = 5 \text{ h}$
Voltage: $\hat{U}/\sqrt{2} = 27 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\hat{U}/\sqrt{2} = 24 \text{ kV}$ with pd reading
PD magnitude (24 kV): $< 10 \text{ pC}$

The test was passed successfully.

5.1.7 Electrical Heat Cycling in Air

This test was carried out as described in 4.

Test date: 02.07. - 2207.2007
Test voltage: $\hat{U}/\sqrt{2} = 30 \text{ kV}$
Heating current: $I = 250 \text{ A}$
Cycle: 5 h heating; 3 h cooling
Number of cycles: 60

Neither flashover nor breakdown occurred.

The test was passed successfully.

5.1.8 Electrical Heat Cycling in Water

This test was carried out as described in 4.

Test date: 06.08. - 27.08.2007
Conductivity: 63 mS/m
Test voltage: $\hat{U}/\sqrt{2} = 30 \text{ kV}$
Heating current: $I = 250 \text{ A}$
Cycle: 5 h heating; 3 h cooling
Number of cycles: 63
Heat of water: 1000mm

Neither flashover nor breakdown occurred.

The test was passed successfully.



5.1.9 Disconnection / Connection

Test date: 30.08.2007
Number: 5 complete operations

With each test object there was no visible damage to contact.

The test was passed successfully.

5.1.10 Partial Discharge Test

5.1.10.1 Partial Discharge Test at ambient temperature

This test was carried out as described in 4.

Test date: 05.09.2007
Voltage: $\diamond/\sqrt{2} = 27 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\diamond/\sqrt{2} = 24 \text{ kV}$ with pd reading
PD magnitude (24 kV): $< 10 \text{ pC}$

The test was passed successfully.

5.1.10.2 Partial Discharge Test at elevated temperature

This test was carried out as described in 4

Test date: 05.09.2007
Heating current: $I = 630 \text{ A}$, $t = 5 \text{ h}$
Voltage: $\diamond/\sqrt{2} = 40,5 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\diamond/\sqrt{2} = 36 \text{ kV}$ with pd reading
PD magnitude (36 kV): $< 10 \text{ pC}$

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



5.1.11 Impulse Voltage Withstand Test

This test was carried out as described in 4.

Test date: 05.09.2007

Test voltage: $\diamond = 125 \text{ kV}$

Number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.1.12 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 05.09.2007

Test voltage: $\diamond/\sqrt{2} = 30 \text{ kV}$, $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



C

(

5.2 Additional Tests

5.2.1 Screen Resistance Measurement

This test was carried out as described in 4.

Test date: 03.09. - 10.09. 2007

Resistance prior to thermal ageing < 5000 Ω

Resistance after thermal ageing < 5000 Ω

Requirement: resistance \leq 5000 Ω

The test was passed successfully.

5.2.2 Leakage Current Measurement

This test was carried out as described in 4.

Test date: 17.09.2007

Test voltage: $\hat{V}/\sqrt{2} = V_m = 24$ kV

Leakage current: $I < 0,5$ mA

Requirement: $I \leq 0,5$ mA

The test was passed successfully.

5.2.3 Screen Fault Current Initiation

This test was carried out as described in 4.

Test date: 19.09.2007

Test voltage: $\hat{V}/\sqrt{2} = V_0 = 12,0$ kV

Short-circuit current: $I = 10,8$ A

Fault current flow continuously.

The test was passed successfully.



5.2.4 Operating Force Test

This test was carried out as described in 4.

Test date: 19.09. - 20.09.2007


Temperature: - 20°C

Duration: 24h

Force: < 900 N

Requirement: $F < 900 \text{ N}$

The test was passed successfully.




6 Conclusion

The separable connector type CELLPLUX-CGS 24 kV 250 A passed all tests described in clause 2 successfully. The test object fulfilled the requirements according CENELEC HD 629.1 / S1 07/1996 and A1 11/2000, table 7, test sequence D1 and additional tests table 7, pos.19-22.

Karlsruhe, 21.09.2007



Dr.-Ing. R. Badent
Bereichsleiter HPT




Dr.-Ing. B. Höferer
stellv. Bereichsleiter HPT

ВЯРНО С
ОРИГИНАЛА



Bereich Hochspannungsprüftechnik

Institut für Elektroenergiesysteme und Hochspannungstechnik



Universität Fridericiana (TH) Karlsruhe
76128 Karlsruhe - Kaiserstraße 12

Telefon (0721) 608 2520 Telefax (0721) 69 52 24

Test Report No 2011-52/1

Type Test of

Separable Connectors Type


CELLPLUX-CGS 250A 24kV 70-150/M/EGA

Customer: Cellpack GmbH
Carl-Zeiss-Str. 20
79761 Waldshut-Tiengen

Reporter: Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer

This report includes 13 numbered pages and is only valid with the original signature.
Copying of extracts is subject to the written authorization of the test laboratory. The test results concern exclusively to the tested objects.

ВЯРНО С
ОРИГИНАЛА



1 Purpose of Test

One separable connector for $U_0 / U_n / U_m = 12 / 20 / 24$ kV was subjected to an additional test according to DIN VDE 0278-629-1:2009-07, table 7, test pos. 21.

2 Miscellaneous Data

Test object: – 1 separable connector, type straight separable connector
CGS 250A 24kV 70-150/M/EGA, $U_m = 24$ V,
Installation instruction no.: 293799/0511/1/6, Figures 2.1 –
2.6
Packing list: 293797, Figure 2.7
Type of the cable: The test object was mounted on a single-wire XLPE-cable, type NA2XS2Y
1x150 RM/25, Figure 2.8

Cable length Connector - termination: 1 m

Manufacturer: Cellpack GmbH
Carl-Zeiss-Str. 20
79761 Waldshut-Tiengen


Place of test: *Institute of Electric Energy Systems and High Voltage
Technology* – University of Karlsruhe
Kaiserstraße 12 – 76128 Karlsruhe

Testing dates: Delivery: 17.03.2011
Mounting: 17.03.2011
Test period: 13.04.2011

Atmospheric conditions: Temperature: $19^{\circ}\text{C} - 24^{\circ}\text{C}$
Air pressure: 980 - 1025 mbar
rel. humidity: 35 % – 60 %

Representatives: Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer
Mr. O. Müller





Working Instruction

Straight-Separable Connector
for single-core polymeric cables
up to 24 kV

293799/05111/1/6

Prüfgegenstand entspricht der
vorgelegten technischen Zeichnung
Chus *B. Kloss*
Unterschrift des Herstellers Unterschrift des Prüfers

CELLPACK GmbH
Electrical Products
D-79761 Walschut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com
e-mail: electrical.products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45

CELLPACK
Electrical Products

293799 CGS 250A 24kV 70-150/M/EGA

Figure 2.1: Installation Instruction.

ВЕРНО С
КОПИРОВАНО



General remarks:

- Check the range and size of the cable and the accessories.
- Check the content of the kit as per packing list.
- Thoroughly read the working instruction.

Installation must be executed by competent personnel only.
The manufacturer accepts no liability for breakdowns resulting from incorrect installation.


Straight-Separable Connector Type CGS 250A 24kV 70-150/M/EGA

Selection of cable sizes

Voltage U ₀ /U _m kV	Cross-section of the conductor (*) mm ²
6/10(12) kV	120 - 150
8,7/15(17,5) kV	95 - 150
12/20(24) kV	70 - 150

(*) Diameter over primary insulation min. 19,9 mm

Adjustment



- Clean thoroughly the cable end up to 1m.
- Adjust the cable overhanging the middle of the bushing by 200 – 500 mm and cut it off.
- Make a mark 150 mm from the centre of the bushing on to the cable sheath.

293799 CGS 250A 24kV 70-150/M/EGA

Figure 2.2: Installation Instruction



Cable with wire screen:


1a)



- Remove the cable sheath up to the mark.
- Bend back the wire of the cable screen and fix it on the cable sheath.
- Cut off the cable at the length of 130 mm.
- Prepare the cable end according to the template (see page 4) and then check the dimensions.
- Clean thoroughly insulation and conductive layer.

Cable with copper tape screen:


1b)



- Remove the cable sheath up to the mark +20 mm.
- Cut the cable according to the drawing.
- Prepare the cable end according to the template (see page 4) and then check the dimensions.
- Clean thoroughly insulation and conductive layer.


293799 CGS 250A 24kV 70-150/M/EGA

2a)




- Protect the end of the conductor with PVC tape.
- Wrap 2/3 of the length of DM1 mastic 10 mm on to the conductive layer and 20 mm on to the wire screen by stretching it 50%.
- Apply at the end of the conductive layer lubricant and filling material GM1 according to the drawing.
- Moisten the conductor insulation with lubricant and filling material GM1.

2b)



- Protect the end of the conductor with PVC tape.
- Fix a flat Cu – braid with a pressure spring RF on to the tape screen (order the earthing kit separately).
- Wrap 2/3 of the length of DM1 mastic 10 mm on to the conductive layer and 20 mm on to the copper tape screen by stretching it 50%.
- Apply at the end of the conductive layer lubricant and filling material GM1 according to the drawing.
- Moisten the conductor insulation with lubricant and filling material GM1.

Figure 2.3: Installation Instruction




293799 CGS 250A 24kV 70-150/MEGA


Figure 2.4: Installation Instruction

ВЕРНО
ОРИГИНАЛ






- Moisten the tongues of the applicator with the silicone towel.
- Insert the applicator in to the stress control element and slip in on to the cable down to sealing wrap.
- Remove the applicator by pulling out the tongues one by one.
- Adjust the stress control element in his final position by turning it slightly (see Fig. 4).



- Remove the protection from the end of the conductor.
- Install the shear-head screw according to the separate instruction.
- Clean carefully the surface of the stress control element.



293799 CGS 250A 24kV 70-150/MEGA


- Moisten the connector body and the stress control element with lubricant and filling material GM1.
- Slip on the connector body onto the end of the cable until the PIN fits into the connector body.

Prüfgegenstand entspricht der vorgelegten technischen Zeichnung
 Unterschrift des Herstellers
 Unterschrift des Prüfers


ВАРНО С
 ОРГНИНАЛАТА

МАСТРОПЕТЕ
 СОФИС
 5/6


Figure 2.5: Installation Instruction




- Wrap the remaining mastic 1/3 DM1 between the end of the connector body and the sealing area.



- Wrap the tape Nr. 2585 adhesive side inwards approx. 20 mm over the end of the connector body up to the end of the sealing area (stretch 20%).




- Moisten accurately the bushing and the connector inside with lubricant and filler GM1.
- Cut out a tongue from the applicator (air release device).
- Insert the air release device into the connector. Attach the connector straight on to the bushing.



- Fix the fastening device and holding plate according to the drawing. Tighten the wing nuts evenly.
 - Pull out the air release device and remove remaining lubricant and filler.
 - Install the earthing set to the connector body and groups.
- Proper earthing set for the connector body and groups to be carried out according to local regulations.
- Unterschrift des Herstellers

293799 CGS 250A 24kV 70-150/MEGA

Figure 2.6: Installation instruction



Packliste Packing list Liste d'emballage	293 797	Lista de carga	CELLPACK Electrical Products
--	---------	----------------	--

MEDIUM VOLTAGE	CELLPLUX
-----------------------	-----------------

Gerader Steckanschluss Straight-Separable Connector Connecteur Séparable à fiche Terminal enchufable recto	Typ	CGS 250A 24kV 70-150/M/EGA	
	$U_o/U(U_m)$	6/10(12)kV	120 - 150 mm ²
		8,7/15(17,5)kV	95 - 150 mm ²
		12/20(24)kV	70 - 150 mm ²
		Isolation min. Ø:19.9mm	
		Version: 01	

Pos		St. Cont.	Dimension		
1		3	CGS 250A	Steckanschluß Plug-in connector	Connecteur séparable Cuerpo terminal
2		3	FSEM 19	Feldsteuerelement Field control element	Contrôleur de champ Elemento de control de campo
3		3	GM1	Gleit- und Füllmittel Lubricant and filler	Lubrifiant Lubrificante
4		3	AH 2	Autschiebehilfe Applicator	Dispositif d'enfilage Aplicador
5		3	CGS 250A Set	Befestigungs-Set Connecting set	Cintre de fixation Elemento de fijación
6		3	CGS C70-150	Schraubkabelschuh Screw cable lug	Cosse de câble Terminal
7		3	EGA-Set	Erdungs-Set Earthing-kit	Kit de mise à la terre Conjuntos de puesta a tierra
8		3	DM 1 25x150 mm	Dichtband grau Sealing tape grey	Ruban d'étanchéité gris Cinta de estanqueidad gris
9		3	2585 50x300 mm	Polsterband Rubber mastic tape	Ruban mastic Cinta mastic
10		1	N° 028 5 m	Isolierband PVC tape	Ruban isolant Cinta aislante
11		3	Paar	Handschuhe Gloves	Gants Guante
12		3	ST	Tuch mit Silikonöl Tissue with silicon oil	Tissu siliconé Toalla siliconada
13		6	RT	Reinigungstuch Cleaning tissue	Tissu de nettoyage Toalla de limpieza
14		4	MA de, en, fr, es	Montageanleitung Working Instructions	Instruccions de montaje Instrucciones de montaje

Prüfgegenstand entspricht der
vorgelegten technischen Zeichnung
B. K. J. J.
Unterschrift des Herstellers

Figure 2.7: Packing list

ВЕРНО С
ОРИГИНАЛ

ЭЛЕКТРО
COD
004

Annex A
(informative)

Identification of test cable
(see 5.1)

Rated voltage $U_d/U (U_m)$: 12/20 (24) kV

Construction: 1-core 3-core Individually screened
 Overall screen

Conductors: Al Cu
 Stranded Solid
 Circular Shaped
 120 mm² 150 mm² 185 mm²

Other cross-section: mm²

Insulation: XLPE
 EPR HEPR

Insulation screen: Bonded Strippable

Metallic screen: Wire Tape Extruded

Armour: Wire Tape

Oversheath: PVC PE (state type)

Water blocking, if any: Within conductor Under oversheath

Diameters:
• Conductor 14,2 mm
• Insulation 25,1 mm
• Insulation screen 27,1 mm
• Oversheath 34,1 mm


Cable marking: 2009 + PROTOHEN X NA2XS2Y 1x150
R11/25 20kV <VDE> 0276


Figure 2.8: Cable data sheet

Tests: Test volume, chronological order and requirements conform to DIN VDE 0278-629-1:2009-07, table 7, additional test pos. 21.

Additional Test:
Pos. 21. *Capacitive test point performance*
 $C_{tc} > 1,0 \text{ pF}$
 $C_{te} / C_{tc} \leq 12$

3 Mounting

Final assembling of the separable connector was executed in the high-voltage laboratory of the IEH.

ВЯРНО С
ОРИГИНАЛА



4 Test Setup

Capacitive test point performance

The test was performed with a different bridge. For this test the capacity of test point to the cable conductor C_{tc} and the capacity of test point to earth C_{te} were measured at ambient temperature.

5 Results

Capacitive test point performance

This test was carried out as described in 4.

Test date: 13.04.2011


Capacitance of test point to cable conductor $C_{tc} > 1,0\text{pF}$

Requirement : $C_{tc} > 1,0\text{pF}$

Ratio of capacitance of test point to earth C_{te} and capacitance of test point to cable conductor: $C_{tc} : C_{te} / C_{tc} < 12$

Requirement: $C_{tc} : C_{te} / C_{tc} \leq 12$

ВАРНО С
ОРИГИНАЛА




C

C


6 Conclusion

The separable connector type CELLPLUX CGS 250A 24kV 70-150/M/EGA passed all tests described in clause 2 successfully. The test object fulfilled the requirements according DIN VDE 0278-629-1:2009-07, additional test table 7, pos.21.

Karlsruhe, 19.05.2011




Dr.-Ing. R. Badent
Head of Department
„High Voltage Dielectric Testing“



Dr.-Ing. B. Hoferer
Vice-Head of Department
„High Voltage Dielectric Testing“

ВЯРНО С
ОРИГИНАЛА





Universität Fridericiana (TH) Karlsruhe
76128 Karlsruhe - Kaiserstraße 12
Telefon (0721) 608 2520 Telefax (0721) 69 52 24

Test Report No 2005-101

Type Test of
Separable Connectors


Type CELLPLUX-CWS 250 24 kV 250 A

Customer: Cellpack GmbH
Carl-Zeiss-Str. 20
79761 Waldshut-Tiengen

Reporter: Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer

ВЯРНО С
ОРИГИНАЛА

This report includes 24 numbered pages and is only valid with the original signature. Copying of extracts is subject to the written authorization of the test laboratory. The test results concern exclusively to the tested objects.



1 Purpose of Test

4 resp. 3 resp. 1 separable connectors for $V_0 / V_n / V_m = 12 / 20 / 24$ kV were subjected to a type test according to CENELEC HD 629.1 S2 02/2006 table 7 test sequence D1 resp. D2 resp. D3. The 3 separable connectors for $V_0 / V_n / V_m = 12 / 20 / 24$ kV were subjected to additional tests according to CENELEC HD 629.1 S2 02/2006, table 7 test pos. 17-20.

2 Miscellaneous Data

Test object: – 11 separable connectors type CELLPLUX-CWS 250 24 kV 250 A
 $V_m = 24$ kV, Figure 2.1
Type of the cable: The test object was mounted on a single-wire XLPE-cable,
type: NA2X(F)2Y 1x70RM/25 12/20kV
Cable length Connector - sealing end: 3 m

Place of test: *Institute of Electric Energy Systems and High Voltage Technology* – University of Karlsruhe
Kaiserstraße 12 – 76128 Karlsruhe

Testing dates: Delivery: 06.04.2006
Mounting: 06.04.2006
Test period: 10.04. - 28.09.2006


Atmospheric conditions: Temperature: $19^{\circ}\text{C} - 24^{\circ}\text{C}$
Air pressure: 980 - 1025 mbar
rel. humidity: 35 % – 60 %

Representatives: Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer
Mr. O. Müller

ВЯРНО С
ОРИГИНАЛА



CELLPACK – CWS 250 24kV 250 A



CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com
e-mail: electrical.products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45

CELLPACK
Electrical Products

ВЪРНО С
ОРИГИНАЛА




Figure 2.1: Separable connector.

Tests: Test volume, chronological order and requirements conform to CENELEC HD 629.1 S2 02/2006 test sequence D1, D2 and D3 , table 7 and additional test pos. 17 - 20.

The PD-test was performed at $2 V_0$. The tests were carried out in accordance with the test methods described in IEC 61442 03/2005.

Test sequence D1:

- Pos. 1. *DC voltage withstand test*
 $V = 6 V_0 = -72 \text{ kV}$; $t = 15 \text{ min}$
- Pos. 2. *AC voltage withstand test*
 $\hat{V}/\sqrt{2} = 4,5 V_0 = 54 \text{ kV}$; $t = 5 \text{ min}$
- Pos. 3. *Partial discharge test*
 $\hat{V}/\sqrt{2} = 2,0 V_0 = 24 \text{ kV}$; $PD \leq 10 \text{ pC}$
- Pos. 4. *Impulse voltage withstand test, at elevated temperature*
Impulse voltage
 $\hat{V} = 125 \text{ kV}$; positive and negative polarity each 10 impulses
- Pos. 5. *Electrical heat cycling in air*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{V}/\sqrt{2} = 30 \text{ kV}$
number of cycles: 63
- Pos. 6. *Electrical heat cycling in water*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{V}/\sqrt{2} = 30 \text{ kV}$
number of cycles: 63
- Pos. 10. *Disconnection / Connection*
5 complete operations,
no visible damage to contact
- Pos. 11. *Partial discharge test at ambient temperature and elevated temperature*
 $\hat{V}/\sqrt{2} = 2,0 V_0 = 24 \text{ kV}$; $PD \leq 10 \text{ pC}$
- Pos. 12. *Impulse voltage withstand test, lightning impulse voltage*
 $\hat{V} = 125 \text{ kV}$; positive and negative polarity each 10 impulses
- Pos. 13. *AC voltage withstand test*
 $\hat{V}/\sqrt{2} = 2,5 V_0 = 30 \text{ kV}$; $t = 15 \text{ min}$



Test sequence D2:

- Pos. 1. *DC voltage withstand test*
 $V = 6 V_0 = -72 \text{ kV}$; $t = 15 \text{ min}$
- Pos. 2. *AC voltage withstand test*
 $\hat{V}/\sqrt{2} = 4,5 V_0 = 54 \text{ kV}$; $t = 5 \text{ min}$
- Pos. 8. *Short circuit test, conductor*
 $\theta_{SC} = 250^\circ\text{C}$; 2 stresses
- Pos. 10 *Disconnection / Connection*
5 complete operations,
no visible damage to contact
- Pos. 12. *Impulse voltage withstand test,*
lightning impulse voltage
 $\hat{V} = 125 \text{ kV}$; positive and negative polarity each 10 impulses
- Pos. 13. *AC voltage withstand test*
 $\hat{V}/\sqrt{2} = 2,5 V_0 = 30 \text{ kV}$; $t = 15 \text{ min}$

Test sequence D3:

- Pos. 14. *Operating eye test*
Axial force 1300N; $t = 1 \text{ min}$
Torque 14 Nm
- Pos. 15 *Partial discharge test at ambient temperature*
 $\hat{V}/\sqrt{2} = 2,0 V_0 = 24 \text{ kV}$; $\text{PD} \leq 10 \text{ pC}$

Additional Tests:

- Pos. 17: *Screen resistance measurement*
 $R \leq 5000 \Omega$
- Pos. 18. *Leakage current measurement*
 $\hat{V}/\sqrt{2} = 2,5 V_m = 24 \text{ kV}$
 $I \leq 0,5 \text{ mA}$
- Pos. 19 *Screen fault current initiation*
Fault current to flow continuously
- Pos. 20 *Operating force test*
 $F \leq 900 \text{ N}$


ВАРНО С
ОРИГИНАЛА



3 Mounting

Final assembling of the separable connector was executed in the high-voltage laboratory of the IEH

ВАРНО С
ОРИГИНАЛА



4 Test Setups

4.1 DC Voltage Withstand Test

The DC-voltage was generated according to Figure 4.1. The voltage measurement was carried out with an ohmic-capacitive divider (ratio 2000:1). The measurement uncertainty was 3%.




Figure 4.1: Scheme of DC voltage test circuit.

$R_H = 3,6 \text{ k}\Omega$, $R_{H1} = 360 \text{ M}\Omega$, $C_H = 180 \text{ pF}$, ratio 2.000:1, PVM: Peak Voltmeter, TO: Test object, measurement uncertainty 3%

4.2 AC Voltage Withstand Test

The test voltage was generated by an 60-kVA transformer. The voltage measurement was carried out with a capacitive divider ($C_H = 180 \text{ pF}$; ratio = 2.000) and a peak voltmeter calibration $\hat{V}/\sqrt{2}$.





Figure 4.2: Scheme of AC test circuit

T_1 : transformer 400V / 200000V ; 60 kVA ; $v_K = 3,5 \%$; 50 Hz
 C_H : 180 pF ; ratio 2000:1 ; PVM : Peak-Voltmeter
 TO: Test object; measurement uncertainty 3 %

ВАРТО С
ОРИГИНАЛА



4.3 Partial-Discharge Test

The PD-measurement was performed with an analog bridge according to *Kreuger*, Figure 4.3. External PDs producing common mode signals at the detector are rejected by the differential amplifier. Internal PDs represent differential mode signals and are amplified. The background noise level at 24 kV_{rms} was 0,8 pC.




Figure 4.3: Scheme of PD test circuit
 TO1: Test object 1
 TO2: Test object 2

For balancing the bridge a calibrating impulse with $q_A = 10.000 \text{ pC}$ is applied between the terminals A (high-voltage) and C (ground) and the amplifier output is minimized. A pulse between the terminals A and C corresponds to an external PD. For the calibration a PD pulse, $q_A = 10 \text{ pC}$, is applied between A and B. Subsequently, the amplifier output of the PD measuring unit is adapted to the applied pulse.

Starting from zero the AC-voltage was steadily raised up to 27,0 kV and kept constant for 60 s, then slowly reduced to 24 kV including pd-reading.

ВАРИАНТ
 ОРИГИНАЛ

ВЕРИФИКАЦИЯ
 СОФИА
 БГА

4.4 Lightning Impulse Voltage Withstand Test

For impulse testing was used a two-stage Marx generator (Haefely) with a maximum cumulative charging voltage of $V = 400$ kV and a maximum impulse energy of $E_{\max} = 20$ kW. At this test, the capacity of the energy storage capacitor was $C_S = 0.25$ μ F. The crest value of the impulse voltage was measured by a damped capacitive divider and a subsequent impulse peak voltmeter (Haefely). The front time and the time to half value were evaluated from the oscillographs.




Figure 4.4: Scheme of impulse voltage test circuit

C_H : 1200 pF ; $R_H = 70$ Ω ; ratio: 3225;

IPV: impulse-peak-voltmeter (Haefely) – measurement uncertainty 3%


Oscilloscope: Tektronix TDS 3044B – measurement uncertainty 2%

The waveform parameters were determined at reduced charging voltage.

Positive impulse: $T_1 = 1.80$ μ s $T_2 = 50.0$ μ s

Negative impulse: $T_1 = 1.73$ μ s $T_2 = 50.4$ μ s

ВЯРНО С
ОРИГИНАЛА



4.5 Electrical Heat Cycling in Air

The test objects must be heated by a current which provides the permitted service temperature of the tested cable plus 5 K - 10 K, that means 95°C - 100°C, for XLPE-cable. The heating current I was determined with a dummy cable. The same cable as used for the test, with a length of 3 m, was drilled with a diameter of 0.8 mm up to the conductor. The temperature was measured with a thermocouple NiCr-Ni. The measurement uncertainty was ± 2 K.

Figure 4.5 illustrates the temperature rise at the conductor with a heating current of $I = 290$ A and the temperature of sheath (dummy and test object). Current inception was accomplished by a transformer ($V_1 = 400$ V; $V_2 = 8$ V) which used the cable as secondary winding. The current was measured by an current transformer, 1500/5, and a digital multimeter. The measurement uncertainty was 1%.

ВЯРНО С
ОРИГИНАЛА



C

C




Figure 4.5: Temperature at conductor and sheaths with $I = 290 \text{ A}$

ВЕРНО С
ОРИГИНАЛА



4.6 Electrical Heat Cycling in Water

The test object were placed in a tank and filled with water. The height of the water was 1000 mm above the test object. The conductivity of the water at 20°C was 63 mS/m.

4.7 Thermal Short Circuit Current Test

According IEC 986 for Al with $q = 70 \text{ mm}^2$ $I^2t = 68,25 \cdot 10^6 \text{ A}^2\text{s}$ with $\theta_{sc} = 250^\circ\text{C}$ and $\theta_l = 25^\circ\text{C}$. That means $I_K(1\text{s}) = 8,26 \text{ kA}$. The short-circuit during test was $I_K = 6,89 \text{ kA}$, resulting in a short-circuit duration of $t_K = 1,48 \text{ s}$. The test object was tested with two thermal short-circuit currents. Between two tests the specimen cooled down to ambient temperature. The current was measured with a $10 \mu\Omega$ -shunt connected to a digital storage oscilloscope (Tektronix 2430 A). The measurement uncertainty was 2%.




Figure 4.7.1: Scheme of short-circuit test.

ВЕРНО С
ОПТИКАМИ






Figure 4.7.2: Short circuit current
Hor: 200 ms/Div; Vert: 10 kA/DIV

4.8 Operating Eye Test

Prior to the test the separable Connector was fixed to the connecting part. The tractive force was gradually applied to the operating eye along the axis of the bushing. The force was steadily raised up to 1300 N and kept constant for 60 s.

Thereafter a torque of 14 Nm was gradually applied to the test object, at first clockwise then counter clockwise.

4.9 Screen Resistance Measurement

Prior to the test silver-painted electrodes were installed. The screen resistance of the plug-in termination was measured at ambient temperature between the two electrodes. Then the test object was subjected to thermal ageing in an air oven at $(120 \pm 2)^\circ\text{C}$ for 168 h. After thermal ageing the screen resistance at ambient temperature was measured again.

ВЯРНО С
КОМПЬЮТЕРНО
СЪСТАВИ



4.10 Leakage Current Measurement

Prior to the test a metal foil of 25 cm² was fixed without any air gap to the outer screen of the plug-in termination. The metal foil was placed at the end of the plug-in termination opposite to the earth bend and earthed through a milliamperemeter and a resistance of 2000 ohms. The leakage current was measured with a test voltage of V_m applied between conductor and earth.

4.11 Screen Fault Current Initiation

Prior to the test a faulting wire of approx. 0.2 mm was placed in the area of the hexagonal connecting bolt through a drilled hole. The wire was connected with the inner and outer screens and did not protrude beyond the outer screen surface.

The test voltage was generated by a 630 kVA-transformer. A capacitor bank was connected in series to the test object, resulting in a short-circuit current of 10A, Figure 4.11. The sequence of the test was as follows:

1. voltage switched on for 1 s
2. voltage switched off for 2 min
3. voltage switched on for 2 min
4. voltage switched off for 2 min
5. voltage switched on for 1 min
6. voltage switched off




Figure 4.11: Scheme of AC test circuit
 T_1 : Transformer 400V/20.000V; 630 kVA
 C_H : 300 pF; C_L : 300 nF; PVM; peak-voltmeter
 C : 2,66 μ F; W : current transformer; TO: test object


ВАРНО С
ОРИГИНАЛА



4.12 Operation Force Test

The test object was placed in a climate chamber and conditioned at $(-20 \pm 2)^\circ\text{C}$ for at least 12h. The test was carried out within 5 min after removal from the climate chamber. The plug-in termination was clamped by means of a tool which allows operation along the axis of the test object. The force was gradually applied to the plug-in termination and measured by means of a tractive dynamometer.

ВЯРНО С
ОРИГИНАЛА



5 Results

5.1 Test Sequence D1

5.1.1 DC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 10.04.2006

Test voltage: $V = - 72 \text{ kV}$; $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the DC voltage withstand test.

The test was passed successfully.

5.1.2 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 10.04.2006

Test voltage: $\hat{U}/\sqrt{2} = 54 \text{ kV}$, $t = 5 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

5.1.3 Partial Discharge Test


This test was carried out as described in 4.

Test date: 10.04.2006

Voltage: $\hat{U}/\sqrt{2} = 27 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\hat{U}/\sqrt{2} = 24 \text{ kV}$ with pd reading

PD magnitude (24 kV): $< 10 \text{ pC}$

The test was passed successfully.



5.1.4 Impulse Voltage Withstand Test at elevated Temperature

This test was carried out as described in 4

Test date: 11.04.2006
Test voltage: $\hat{U} = 125 \text{ kV}$
Heating current: $I = 290 \text{ A}; t = 5 \text{ h}$
Number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.1.5 Electrical Heat Cycling in Air

This test was carried out as described in 4.

Test date: 24.04. - 15.05.20026
Test voltage: $\hat{U}/\sqrt{2} = 30 \text{ kV}$
Heating current: $I = 290 \text{ A}$
Cycle: 5 h heating; 3 h cooling
Number of cycles: 63

Neither flashover nor breakdown occurred.

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



5.1.6 Electrical Heat Cycling in Water

This test was carried out as described in 4.

Test date: 18.05.-10.06.2006
Conductivity: 63 mS/m
Test voltage: $\hat{U}/\sqrt{2} = 30 \text{ kV}$
Heating current: $I = 290 \text{ A}$
Cycle: 5 h heating; 3 h cooling
Number of cycles: 63
Heat of water: 1000mm

Neither flashover nor breakdown occurred.

The test was passed successfully.

5.1.7 Disconnection / Connection

Test date: 16.06.2006
Number: 5 complete operations.

With each test object there was no visible damage to contact.

The test was passed successfully.


5.1.8 Partial Discharge Test

5.1.8.1 Partial Discharge Test at ambient temperature

This test was carried out as described in 4.

Test date: 19.06.2006
Voltage: $\hat{U}/\sqrt{2} = 27 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\hat{U}/\sqrt{2} = 24 \text{ kV}$ with pd reading
PD magnitude (24 kV): $< 10 \text{ pC}$

The test was passed successfully.



5.1.8.2 Partial Discharge Test at elevated temperature

This test was carried out as described in 4

Test date: 19.06.2006
Heating current: $I = 290 \text{ A}$, $t = 5 \text{ h}$
Voltage: $U/\sqrt{2} = 27 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $U/\sqrt{2} = 24 \text{ kV}$ with pd reading
PD magnitude (24 kV): $< 10 \text{ pC}$

The test was passed successfully.

5.1.9 Impulse Voltage Withstand Test

This test was carried out as described in 4.

Test date: 19.06.2006
Test voltage: $U = 125 \text{ kV}$
Number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.1.10 AC Voltage Withstand Test


This test was carried out as described in 4.

Test date: 19.06.2006
Test voltage: $U/\sqrt{2} = 30 \text{ kV}$, $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



5.2 Test Sequence D2

5.2.1 DC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 01.08.2006

Test voltage: $V = -72 \text{ kV}$; $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the DC voltage withstand test.

The test was passed successfully.

5.2.2 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 01.08.2006

Test voltage: $\hat{V}/\sqrt{2} = 54 \text{ kV}$, $t = 5 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

5.2.3 Thermal Short Circuit, Conductor

This test was carried out as described in 4.

Test date: 22.08.2006


current: $I_K = 6,89 \text{ kA}$

$t_K = 1,48 \text{ s}$

number of stresses: 2

time between stresses: 2h

The test was passed successfully.



5.2.4 Disconnection / Connection

Test date: 25.08.2006

Number: 5 complete operations

With each test object there were no visible damage to contact.

The test was passed successfully.

5.2.5 Impulse Voltage Withstand Test

This test was carried out as described in 4.

Test date: 27.08.2006

Test voltage $\hat{U} = 125 \text{ kV}$

- number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.2.6 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 27.08.2006

Test voltage: $\hat{U}/\sqrt{2} = 30 \text{ kV}$, $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



5.3 Test Sequence D3

5.3.1 Operating Eye Test

This test was carried out as described in 4.

Test date: 25.09.2006
Force: 1300 N ; t = 1 min
Torque: 14 Nm

The test was passed successfully.

5.3.2 Partial Discharge Test

This test was carried out as described in 4.

Test date: 25.09.2006
Voltage: $\varnothing/\sqrt{2} = 27$ kV, t = 60s thereafter
 $\varnothing/\sqrt{2} = 24$ kV with pd-reading
PD magnitude (24 kV): < 10 pC

The test was passed successfully.



5.4 Additional Tests

5.4.1 Screen Resistance Measurement

This test was carried out as described in 4.

Test date: 21.09. - 28.09.2006
Resistance prior to thermal ageing < 5000 Ω
Resistance after thermal ageing < 5000 Ω
Requirement: resistance \leq 5000 Ω

The test was passed successfully.



5.4.2 Leakage Current Measurement

This test was carried out as described in 4.

Test date: 26.09.2006

Test voltage: $\hat{V}/\sqrt{2} = V_m = 24 \text{ kV}$

Leakage current: $I < 0,5 \text{ mA}$

Requirement: $I \leq 0,5 \text{ mA}$

The test was passed successfully.

5.4.3 Screen Fault Current Initiation

This test was carried out as described in 4.

Test date: 26.09.2006

Test voltage: $\hat{V}/\sqrt{2} = V_0 = 12,0 \text{ kV}$

Short-circuit current: $I = 10,6 \text{ A}$

Fault current flow continuously.

The test was passed successfully.

5.4.4 Operating Force Test

This test was carried out as described in 4.

Test date: 21.09. - 22.09.2006

Temperature: $- 20^\circ\text{C}$

Duration: 24h

Force: $< 900 \text{ N}$

Requirement: $F < 900 \text{ N}$

The test was passed successfully.

ВАРНО С
ОРИГИНАЛА




C

C


6 Conclusion

The separable connector type CELLPLUX-CWS 250.24 kV 250 A passed all tests described in clause 2 successfully. The test object fulfilled the requirements according CENELEC HD 629.1 / S2 02/2006, Table 7, test sequences D1, D2 and D3 and additional tests table 7, pos.17-20.

Karlsruhe, 28.09.2006





Dr.-Ing. R. Badent
Bereichsleiter HPT



Dr.-Ing. B. Hoferer
stellv. Bereichsleiter HPT

ВАРНО С
ОРИГИНАЛА







Test Report No 2007-74

Test of Screen Fault Current Initiation of
Separable Connectors
Type CELLPLUX-CWS 250 24 kV 250 A

Customer: Cellpack GmbH
Carl-Zeiss-Str. 20
79761 Waldshut-Tiengen

Reporter: Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer

This report includes 7 numbered pages and is only valid with the original signature.
Copying of extracts is subject to the written authorization of the test laboratory. The test
results concern exclusively to the tested objects.



A handwritten signature in black ink, appearing to be "R. Badent".

1 Purpose of Test

1 separable connector for $V_0 / V_n / V_m = 12 / 20 / 24$ kV was subjected to a test of screen fault current initiation for reduced system voltage of $V_0 / V_n / V_m = 6 / 10 / 12$ kV according to CENELEC HD 629.1 S2 02/2006 table 7.

2 Miscellaneous Data

Test object: – 1 separable connectors type
 CELLPLUX-CWS 250 24 kV 250 A, Figure 2.1
Type of the cable: The test object was mounted on a
 single-wire XLPE-cable,
 type: NA2X(F)2Y 1x70RM/25 12/20kV


Cable length Connector - sealing end: 1 m

Place of test: *Institute of Electric Energy Systems and High Voltage
 Technology – University of Karlsruhe
 Kaiserstraße 12 – 76128 Karlsruhe*


Testing dates: Delivery: 19.04.2007
 Mounting: 19.04.2007
 Test period: 19.04.2007

Atmospheric
conditions: Temperature: 20°C
 Air pressure: 1010 mbar
 rel. humidity: 40 %

Representatives: Dr.-Ing. R. Badent
 Dr.-Ing. B. Hoferer
 Mr. O. Müller



CELLPAX – CWS 250 24kV 250 A



CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com
e-mail: electrical.products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45

ВЪРНО С
ОРИГИНАЛА

CELLPACK
Electrical Products

ВЕРНО С
ОРИГИНАЛА

СОФИЯ

ГОД

Figure 2.1: Separable connector.

Test: Test volume and requirements conform to CENELEC HD 629.1 S2 02/2006, table 7 and additional test pos. 19.

The test was carried out in accordance with the test methods described in IEC 61442 03/2005.

Pos. 19 *Screen fault current initiation with reduced voltage $V_0/V_n/V_m = 6/10/12$ kV*
Fault current to flow continuously

3 Mounting

Final assembling of the separable connector was executed in the high-voltage laboratory of the IEH

ВЯРНО С
ОРИГИНАЛА



[Handwritten signature]

4 Test Setup

Screen Fault Current Initiation

Prior to the test a faulting wire of approx. 0.2 mm was placed in the area of the hexagonal connecting bolt through a drilled hole. The wire was connected with the inner and outer screens and did not protrude beyond the outer screen surface.

The test voltage was generated by a 630 kVA-transformer. A resistor was connected in series to the test object, resulting in a short-circuit current of 10A, Figure 4.1. The sequence of the test was as follows:

1. voltage switched on for 1 s
2. voltage switched off for 2 min
3. voltage switched on for 2 min
4. voltage switched off for 2 min
5. voltage switched on for 1 min
6. voltage switched off




Figure 4.1: Scheme of AC test circuit
 T₁: Transformer 400V/20.000V; 630 kVA
 C_H: 300 pF; C_L: 300 nF; PVM; peak-voltmeter
 R: 600 Ω; W: current transformer; TO: test object.

ВАРНО С
ОРИГИНАЛА



[Handwritten signature]

5 Results

Screen Fault Current Initiation

This test was carried out as described in 4.

Test date: 19.04.2007

Test voltage: $\hat{V}/\sqrt{2} = V_0 = 6.0 \text{ kV}$

Short-circuit current: $I = 10,0 \text{ A}$

Fault current flow continuously.

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



6 Conclusion

The separable connector type CELLPLUX-CWS 250 24 kV 250 A passed all tests described in clause 2 successfully. The test object fulfilled the requirements according CENELEC HD 629.1 / S2 02/2006, additional test table 7, pos.19 at reduced voltage $V_0 / V_n / V_m = 6 / 10 / 12$ kV.

Karlsruhe, 24.04.2007



Dr.-Ing. R. Badent
Bereichsleiter HPT




Dr.-Ing. B. Hoferer
stellv. Bereichsleiter HPT

ВЕРНО С
ОРИГИНАЛА



Bereich Hochspannungsprüftechnik
Institut für Elektroenergiesysteme und Hochspannungstechnik



Universität Fridericiana (TH) Karlsruhe
76128 Karlsruhe - Kaiserstraße 12
Telefon (0721) 608 2520 Telefax (0721) 69 52 24


Test Report No 2011-52/1

Type Test of
Separable Connectors Type
CELLPLUX-CWS 250A 24kV 70-150/M/EGA

Customer: Cellpack GmbH
 Carl-Zeiss-Str. 20
 79761 Waldshut-Tiengen

Reporter: Dr.-Ing. R. Badent
 Dr.-Ing. B. Hoferer

This report includes 13 numbered pages and is only valid with the original signature.
Copying of extracts is subject to the written authorization of the test laboratory. The test results concern exclusively to the tested objects.



A handwritten signature in black ink.

1 Purpose of Test

One separable connector for $U_0 / U_n / U_m = 12 / 20 / 24$ kV was subjected to an additional test according to DIN VDE 0278-629-1:2009-07, table 7, test pos. 21.

2 Miscellaneous Data

Test object: – 1 separable connector, type elbow separable connector
CWS 250A 24kV 70-150/M/EGA, $U_m = 24$ V,
Installation instruction no.: 293795/0511/1/6, Figures 2.1 –
2.6

Packing list: 293792, Figure 2.7

Type of the cable: The test object was mounted on a single-wire XLPE-cable, type NA2XS2Y
1x150 RM/25, Figure 2.8

Cable length Connector - termination: 1 m

Manufacturer: Cellpack GmbH
Carl-Zeiss-Str. 20
79761 Waldshut-Tiengen


Place of test: *Institute of Electric Energy Systems and High Voltage
Technology – University of Karlsruhe
Kaiserstraße 12 – 76128 Karlsruhe*

Testing dates: Delivery: 17.03.2011
Mounting: 17.03.2011
Test period: 13.04.2011

Atmospheric conditions: Temperature: $19^{\circ}\text{C} - 24^{\circ}\text{C}$
Air pressure: 980 - 1025 mbar
rel. humidity: 35 % – 60 %

Representatives: Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer
Mr. O. Müller





Working Instruction

Elbow Separable Connector
for single-core polymeric cables
up to 24 kV

293795/0511/1/6

Prüfgegenstand entspricht der
vorgelegten technischen Zeichnung
Amby
Unterschrift des Herstellers
B. Nojed
Unterschrift des Prüfers

CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com
e-mail: electrical.products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45

CELLPACK
Electrical Products

293795 CWS 250A 24kV 70-150/M/EGA




Figure 2.1: Installation Instruction.

ВАРНО С
ОРЪЖИНАТА
[Signature]

General remarks:

- Check the range and size of the cable and the accessories.
- Check the content of the kit as per packing list.
- Thoroughly read the working instruction.

Installation must be executed by competent personnel only.
The manufacturer accepts no liability for breakdowns resulting from incorrect installation.


Elbow Separable Connector Type CWS 250A 24kV 70-150/M/EGA

Selection of cable sizes

Voltage U ₀ /U(U _m) kV	Cross-section of the conductor (*) mm ²
6/10(12) kV	120 - 150
8,7/15(17,5) kV	95 - 150
12/20(24) kV	70 - 150

(*) Diameter over primary insulation min. 19,9 mm


Adjustment



- Clean thoroughly the cable end up to 1m.
- Adjust the cable overhanging the middle of the bushing by 200 – 500 mm and cut it off.
- Make a mark 150 mm from the centre of the bushing on to the cable sheath.


293795 CWS 250A 24kV 70-150/M/EGA

Figure 2.2: Installation Instruction



Cable with wire screen:


1a)



- Remove the cable sheath up to the mark.
- Bend back the wire of the cable screen and fix it on the cable sheath.
- Cut off the cable at the length of 130 mm.
- Prepare the cable end according to the template (see page 4) and then check the dimensions.
- Clean thoroughly insulation and conductive layer.

Cable with copper tape screen:


1b)



- Remove the cable sheath up to the mark +20 mm.
- Cut the cable according to the drawing.
- Prepare the cable end according to the template (see page 4) and then check the dimensions.
- Clean thoroughly insulation and conductive layer.


293795 CWS 250A 24kV 70-150/MEGA

2a)



- Protect the end of the conductor with PVC tape.
- Wrap 2/3 of the length of DM1 mastic 10 mm on to the conductive layer and 20 mm on to the wire screen by stretching it 50%.
- Apply at the end of the conductive layer lubricant and filling material GM1 according to the drawing.
- Moisten the conductor insulation with lubricant and filling material GM1.

2b)



- Protect the end of the conductor with PVC tape.
- Fix a flat Cu – braid with a pressure spring RF on to the tape screen (order the earthing kit separately).
- Wrap 2/3 of the length of DM1 mastic 10 mm on to the conductive layer and 20 mm on to the copper tape screen by stretching it 50%.
- Apply at the end of the conductive layer lubricant and filling material GM1 according to the drawing.
- Moisten the conductor insulation with lubricant and filling material GM1.


3/6
ВЕРНО С
ОРИГИНАЛА

Figure 2.3: Installation Instruction



C

C



293795 CWS 250A 24kV 70-150/M/EGA


Prüfgegenstand entspricht der vorgelegten technischen Zeichnung
Андрей В. М. [Signature]
 Unterschrift: In. Prüfer
 4/8

ВЯРНО С
 ОРГИНИАДА

ЭЛЕКТРОТЕХ
 СОФИЯ
 00А

Figure 2.4: Installation Instruction

3)




- Moisten the tongues of the applicator with the silicone towel.
- Insert the applicator in to the stress control element and slip in on to the cable down to sealing wrap.
- Remove the applicator by pulling out the tongues one by one.
- Adjust the stress control element in his final position by turning it slightly (see Fig. 4).

4)



- Remove the protection from the end of the conductor.
- Install the shear-head screw according to the separate instruction. Please note that the tapped hole in the ear of the lug is in line with the bushing.
- Clean carefully the surface of the stress control element.

5)



- Moisten the connector body and the stress control element with lubricant and filling material GM1.
- Slip on the connector body on to the end of the cable and adjust it until the tapped hole in the ear of the lug is centred inside the connector body (see Fig. 6).

293795 CWS 250A 24kV 70-150/MEGA


Prüfgegenstand entspricht der vorgelegten technischen Zeichnung
 Unterschrift der Hersteller: *B. Moe*
 Unterschrift des Prüfer: *[Signature]*

5/8
 ВАРНО С
 ОПИШКАТА

ЕЛЕКТРОТЕХНИЧЕСКОЕ
 СОЮЗНОЕ
 ПРАВИТЕЛЬСТВО
 СССР


Figure 2.5: Installation Instruction

6)




- Screw in the contact pin into the cable lug with an allen key and tighten it manually.
- Wrap the remaining mastic 1/3 DM1 between the end of the connector body and the sealing area.

7)



8)



- Wrap the tape Nr. 2585 adhesive side inwards approx. 20 mm over the end of the connector body up to the end of the sealing area (stretch 20%).
- Moisten accurately the bushing and the connector inside with lubricant and filler GM1.
- Cut out a tongue from the applicator (air release device).
- Insert the air release device into the connector. Attach the connector straight on to the bushing.


- Fix the fastening device and tighten the nut evenly.
- Pull out the air release device and remove remaining lubricant and filler.
- Install the earthing-set to the connector body and ground it.
- Further earthing measurements to be carried out according to local regulations.

293795 CWS 250A 24kV 70-150/M/EGA

Prüfungsvorgang
 vorgelegten technischen Zeichnung
 Unterschrift des Herstellers
 Unterschrift des Prüfers

ВЯНО С
 ОРИГИНАЛА

Figure 2.6: Installation instruction



Packliste	293 792	Lista de carga	CELLPACK Electrical Products
Packing list			
Liste d'emballage			

MEDIUM VOLTAGE	CELLPLUX
-----------------------	-----------------

Winkel-Steckanschluss	Typ	CWS 250A 24kV 70-150/MEGA	
Elbow Separable Connector	$U_n/U(U_m)$	6/10(12)kV	120 - 150 mm ²
Connecteur Séparable Equerre		8,7/15(17,5)kV	95 - 150 mm ²
Terminal Enchufable Acodado		12/20(24)kV	70 - 150 mm ²
		Isolation min. Ø: 19,9 mm	
		Version: 01	

Pos		St. Cont.	Dimension		
1		3	CWS 250A	Steckanschluß Plug-in connector	Connecteur séparable Cuerpo terminal
2		3	FSEM 19	Feldsteuerelement Field control element	Contrôleur de champ Elemento de control de campo
3		3	GM1	Gleit- und Füllmittel Lubricant and filler	Lubrifiant Lubrificante
4		3	AH 2	Aufschiebehülse Applicator	Dispositif d'application Aplicador
5		3	CWS 250A Set	Befestigungs-Set Connecting set	Cintre de fixation Elemento de fijación
6		3	CWS C70-150	Schraubkabelschuh Screw cable lug	Cossa de cable Terminal
7		1	M 4 60x60 mm	Inbusschlüssel Allen key	Clé six-pans Llave allen
8		3	CWS - Pin	Kontaktstift Pin	Pointe de contact Varilla terminal
9		3	EGA-Set	Erdungs-Set Earthing-kit	Kit de mise à terre Conjuntos de puesta a tierra
10		3	DM 1 25x150 mm	Dichtband grau Sealing tape grey	Ruban d'étanchéité gris Cinta de estanqueidad gris
11		3	2585 50x300 mm	Polsterband Rubber mastic tape	Ruban mastique Cinta mastik
12		1	N° 028 5 m	Isolierband PVC tape	Ruban isolant Cinta aislante
13		3	Paar	Handschuhe Gloves	Gants Guantes
14		3	ST	Tuch mit Silikonöl Tissue with silicon oil	Tissu silicone Toalla siliconada
15		6	RT	Reinigungstuch Cleaning tissue	Tissu de nettoyage Toalla de limpieza
16		4	MA de, en, fr, es	Montageanleitung Working Instructions	Instructions de montage Instrucciones de montaje

Prüfgegenstand entspricht der vorgelegten technischen Zeichnung
 Unterschrift des Herstellers
 B. Holzer



Figure 2.7: Packing list

Annex A
(Informative)

Identification of test cable
(see 5.1)

Rated voltage $U_j/U (U_m)$: 12/20(24) kV

Construction: 1-core 3-core Individually screened
 Overall screen

Conductors: Al Cu
 Stranded Solid
 Circular Shaped
 120 mm² 150 mm² 185 mm²

Other cross-section: mm²

Insulation: XLPE
 EPR HEPR

Insulation screen: Bonded Strippable

Metallic screen: Wire Tape Extruded

Armour: Wire Tape

Oversheath: PVC PE (state type)

Water blocking, if any: Within conductor Under oversheath

Diameters:


- Conductor 14,2 mm
- Insulation 25,1 mm
- Insulation screen 27,1 mm
- Oversheath 34,1 mm

Cable marking: 2009 + PROTOTHEN X NA2XS2Y 1x150
PH/25 20kV <VDE> 0276

Prüfgegenstand entspricht der
vorgelegten technischen Zeichnung
C. P. ... *Z. M. ...*
Unterschrift des Herstellers Unterschrift des Prüfers

ВАРНО С
ОРИГИНАЛА

Figure 2.8: Cable data sheet



Tests: Test volume, chronological order and requirements conform to DIN VDE 0278-629-1:2009-07, table 7, additional test pos. 21.

Additional Test:

Pos. 21. *Capacitive test point performance*

$C_{tc} > 1,0 \text{ pF}$

$C_{te} / C_{tc} \leq 12$

3 Mounting

Final assembling of the separable connector was executed in the high-voltage laboratory of the IEH.

ВЯРНО С
ОРИГИНАЛА



4 Test Setup

Capacitive test point performance

The test was performed with a different bridge. For this test the capacity of test point to the cable conductor C_{tc} and the capacity of test point to earth C_{te} were measured at ambient temperature.

5 Results

Capacitive test point performance

This test was carried out as described in 4.

Test date: 13.04.2011

Capacitance of test point to cable conductor $C_{tc} > 1,0\text{pF}$

Requirement : $C_{tc} > 1,0\text{pF}$

Ratio of capacitance of test point to earth C_{te} and capacitance of test point to cable conductor: $C_{tc} : C_{te} / C_{tc} < 12$

Requirement: $C_{tc} : C_{te} / C_{tc} \leq 12$




6 Conclusion

The separable connector type CELLPLUX CWS 250A 24kV 70-150/M/EGA passed all tests described in clause 2 successfully. The test object fulfilled the requirements according DIN VDE 0278-629-1:2009-07, additional test table 7, pos.21.

Karlsruhe, 19.05.2011




Dr.-Ing. R. Badent
Head of Department
„High Voltage Dielectric Testing“




Dr.-Ing. B. Hoferer
Vice-Head of Department
„High Voltage Dielectric Testing“

ВЕРНО С
ОРИГИНАЛА



Bereich Hochspannungsprüftechnik

Institut für Elektroenergiesysteme und Hochspannungstechnik



Universität Fridericiana (TH) Karlsruhe
76128 Karlsruhe - Kaiserstraße 12

Telefon (0721) 608 2520 Telefax (0721) 69 52 24



Test Report No 2006-115

Type Test of Separable Connectors Type CELLPLUX-CTS 630 A 24 kV

Customer: Cellpack GmbH
Carl-Zeiss-Str. 20
79761 Waldshut-Tiengen

Reporter: Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer

This report includes 22 numbered pages and is only valid with the original signature. Copying of extracts is subject to the written authorization of the test laboratory. The test results concern exclusively to the tested objects.



A handwritten signature in black ink, written over the circular stamp.

1 Purpose of Test

4 resp. 3 separable connectors for $V_0 / V_n / V_m = 12,7 / 22 / 24$ kV were subjected to a type test according to CENELEC HD 629.1 S1 06/2002 table 7 test sequence D1 resp. D2. 3 separable connectors for $V_0 / V_n / V_m = 12,7 / 22 / 24$ kV were subjected to additional tests according to CENELEC HD 629.1 S1 06/2002, table 7 test pos. 19-22.

2 Miscellaneous Data



Test object: – 10 separable connectors type CELLPLUX-CTS 630 A
24 kV 95 - 250
 $V_m = 24$ kV, Figure 2.1
Type of the cable: The test object was mounted on a
single-wire XLPE-cable,
type:N2X(F)2Y 1x185RM/25 12/20kV
Cable length Connector - sealing end: 3 m


Place of test: *Institute of Electric Energy Systems and High Voltage
Technology* – University of Karlsruhe
Kaiserstraße 12 – 76128 Karlsruhe

Testing dates: Delivery: 10.10.2006
Mounting: 10.10.2006
Test period: 12.10. - 21.12.2006

Atmospheric conditions: Temperature: $19^{\circ}\text{C} - 24^{\circ}\text{C}$
Air pressure: 980 - 1025 mbar
rel. humidity: 35 % – 60 %

Representatives:
Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer
Mr. O. Müller





Montageanleitung

**T-Steckanschluss für
Einleiter Kunststoffkabel
bis 24 kV**

206741/1006/1/7

CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com

e-mail: electrical.products@cellpack.com
CTS 630A 24kV 95-240 206741/1006/1/7

CELLPACK AG
Electrical Products
CH-5812 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45





Figure 2.1: Separable connector.




Tests: Test volume, chronological order and requirements conform to CENELEC HD 629.1 S1 06/2002 test sequence D1 and D2, table 7 and additional test pos. 19 - 22.

The PD-test was performed at $2 V_0$. The tests were carried out in accordance with the test methods described in CENELEC HD 628 S1 06/2002 .

Test sequence D1:

- Pos. 1. *DC voltage withstand test*
 $V = 6 V_0 = -76 \text{ kV}$; $t = 15 \text{ min}$
- Pos. 2. *AC voltage withstand test*
 $\hat{V}/\sqrt{2} = 4,5 V_0 = 57 \text{ kV}$; $t = 5 \text{ min}$
- Pos. 3. *Partial discharge test*
 $\hat{V}/\sqrt{2} = 2,0 V_0 = 25 \text{ kV}$; $PD \leq 10 \text{ pC}$
- Pos. 4. *Impulse voltage withstand test at elevated temperature*
 $\hat{V} = 125 \text{ kV}$; positive and negative polarity each 10 impulses
- Pos. 5. *Partial discharge test at ambient temperature and elevated temperature*
 $\hat{V}/\sqrt{2} = 2,5 V_0 = 32 \text{ kV}$; $PD \leq 10 \text{ pC}$
- Pos. 6. *Electrical heat cycling in air*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{V}/\sqrt{2} = 32 \text{ kV}$
number of cycles: 3
- Pos. 10. *Electrical heat cycling in air*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{V}/\sqrt{2} = 32 \text{ kV}$
number of cycles: 60
- Pos. 11. *Electrical heat cycling in water*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{V}/\sqrt{2} = 32 \text{ kV}$
number of cycles: 63
- Pos. 12 *Disconnection / Connection*
5 complete operations,
no visible damage to contact




- Pos. 13. *Partial discharge test at ambient temperature and elevated temperature*
 $\sqrt{V} = 2,0 \text{ V}_0 = 25 \text{ kV} ; \text{PD} \leq 10 \text{ pC}$
- Pos. 14. *Impulse voltage withstand test,*
 $\hat{V} = 125 \text{ kV}$; positive and negative polarity each 10 impulses
- Pos. 15. *AC voltage withstand test*
 $\sqrt{V} = 2,5 \text{ V}_0 = 32 \text{ kV}$; $t = 15 \text{ min}$

Test sequence D2:

- Pos. 1. *DC voltage withstand test*
 $V = 6 \text{ V}_0 = -76 \text{ kV} ; t = 15 \text{ min}$
- Pos. 2. *AC voltage withstand test*
 $\sqrt{V} = 4,5 \text{ V}_0 = 57 \text{ kV}$; $t = 5 \text{ min}$
- Pos. 8. *Short circuit test, conductor*
 $\theta_{SC} = 250^\circ\text{C}$; 2 stresses
- Pos. 12. *Disconnection / Connection*
5 complete operations,
no visible damage to contact
- Pos. 14. *Impulse voltage withstand test,*
 $\hat{V} = 125 \text{ kV}$; positive and negative polarity each 10 impulses
- Pos. 15. *AC voltage withstand test*
 $\sqrt{V} = 2,5 \text{ V}_0 = 32 \text{ kV}$; $t = 15 \text{ min}$

Additional Tests:


- Pos. 19. *Screen resistance measurement*
 $R \leq 5000 \Omega$
- Pos. 20. *Leakage current measurement*
 $\sqrt{V} = 2,5 \text{ V}_m = 24 \text{ kV}$
 $I \leq 0,5 \text{ mA}$
- Pos. 21. *Screen fault current initiation*
Fault current to flow continuously
- Pos. 22. *Operating force test*
 $F \leq 900 \text{ N}$



3 Mounting

Final assembling of the separable connector was executed in the high-voltage laboratory of the IEH

ВЕРНО
ОРИГИНАЛ



4 Test Setups

4.1 DC Voltage Withstand Test

The DC-voltage was generated according to Figure 4.1. The voltage measurement was carried out with an ohmic-capacitive divider (ratio 2000:1). The measurement uncertainty was 3%.




Figure 4.1: Scheme of DC voltage test circuit.

$R_H = 3,6 \text{ k}\Omega$, $R_{H1} = 360 \text{ M}\Omega$, $C_H = 180 \text{ pF}$, ratio 2.000:1, PVM: Peak Voltmeter, TO: Test object, measurement uncertainty 3%

4.2 AC Voltage Withstand Test

The test voltage was generated by an 60-kVA transformer. The voltage measurement was carried out with a capacitive divider ($C_H = 180 \text{ pF}$; ratio = 2.000) and a peak voltmeter calibration $\hat{v}/\sqrt{2}$.





Figure 4,2: Scheme of AC test circuit

T_1 : transformer 400V / 200000V ; 60 kVA ; $v_K = 3,5 \%$; 50 Hz
 C_H : 180 pF ; ratio 2000:1 ; PVM : Peak-Voltmeter
 TO: Test object; measurement uncertainty 3 %



4.3 Partial-Discharge Test

The PD-measurement was performed with an analog bridge according to *Kreuger*, Figure 4.3. External PDs producing common mode signals at the detector are rejected by the differential amplifier. Internal PDs represent differential mode signals and are amplified. The background noise level at 25 kV_{rms} was 0,8 pC.





Figure 4.3: Scheme of PD test circuit
 TO1: Test object 1
 TO2: Test object 2

For balancing the bridge a calibrating impulse with $q_A = 10.000 \text{ pC}$ is applied between the terminals A (high-voltage) and C (ground) and the amplifier output is minimized. A pulse between the terminals A and C corresponds to an external PD. For the calibration a PD pulse, $q_A = 10 \text{ pC}$, is applied between A and B. Subsequently, the amplifier output of the PD measuring unit is adapted to the applied pulse.

Starting from zero the AC-voltage was steadily raised up to 28,1 kV and kept constant for 60 s, then slowly reduced to 25 kV including pd-reading.

ВАРНОС
 ДРУЖИНАЛА



4.4 Lightning Impulse Voltage Withstand Test

For impulse testing was used a two-stage Marx generator (Haefely) with a maximum cumulative charging voltage of $V = 400$ kV and a maximum impulse energy of $E_{\max} = 20$ kWs. At this test, the capacity of the energy storage capacitor was $C_S = 0.25$ μ F. The crest value of the impulse voltage was measured by a damped capacitive divider and a subsequent impulse peak voltmeter (Haefely). The front time and the time to half value were evaluated from the oscillographs.




Figure 4.4: Scheme of Impulse voltage test circuit

C_H : 1200 pF ; $R_H = 70$ Ω ; ratio: 3225;

IPV: impulse-peak-voltmeter (Haefely) – measurement uncertainty 3%


Oscilloscope: Tektronix TDS 3044B – measurement uncertainty 2%

The waveform parameters were determined at reduced charging voltage.

Positive impulse: $T_1 = 1.35$ μ s $T_2 = 46.8$ μ s

Negative impulse: $T_1 = 1.34$ μ s $T_2 = 47.2$ μ s

ВАРНО С
ОРИГИНАЛА



4.5 Electrical Heat Cycling in Air

The test objects must be heated by a current of $I = 630 \text{ A}$. Current inception was accomplished by a transformer ($V_1 = 400 \text{ V}$; $V_2 = 8 \text{ V}$) which used the cable as secondary winding. The current was measured by an current transformer, 1500/5, and a digital multimeter. The measurement uncertainty was 1%.

4.6 Electrical Heat Cycling in Water

The test object were placed in a tank and filled with water. The height of the water was 1000 mm above the test object. The conductivity of the water at 20°C was 63 mS/m.

4.7 Thermal Short Circuit Current Test

According IEC 986 for Cu with $q = 185 \text{ mm}^2$ $I^2t = 1091,4 \cdot 10^6 \text{ A}^2\text{s}$ with $\theta_{sc} = 250^\circ\text{C}$ and $\theta_i = 25^\circ\text{C}$. That means $I_K(1s) = 33,04 \text{ kA}$. The short-circuit during test was $I_K = 18,74 \text{ kA}$, resulting in a short-circuit duration of $t_K = 3,20 \text{ s}$. The test object was tested with two thermal short-circuit currents. Between two tests the specimen cooled down to ambient temperature. The current was measured with a $10 \mu\Omega$ -shunt connected to a digital storage oscilloscope (Tektronix 2430 A). The measurement uncertainty was 2%.





Figure 4.7.1: Scheme of short-circuit test.

ВАРНО С
ОРИГИНАЛА







Figure 4.7.2: Short circuit current
Hor: 200 ms/Div; Vert: 20 kA/DIV

4.8 Screen Resistance Measurement

Prior to the test silver-painted electrodes were installed. The screen resistance of the plug-in termination was measured at ambient temperature between the two electrodes. Then the test object was subjected to thermal ageing in an air oven at $(120 \pm 2)^\circ\text{C}$ for 168 h. After thermal ageing the screen resistance at ambient temperature was measured again.

4.9 Leakage Current Measurement

Prior to the test a metal foil of 25 cm^2 was fixed without any air gap to the outer screen of the plug-in termination. The metal foil was placed at the end of the plug-in termination opposite to the earth bend and earthed through a milliamperemeter and a resistance of 2000 ohms. The leakage current was measured with a test voltage of V_m applied between conductor and earth.



4.10 Screen Fault Current Initiation

Prior to the test a faulting wire of approx. 0.2 mm was placed in the area of the hexagonal connecting bolt through a drilled hole. The wire was connected with the inner and outer screens and did not protrude beyond the outer screen surface.

The test voltage was generated by a 630 kVA-transformer. A capacitor bank was connected in series to the test object, resulting in a short-circuit current of 10A, Figure 4.10. The sequence of the test was as follows:

1. voltage switched on for 1 s
2. voltage switched off for 2 min
3. voltage switched on for 2 min
4. voltage switched off for 2 min
5. voltage switched on for 1 min
6. voltage switched off





Figure 4.10: Scheme of AC test circuit
 T₁: Transformer 400V/20.000V; 630 kVA
 C_H: 180 pF; $\dot{u} = 2000:1$; PVM; peak-voltmeter
 C: 2,66 μ F; W: current transformer; TO: test object

4.11 Operation Force Test

The test object was placed in a climate chamber and conditioned at $(-20 \pm 2)^\circ\text{C}$ for at least 12h. The test was carried out within 5 min after removal from the climate chamber. The plug-in termination was clamped by means of a tool which allows operation along the axis of the test object. The force was gradually applied to the plug-in termination and measured by means of a tractive dynamometer.



5 Results

5.1 Test Sequence D1

5.1.1 DC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 12.10.2006

Test voltage: $V = - 76 \text{ kV} ; t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the DC voltage withstand test.

The test was passed successfully.

5.1.2 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 12.10.2006

Test voltage: $\hat{U}/\sqrt{2} = 57 \text{ kV} , t = 5 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

5.1.3 Partial Discharge Test


This test was carried out as described in 4.

Test date: 12.10.2006

Voltage: $\hat{U}/\sqrt{2} = 28,1 \text{ kV} , t = 60 \text{ s thereafter}$
 $\hat{U}/\sqrt{2} = 25 \text{ kV with pd reading}$

PD magnitude (25 kV): $< 10 \text{ pC}$

The test was passed successfully.



5.1.4 Impulse Voltage Withstand Test at elevated Temperature

This test was carried out as described in 4

Test date: 13.10.2006
Test voltage: $\hat{U} = 125 \text{ kV}$
Heating current: $I = 630 \text{ A}; t = 5 \text{ h}$
Number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.1.5 Electrical Heat Cycling in Air

This test was carried out as described in 4.

Test date: 02.11. - 03.11.2006
Test voltage: $\hat{U}/\sqrt{2} = 32 \text{ kV}$
Heating current: $I = 630 \text{ A}$
Cycle: 5 h heating; 3 h cooling
Number of cycles: 3

Neither flashover nor breakdown occurred.

The test was passed successfully.

5.1.6 Partial Discharge Test

5.1.6.1 Partial Discharge Test at ambient temperature

This test was carried out as described in 4.

Test date: 06.11.2006
Voltage: $\hat{U}/\sqrt{2} = 28,1 \text{ kV}, t = 60 \text{ s}$ thereafter
 $\hat{U}/\sqrt{2} = 25 \text{ kV}$ with pd reading
PD magnitude (25 kV): $< 10 \text{ pC}$

The test was passed successfully.



5.1.6.2 Partial Discharge Test at elevated temperature

This test was carried out as described in 4

Test date: 06.11.2006
Heating current: $I = 630 \text{ A}$, $t = 5 \text{ h}$
Voltage: $\hat{U}/\sqrt{2} = 28,1 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\hat{U}/\sqrt{2} = 25 \text{ kV}$ with pd reading
PD magnitude (25 kV): $< 10 \text{ pC}$

The test was passed successfully.

5.1.7 Electrical Heat Cycling in Air

This test was carried out as described in 4.

Test date: 07.11. - 27.11.2006
Test voltage: $\hat{U}/\sqrt{2} = 32 \text{ kV}$
Heating current: $I = 630 \text{ A}$
Cycle: 5 h heating; 3 h cooling
Number of cycles: 60

Neither flashover nor breakdown occurred.

The test was passed successfully.

5.1.8 Electrical Heat Cycling in Water


This test was carried out as described in 4.

Test date: 27.11.-18.12.2006
Conductivity: 63 mS/m
Test voltage: $\hat{U}/\sqrt{2} = 32 \text{ kV}$
Heating current: $I = 630 \text{ A}$
Cycle: 5 h heating; 3 h cooling
Number of cycles: 63
Heat of water: 1000mm

Neither flashover nor breakdown occurred.

The test was passed successfully.

ВЪРНО С
ОРИГИНАЛА



5.1.9 Disconnection / Connection

Test date: 20.12.2006
Number: 5 complete operations

With each test object there was no visible damage to contact.

The test was passed successfully.

5.1.10 Partial Discharge Test

5.1.10.1 Partial Discharge Test at ambient temperature

This test was carried out as described in 4.

Test date: 21.12.2006
Voltage: $\hat{U}/\sqrt{2} = 28,1 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\hat{U}/\sqrt{2} = 25 \text{ kV}$ with pd reading
PD magnitude (25 kV): $< 10 \text{ pC}$



The test was passed successfully.

5.1.10.2 Partial Discharge Test at elevated temperature

This test was carried out as described in 4

Test date: 21.12.2006
Heating current: $I = 630 \text{ A}$, $t = 5 \text{ h}$
Voltage: $\hat{U}/\sqrt{2} = 28,1 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\hat{U}/\sqrt{2} = 25 \text{ kV}$ with pd reading
PD magnitude (25 kV): $< 10 \text{ pC}$

The test was passed successfully.



5.1.11 Impulse Voltage Withstand Test

This test was carried out as described in 4.

Test date: 21.12.2006

Test voltage: $\hat{U} = 125 \text{ kV}$

Number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.1.12 AC Voltage Withstand Test

This test was carried out as described in 4.


Test date: 21.12.2006

Test voltage: $\hat{U}/\sqrt{2} = 32 \text{ kV}$, $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

ВАРНО С
ОРИГИНАЛА



5.2 Test Sequence D2

5.2.1 DC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 11.11.2006

Test voltage: $V = -76 \text{ kV}$; $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the DC voltage withstand test.

The test was passed successfully.

5.2.2 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 11.11.2006

Test voltage: $\hat{V}/\sqrt{2} = 57 \text{ kV}$, $t = 5 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

5.2.3 Thermal Short Circuit, Conductor

This test was carried out as described in 4.

Test date: 04.12.2006


current: $I_K = 18,74 \text{ kA}$

$t_K = 3,20 \text{ s}$

number of stresses: 2

time between stresses: 2h

The test was passed successfully.



5.2.4 Disconnection / Connection

Test date: 20.12.2006

Number: 5 complete operations

With each test object there were no visible damage to contact.

The test was passed successfully.

5.2.5 Impulse Voltage Withstand Test

This test was carried out as described in 4.

Test date: 21.12.2006

Test voltage $\hat{U} = 125 \text{ kV}$

number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.2.6 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 21.12.2006

Test voltage: $\hat{U}/\sqrt{2} = 32 \text{ kV}$, $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

ВАРНО С
ОРУГИНАЛА



5.3 Additional Tests

5.3.1 Screen Resistance Measurement

This test was carried out as described in 4.

Test date: 30.11. - 07.12.2006

Resistance prior to thermal ageing < 5000 Ω

Resistance after thermal ageing < 5000 Ω

Requirement: resistance \leq 5000 Ω

The test was passed successfully.

5.3.2 Leakage Current Measurement

This test was carried out as described in 4.

Test date: 11.12.2006

Test voltage: $\hat{U}/\sqrt{2} = V_m = 24$ kV

Leakage current: $I < 0,5$ mA

Requirement: $I \leq 0,5$ mA

The test was passed successfully.

5.3.3 Screen Fault Current Initiation

This test was carried out as described in 4.


Test date: 15.12.2006

Test voltage: $\hat{U}/\sqrt{2} = V_0 = 12,7$ kV

Short-circuit current: $I = 10,3$ A

Fault current flow continuously.

The test was passed successfully.



5.3.4 Operating Force Test

This test was carried out as described in 4.

Test date: 11.12. - 12.12.2206



Temperature: - 20°C

Duration: 24h

Force: < 900 N

Requirement: $F < 900 \text{ N}$


The test was passed successfully.




6 Conclusion

The separable connector type CELLPLUX-CTS 630 A 24 kV passed all tests described in clause 2 successfully. The test object fulfilled the requirements according CENELEC HD 629.1 / S1 06/2002, table 7, test sequences D1 and D2 and additional tests table 7, pos.19-22.

Karlsruhe, 08.01.2007




Dr.-Ing. R. Badent
Bereichsleiter HPT




Dr.-Ing. B. Hoferer
stellv. Bereichsleiter HPT

ВАРНО С
ОРИГИНАЛА



Bereich Hochspannungsprüftechnik
Institut für Elektroenergiesysteme und Hochspannungstechnik



Universität Fridericiana (TH) Karlsruhe
76128 Karlsruhe - Kaiserstraße 12
Telefon (0721) 608 2520 Telefax (0721) 69 62 24


Test Report No 2010-77

Type Test of
Separable Connectors
Type CELLPLUX-CTKS 630A 24 kV

Customer: Cellpack GmbH
Carl-Zeiss-Str. 20
79761 Waldshut-Tiengen

Reporter: Dr.-Ing. R. Badent
Dr.-Ing. B. Hoferer

This report includes 24 numbered pages and is only valid with the original signature.
Copying of extracts is subject to the written authorization of the test laboratory. The test results concern exclusively to the tested objects.



1 Purpose of Test

4 separable connectors for $V_0 / V_n / V_m = 12,7 / 22 / 24$ kV were subjected to a type test according to DIN VDE 0278-629-1:2009-07 table 7, test sequence D1. One separable connector for $V_0 / V_n / V_m = 12,7 / 22 / 24$ was subjected to additional tests according to CENELEC HD 629.1 S2 02/2006, table 7 test pos. 21.

2 Miscellaneous Data

Test object: – 5 separable connectors
 type T coupling connector CTKS 630A 24 kV
 $V_m = 24V$,
 Installation instruction no.: 257258/0910/3/9, Figures 2.1 – 2.9
 Packing llt: 256839, Figure 2.10
 Type of the cable: The test object was mounted on a
 single-wire XLPE-cable, type N2XS
 1x185/25 12/20kV, Figure 2.11

Cable length Connector - termination: 3 m

Manufacturer: Cellpack GmbH
 Carl-Zeiss-Str. 20
 79761 Waldshut-Tiengen

Place of test: *Institute of Electric Energy Systems and High Voltage
 Technology – University of Karlsruhe
 Kaiserstraße 12 – 76128 Karlsruhe*


Testing dates: Delivery: 23.09.2010
 Mounting: 23.09.2010
 Test period: 24.09. - 22.12.2010

Atmospheric
conditions: Temperature: $19^{\circ}C - 24^{\circ}C$
 Air pressure: 980 - 1025 mbar
 rel. humidity: 35 % – 60 %

Representatives: Dr.-Ing. R. Badent
 Dr.-Ing. B. Hoferer
 Mr. O. Müller

ВЕРНО
ОРИГИНАЛ





Working Instruction

Separable T Coupling Connector for
single-core polymeric cables
up to 24 kV

257258/0910/3/9

Prüfgegenstand entspricht der
vorgelegten technischen Zeichnung
C. Anke *B. Hojasel*
Unterschrift des Herstellers Unterschrift des Profests

CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com
e-mail: electrical.products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Vilkmergen
Tel. +41(0)58/618 12 34
Fax +41(0)58/618 12 45

CELLPACK
Electrical Products

257258 CTKS 630A 24kV 95-240/EGA

1/9

Figure 2.1: Installation Instruction.

ВЕРНО С
ОРИГИНАЛА



General remarks:

- Check if the range and size of the accessories is appropriate to the cable.
- Check the content of the kit as per packing list.
- Thoroughly read the working instruction.


Installation must be executed by competent personnel only.
 The manufacturer accepts no liability for breakdowns or damages resulting from an incorrect installation.

Separable T Coupling Connector CELLPLUX CTKS 630A 24kV 95-240/EGA:

Cross-Section Application

Voltage U ₀ /U(U _m) kV	Cable Cross-Section (*) mm ²
6/10(12) kV	150 – 240 *)
8,7/15(17,5) kV	120 – 240 *)
12/20(24) kV	95 – 240 *)

(*) Minimal diameter over cable insulation of 22 mm



- Clean thoroughly the cable ends up to 1 m.
- Adjust the cable overhanging in the middle of the bushing by L = 200 – 500 mm. Cut-off the excess of cable
- Make a mark 210 mm from the centre of the bushing onto the cable sheath.

257258 CTKS 630A 24kV 95-240/EGA

Figure 2.2: Installation Instruction


ВЕРНО С
ОРИГИНАЛА
2/0



Preparation of the cable


Cable with wire screen:

1a)




- Remove the cable sheath up to the mark.
- Band back the screen wires of the cable and fix them on the cable sheath with PVC tape (Fig. 1a).
- Cut off the conductor at the length of 165 mm.

2a)



- Remove carefully the outer conductive layer up to 30 mm (mind a clean cut back edge).
- Cut back the cable insulation by 55 mm.
- Clean thoroughly insulation and the outer conductive layer of the cable.

3a)



257258 GTKS 630A 24kV 95-240/EGA

Prüfgegenstand entspricht der vorgelegten technischen Zeichnung

[Signature] *[Signature]*


Unterschrift des Herstellers Unterschrift des Prüfers

- Wrap the tip end of the conductor with PVC tape.
- Wrap 2/3 of the length of DM1 mastic 10 mm on to the conductive layer and 20 mm on to the wire screen (stretch 50%).
- Apply at and around the cut edge of the conductive layer lubricant and filling agent GM1 (forming a ring).
- Moisten the insulation with lubricant and filling agent GM1.

3/9


Figure 2.3: Installation Instruction

ВАРНО С
ОРУЖИНАДА




Cable with tape screen:

1b)




2b)



- Remove the cable sheath up to the mark + 20mm.
- Cut the cable according to the drawing.
- Remove carefully the tape screen up to 20 mm.

- Remove carefully the outer conductive layer up to 30 mm (mind a clean cut back edge).
- Cut back the cable insulation by 55 mm.
- Clean thoroughly the insulation and the conductive layer.

3b)



257258 CTKS 630A 24KV 95-240/EGA


- Wrap the tip end of the conductor with PVC tape.
- Fix the flat Cu-braid and earthing cable with the pressure spring RF on to the tape screen (order the earthing kit separately).
- Wrap 2/3 of the length of mastic tape DM1 10 mm on to the conductive layer and 20 mm on to the copper tape screen (Fig. 3b).
- Apply at and around the cut edge of the conductive layer lubricant and filler agent GM1 (forming a ring).
- Moisten the insulation with lubricant and filling agent GM1.


Prüfgegenstand entspricht der vorgelegten technischen Zeichnung
 C. Dürse B. Hoyer S
 Unterschrift des Herstellers Unterschrift des Prüfers

4/8


ВАРНО С
 АРИГИНАЛАТА

Figure 2.4: Installation Instruction






- Moisten the tongues of the applicator AH with the silicon towel.
- Insert the applicator AH in to the stress control element FSE and slip it on to the cable up to the sealing wrap.
- Remove the applicator AH by pulling out the tongues one by one.
- Adjust the position of the stress control element FSE by turning it slightly (Fig. 5).



- Remove the protection wrap from the tip end of the conductor.
- Install the shear-head screw cable lug according to the separate instruction. Please note that the tapped hole of the cable lug is in line with the bushing axle.
- Clean thoroughly the surface of the stress control element FSE.




- Moisten the connector body and the surface of the stress control elements FSE with lubricant and filling agent GM1.
- Attention: The cable lug must not be moistured.
- Slip the connector body on to the conductor until the tapped hole of the cable lug is centred inside the connector body.


257258 CTKS 630A 24kV 95-240/EGA

Prüfgegenstand entspricht der vorgelegten technischen Zeichnung
 Unterschrift des Herstellers Unterschrift des Prüfers


ВЕРИТЕ С
 ПРИВИНАЛА

Figure 2.5: Installation Instruction







- Wrap the remaining 1/3 of mastic tape DM1 between the end of the connector body and the sealing area.



- Wrap the tape Nr. 2585 adhesive side inwards approx. 20 mm over the end of the connector body up to the end of the sealing area (stretch 20%).



- Take off the conductive protection cup of the T - connector body.



- Unscrew the insulating plug. Use appropriate tool.


257258 CTKS 630A 24kV 95-240/EGA

Prüfgegenstand entspricht der vorgelegten technischen Zeichnung
[Signature] *[Signature]*
 Unterschrift des Herstellers Unterschrift des Prüfers
 6/6

Figure 2.6: Installation Instruction


ВАРНО С
 ОПРИГНАЛНА
 ЕЛЕКТРОТЕХ
 НИКА
 БУЛГАРИЯ
 ДОО

11)



- Clean thoroughly inside of the T-connector body and moisten again with lubricant and filling agent GM1.
 - Insert the adaptor plug into the T-connector body and screw the adaptor plug manually. Tighten the adaptor plug with an appropriate tool till the shear head breaks.
- Attention:
To reuse the adaptor plug it must be tighten with a shear moment „M” of 40 Nm

12)





- Moisten outside of the CTKS-connector body with lubricant and filling agent GM1.
 - Cut out a tongue from the applicator AH (air decompression device). Insert the decompression device into the T-connector body.
 - Attach the CTKS-connector straight on to the adaptor plug and screw the contact screw manually.
 - Tighten the contact screw with an appropriate tool till the shear head breaks.
- Attention:
To reuse the contact screw it must be tighten with a shear moment „M” of 50 Nm

257268 CTKS 630A 24kV 95-240/EGA

Figure 2.7: Installation Instruction


ВАЖНО С ПРИМНАТА







13)

M = 40 Nm



- Moisten inside of the CTKS-connector body and the new Insulating plug with lubricant and filling agent GM1.
- Cut out a second tongue from the applicator and insert it into the connector body.
- Insert the new insulating plug into the connector body. Tighten the Insulating plug with an appropriate tool. Do not apply a shear moment „M“ bigger than 40 Nm.

14)




- Pull out gently the decompression devices and remove remaining of lubricant and filling agent GM1.

257258 CTKS 630A 24kV 95-240/EGA

Figure 2.8: Installation Instruction



15)



- Insert the conductive protection cup over the connector body and ground the GTKS-connector body.
- Further earthing measurements have to be carried out according to local regulations.



257258 GTKS 630A 24kV 85-240/EGA

Figure 2.9: Installation Instruction



Packliste	256 839	Lista de carga	CELLPACK Electrical Products
Packing list			
Liste d'emballage			

MEDIUM VOLTAGE	CELLPLUX
-----------------------	-----------------

T-Koppelsteckanschluss T Coupling Connector Connecteur de couplage en T Terminal de acople en T	Typ	CTKS 630A 24kV 95-240/EGA	
	U ₀ /U(U _m)	6/10(12)kV	150 - 240 mm ²
		8,7/15(17,5)kV	120 - 240 mm ²
		12/20(24)kV	95 - 240 mm ²
		Isolation min. Ø: 22 mm	
		Version: 03	

Pos		St. Cont.	Dimension			
1		3	CTKS 630A 24 kV	Steckanschluss Plug-in connector		Connecteur Séparable Cuerpo Terminal
2		3	CTKS 630A 24 kV	Isol. Anschluss-Stopfen Insulated plug		Connecteur Isolé Enchufe aislada
3		3	FSE 20	Feldsteuerelement Field control element		Contrôleur de champ Elemento de control de campo
4		4	GM1	Gleß- und Füllmittel Lubricant and filter		Lubrifiant Lubrificante
5		3	AH 3	Aufschlebehilfe Applicator		Dispositif d'ontage Aplicador
6		3	CTKS(A) 630A	Verbindungssteck Adaptor plug		Raccordement Pieza de conexión
7		3	CTKS 630A 95-240	Schraubkabelschuh + Anschlussbolzen Cable lug with connecting bolt		Cintre de fixation Terminal con
8		3	DM 1 25x200 mm	Dichtband grau Sealing tape grey		Ruban d'étanchéité gris Cinta de estanqueidad gris
9		3	2585 50x350 mm	Polsterband Rubber mastic tape		Ruban mastique Cinta Mástik
10		1	N° 028 5 m	Isolierband PVC tape		Ruban isolant Cinta aislante
11		3	Paar	Handschuhe Gloves		Gants Guante
12		3	ST	Tuch mit Silikonöl Tissue with silicon oil		Tissu siliconé Toalla siliconada
13		9	RT	Reinigungstuch Cleaning tissue		Tissu de nettoyage Toalla de Limpieza
14		4	MA de, en, fr, es	Montageanleitung Working Instructions		Instructions de montage Instrucciones de montaje

Prüfgegenstand entspricht der vorgelegten technischen Zeichnung

[Signature] *[Signature]*

Unterschrift des Herstellers Unterschrift des Prüfers




Figure 2.10: Packing list

Anhang A
 (Informativ)

Dokumentation der Prüfkabel (siehe 5.1.1 und 8.2)

Nennspannung U_{N} (V_m): 12/20(24)kV

Kabelaufbau: 1-Leiter 3-Leiter einzeln geschirmt
 gemeinsam geschirmt

Leiteraufbau: Al Cu
 mehrdrähtig massiv
 Rundleiter Sektorleiter
 120 mm² 150 mm² 185 mm²
 anderer Querschnitt: mm²

Kabellösung: VPE
 EPR HEPR

Äußere Leitschicht: fest extrudiert abziehbar

Metallischer Schirm: Drähte Bänder extrudiert

Armerung: Draht Band



Außenmantel: PVC PE (Typ ist anzugeben)

Wassersperre, wenn vorhanden: im Leiter unter Außenmantel

Durchmesser:
 • Leiter 16,2 mm
 • Isolierung 28,3 mm
 • äußere Leitschicht 29,1 mm
 • Außenmantel 36,5 mm

Kabelbezeichnung: TF Kabel 5

N2XSY 1x185 RM125 20kV



Tests: Test volume, chronological order and requirements conform to DIN VDE 0278-629-1:2009-07 test sequence D1, table 7 and additional test pos. 21.
The PD-test was performed at $2 V_0$. The tests were carried out in accordance with the test methods described in DIN EN 61442 01/2006.

Test sequence D1:

- Pos. 1. *DC voltage withstand test*
 $V = 6 V_0 = -76 \text{ kV}$; $t = 15 \text{ min}$
- Pos. 2. *AC voltage withstand test*
 $\hat{V} / \sqrt{2} = 4,5 V_0 = 57 \text{ kV}$; $t = 5 \text{ min}$
- Pos. 3. *Partial discharge test*
 $\hat{V} / \sqrt{2} = 2,0 V_0 = 25 \text{ kV}$; $PD \leq 10 \text{ pC}$
- Pos. 4. *Impulse voltage withstand test at elevated temperature*
Impulse voltage
 $\hat{V} = 125 \text{ kV}$; positive and negative polarity each 10 impulses
- Pos. 5. *Electrical heat cycling in air*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{V} / \sqrt{2} = 32 \text{ kV}$, number of cycles: 63
- Pos. 6. *Electrical heat cycling in water*
each loading cycle had a 5 hour heating period and a 3 hour no-load cooling period;
test voltage: $\hat{V} / \sqrt{2} = 32 \text{ kV}$, number of cycles: 63
- Pos. 10. *Disconnection / Connection*
5 complete operations,
no visible damage to contact
- Pos. 11. *Partial discharge test at ambient temperature and elevated temperature*
 $\hat{V} / \sqrt{2} = 2,0 V_0 = 25 \text{ kV}$; $PD \leq 10 \text{ pC}$
- Pos. 12. *Impulse voltage withstand test, lightning impulse voltage*
 $\hat{V} = 125 \text{ kV}$; positive and negative polarity each 10 impulses
- Pos. 13. *AC voltage withstand test*
 $\hat{V} / \sqrt{2} = 2,5 V_0 = 32 \text{ kV}$; $t = 15 \text{ min}$

Additional Test:

- Pos. 21. *Capacitive test point performance*
 $C_{tc} > 1,0 \text{ pF}$
 $C_{te} / C_{tc} \leq 12$



3 Mounting

Final assembling of the separable connector was executed in the high-voltage laboratory of the IEH.

ВЯРНО С
ОРИГИНАЛА



4 Test Setups

4.1 DC Voltage Withstand Test

The DC-voltage was generated according to Figure 4.1. The voltage measurement was carried out with an ohmic-capacitive divider (ratio 2000:1). The measurement uncertainty was 3%.




Figure 4.1: Scheme of DC voltage test circuit.
 $R_H = 3,6 \text{ k}\Omega$, $R_{H1} = 360 \text{ M}\Omega$, $C_H = 180 \text{ pF}$, ratio 2.000:1, PVM: Peak Voltmeter, TO: Test object, measurement uncertainty 3%

4.2 AC Voltage Withstand Test

The test voltage was generated by an 60-kVA transformer. The voltage measurement was carried out with a capacitive divider ($C_H = 180 \text{ pF}$; ratio = 2.000) and a peak voltmeter calibration $\diamond / \sqrt{2}$.




Figure 4.2: Scheme of AC test circuit
 T_1 : transformer 400V / 200000V ; 60 kVA ; $v_K = 3,5\%$; 60 Hz
 C_H : 180 pF ; ratio 2000:1 ; PVM : Peak-Voltmeter
 TO: Test object; measurement uncertainty 3%



4.3 Partial-Discharge Test

The PD-measurement was performed with an analog bridge according to *Kreuger*, Figure 4.3. External PDs producing common mode signals at the detector are rejected by the differential amplifier. Internal PDs represent differential mode signals and are amplified. The background noise level at 25 kV_{rms} was 1,0 pC.




Figure 4.3: Scheme of PD test circuit
 TO1: Test object 1
 TO2: Test object 2

For balancing the bridge a calibrating impulse with $q_A = 10.000 \text{ pC}$ is applied between the terminals A (high-voltage) and C (ground) and the amplifier output is minimized. A pulse between the terminals A and C corresponds to an external PD. For the calibration a PD pulse, $q_A = 10 \text{ pC}$, is applied between A and B. Subsequently, the amplifier output of the PD measuring unit is adapted to the applied pulse.

Starting from zero the AC-voltage was steadily raised up to 28,1 kV and kept constant for 60 s, then slowly reduced to 25 kV including pd-reading.

ВЪРНО С
ОРИГИНАЛА



4.4 Lightning Impulse Voltage Withstand Test

For impulse testing was used a two-stage Marx generator (Haefely) with a maximum cumulative charging voltage of $V = 400$ kV and a maximum impulse energy of $E_{\max} = 20$ kWs. At this test, the capacity of the energy storage capacitor was $C_S = 0.25$ μ F. The crest value of the impulse voltage was measured by a damped capacitive divider and a subsequent impulse peak voltmeter (Haefely). The front time and the time to half value were evaluated from the oscillographs.




Figure 4.4: Scheme of impulse voltage test circuit

C_H : 1200 pF ; $R_H = 70$ Ω ; ratio: 3215;

IPV: Impulse-peak-voltmeter (Haefely) – measurement uncertainty 3%


Oscilloscope: Tektronix TDS 3044B – measurement uncertainty 2%

The waveform parameters were determined at reduced charging voltage.

Positive impulse: $T_1 = 3.07$ μ s $T_2 = 49.6$ μ s

Negative impulse: $T_1 = 2.87$ μ s $T_2 = 49.4$ μ s

ВЯРНО С
ОРИГИНАЛА



4.5 Electrical Heat Cycling in Air

The test objects must be heated by a current which provides the permitted service temperature of the tested cable plus 5 K - 10 K, that means 95°C - 100°C, for XLPE-cable. The heating current I was determined with a dummy cable. The same cable as used for the test, with a length of 3 m, was drilled with a diameter of 0.8 mm up to the conductor. The temperature was measured with a thermo couple NiCr-Ni. The measurement uncertainty was ± 2 K.

The maximum heating current for this test was 760 A. Current inception was accomplished by a transformer ($V_1 = 400$ V; $V_2 = 8$ V) which used the cable as secondary winding. The current was regulated by a control unit and measured by a current transformer, 1500/5, and a digital multimeter. The measurement uncertainty was 1%.

4.6 Electrical Heat Cycling in Water


The test object were placed in a tank and filled with water. The height of the water was 1000 mm above the test object. The conductivity of the water at 20°C was 63 mS/m.

At a distance of 100 mm from each side of the accessory, the cable oversheath was removed for a distance of 50 mm.

4.7 Capacitive test point performance

The test was performed with a different bridge. For this test the capacity of test point to the cable conductor C_{tc} and the capacity of test point to earth C_{te} were measured at ambient temperature.

ВЯРНО С
ОРИГИНАЛА



5 Results

5.1 Test Sequence D1

5.1.1 DC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 24.09.2010

Test voltage: $V = -76 \text{ kV}$; $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the DC voltage withstand test.

The test was passed successfully.

5.1.2 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 24.09.2010

Test voltage: $\diamond / \sqrt{2} = 57 \text{ kV}$, $t = 5 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

5.1.3 Partial Discharge Test

This test was carried out as described in 4.

Test date: 24.09.2010

Voltage: $\diamond / \sqrt{2} = 28.1 \text{ kV}$, $t = 60 \text{ s}$ thereafter
 $\diamond / \sqrt{2} = 25 \text{ kV}$ with pd reading

PD magnitude (25 kV): $< 10 \text{ pC}$

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



5.1.4 Impulse Voltage Withstand Test at elevated Temperature

This test was carried out as described in 4

Test date: 24.09.2010
Test voltage: $\diamond = 125$ kV
Maximum heating current: $I = 760$ A; $t = 5$ h
Number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.1.5 Electrical Heat Cycling in Air

This test was carried out as described in 4.

Test date: 30.09. - 21.10.2010
Test voltage: $\diamond / \sqrt{2} = 32$ kV
Maximum heating current: $I = 760$ A
Cycle: 5 h heating; 3 h cooling
Number of cycles: 63

Neither flashover nor breakdown occurred.

The test was passed successfully.

5.1.6 Electrical Heat Cycling in Water


This test was carried out as described in 4.

Test date: 28.10. – 18.11.2010
Conductivity: 63 mS/m
Test voltage: $\diamond / \sqrt{2} = 32$ kV
Maximum heating current: $I = 760$ A
Cycle: 5 h heating; 3 h cooling
Number of cycles: 63
Heat of water: 1000mm

Neither flashover nor breakdown occurred.

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



5.1.7 Disconnection / Connection

Test date: 30.11.2010
Number: 5 complete operations

With each test object there was no visible damage to contact.

The test was passed successfully.

5.1.8 Partial Discharge Test

5.1.8.1 Partial Discharge Test at ambient temperature

This test was carried out as described in 4.

Test date: 09.12.2010
Voltage: $\diamond/\sqrt{2} = 28.1$ kV, t = 60 s thereafter
 $\diamond/\sqrt{2} = 25$ kV with pd reading
PD magnitude (25 kV): < 10 pC

The test was passed successfully.


5.1.8.2 Partial Discharge Test at elevated temperature

This test was carried out as described in 4

Test date: 10.12.2010
Maximum heating current: I = 760 A, t = 5 h
Voltage: $\diamond/\sqrt{2} = 28.1$ kV, t = 60 s thereafter
 $\diamond/\sqrt{2} = 25$ kV with pd reading
PD magnitude (25 kV): < 10 pC

The test was passed successfully.

ВЯРНО С
ОРИГИНАЛА



5.1.9 Impulse Voltage Withstand Test

This test was carried out as described in 4.

Test date: 10.12.2010

Test voltage: $\hat{U} = 125 \text{ kV}$

Number of tests: 10 positive polarity, 10 negative polarity

Neither flashover nor breakdown occurred at the test objects during all lightning impulse voltage withstand tests.

The test was passed successfully.

5.1.10 AC Voltage Withstand Test

This test was carried out as described in 4.

Test date: 10.12.2010

Test voltage: $\hat{U}/\sqrt{2} = 32 \text{ kV}$, $t = 15 \text{ min}$

With each test object neither flashover nor breakdown occurred at the test objects during the AC voltage withstand test.

The test was passed successfully.

5.2 Additional Tests

Capacitive test point performance

This test was carried out as described in 4.

Test date: 22.12.2010

Capacitance of test point to cable conductor $C_{tc} > 1,0\text{pF}$

Requirement : $C_{tc} > 1,0\text{pF}$

Ratio of capacitance of test point to earth C_{te} and capacitance of test point to cable conductor: $C_{tc} : C_{te} / C_{tc} < 12$

Requirement: $C_{tc} : C_{te} / C_{tc} \leq 12$

ВЕРНО
ОРИГИНАЛ



6 Conclusion

The separable connector type CELLPLUX CTKS 630A 24 kV passed all tests described in clause 2 successfully. The test object fulfilled the requirements according DIN VDE 0278-629-1:2009-07, table 7, test sequence D1 and additional test table 7, pos.21.

Karlsruhe, 15.01.2011




Dr.-Ing. R. Badent
Bereichsleiter HPT



Dr.-Ing./B. Hoferer
stellv. Bereichsleiter HPT

ВАРНО С
ОРИГИНАЛА



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № РРД 15-042

“Щепселни кабелни глави за КРУ за едножилни полиетиленови кабели 10 kV и 20 kV”

Приложение № 4



DATEch Deutsche Akkreditierungsstelle Technik in der TGA GmbH
Unterzeichner der Multilateralen Abkommen von EA und ILAC zur
gegenseitigen Anerkennung

vertreten im

Deutschen AkkreditierungsRat



Akkreditierung

Die TGA GmbH, vertreten durch die DATEch Deutsche Akkreditierungsstelle Technik
in der TGA GmbH, bestätigt hiermit, dass das Prüflaboratorium

Institut für Elektroenergiesysteme und
Hochspannungstechnik (IEH)
der Universität Karlsruhe
Kaiserstraße 12

D-76128 Karlsruhe

die Kompetenz nach DIN EN ISO/IEC 17025:2005 besitzt, Prüfungen in den Bereichen

Dielektrische und Klimaprüfungen an Hochspannungsgeräten und -
Komponenten, Prüfungen an Hochspannungskabeln, -Garnituren und -
Leitungen und Elektromagnetische Verträglichkeit (EMV)


nach den in der Anlage aufgeführten Normen und Spezifikationen auszuführen.

Die Akkreditierung ist gültig bis: 20.08.2014


Die Anlage ist Bestandteil der Urkunde und besteht aus 19 Seiten.

DAR-Registriernummer: DAT-PL-039/94-03

Frankfurt/Main, 21.08.2009


I.V. Dipl.-Ing. (FH) R. Egnor
Leiter der Akkreditierungsstelle

Mitglied in EA, ILAC, IAF



Siehe Hinweis auf der Rückseite

Deutsche Akkreditierungsstelle GmbH

Office Berlin
Spittelmarkt 10
10117 Berlin

Office Frankfurt am Main
Gartenstraße 6
60594 Frankfurt am Main

Office Braunschweig
Bundesallee 100
38116 Braunschweig

The publication of extracts of the accreditation certificate is subject to the prior written approval by Deutsche Akkreditierungsstelle GmbH (DAkKS). Exempted is the unchanged form of separate disseminations of the cover sheet by the conformity assessment body mentioned overleaf.

No impression shall be made that the accreditation also extends to fields beyond the scope of accreditation attested by DAkKS.

The accreditation was granted pursuant to the Act on the Accreditation Body (AkkStelleG) of 31 July 2009 (Federal Law Gazette I p. 2625) and the Regulation (EC) No 765/2008 of the European Parliament and of the Council of 9 July 2008 setting out the requirements for accreditation and market surveillance relating to the marketing of products (Official Journal of the European Union L 218 of 9 July 2008, p. 30). DAkKS is a signatory to the Multilateral Agreements for Mutual Recognition of the European co-operation for Accreditation (EA), International Accreditation Forum (IAF) and International Laboratory Accreditation Cooperation (ILAC). The signatories to these agreements recognise each other's accreditations.

The up-to-date state of membership can be retrieved from the following websites:

EA: www.european-accreditation.org

ILAC: www.ilac.org

IAF: www.laf.nu



Deutsche Akkreditierungsstelle GmbH

Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1 subsection 1 AkkStelleGBV
Signatory to the Multilateral Agreements of
EA, ILAC and IAF for Mutual Recognition

Accreditation



The Deutsche Akkreditierungsstelle GmbH attests that the testing laboratory

Karlsruher Institut für Technologie (KIT)
Institut für Elektroenergiesysteme und Hochspannungstechnik (IEH)
Engesserstraße 11, 76128 Karlsruhe

is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out tests in the following fields:

Electromagnetic Compatibility (EMC); High Voltage, Power Cable

The accreditation certificate shall only apply in connection with the notice of accreditation of 10.07.2014 with the accreditation number D-PL-11068-09 and is valid until 09.07.2019. It comprises the cover sheet, the reverse side of the cover sheet and the following annex with a total of 21 pages.

Registration number of the certificate: D-PL-11068-09-00

Frankfurt am Main, 10.07.2014


Dipl.-Ing. (FH) Ralf Egner
Abteilungsleiter

This document is a translation. The definitive version is the original German accreditation certificate.

See notes overleaf.



Deutsche Akkreditierungsstelle GmbH

Annex to the Accreditation Certificate D-PL-11068-09-00 according to DIN EN ISO/IEC 17025:2005

Period of validity: 10.07.2014 to 09.07.2019

Date of issue: 10.07.2014

Holder of certificate:

Karlsruher Institut für Technologie (KIT)
Institut für Elektroenergiesysteme und Hochspannungstechnik (IEH)
Engesserstraße 11, 76128 Karlsruhe

Tests in the fields:

Electromagnetic Compatibility (EMC), High Voltage, Power Cable


Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 60034-15:2009 DIN EN 60034- 15:2010 VDE 0530-15:2010	Rotating electrical machines - Part 15: Impulse voltage withstand levels of form- wound stator coils for rotating a.c. machines	
High Voltage	IEC 60044-3:2002 DIN EN 60044-3:2003 VDE 0414-44-3:2003	Instrument transformers - Part 3: Combined transformers	
High Voltage	IEC 60044-7:1999 DIN EN 60044-7:2000 VDE 0414-44-7:2000	Instrument transformers - Part 7: Electronic voltage transformers	
High Voltage	IEC 60044-8:2002 DIN EN 60044-8:2003 VDE 0414-44-8:2003	Instrument transformers - Part 8: Electronic current transformers	
High Voltage	IEC 60060-1:2010 DIN EN 60060-1:2011 VDE 0432-1:2011	High-voltage test techniques - Part 1: General definitions and test requirements	


This document is a translation. The definitive version is the original German annex to the accreditation certificate.



Annex to the Accreditation Certificate D-PL-11068-09-00


Department	Standard / In house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 60060-2:2010 DIN EN 60060-2:2011 VDE 0432-2:2011	High-voltage test techniques – Part 2 Measuring systems	
High Voltage	IEC 60068-2-1:2007 DIN EN 60068-2-1:2008	Environmental testing - Part 2-1: Tests - Test A: Cold	
High Voltage	IEC 60068-2-11:1981 DIN EN 60068-2-11 IEC 60068-2-14:2009 DIN EN 60068-2-14:2010 VDE 0468-2-14:2010	Environmental testing - Part 2: Tests. Test Ka: Salt mist Environmental testing - Part 2-14: Tests - Test N: Change of temperature	
High Voltage	IEC 60068-2-17:1994 DIN EN 60068-2-17:1995	Basic environmental testing procedures - Part 2: Tests - Test Q: Sealing	
High Voltage	IEC 60068-2-2:2007 DIN EN 60068-2-2:2008 VDE 0468-2-2:2008	Environmental testing - Part 2-2: Tests - Test B: Dry heat	
High Voltage	IEC 60068-2-21:2006 DIN EN 60068-2-21:2007	Environmental testing - Part 2-21: Tests - Test U: Robustness of terminations and integral mounting devices	
High Voltage	IEC 60068-2-38:2009 DIN EN 60068-2-38:2010 VDE 0468-2-38:2010	Environmental testing - Part 2-38: Tests - Test Z/AD: Composite temperature/humidity cyclic test	
High Voltage	IEC 60076-1:2011 DIN EN 60076-1:2012 VDE 0532-76-1:2012	Power transformers - Part 1: General	
High Voltage	IEC 60076-11:2004 DIN EN 60076-11:2005 VDE 0532-76-11:2005	Power transformers - Part 11: Dry-type transformers	
High Voltage	IEC 60076-16:2011 DIN EN 60076-16:2012 VDE 0532-76-16:2012	Power transformers - Part 16: Transformers for wind turbine applications	





Annex to the Accreditation Certificate D-PL-11068-09-00


Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 60076-3:2013 DIN EN 60076-3:2012 VDE 0532-76-3:2012	Power transformers - Part 3: Insulation levels, dielectric tests and external clearances in air	
High Voltage	IEC 60076-4:2002 DIN EN 60076-4:2003 VDE 0532-76-4:2003	Power transformers - Part 4: Guide to the lightning impulse and switching impulse testing - Power transformers and reactors	
High Voltage	IEC 60076-6:2007 DIN EN 60076-6:2008 VDE 0532-76-6:2009	Power transformers - Part 6: Reactors	
High Voltage	IEC 60099-4:2009 DIN EN 60099-4:2010 VDE 0675-4:2010	Surge arresters - Part 4: Metal-oxide surge arresters without gaps for a.c. systems	
High Voltage	IEC 60137:2008 DIN EN 60137:2009 VDE 0674-5:2009	Insulated bushings for alternating voltages above 1 000 V	
High Voltage	IEC 60143-1:2004 DIN EN 60143-1:2004 VDE 0560-42:2004	Series capacitors for power systems - Part 1: General	
High Voltage	IEC 60156:1995 DIN EN 60156:1996 VDE 0370-5:1996	Insulating liquids - Determination of the breakdown voltage at power frequency - Test method	
High Voltage	IEC 60168:2001 DIN EN 60168:2001 VDE 0674-1:2001	Tests on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltages greater than 1000 V	
High Voltage	IEC 60214-1:2003 DIN EN 60214-1:2003 VDE 0532-214-1:2003	Tap-changers - Part 1: Performance requirements and test methods	
High Voltage	IEC 60243-1:2013 DIN EN 60243-1:1999 VDE 0303-21:1999	Electric strength of insulating materials - Test methods - Part 1: Tests at power frequencies	
High Voltage	IEC 60243-2:2001 DIN EN 60243-2:2001 VDE 0303-22:2001	Electric strength of insulating materials - Test methods - Part 2: Additional requirements for tests using direct voltage	



[Handwritten signature]

Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 60243-3:2001 DIN EN 60243-3:2002 VDE 0303-23:2002	Electric strength of insulating materials - Test methods - Part 3: Additional requirements for 1,2/50 μ s impulse tests	
High Voltage	IEC 60252-1:2013 DIN EN 60252-1:2011 VDE 0560-8:2011	AC motor capacitors - Part 1: General - Performance, testing and rating - Safety requirements - Guidance for installation and operation	
High Voltage	IEC 60270:2000 DIN EN 60270:2001 VDE 0434:2001	High-voltage test techniques - Partial discharge measurements	
High Voltage	IEC 60273:1990 DIN IEC 60273:1993 VDE 0674-4:1993	Characteristic of indoor and outdoor post insulators for systems with nominal voltages greater than 1000 V	
High Voltage	IEC 60282-1:2009 DIN EN 60282-1:2010 VDE 0670-4:2010	High-voltage fuses - Part 1: Current-limiting fuses	
High Voltage	IEC 60358-1:2013 DIN EN 60358-1:2013 VDE 0560-2:2013	Corrigendum 1 - Coupling capacitors and capacitor dividers - Part 1: General rules	
High Voltage	IEC 60383-1:1993 DIN EN 60383-1:2001 VDE 0446-1:2001	Insulators for overhead lines with a nominal voltage above 1000 V - Part 1: Ceramic or glass insulator units for a.c. systems - Definitions, test methods and acceptance criteria	
High Voltage	IEC 60383-2:1993 DIN EN 60383-2:1995 VDE 0446-4:1995	Insulators for overhead lines with a nominal voltage above 1000 V - Part 2: Insulator strings and insulator sets for a.c. systems - Definitions, test methods and acceptance criteria	
High Voltage	IEC 60433:1998 DIN EN 60433:1999 VDE 0446-7:1999	Insulators for overhead lines with a nominal voltage above 1 000 V - Ceramic insulators for a.c. systems - Characteristics of insulator units of the long rod type	



Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 60437:1997 DIN EN 60437:1998 VDE 0674-6:1998	Radio interference test on high-voltage insulators	
High Voltage	IEC 60507:1991 DIN EN 60507:1994 VDE 0448-1:1994	Artificial pollution tests on high-voltage insulators to be used on a.c. systems	
High Voltage	IEC 60618:1978 EN 60618:1999	Inductive voltage dividers	
High Voltage	IEC 60644:2009 DIN EN 60644:2010 VDE 0670-401:2010	Specification for high-voltage fuse-links for motor circuit applications	
High Voltage	IEC 60660:1999 DIN EN 60660:2000 VDE 0441-3:2000	Insulators - Tests on indoor post insulators of organic material for systems with nominal voltages greater than 1 000 V up to but not including 300 kV	
High Voltage	IEC 60700-1:2008 DIN EN 60700-1:2009 VDE 0553-1:2009	Thyristor valves for high voltage direct current (HVDC) power transmission - Part 1: Electrical testing	
High Voltage	IEC 60832-1:2010 DIN EN 60832-1:2010 VDE 0682-211:2010	Live working - Insulating sticks and attachable devices - Part 1: Insulating sticks	
High Voltage	IEC 60832-2:2010 DIN EN 60832-2:2010 VDE 0682-212:2010	Live working - Insulating sticks and attachable devices - Part 2: Part 2: Attachables devices	
High Voltage	IEC 60871-1:2005 DIN EN 60871-1:2006 VDE 0560-410:2006	Shunt capacitors for a.c. power systems having a rated voltage above 1000 V - Part 1: General	
High Voltage	IEC 60871-4:1996 DIN EN 60871-4:1997 VDE 0560-440:1997	Shunt capacitors for AC power systems having a rated voltage above 1000 V - Part 4: Internal fuses	
High Voltage	IEC 60895:2003 DIN EN 60895:2004 VDE 682-304:2004	Live working - Conductive clothing for use at nominal voltage up to 800 kV a.c. and +/- 600 kV d.c.	




[Handwritten signature]

Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 60900:2012 DIN EN 60900:2013 VDE 0682-201:2013	Live working - Hand tools for use up to 1 000 V a.c. and 1 500 V d.c.	
High Voltage	IEC 60903:2005 DIN EN 60903:1:2005 VDE 0682-311:1:2005	Live working - Gloves of insulating material	
High Voltage	IEC 60947-3:2012 DIN EN 60947-3:2012 VDE 0660-107:2012	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units	
High Voltage	IEC 60984:2005 DIN EN 60984:2003 VDE 0682-312:2003	Sleeves of insulating material for live working	
High Voltage	IEC 61071:2007 DIN EN 61071:2008 VDE 0560-120:2008	Capacitors for power electronics	
High Voltage	IEC 61071:2007 DIN EN 61071:2008 VDE 0560-120:2008	Capacitors for power electronics	
High Voltage	IEC 61219:2000 DIN EN 61219:1995 VDE 0683-200:1995	Corrigendum 1 - Live working - Earthing or earthing and short-circuiting equipment using lances as a short-circuiting device - Lance earthing	
High Voltage	IEC 61229:2002 DIN EN 61229/A2:2003 VDE 0682-551/A2:2003	Rigid protective covers for live working on a.c. installations	
High Voltage	IEC 61230:2008 DIN EN 61230:2009 VDE 0683-100:2009	Live working - Portable equipment for earthing or earthing and short-circuiting	
High Voltage	IEC 61236:2010 DIN EN 61236:2011 VDE 0682-651:2011	Live working - Saddles, stick clamps and their accessories	
High Voltage	IEC 61243-1:2009 DIN EN 61243-1:2010 VDE 0682-411:2010	Live working - Voltage detectors - Part 1: Capacitive type to be used for voltages exceeding 1 kV a.c.	

Period of validity: 10.07.2014 to 09.07.2019
Date of Issue: 10.07.2014

- Translation -



Page 6 of 21


[Handwritten signature]

Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 61243-2:2002 DIN EN 61243- 2/A2:2003 VDE 0682- 412/A1:2003	Live working - Voltage detectors - Part 2: Resistive type to be used for voltages of 1 kV to 36 kV a.c.	
High Voltage	IEC 61243-3:2009 DIN EN 61243-3:2011 VDE 0682-401:2011	Live working - Voltage detectors - Part 3: Two- pole low-voltage type	
High Voltage	IEC 61243-5:1997 DIN EN 61243-5:2002 VDE 0682-415:2002	Live working - Voltage detectors - Part 5: Voltage detecting systems (VDS)	
High Voltage	IEC 61284:1997 DIN EN 61284:1998 VDE 0212-1:1998	Overhead lines - Requirements and tests for fittings	
High Voltage	IEC 61325:1995 DIN EN 61325:1996 VDE 0446-5:1996	Insulators for overhead lines with a nominal voltage above 1000 V - Ceramic or glass insulator units for d.c. systems - Definitions, test methods and acceptance criteria	
High Voltage	IEC 61378-1:2012 DIN EN 61378-1:2012 VDE 0532-41:2012	Converter transformers - Part 1: Transformers for industrial applications	
High Voltage	IEC 61378-2:2001 DIN EN 61378-2:2001 VDE 0532-42:2001	Converter transformers - Part 2: Transformers for HVDC applications	
High Voltage	IEC 61462:2007 DIN EN 61462:2008 VDE 0441-102:2008	Composite hollow insulators - Pressurized and unpressurized insulators for use in electrical equipment with rated voltage greater than 1000 V - Definitions, test methods, acceptance criteria and design recommendations	
High Voltage	IEC 61466-1:2007 DIN EN 61466-1:2010 VDE 0441-4:2010	Composite string insulator units for overhead lines with a nominal voltage greater than 1000 V - Part 1: Standard strength classes and end fittings	
High Voltage	IEC 61466-2:2002 DIN EN 61466-2:2002 VDE 0441-5:2002	Composite string insulator units for overhead lines with a nominal voltage greater than 1000 V - Part 2: Dimensional and electrical characteristics	


Period of validity: 10.07.2014 to 09.07.2019
Date of issue: 10.07.2014

- Translation -



Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 61854:1998 DIN EN 61854:1999 VDE 0212-2:1999	Overhead lines - Requirements and tests for spacers	
High Voltage	IEC 61869-1:2007 DIN EN 61869-1:2010 VDE 0414-9-1:2010	Instrument transformers - Part 1: General requirements	
High Voltage	IEC 61869-2:2012 DIN EN 61869-2:2013 VDE 0414-9-2:2013	Instrument transformers - Part 2: Additional requirements for current transformers	
High Voltage	IEC 61869-3:2011 DIN EN 61869-3:2012 VDE 0414-9-3:2012	Instrument transformers - Part 3: Additional requirements for inductive voltage transformers	
High Voltage	IEC 61869-4:2013 VDE 0414-9-4:2008	Instrument transformers - Part 4: Additional requirements for combined customers	
High Voltage	IEC 61869-5:2011 DIN EN 61869-5:2012 VDE 0414-9-5:2012	Instrument transformers - Part 5: Additional requirements for capacitor voltage transformers	
High Voltage	IEC 61921:2003 DIN EN 61921:2004 VDE 0560-700:2004	Power capacitors - Low-voltage power factor correction banks	
High Voltage	IEC 61952:2008 DIN EN 61952:2009 VDE 0441-200:2009	Insulators for overhead lines - Composite line post insulators for A.C. systems with a nominal voltage greater than 1000 V - Definitions, test methods and acceptance criteria	
High Voltage	IEC 61954:2013 DIN EN 61954:2012 VDE 0553-100:2012	Static var compensators (SVC) - Testing of thyristor valves	
High Voltage	IEC 62146-1:2013	Grading capacitors for high-voltage alternating current circuit breakers	
High Voltage	IEC 62155:2003 DIN 62155:2004 VDE 0674-200:2004	Hollow pressurized and unpressurized ceramic and glass insulators for use in electrical equipment with rated voltages greater than 1000 V	



Annex to the Accreditation Certificate D-PL-11068-09-00


Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 62217:2012 DIN EN 62217:2013 VDE 0441-1000:2013	Polymeric HV insulators for indoor and outdoor use - General definitions, test methods and acceptance criteria	
High Voltage	IEC 62271-1:2011 DIN EN 62271-1:2012 VDE 0671-1:2012	High-voltage switchgear and controlgear - Part 1: Common specifications	
High Voltage	IEC 62271-100:2012 DIN EN 62271-100:2013 VDE 0671-100:2013	High-voltage switchgear and controlgear - Part 100: Alternating current circuit-breakers	
High Voltage	IEC 62271-102:2001 DIN EN 62271-102:2012 VDE 0671-102:2012	High-voltage switchgear and controlgear - Part 102: Alternating current disconnectors and earthing switches	
High Voltage	IEC 62271-102:2013 DIN EN 62271-102:2012 VDE 0671-102:2012	Amendment 2 - High-voltage switchgear and controlgear - Part 102: Alternating current disconnectors and earthing switches	
High Voltage	IEC 62271-104:2009 DIN EN 62271-104:2010 VDE 0671-104:2010	High-voltage switchgear and controlgear - Part 104: Alternating current switches for rated voltages of 52 kV and above	
High Voltage	IEC 62271-105:2012 DIN EN 62271-105:2013 VDE 0671-105:2013	High-voltage switchgear and controlgear - Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV	
High Voltage	IEC 62271-107:2012 DIN EN 62271-107:2013 VDE 0671-107:2013	High-voltage switchgear and controlgear - Part 107: Alternating current fused circuit-switchers for rated voltages above 1 kV up to and including 52 kV	
High Voltage	IEC 62271-108:2005 DIN EN 62271-108:2006 VDE 0671-108:2006	High-voltage switchgear and controlgear - Part 108: High-voltage alternating current disconnecting circuit-breakers for rated voltages of 72,5 kV and above	



[Handwritten signature]

Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / In house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	IEC 62271-200:2011 DIN EN 62271- 200:2012 VDE 0671-200:2012	High-voltage switchgear and controlgear - Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	
High Voltage	IEC 62271-201:2006 DIN EN 62271- 201:2007 VDE 0671-201:2007	High-voltage switchgear and controlgear - Part 201: AC insulation-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	
High Voltage	IEC 62271-203:2013 DIN EN 62271- 203:2012 VDE 0671-203:2012	Corrigendum 1 - High-voltage switchgear and controlgear - Part 203: Gas-insulated metal- enclosed switchgear for rated voltages above 52 kV	
High Voltage	IEC 62271-206:2011 DIN EN 62271- 206:2011 VDE 0671-206:2011	High-voltage switchgear and controlgear - Part 206: Voltage presence indicating systems for rated voltages above 1 kV and up to and including 52 kV	
High Voltage	IEC/PAS 60099-7:2004 DIN EN 60099-1:2000 VDE 0675-1:2000	Surge arresters - Part 7: Glossary of terms and definitions from IEC publications 60099-1, 60099-4, 60099-6, 61643-1, 61643-12, 61643- 21, 61643-311, 61643-321, 61643-331 and 61643-341	
High Voltage	IEC/TR 61294:1993 DIN VDE 0380-5:1995	Insulating liquids - Determination of the partial discharge inception voltage (PDIV) - Test procedure	
High Voltage	IEC/TR 62271- 305:2009	High-voltage switchgear and controlgear - Part 305: Capacitive current switching capability of air-insulated disconnectors for rated voltages above 52 kV	
High Voltage	IEC/TS 61639:1996	Direct connection between power transformers and gas-insulated metal- enclosed switchgear for rated voltages of 72,5 kV and above	
High Voltage	DIN EN 137000:1998 VDE 0560-800:1998	Generic specification - Fixed aluminium electrolytic a.c. capacitors with non-solid electrolyte for use with motors	




[Handwritten signature]

Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	DIN EN 50089:1994 VDE 0670-806:1994	Cast resin partitions for metal enclosed gas-filled high voltage switchgear and controlgear	
High Voltage	DIN EN 50482:2008 VDE 0414-6:2008	Instrument transformers - Three-phase inductive voltage transformers having Um up to 52 kV	
High Voltage	DIN IEC 60871-2:1993 VDE 0560-420:1993 IEC/TS 60871-2:1996	Shunt capacitors for AC power systems having a rated voltage above 1000 V - Part 1: General	
High Voltage	DIN VDE 0212 Teil 55:1998 VDE 0212-55:1998	Fittings for overhead lines and switchgear; dynamic-mechanical behaviour of antivibration fittings	
High Voltage	DIN VDE 0303 Teil 4:1969 VDE 0303-4:1969	Specification for electrical tests of insulating materials; Determination of the dielectric properties	
High Voltage	DIN VDE 0441-1:1985	Tests on insulators of organic material for systems with nominal alternating voltages greater than 1000 V; tests on materials	
High Voltage	DIN VDE 0532- 21:1982 VDE 0532-21:1982 DIN 57532-21:1982	Transformers and reactors; starting transformers and starting reactors [VDE Specification]	
High Voltage	DIN VDE 0560-1:1969 VDE 0560-1:1969 DIN VDE 0560- 11:1970	Rules for capacitors; part 11: Rules for capacitors of more than 600 V for the equalizing of pulsating direct voltages	
High Voltage	DIN VDE 0560-3:1968	Regeln für Kondensatoren; Teil 3: Regeln für Kondensatoren für Kopplung, Spannungsmessung und Überspannungsschutz 0560-3	
High Voltage	DIN VDE 0660- 112:1987	Switchgear and controlgear; additional specification for d.c. air-break switches, air-break disconnectors and air-break switch-disconnectors exceeds 1200 V but not exceeds 3000 V	
High Voltage	DIN VDE 0681-1:1986	Operating, testing and safe-guarding devices for work on electrically energized systems with rated voltages exceeding 1 kV; part 1: general requirements for the parts 2 to 4	


Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
High Voltage	DIN VDE 0681-2:2013	Live working - Devices for operating, testing and safe-guarding with rated voltages exceeding 1 kV - Part 2: Switching sticks	
High Voltage	DIN VDE 0681-3:2013	Live working - Devices for operating, testing and safe-guarding with rated voltages exceeding 1 kV - Part 3: Fuse tongs	
High Voltage	DIN VDE 0681-6:1985	Operating and testing devices for work and safe guarding on electrically energized systems with rated voltages exceeding 1 kV; voltage detectors to be used for overhead contact systems	
High Voltage	DIN VDE 0682-421:2008	Live working - Voltage detectors - Capacitive type to be used for a.c. systems of 15 kV and 110 kV with a frequency of 16,7 Hz	
High Voltage	DIN VDE 0682-552:2003	Live working - Insulating protective barriers above 1 kV	
High Voltage	DIN VDE 0682-621:2004	Arbeiten unter Spannung - Vorrichtung zum Reinigen durch Absaugen von unter Spannung stehenden Teilen mit emessungsspannungen über 1 kV bis 36 kV	
Power cable	IEC 60141-1:1998	Tests on oil-filled and gas-pressure cables and their accessories - Part 1: Oil-filled, paper or polypropylene paper laminate insulated, metal-sheathed cables and accessories for alternating voltages up to and including 500 kV	
Power cable	IEC 60141-2:1967	Tests on oil-filled and gas-pressure cables and their accessories. Part 2: Internal gas-pressure cables and accessories for alternating voltages up to 275 kV	
Power cable	IEC 60141-3:1967	Tests on oil-filled and gas-pressure cables and their accessories. Part 3: External gas-pressure (gas compression) cables and accessories for alternating voltages up to 275 kV	



Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
Power cable	IEC 60141-4:1990	Tests on oil-filled and gas-pressure cables and their accessories. Part 4: Oil-impregnated paper-insulated high pressure oil-filled pipe-type cables and accessories for alternating voltages up to and including 400 kV	
Power cable	IEC 60230:1966 DIN EN 60230:2003 VDE 0481-230:2003	Impulse tests on cables and their accessories	
Power cable	IEC 60502-1:2009	Power cables with extruded insulation and their accessories for rated voltages from 1 kV (Um = 1,2 kV) up to 30 kV (Um = 36 kV) - Part 1: Cables for rated voltages of 1 kV, (Um = 1,2 kV) and 3 kV (Um = 3,6 kV)	
Power cable	IEC 60502-2:2005	Power cables with extruded insulation and their accessories for rated voltages from 1 kV (Um = 1,2 kV) up to 30 kV (Um = 36 kV) - Part 2: Cables for rated voltages from 6 kV (Um = 7,2 kV) up to 30 kV (Um = 36 kV)	
Power cable	IEC 60502-4:2010	Power cables with extruded insulation and their accessories for rated voltages from 1 kV (Um = 1,2 kV) up to 30 kV (Um = 36 kV) - Part 4: Test requirements on accessories for cables with rated voltages from 6 kV (Um = 7,2 kV) up to 30 kV (Um = 36 kV)	
Power cable	IEC 60840:2011	Power cables with extruded insulation and their accessories for rated voltages above 30 kV (Um = 36 kV) up to 150 kV (Um = 170 kV) - Test methods and requirements	
Power cable	IEC 60885-2:1987 DIN 60885-2:2004 VDE 0481-885-2:2004	Electrical test methods for electric cables. Part 2: Partial discharge tests	
Power cable	IEC 60885-3:1988 DIN EN 60885-3:2004 VDE 0481-885-3:2004	Electrical test methods for electric cables. Part 3: Test methods for partial discharge measurements on lengths of extruded power cables	



Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
Power cable	IEC 61238-1:2003 DIN EN 61238-1:2004 VDE 0220-100:2004 IEC/TRF 61238-1:2011	Compression and mechanical connectors for power cables for rated voltages up to 30 kV (Um = 36 kV) - Part 1: Test methods and requirements	
Power cable	IEC 61284:1998 DIN EN 61284:1998 VDE 0212-1:1998	Corrigendum 1 - Overhead lines - Requirements and tests for fittings	
Power cable	IEC 61442:2005 DIN EN 61442:2006 VDE 0278-442:2006	Test methods for accessories for power cables with rated voltages from 6 kV (Um = 7,2 kV) up to 30 kV (Um = 36 kV)	
Power cable	IEC 61854:1998 DIN EN 61854:1999 VDE 0212-2:1999	Overhead lines - Requirements and tests for spacers	
Power cable	IEC 62067:2011 DIN IEC 62067:2013 VDE 0276-2067:2013	Power cables with extruded insulation and their accessories for rated voltages above 150 kV (Um = 170 kV) up to 500 kV (Um = 550 kV) - Test methods and requirements	
Power cable	DIN EN 50393:2006 VDE 0278-393:2006	Test methods and requirements for accessories for use on distribution cables of rated voltage 0,6/1,0 (1,2) kV	
Power cable	HD 620 S2:2010 DIN VDE 0276-620:2010	Power cables - Distribution cables with extruded insulation for rated voltages from 3,6/6 (7,2) kV up to and including 20,8/36 (42) kV; German version HD 620 S2:2010, parts 0, 1 and 10-C	
Power cable	HD 621 S1:1996 DIN VDE 0276-621:1997	Power cables - Part 621: Medium voltage impregnated paper insulated distribution cables; German version HD 621 S1:1996 Parts 1, 2, 3C and 4C	
Power cable	HD 626 S1:1996 DIN VDE 0276-626/A1:1998	Power cables Part 626- Overhead distribution cables of rated voltage U ₀ /U(U _m):0,6/1 (1,2) kV; German version HD 626 S1 Parts 1, 2 and 4 F-1:1996	
Power cable	HD 629.1 S2:2006 DIN VDE 0278-629-1:2009	Test requirements on accessories for use on power cables of rated voltage from 3,6/6(7,2) kV up to 20,8/36(42) kV - Part 1: Cables with extruded insulation	




Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
Power cable	HD 629.2 S2:2006 DIN VDE 0278-629- 2:2009	Test requirements on accessories for use on power cables of rated voltage from 3,6/6(7,2) kV up to 20,8/36(42) kV - Part 2: Cables with impregnated paper insulation	
Power cable	HD 632 S3:2012 DIN VDE 0276-632- 3:2013 VDE 0276-632-3:2013	Power cables with extruded insulation and their accessories for rated voltages above 36 kV ($U_m = 42$ kV) up to 150 kV ($U_m = 170$ kV); German version HD 632 S1 Parts 1, 3D, 4D and 5D:1998	
Power cable	HD 633 S1:1997 DIN VDE 0276- 633:1999 VDE 0276-633:1999	Prüfungen an Ölkabeln mit einer Isolierung aus Papier oder polypropylenbeschichtetem Papier und Metallmantel und Garnituren für Wechselspannungen bis einschließlich 400 kV ($U_m=420$ kV)	
Power cable	HD 634 S1:1997 DIN VDE 0276- 634:1999 VDE 0276-634:1999	Tests on internal gas-pressure cables and accessories for alternating voltages up to and including 275 kV ($U_m=300$ kV); German version HD 634 S1 Parts 1 and 3C:1997	
Power cable	HD 635 S1:1997 DIN VDE 0276- 635:1999 VDE 0276-635:1999	Tests on external gas-pressure (gas compression) cables and accessories for alternating voltages up to and including 275 kV ($U_m=300$ kV); German version HD 635 S1 Parts 1 and 3C:1997	
Power cable	DIN VDE 0212 Teil 55:1998 VDE 0212-55:1998	Fittings for overhead lines and switchgear; insulation behaviour of fittings for insulated overhead lines	
Power cable	DIN VDE 0220-1:1971	Specifications for single- and multiple cable clamps with insulating parts in electrical power cable installations up to 1000 V	
Power cable	DIN VDE 0220-2:1971	Bestimmungen für Preßverbinder in Starkstromkabelanlagen bis 1000 V	
Power cable	DIN 57220-3:1977 DIN VDE 0220-3:1977 VDE 0220-3:1997	Specifications for single- and multiple cable clamps with insulating parts in electrical power cable installations up to 1000 V	
Power cable	DIN VDE 0271:2008 VDE 0271:2008	Power cables - Specifications for power cables 0,6/1 kV and above for special applications	

Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
Power cable	DIN VDE 0276-632:1999 VDE 0276-632:1999	Power cables with extruded insulation and their accessories for rated voltages above 36 kV ($U_m = 42$ kV) up to 150 kV ($U_m = 170$ kV); German version HD 632 S1 Parts 1, 3D, 4D and 5D:1998	
Power cable	DIN VDE 0276-634:1999 VDE 0276-634:1999	Tests on internal gas-pressure cables and accessories for alternating voltages up to and including 275 kV ($U_m=300$ kV); German version HD 634 S1 Parts 1 and 3C:1997	
Power cable	DIN VDE 0472-505:1983 DIN 57472-505:1983 VDE 0472-505:1983	Testing of cables, wires and flexible cords; loss factor, dielectric loss coefficient and leakance [VDE Specification]	
Power cable	DIN VDE 0472-512:1985	Testing of cables, wires and flexible cords; resistance between protective conductor and semi-conductive layer	
Power cable	DIN VDE 0472-603:1989 VDE 0472-603:1989	Prüfung an Kabeln und isolierten Leitungen; Biegeverhalten	
Power cable	IEEE 404:2012	IEEE Standard for Extruded and Laminated Dielectric Shielded Cable Joints Rated 2.5 kV to 500 kV	
Power cable	IEEE 48:2009	Standard for test procedures and requirements for alternating-current cable terminations used on shielded cables having laminated insulation rated 2.5 kV through 765 kV or extruded insulation rated 2.5 kV through 500 kV	
Power cable	CIGRE 415:2010	Test Procedures for HV Transition Joints for Rated Voltages 30 kV up to 500 kV	




Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
Generic Standards			
EMC	DIN EN 61000-6-1; VDE 0839-6-1:2007	Electromagnetic compatibility (EMC) - Part 6-1: Generic standards -Immunity for residential, commercial and light-industrial environments	Only immunity according to DIN EN 61000-4-3
EMC	EN 61000-6-1:2007	Electromagnetic compatibility (EMC) - Part 6-1: Generic standards -Immunity for residential, commercial and light-industrial environments	Only immunity according to DIN EN 61000-4-3
EMC	IEC 61000-6-1:2005	Electromagnetic compatibility (EMC) - Part 6-1: Generic standards -Immunity for residential, commercial and light-industrial environments	Only immunity according to DIN EN 61000-4-3
EMC	DIN EN 61000-6-2; VDE 0839-6-2:2011	Electromagnetic compatibility (EMC) - Part 6-1: Generic standards -Immunity for residential, commercial and light-industrial environments	Only immunity according to DIN EN 61000-4-3
EMC	EN 61000-6-2:2005	Electromagnetic compatibility (EMC) - Part 6-1: Generic standards -Immunity for residential, commercial and light-industrial environments	Only immunity according to DIN EN 61000-4-3


Period of validity: 10.07.2014 to 09.07.2019
Date of issue: 10.07.2014

- Translation -



Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
EMC	IEC 61000-6-2:2005	Electromagnetic compatibility (EMC) - Part 6-2: Generic standards - Immunity for industrial environments	Only immunity according to DIN EN 61000-4-3
EMC	DIN EN 61000-6-3; VDE 0839-6-3:2012	Electromagnetic compatibility (EMC) - Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments	Only conducted emission
EMC	EN 61000-6-3:2007 + A1:2011 + A2:2012	Electromagnetic compatibility (EMC) - Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments	Only conducted emission
EMC	IEC 61000-6-3:2006 + A1:2010	Electromagnetic compatibility (EMC) - Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments	Only conducted emission
EMC	DIN EN 61000-6-4; VDE 0839-6-4:2011	Electromagnetic compatibility (EMC) - Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments	Only conducted emission
EMC	EN 61000-6-4:2007 + A1:2011	Electromagnetic compatibility (EMC) - Part 6-4: Generic standards - Emission standard for industrial environments	Only conducted emission




[Handwritten signature]

Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / in house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
EMC	IEC 61000-6-4:2006 + A1:2010	Electromagnetic compatibility (EMC) - Part 6-4: Generic standards - Emission standard for industrial environments	Only conducted emission
Basic Standards			
EMC	DIN EN 61000-4-3; VDE 0847-4-3:2011	Electromagnetic compatibility (EMC) - Part 4-3: Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test (IEC 61000-4-3:2006 + A1:2007 + A2:2010); German version EN 61000-4-3:2006 + A1:2008 + A2:2010	
EMC	EN 61000-6-4:2007 + A1:2011	Electromagnetic compatibility (EMC) - Part 6-4: Generic standards - Emission standard for industrial environments	
EMC	IEC 61000-6-4:2006 + A1:2010	Electromagnetic compatibility (EMC) - Part 6-4: Generic standards - Emission standard for industrial environments	
EMC	DIN EN 61000-4-8; VDE 0847-4-8:2010	Electromagnetic compatibility (EMC) - Part 4-8: Testing and measurement techniques - Power frequency magnetic field immunity test (IEC 61000-4-8:2009); German version EN 61000-4-8:2010	
EMC	EN 61000-4-8:2010	Electromagnetic compatibility (EMC) - Part 4-8: Testing and measurement techniques - Power frequency magnetic field immunity test	
EMC	IEC 61000-4-8:2009	Electromagnetic compatibility (EMC) - Part 4-8: Testing and measurement techniques - Power frequency magnetic field immunity test	


Period of validity: 10.07.2014 to 09.07.2019
Date of issue: 10.07.2014

- Translation -



Annex to the Accreditation Certificate D-PL-11068-09-00


Department	Standard / In house procedure / Version	Title of standard or in house procedure (deviations / modifications of standard)	Test area / reductions
EMC	DIN EN 61000-4-13; VDE 0847-4-13:2010 IEC 61000-4-13:2002 + A1:2009 EN 61000-4-13:2002 + A1:2009	Electromagnetic compatibility (EMC) - Part 4-13: Testing and measurement techniques - Harmonics and interharmonics including mains signaling at a.c. power port, low frequency immunity tests (IEC 61000-4-13:2002 + A1:2009); German version EN 61000-4-13:2002 + A1:2009	Only single phase
EMC	EN 61000-4-13:2002 + A1:2009	Electromagnetic compatibility (EMC) - Part 4-13: Testing and measurement techniques - Harmonics and interharmonics including mains signaling at a.c. power port, low frequency immunity tests	Only single phase
EMC	IEC 61000-4-13:2002 + A1:2009	Electromagnetic compatibility (EMC) - Part 4-13: Testing and measurement techniques - Harmonics and interharmonics including mains signaling at a.c. power port, low frequency immunity tests	Only single phase
EMC	DIN EN 55014-1; VDE 0875-14-1:2012 CISPR 14-1:2005 + A1:2008 + Cor. :2009 + A2:2011	Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus - Part 1: Emission (CISPR 14-1:2005 + A1:2008 + Cor. :2009 + A2:2011); German version EN 55014-1:2006 + A1:2009 + A2:2011	No radiated emission, no toys
EMC	EN 55014-1:2006 + A1:2009 + A2:2011	Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus - Part 1: Emission	No radiated emission, no toys
EMC	CISPR 14-1:2005 + A1:2008 + Cor. :2009 + A2:2011	Electromagnetic compatibility - Requirements for household appliances, electric tools and similar apparatus - Part 1: Emission	No radiated emission, no toys



Handwritten signature

Annex to the Accreditation Certificate D-PL-11068-09-00

Department	Standard / In house procedure / Version	Title of standard or In house procedure (deviations / modifications of standard)	Test area / reductions
EMC	DIN EN 55014-2; VDE 0875-14-2:2009	Electromagnetic compatibility - Requirements for household appliances , electric tools and similar apparatus - Part 2: Immunity - Product family standard (IEC/CISPR 14-2:1997 + A1:2001 + A2:2008); German version EN 55014-2:1997 + Corrigendum 1997 + A1:2001 + A2:2008	Only immunity according to DIN EN 61000-4-3
EMC	EN 55014-2:1997 + Corrigendum 1997 + A1:2001 + A2:2008	Electromagnetic compatibility - Requirements for household appliances , electric tools and similar apparatus - Part 2: Immunity - Product family standard	Only immunity according to DIN EN 61000-4-3
EMC	IEC/CISPR 14-2:1997 + A1:2001 + A2:2008	Electromagnetic compatibility - Requirements for household appliances , electric tools and similar apparatus - Part 2: Immunity - Product family standard	Only immunity according to DIN EN 61000-4-3
EMC	IEEE 299:2006	IEEE Standard Method for Measuring the Effectiveness of Electromagnetic Shielding Enclosures	
EMC	VG 95373-15:2004	Elektromagnetische Verträglichkeit - Elektromagnetische Verträglichkeit von Geräten - Teil 15: Messverfahren für Kopplungen und Schirmungen	



[Handwritten signature]

ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Щепселни кабелни глави за КРУ за едножилни полиетиленови кабели 10 kV и 20 kV”

Приложение № 5



ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ

Долуподписаният /-ната/ инж. Георги Димитров Георгиев
в качеството ми на Управител на "ЕЛЕКТРОГЕЦ" ООД
със седалище и адрес на управление: гр. София, ул. Майор Горталов 9А, вписано в Търговския
регистър към Агенцията по вписванията с ЕИК 130 761 934, за участие в процедура за
възлагане на обществена поръчка за Доставка и монтаж на Бетонови комплектни
трансформаторни постове /БКТП/, РЕФ. № PPD 15-042,


ДЕКЛАРИРАМ,

че предлагания материал Щепселни кабелни глави за КРУ за едножилни полиетиленови кабели
10 kV и 20 kV Cellpack тип CGS 250A, CWS 250A, CTS 630A и CTKS 630A съответстват с
изискванията на техническата спецификация на стандарт за материал "Щепселни кабелни
глави за КРУ за едножилни полиетиленови кабели 10 kV и 20 kV, вкл. на параграфи
„Характеристика на материала“ и „Съответствие на предложеното изпълнение с
стандартизационните документи“ от документацията по търг с реф. № РЕФ. № PPD 15-042.

Дата 20.01.2016 г.

Декларатор:

инж. Георги Димитров Георгиев



/име, подпис и печат/



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Щелселни кабелни глави за КРУ за едножилни полиетиленови кабели 10 kV и 20 kV”

Приложение № 6





CGS 24kV 250A 25 – 95/EGA
U₀/U(U_m) 6/10(12)kV - 12/20(24) kV

Инструкция за монтаж

Кабелна глава щепселна, права за едножилни кабели с полимерна изолация за напрежения до 24 kV

224446/0607/1/6

CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com
e-mail: electrical.products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45

CELLPACK
Electrical Products
РЕКТОРЪТ
ООА

A handwritten signature in black ink, located at the bottom right of the page.

Общи указания:

- Проверете дали обхватът на кабелните аксесоари е подходящи за размера на кабела.
- Проверете съдържанието на комплекта съгласно опаковъчния лист.
- Старателно прочетете инструкциите за монтаж.

Монтажът трябва да се извършва само от компетентен персонал.

Производителят не носи отговорност за повреди, причинени от неправилен монтаж.


Кабелна глава щепселна, права тип CGS 250A 24kV 25-95/EGA

Сечения:

Напрежение $U_0/U(U_m)$ kV	Сечение на кабела RM/RE (*) mm ²
6/10(12) kV	50 - 95
8,7/15(17,5) kV	25 - 95
12/20(24) kV	25 - 95

(*) Минимален диаметър над кабелната изолация от 14,7 мм

Нагласяне




- Почистете грижливо края на кабела до 1м.
- Нагласете кабела над средата на клемата оставяйки свободна дължина $L = 200-500$ мм. Изрежете излишното.
- Маркирайте кабела на 150 mm от центъра на клемата.

Подготовка на кабела


Кабел с екран от медни жички:

1a)




- Отстранете външната изолация на кабела до маркировката.
- Подгънете назад медните жици на екрана и ги фиксирайте към външната изолация на кабела с PVC лента (Fig. 1a).
- Отрежете кабела на дължина **130 mm**.
- Внимателно отстранете външния полупроводим слой, така че да остане слой с дължина **30 mm**.

2a)




- Уверете се, че ръбът на слоя е гладък.
- Отстранете XLPE изолацията на кабела на размер **35 mm**.
- Почистете старателно XLPE изолацията и външния полупроводим слой на кабела.

3a)



- Защитете края на жилото с PVC-лента.
- Навийте 2/3 от дължината на уплътняващата лента DM1 върху **20 mm** от екрана и върху **10 mm** от полупроводящия слой (с разтягане 50%)
- Нанесете на и около ръба на полупроводящия слой смазка и пълнеж GM1 (оформете пръстен).
- Навлажнете изолацията със смазка и пълнеж GM1.




①


②

Кабел с лентов екран:

1b)



2b)




- Отстранете външната изолация на кабела до маркировката + 20mm.
- Отрежете кабела както е показано на фигурата.
- Отрежете лентовия екран, така че върху кабела да остане **20 мм** от него.
- Внимателно отстранете външния полупроводим слой, така че да остане слой с дължина **30 мм**.

Уверете се, че ръбът на слоя е гладък.


- Отстранете XLPE изолацията на кабела на размер **35 мм**.
- Почистете старателно изолацията и външния полупроводим слой на кабела.

3b)



- Защитете края на жилото с PVC-лента.
- Фиксирайте заземителната оплетка и заземителния проводник чрез ролкова пружина към лентовия екран (заземителния комплект се поръчва отделно).
- Навийте 2/3 от дължината на уплътняващата лента DM1 върху **20 mm** от екрана и върху **10 mm** от полупроводящия слой (фиг. 3b).
- Нанесете на и около ръба на полупроводящия слой смазка и пълнеж GM1 (оформете пръстен).
- Навлажнете изолацията със смазка и пълнеж GM1.

4)




5)



- Навлажнете лентите на апликатора АН със силиконовата кърпичка.
- Вмъкнете апликатора АН в елемента за контрол на полето FSE и ги нахлузете върху кабела до достигане на уплътняващата обвивка.
- Отстранете апликатора, издърпвайки лентите му една по една.
- Позиционирайте елемента за контрол на полето като леко го завъртате (фиг. 5).
- Отстранете PVC лентата от края на жилото на кабела.
- Монтирайте кабелния накрайник с болтове с откъсващи се глави, съгласно отделна инструкция.
- Моля, обърнете внимание, че щифтът на кабелния накрайник трябва да бъде съосен с оста на клемата за присъединяване.
- Почистете старателно повърхността на елемента за контрол на полето FSE.



6)



- Навлажнете тялото на щепселна глава и повърхността на елемента за контрол на полето FSE със смазка и пълнеж GM1.
- Нахлузете тялото на щепселна глава върху кабела докато контактната шпилка се вмъкне в тялото.





8)



- Навийте останалата **1/3** от лентата DM1 между края на тялото и зоната за запечатване.


- Навийте лента № 2585 приблизително **20 мм** върху края на тяло до края на зоната за запечатване (с разтягане 20%).

9)




- Навлажнете повърхността на клемата за присъединяване и вътрешността на тялото със смазката и пълнежа GM1.
- Отрежете лента от апликатора АН (приспособление за изтегляне на въздуха).
- Вмъкнете приспособлението за изтегляне на въздуха в тялото.
- Вкарайте тялото върху клемата.
- Закрепете закопчалката, заземителния проводник и

10)



прикрепващата плоча съгласно фигурата.

- Затегнете крилчатите гайки равномерно.
- Издърпайте внимателно приспособлението за изтегляне на въздуха и отстранете остатъците от смазката и пълнежа GM1.
- Допълнителните мерки за заземяване да бъдат съобразени със местните законови разпоредби.



CWS 250A 24kV 16 - 95/EGA
 $U_o/U(U_m)$ 6/10(12)kV - 12/20(24) kV

Инструкция за монтаж

Кабелна глава, Г-образна щепселна, за едножилни кабели с полимерна изолация за напрежения до 24 kV

221295/0609/3/6

CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com
e-mail: electrical.products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45



Общи указания:

- Проверете дали обхватът на кабелните аксесоари е подходящ за размера на кабела.
- Проверете съдържанието на комплекта съгласно опаковъчния лист.
- Старателно прочетете инструкциите за монтаж.

Монтажът трябва да се извършва само от компетентен персонал.

Производителят не носи отговорност за повреди, причинени от неправилен монтаж.


Кабелна глава, Г-образна, щепселна CWS 250A 24kV 16-95/EGA

Сечения:

Напрежение $U_0/U(U_m)$ kV	Сечение на кабела RM/RE (*) mm ²
6/10(12) kV	50 - 95
8,7/15(17,5) kV	25 - 95
12/20(24) kV	16 - 95

(*) Минимален диаметър над кабелната изолация от 14.7 мм

Нагласяне




- Почистете грижливо краищата на кабела до 1м.
- Нагласете кабела спрямо оста на клемата за присъединяване оставяйки свободна дължина $L = 200-500$ мм. Изрежете излишното.
- Маркирайте кабела на 150 mm от центъра на клемата.


Подготовка на кабела

Кабел с екран от медни жички:

1a)



2a)




- Отстранете външната изолация на кабела до маркировката.
- Подгънете назад медните жици на екрана и ги фиксирайте към външната изолация на кабела с PVC лента (Fig. 1a).
- Отрежете кабела на дължина **130 mm**.
- Внимателно отстранете външния полупроводим слой, така че да остане слой с дължина **30 mm**.


Уверете се, че ръбът на слоя е гладък.

- Отстранете XLPE изолацията на кабела на размер **35 mm**.
- Почистете старателно XLPE изолацията и външния полупроводим слой на кабела.

3a)




- Защитете края на жилото с PVC-лента.
- Навийте 2/3 от дължината на уплътняващата лента DM1 върху **20 mm** от екрана и върху **10 mm** от полупроводящия слой (с разтягане 50%)
- Нанесете на и около ръба на полупроводящия слой смазка и пълнеж GM1[®] (оформете пръстен).
- Навлажнете изолацията със смазка и пълнеж GM1.




Кабел с лентов екран:

1b)



- Отстранете външната изолация на кабела до маркировката + 20mm.
- Отрежете кабела както е показано на фигурата.
- Отрежете лентовия екран, така че върху кабела да остане 20 мм от него.
- Внимателно отстранете външния полупроводим слой, така че да остане слой с дължина 30 мм.


2b)




Уверете се, че ръбът на слоя е гладък.

- Отстранете XLPE изолацията на кабела на размер 35 mm.
- Почистете старателно изолацията и външния полупроводим слой на кабела


3b)




- Защитете края на жилото с PVC-лента.
- Фиксирайте заземителната оплетка и заземителния проводник чрез ролкова пружина към лентовия екран (заземителният комплект се поръчва отделно).
- Навийте 2/3 от дължината на уплътняващата лента DM1 върху 20 mm от екрана и върху 10 mm от полупроводящия слой (фиг. 3b).
- Нанесете на и около ръба на полупроводящия слой смазка и пълнеж GM1 (оформете пръстен).
- Навлажнете изолацията със смазка и пълнеж GM1.



4)




5)




- Навлажнете лентите на апликатора АН със силиконовата кърпичка.
- Вмъкнете апликатора АН в елемента за контрол на полето FSE и ги нахлузете върху кабела до достигане на уплътняващата обвивка.
- Отстранете апликатора, издърпвайки лентите му една по една.
- Позиционирайте елемента за контрол на полето като леко го завъртате (фиг. 5).
- Отстранете PVC лентата от края на жилото на кабела.
- Монтирайте кабелна обувка с болтове с откъсващи се глави, съгласно отделна инструкция.
Моля, обърнете внимание, че отворът на кабелната обувка трябва да бъде съосен с оста на клемата за присъединяване.
- Почистете старателно повърхността на елемента за контрол на полето FSE

6)




- Навлажнете тялото на щепселната глава и повърхността на елемента за контрол на полето FSE със смазка и пълнеж GM1. **Внимание: Кабелната обувка да не се навлажнява.**
- Нахлузете тялото на щепселната глава върху кабела докато отвора на кабелната обувка се центрира в него.

7)




- Затегнете контактната шпилка в кабелната обувка със шестостенния ключ и я стягайте ръчно.
- Навийте останалата 1/3 от лентата DM1 между края на тялото и зоната за запечатване.


8)



9)



- Навийте лента № 2585 приблизително 20 мм върху края на тялото до края на зоната за запечатване (с разтягане 20%).
- Навлажнете повърхността на клемата за присъединяване и вътрешността на щепселната глава със смазката и пълнежа GM1.
- Отрежете лента от апликатора АН (приспособление за изтегляне на въздуха).
- Вмъкнете приспособлението за изтегляне на въздуха в тялото.
- Закрепете тялото върху клемата.
- Закрепете закопчалката, заземителния проводник и прикрепващата плоча съгласно фигурата.
- Затегнете крилчатите гайки равномерно.
- Издърпайте внимателно приспособлението за изтегляне на въздуха и отстранете остатъците от смазката и пълнежа GM1.
- Допълнителните мерки за заземяване да бъдат съобразени със местните законови разпоредби.



CTS 630A 24kV 95 - 240
 $U_o/U(U_m)$ 8,7/15(17,5) kV – 12,7/22(24) kV

Инструкция за монтаж

Кабелна глава щепселна, Т-образна за едножилни кабели с полимерна изолация за напрежения до 24 kV


206742/0908/4/7

CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com

e-mail: electrical.products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45

CELLPACK
Electrical Products



Общи указания:

- Проверете дали обхватът на кабелните аксесоари е подходящи за размера на кабела.
- Проверете съдържанието на комплекта съгласно опаковъчния лист.
- Старателно прочетете инструкциите за монтаж.

Монтажът трябва да се извършва само от компетентен персонал.
Производителят не носи отговорност за повреди, причинени от неправилен монтаж.


Кабелна глава щепселна, Т-образна тип CELLPLUX CTS 630A 24kV 95-240 :

Сечения:

Напрежение $U_0/U(U_m)$ kV	Сечение на кабела (*) mm ²
8,7/15(17,5) kV	120 – 240 *)
12/20(24) kV	95 – 240 *)

(*) Минимален диаметър над кабелната изолация от 22 мм

Нагласяне



- Почистете грижливо краищата на кабела до 1м.
- Нагласете кабела спрямо оста на клемата за присъединяване, оставяйки свободна дължина $L = 200-500$ мм. Изрежете излишното.
- Маркирайте кабела на 210 mm от центъра на клемата.

206742 CTS 630A 24kV 95-240




[Handwritten signature]

Подготовка на кабела


Кабел с екран от медни жички:

1a)




- Отстранете външната изолация на кабела до маркировката.
- Подгънете назад медните жици на екрана и ги фиксирайте към външната изолация на кабела с PVC лента (Fig. 1a).
- Отрежете кабела на дължина 165 mm.
- Внимателно отстранете външния полупроводим слой, така че да

2a)




- остане слой с дължина 30 mm. Уверете се, че ръбът на слоя е гладък.
- Отстранете XLPE изолацията на кабела на размер 55 mm.
- Почистете старателно XLPE изолацията и външния полупроводим слой на кабела.

3a)




- Защитете края на жилото с PVC-лента.
- Навийте 2/3 от дължината на уплътняващата лента DM1 върху 20 mm от екрана и върху 10 mm от полупроводящия слой (с разтягане 50%)
- Нанесете на и около ръбът на полупроводящия слой смазка и пълнеж GM1 (оформете пръстен).
- Навлажнете изолацията със смазка и пълнеж GM1.

Handwritten signature




Кабел с лентов екран:

1b)



- Отстранете външната изолация на кабела до маркировката + 20mm.
- Отрежете кабела както е показано на фигурата.
- Отрежете лентовия екран, така че върху кабела да остане 20 мм от него.
- Внимателно отстранете външния полупроводим слой, така че да остане слой с дължина 30 мм.


2b)




Уверете се, че ръбът на слоя е гладък.

- Отстранете XLPE изолацията на кабела на размер **55 mm**.
- Почистете старателно изолацията и външния полупроводим слой на кабела.

3b)




- Защитете края на жилото с PVC-лента.
- Фиксирайте заземителната оплетка и заземителния проводник чрез ролкова пружина към лентовия екран (заземителния комплект се поръчва отделно).
- Навийте 2/3 от дължината на уплътняващата лента DM1 върху **20 mm** от екрана и върху **10 mm** от полупроводящия слой (фиг. 3b).
- Нанесете на и около ръбът на полупроводящия слой смазка и пълнеж GM1 (оформете пръстен).
- Навлажнете изолацията със смазка и пълнеж GM1.




Handwritten signature

4)




- Навлажнете лентите на апликатора АН със силиконовата кърпичка.
- Вмъкнете апликатора АН в елемента за контрол на полето FSE и ги нахлузете върху кабела до достигане на уплътняващата обвивка.
- Отстранете апликатора, издърпвайки лентите му една по една.
- Позиционирайте елемента за контрол на полето като леко го завъртате (фиг. 5).
- Отстранете PVC лентата от края на жилото на кабела.

5)




- Монтирайте кабелна обвивка с болтове с откъсващи се глави, съгласно отделна инструкция. Моля, обърнете под внимание, че отвората на кабелната обвивка трябва да бъде съосен оста на клемата за присъединяване.
- Почистете старателно повърхността на елемента за контрол на полето FSE.

6)




- Навлажнете тялото на Т-образната щепселна глава и повърхността на елемента за контрол на полето FSE със смазка и пълнеж GM1. **Внимание: Кабелната обвивка да не се навлажнява.**
- Нахлузете тялото на Т-образна щепселна глава върху кабела докато отвората на кабелната обвивка се центрира в него

7)




- Навийте останалата **1/3** от лентата DM1 между края на Т-образното тяло и зоната за запечатване.

8)



- Навийте лента № 2585 приблизително **20 мм** върху края на Т-образното тяло до края на зоната за запечатване (с разтягане 20%).

9)




- Навлажнете повърхността на клемата за присъединяване и вътрешността на Т-образното тяло със смазката и пълнежа GM1.
- Отрежете лента от апликатора АН (приспособление за изтегляне на въздуха).
- Вмъкнете приспособлението за изтегляне на въздуха в Т-образното тяло.
- Закрепете Т-образното тяло право върху клемата за присъединяване и завийте контактния болт ръчно.
- Затегнете контактния болт с подходящ инструмент до скъсване на главата му.

Внимание:


За повторно използване на контактния болт, при затягане на последния, трябва да бъде приложен срязващ момент от 50 Nm.

10)




- Навлажнете T-образното тяло и екранирания изолационен конус със смазката и пълнежа GM1.
- Отрежете втора лента от апликатора АН и го поставете в T-образното тяло.
- Вкарайте екранирания изолационен конус в T-образното тяло. Затегнете го с подходящ инструмент. Не прилагайте срязващ момент по-голям от 10 Nm.

11)



12a)



- Издърпайте внимателно приспособлението за изтегляне на въздуха и отстранете остатъците от смазката и пълнежа GM1.


- Поставете полупроводящата защитна капачка върху Т-образното тяло.

Версия без заземителен комплект

- Усучете 3 жички от екрана и ги фиксирайте към отвора на Т-образното тяло.

Версия със заземителен комплект – версия EGA

12b)




- Инсталирайте заземителния комплект към Т-образното тяло и го заземете (съгласно фиг. 12b).
- Допълнителните мерки за заземяване да бъдат съобразени със местните законови разпоредби.

C

C

Medium Voltage

CELLPLUX



CTKS 630A 24kV 95 – 240/EGA
 $U_o/U(U_m)$ 6/10(12) kV - 12/20(24) kV

Working Instruction

**Separable T Coupling Connector for
single-core polymeric cables
up to 24 kV**

257258/0910/3/9

CELLPACK GmbH
Electrical Products
D-79761 Waldshut-Tiengen
Tel. +49(0)7741/60 07 11
Fax +49(0)7741/60 07 83
www.cellpack.com
e-mail: electrical.products@cellpack.com

CELLPACK AG
Electrical Products
CH-5612 Villmergen
Tel. +41(0)56/618 12 34
Fax +41(0)56/618 12 45

257258 CTKS 630A 24kV 95-240/EGA

CELLPACK
Electrical Products



General remarks:

- Check if the range and size of the accessories is appropriate to the cable.
- Check the content of the kit as per packing list.
- Thoroughly read the working instruction.


Installation must be executed by competent personnel only.
The manufacturer accepts no liability for breakdowns or damages resulting from an incorrect installation.

Separable T Coupling Connector CELLPLUX CTKS 630A 24kV 95-240/EGA:

Cross-Section Application

Voltage $U_0/U(U_m)$ kV	Cable Cross-Section (*) mm ²
6/10(12) kV	150 – 240 *)
8,7/15(17,5) kV	120 – 240 *)
12/20(24) kV	95 – 240 *)

(*) Minimal diameter over cable insulation of 22 mm




- Clean thoroughly the cable ends up to 1 m.
- Adjust the cable overhanging in the middle of the bushing by $L = 200 - 500$ mm. Cut-off the excess of cable.
- Make a mark 210 mm from the centre of the bushing onto the cable sheath.

Handwritten signature
0012/9
GOA

Preparation of the cable


Cable with wire screen:

1a)




- Remove the cable sheath up to the mark.
- Band back the screen wires of the cable and fix them on the cable sheath with PVC tape (Fig. 1a).
- Cut off the conductor at the length of 165 mm.

2a)



- Remove carefully the outer conductive layer up to 30 mm (mind a clean cut back edge).
- Cut back the cable insulation by 55 mm.
- Clean thoroughly insulation and the outer conductive layer of the cable.


3a)



- Wrap the tip end of the conductor with PVC tape.
- Wrap 2/3 of the length of DM1 mastic 10 mm on to the conductive layer and 20 mm on to the wire screen (stretch 50%).
- Apply at and around the cut edge of the conductive layer lubricant and filling agent GM1 (forming a ring).
- Moisten the insulation with lubricant and filling agent GM1.


Cable with tape screen:

1b)




- Remove the cable sheath up to the mark + 20 mm.
- Cut the cable according to the drawing.
- Remove carefully the tape screen up to 20 mm.

2b)




- Remove carefully the outer conductive layer up to 30 mm (mind a clean cut back edge).
- Cut back the cable insulation by 55 mm.
- Clean thoroughly the insulation and the conductive layer.


3b)



- Wrap the tip end of the conductor with PVC tape.
- Fix the flat Cu-braid and earthing cable with the pressure spring RF on to the tape screen (order the earthing kit separately).
- Wrap 2/3 of the length of mastic tape DM1 10 mm on to the conductive layer and 20 mm on to the copper tape screen (Fig. 3b).
- Apply at and around the cut edge of the conductive layer lubricant and filler agent GM1 (forming a ring).
- Moisten the insulation with lubricant and filling agent GM1.



4)




- Moisten the tongues of the applicator AH with the silicon towel.
- Insert the applicator AH in to the stress control element FSE and slip it on to the cable up to the sealing wrap.
- Remove the applicator AH by pulling out the tongues one by one.
- Adjust the position of the stress control element FSE by turning it slightly (Fig. 5).

5)



- Remove the protection wrap from the tip end of the conductor.
- Install the shear-head screw cable lug according to the separate instruction. Please note that the tapped hole of the cable lug is in line with the bushing axle.
- Clean thoroughly the surface of the stress control element FSE.

6)




- Moisten the connector body and the surface of the stress control elements FSE with lubricant and filling agent GM1.
Attention: The cable lug must not be moistured.
- Slip the connector body on to the conductor until the tapped hole of the cable lug is centred inside the connector body.




[Handwritten signature]

7)




- Wrap the remaining 1/3 of mastic tape DM1 between the end of the connector body and the sealing area.

8)




- Wrap the tape Nr. 2585 adhesive side inwards approx. 20 mm over the end of the connector body up to the end of the sealing area (stretch 20%).

9)




- Take off the conductive protection cup of the T - connector body.

10)




- Unscrew the insulating plug. Use appropriate tool.

11)




- Clean thoroughly inside of the T-connector body and moisten again with lubricant and filling agent GM1.
 - Insert the adaptor plug into the T-connector body and screw the adaptor plug manually. Tighten the adaptor plug with an appropriate tool till the shear head breaks.
- Attention:**
To reuse the adaptor plug it must be tighten with a shear moment „M” of 40 Nm.


12)



- Moisten outside of the CTKS-connector body with lubricant and filling agent GM1.
 - Cut out a tongue from the applicator AH (air decompression device). Insert the decompression device into the T-connector body.
 - Attach the CTKS-connector straight on to the adaptor plug and screw the contact screw manually.
 - Tighten the contact screw with an appropriate tool till the shear head breaks.
- Attention:**
To reuse the contact screw it must be tighten with a shear moment „M” of 50 Nm.




13)




- Moisten inside of the CTKS-connector body and the new insulating plug with lubricant and filling agent GM1.
- Cut out a second tongue from the applicator and insert it into the connector body.
- Insert the new insulating plug into the connector body. Tighten the insulating plug with an appropriate tool. Do not apply a shear moment „M“ bigger than 40 Nm.

14)



- Pull out gently the decompression devices and remove remaining of lubricant and filling agent GM1.

15)



- Insert the conductive protection cup over the connector body and ground the CTKS-connector body.
- Further earthing measurements have to be carried out according to local regulations.



Наименование на материала: Комплект измервателен клемен блок с клеми за медни проводници от проходен тип и 1P, 3P или 3P+N стопяеми цилиндрични предпазител-прекъсвач-разединители

Съкратено наименование на материала: Клемен блок с Цилиндрични П-л П-ч Р-ли

Област: G - Инсталации

Категория: 14 - Инсталационни тръби, кутии, клемни кутии, клеми, планки

Мерна единица: Брой

Аварийни запаси: Да

Характеристика на материала:

Клемен блок комплектуван с делими измервателни клеми от проходен тип, за монтаж на DIN шина, с резбови контактни съединения за медни токопроводими жила с класове 1,2 и 5 съгласно БДС EN 60228:2006 или еквивалент със сечения от от 2,5 mm² до min 6 mm² (max 16 mm²) и 1P, 3P или 3P+N стопяеми цилиндрични предпазител-прекъсвач-разединители. Клеморедът е защитен от неправомерен достъп посредством прозрачен устойчив на деформации капак с възможност за пломбиране.

Използване:

Клемният блок, комплектуван с делими измервателни клеми и 1P, 3P или 3P+N стопяеми цилиндрични предпазител-прекъсвач-разединители е предназначен за присъединяване на медни токопроводими жила при опроводяване на системи за измерване на използваните от потребителите количества електрическа енергия, еталонна апаратура за проверка и аналогични инсталации.

Съответствие на предложеното изпълнение със стандартизационните документи:

Клемният блок, комплектуван с делими измервателни клеми за медни проводници от проходен тип и 1P, 3P или 3P+N стопяеми цилиндрични предпазител-прекъсвач-разединители, трябва да бъдат в съответствие с изискванията на посочените стандарти или еквиваленти, включително на техните валидни изменения и поправки:

- БДС EN 60947-7-1:2009 "Комутационни апарати за ниско напрежение. Част 7-1: Спомагателни принадлежности. Клемни блокове за медни проводници (IEC 60947-7-1:2009)";
- БДС EN 60947-1:2007 „Комутационни апарати за ниско напрежение. Част 1: Общи правила (IEC 60947-1:2007)“; и
- БДС EN 60947-3:2009 „Комутационни апарати за ниско напрежение. Част 3: Товарни прекъсвачи, разединители, товаров прекъсвач-разединители и апарати, комбинирани с предпазител (IEC 60947-3:2008)“ и



да бъдат оценени положително по реда и при условията на Наредбата за съществените изисквания и оценяване на съответствието на електрически съоръжения, предназначени за използване в определени граници на напрежението, приета с ПМС № 182 от 6.07.2001 г., обн., ДВ, бр. 62 от 13.07.2001 г.

Изисквания към документацията и изпитванията


№ по ред	Документ	Приложение № или текст
1.	Точно означение на типа, производителя и страната на производство (произход) и последно издание на каталога на производителя	URTK/S, Phoenix Contact, Германия Приложение 1
2.	Техническо описание и чертежи с нанесени на тях размери	Приложение 2
3.	ЕО декларация за съответствие	Приложение 3
4.	Протоколи от типови изпитвания на английски или български език съответно за 1P, 3P или 3P+N стопяеми цилиндрични предпазител-прекъсвач-разединители и клемните блокове, проведени от независима изпитвателна лаборатория – заверени копия, с приложен списък на отделните изпитвания на български език	Приложение 4
5.	Сертификат/акредитация на независимата изпитвателна лаборатория, провела типовите изпитвания по т. 4 – заверено копие	Приложение 5

Забележка: Всички оригинални документи трябва да бъдат на български език или с превод на български език. Каталогите и протоколите от проверките и изпитванията могат да бъдат и само на английски език.

Технически данни

1. Характеристики на работната среда

№ по ред	Характеристика	Стойност
1.1	Околна среда, в която работи	На закрито
1.2	Максимална околна температура	+ 40°C



Handwritten signatures and initials in black ink.

1.3	Минимална околна температура	Минус 5°C
1.4	Относителна влажност (при 20 °C)	До 90 %
1.5	Степен на замърсяване	III
1.6	Надморска височина	До 1000 m

2. Параметри на електроразпределителната мрежа


№ по ред	Параметър	Стойност
2.1	Номинално напрежение	400 / 230 V
2.2	Максимално работно напрежение	440 / 253 V
2.3	Номинална честота	50 Hz
2.4	Брой на фазите	3
2.5	Заземяване на звездния център	Директно заземен

3. Технически характеристики

№ по ред	Характеристика	Изискване	Гарантирано предложение
3.1	Клемен блок	-	-
3.1.1	Конструкция	а) Клемният блок трябва да бъде комплектуван с делими измервателни клеми от проходен тип с резбови контактни съединения, за монтаж на DIN шина	а) Клемният блок трябва е комплектуван с делими измервателни клеми от проходен тип с резбови контактни съединения, за монтаж на DIN шина
		б) Клемите за началата и краищата на отделните токови вериги трябва да бъдат монтирани една до друга.	б) Клемите за началата и краищата на отделните токови вериги са монтирани една до друга.
		в) Клемният блок трябва да осигурява	в) Клемният блок


Official stamp and signature of the company.

№ по ред	Характеристика	Изискване	Гарантирано предложение
		възможност за независимо шунтиране и разкъсване на токовите вериги на всяка от фазите	осигурява възможност за независимо шунтиране и разкъсване на токовите вериги на всяка от фазите
		г) Клемният блок трябва да бъде комплектуван с разделителни стени между нееднородните фази и клемата за неутралния проводник	г) Клемният блок е комплектуван с разделителни стени между нееднородните фази и клемата за неутралния проводник
		д) Клемният блок ведно със стопяемите цилиндрични предпазител-прекъсвач-разединители трябва да бъдат защитени срещу неправомерен достъп с прозрачен монолитен капак с възможност за пломбиране	д) Клемният блок ведно със стопяемите цилиндрични предпазител-прекъсвач-разединители са защитени срещу неправомерен достъп с прозрачен монолитен капак с възможност за пломбиране
		е) Защитният монолитен капак трябва бъде изработен от поликарбонат или еквивалентен прозрачен материал с дебелина на стените min 2 mm и да осигурява клас на защита на клемния блок IP 4X съгласно БДС EN 60529+A1:2004 до ниво монтажна плоча от всички страни или еквивалент.	е) Защитният монолитен капак е изработен от поликарбонат или еквивалентен прозрачен материал с дебелина на стените min 2 mm и осигурява клас на защита на клемния блок IP 4X съгласно БДС EN 60529+A1:2004 до ниво монтажна плоча от всички страни или еквивалент.
3.1.2	Размери	-	




№ по ред	Характеристика	Изискване	Гарантирано предложение
3.1.2a	Височина	max 140 mm	140 mm
3.1.2b	Широчина	max 170 mm	150 mm
3.1.2c	Дълбочина	80 mm (препоръчително)	78 mm
3.2	Проходни делими клеми	-	-
3.2.1	Конструкция	а) Клемите с резбови контактни съединения трябва да позволяват присъединяване на медни токопроводими жила с класове 1,2 и 5 съгласно БДС EN 60228 или еквивалент със сечения от от 2,5 mm ² до min 6 mm ² (max 16 mm ²)	а) Клемите с резбови контактни съединения позволяват присъединяване на медни токопроводими жила с класове 1,2 и 5 съгласно БДС EN 60228 или еквивалент със сечения от от 0,5 mm ² до 10 mm ²
		б) Клемите трябва да бъдат окомплектовани със съответните аксесоари, позволяващи свързване на измервателна апаратура	б) Клемите са окомплектовани със съответните аксесоари, позволяващи свързване на измервателна апаратура
3.2.2	Съответствие със стандарти	БДС EN 60947-7-1 или еквивалент	БДС EN 60947-7-1 или еквивалент
3.2.3	Обявено работно напрежение AC, U _e	min 500 V	500V
3.2.4	Обявен продължителен ток, I _n	min 10 A	41A
3.2.5	Сравнителен показател за устойчивост срещу пропълзващи токове - CTI	min 600	600
3.2.6	Минимален работен температурен	От минус 30°C до + 90°C	От минус 60°C до +90°C



№ по ред	Характеристика	Изискване	Гарантирано предложение
	диапазон		
3.2.7	Категория на горимост	min V-0	V-0
3.2.8	Закрепване	Към шина с DIN – профил с размери 35x7.5 mm	Към шина с DIN – профил с размери 35x7.5 mm
3.2.9	Клеми за токовите вериги	6 бр. токови клеми, позволяващи: <ul style="list-style-type: none"> ○ независимо свързване на късо (шунтиране) на токовите вериги на електромера на всяка фаза посредством мостова връзка; ○ видимо разкъсване на токовите вериги. 	6 бр. токови клеми, позволяващи: <ul style="list-style-type: none"> ○ независимо свързване на късо (шунтиране) на токовите вериги на електромера на всяка фаза посредством мостова връзка; ○ видимо разкъсване на токовите вериги.
3.2.10	Клема за неутралния проводник	1 бр. с възможност за видимо разкъсване на веригите. (Не се изисква при използване на 3P+N цилиндрични предпазител-прекъсвач-разединители)	1 бр. с възможност за видимо разкъсване на веригите
3.2.11	Разделителна стена между нееднородните фази и неутралния проводник	Клемният блок трябва да бъде комплектуван с разделителни стени за предотвратяване на неволно шунтиране или късо съединение	Клемният блок е комплектуван с разделителни стени за предотвратяване на неволно шунтиране или късо съединение
3.2.12	Крайна капачка	1 бр. или 2 бр. (в зависимост от конструкцията)	1бр
3.2.13	Краен притискач с винтове	2 бр.	2бр
3.2.14	Маркировка на клемите	а) Токовите клемите трябва да бъдат маркирани с буквено-цифрени означения за фаза и начало и край на съответните фази б) Цветова маркировка –	а) Токовите клемите са маркирани с буквено-цифрени означения за фаза и начало и край на съответните фази б) Цветова маркировка


Handwritten signature



№ по ред	Характеристика	Изискване	Гарантирано предложение
		препоръчително	- на тест буксите
3.3	Спецификация 1P, 3P или 3P+N стопяеми цилиндрични предпазител-прекъсвач-разединители		
3.3.1		а) 3 броя еднополюсни (1P) или 1 брой триполюсни (3P или 3P+N) стопяемите цилиндрични предпазител-прекъсвач-разединители	3 бр еднополюсни
		б) Еднополюсни (1P) или триполюсни (3P) стопяемите цилиндрични предпазител-прекъсвач-разединители са съгласно стандарт 20 16 6zzz в Приложение 1 с предпазител 10x38 mm от категория на приложение gG с обявен ток на стопяемата вложка 4 А	б) Еднополюсни (1P) стопяеми цилиндрични предпазител-прекъсвач-разединители са съгласно стандарт 20 16 6zzz в Приложение 1 с предпазител 10x38 mm от категория на приложение gG с обявен ток на стопяемата вложка 4 А
		в) Съответствието на 1P, 3P или 3P+N стопяеми цилиндрични предпазител-прекъсвач-разединители с изискванията на стандартизационните документи се доказва с последно издание на каталога на производителя и със заверени копия на протоколи от типови изпитвания, проведени от независима акредитирана лаборатория.	в) Съответствието на 1P стопяеми цилиндрични предпазител-прекъсвач-разединители с изискванията на стандартизационните документи е доказано с последно издание на каталога на производителя и със заверени копия на протоколи от типови изпитвания, проведени от независима акредитирана лаборатория
			Приложение 6


M

Ваня



№ по ред	Характеристика	Изискване	Гарантирано предложение
3.3.2	Технически изисквания за 3P+N триполюсен стопяем цилиндричен предпазител-прекъсвач-разединител, размер 10x38 mm		
3.3.2.1	Брой на полюсите	3+N	3 бр. еднополюсни
3.3.2.2	Широчина	max 54 mm	3x18 mm (54 mm общо)
3.3.2.3	Обявено работно напрежение AC, Ue	min 500 V	690V
3.3.2.4	Обявена честота	50 Hz	50Hz
3.3.2.5	Обявено напрежение на изолацията Ui AC	min 750 V	750V
3.3.2.6	Категория по пренапрежение при 400 V AC	III	III
3.3.2.7	Обявено издържано импулсно напрежение, Uimp	4 kV	6kV
3.3.2.8	Категория на приложение (при 400V AC)	AC 21 B	AC21B
3.3.2.9	Термичен ток със стопяема вложка, Ith	32 A	32A
3.3.2.10	Условен ток на късо съединение (ефективна стойност) при 400 V AC	min 50 kA	100kA
3.3.2.11	Размер на цилиндричната стопяема вложка	10 x 38 mm	10x38mm
3.3.2.12	Максимална стойност на обявения ток на стопяемата вложка In	32 A	32A
3.3.2.13	Ток на приложената стопяема вложка	4 A	4 A
3.3.2.14	Максимална мощност на разсейване на	3,5 W	3W

Handwritten signature



№ по ред	Характеристика	Изискване	Гарантирано предложение
	стояемата вложка		
3.3.2.15	Механична износоустойчивост (комутационни цикли)	min 1 700	min 1700
3.3.2.16	Електрическа износоустойчивост (комутационни цикли)	min 300	min 300
3.3.2.17	Степен на защита	min IP20	IP20
3.3.2.18	Диапазон на сеченията на присъединяваните проводници	От 2,5 до 10 mm ² за Cu проводници	От 0.5 до 25 mm ² за Cu/Al проводници
3.3.2.19	Тегло, g	Да се посочи	3x65 g (195 g общо)
3.4	DIN-шина	а) Шината с DIN – профил за закрепване на клеморедата трябва да бъде с размери 35x7,5 mm и да съответства на изискванията на DIN 46277 P3 или еквивалент.	а) Шината с DIN – профил за закрепване на клеморедата с размери 35x7,5 mm и да съответства на изискванията на DIN 46277 P3 или еквивалент.
		б) DIN шината трябва да бъде изработена от стомана и да бъде защитена от корозия чрез поцинковане или друго еквивалентно антикорозионно покритие.	б) DIN шината е изработена от стомана и е защитена от корозия чрез поцинковане или друго еквивалентно антикорозионно покритие.
		в) DIN шината не трябва да се показва извън капака, покриващ целия клемен блок	в) DIN шината не се показва извън капака, покриващ целия клемен блок


AM

Аврил

4. Свързани документи

В техническата спецификация на стандарта за „Комплект измервателен клемен блок с клеми за медни проводници от проходен тип и 1P, 3P или 3P+N стопяеми цилиндрични предпазител-прекъсвач-разединители“ е направено позоваване на следните технически спецификации на стандарти за материали с йерархична съподчиненост, които са неразделна част от документа, както следва:

№ по ред	Номер на техническа спецификация на стандарт	Наименование на материала
4.1	20 16 6zzz	Триполюсни и еднополюсни стопяем цилиндричен предпазител-прекъсвач-разединители, размер 10x38 mm



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042


“Комплект измервателен клемен блок с клеми за медни проводници от проходен тип и 1P, 3P или 3P+N
стояеми цилиндрични предпазител-прекъсвач-разединители”

Приложение № 1


ЕЛЕКТРОТЕХНИКА
ООО


URTK/S

Order No.: 0311087




<http://eshop.phoenixcontact.net/phoenix/treeViewClick.do?UID=0311087>

Test disconnect terminal block, Connection method: Screw connection, Cross section: 0.5 mm² - 10 mm², AWG: 20 - 10, Width: 8.2 mm, Mounting type: NS 35/7.5, NS 35/15, NS 32, Color: gray

Commercial data	
EAN	 4 017918 001292
Pack	50 pcs.
Customs tariff	85369010
Gross weight in pieces	0.035996 KG
Net weight per piece (exclusive packing)	0.03581 KG
Catalog page information	Page 463 (CL1-2011)


Product notes

WEEE/RoHS-compliant since:
01/01/2003



<http://www.download.phoenixcontact.com>
Please note that the data given here has been taken from the online catalog. For comprehensive information and data, please refer to the user documentation. The General Terms and Conditions of Use apply to Internet downloads.

Technical data	
General	
Number of levels	1
Number of connections	2
Color	gray




Insulating material	PA
Inflammability class according to UL 94	V0

Dimensions

Length	72 mm
Width	8.2 mm
Height NS 35/7,5	51.5 mm
Height NS 35/15	59 mm
Height NS 32	56 mm

Technical data


Rated surge voltage	6 kV
Pollution degree	3
Surge voltage category	III
Insulating material group	I
Connection in acc. with standard	IEC 60947-7-1
Nominal current I_N	41 A
Nominal voltage U_N	400 V
Open side panel	ja
Shock protection test specification	DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection	guaranteed
Surge voltage test setpoint	7.3 kV
Result of surge voltage test	Test passed
Power frequency withstand voltage setpoint	1.89 kV
Result of power-frequency withstand voltage test	Test passed
Checking the mechanical stability of terminal points (5 x conductor connection)	Test passed
Bending test rotation speed	10 rpm
Bending test turns	135
Bending test conductor cross section/weight	0.5 mm ² / 0.3 kg
	6 mm ² / 1.4 kg
	10 mm ² / 2 kg
Result of bending test	Test passed
Conductor cross section tensile test	0.5 mm ²
Tractive force setpoint	20 N
Conductor cross section tensile test	6 mm ²
Tractive force setpoint	80 N



Conductor cross section tensile test	10 mm ²
Tractive force setpoint	90 N
Tensile test result	Test passed
Tight fit on carrier	NS 32/NS 35
Setpoint	5 N
Result of tight fit test	Test passed
Result of voltage drop test	Test passed
Temperature-rise test	Test passed
Conductor cross section short circuit testing	6 mm ²
Short-time current	0.72 kA
Conductor cross section short circuit testing	10 mm ²
Short-time current	1.2 kA
Short circuit stability result	Test passed
Proof of thermal characteristics (needle flame) effective duration	30 s
Result of thermal test	Test passed
Temperature index, insulating material (DIN EN 60216-1 (VDE 0304-21))	130 °C
Static insulating material application in cold	-60 °C

Connection data

Conductor cross section solid min.	0.5 mm ²
Conductor cross section solid max.	10 mm ²
Conductor cross section stranded min.	0.5 mm ²
Conductor cross section stranded max.	6 mm ²
Conductor cross section AWG/kcmil min.	20
Conductor cross section AWG/kcmil max	8
Conductor cross section stranded, with ferrule without plastic sleeve min.	0.5 mm ²
Conductor cross section stranded, with ferrule without plastic sleeve max.	6 mm ²
Conductor cross section stranded, with ferrule with plastic sleeve min.	0.5 mm ²
Conductor cross section stranded, with ferrule with plastic sleeve max.	4 mm ²
2 conductors with same cross section, solid min.	0.5 mm ²
2 conductors with same cross section, solid max.	2.5 mm ²
2 conductors with same cross section, stranded min.	0.5 mm ²



2 conductors with same cross section, stranded max.	6 mm ²
2 conductors with same cross section, stranded, ferrules without plastic sleeve, min.	0.5 mm ²
2 conductors with same cross section, stranded, ferrules without plastic sleeve, max.	4 mm ²
2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, min.	0.5 mm ²
2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, max.	4 mm ²
Connection method	Screw connection
Stripping length	13 mm
Internal cylindrical gage	A5
Screw thread	M4
Tightening torque, min	1.2 Nm
Tightening torque max	1.5 Nm

Certificates / Approvals



Certification


CSA, cULus Recognized, GOST, KEMA-KEUR, DNV, LR, PRS, RS, CCA

Certifications applied for:


Certification Ex:

Accessories

Item	Designation	Description
Assembly		
3034361	AP-ME METER	Cover profile, for covering terminal strips, snapped onto APT-ME cover profile carrier or APH-ME end bracket. A cover profile carrier should be positioned at the ends and at intervals of around 40 cm. Length supplied: 1 m
3034374	APH-ME	Cover profile carrier for mounting on NS 35/7.5 DIN rail for attaching the cover profile AP-ME
3034358	APT-ME	Cover profile carrier for mounting on NS 35/7.5 DIN rail for attaching the cover profile AP-ME



0310224	ATS-RTK	Partition plate, Length: 72 mm, Width: 0.8 mm, Height: 51.5 mm, Color: gray
3022218	CLIPFIX 35	Snap-on end bracket, for 35 mm NS 35/7.5 or NS 35/15 DIN rail, can be fitted with Zack strip ZB 8 and ZB 8/27, terminal strip marker KLM 2 and KLM, width: 9.5 mm, color: gray
3022276	CLIPFIX 35-5	Quick mounting end clamp for NS 35/7,5 DIN rail or NS 35/15 DIN rail, can be fitted with ZB 5 and ZBF 5 zack marker strip, KLM 2, KLM3, and KML3L terminal strip marker, parking option for FBS...5, FBS...6, KSS 5, KSS 6, width: 5.15 mm, color: gray
0310020	D-URTK	End cover, Length: 72 mm, Width: 2.2 mm, Height: 41.5 mm, Color: gray
1201442	E/UK	End clamp, for assembly on NS 32 or NS 35/7.5 DIN rail
1201413	E/UK 1	End clamps, for supporting the ends of double-level and three-level terminal blocks, width: 10 mm, color: gray
1201002	NS 32 PERF 2000MM	G-profile DIN rail, material: Steel, perforated, height 15 mm, width 32 mm, length 2 m
1201015	NS 32 UNPERF 2000MM	G-profile DIN rail, material: Steel, unperforated, height 15 mm, width 32 mm, length 2 m
0801704	NS 35/ 7,5 AL UNPERF 2000MM	DIN rail, material: Aluminum, unperforated, height 7.5 mm, width 35 mm, length: 2 m
1206560	NS 35/ 7,5 CAP	DIN rail end piece, for DIN rail NS 35/7.5
0801762	NS 35/ 7,5 CU UNPERF 2000MM	DIN rail, material: Copper, unperforated, height 7.5 mm, width 35 mm, length: 2 m
0801733	NS 35/ 7,5 PERF 2000MM	DIN rail, material: steel galvanized and passivated with a thick layer, perforated, height 7.5 mm, width 35 mm, length: 2000 mm
0801681	NS 35/ 7,5 UNPERF 2000MM	DIN rail, material: Steel, unperforated, height 7.5 mm, width 35 mm, length: 2 m
1204119	NS 35/ 7,5 WH PERF 2000MM	DIN rail 35 mm (NS 35)
1204122	NS 35/ 7,5 WH UNPERF 2000MM	DIN rail 35 mm (NS 35)
1206421	NS 35/ 7,5 ZN PERF 2000MM	DIN rail, material: Galvanized, perforated, height 7.5 mm, width 35 mm, length: 2 m
1206434	NS 35/ 7,5 ZN UNPERF 2000MM	DIN rail, material: Galvanized, unperforated, height 7.5 mm, width 35 mm, length: 2 m
1201756	NS 35/15 AL UNPERF 2000MM	DIN rail, deep drawn, high profile, unperforated, 1.5 mm thick, material: aluminum, height 15 mm, width 35 mm, length 2000 mm
1206573	NS 35/15 CAP	DIN rail end piece, for DIN rail NS 35/15
1201895	NS 35/15 CU UNPERF 2000MM	DIN rail, material: Copper, unperforated, 1.5 mm thick, height 15 mm, width 35 mm, length: 2 m
1201730	NS 35/15 PERF 2000MM	DIN rail, material: steel galvanized and passivated with a thick layer, perforated, height 15 mm, width 35 mm, length: 2000 mm
1201714	NS 35/15 UNPERF 2000MM	DIN rail, material: Steel, unperforated, height 15 mm, width 35 mm, length: 2 m



0806602	NS 35/15 WH PERF 2000MM	DIN rail 35 mm (NS 35)
1204135	NS 35/15 WH UNPERF 2000MM	DIN rail 35 mm (NS 35)
1206599	NS 35/15 ZN PERF 2000MM	DIN rail, material: Galvanized, perforated, height 15 mm, width 35 mm, length: 2 m
1206586	NS 35/15 ZN UNPERF 2000MM	DIN rail, material: Galvanized, unperforated, height 15 mm, width 35 mm, length: 2 m
1201798	NS 35/15-2,3 UNPERF 2000MM	DIN rail, material: Steel, unperforated, 2.3 mm thick, height 15 mm, width 35 mm, length: 2 m
0310211	TS-RTK	Separating plate, Length: 72 mm, Width: 0.8 mm, Color: gray

Bridges


0311281	ASB 2-RTK/S	Switching jumper, Number of positions: 2, Color: silver
0202154	EB 2- 8	Insertion bridge, Number of positions: 2, Color: gray
0202141	EB 3- 8	Insertion bridge, Number of positions: 3, Color: gray
0202142	EB 4- 8	Insertion bridge, Number of positions: 4, Color: gray
0202138	EB 10- 8	Insertion bridge, Number of positions: 10, Color: gray
0311171	FB 10- RTK/S	Fixed bridge, Number of positions: 10, Color: silver
0308359	S	Switching lock, Length: 12 mm, Width: 8.2 mm, Color: white
0311236	SB 2-RTK/S	Switching jumper, Number of positions: 2, Color: silver
0311265	SB 4-RTK/S	Switching jumper, Number of positions: 4, Color: silver
0311278	USB 2-RTK/S	Switching jumper, Number of positions: 2, Color: silver

General

0800886	E/NS 35 N	End clamp, width: 9.5 mm, color: gray
---------	-----------	---------------------------------------

Marking

1007235	SBS 8:UNBEDRUCKT	Marker cards, Card, white, Unlabeled, Can be labeled with: Plotter, Mounting type: Snap into tall marker groove, Snap into flat marker groove, For terminal block width: 8.2 mm, Lettering field: 6 x 8.1 mm
0818072	UC-TM 8	Marker for terminal blocks, Sheet, white, Unlabeled, Can be labeled with: BLUEMARK CLED, Bluemark, Plotter, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 7.6 x 10.5 mm
0824597	UC-TM 8 CUS	Marker for terminal blocks, Can be ordered: By sheet, white, Labeled according to customer specifications, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 7.6 x 10.5 mm
0828740	UCT-TM 8	Marker for terminal blocks, Sheet, white, Unlabeled, Can be labeled with: Thermomark C+, Thermomark C, BLUEMARK CLED, Bluemark, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 7.6 x 10.5 mm




0829616	UCT-TM 8 CUS	Marker for terminal blocks, Can be ordered: By sheet, white, Labeled according to customer specifications, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 7.6 x 10.5 mm
0825011	ZB 8 CUS	Zack marker strip, Can be ordered: Strip, white, Labeled according to customer specifications, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 10.5 x 8.15 mm
1052002	ZB 8:UNBEDRUCKT	Zack marker strip, Strip, white, Unlabeled, Can be labeled with: Plotter, Mounting type: Snap into tall marker groove, For terminal block width: 8.2 mm, Lettering field: 10.5 x 8.15 mm

Plug/Adapter

0311728	PSBJ-URTK/S BK	Female test connector, Color: black
0311757	PSBJ-URTK/S BU	Female test connector, Color: blue
0311760	PSBJ-URTK/S GN	Female test connector, Color: green
0311744	PSBJ-URTK/S RD	Female test connector, Color: red
0311773	PSBJ-URTK/S VT	Female test connector, Color: violet
0311731	PSBJ-URTK/S YE	Female test connector, Color: yellow


Tools

1205066	SZS 1,0X4,0 VDE	Screwdriver, bladed, VDE insulated, size: 1.0 x 4.0 x 100 mm, 2-component grip, with non-slip grip
---------	-----------------	--




Diagrams/Drawings

Circuit diagram




- a = open
- 1 = cover
- 3 = fixed bridge
- 4 = switch bar, for 2 terminal blocks, useable on both sides of the disconnect point, inward switching motion
- 5 = switch bar, for 2 terminal blocks, useable on both sides of the disconnect point, outward switching motion
- 7 = switch bar, for 3-phasige short-circuiting of linked current transformer sets, only on the right
- 8 = switching lock, prevents disconnect slide from being actuated
- 9 = separating plate, for electrical separation of neighboring bridges in terminal center
- 10 = partition plate


Schematic diagram




Three-phase transducer test set



Three-phase linked transducer test set






Simple current transformer test circuit

- a = normal operation
- b = measured value testing
- c = transformer short-circuit
- d = relay testing





Address

PHOENIX CONTACT GmbH & Co. KG
Flachsmarktstr. 8
32825 Blomberg, Germany
Phone +49 5235 3 00
Fax +49 5235 3 41200
<http://www.phoenixcontact.com>



© 2013 Phoenix Contact
Technical modifications reserved;



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки


с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Комплект измервателен клемен блок с клеми за медни проводници от проходен тип и 1P, 3P или 3P+N
стояеми цилиндрични предпазител-прекъсвач-разединители”

Приложение № 2



ТЕХНИЧЕСКИ ХАРАКТЕРИСТИКИ

Предлаганите клеми са производство на фирма Phoenix Contact – Германия. Фирмата е сертифицирана по ISO 9001. Клемите са тествани и са в съответствие с IEC 60 947-7-1, IEC 60947-1, IEC 60695-2-2, EN 50019, а също така притежават и други сертификати, които са дадени за всяка клема в каталога.

Клемите на Phoenix Contact са с универсална основа за закрепване както към симетрична шина NS 35/7,5, NS 35/15, така и към несиметрична - NS 32. Кабелните входове на клемата са затворени фунии, което улеснява въвеждането на проводника. Всички клеми имат гнезда за индивидуално и рационално маркиране.

Предлаганите клеми, производство на Phoenix Contact притежават следните по-важни качества:

- **всички метални части са устойчиви на електролитна корозия и ръжда**
Всички метални елементи на клемите са изработени от медна сплав, с високо съдържание на мед, като напълно се избягва използването на стомана. Това елиминира две възможни причини за корозия: Едната е електролитна корозия, която възниква между медния проводник и стоманата, при наличие на влага. Втората е ръждата и последиците от нея – ненадежден електрически контакт, блокирани винчета. Използването само на медна сплав има и допълнителни предимства като: 1) ниско температурно повишение, поради високата електрическа проводимост и 2) по-малко вероятно е разхлабване на винчетата, тъй като практически няма относително термично разширение между проводника и притискащата част. Повърхността на металните части е защитена с калаено или никелово галванично покритие.

- **блокиране на винчетата срещу саморазвиване**
Phoenix Contact притежава патент, наречен "Reakdun principle" за предпазване на винчетата от саморазвиване. Конструкцията на притискащата част е на принципа на движеща се клетка. При завъртане на винта, той натиска тоководещата част и издърпва проводника в клетката към тоководещата част. Поради високата притискаща сила проводника се интегрира в мекото калаено покритие на тоководещата част. Така се постига контактно съпротивление което превишава изискванията на IEC 60 947-7-1, като за клема 4 mm² то е 0,3mΩ. Поради специалната си форма при затягане на винчето горната част на клетката се деформира еластично и предизвиква нарастваща триеща сила в главата на винчето, която не му позволява да се саморазвие.

- **надежна механична и електрическа връзка, съгласно IEC 60 947-7-1**
Конструкцията на притискащата част на клемата не само удовлетворява тези изисквания, но дори ги надвишава, поради следните качества: 1) Равната основа на притискащата част гарантира, че дори и най тънкия проводник ще бъде стегнат както трябва., 2) напречните жлебове на тоководещата част гарантират нарушаване оксидацията по проводника, без да го извиват и така осигуряват добър контакт, 3) стабилната конструкция на притискащите части, заедно с високата точност при изработка, осигуряват връзка, недопускаща проникването на газ, както и голяма

при
и голяма
СОФИЯ
ООД

сила на притискане. Това означава, че условията за контакт могат да се поддържат стабилни за дълъг период от време, дори в агресивна атмосфера.

- качества на изолационния материал


Изолационния материал на клемите, които са предмет на настоящия търг е Полиамид 6.6. Този материал е одобрен от всички оторизирани лаборатории като CSA, NEMKO, КЕМА, VDE и др. Той има отлични електрически, механични, химически и други качества, дори при високи температури. Позволен са кратковременно температури до 200° С. Полиамида абсорбира вода до 2,8%, но тази влага не е във формата на кристализирана вода в пластмасата, а е химически свързана в молекулната структура. Това прави пластмасата гъвкава и нечуплива, дори при ниски температури от -40° С. Полиамида има клас на негоримост V0, съгласно UL 94.

Максималния допустим ток на клемите зависи от максимално допустимото сечение на проводника и е в съответствие с IEC 60947-7-1.

Съответствие на техническите изисквания

Съгласно горното, предлаганите клеми притежават следните характеристики в съответствие с техническите изисквания:

1. Проводниците се присъединяват към клемите чрез винтова връзка, осигуряваща необслабваща електрическа връзка при вибрации и стареене;
2. Проводимите и притискащи части са устойчиви срещу електролитна корозия и ръжда. Гарантиран клас на негоримост – V0 съгласно UL 94;
3. Повишена механична устойчивост;
4. Изолационният материал не абсорбира влага;
5. Клемите са с гнезда за поставяне на етикети от двете страни;
6. Клемите се монтират върху универсална монтажна рейка. Възможен е монтаж както към симетрична шина NS 35/7,5, NS 35/15, така и към несиметрична - NS 32
7. Токови клеми:
 - Пофазно шунтиране на токовите вериги към ТТ с подвижни (фиксиращи към клемата) или преносими изолирани мостове, съгласно приложената схема;
 - Видимо разкъсване на токовите вериги след шунтиране;
 - Включване на товарно устройство за тестване – монтирана или с възможност за монтаж на тест бокса с диаметър 4mm;
 - Видимо разделяне на токовите вериги по предназначение (ядра);
8. Напреженови вериги:
 - Видимо разкъсване ;
 - Включване на товарно устройство за тестване – монтирана или с възможност за монтаж на тест бокса с диаметър 4mm;
 - Възможност за видимо разделяне на напреженовите вериги по фази и предназначение;
 - Възможност за включване на измервателни уреди от двете страни на клемата;



Кратко описание на предложените клеми и аксесоари към тях

1. URTK/S

Клеми с винтова връзка за присъединяване на кръгъл твърд проводник до 10mm^2 или гъвкав проводник с/без накрайник до 6mm^2 . Клемата е с възможност за фиксирано разкъсване на връзката, с гнезда за присъединяване на тестови проводници или за поставяне на шунтиращи мостчета от двете страни на клемата - щифт 4mm . Тази клема е универсална и удовлетворява всички изисквания за яснота на веригата, удобства за превключване. Клемата предлага няколко типа на замостване: чрез конектори с изолирана ръкохватка (2, 4 поз.), превключващи мостове (2, 4 поз.) за окъсяване на трансформаторни вериги, фиксиран мост – 10 позиционен, делим, окомплектован с винтове. Гнездата за тестови проводник или шунтиращ конектор всяка страна са независими от винта за присъединяване на проводника.

2. URTK/SP

Клеми с винтова връзка за присъединяване на кръгъл твърд проводник до 10mm^2 или гъвкав проводник с/без накрайник до 6mm^2 . Клемата е с възможност за фиксирано разкъсване на връзката, с гнезда за присъединяване на тестови проводници или за поставяне на шунтиращи мостчета от двете страни на клемата - щифт 4mm . Тази клема е универсална и удовлетворява всички изисквания за яснота на веригата, удобства за превключване и защита от допир до тоководещи части. Клемата предлага няколко типа на замостване: чрез изолирани превключващи мостове (2, 3, 4, 10 поз.), неизолиран фиксиран мост, конектори с изолирана ръкохватка (2, 4 поз.) Гнездата за тестови проводник или шунтиращ конектор са напълно изолирани.

3. D-URTK

Крайна капачка за клема URTK/S.

4. Разделителна пластина ATP-URTK/SP.

Секционна разделителна пластина за визуално и електрическо разделяне на клемни групи за директен монтаж на DIN шина. Дебелина: 2 мм.

Подходяща за използване с всички токови и напреженови клеми.

5. Шунтиращ мост SB 2-RTK/S.

Двупозиционен подвижен, шунтиращ мост за клеми URTK/S.

6. Шунтиращ мост SB 2-URTK/SP.

Двупозиционен изолиран, подвижен, шунтиращ мост за клеми URTK/SP.

7. Фиксатор за клемен пакет CLIPFIX 35.

Фиксатор със защипване за симетрични шини $35/7,5\text{ mm}$, $35/15\text{ mm}$.


Ширина: $9,5\text{ mm}$. Материал: полиамид.


Клас на запалимост: V0. Цвят: сив.

Може да се маркира със стандартни клемни маркировки ZB, маркировки: KLM, KLM 2.


Съставил:

Инж. Владимир Лазаров
"ВиВ Изоматик" ООД





Вив Изоматик ООД 1680 София, ул. "Тичин" №40А тел. 02 958 63 40, 958 63 44, 958 31 11, факс 958 22 70			
ОБЕКТ: Измервателен клеморед ЧЕЗ		СР / АСУВА / И	
ЧАСТ:	ЛИСТ №: 1 / 1	ВЪЗЛОЖИТЕЛ:	
ОСОБ: РП	МОДЕЛ: -	Чертаж:	
		Р-л: ел.монтаж. инж. Вл. Лазаров	



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки


с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Комплект измервателен клемен блок с клеми за медни проводници от проходен тип и 1Р, 3Р или 3Р+N
стояеми цилиндрични предпазител-прекъсвач-разединители”

Приложение № 3



PHOENIX CONTACT GmbH & Co. KG
Flachsmarktstraße 8
32825 Blomberg, Germany
Telefon: ++49 / (0) 52 35/300
Telefax: ++49 / (0) 52 35/34 12 00
Internet: <http://www.phoenixcontact.com>
USt-Id-Nr.: DE124613250

PHOENIX CONTACT GmbH & Co. KG · 32823 Blomberg

TO WHOM IT MAY CONCERN

Development Quality Laboratory
Business Unit
Industrial Connection Technology

Telefon: ++49 / (0) 52 35/34 20 71
++49 / (0) 52 35/34 10 97
Telefax: ++49 / (0) 52 35/34 12 06

04th of Decembre 2009

Certification regarding the static use of modular terminal blocks in the temperature range from -60°C to +120°C

Dear Sir or Madam,

Based on the available documentation of our plastic suppliers, we herewith certify for the non-reinforced polyamide plastics used in the area of CLIPLINE (Industrial Connection Technology) as follows:

Considering self-heating, articles made of the above materials can be used in static operation from -60°C to +120°C.

Best regards

PHOENIX CONTACT GmbH & Co. KG

PHOENIX CONTACT GmbH & Co. KG
Flachsmarktstraße 8
32825 Blomberg, Germany
Development Quality Laboratory
Business Unit
Industrial Connection Technology

Alessandro Alberani
i.V. Dipl.-Phys. Ing. Alessandro Alberani
Head of Development
Quality Laboratory
Business Unit ICT
i.V. Dipl.-Phys. Ing. Alessandro Alberani

J. Jacke
i.V. Dipl.-Chem. Ing. J. Jacke

ВАРНО С
ОРИГИНАЛА

ЭЛЕКТРОТЕХНИКА
СОФИЯ
2009

PHOENIX CONTACT GmbH & Co. KG
Flachsmarktstraße 8
32825 Blomberg, Germany
Telefon: +49 5235 300
Telefax: +49 5235 3-41200
Internet: <http://www.phoenixcontact.com>
USt-Id-Nr.: DE124613250
WEEE-Reg.-Nr.: DE50738265

PHOENIX CONTACT GmbH & Co. KG · 32823 Blomberg

TO WHOM IT MAY CONCERN

Development Quality Laboratory
Business Unit
Industrial Connection Technology

Phone: ++49 / (0) 52 35/34 20 71
Fax: ++49 / (0) 52 35/341 2 06

04st of Decembre 2009


Confirmation

Dear Sir or Madam,

We hereby confirm that the universal test disconnect terminal block URTK/S (0311087) is applicable at the rated insulation voltage up to 500 V in accordance to IEC 60947-7-1:2002-07 (partly)

Yours sincerely

PHOENIX CONTACT GmbH & Co. KG
Flachsmarktstraße 8
32825 Blomberg, Germany
Development Quality Laboratory
Business Unit
Industrial Connection Technology


i.V. Dipl.-Phys. Ing. Alessandro Alberani
Head of Development
Quality Laboratory
Business Unit ICT


i.V. Dipl.-Phys. Ing. Alessandro Alberani

Pers. haftende Gesellschafterin:
Phoenix Contact Verwaltungs GmbH
Amtsgericht Lemgo HRB 5273
Kön. Ges. Amtsgericht Lemgo HRA 3746

Geschäftsführer: Klaus Eisert,
Roland Bent, Dr. Martin Heubeck,
Prof. Dr. Günther Olesch,
Frank Stührenberg, Dr. Heinz Wesch

Deutsche Bank AG Essen
(BLZ 360 700 50) 226 266 500
Commerzbank Lemgo
(BLZ 476 400 51) 226 039 600

Stadtparkasse Blomberg
(BLZ 476 612 25) 44 008
Postbank Essen
(BLZ 360 100 43) 75 954 34



ДЕКЛАРАЦИЯ ЗА СЪОТВЕТВИЕ

Долуподписаният, Владимир Лазаров- Управител на ВИВ-ИЗОМАТИК ООД,

Декларирам че, материалите, с които се асемблират клемореди тип ИК7ТКЗР, отговарят на следните стандарти и нормативни актове:


-Клеми тип URTK/S и аксесоари за тях, производство на Phoenix Contact GmbH отговарят на следните технически одобрения и нормативни актове:
IEC 60947-7-1

-Разединяеми предпазител-разединители тип FB, производство на Lovato Electric отговарят на следните технически одобрения и нормативни актове :
IEC/EN 60269-1, IEC/EN 60269-2, IEC/EN 60947-1, IEC/EN 60947-3.

25.10.2013.

Владимир Лазаров

ВЯРНО С
ОРИГИНАЛА



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:


„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

“Комплект измервателен клемен блок с клеми за медни проводници от проходен тип и 1P, 3P или 3P+N
стояеми цилиндрични предпазител-прекъсвач-разединители”

Приложение № 4

ВЯРНО С
ОРИГИНАЛА



CERTIFICATE

KEMA No. 97-4117-13

Issued to:

Applicant:

Phoenix Contact GmbH & Co.
Flachmarktstrasse 8-28
BLOMBERG, Germany

Manufacturer/Licensee:

Phoenix Contact GmbH & Co.
Flachmarktstrasse 8-28
BLOMBERG, Germany

Product: terminal blocks

Trade name: PHOENIX CONTACT

Types/models: URTK/S-BEN BU, URTK/S-BEN, URTK/S, URTK/SP,
USLKG 10, USLKG 6N

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-1:1991, EN 60947-7-2:1995
- an inspection of the production location according to CCA Group Operational Document CCA 204
- a certification agreement with the number 900469

KEMA hereby grants the right to use the KEMA certification mark



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: August 6, 1999

C.M. Boschloo
Certification Manager

Integral publication of this certificate is allowed

N.V. KEMA

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9035, 6800 ET Arnhem, The Netherlands
Telephone +31 26 3 56 28 50, Telefax +31 26 3 51 49 22

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

product : terminal blocks
 trade name : PHOENIX CONTACT
 types : URTK/S-BEN BU, URTK/S-BEN, URTK/S,
 URTK/SP, USLKG 10, USLKG 6N
 material : thermoplastic material
 mounting : top hat rail 35 mm (EN 50022) and G-profile
 rail 32 mm (EN 50035)

Additional Information

Markings

Trademark, type designation, rated connection capacity and rated insulation voltage are indented in the insulation material.

Product data – type USLKG 6N

rated connection capacity : 6 mm²
 connectable conductors : one conductor
 0,2 - 10 mm² solid
 0,2 - 6 mm² flexible without ferrule
 0,25 - 6 mm² flexible with ferrule
 two conductors
 0,2 - 2,5 mm² solid
 0,2 - 2,5 mm² flexible without ferrule
 0,25 - 1,5 mm² flexible with ferrule
 description : protective conductor terminal block with 2
 screw-type clamping units, 1-pole

Product data – type URTK/S

rated voltage : 400 V
 rated connection capacity : 6 mm²
 connectable conductors : one conductor
 0,5 - 10 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 10 mm² flexible with ferrule
 two conductors
 0,5 - 2,5 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 4 mm² flexible with ferrule
 rated impulse withstand voltage : 6 kV
 description : disconnect terminal block with 2 screw-type
 clamping units, 1-pole

N.V. KEMA

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
 P.O. Box 9035, 6800 ET ARNHEM, The Netherlands
 Telephone +31 26 3562850, Telefax +31 26 3514922



Product data – type USLKG 10

rated connection capacity : 6 mm²
 connectable conductors : one conductor
 0,5 - 10 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 6 mm² flexible with ferrule
 two conductors
 0,5 - 2,5 mm² solid
 0,5 - 2,5 mm² flexible without ferrule
 0,5 - 2,5 mm² flexible with ferrule
 description : protective conductor terminal block with 2
 screw-type clamping units, 1-pole

Product data – type URTK/S-BEN


rated voltage : 500 V
 rated connection capacity : 6 mm²
 connectable conductors : one conductor
 0,5 - 10 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 10 mm² flexible with ferrule
 two conductors
 0,5 - 2,5 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 4 mm² flexible with ferrule
 rated impulse withstand voltage : 6 kV
 description : disconnect terminal block with 2 screw-type
 clamping units, 1-pole

Product data – type URTK/S-BEN BU

rated voltage : 500 V
 rated connection capacity : 6 mm²
 connectable conductors : one conductor
 0,5 - 10 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 10 mm² flexible with ferrule
 two conductors
 0,5 - 2,5 mm² solid
 0,5 - 6 mm² flexible without ferrule
 0,5 - 4 mm² flexible with ferrule
 rated impulse withstand voltage : 6 kV
 description : disconnect terminal block with 2 screw-type
 clamping units, 1-pole

N.V. KEMA
 Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
 P.O. Box 9035, 6800 ET ARNHEM, The Netherlands
 Telephone +31 26 3562850, Telefax +31 26 3514922

ВЯРНО С
 ОРВИГИНАЛА



Product data – type URTK/SP

rated voltage : 500 V
rated connection capacity : 6 mm²
connectable conductors : one conductor
0,5 - 10 mm² solid
0,5 - 6 mm² flexible without ferrule
0,5 - 6 mm² flexible with ferrule
two conductors
0,5 - 2,5 mm² solid
0,5 - 4 mm² flexible without ferrule
0,5 - 2,5 mm² flexible with ferrule
rated impulse withstand voltage : 6 kV
description : disconnect terminal block with 2 screw-type
clamping units, 1-pole

TESTS**Test requirements**

EN 60947-7-1:1991 + C:1997-06 + A11:1997
EN 60947-7-2:1995 + C:1996-01

Test results


The test results are laid down in KEMA test file 97.4117.13.

Conclusion

The examination proved that all test requirements were met.

Tested by : H.L. Schendstok

Checked by : L.J.W. van Megen

**FACTORY-LOCATION(S)**

Phoenix Contact GmbH & Co.
Flachsmarktstrasse 8-28, BLOMBERG, Germany

N.V. KEMA

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9035, 6800 ET ARNHEM, The Netherlands
Telephone +31 26 3562850, Telefax +31 26 3514922

ВЯРНО С
ОРИГИНАЛА



Тестови изпитвания приложени върху клемите

Клемите са изпитани съгласно IEC60947-7-1,

извършените тестове са:

Капацитет за присъединявания проводник

Механична якост

Огъване

Усилие за отделяне на проводника

Изоляционно разстояние

Повишено напрежение

Загуба на напрежение

Температурен тест

Тест приток на късо съединение


Тест за стареене на материала

Точково нагряване

Управител:

Вл. Лазаров

ВЯРНО С
ОРИГИНАЛА



ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:

„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042

**“Комплект измервателен клемен блок с клеми за медни проводници от проходен тип и 1P, 3P или 3P+N
стояеми цилиндрични предпазител-прекъсвач-разединители”**

Приложение № 5



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

Location where activities are performed under accreditation


Head Office

Meander 1051
6825 MJ
Arnhem
The Netherlands

No.	Material or product	Type of activity	Reference number	Remarks
A. Electrical Safety Tests				
1a	Cables and cords (CABL)	Type test of cables and cords according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	HD 21 HD 22 HD 603 HD 604 HD 605 EN 13501, EN 50143; EN 50214; EN 50267; EN 50525; EN 50288; EN 50399; EN 50618 NEN/EN 50200 NEN/EN/IEC 60228 NEN-EN 50525 NEN/EN 50266 NEN/EN 50362 NEN/EN /IEC 61034 IEC 60092; IEC 60227 *; IEC 60245 *; IEC 60331; IEC 60332; IEC 60502-1; IEC 60502-2; IEC 60754; IEC 60800; IEC 60840; IEC 62067	* see note 3

This annex has been approved by:

Ir. J.C. van der Poel
Chief Executive




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
1a	Cables and cords (CABL)	Type test of cables and cords according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	DEKRA K 42; DEKRA K 102 DEKRA K 145; DEKRA K 146 DEKRA K 151; DEKRA K 152 DEKRA K 156; DEKRA K 157 DEKRA K 158; DEKRA K 160 DEKRA K 161; DEKRA K 162 DEKRA K 163; DEKRA K 164 DEKRA K 165; DEKRA K 167 DEKRA K 168; DEKRA K 169 DEKRA K 170; DEKRA K 171 DEKRA K 175; DEKRA K 176 DEKRA K 177; DEKRA K 178 DEKRA K 179 BS 6004; BS 6007; BS 4553; BS 5467; BS 6231; BS 6346; BS 6387; BS 6500; BS 6622; BS 6724; BS 6883; BS 7211; BS 7629; BS 7835; BS 7846; BS 7889; BS 8491; BS EN 50288-7 BS EN 50525 DIN VDE0815; DIN VDE0250	* see note 3
		Test methods for non-metallic materials	IEC 60811-201; IEC 60811-202 IEC 60811-203; IEC 60811-401 IEC 60811-402; IEC 60811-403 IEC 60811-404; IEC 60811-405 IEC 60811-406; IEC 60811-408 IEC 60811-409; IEC 60811-411 IEC 60811-412; IEC 60811-501 IEC 60811-502; IEC 60811-503 IEC 60811-504; IEC 60811-505 IEC 60811-506; IEC 60811-507 IEC 60811-508; IEC 60811-509 IEC 60811-510; IEC 60811-511 IEC 60811-605; IEC 60811-606 IEC 60811-607	
		Electrical test methods for low voltage energy cables	NEN-EN 50395	
		Non electrical test methods for low voltage energy cables	NEN-EN 50396	



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
1b	Conduits	Type test of conduits according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	NEN/EN/IEC 61386 DEKRA K24 EN 50086	
1c	Installation systems Cable trays Cable ladders	Type test of cable trays and cable ladders, according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	KEMA 55 NEN/EN 50085 NEN/IEC/EN 61537 BS EN 61537	
1d	Boxes and enclosures for electrical installations	Type test of boxes and enclosures for electrical installations, according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	NEN/EN/IEC 60670	
2a	Switches for appliances and automatic controls for electrical household appliances (CONT)	Type test of switches according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests. 	IEC/EN 60730*, 61095* IEC/EN 60691, 60934, 61058*, 60529 IEC 60265, 62271-1, 62271-100, 62271-101, 62271-102, 62271-105, 62271-110, 62271-200, 62271-201, 62271-202, 62271-203, EN 50152-1 IEEE Std C37.09, C37.081, 37.60, C37.013, C37.34, ANSI C37.41, C37.73, C37.20.2, C37.122 ANSI/IEEE C37.21 ANSI C37.54, C37.55, C37.20.2, C37.72	* see note 3


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
3	Household and similar equipment (HOUS)	Type test of household equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60335* IEC/EN 61770 IEC/EN 62233 EN 50366 IEC/EN 60204 IEC/EN 60730-1/ 2-8 / 2-9 IEC/EN 61558-1/ 2-3 / 2-6 / 2-5 / 2-6 / 2-16 IEC/EN 62061 EN/ISO 13849-1	* see note 3
		Low power measurements	IEC/EN 62301	
4	Installation accessories and connection devices (INST)	Type test of installation accessories and connection devices according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60309*, 60320*, 60669*, 60670*, 60799*, 60884*, 60998*, 61058*, 61242*, 61534*, 61984*, 62208*; IEC/EN 60335-2-76, 60974, 61316, 61386, 62094 EN 50075, 50066, 50146, 50250, 50393 NEN 1251, IEC 60884*, 61238, 62080 BS 1363-1, BS 1363-2, BS 1363-3, BS 1363-4 SS 145 BS 546 BS 4573 BS 5733 NEN 1020 NF C61-314 DIN VDE 0620-1 DIN VDE 0620-2-1 CEI 23-50 NBN C 61-112-1 NEK IEC 60884-1 NEK 502 ÖVE/ÖNORM E 8684-1 ÖVE/ÖNORM E 8620-2(-3,-4, -5) SFS 5610 SS 428 08 34 DS 60884-2-D1 SEV 1011 UNE 20315-1-1; UNE 20315-1-2 IEC/EN 61535 EN 50428 required with 60669	* see note 3



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
5	Luminaires (LITE)	Type test of luminaires according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 60155*, 60238*, 60400*, 60570*, 60598*, 60838*, 60921*, 60968*, 60969*, 61347*, 62471* IEC/EN 60929, 61184, 62031, 62035, 60923, 60925, 60927, 61047, 62384, 62560, 61195, 62493	* see note 3
6	Measurement, control and laboratory equipment (MEAS)	Type test of measurement-, control- and laboratory equipment according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 61010* IEC/EN 60044 IEC/EN 61243 IEEE Std C57.13	* see note 3
7	Electrical equipment for medical use (MED)	Type test of electrical equipment for medical use according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 60601* IEC/EN/ISO 80601 HD 395	* see note 3
8	Miscellaneous equipment (MISC)	Type test of miscellaneous equipment according to the tests in the standard, among others: <ul style="list-style-type: none"> - electrical safety tests - mechanical tests - environmental tests 	IEC/EN 60825*	* see note 3




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
9	IT and office equipment (OFF)	Type test of IT and office equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60950* IEC/EN 62040* IEC/EN 60825 IEC 62368 EN 41003	* see note 3
10	Low voltage, high power switching equipment (POW)	Type test of low voltage, high power switching equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60439*, 61439, IEC/EN 60947* IEC/EN 60282, 62208 EN 50178, IEC 60470, 60549, 60644, EN 60282-1 IEEE Std C37.41, C37.60 ANSI C37.44 IEC 61921	* see note 3
11	Installation protective equipment (PROT)	Type test of installation protective equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60127*, 60269*, 60529*, 60898*, 61008*, 61009*, 61643*, 60755, 62019 IEC 60099, 60137, 60168, 60383, 60507, 60660, 61109, 60815 HD 630, 639, 60269 IEEE Std 62.11 ANSI C29 CAN/CSA C411.1	* see note 3
12	Safety transformers and similar equipment (SAFE)	Type test of safety transformers and similar equipment according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60044*, IEC/EN 61558* IEC/EN 62040, IEC/EN 60076, IEC/EN 60353 EN 50091, EN 50464-1 HD 538.1 IEEE Std. C57.12.90, C57.21 NEMA 107 CISPR 16	* see note 3



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
13	Electric tools (TOOL)	Type test of electric tools according to the tests in the standard, among others: - electrical safety tests - mechanical tests - environmental tests	IEC/EN 60745* IEC/EN 61029* IEC/EN 60335* (Gardening) IEC/EN 62233, IEC/EN 60204 EN 50144 EN 50260-2-7 EN 792 EN/ISO 1114 IEC/EN 62061 EN/ISO 13849-1	* see note 3
14	Electronics, entertainment equipment (TRON)	Type test according to the tests as mentioned in the standard, except the following tests which are subcontracted: 60065, cl. 20.1.3 Pre-conditioning of printed circuit boards 60065, cl. 12.1.2 Vibration-sine	IEC / EN 60065* IEC / EN 60491 IEC 62368	* see note 3
15	Products within the scope of the EMC Directive 2004/108/EC (EMC)	Type test according to the tests as mentioned in the standard	CISPR11; CISPR12; CISPR13; CISPR14-*; CISPR15; CISPR16-*-*; CISPR20; CISPR22; CISPR24; CISPR25; IEC60601-*-*; IEC60945; IEC60947-*-*; IEC61000-*-*; IEC61008-1; IEC61009-1; IEC61131-2; IEC61204-3; IEC61326-*; IEC61543; IEC61547; IEC61800-*; IEC62040-2; IEC62052-*; IEC62053-*; IEC62054-*;	* see note 3

B. Electromagnetic Compatibility (EMC): Automotive tests

1	Vehicles, Motorcycles, Motorboats and Spark-ignited engine-driven devices	Radiated emission 30 to 1000 MHz OATS	European Directives 2004/104/EC, 97/24/EC European regulation ECE-R10.04 EN 55012, CISPR 12	
2	Vehicles, Motorcycles, Motorboats and Spark-ignited engine-driven devices	Radiated immunity up to 30 V/m 20 to 2000 MHz OATS	European Directive 2004/104, 97/24/EC European regulation ECE-R10.04	

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**


This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
3	Electrical/ electronic sub-assembly	Pulse emission for ESA's along supply lines 12V and 24V	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 7637-1 ISO 7637-2	
4		Conducted emission for ESA's (V-method, LISN) 150 kHz to 108 MHz	European Directive 2004/104/EC European regulation ECE-R10.04 CISPR25	
5		Radiated emission for ESA's Anechoic Chamber method 30 to 1000 MHz	European Directive 2004/104/EC European regulation ECE-R10.04 CISPR25	
6		Radiated immunity for ESA's Anechoic Chamber method and GTEM method 20 to 2000 MHz up to 30V/m	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 11452-1, ISO 11452-2, ISO 11452-3	
7	Electrical/ electronic sub-assembly	Bulk Current Injection for ESA's 20 to 400 MHz up to 100 mA	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 11452-1, ISO 11452-4	
8		Pulse immunity for ESA's along supply lines 12V and 24V	European Directive 2004/104/EC European regulation ECE-R10.04 ISO 7637-1 ISO 7637-2	

C. Electromagnetic Compatibility (EMC): EMF tests

1	Electrical and electronic equipment	EMF measurements: 0-400 kHz	EN 62233 EN 62493	
---	--	--------------------------------	----------------------	--



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
-----	---------------------	------------------	------------------	---------

D. Electromagnetic Compatibility (EMC): Emission tests


1	Electrical and electronic equipment	Conducted emission 9 kHz to 30 MHz	EN 55011, CISPR 11 EN 55013, CISPR 13 EN 55014-1, CISPR 14-1 EN 55015, CISPR 15 EN 55022, CISPR 22	
2		Radiated Emission Electric (EM) Field 30 MHz to 18 GHz	EN 55011, CISPR 11 EN 55014-1, CISPR 14-1 EN 55022, CISPR 22	
3		Disturbance power 30 MHz to 300 MHz	EN 55014-1, CISPR 14-1	
4		Click disturbances 150 kHz to 30 MHz	EN 55011, CISPR 11 EN 55014-1, CISPR 14-1	
5		Radiated Emission Magnetic Field 9 kHz to 30 MHz	EN 55011, CISPR 11 EN 55015, CISPR 15	
6		Harmonic current emissions 0 Hz to 2 kHz up to 16 A per phase	IEC / EN 61000-3-2	
7		Pulse magnetic field immunity up to 1000 A/m	IEC/EN 61000-4-9	
8		Limitation of voltage fluctuations and flicker up to 16 A per phase	IEC / EN 61000-3-3	

E. Electromagnetic Compatibility (EMC): FCC tests (USA legislation)

1	Radio-Frequency Devices Industrial, Scientific and Medical Equipment	Emission 9 kHz to 3 GHz	47 CFR FCC Part 15, Part 18 ANSI C63.4 FCC MP-5	
---	---	----------------------------	---	--

F. Electromagnetic Compatibility (EMC): Immunity test

1	Electric and electronic equipment	Electrostatic discharge immunity up to 30 kV	IEC/EN 61000-4-2	
2		Radiated EM field immunity up to 2,5 GHz up to 30 V/m	IEC/EN 61000-4-3	
3		EFT Burst immunity up to 4 kV	IEC/EN 61000-4-4	



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
4	Electric and electronic equipment	Surge immunity up to 10 kV	IEC/EN 61000-4-5	
5		Immunity to conducted RF disturbances up to 230 MHz, up to 30 Vrms	IEC/EN 61000-4-6	
6		Power frequency magnetic field immunity up to 100 A/m	IEC/EN 61000-4-8	
7		Voltage dips and interruptions Single phase equipment up to 16 A	IEC/EN 61000-4-11	
8		Ring wave immunity test	IEC/EN 61000-4-12	


G. Electromagnetic Compatibility (EMC): MISC

1	Railway applications - Electromagnetic compatibility	Electromagnetic compatibility testing according the listed product standards	EN 50121-1 to -5	
2	Road traffic signal systems	Electromagnetic compatibility testing according the listed product standard	EN 50293	

H. Photometric Tests

(all tests are in accordance with the reference method)

1	Headlamps low and high beams and front fog lamps	All tests as mentioned in the ECE Regulations stated under Test method Photometry Colorimetry Heat tests Plastic tests	ECE Regulations Nos. 1, 5, 8, 19, 20, 31, 56, 57, 72, 76, 82, 98, 112, 113 and 123; European Directives 76/761, 76/762 and 97/24	Note 1
2	Signalling lamps	All tests as mentioned in the ECE Regulations stated under Test method Photometry Colorimetry Heat test	ECE Regulations Nos. 6, 7, 23, 38, 50, 77, 87 and 91 and European Directives 76/757, 76/759, 76/758, 77/538, 77/539, 77/540 and 97/24 ECE Regulation 38 (rear fog lamps only)	
3	Devices for the illumination of rear registration plates	All tests as mentioned in the ECE Regulations stated under Test method Luminance	ECE Regulations Nos. 4 and 50 European Directives 76/760 and 97/24	



C

C


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
4	Retro-reflective devices	All tests as mentioned in the ECE Regulations stated under Test method Retro-reflection Colorimetry Water resistance test Corrosion Fuel and oil resistance Heat test UV resistance	ECE Regulations Nos. 3, 27, 69, 70, 88 and 104 European Directive 76/757	Note 2
5	Light Sources	All tests as mentioned in the ECE Regulations stated under Test method Geometry Photometry Colorimetry Optical quality Mechanical tests	ECE Regulations Nos. 37, 99 IEC 60809 IEC 60810 IEC 60983 IEC 60061	
6	Special warning lamps (beacons and flash lights)	All tests as mentioned in the ECE Regulations stated under Test method Photometry Colorimetry Water resistance test	ECE Regulation No. 65	
7	Cornering Lamps	All tests as mentioned in the ECE Regulation stated under Test method Photometry Colorimetry	ECE Regulation No.119	



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of DEKRA Certification B.V.

This annex is valid from: 29-04-2015 to 01-03-2018

Replaces annex dated: 03-11-2014

No.	Material or product	Type of activity	Reference number	Remarks
I. Lighting testing: EPA ENERGY STAR Program				
1	Non-directional Fluorescent Luminaires	Specifications for Performance of Self-Ballasted Compact Fluorescent Lamps, Source Run-up Time (ms)	ANSI C78.5:2003	
		Method of Measurement of Fluorescent Lamp Ballasts, Power Factor, Operating Frequency	ANSI C82.2:2002	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electric and Photometric Measurements of Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-9:2009	
		Life Testing of Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-40:2010	
		Life Testing of Compact Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-65:2010	
		Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-66:2011	



[Handwritten signature]


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
2	Directional Fluorescent Luminaires	Specifications for Performance of Self-Ballasted Compact Fluorescent Lamps, Source Run-up Time (ms)	ANSI C78.5:2003	
		Method of Measurement of Fluorescent Lamp Ballasts, Power Factor, Operating Frequency	ANSI C82.2:2002	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electric and Photometric Measurements of Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-9:2009	
		Life Testing of Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-40:2010	
		Life Testing of Compact Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-65:2010	
		Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-66:2011	
		Photometric Testing of Outdoor Fluorescent Luminaires, Efficacy, Light Output, Zonal Lumen Distribution	IES LM-10:2013	
Approved Method for Photometric Testing of Indoor Fluorescent Luminaires, Efficacy, Light Output, Zonal Lumen Distribution	IES LM-41:2013			
3	Luminaires CSD - Fluorescent Ballasts	Method of Measurement of Fluorescent Lamp Ballasts, Power Factor, Operating Frequency	ANSI C82.2:2002	



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
4	Luminaires CSD - Fluorescent Lamps	Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electric and Photometric Measurements of Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-9:2009	
		Life Testing of Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-40:2010	
		Life Testing of Compact Fluorescent Lamps, Light Source Life, Lumen Maintenance	IES LM-65:2010	
		Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Lumen Maintenance, CCT, CRI	IES LM-66:2011	
5	Non-Directional HID Luminaires	High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		Ballasts for High Intensity Discharge (HID) Lamps - Methods of Measurement, Power Factor, Lamp Current Crest Factor	ANSI C82.6:2005	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Life Testing of High Intensity Discharge (HID) Lamps, Light Source Life, Lumen Maintenance	IES LM-47:2012	
		Electrical and Photometric Measurements of High Intensity Discharge Lamps, Efficacy, Light Output, CCT, CRI	IES LM-51:2013	

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
6	Directional HID Luminaires	High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		Ballasts for High Intensity Discharge (HID) Lamps - Methods of Measurement, Power Factor, Lamp Current Crest Factor	ANSI C82.6:2005	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Life Testing of High Intensity Discharge (HID) Lamps, Light Source Life, Lumen Maintenance	IES LM-47:2012	
		Electrical and Photometric Measurements of High Intensity Discharge Lamps, Efficacy, Light Output, CCT, CRI	IES LM-51:2013	
		Photometric Testing of Roadway Luminaires Using Incandescent Filament and High Intensity Discharge (HID) Lamps, Efficacy, Output, Zonal Lumen Distribution	IES LM-31:2013	
		Photometric Testing of Indoor Luminaires Using High Intensity Discharge or Incandescent Filament Lamps, Efficacy, Light Output, Zonal Lumen Distribution	IES LM-46:2004	
7	Luminaires CSD - HID Ballasts	High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		High-Intensity Discharge (HID)— Methods of Measuring Characteristics, Operating Frequency	ANSI C78.389:2004 (R2009)	
		Ballasts for High Intensity Discharge (HID) Lamps - Methods of Measurement, Power Factor, Lamp Current Crest Factor	ANSI C82.6:2005	


Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
8	Luminaires GSD - HID Lamps	Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering	CIE Pub. No.13.3:1995	
		Life Testing of High Intensity Discharge (HID) Lamps, Light Source Life, Lumen Maintenance	IES LM-47:2012	
		Electrical and Photometric Measurements of High Intensity Discharge Lamps, Efficacy, Light Output, CCT, CRI	IES LM-51:2013	
9	Non-directional Solid State Luminaires and Subcomponents	Electrical and Photometric Measurements of Solid-State Lighting Products (section 10 not required for non-directional or subcomponents), Efficacy, Output, Lumen Maintenance, CCT, CRI, Color Maintenance	IES LM-79:2008	
		Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, Power Factor	ANSI C82.77:2002	
		Method of Measuring and Specifying Color Rendering of Light Sources, CRI	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Characterization of LED Light Engines and LED Lamps for Electrical and Photometric Properties as a Function of Temperature, Efficacy, Light Output, Lumen Maintenance, CCT, CRI, Color Maintenance, Light Source Life	IES LM-82:2012	
10	Directional Solid State Luminaires	Electrical and Photometric Measurements of Solid-State Lighting Products (Goniophotometer), Zonal Lumen Distribution, Color Angular Uniformity, Luminaire Photometry	IES LM-79:2008 sections 10 and 12	
		Guide to Spectroradiometric Measurements, Color Angular Uniformity	IES LM-58:2013	



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
10	Directional Solid State Luminaires	Method of Measuring and Specifying Color Rendering of Light Sources, CRI	CIE Pub. No.13.3:1995	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Electrical and Photometric Measurements of Solid-State Lighting Products, Efficacy, Light Output, Lumen Maintenance, CCT, CRI, Color Maintenance	IES LM-79:2008	
11	Lumen Maintenance of LED Packages, Arrays, and Modules	Method for Measuring Lumen Maintenance of LED Light Sources, Light Source Life, Lumen Maintenance	IES LM-80:2008	
12	Non-Directional Outdoor Halogen Luminaires	Approved Method for Life Testing of Filament Lamps, Light Source Life Requirements	IES LM-49:2001, IES LM-49:2011	
13	Directional Outdoor Halogen Luminaires	Approved Method for Life Testing of Filament Lamps, Light Source Life Requirements	IES LM-49:2001	
		Photometric Testing of Outdoor Fluorescent Luminaires, Zonal Lumen Distribution	IES LM-10:1996	
		Photometric Testing of Roadway Luminaires Using Incandescent Filament and High Intensity Discharge (HID) Lamps, Zonal Lumen Distribution	IES LM-31:1991	
		Photometric Testing of Indoor Fluorescent Luminaires, Zonal Lumen Distribution	IES LM-41:1998	
		Photometric Testing of Indoor Luminaires Using High Intensity Discharge or Incandescent Filament Lamps, Zonal Lumen Distribution	IES LM-46:2004	
		Electrical and Photometric Measurements of Solid-State Lighting Products, Zonal Lumen Distribution	IES LM-79:2008 Section 10	

Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
14	CFL Directional Lamps	Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Center beam Intensity, Lumen Maintenance, Lifetime, CCT, CRI	IES LM-66:2011	
		Life Testing of Compact Fluorescent Lamps, Lumen Maintenance, Lifetime, Rapid Cycle Stress Test	IES LM-65:2010	
		IEEE Recommended Practice on Characterization of surges in Low Voltage (1000V and Less) AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Fluorescent Lamp Ballasts, Method of Measurement of Power Factor (included supplements)	ANSI C82.2:2002	
		Specifications for the Chromaticity of Fluorescent lamps, CCT	ANSI C78.376-2001	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Tool for Calculating Minimum Center beam Intensity, Minimum Center Beam Intensity – PAR and MR Lamps	Energy Star Online CBCP Tool	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, ETLOR	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Light Output Ratio	
ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time			




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
14	CFL Directional Lamps	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	
15	CFL Omnidirectional and Decorative Lamps	Electrical and Photometric Measurements of Single-Ended Compact Fluorescent Lamps, Efficacy, Light Output, Center beam Intensity, Lumen Maintenance, Lifetime, CCT, CRI	IES LM-66:2011	
		Life Testing of Compact Fluorescent Lamps, Lumen Maintenance, Lifetime, Rapid Cycle Stress Test	IES LM-65:2010	
		IEEE Recommended Practice on Characterization of surges in Low Voltage AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Specifications for the Chromaticity of Fluorescent lamps, CCT	ANSI C78.376-2001	
		Method of Measurement of Fluorescent Lamp Ballasts, Power Factor	ANSI C82.2:2002	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Run-up Time	




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
16	LED Directional Lamps	Electrical and Photometric Measurements of Solid-State Lighting Products, Efficacy, Output, Center Beam Intensity, Luminous Intensity Distribution, Lumen Maintenance, Lifetime, CCT, CRI, Color Maintenance, Color Angular Uniformity	IES LM-79:2008	
		Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, Power Factor	ANSI C82.77:2002 Sections 6 and 7	
		IEEE Recommended Practice on Characterization of surges in Low Voltage AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Chromaticity of Solid State Lighting Products, CCT	ANSI C78.377-2011	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		Tool for Calculating Minimum Center beam Intensity, Minimum Center Beam Intensity – PAR and MR Lamps	Energy Star Online CBCP Tool	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing	
ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, ET/LOR	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Light Output Ratio			




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
16	LED Directional Lamps	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	
17	LED Omnidirectional and Decorative Lamps	Electrical and Photometric Measurements of Solid-State Lighting Products, Efficacy, Output, Center Beam Intensity, Luminous Intensity Distribution, Lumen Maintenance, Lifetime, CCT, CRI, Color Maintenance, Color Angular Uniformity	IES LM-79:2008	
		Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, Power Factor	ANSI C82.77:2002 Sections 6 and 7	
		IEEE Recommended Practice on Characterization of surges in Low Voltage AC Power Circuits, Transient Protection	ANSI/IEEE C62.41.2-2002	
		Colorimetry, CCT	CIE Pub No. 15:2004	
		Method of Measuring and Specifying Color Rendering of Light Sources, Color Rendering (CRI)	CIE Pub. No.13.3:1995	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Elevated Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing, Lumen Maintenance, Lifetime	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Ambient Temperature Life Testing	
		ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Start Time	




Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: L 022

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

No.	Material or product	Type of activity	Reference number	Remarks
I. Additional Standards related to Energy Star				
1	Reflector type lamps	Photometric Testing	IES LM-35:2002	
2	Floodlights Using Incandescent Filament of Discharge Lamps	Electrical and photometric measurements	IES LM-45:2009	
3	Fluorescent Lamps	Electrical measurements	ANSI C78.375:1997 ANSI C78.375:2014	
4	Fluorescent Lamps	Chromaticity of Fluorescent Lamps	ANSI C78.376-2001	
5	Fluorescent Lamps	Chromaticity of Solid State Lighting Products	ANSI C78.377-2011	
6	Mercury Lamps	Measuring Characteristics	ANSI C78.386:1989	
7	Metal-Halide Lamps	Measuring Characteristics	ANSI C78.387:1987	
8	High Pressure Sodium Lamps	Measuring Characteristics	ANSI C78.388:1990	
9	High-Frequency Fluorescent Lamp Ballast	Measurement of a High-Frequency Fluorescent Lamp Ballast	ANSI C82.11-2002	
10	Light sources	The measurement of luminous flux	CIE 84:1989	
11	Luminaires	The Photometry and goniophotometry of luminaires	CIE121:1996	
12	All LED Products	Measurements of LEDs	CIE127:1997 CIE127:2007	
13	All products	Transient protection	ANSI/IEEE C62.41.1 ANSI/IEEE C62.41.2	
14	Decorative Light Strings	Weathering Test	ASTM G154-06 ASTM G154-12a	
15	Decorative Light Strings	ENERGY STAR Test Method for Decorative Light Strings	ENERGY STAR Test Method for Decorative Light Strings	
16	All products	ENERGY STAR Program requirements Product Specification for Lamps Version 1.0: Final Test Methods and Recommended Practices	ENERGY STAR Program Requirements Product Specification for Lamps Version 1.0: Final Test Methods and Recommended Practices	



Annex to ISO/IEC 17025:2005 declaration of accreditation for registration number: **L 022**

of **DEKRA Certification B.V.**

This annex is valid from: **29-04-2015** to **01-03-2018**

Replaces annex dated: **03-11-2014**

Note 1: Weather-beaten tests of synthetic lenses is subcontracted

Note 2: Salt-nebula test is subcontracted

Note 3: See current list of sub set of standards on the IECEE CBTL website



CC

CC

ДОКУМЕНТАЦИЯ

за участие в процедура на договаряне с обявление
за сключване на рамково споразумение за възлагане на обществени поръчки

с предмет:



„Доставка и монтаж на бетонови комплектни трансформаторни постове /БКТП/“

РЕФ. № PPD 15-042


**“Комплект измервателен клемен блок с клеми за медни проводници от проходен тип и 1Р, 3Р или 3Р+N
стояеми цилиндрични предпазител-прекъсвач-разединители”**


Приложение № 6






Fuse holders and fuses

 **Lovato**
electric
100% electricity




Fuse holders





- ◆ Modular concept for quick assembly of different versions based on various requirements.
- ◆ Compact size compliant with standards for electrical equipment.
- ◆ DIN rail mounting and removal ease.
- ◆ IP20 protection degree, finger safe.
- ◆ Sealable cover in open or closed position to increase user's safety.
- ◆ Version with status indicator to quickly determine if the fuse is still operative or needs to be replaced.
- ◆ Ergonomic grip for easy cover opening.
- ◆ Dedicated cylindrical 10x38 DC fuses for photovoltaic systems.
- ◆ UL and GSA certified versions.

Range	AC			DC	DC FUSES	CLASS CC
Fuse size	10x38	14x51	22x58	10x38	10x38	10x38
Type	gG or aM			gPV	gPV	Class CC
Rated voltage	690VAC			1000VDC / 690VAC	1000VDC	600VAC
Rated current	32A	50A	125A	32A	20A	30A
Utilisation category	AC-22B 500V AC-21B 690V		-	DC-20B 1000VDC AC-21B 690V	DC-20B 1000VDC	AC-22B 500V AC-21B 690V



and fuses




LOVATO Electric fuse holders can be used to protect against overloads and short circuits of electric lines, for motor protection and control and for the protection of electric installations.

This equipment can assure the disconnect function but is not suitable for isolation so cannot be used as switch disconnecter.

The range is available in two versions: with or without fuse status indicator. If the fuse fitted on the holder blows, the failure status is shown by the indicator on the fuse-holder front.

All the fuse holders are certified for the North-American market (UL Listed, UL Recognized and CSA). Furthermore, there is a non-certified version in 10x38mm size available too.




Fuse holders **AC** RANGE

LOVATO Electric AC fuse-holder range is suitable for class gG fuses, to protect cables and conductors, and for class aM fuses, to protect motor starting.

Function: Overload and short-circuit protection of control circuits, motor controls, electric installations.


Usage: Service industry, electric panels onboard machinery, electric installations in general.



Fuse size	FB01 A...	FB01 B...	FB02 A...	FB03 A...
Version without indicator	1P, 1P+N, 2P, 3P, 3P+N			
Version with indicator	1P			
Main characteristics				
- Rated voltage	690VAC			
- Rated current	32A		50A	125A
- Utilisation category	AC-22B 500V, AC-21B 690V		AC-22B 500V, AC-21B 690V	AC-21B 690V
- Suitable for fuses	10x38 gG or aM		14x51 gG or aM	22x58 gG or aM
- Maximum conductor cross section	16mm ² flexible/stranded; 25mm ² rigid/solid		25mm ² flexible/stranded; 35mm ² rigid/solid	35mm ² flexible/stranded; 50mm ² rigid/solid
Certifications obtained	UR, CSA	-	cURus	cURus
Compliant with standards	IEC/EN 60947-1, IEC/EN 60947-3, RoHS directive, UL512, CSA C22.2 n°39			

UR: UL Recognized; cURus: UL Recognized for USA and Canada.

CLASS **CC** Fuse holders RANGE




FB01 C...

LOVATO Electric fuse holders for class CC fuses are used to protect branch circuits, consisting of conductors and components following the last overcurrent protective device protecting a load, in industrial applications which require high breaking capacity.

Suitable only and exclusively for fitting fuses defined as "class CC", quite common on the North American market.


Usage: Service industry, electric panels onboard machinery, electric installations in general.

Fuse size	Class CC
Version without indicator	1P, 2P, 3P
Version with indicator	1P
Main characteristics	
- Rated voltage	600VAC
- Rated current	30A
- Utilisation category	AC-22B 500V, AC-21B 690V
- Suitable for fuses	10x38 class CC
- Maximum conductor cross section	16mm ² flexible/stranded; 25mm ² rigid/solid
Certifications obtained	UL, CSA
Compliant with standards	IEC/EN 60947-1, IEC/EN 60947-3UL512, RoHS directives, CSA 22.2 n° 39



Fuse holders


DC



FB01 D...

LOVATO Electric DC fuse holder range is suitable for 1000VDC rated voltage and gPV class. Used for overload and short-circuit protection of photovoltaic modules (strings) and the relative connecting cables.

Fuse size	10x38
Version without indicator	1P, 2P
Version with indicator	1P
Main characteristics	
- Rated voltage	1000VDC / 690VAC
- Rated current	32A
- Utilisation category	DC-20B 1000VDC, AC-21B 690V
- Suitable for fuses	10x38 gPV
- Maximum conductor cross section	16mm ² flexible/stranded, 25mm ² rigid/solid
Compliant with standards	IEC/EN 60947-1, IEC/EN 60947-3, RoHS directive



Fuses



DC



FE01 D 0...

LOVATO Electric offers a range of cylindrical 10x38 fuses dedicated to photovoltaic duty and designed for 1000VDC maximum use. Contrary to AC type fuses that blow for high overcurrent values, this type of DC fuse is designed to blow with low-intensity overcurrent values, created on photovoltaic cells and panels.

Fuses for photovoltaic application	
Breaking capacity	30kA
Main characteristics	
- Rated voltage	1000VDC
- Rated current	2...20A




TECHNICAL CHARACTERISTICS


Type	FB01 A...	FB01 B...	FB02 A...	FB03 A...	FB01 C...	FB01 D...	
Range	AC	AC	AC	AC	Class CC (AC)	DC	
Certifications obtained	UR, CSA	—	cURus	cURus	UL, CSA	—	
Maximum power dissipation	3W	3W	5W	9.5W	3W	4W	
Derating factor of current I_e for different ambient temperatures	20°C	1	1	1	1	1	
	30°C	0.95	0.95	0.95	0.95	0.95	
	40°C	0.9	0.9	0.9	0.9	0.9	
	50°C	0.8	0.8	0.8	0.8	0.8	
	60°C	0.7	0.7	0.7	0.7	0.7	
	70°C	0.5	0.5	0.5	0.5	0.5	
Derating factor of current I_e for side-by-side fuse holders - n° poles	1-3	1	1	1	1	1	
	4-6	0.8	0.8	0.8	0.8	0.8	
	7-9	0.7	0.7	0.7	0.7	0.7	
>10	0.6	0.6	0.6	0.6	0.6	0.6	
Voltage for status indicator	120...690VAC	120...690VAC	230...690VAC	230...690VAC	120...600VAC	350...1000VDC	
CONNECTIONS							
Maximum tightening torque	2.5Nm/22lbin	2.5Nm/22lbin	3Nm/26lbin	4Nm/35lbin	2.5Nm/22lbin	2.5Nm/22lbin	
Maximum conductor cross section	flexible/stranded	1-16mm ² /8 AWG	1-16mm ² /6 AWG	1-25mm ² /4 AWG	1-35mm ² /2 AWG	1-16mm ² /8 AWG	1-16mm ² /6 AWG
	rigid/solid	1-25mm ² /8 AWG	1-25mm ² /4 AWG	1-35mm ² /2 AWG	1-50mm ² /1 AWG	1-25mm ² /10 AWG	1-25mm ² /4 AWG
AMBIENT CONDITIONS							
Operating temperature	-20...+70°C	-20...+70°C	-20...+70°C	-20...+70°C	-20...+70°C	-20...+70°C	
Storage temperature	-40...+80°C	-40...+80°C	-40...+80°C	-40...+80°C	-40...+80°C	-40...+80°C	
HOUSING							
Din rail mount version	Yes	Yes	Yes	Yes	Yes	Yes	
Degree of protection	IP20	IP20	IP20	IP20	IP20	IP20	

DIMENSIONS


FB01 A... FB01 B... FB01 C... FB01 D...



FB02 A...




FB03 A...



ASSEMBLY

Accessories: Coupling elements (clips and pins) to mount and fix fuse holders side by side



HOW TO ORDER

FUSE HOLDERS

Order code	Pole arrangement	DIN modules n°	Status indicator	Rated voltage Ue [V]	Rated nominal Ie [A]	Qty per pkg n°	Weight [kg]
Fuse holder (fuse disconnecter), 10x38, certified by UR and CSA.							
FB01 A 1P	1 pole	1	--	690VAC	32	12	0.750
FB01 A 1PL	1 pole	1	Yes	690VAC	32	12	0.750
FB01 A 1N	1 pole + N	2	--	690VAC	32	6	0.750
FB01 A 2P	2 poles	2	--	690VAC	32	6	0.750
FB01 A 3P	3 poles	3	--	690VAC	32	4	0.750
FB01 A 3N	3 poles + N	4	--	690VAC	32	3	0.750
Fuse holder (fuse disconnecter), 14x51, certified by cURus.							
FB02 A 1P	1 pole	1.5	--	690VAC	50	6	1.000
FB02 A 1PL	1 pole	1.5	Yes	690VAC	50	6	1.000
FB02 A 1N	1 pole + N	3	--	690VAC	50	3	1.000
FB02 A 2P	2 poles	3	--	690VAC	50	3	1.000
FB02 A 3P	3 poles	4.5	--	690VAC	50	2	1.000
FB02 A 3N	3 poles + N	6	--	690VAC	50	1	0.650
Fuse holder (fuse disconnecter), 22x58, certified by cURus.							
FB03 A 1P	1 pole	2	--	690VAC	125	6	1.050
FB03 A 1PL	1 pole	2	Yes	690VAC	125	6	1.050
FB03 A 1N	1 pole + N	4	--	690VAC	125	3	1.050
FB03 A 2P	2 poles	4	--	690VAC	125	3	1.050
FB03 A 3P	3 poles	6	--	690VAC	125	2	1.050
FB03 A 3N	3 poles + N	8	--	690VAC	125	1	0.700
Fuse holder (fuse disconnecter), class CC, certified by UL and CSA.							
FB01 C 1P	1 pole	1	--	600VAC	30	12	0.750
FB01 C 1PL	1 pole	1	Yes	600VAC	30	12	0.750
FB01 C 2P	2 poles	2	--	600VAC	30	6	0.750
FB01 C 3P	3 poles	3	--	600VAC	30	4	0.750
Fuse holder (fuse disconnecter), 10x38.							
FB01 B 1P	1 pole	1	--	690VAC	32	12	0.750
FB01 B 1PL	1 pole	1	Yes	690VAC	32	12	0.750
FB01 B 1N	1 pole + N	2	--	690VAC	32	6	0.750
FB01 B 2P	2 poles	2	--	690VAC	32	6	0.750
FB01 B 3P	3 poles	3	--	690VAC	32	4	0.750
FB01 B 3N	3 poles + N	4	--	690VAC	32	3	0.750
Fuse holder (fuse disconnecter), 10x38, for photovoltaic applications.							
FB01 D 1P	1 pole	1	--	1000VDC	32	12	0.750
FB01 D 1PL	1 pole	1	Yes	1000VDC	32	12	0.750
FB01 D 2P	2 poles	2	--	1000VDC	32	6	0.750

FUSES FOR PHOTOVOLTAIC APPLICATIONS

Order code	Rated breaking capacity [kA]	Rated voltage Ue [V]	Rated current Ie [A]	Qty per pkg n°	Weight [kg]
FE01 D 00200	30	1000VDC	2	10	0.130
FE01 D 00400	30	1000VDC	4	10	0.130
FE01 D 00600	30	1000VDC	6	10	0.130
FE01 D 00800	30	1000VDC	8	10	0.130
FE01 D 01000	30	1000VDC	10	10	0.130
FE01 D 01200	30	1000VDC	12	10	0.130
FE01 D 01600	30	1000VDC	16	10	0.130
FE01 D 02000	30	1000VDC	20	10	0.130

ACCESSORIES

Order code	Description	Qty per pkg n°	Weight [kg]
FBX 00	Coupling clip for 10x38, 14x51 and 22x58 sizes	100	0.050
FBX 01	Coupling pin for 10x38 size	100	0.130
FBX 02	Coupling pin for 14x51 and 22x58 sizes	100	0.150

N.B. Two clips FBX 00 and one pin FBX 01 are needed to couple two fuse holder FB01... types.
Three clips FBX 00 and one pin FBX 02 are needed to couple two fuse holder FB02... and FB03... types.


WIRING DIAGRAMS




Loyato
electric




2011




Switch disconnectors
16 to 1600A




Modular digital multimeters



Flush-mount digital multimeters
and power analyzers



Energy meters



Automatic transfer switch
controllers



Switching power supplies


























100% electricity

Industrial Switch

Industrial DIN

Industrial Logic

-  Motor protection circuit breakers
-  Switch disconnectors
-  Contactors
-  Motor protection relays
-  Electromechanical starters
-  Control and signalling units
-  Limit, micro and foot switches
-  Rotary cam switches
-  Modular contactors
-  Time relays
-  Protection relays
-  Level control relays
-  Earth leakage relays
-  Fuse holders
-  Metering Instruments and current transformers
-  Soft starters
-  AC motor drives
-  Automatic power factor controllers
-  Automatic battery chargers
-  Automatic transfer switch controllers
-  Programmable logic relays
-  Switching power supplies
-  Expansion modules and accessories

www.LovatoElectric.com

LOVATO ELECTRIC S.P.A.
CONTROL SOLUTIONS FOR INDUSTRY
VIA DON E. MAZZA, 12 - 24020 GORLE (BERGAMO) ITALY
Tel. +39 035 4282111 Fax +39 035 4282200
E-mail: info@LovatoElectric.com

Sales department: Tel. +39 035 4282354 - Fax +39 035 4282400

LOVATO Electric offices in the world

United Kingdom
LOVATO (UK) LTD
Tel. +44 8458 110023
www.Lovato.co.uk

Czech Republic
LOVATO S.R.O.
Tel. +420 382 265482
www.Lovato.cz

Germany
DELTEG LOVATO GmbH
Tel. +49 7237 1733
www.DeltecLovato.de


USA
LOVATO ELECTRIC INC
Tel. +1 757 545 4700
www.LovatoUsa.com

Spain
LOVATO ELECTRIC S.L.U.
Tel. +34 93 7812016
www.LovatoElectric.es

Canada
LOVATO ELECTRIC
CORPORATION
Tel. +1 450 681 9200
www.Lovato.ca

Poland
LOVATO ELECTRIC SP. Z O.O.
Tel. +48 71 7879010
www.LovatoElectric.pl

Mexico
LOVATO ELECTRIC
DE MEXICO, S.A. DE C.V.
Tel. +52 555 3415662
www.LovatoElectric.com.mx



Present in over 90 countries

The products described in this publication are subject to be revised or improved at any moment. Catalogue descriptions and details such as technical and operational data, drawings, diagrams and instructions, etc. do not have any contractual value. In addition, products should be installed and used by qualified personnel and in compliance with the regulations in force for electrical systems in order to avoid damages and safety hazards.

DEVICE UNDER TEST..... Fuse holder *FB01B types*
MANUFACTURER..... Lovato Electric S.p.A.
TYPE OF TEST..... Temperature rise test on FB01B fuse holders

DATE OF DEVICE RECEIPT..... 27/04/2011
START / END TESTING 29/04/2011 – 13/05/2011

SAMPLES STORING..... Eliminated / returned to customer Storage :

INDEX.....	1. PURPOSE OF TESTING.....	2
	2. TEST SAMPLES.....	2
	3. TEST METHOD.....	2
	4. TEST PROCEDURES.....	2
	5. TEST RESULTS	3
	6. TEST EQUIPMENT	5
	7. REMARKS & ANALYS.....	5
	8. ANNEX.....	6

ISSUE 16/05/2011
COMPILED STAFF LPR
APPROVED RESP. LPR

ВЯРНО С
ОРИГИНАЛА



The test results are related only to the exemplary tested and listed under the "test samples".

1. PURPOSE OF TESTING

Requested test (according to the customer specification):
Temperature rise at 690V – 32A on FB01B fuse holders

Test purpose:
"Verify the good function of FB01B fuse holders ."

Test target:
Pass the test.

2. TEST SAMPLES

- N. 1 FB01B1P fuse holder - 32A (10 x 38 mm), batch production number ...¹
- N. 1 FB01B2P fuse holder - 32A (10 x 38 mm), batch production number ...¹
- N. 1 FB01B3P fuse holder - 32A (10 X 38 mm), batch production number ...¹

3. TEST METHOD

IEC 60947-3 (2008-08) Ed. 3.0 + IEC 60947-1 Ed. 5.1 (2011-03)
Temperature rise (§ 8.3.3.1)

4. TEST PROCEDURES

Temperature rise..... Test instruction LPR 051-1, rev. 4, dated 11/10/2010.

ВАРНО С
ОРИГИНАЛА



¹ not available
¹ not available
¹ not available

The test results are related only to the exemplary tested and listed under the "test samples".

5. TEST RESULTS

5.1 TEMPERATURE RISE

5.1.1 WITH LEGRAND FUSE 32 A gG 400 V

Sample under test.....N. 1 FB01B1P - 32A
N. 1 FB01B2P - 32A
N. 1 FB01B3P - 32A

Test conditions

Ambient temperature.....21 °C
Relative humidity.....46 %
Installation.....in vertical way, on DIN RAIL 35mm

Data sheet fusible used:

- SupplierLegrand
- Codecod. 133 32

Test parameters

Wiring of the main circuit

- cables section / length.....6,0 mm² / 1,0 m
- screws tightening nominal torque2,0 + 2,5 N.m
- screws applied tightening torque2,0 N.m

Supply of the main circuit

- rated current.....I_{th} = 25 - 32 A
- test current.....I = 32 A
- supply frequency.....50 Hz

Test results

See next page.

ВЯРНО С
ОРИГИНАЛА



The test results are related only to the exemplary tested and listed under the "test samples".

Temperature rise main circuit

	[K]			Standard limit EN60947-1 tab. 2
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Terminal L1	43	54	57	65
Terminal T1	39	51	52	65
Terminal L2	-	55	61	65
Terminal T2	-	49	58	65
Terminal L3	-	-	57	65
Terminal T3	-	-	50	65
Note.....	Silver plated-brass terminal			

Temperature rise for accessible parts

	[K]			Standard limit EN60947-1 tab. 3
	One pole fuse holder FB01B1P	2 pole fuse holder FB01B2P	3 pole fuse holder FB01B3P	
Line side	14	24	29	40
Load side	10	19	21	40
Left side	24	30	32	40
Right side	22	30	31	40
On front	18	24	29	40
Lower	9	16	17	40

ВЯРНО С
ОРИГИНАЛА



The test results are related only to the exemplary tested and listed under the "test samples".

6. TEST EQUIPMENT AND INSTRUMENTS

6.1. TEST EQUIPMENT

Description	Used for	Full scale	Code
Current supply station	Power supply main circuit	20V – 50A	LPRA 065

6.2. MEASURING INSTRUMENTS

Description	Used to measure	Full scale	Code	Calibration expiration date
Thermohygrometer	Ambient temperature	-5 + 50 °C	LPR 165	27/10/2011
Thermohygrometer	Relative humidity	10 + 90%	LPR 165	27/10/2011
Termometric instrument	Temperature rise	-30 + +200 °C	LPR 201	10/01/2012
Termocouple T type	Temperature rise	-30 + +200 °C	L PR 201	10/01/2012
Termocouple T type	Temperature rise	-30 + +200 °C	L PR 201.13	10/01/2012
Current transformer	Main circuit current	1.004/50 A	LPR 155	11/05/2014
Digital multimeter	Main circuit current	10 A	LPR 55	11/05/2012
Digital multimeter	Drop voltage	mV - Autom.	LPR 125	11/05/2012
Dynamometric screw driver	Main terminal screw tightening	6,0 Nm	LPR 231	07/01/2012

7. REMARKS & ANALYS

Temperature rise test 690V – 32A: test passed


ВЪРНО С
ОРИГИНАЛА




The test results are related only to the exemplary tested and listed under the "test samples".

8. ANNEX

Picture 1: Temperature rise – test setup



Picture 1a: Temperature rise – test setup



ВАЖНО С
ОРИГИНАЛА



The test results are related only to the exemplary tested and listed under the "test samples".

Picture 2: Catalogue Legrand fuses



Fusibili cilindrici



Informazioni tecniche, curve e quote (p. 122)


Tipo "gG"				Tipo "aM"			
B.C.R. (Alta Capacità di Rottura) Rispondenti alle norme CEI 32-1, CEI 32-4, EN 60269-1, EN 60269-3				Rispondenti alla norma IEC EN 60269-1 Approvazione Bureau Veritas			
Intensità (A)	Tensione (V~)	Potenza (KA)		Intensità (A)	Tensione (V~)	Potenza (KA)	
6,5 x 23 mm				6,5 x 31,5 mm			
10	250	6	0113 02	1	400	20	0120 01
10			0113 04	2			0120 02
10			0113 06	4			0120 04
100			0113 10	6			0120 06
10			0123 01	8			0123 08
10			0123 02	10			0120 10
10			0123 04	12			
10			0123 06	16			
10			0123 08	20			
10			0123 10	25			
10			0123 12				
10			0123 16				
100			0123 20				
10,3 x 38 mm				10,3 x 38 mm			
10	400	20	0133 01	0,25			0130 02
10			0133 02	0,60			0130 05
10			0133 04	1			0130 01
10			0133 06	2			0130 02
10			0133 08	4			0130 04
10			0133 10	6	500	100	0130 06
10			0133 12	8			0130 08
10			0133 14	10			0130 10
10			0133 16	12			0130 12
10			0133 18	16			0130 16
10			0133 20	20			0130 18
10			0133 25	25			0130 20
10				25			0130 25
14 x 51 mm				14 x 51 mm			
10			0143 02	2			0140 02
10			0143 04	4			0140 04
10			0143 06	6			0140 06
10			0143 08	8			0140 08
10			0143 10	10			0140 10
10			0143 12	12			0140 12
10			0143 14	16	500	100	0140 14
10			0143 16	16			0140 16
10			0143 18	20			0140 18
10			0143 20	25			0140 20
10			0143 25	32			0140 25
10			0143 32	40			0140 32
10			0143 40	40			0140 40
10			0143 50	50			0140 45
10				60			0140 50
22 x 58 mm				22 x 58 mm			
10			0153 10	16			0150 16
10			0153 16	20			0150 20
10			0153 20	25			0150 25
10			0153 25	32			0150 32
10			0153 32	40			0150 40
10			0153 40	40			0150 50
10			0153 50	50			0150 60
10			0153 63	63			0150 63
10			0153 80	80			0150 80
10			0153 96	100			0150 96
10			0153 97	125			0150 97
Neutri				Neutri			
10			0123 00	8,5 x 31,5			
10			0143 00	10,3 x 38			
10			0153 00	14 x 51			
10				22 x 58			

(1) Tipo g

(1) colore non normalizzato

ВАРНО С
ОРУЖИНАТА

The test results are related only to the exemplary tested and listed under the "test samples".



[Handwritten signature]



TESTING AUTHORIZATION

ACAIE (Associazione per la Certificazione delle Apparecchiature Elettriche), Member of **LOVAG** (Low Voltage Agreement Group)

authorizes the Laboratory

LOVATO ELECTRIC S.p.A. Via Don Mazza 12 Gorle (BG)

Laboratory codification number: *IL 01*

to carry out the tests listed in the following, for the purpose to certify the products as stated in the Certificate n° 070B and its enclosure, issued to ACAIE by ACCREDIA.

List of the authorized tests on the low - voltage components:

*Verification of dielectric withstand
Verification of temperature – rise
Operation and operating limits
Making and breaking capacities
Overload performance
Mechanical properties of terminals*

ACAIE will witness the tests according to its Quality Procedure PA 5.2.1 "Test supervision".

The renewal of the authorization is subjected to annual audit.

First issue date: 2013-05-14

Current issue date: 2014-12-01

*ACAIE General Secretary
Mr. Virginio Scarioni*

Virginio Scarioni



PRD N°070 B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

ACAIE

ASSOCIAZIONE PER LA CERTIFICAZIONE DELLE APPARECCHIATURE ELETTRICHE
Via Tito Livio 5 - 24123 Bergamo, BG - ITALY
Tel: +39 035 4175244 Fax: +39 035 4534662
e-mail: acaie@acaecert.it www.acaecert.it
C.F. 03260610104 P.IVA IT 02911610166
R.E.A. N. 333322 C.C.I.A. BG



СЕРТИФИКАТ по ISO 9001:2008
 BG120619Q /16.10.2015год.
 издаден от Bureau Veritas Certification

Декларация за характеристиките на строителен продукт

№ 5-11

1. Идентификационен код на продукта:

Обикновен бетон с рецептурен състав ХБ -27а

2. Национални изисквания /заповед на министъра на регионалното развитие и благоустройство, национален нормативен акт / техническа спецификация /национален стандарт,българско техническо одобрение / приложим за строителния продукт:

БДС EN 206-1:2002, БДС EN 206-1:2002/НА:2008 /БДС EN206-1:2002/А1:2006,БДС EN206-1:2002/А2:2006

3.Предвидена употреба или употреби на строителния продукт в съответствие с националните изисквания, както е предвидено от производителя

Обикновен бетон за влагане в бетонни и стоманобетонни конструкции и изделия

4.Име,регистрирано търговско наименование или регистрирана търговска марка ,адрес за контакт на производителя и мястото на производство :

„ХИДРОБЕТОН“ ООД ,гр. София – кв. Казичене, ул. „Л.Каравелов“ №16

Място на производство: „ХИДРОБЕТОН“- БВ „ИЛИЯНЦИ“

5.Име и адрес за контакт на упълномощения представител /когато е приложимо /: Не

6.Наименование на лицето за оценяване на съответствието с националните изисквания /когато е приложимо/:

„НСИ“ ЕООД ,бул. „Н.Петков“86,с рег.№07 от регистъра на МРРБ

Сертификат №07-НСИСОССП – 09.80Б/28.03.2013год.

/Сертификат за съответствие ,протоколи от изпитвания/в зависимост от приложимото/

7. Декларираните показатели на характеристиките на строителния продукт:

Характеристика	Показатели	Метод за изпитване/изчисление /определяне
Клас по якост на натиск	C 32/40	БДС EN12390-3:2009
Клас по консистенция	S3	БДС EN12350-2:2009
Клас по водонепропускливост	NPD	БДС EN206-1 /НА:2008
Клас по мразоустойчивост	NPD	БДС EN206-1 /НА:2008
Максимален размер на добавъчния материал	D max 16mm	БДС EN 933-1 Д-я на производителя на доб. м-л.
Клас по съдържание на хлориди	Cl 0,1	БДС EN 206-1 т 5.2.7
Класове по въздействие на околната среда	XC4	БДС EN 206-ТаблицаF1

8. Характеристики на строителния продукт ,посочен в т.1,имат показатели , съответстващи на декларираните съгласно т.7.

Тази декларация за характеристиките на строителния продукт се издава изцяло на отговорността на производителя съгласно т.4 и се отнася за бетон , произведен от 19.11.2015г.

За фирма : „ЕЛЕКТРОГЕЦ“ ООД

Строеж: ИЛИЯНЦИ

Неразделна част от декларацията е приложената справка декларация от записите на действащата в фирмата система за производствен контрол.

Декларирам ,че ми е известна отговорността, която нося съгласно чл. 313 от НК

Подписано за и от името на производителя:

Управител:
 Росен Николов
 Бетон

ВЯРНО
 АУТИНТИЧНО

ХИДРОБЕТОН
 ООД
 * Казичене *

18. 01.2016г.
 гр. София

СПРАВКА – ИЗВЛЕЧЕНИЕ

От Записите на Системата за производствен контрол
на БЦ "ИЛИЯНЦИ "

От произведените през месец Ноември 2015год. бетонни смеси от дата
19.11.2015г. на Фирма „ЕЛЕКТРОГЕЦ“ ООД са доставени следните количества бетонна
смес, за които вероятният клас на бетона се определя от посочените резултати въз основа на
произведените планови изпитвания за окачествяването им:


Наименование на продукта	Количе ство / m ³ /	Технически характеристики			Забележки
		Rcp. / МРа /	Rmin / МРа /	Други	
Бетонна смес					
C32/40	3,00	49,3	48,4	-	-

Посочените данни са извадка на заявените - експедирани бетонни смеси за месец
11/2015год. и резултатите от изпитването на контролните пробни тела, в
акредитирана лаборатория на НИСИ- ЕООД
с протокол № 1060-1-623 /28.12.2015год.

София
18.01.2016г.

Управител :
/ Р. Николов /

ВЯРНО Е
ОРИГИНАЛА



○

○